RECEIVED -FPSC

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

11 OCT -6 PM 2:41

In re: Application for increase in DOCKET NO. 100330-WS	COMMISSION
water/wastewater rates in Alachua, Brevard,	CLERK
DeSoto, Hardee, Highlands, Lake, Lee, DATED: October 6, 2011	
Marion, Orange, Palm Beach, Pasco, Polk,	
Putnam, Seminole, Sumter, Volusia, and	
Washington Counties by Aqua Utilities	
Florida, Inc.	

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing Direct Testimony of

Gary P. Miller has been served by U.S. Mail this 6th day of October, 2011, to the following:


D. Bruce May / Gigi Rollini Holland & Knight LLP Post Office Drawer 810 Tallahassee, FL 32302-0810

Aqua Utilities Florida Inc. Post Office Box 2480 Lady Lake, FL 32158-2480

Kelly Sullivan 570 Osprey Lakes Circle Chuluota, FL 32667-6652 Kimberly A. Joyce, Aqua America Inc. 762 W. Lancaster Avenue Bryn Mawr, PA 19010

Kenneth M. Curtin Adams and Reese LLP 150 Second Avenue N. Suite 1700 St. Petersburg, FL 33701

Office of Public Counsel J. R. Kelly/ Patricia Christensen c/o The Florida Legislature 111 W. Madison Street, Room 812 Tallahassee, Florida 32399-1400



DOCUMENT NUMBER-DATE 07298 OCT-6 = FPSC-COMMISSION CLERK CERTIFICATE OF SERVICE DOCKET NO. 100330-WS PAGE 2

Cecilia Bradley / Pamela Jo Bondi Office of the Attorney General The Capitol PL01 Tallahassee, FL 32399-1050 Pasco County Board of County Commissioner c/o Joseph D. Richards Pasco County Attorney's Office 87321 Citizens Drive, Suite 340 New Port Richey, FL 34654

RALPH R.JAEGER SENIOR ATTORNEY

FLORIDA PUBLIC SERVICE COMMISSION Gerald L. Gunter Building 2540 Shumard Oak Boulevard Tallahassee, Florida 32399-0850 Telephone: (850) 413-6199 **DOCKET NO. 100330-WS -** Application for increase in water/wastewater rates in Alachua, Brevard, DeSoto, Hardee, Highlands, Lake, Lee, Marion, Orange, Palm Beach, Pasco, Polk, Putnam, Seminole, Sumter, Volusia, and Washington Counties by Aqua Utilities Florida, Inc.

WITNESS: Direct Testimony of Gary P. Miller Appearing on Behalf of the Staff of the Florida Public Service Commission.

DATE FILED: October 6, 2011

DOCUMENT NUMPER-DATE 07298 OCT-6 = FPSC-COMMISSION CLERK

	1]	DIRECT TESTIMONY OF GARY P. MILLER
	2	Q.	Please state your name and business address.
	3	A.	Gary P. Miller, Florida Department of Environmental Protection (FDEP), 3319
	4		Maguire Blvd., Suite 232, Orlando, Florida 32803.
	5	Q.	Please provide a brief description of your educational background and experience.
	6	A.	I have a B.S. Degree in Biology. For about 5 years I worked at the Osceola County
	7		Health Department in the Environmental Health Section, and I have worked
	8		approximately 26 years at the FDEP in the Wastewater and Drinking Water Sections.
	9	Q.	What are your general responsibilities at the Department of Environmental Protection?
	10	A.	I manage the Wastewater Compliance/Enforcement Section that includes reviewing all
	11		enforcement documents (warning letters, consent orders, notice of violations etc.),
	12		noncompliance letters of all Type I and II domestic wastewater facilities & conducting
	13		enforcement and compliance meetings.
	14	Q.	Are you familiar with the AUF wastewater systems in Lake, Seminole, and Volusia
	15		Counties, particularly the wastewater treatment systems in Lake County, including
	16		Fairways at Mt. Plymouth, Holiday Haven, Kings Cove, Morningview, Summit Chase,
	17		Valencia Terrace, and Venetian Village, the wastewater treatment systems in Seminole
	18		County, including Chuluota, and Florida Commerce Park, and the Jungle Den
	19		wastewater treatment system in Volusia County?
1	20	A.	Yes
	21	Q.	Are these systems in compliance with all applicable construction and operating
1	22		permits?
	23	A.	The following systems are not in compliance with their permits:
)	24		Chuluota – Based on the Discharge Monitoring Reports (DMRs), the annual average
	25		daily flow to the effluent sprayfields (R-001) exceeded the permit limit of 0.10 million

1		gallons per day (MGD). The flow exceedance was to be resolved by implementing
2		public access reuse by December 31, 2010, in accordance with Part VI, Schedules, of
3		the wastewater permit. As of September 16, 2011, public access reuse has not been
4		implemented.
5		Jungle Den – The Department's inspection on October 15, 2010, indicated that the
6		physical plant was very rusty, the minimum pH result reported on the DMR for June
7		2010 was less than the minimum of 6.0 S.U., the percolation ponds had a freeboard of
8		less than one foot, overflow pump to the sprayfield was leaking and a spray head was
9		missing in the sprayfield. These deficiencies were addressed in a noncompliance letter
10		dated November 5, 2010. See Exhibit GM-1. The Department has no records
11		indicating a response was received regarding these deficiencies.
12	Q,	Have any of these AUF systems been the subject of any FDEP compliance
13		enforcement action within the past three years?
14	А.	The Fairways at Mt. Plymouth system is the only facility that has been under
15		enforcement within the past three years. The system's previous permit expired on June
16		14, 2010 and they operated without a permit until September 8, 2010. The
17		enforcement action was resolved via a Consent Order (CO). The CO requirements
18		have been completed and the case has been closed.
19	Q.	Other than any violations discussed above, is AUF in compliance with all DEP
20	:	requirements for their wastewater systems in Lake, Seminole & Volusia Counties?
21	A.	Yes
22	Q.	Is the overall operation and maintenance of these wastewater treatment plants and
23		collection facilities satisfactory?
24	A.	Yes
25	Q.	Do you have anything further to add?

1 A	No, I do not.
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21 22	
22	
23	
25	
20	

- 3 -

Exhibit GM-1 Page 1 of 2

OCD-C-WW-10-0777



Florida Department of Environmental Protection

> Central District 3319 Maguire Boulevard, Suite 232 Orlando, Florida 32803-3767

Governor

Jeff Kottkamp Lt. Governor

Mimi A. Drew Secretary

SENT VIA E-MAIL TO: imlihvarcik@aguaamerica.com

November 5, 2010

AQUA UTILITIES FLORIDA INC 510 HWY 466 SUITE 204 LADY LAKE FL 32159

ATTENTION JOHN M LIHVARCIK CHIEF OPERATING OFFICER

> Volusia County - DW Jungle Den WWTF Wastewater Facility - Permit No. FLA011261 Noncompliance Letter

Dear Mr. Lihvarcik:

On October 15, 2010, Department personnel conducted a routine inspection of the abovereferenced facility. A copy of the inspection report is attached for your review. Please note the items listed below which need to be addressed:

- 1. A copy of the current laboratory certification was not on-site.
- 2. On many occasions various values were reported incorrectly on Part A and B of the Discharge Monitoring Reports (DMRs) for November 2009 through June 2010. Please see the inspection report for details. It is important to report all data carefully and accurately as specified on the DMRs. Please see the inspection report for details.
- 3. Solids were present in the Parshall flume and the effluent flow meter.
- 4. The physical plant was very rusty. Please see the inspection report for details
- 5. The minimum pH result reported on the DMR for June 2010 was less than the minimum of 6.0 SU as required.
- 6. The percolation ponds had a freeboard of less than one (1) foot. There must be at least one (1) foot of percolation pond freeboard.
- 7. The Overflow pump to the sprayfield was leaking.
- 8. A spray head was missing in the sprayfield.

The Department requests a written response addressing the items listed above within 14 days from the date of this letter. Your response should include an explanation of any corrective actions that have either been taken or that you plan to take. Please note that this letter and report, being part of the Department's investigation, is preliminary to agency action in

"More Protection, Less Process" <u>www.dep.state.fl.us</u> Jungle Den WWTF OCD-C-WW-10-0777 Page 2

accordance with Section 120.57(5), Florida Statutes. Please direct your response and any questions to Debra Knight at (407) 893-3313, or via e-mail: <u>debra.knight@dep.state.fl.us</u>.

Sincerely,

David Smithele

David Smicherko Supervisor Wastewater Compliance/Enforcement

DS/dlk/ar

Enclosure: Inspection Report

cc: Volusia County Environmental Management, <u>dabrahamson@co.volusia.fl.us</u> Aqua Utilities, <u>PRWilliams@aquaamerica.com</u>