



RECEIVED-FPSC
11 OCT 20 AM 10:22
COMMISSION
CLERK

John T. Butler
Managing Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5639
(561) 691-7135 (Facsimile)
E-mail: john.butler@fpl.com

October 20, 2011

Ms. Ann Cole
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850


Re: Docket No. 110001-EI

Dear Ms. Cole:

As requested by the Commission Staff, Florida Power & Light Company hereby files the original and ten (10) copies of the GPIF Actual Unit Performance Data Schedules covering the month of September 2011. These schedules are being filed at the same time but separately from its monthly filing of the A Schedules.

If there are any questions regarding this transmittal, please contact me at 561-304-5639.

- COM _____
- APA 1
- ECR 2
- GCL 2
- RAD 1
- SRC _____
- ADM _____
- OPC _____
- CLK _____

Sincerely,

John T. Butler

Copy to: All parties of record

03 0 00 00 100 11
DOCUMENT NUMBER-DATE
07678 OCT 20 =
FPSC-COMMISSION CLERK

CERTIFICATE OF SERVICE
Docket No. 110001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished by overnight delivery (*) or United States mail this 20th day of October, 2011, to the following:

Lisa Bennett, Esq.*
Jennifer Crawford, Esq.
Division of Legal Services
Florida Public Service Commission
2540 Shumard Oak Blvd
Tallahassee, Florida 32399-0850
lbennett@psc.state.fl.us
jcrawford@psc.state.fl.us

J. R. Kelly, Esq.
Patricia Christensen, Esq.
Charles Rehwinkel, Esq.
Office of Public Counsel
c/o The Florida Legislature
111 West Madison Street, Room 812
Tallahassee, Florida 32399
Kelly.jr@leg.state.fl.us
Christensen.patty@leg.state.fl.us
rehwinkel.charles@leg.state.fl.us

James D. Beasley, Esq
J. Jeffrey Wahlen, Esq.
Ausley & McMullen
Attorneys for Tampa Electric
P.O. Box 391
Tallahassee, Florida 32302
jbeasley@ausley.com
jwahlen@ausley.com

John T. Burnett, Esq./Dianne M. Triplett, Esq.
Progress Energy Service Company, LLC
P.O. Box 14042
St. Petersburg, Florida 33733-4042
john.burnett@pgnmail.com
dianne.triplett@pgnmail.com

John W. McWhirter, Jr., Esq
McWhirter & Davidson, P.A.
Attorneys for FIPUG
P.O. Box 3350
Tampa, Florida 33602
jmcwhirter@mac-law.com

Beth Keating, Esq.
Gunster Firm
Attorneys for FPUC
215 So. Monroe St., Suite 618
Tallahassee, Florida 32301-1804
bkeating@gunster.com

Jeffrey A. Stone, Esq.
Russell A. Badders, Esq.
Beggs & Lane
Attorneys for Gulf Power
501 Commendencia Street
Pensacola, FL 32502
jas@beggslane.com
rab@beggslane.com

James W. Brew, Esq / F. Alvin Taylor, Esq.
Attorney for White Springs
Brickfield, Burchette, Ritts & Stone, P.C
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 2007-5201
jbrew@bbrslaw.com
ataylor@bbrslaw.com

Robert Scheffel Wright, Esq.
Gardner, Bist, Wiener, et al., P.A.
Attorneys for Florida Retail Federation and
City of Marianna
1300 Thomaswood Drive
Tallahassee, FL 32308
schef@gbwlegal.com


Jon C. Moyle, Esq. and Vicki Kaufman, Esq.
Keefe, Anchors Gordon & Moyle, P.A.
118 N. Gadsden St.
Tallahassee, FL 32301
Co-Counsel for FIPUG
vkaufman@kagmlaw.com
jmoyle@kagmlaw.com

Patrick K. Wiggins
AFFIRM
Grossman, Furlow & Bayó, L.L.C.
2022-2 Raymond Diehl Road
Tallahassee, FL 32308
p.wiggins@gfblawfirm.com

Michael Barrett, Esq.
Division of Legal Services
Florida Public Service Commission
2540 Shumard Oak Blvd
Tallahassee, Florida 32399-0850
mbarrett@psc.state.fl.us

Karen S. White, Esq
Staff Attorney
AFLOA/JACL-ULT/FLOA/JACL-ULT
139 Barnes Drive, Suite 1
Tyndall AFB, FL 32403-5317
Attorney for the Federal Executive Agencies
Karen.White@tyndall.af.mil

By:



John T. Butler
Fla. Bar No. 283479

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: FORT MYERS 02										PFM 02		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	95.6	86.8	95.7	58.4	42.2	45	92.1	96.6	99.5	0	0	0	79.1
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	438.4	712.67	525.17	463.37	384.95	631.75	744	720	0	0	0	5354.3
4.	RSH	0	233.6	30.33	194.83	290.63	336.05	112.25	0	0	0	0	0	1196.7
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	698.07	744	626	0	0	0	0	0	0	2066.07
10.	LR PP (MW)	0	0	0	502.72	762.27	735	0	0	0	0	0	0	666.56
11.	PFOH	4.83	263.45	21.32	21.73	31.27	30.95	46.7	20.75	0	0	0	0	441
12.	LR PF (MW)	221.84	409.7	221.59	136.67	142.65	321.2	406.18	221.84	0	0	0	0	350.74
13.	PMOH	190.62	38.65	169.65	166.03	0	129.52	184.67	122.6	21.83	0	0	0	1022.57
14.	LR PM (MW)	221.84	251.68	221.84	276.58	0	438.27	322.45	233	221.84	0	0	0	278.72
15.	NSC	1330	1330	1330	1330	1330	1330	1330	1330	1330	0	0	0	1330
16.	OPER BTU (MBTU)	5165040	3142505	5364734	3025766	1713630	1578734	4620814	6997165	6220332	0	0	0	36818720
17.	NET GEN	700504	421002	731719	278056	152806	143125	628997	829082	863807	0	0	0	4749098
18.	ANOHR (BTU/KWH)	7373	7464	7318	10882	11214	11030	7346	7234	7201	0	0	0	7753
19.	NOF (%)	70.8	72.2	77.2	39.8	25.3	28	74.9	83.8	90.2	0	0	0	66.7
20.	NPC (MW)	1570	1570	1570	1432	1432	1432	1432	1432	1432	0	0	0	1478

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)

A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: SCHERER 04										PSG 04		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	93	97.7	99.7	92.1	99.8	56.6	61.7	100	99.6	0	0	0	88.9
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	729	672	742.67	663.35	742.3	408.03	458.72	744	718.78	0	0	0	5878.85
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	15	0	0.33	56.65	1.7	311.97	285.28	0	1.22	0	0	0	672.15
6.	POH	0	0	0	0	0	311.97	241.47	0	0	0	0	0	553.43
7.	FOH	15	0	0.33	0	1.7	0	0	0	1.22	0	0	0	18.25
8.	MOH	0	0	0	56.65	0	0	43.82	0	0	0	0	0	100.47
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	59.67	28.1	3.33	0	0	1.05	0	0	1.48	0	0	0	93.63
12.	LR PF (MW)	551.99	492.83	531.53	0	0	411	0	0	861.14	0	0	0	536.81
13.	PMOH	0	0	0	0	0	0	0	0	2.97	0	0	0	2.97
14.	LR PM (MW)	0	0	0	0	0	0	0	0	30.97	0	0	0	30.97
15.	NSC	881	881	881	881	881	881	881	881	881	0	0	0	881
16.	OPER BTU (MBTU)	5571539	5201730	5896928	5320055	5968488	3302036	3582983	6123906	4998803	0	0	0	45966467
17.	NET GEN	549546	523979	583098	536347	595116	327202	340560	575283	488127	0	0	0	4519257
18.	ANOHR (BTU/KWH)	10138	9927	10113	9919	10029	10092	10521	10645	10241	0	0	0	10171
19.	NOF (%)	85.6	88.5	89.1	91.8	91	91	84.3	87.8	77.1	0	0	0	87.3
20.	NPC (MW)	882	882	882	869	869	869	869	869	869	0	0	0	873

21. ANOHR EQUATION

$$\text{ANOHR} = A + B \text{ (N.O.F.)}$$

$$A = 0 \quad B = 0$$

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: ST LUCIE 01										PSL 01		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	100	98.2	96.4	99.1	98.7	85.8	100	0	0	0	97.5
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	672	743	720	744	720	744	647.72	720	0	0	0	6454.72
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	96.28	0	0	0	0	96.28
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	96.28	0	0	0	0	96.28
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	133.65	0	0	0	0	0	0	0	0	133.65
10.	LR PP (MW)	0	0	0	66.36	0	0	0	0	0	0	0	0	66.36
11.	PFOH	0	0	0	27.87	323.67	0	97.1	32.4	0	0	0	0	481.03
12.	LR PF (MW)	0	0	0	76.73	62.62	0	82	275.34	0	0	0	0	81.68
13.	PMOH	0	0	0	0	25.53	71.17	0	0	0	0	0	0	96.7
14.	LR PM (MW)	0	0	0	0	76.1	76.09	0	0	0	0	0	0	76.09
15.	NSC	839	839	839	839	839	839	839	839	839	0	0	0	839
16.	OPER BTU (MBTU)	6848471	6186797	6841164	6504342	6617776	6563812	6754366	5867372	6625472	0	0	0	58809572
17.	NET GEN	641983	579372	639624	606465	607316	605252	623297	539069	607162	0	0	0	5448540
18.	ANOHR (BTU/KWH)	10668	10678	10696	10743	10897	10845	10837	10884	10912	0	0	0	10794
19.	NOF (%)	102.8	102.8	102.6	100.2	97.3	100.2	99.9	99.2	100.5	0	0	0	100.6
20.	NPC (MW)	839	839	839	839	839	839	839	839	839	0	0	0	839

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)
 A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDEED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: ST LUCIE 02										PSL 02		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	4.1	0	0	0	61.4	95.4	100	91.4	100	0	0	0	50.7
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	41.03	0	0	0	512	692.32	744	744	720	0	0	0	3453.35
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	702.97	672	743	720	232	27.68	0	0	0	0	0	0	3097.65
6.	POH	702.97	672	743	384.63	0	0	0	0	0	0	0	0	2502.6
7.	FOH	0	0	0	335.37	232	27.68	0	0	0	0	0	0	595.05
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	41.03	0	0	0	66.77	0	0	0	0	0	0	0	107.8
10.	LR PP (MW)	207.97	0	0	0	270.83	0	0	0	0	0	0	0	246.91
11.	PFOH	0	0	0	0	95.38	14.15	0	77.87	0	0	0	0	187.4
12.	LR PF (MW)	0	0	0	0	294.95	338.56	0	243.57	0	0	0	0	276.89
13.	PMOH	0	0	0	0	0	0	0	91.77	0	0	0	0	91.77
14.	LR PM (MW)	0	0	0	0	0	0	0	378.69	0	0	0	0	378.69
15.	NSC	839	839	839	839	839	839	839	839	839	0	0	0	839
16.	OPER BTU (MBTU)	284680	0	0	0	4204961	6314540	6843760	6257281	6626446	0	0	0	30531668
17.	NET GEN	25951	-43	0	0	396986	606476	662415	594745	634144	0	0	0	2920674
18.	ANOHR (BTU/KWH)	10970	0	0	0	10592	10412	10332	10521	10449	0	0	0	10454
19.	NOF (%)	76.4	0	0	0	92.4	104.4	106.1	95.3	105	0	0	0	100.8
20.	NPC (MW)	839	839	839	731	731	731	731	731	731	0	0	0	767

21. ANOHR EQUATION

$$\text{ANOHR} = A + B (\text{N.O.F.})$$

$$A = 0 \quad B = 0$$

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: TURKEY POINT 03										PTN 03		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	72.9	100	100	100	100	100	100	0	0	0	96.9
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	672	551.95	720	744	720	744	744	720	0	0	0	6369.95
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	
5.	UH	0	0	191.05	0	0	0	0	0	0	0	0	0	191.05
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	
7.	FOH	0	0	191.05	0	0	0	0	0	0	0	0	0	191.05
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	
11.	PFOH	18.88	0	24.02	0	0	0	0	0	0	0	0	0	42.9
12.	LR PF (MW)	2	0	300.14	0	0	0	0	0	0	0	0	0	168.93
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	
15.	NSC	693	693	693	693	693	693	693	693	693	0	0	0	693
16.	OPER BTU (MBTU)	5825894	5288087	4241357	5644938	5833053	5648730	5833920	5832959	5637836	0	0	0	49763775
17.	NET GEN	540295	484394	389638	514935	529169	508953	520958	520478	503626	0	0	0	4512444
18.	ANOHR (BTU/KWH)	10783	10876	10885	10962	11023	11093	11198	11207	11194	0	0	0	11028
19.	NOF (%)	104.8	104	101.9	103.2	102.6	102	101	100.9	100.9	0	0	0	102.4
20.	NPC (MW)	693	693	693	693	693	693	693	693	693	0	0	0	693

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)
 A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: TURKEY POINT 04										PTN 04		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	62.9	0	43.9	100	100	100	100	0	0	0	78.4
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6561
3.	SH	744	672	479.02	0	366.27	720	744	744	720	0	0	0	6189.28
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	263.98	720	377.73	0	0	0	0	0	0	0	1361.72
6.	POH	0	0	263.98	720	336.02	0	0	0	0	0	0	0	1320
7.	FOH	0	0	0	0	41.72	0	0	0	0	0	0	0	41.72
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	23.98	0	97.25	0	0	0	0	0	0	0	121.23
10.	LR PP (MW)	0	0	327.48	0	285	0	0	0	0	0	0	0	293.4
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15.	NSC	693	693	693	693	693	693	693	693	693	0	0	0	693
16.	OPER BTU (MBTU)	5833769	5266692	3668139	0	2578692	5646295	5832093	5830962	5642659	0	0	0	40299301
17.	NET GEN	543311	485792	338163	0	230031	509875	521865	522299	506303	0	0	0	3657638
18.	ANOHR (BTU/KWH)	10737	10841	10847	0	11210	11074	11175	11164	11145	0	0	0	11018
19.	NOF (%)	105.4	104.3	101.9	0	90.6	102.2	101.2	101.3	101.5	0	0	0	101.7
20.	NPC (MW)	693	693	693	693	693	693	693	693	693	0	0	0	693

21. ANOHR EQUATION

$$\text{ANOHR} = A + B \text{ (N.O.F.)}$$

$$A = 0 \quad B = 0$$

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: TURKEY POINT #5 05										TP5 05		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	90.6	85.5	89.2	94.6	100	99.2	96.6	89.3	81.2	0	0	0	91.9
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	480.23	418.67	711.6	728.52	720	744	744	720	0	0	0	6011.02
4.	RSH	0	191.77	324.33	8.4	15.48	0	0	0	0	0	0	0	539.98
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	198.02	264	0	0	0	0	264	502.75	0	0	0	1226.77
10.	LR PP (MW)	0	519.99	316.44	0	0	0	0	261.25	261.25	0	0	0	314.47
11.	PFOH	0	0	0	5.25	0.1	5.87	0	24.37	39	0	0	0	74.58
12.	LR PF (MW)	0	0	0	463	261.25	261.25	0	72	251.96	0	0	0	208.76
13.	PMOH	280.92	0	0	148.2	0	17.57	101.27	48.43	0	0	0	0	596.38
14.	LR PM (MW)	261.25	0	0	261.25	0	261.25	261.25	261.25	0	0	0	0	261.25
15.	NSC	1045	1045	1045	1045	1045	1045	1045	1045	1045	0	0	0	1045
16.	OPER BTU (MBTU)	3524778	2466162	2278645	4442671	4412231	3881579	4237269	4023660	3578799	0	0	0	32845694
17.	NET GEN	487069	343650	313410	626052	622575	542180	594764	584638	499920	0	0	0	4594258
18.	ANOHR (BTU/KWH)	7237	7178	7270	7096	7087	7159	7124	7126	7159	0	0	0	7149
19.	NOF (%)	62.6	68.5	71.6	84.2	81.8	72.1	76.5	72.6	66.4	0	0	0	73.1
20.	NPC (MW)	1179	1179	1179	1148	1148	1148	1148	1148	1148	0	0	0	1158

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)
 A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: MANATEE UNIT 3 CC 03										PM3 03		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	98.4	73.4	98.1	74.1	18.4	100	100	92.2	65.6	0	0	0	80.1
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	672	743	720	269.23	720	744	729.4	688.83	0	0	0	6030.47
4.	RSH	0	0	0	0	0	0	0	10.03	31.17	0	0	0	41.2
5.	UH	0	0	0	0	474.77	0	0	4.57	0	0	0	0	479.33
6.	POH	0	0	0	0	474.77	0	0	0	0	0	0	0	474.77
7.	FOH	0	0	0	0	0	0	0	4.57	0	0	0	0	4.57
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	602.88	0	433.72	258.7	0	0	0	0	0	0	0	1295.3
10.	LR PP (MW)	0	260.25	0	448.15	526.13	0	0	0	0	0	0	0	376.27
11.	PFOH	32.03	1.32	3.8	0	6.42	0	0	122.43	563.6	0	0	0	729.6
12.	LR PF (MW)	260.25	260.25	260.25	0	202.38	0	0	453.36	457.38	0	0	0	444.42
13.	PMOH	16	111.92	53.95	0	0	0	0	0	0	0	0	0	181.87
14.	LR PM (MW)	260.25	260.25	260.25	0	0	0	0	0	0	0	0	0	260.25
15.	NSC	1041	1041	1041	1041	1041	1041	1041	1041	1041	0	0	0	1041
16.	OPER BTU (MBTU)	3680363	2998868	4164617	3559788	949742	4589931	4816644	4390022	2708148	0	0	0	31858123
17.	NET GEN	529200	435716	599815	511260	130626	657371	689675	598714	283863	0	0	0	4436239
18.	ANOHR (BTU/KWH)	6956	6883	6943	6963	7271	6982	6984	7332	9540	0	0	0	7181
19.	NOF (%)	68.3	62.3	77.5	68.2	46.6	87.7	89	78.9	39.6	0	0	0	70.7
20.	NPC (MW)	1187	1187	1187	1111	1111	1111	1111	1111	1111	0	0	0	1136

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)
 A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: MARTIN-UNIT 8 08										PM8 08		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	91.6	97.8	95.1	41.8	75.5	98.9	94.7	95.6	99	0	0	0	87.7
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	744	672	743	300.66	575.38	720	744	744	720	0	0	0	5963.03
4.	RSH	0	0	0	11.35	0	0	0	0	0	0	0	0	11.35
5.	UH	0	0	0	408	168.62	0	0	0	0	0	0	0	576.62
6.	POH	0	0	0	408	168.62	0	0	0	0	0	0	0	576.62
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	13.83	32.83	0	0	0	0	0	0	0	46.67
10.	LR PP (MW)	0	0	0	813.1	416.42	0	0	0	0	0	0	0	534
11.	PFOH	0.75	7.72	2.9	0	26.72	31.43	45.3	70.05	5.17	0	0	0	189.03
12.	LR PF (MW)	257.75	257.75	257.75	0	12	257.75	257.75	304.07	229.06	0	0	0	240.7
13.	PMOH	249.42	50.18	136.6	0	0	0	58.35	49.1	25.27	0	0	0	568.92
14.	LR PM (MW)	257.75	257.75	271.49	0	0	0	500.63	257.75	257.75	0	0	0	285.96
15.	NSC	1031	1031	1031	1031	1031	1031	1031	1031	1031	0	0	0	1031
16.	OPER BTU (MBTU)	3678928	3455707	3854156	1696770	3564512	4534296	4495256	4541794	4488889	0	0	0	34310308
17.	NET GEN	520660	488630	549208	241418	508372	641653	631722	638304	637113	0	0	0	4857080
18.	ANOHR (BTU/KWH)	7066	7072	7018	7028	7012	7067	7116	7115	7046	0	0	0	7064
19.	NOF (%)	67.9	70.5	71.7	77.9	85.7	86.4	82.4	83.2	85.8	0	0	0	79
20.	NPC (MW)	1180	1180	1180	1105	1105	1105	1105	1105	1105	0	0	0	1130

21. ANOHR EQUATION

$$\text{ANOHR} = A + B \text{ (N.O.F.)}$$

$$A = 0 \quad B = 0$$

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: SANFORD 4 & 5 CC 04											PSR 04	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	93.3	98.9	88.2	59.5	99.4	99.2	99.8	80.5	97.2	0	0	0	90.6
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	720.97	672	625.63	429.3	744	710.28	732.68	744	712.87	0	0	0	6091.73
4.	RSH	23.03	0	29.37	0.55	0	9.72	11.32	0	7.13	0	0	0	81.12
5.	UH	0	0	88	290.15	0	0	0	0	0	0	0	0	378.15
6.	POH	0	0	88	290.15	0	0	0	0	0	0	0	0	378.15
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0.63	0	0	0	0	0	0	0	0	0.63
10.	LR PP (MW)	0	0	0	413.39	0	0	0	0	0	0	0	0	413.39
11.	PFOH	40.52	7.58	0	4.68	3.63	5.55	4.33	21.9	10.15	0	0	0	98.35
12.	LR PF (MW)	253.52	221.25	0	221.25	212.79	197.29	218.35	221.11	309.43	0	0	0	241.82
13.	PMOH	154.2	22.2	0	0	15.63	17.45	0.6	558.15	65.35	0	0	0	833.58
14.	LR PM (MW)	221.25	221.25	0	0	221.25	221.25	221.25	221.25	221.25	0	0	0	221.25
15.	NSC	885	885	885	885	885	885	885	885	885	0	0	0	885
16.	OPER BTU (MBTU)	3264575	3322366	3189247	2569589	4177384	3598176	3857998	3252137	3678496	0	0	0	30909988
17.	NET GEN	432445	448087	425778	355695	576991	486921	524140	438957	497011	0	0	0	4188025
18.	ANOHR (BTU/KWH)	7549	7415	7490	7224	7240	7390	7361	7409	7401	0	0	0	7384
19.	NOF (%)	67.8	75.3	76.9	93.6	87.6	77.5	80.8	66.7	78.8	0	0	0	77.6
20.	NPC (MW)	1040	1040	1040	958	958	958	958	958	958	0	0	0	985

21. ANOHR EQUATION

ANOHR = A + B (N.O.F.)

A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2011 TO: Dec-2011

		PLANT / UNIT: SANFORD 4 & 5 CC 05										PSR 05		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAFF (%)	97.4	96.8	97	96	97.3	95.4	81.5	100	98.3	0	0	0	95.5
2.	PH	744	672	743	720	744	720	744	744	720	0	0	0	6551
3.	SH	642.52	655.38	728.3	720	744	715.7	725.92	741.08	720	0	0	0	6392.9
4.	RSH	101.48	18.62	14.7	0	0	4.3	18.08	2.92	0	0	0	0	158.1
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	7.97	2.37	19.12	77.98	7.07	11.07	5.73	0	0.43	0	0	0	131.73
12.	LR PF (MW)	220.75	220.75	220.75	220.13	220.75	220.75	220.75	0	220.75	0	0	0	220.38
13.	PMOH	68.72	84.85	68.98	36.45	74.53	74.1	521.43	0	47.95	0	0	0	977.02
14.	LR PM (MW)	220.75	220.75	220.75	220.75	220.75	365.63	230.32	0	220.75	0	0	0	236.84
15.	NSC	883	883	883	883	883	883	883	883	883	0	0	0	883
16.	OPER BTU (MBTU)	2743172	3162829	3538607	4008476	4002169	3437146	3120530	3889654	3708772	0	0	0	31611355
17.	NET GEN	368811	431160	475855	550357	547664	463188	420404	525755	502907	0	0	0	4286101
18.	ANOHR (BTU/KWH)	7438	7336	7436	7283	7308	7421	7423	7398	7375	0	0	0	7375
19.	NOF (%)	65	74.5	74	86.6	83.4	73.3	65.6	80.3	79.1	0	0	0	75.9
20.	NPC (MW)	1037	1037	1037	954	954	954	954	954	954	0	0	0	982
21.	ANOHR EQUATION													

ANOHR = A + B (N.O.F.)
A = 0 B = 0

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:
SUSPENDED:
EFFECTIVE: -
DOCKET NO.:
ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: FORT MYERS

02

PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/02/2011	FMO	19.8	141	2F CT Generator Breaker Repair
01/02/2011	PMO	19.8	71.15	Impact loss due to curtailment on 2F
01/02/2011	PMO	19.8	9.69	Impact loss due to curtailment on 2F
01/03/2011	FMO	87.4	141	2D REPAIR BOILER FEED PUMP
01/03/2011	PMO	87.4	9.69	Impact loss due to curtailment on 2D
01/03/2011	PMO	87.4	71.15	Impact loss due to curtailment on 2D
01/13/2011	FFO	4.8	141	2D CT 41AC-2 failed
01/13/2011	PFO	4.8	71.15	Impact loss due to curtailment on 2D
01/13/2011	PFO	4.8	9.69	Impact loss due to curtailment on 2D
01/20/2011	FMO	32.0	141	2C CT Offline waterwash
01/20/2011	PMO	32.0	9.69	Impact loss due to curtailment on 2C
01/20/2011	PMO	32.0	71.15	Impact loss due to curtailment on 2C
01/23/2011	FMO	50.9	141	2D CT 41AC-2 Outage
01/23/2011	PMO	50.9	9.69	Impact loss due to curtailment on 2D
01/23/2011	PMO	50.9	71.15	Impact loss due to curtailment on 2D
01/31/2011	FMO	33.6	141	2E CT OFF LINE WATER WASH
01/31/2011	PMO	33.6	9.69	Impact loss due to curtailment on 2E
01/31/2011	PMO	33.6	71.15	Impact loss due to curtailment on 2E
02/02/2011	FFO	0.4	58	ST1 EFOR: ST2 GSU failure caused trip
02/02/2011	FFO	242.0	426	ST2 EFOR: GSU failure
02/02/2011	FFO	0.4	141	2D CT EFOR: IP drum level trip
02/13/2011	FMO	5.7	426	ST2 Event MOF: Reset GSU Protection
02/14/2011	FFO	5.2	141	2D CT EFOR: #2 bearing area fan
02/14/2011	PFO	5.2	9.69	Impact loss due to curtailment on 2D

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011
 PLANT / UNIT: FORT MYERS 02 PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
02/14/2011	PFO	5.2	71.15	Impact loss due to curtailment on 2D
02/21/2011	FFO	14.3	141	2F CT/HRSG FSGJ-ACV-10 failure
02/21/2011	PFO	14.3	9.69	Impact loss due to curtailment on 2F
02/21/2011	PFO	14.3	71.15	Impact loss due to curtailment on 2F
02/25/2011	FFO	2.0	141	2E CT EFOR: TUBE AND SHELL HEATER RUNBACK
02/25/2011	PFO	2.0	71.15	Impact loss due to curtailment on 2E
02/25/2011	PFO	2.0	9.69	Impact loss due to curtailment on 2E
03/03/2011	FMO	25.0	141	2F CT PM-1 Gas valve
03/03/2011	PMO	25.0	71.15	Impact loss due to curtailment on 2F
03/03/2011	PMO	25.0	9.69	Impact loss due to curtailment on 2F
03/06/2011	FMO	24.3	141	2DCT Bearing blower/ HP Bypass
03/06/2011	PMO	24.3	71.15	Impact loss due to curtailment on 2D
03/06/2011	PMO	24.3	9.69	Impact loss due to curtailment on 2D
03/16/2011	FMO	48.3	141	2B CT/HRSG BSGG-ACV-3/ PM-1 Centerline maintenance ou
03/16/2011	PMO	48.3	71.15	Impact loss due to curtailment on 2B
03/16/2011	PMO	48.3	9.69	Impact loss due to curtailment on 2B
03/20/2011	FFO	0.4	58	Unit 1 loss of vacuum
03/25/2011	PFO	0.7	115	2A CT loss of shell & tube heater runback
03/25/2011	FFO	20.8	141	2E CT HP TO CRH Bypass Valve Failure
03/25/2011	PFO	20.8	71.15	Impact loss due to curtailment on 2E
03/25/2011	PFO	20.8	9.69	Impact loss due to curtailment on 2E
03/28/2011	FMO	47.7	141	2F BLANKING PLATE
03/28/2011	PMO	47.7	71.14	Impact loss due to curtailment on 2F
03/28/2011	PMO	47.7	9.69	Impact loss due to curtailment on 2F

(1) FFO - FULL FORCED OUTAGE
 PFO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: FORT MYERS 02

PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
03/30/2011	FMO	47.8	141	2B BLANKING PLATE
03/30/2011	PMO	47.8	9.69	Impact loss due to curtailment on 2B
03/30/2011	PMO	47.8	71.15	Impact loss due to curtailment on 2B
04/01/2011	FPO	2066.1	58	ST1 Site Outage
04/02/2011	FPO	2064.1	426	ST2 outage
04/02/2011	FMO	42.0	141	2ECT outage
04/02/2011	FMO	103.2	141	2DCT outage
04/02/2011	FMO	141.5	141	2ACT outage
04/04/2011	PFO	0.8	21	2E Gas Fired Heater runback
04/10/2011	FFO	3.7	141	2BCT Direct fired heater failure
04/19/2011	FFO	0.2	141	PFM 2B Runback
04/19/2011	FFO	3.4	141	2B CT EFOR Out of NOX Time
04/23/2011	FFO	12.3	141	2A CT EFOR due EX2000 issues
04/27/2011	FFO	1.5	141	2D CT Direct fired heater runback
04/28/2011	FPO	392.9	141	2ECT Outage
04/28/2011	FPO	425.7	141	2FCT outage
05/04/2011	PFO	0.3	111	2B CT direct fired heater flameout late RFC
05/07/2011	FFO	4.0	141	2D CT #2 LCI EFOR
05/07/2011	PFO	0.6	111	2B CT late for RFC (LCI issues)
05/08/2011	FFO	26.8	141	2A CT High Vibration (CT not on Turning Gear)
05/14/2011	FPO	905.9	141	2A CT Planned Outage (Hot Gas Path Inspection)
05/15/2011	FPO	290.2	141	2B CT Planned outage (Hot Gas Path Inspection)
05/18/2011	PFO	0.3	111	2E Field breaker failed
05/29/2011	FPO	49.0	141	2D CT Planned outage (Hot gas path inspection)

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011

PLANT / UNIT: FORT MYERS 02 PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
06/01/2011	FPO	288.5	141	2D CT Planned outage (Hot gas path inspection)
06/01/2011	FPO	329.0	141	2C Hot Gas Path Inspection
06/22/2011	FMO	99.3	141	2B CT Planned Outage Blanking Plate Swap
06/22/2011	FMO	98.2	141	2F CT Blanking Plate install
06/24/2011	FMO	57.2	141	2D CT Planned Outage Blanking Plate Swap
06/24/2011	FMO	56.5	141	2E CT Planned Outage Blanking plate Swap
06/27/2011	FFO	31.0	141	2E CT EFOR 408 Valve issues
06/27/2011	PFO	22.3	71.14	Impact loss due to curtailment on 2E
06/27/2011	PFO	31.0	9.69	Impact loss due to curtailment on 2E
06/27/2011	FFO	4.8	426	ST2 Startup Failure (EFOR)
06/28/2011	FFO	3.8	426	ST2 EFOR Vibration Trip
06/29/2011	FMO	121.3	426	STEAMER 2 BALANCE SHOT
07/04/2011	FFO	42.2	426	Main Steam Stop Valve not fully closing
07/08/2011	FFO	4.5	141	2F CT Trip
07/08/2011	PFO	4.5	71.15	Impact loss due to curtailment on 2F
07/08/2011	PFO	4.5	9.69	Impact loss due to curtailment on 2F
07/11/2011	FMO	41.6	141	2ACT Blanking plate change over
07/11/2011	PMO	41.6	71.15	Impact loss due to curtailment on 2A
07/11/2011	PMO	41.6	9.69	Impact loss due to curtailment on 2A
07/13/2011	FMO	36.8	141	2ECT Blanking plate change over
07/13/2011	PMO	36.8	71.15	Impact loss due to curtailment on 2E
07/13/2011	PMO	36.8	9.69	Impact loss due to curtailment on 2E
07/22/2011	FMO	15.3	141	2A CT OUTAGE
07/22/2011	PMO	15.3	71.15	Impact loss due to curtailment on 2A

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011

PLANT / UNIT: FORT MYERS 02 PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
07/22/2011	PMO	15.3	9.69	Impact loss due to curtailment on 2A
08/05/2011	FMO	30.2	141	2B FPI INSPECTION
08/05/2011	PMO	30.2	71.15	Impact loss due to curtailment on 2B
08/05/2011	PMO	30.2	9.69	Impact loss due to curtailment on 2B
08/06/2011	FMO	28.6	141	2E FPI Inspection
08/06/2011	PMO	28.6	71.15	Impact loss due to curtailment on 2E
08/06/2011	PMO	28.6	9.69	Impact loss due to curtailment on 2E
08/08/2011	FFO	8.9	141	2E CT ESGJ-ACV-3 failure EFOR
08/08/2011	PFO	8.9	71.15	Impact loss due to curtailment on 2E
08/08/2011	PFO	8.9	9.69	Impact loss due to curtailment on 2E
08/10/2011	FMO	29.8	141	2F FPI Inspection
08/10/2011	PMO	29.8	71.15	Impact loss due to curtailment on 2F
08/10/2011	PMO	29.8	9.69	Impact loss due to curtailment on 2F
08/13/2011	FFO	0.5	141	2b start up trip [sgj-acv-003]
08/13/2011	PFO	0.5	71.15	Impact loss due to curtailment on 2B
08/13/2011	PFO	0.5	9.69	Impact loss due to curtailment on 2B
08/16/2011	FFO	3.8	141	2C CT/HRSG GAS AUX STOP VALVE
08/16/2011	PFO	3.8	71.15	Impact loss due to curtailment on 2C
08/16/2011	PFO	3.8	9.69	Impact loss due to curtailment on 2C
08/19/2011	FFO	7.7	141	2E CT high exhaust temp spread trip
08/19/2011	PFO	7.7	71.15	Impact loss due to curtailment on 2E
08/19/2011	PFO	7.7	9.69	Impact loss due to curtailment on 2E
08/21/2011	FMO	40.1	141	2E MOF(Tube Leak)
08/21/2011	PMO	40.1	71.15	Impact loss due to curtailment on 2E

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: FORT MYERS 02

PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
08/21/2011	PMO	40.1	9.69	Impact loss due to curtailment on 2E
09/02/2011	FMO	21.8	141	2A CT/HRSG
09/02/2011	PMO	21.8	71.15	Impact loss due to curtailment on 2A
09/02/2011	PMO	21.8	9.69	Impact loss due to curtailment on 2A

- (1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

ISSUED BY: FLORIDA POWER & LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011

PLANT / UNIT: SCHERER 04 PSG 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/10/2011	PFO	18.5	681	Lack of coal due to bad weather
01/11/2011	FFO	15.0	881	Lack of coal due to bad weather
01/12/2011	PFO	21.5	506	Lack of coal due to bad weather
01/13/2011	PFO	19.7	481	Lack of coal due to bad weather
02/05/2011	PFO	5.8	531	Wet Coal
02/06/2011	PFO	0.7	181	Baghouse Differential High
02/06/2011	PFO	20.0	531	Wet Coal
02/12/2011	PFO	1.0	31	4F Feeder Wet Coal
02/12/2011	PFO	0.7	31	4E Feeder Tripped
03/20/2011	FFO	0.3	881	Automatic Turbine Control System Tripped
03/22/2011	PFO	3.3	531	Pulverizer Feeder Trip
04/21/2011	FMO	56.7	881	Boiler Tube Leak
05/12/2011	FFO	1.7	881	Debris in circulating water
06/07/2011	PFO	1.1	411	4A BFPT Tripped
06/18/2011	FPO	553.4	881	Major Turbine Overhaul
07/12/2011	FMO	43.8	881	Boiler Tube Leak - Waterwall
09/01/2011	PFO	0.2	861	Seal Air Fan
09/01/2011	FFO	1.2	881	Exhaust Hood Temp
09/01/2011	PFO	1.3	859	Flame Scanner Loss
09/14/2011	PMO	3.0	31	Turbine Test for Data Collection

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: ST LUCIE 01

PSL 01

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
04/04/2011	PPO	128.0	67.32	U1 PEL 1A2 Waterbox Repair 040411
04/09/2011	PPO	5.7	44.55	U1 PEL Turbine Valve Test 040911
04/29/2011	PFO	27.9	76.74	U1 UEL 1A2 Circ Water Pump Vibration 042911
05/01/2011	PFO	323.7	62.62	U1 UEL 1A2 Circ Water Pump Vibration 050111
05/30/2011	PMO	96.7	76.09	U1 UEL 1A2 Waterbox Repair 053011
07/05/2011	PFO	97.1	82	U1 UEL 1A2 Waterbox Maintenance 070511
08/22/2011	PFO	0.7	222.86	U1 OMC Jellyfish Intake Intrusion Down Power 082211
08/22/2011	FFO	96.3	839	U1 OMC Jellyfish Intake Intrusion SNO 082211
08/26/2011	PFO	31.8	276.41	U1 OMC Jellyfish Intake Intrusion Uppower 082611

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: ST LUCIE

02

PSL 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/01/2011	PPO	37.8	188.29	U2 PEL MSSV Testing part 2 01012011
01/02/2011	PPO	3.2	440.48	U2 PEL SL2-19 Refueling Outage Downpower 010211
01/02/2011	FPO	703.0	839	U2 PEL SL2-19 Refueling Outage 010211
02/01/2011	FPO	672.0	839	U2 PEL SL2-19 Refueling Outage 020111
03/01/2011	FPO	591.0	839	U2 PEL SL2-19 Refueling Outage 030111
03/25/2011	FPO	152.0	839	U2 PEL SL2-19 Refueling Outage Extension 032511
04/01/2011	FPO	384.6	839	U2 PEL SL2-19 Refueling Outage Extension 040111
04/17/2011	FFO	335.4	839	U2 UEL SL2-19 Refueling Outage Ext CEA 89 041711
05/01/2011	FFO	172.1	839	U2 UEL SL2-19 Refueling Outage Ext CEA 89 050111
05/08/2011	PPO	18.1	568.74	U2 PEL SL2-19 Power Ascension Part 1 050811
05/08/2011	PFO	18.5	448.07	U2 UEL SL2-19 Up Power Chemistry Hold 050811
05/09/2011	PPO	5.1	383.78	U2 PEL SL2-19 Power Ascension part 2 050911
05/09/2011	PFO	13.0	340.78	U2 UEL SL2-19 Up Power Chemistry Hold part 2 050911
05/10/2011	PPO	2.6	312.19	U2 PEL SL2-19 Power Ascension part 3 050911
05/10/2011	PFO	19.7	281.09	U2 UEL SL2-19 Up Power Chemistry Hold part 3 051011
05/11/2011	PPO	41.0	122.58	U2 PEL SL2-19 Power Ascension part 4 051111
05/16/2011	PFO	2.5	300.84	U2 UEL Main Steam Vent Line Leak down power 051611
05/16/2011	FFO	47.3	839	U2 UEL Main Steam Vent Line SNO 05162011
05/18/2011	FFO	10.2	839	U2 UEL Turbine GV #1 repair 051811
05/18/2011	FFO	2.4	839	U2 UEL Main Steam Vent Line Leak SNO part 2 051811
05/18/2011	PFO	41.8	219.04	U2 UEL Main Steam Vent Line Leak Power Ascension 051811
06/06/2011	FFO	27.7	839	U2 UEL Automatic Scram 060611
06/07/2011	PFO	14.2	338.56	U2 UEL Unplanned Scram Power Ascension 060711
08/16/2011	PMO	8.1	72.24	U2 PEL Turbine Valve Test 081611

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: ST LUCIE

02

PSL 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
08/16/2011	PMO	70.6	451.35	U2 PEL TCW HX & 2A MF PP maint 081611
08/19/2011	PFO	4.5	534.08	U2 UEL Generator Cooling System Cold Gas Hi Temp Down F
08/20/2011	PMO	5.5	307.99	U2 PEL TCW HX & 2A MF PP maint Part 2 082011
08/20/2011	PMO	7.5	79.43	U2 PEL Turbine Valve Test part 2 082011
08/22/2011	PFO	73.3	225.62	U2 OMC Jellyfish Intrusion UEL down power 082211

- (1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: TURKEY POINT

03

PTN 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/08/2011	PFO	18.9	2	Unit 3 unplanned power reduction to repair 3B SG FRV positio
03/06/2011	PFO	4.8	289	Unit 3 fast load reduction due to high sodium in the steam gen.
03/06/2011	FFO	191.1	693	Unit 3 was manually tripped due to high sodium in the steam g
03/14/2011	PFO	19.2	303	Unit 3 power ascension followin reactor trip due to condenser l

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: TURKEY POINT

04

PTN 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
03/20/2011	PPO	20.0	307	Unit 4 planned downpower for testing of the main steam safety
03/20/2011	PPO	4.0	429	Unit 4 planned power reduction to support cycle 26 RFO
03/21/2011	FPO	1320.0	693	Unit 4 Cycle 26 RFO
05/15/2011	FFO	41.7	693	Unit 4 Cycle 26 RFO outage extension
05/16/2011	PPO	97.3	285	Unit 4 Cycle 26 RFO - planned power ascension

- (1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

ISSUED BY: FLORIDA POWER & LIGHT CO.

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011

PLANT / UNIT: TURKEY POINT #5 05 TP5 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/09/2011	FMO	77.5	142	5A Rainbow Testing SNOW
01/09/2011	PMO	77.5	119.25	Impact loss due to curtailment on 5A
01/17/2011	FMO	99.3	142	5C Rainbow Testing SNOW
01/17/2011	PMO	99.3	119.25	Impact loss due to curtailment on 5C
01/23/2011	FMO	104.2	142	5C HP Desuperheater Repair
01/23/2011	PMO	104.2	119.25	Impact loss due to curtailment on 5C
02/20/2011	FPO	229.9	142	5C Spring Outage
02/20/2011	PPO	229.9	119.25	Impact loss due to curtailment on 5C
02/20/2011	FPO	240.0	142	5B Spring Outage
02/20/2011	PPO	240.0	119.25	Impact loss due to curtailment on 5B
03/02/2011	FPO	240.0	142	5D Spring Outage
03/02/2011	PPO	240.0	119.25	Impact loss due to curtailment on 5D
04/09/2011	FFO	4.3	477	Steam turbine Loss of Vacuum Trip
04/09/2011	PFO	0.7	127.3	5A Runback due to RH high Temp
04/09/2011	PFO	0.5	124	5A Hi Reheat Temp Runback #2
04/09/2011	PFO	0.7	125	5A Hi Reheat Temp Runback #3
04/09/2011	PFO	0.7	125	5D Hi Reheat Temp Runback
04/14/2011	FMO	74.8	142	5C Offline Water wash and Boroscope inspection
04/14/2011	PMO	74.8	119.25	Impact loss due to curtailment on 5C
04/18/2011	FMO	73.4	142	5A CT SNOW- Offline water wash and Boroscope inspection
04/18/2011	PMO	73.4	119.25	Impact loss due to curtailment on 5A
04/25/2011	FFO	0.3	142	5D Liquid Fuel Swap Reliability Check
04/25/2011	PFO	0.3	119.25	Impact loss due to curtailment on 5D
05/01/2011	FFO	0.1	142	PTF 5D Trip During Fuel Swap

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: TURKEY POINT #5 05

TP5 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
05/01/2011	PFO	0.1	119.25	Impact loss due to curtailment on 5D
05/23/2011	FFO	0.0	142	PTF 5D Trip During Fuel Swap
05/23/2011	PFO	0.0	119.25	Impact loss due to curtailment on 5D
06/04/2011	FFO	0.0	142	PTF 5C Trip During Fuel Swap
06/04/2011	PFO	0.0	119.25	Impact loss due to curtailment on 5C
06/16/2011	FFO	5.9	142	PTF 5C Shutdown
06/16/2011	PFO	5.9	119.25	Impact loss due to curtailment on 5C
06/21/2011	FMO	17.6	142	5B BFP Recirc Overhaul
06/21/2011	PMO	17.6	119.25	Impact loss due to curtailment on 5B
07/17/2011	FMO	101.3	142	5C Rainbow Inspection SNOW
07/17/2011	PMO	101.3	119.25	Impact loss due to curtailment on 5C
08/04/2011	PFO	24.4	72	PTF 5 Block is load limited to 1000 MW
08/18/2011	FMO	48.4	142	5A SNOW - Offline water wash and boroscope inspection
08/18/2011	PMO	48.4	119.25	Impact loss due to curtailment on 5A
08/21/2011	FPO	264.0	142	5A Minor Outage
08/21/2011	PPO	264.0	119.25	Impact loss due to curtailment on 5A
09/01/2011	FPO	502.8	142	5A Outage Extension - BFP
09/01/2011	PPO	502.8	119.25	Impact loss due to curtailment on 5A
09/02/2011	FFO	35.0	142	5B BFP motor failure
09/02/2011	PFO	35.0	119.25	Impact loss due to curtailment on 5B
09/22/2011	FFO	2.4	142	5D Runback (Ovation Card)
09/22/2011	PFO	2.4	119.25	Impact loss due to curtailment on 5D
09/23/2011	PFO	1.6	30	5A Runback - IBH

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: MANATEE UNIT 3 CC 03

PM3 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/11/2011	FFO	32.0	146	Transformer failure
01/11/2011	PFO	32.0	114.25	Impact loss due to curtailment on 3D
01/31/2011	FMO	48.0	146	water wash and boroscope
01/31/2011	PMO	48.0	114.25	Impact loss due to curtailment on 3D
02/02/2011	FPO	602.9	146	3D CT Major Outage
02/02/2011	PPO	602.9	114.25	Impact loss due to curtailment on 3D
02/17/2011	FMO	79.9	146	offline water wash
02/17/2011	PMO	79.9	114.25	Impact loss due to curtailment on 3A
02/21/2011	FFO	1.3	146	ignitor failure
02/21/2011	PFO	1.3	114.25	Impact loss due to curtailment on 3A
02/27/2011	FMO	0.1	146	STARS testing
02/27/2011	PMO	0.1	114.25	Impact loss due to curtailment on 3D
03/08/2011	FFO	1.1	146	BFP trip on low disch pressure
03/08/2011	PFO	1.1	114.25	Impact loss due to curtailment on 3D
03/09/2011	FMO	54.0	146	Off Line Water wash
03/09/2011	PMO	54.0	114.25	Impact loss due to curtailment on 3C
03/18/2011	FFO	2.7	146	PMT 3D Trip
03/18/2011	PFO	2.7	114.25	Impact loss due to curtailment on 3D
04/12/2011	FPO	1167.2	146	CT-B MAJOR
04/12/2011	PPO	681.5	114.25	Impact loss due to curtailment on 3B
04/17/2011	FPO	1041.9	146	CT-A MAJOR
04/17/2011	PPO	556.2	114.25	Impact loss due to curtailment on 3A
05/09/2011	FPO	485.7	457	major steam valve inspection
05/09/2011	FPO	476.1	146	3 Steam major steam valves

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011
 PLANT / UNIT: MANATEE UNIT 3 CC 03 PM3 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
05/09/2011	FPO	474.8	146	3 Steam Major Valves
05/29/2011	FFO	3.3	146	FW start up valve open
05/31/2011	FFO	3.2	146	Fuel gas system
05/31/2011	PFO	3.2	114.25	Impact loss due to curtailment on 3B
08/15/2011	FFO	2.3	146	PMT 3C Trip
08/15/2011	PFO	2.3	114.25	Impact loss due to curtailment on 3C
08/26/2011	FFO	688.0	457	Transformer Failure
08/26/2011	FFO	4.6	146	PMT 3 ST XFMR FIRE
08/26/2011	FFO	4.6	146	PMT 3 ST XFMR FIRE
08/26/2011	FFO	4.6	146	PMT 3 ST XFMR FIRE
08/26/2011	FFO	4.6	146	PMT 3 ST XFMR FIRE
09/19/2011	FFO	2.0	146	3D BFP trip
09/24/2011	FFO	0.4	146	Main header pressure to low
09/24/2011	PFO	0.4	114.25	Impact loss due to curtailment on 3A

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: MARTIN-UNIT 8 08

PM8 08

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/07/2011	FMO	57.6	142	8C SNOW OUTAGE BOROSCOPE INSPECTION
01/07/2011	PMO	57.6	115.75	Impact loss due to curtailment on 8C
01/11/2011	FFO	0.8	142	8C CT tripped due to condenser protection trip circuit
01/11/2011	PFO	0.8	115.75	Impact loss due to curtailment on 8C
01/18/2011	FMO	103.0	142	8D CT SNOW
01/18/2011	PMO	103.0	115.75	Impact loss due to curtailment on 8D
01/24/2011	FMO	88.8	142	8A SNOW OUTAGE
01/24/2011	PMO	88.8	115.75	Impact loss due to curtailment on 8A
02/03/2011	FFO	6.9	142	8A CT TRIPPED DURING START-UP
02/03/2011	PFO	6.9	115.75	Impact loss due to curtailment on 8A
02/04/2011	FMO	50.2	142	8A CT Off Line Water Wash
02/04/2011	PMO	50.2	115.75	Impact loss due to curtailment on 8A
02/20/2011	FFO	0.8	142	8A CT missed RFC 02/20.2011
02/20/2011	PFO	0.8	115.75	Impact loss due to curtailment on 8A
03/09/2011	FMO	30.6	142	8ACT Event MOF, CBVs sticking unit able to stay online throug
03/09/2011	PMO	30.6	115.75	Impact loss due to curtailment on 8A
03/10/2011	FMO	32.3	142	8C CT Event MOF, HP-CRH B/P Able to stay on through next
03/10/2011	PMO	32.3	115.75	Impact loss due to curtailment on 8C
03/13/2011	FMO	81.0	142	8B Event MOF,HRH SKYVENT able to stay on through next w
03/13/2011	PMO	81.0	115.75	Impact loss due to curtailment on 8B
03/14/2011	FFO	2.9	142	8A CT EXHAUST SPREAD TRIP
03/14/2011	PFO	2.9	115.75	Impact loss due to curtailment on 8A
04/13/2011	FPO	603.0	142	8B CT PLANNED OUTAGE
04/13/2011	PPO	5.4	115.75	Impact loss due to curtailment on 8B

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011
 PLANT / UNIT: MARTIN-UNIT 8 08 PM8 08

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
04/13/2011	FPO	597.6	463	8X PLANNED OUTAGE
04/13/2011	FPO	621.3	142	8D PLANNED OUTAGE
04/13/2011	FPO	588.2	142	8A PLANNED OUTAGE
04/14/2011	FPO	576.6	142	8C CT PLANNED OUTAGE
05/08/2011	PPO	24.5	115.75	Impact loss due to curtailment on 8D
05/09/2011	PFO	25.7	12	8B CT Runback due to low gas pressure
06/11/2011	FFO	31.4	142	8A CT Trip 06/11/11
06/11/2011	PFO	31.4	115.75	Impact loss due to curtailment on 8A
06/21/2011	FFO	0.1	142	8C Liquid Fuel Testing Trip
06/21/2011	PFO	0.1	115.75	Impact loss due to curtailment on 8C
07/15/2011	FMO	58.4	142	CT 8D HTF RESIDUAL INSPECTION-EVENT MOF
07/15/2011	PMO	58.4	115.75	Impact loss due to curtailment on 8D
07/16/2011	FMO	55.0	142	8A CT HTF RESIDUALS INSPECTION-EVENT MOF
07/16/2011	PMO	55.0	115.75	Impact loss due to curtailment on 8A
07/18/2011	FFO	33.6	142	8A CT EFOR EVENT (EXC TC TRIP)
07/18/2011	PFO	33.6	115.75	Impact loss due to curtailment on 8A
07/30/2011	FFO	11.8	142	8D Exhaust Over Temperature Trip
07/30/2011	PFO	11.8	115.75	Impact loss due to curtailment on 8D
08/02/2011	PFO	18.0	438	8B DUCT BURNER INOPERATIVE / STEAM TURBINE DERA
08/02/2011	FFO	0.6	142	8A CT FIRED SHUTDOWN
08/02/2011	PFO	0.6	115.75	Impact loss due to curtailment on 8A
08/12/2011	FFO	3.7	142	8A CT FAILED POWER SUPPLY 'R' CORE
08/12/2011	PFO	3.7	115.75	Impact loss due to curtailment on 8A
08/13/2011	FFO	41.2	142	8A CT UNABLE TO ROTATE ROTOR

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011

PLANT / UNIT: MARTIN-UNIT 8 08

PM8 08

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
08/13/2011	PFO	41.2	115.75	Impact loss due to curtailment on 8A
08/18/2011	FMO	49.1	142	8B CT SNOW OUTAGE
08/18/2011	PMO	49.1	115.75	Impact loss due to curtailment on 8B
08/22/2011	FFO	5.3	142	8B CT DLN EXHAUST TEMP SPREAD TRIP
08/22/2011	PFO	5.3	115.75	Impact loss due to curtailment on 8B
08/25/2011	FFO	1.3	142	8A CT Solar/Drum Level Trip
08/25/2011	PFO	1.3	115.75	Impact loss due to curtailment on 8A
09/08/2011	PFO	1.0	107	8B CT FUEL GAS HEATER TEMPERATURE RUNBACK
09/23/2011	FFO	0.6	142	8B CT GENERATOR LOCKOUT
09/23/2011	PFO	0.6	115.75	Impact loss due to curtailment on 8B
09/26/2011	FFO	3.6	142	8B CT High exhaust temp. spread trip
09/26/2011	PFO	3.6	115.75	Impact loss due to curtailment on 8B
09/29/2011	FMO	25.3	142	8D CT LIQUID FUEL PUMP Event MOF
09/29/2011	PMO	25.3	115.75	Impact loss due to curtailment on 8D

- (1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 04

PSR 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/06/2011	FMO	70.2	142	PSR 4C OFF TO REPAIR EXPANSION JOINT AND BFP COL
01/06/2011	PMO	70.2	79.25	Impact loss due to curtailment on 4C
01/13/2011	PFO	11.5	79.25	4D HP MUV failed to open during S/U on 1/13/11
01/13/2011	PFO	2.9	22	Impact loss due to curtailment on 4D
01/13/2011	PFO	2.9	68	4D HRH bypass spraywater strainer was clogged curtailing uni
01/15/2011	FMO	18.7	142	PSR 4B OFFLINE COMPRESSOR WASH
01/15/2011	PMO	18.7	79.25	Impact loss due to curtailment on 4B
01/19/2011	FMO	42.1	142	RSD
01/19/2011	PMO	42.1	79.25	Impact loss due to curtailment on 4A
01/22/2011	PFO	0.2	52.8	Impact loss due to curtailment on 4A
01/22/2011	PFO	0.2	113	4A runback on LO IP drum (1/22/11)
01/24/2011	FFO	28.1	317	4ST generator lock out relay
01/26/2011	FFO	0.8	142	4D HRSG blocked steam path during drum soak
01/26/2011	PFO	0.8	79.25	Impact loss due to curtailment on 4D
01/28/2011	FMO	23.2	142	PSR 4B OFF TO REPAIR INLET BLEED HEAT VALVE
01/28/2011	PMO	23.2	79.25	Impact loss due to curtailment on 4B
02/07/2011	FFO	0.1	142	4D CT runback to FSNL Comp Bleed Valve failed to close on
02/07/2011	PFO	0.1	79.25	Impact loss due to curtailment on 4D
02/07/2011	FFO	0.2	142	4D CT trip on start-up Compressor Bleed Valve failed to close
02/07/2011	PFO	0.2	79.25	Impact loss due to curtailment on 4D
02/09/2011	FFO	7.3	142	4A CT TRIP, High Exhaust Temperature Spread
02/09/2011	PFO	7.3	79.25	Impact loss due to curtailment on 4A
02/11/2011	FMO	22.2	142	PSR4A OFF FOR COMPRESSOR WASH
02/11/2011	PMO	22.2	79.25	Impact loss due to curtailment on 4A

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 04

PSR 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
03/28/2011	FPO	378.2	317	4ST Outage to Repair Bearing #3
03/28/2011	FPO	378.2	142	4C Outage to Repair ST Brg #3
03/28/2011	FPO	378.2	142	4B Outage to Repair Steam Turbine Brg #3
03/28/2011	FPO	378.7	142	4A Outage to Repair ST Brg #3
03/28/2011	FPO	378.8	142	4D Outage to Repair Steam Turbine Brg #3
04/13/2011	PPO	0.6	79.25	Impact loss due to curtailment on 4A
04/13/2011	PPO	0.6	79.25	Impact loss due to curtailment on 4D
04/13/2011	FFO	4.7	142	4C CT taken off to repair IP feedwater valve
04/13/2011	PFO	4.7	79.25	Impact loss due to curtailment on 4C
05/22/2011	FMO	15.6	142	PSR 4D OFF FOR COMPRESSOR WASH
05/22/2011	PMO	15.6	79.25	Impact loss due to curtailment on 4D
05/29/2011	FFO	3.3	142	4A inlet bleed heat position versus pressure
05/29/2011	PFO	3.3	79.25	Impact loss due to curtailment on 4A
05/31/2011	PFO	0.4	41.4	Impact loss due to curtailment on 4D
05/31/2011	PFO	0.4	96	4D runback on loss of 2 exhaust T/C signals
06/06/2011	FFO	0.1	317	4 steam turbine breaker opened on reverse power just after co
06/12/2011	FMO	12.0	142	PSR 4A OFF TO REPAIR INLET BLEED VALVE
06/12/2011	PMO	12.0	79.25	Impact loss due to curtailment on 4A
06/12/2011	FMO	5.5	142	PSR 4A OFF FOR OFFLINE COMPRESSOR WASH
06/12/2011	PMO	5.5	79.25	Impact loss due to curtailment on 4A
06/17/2011	FFO	2.2	142	4A CT Came offline to FSNL on reverse power
06/17/2011	PFO	2.2	79.25	Impact loss due to curtailment on 4A
06/21/2011	FFO	1.4	142	4A Ignitor stuck preventing ignitor from firing
06/21/2011	PFO	1.4	79.25	Impact loss due to curtailment on 4A

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 04

PSR 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
06/23/2011	PFO	1.9	79.25	Impact loss due to curtailment on 4B
06/23/2011	PFO	1.9	68	4B ACV-4 & ACV-8 casualties prevented blending of 4B CT
07/17/2011	FFO	4.1	142	4B CT 89SS failed to close on S/U.
07/17/2011	PFO	4.1	79.25	Impact loss due to curtailment on 4B
07/17/2011	PFO	0.2	54.4	Impact loss due to curtailment on 4A
07/17/2011	PFO	0.2	113	4A Runback on Low Gas Tempature
07/31/2011	FMO	140.9	142	PSR 4A OFF FOR HRSG INSPECTION
07/31/2011	PMO	140.9	79.25	Impact loss due to curtailment on 4A
08/07/2011	FMO	174.8	142	PSR 5B off for HRSG INSPECTION
08/07/2011	PMO	174.8	79.25	Impact loss due to curtailment on 4B
08/14/2011	PFO	0.1	58.6	Impact loss due to curtailment on 4B
08/14/2011	PFO	0.1	118	4B CT runback on account of high HP superheat temperatures
08/15/2011	FMO	125.0	142	PSR 4C OFF FOR HRSG INSPECTION
08/15/2011	PMO	125.0	79.25	Impact loss due to curtailment on 4C
08/18/2011	FFO	4.3	142	4A Generator tripped offline due to water intrusion
08/18/2011	PFO	4.3	79.25	Impact loss due to curtailment on 4A
08/21/2011	FMO	68.1	142	PSR 4D OFF FOR HRSG INSPECTION
08/21/2011	PMO	68.1	79.25	Impact loss due to curtailment on 4D
08/27/2011	FFO	17.5	142	4C 89ND did not open during startup
08/27/2011	PFO	17.5	79.25	Impact loss due to curtailment on 4C
08/29/2011	FMO	115.4	142	PSR 4D OFF FOR HRSG INSPECTION
08/29/2011	PMO	115.4	79.25	Impact loss due to curtailment on 4D
09/05/2011	FFO	7.4	317	4ST missed RFC on 9/5/11 due to RSV1 not opening
09/12/2011	PFO	1.8	62	Impact loss due to curtailment on 4E

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 04

PSR 04

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
09/12/2011	PFO	1.8	62	Impact loss due to curtailment on 4E
09/12/2011	PFO	1.8	202	4ST RSV1 stuck
09/16/2011	FFO	1.0	142	4C CT tube oil temperature control valve malfunction
09/16/2011	PFO	1.0	79.25	Impact loss due to curtailment on 4C

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:

SUSPENDED:

EFFECTIVE:

DOCKET NO.:

ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2011 To: Dec-2011
 PLANT / UNIT: SANFORD 4 & 5 CC 05 PSR 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/07/2011	FFO	8.0	142	5B CT HP to CRH By-Pass Closed on Shut-Down
01/07/2011	PFO	8.0	78.75	Impact loss due to curtailment on 5B
01/10/2011	FMO	49.3	142	5C Cycle to repair LP Evap Tube Leak
01/10/2011	PMO	49.3	78.75	Impact loss due to curtailment on 5C
01/16/2011	FMO	19.4	142	PSR 5D OFF FOR OFFLINE COMPRESSOR WASH
01/16/2011	PMO	19.4	78.75	Impact loss due to curtailment on 5D
02/02/2011	FMO	44.5	142	PSR 5D OFF FOR BLADE INSPECTION
02/02/2011	PMO	44.5	78.75	Impact loss due to curtailment on 5D
02/15/2011	FFO	2.4	142	5D CT LATE FOR RFC - AUX STOP VALVE FAIL TO OPEN
02/15/2011	PFO	2.4	78.75	Impact loss due to curtailment on 5D
02/18/2011	FMO	40.4	142	PSR 5D OFF TO REPAIR LUBE OIL PUMP
02/18/2011	PMO	40.4	78.75	Impact loss due to curtailment on 5D
03/04/2011	FMO	69.0	142	5A Repair HRSG Insulation
03/04/2011	PMO	69.0	78.75	Impact loss due to curtailment on 5A
03/15/2011	FFO	8.2	142	5D CT DELAYED START DUE TO OFF TURNING GEAR
03/15/2011	PFO	8.2	78.75	Impact loss due to curtailment on 5D
03/30/2011	FFO	10.9	142	PSR 5B Generator Breaker Trip
03/30/2011	PFO	10.9	78.75	Impact loss due to curtailment on 5B
04/05/2011	FFO	9.7	142	5D BFP Coupling Failure
04/05/2011	PFO	9.7	78.75	Impact loss due to curtailment on 5D
04/06/2011	FFO	5.2	142	5A tripped off on loss of speed indication in the protection core
04/06/2011	PFO	5.2	78.75	Impact loss due to curtailment on 5A
04/18/2011	FMO	20.1	142	PSR 5D off for BFP coupling repair
04/18/2011	PMO	20.1	78.75	Impact loss due to curtailment on 5D

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 05

PSR 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
04/22/2011	FMO	16.4	142	PSR 5B OFF FOR OFFLINE COMPRESSOR WASH
04/22/2011	PMO	16.4	78.75	Impact loss due to curtailment on 5B
04/23/2011	FFO	19.1	142	5B MISSED RFC, BFP Seal
04/23/2011	PFO	19.1	78.75	Impact loss due to curtailment on 5B
04/26/2011	FFO	43.7	142	PSR 5D HRSG Tube Leak
04/26/2011	PFO	43.7	78.75	Impact loss due to curtailment on 5D
04/28/2011	PFO	0.4	18	Impact loss due to curtailment on 5D
04/28/2011	PFO	0.4	64	5D GSU LOSS OF CONTROL POWER
05/18/2011	FFO	1.3	142	5B ct fuel gas electric heater relief valve failure
05/18/2011	PFO	1.3	78.75	Impact loss due to curtailment on 5B
05/18/2011	FFO	0.7	142	5B Inadvertant Energization Relay Operation
05/18/2011	PFO	0.7	78.75	Impact loss due to curtailment on 5B
05/19/2011	FMO	16.5	142	PSR 5A OFF TO PERFORM COMPRESSOR WASH
05/19/2011	PMO	16.5	78.75	Impact loss due to curtailment on 5A
05/19/2011	FMO	49.2	142	PSR 5B OFF FOR BLADE INSPECTION
05/19/2011	PMO	49.2	78.75	Impact loss due to curtailment on 5B
05/22/2011	FMO	8.9	142	PSR 5C COMPRESSOR WASH
05/22/2011	PMO	8.9	78.75	Impact loss due to curtailment on 5C
05/22/2011	FFO	5.1	142	5B CT generator exciter fault
05/22/2011	PFO	5.1	78.75	Impact loss due to curtailment on 5B
06/01/2011	FFO	11.1	142	5C missed RFC due to high BFP inboard motor bearing tempe
06/01/2011	PFO	11.1	78.75	Impact loss due to curtailment on 5C
06/01/2011	FMO	5.6	142	PSR 5C OFF FOR COMPRESSOR WASH
06/01/2011	PMO	5.6	78.75	Impact loss due to curtailment on 5C

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 05

PSR 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
06/03/2011	FMO	31.4	142	PSR 5A DOWN TO SUPPORT WATERBOX CLEANING
06/03/2011	PMO	31.4	78.75	Impact loss due to curtailment on 5A
06/03/2011	FMO	26.8	142	PSR 5B OFF TO SUPPORT WATERBOX CLEANING
06/03/2011	PMO	26.8	78.75	Impact loss due to curtailment on 5B
06/05/2011	FMO	37.2	142	PSR 5D OFF TO SUPPORT CONDENSER CLEANING
06/05/2011	PMO	37.2	78.75	Impact loss due to curtailment on 5D
06/05/2011	FMO	21.9	142	PSR 5C OFF TO SUPPORT CONDENSER CLEANING
06/05/2011	PMO	21.9	78.75	Impact loss due to curtailment on 5C
07/01/2011	FMO	27.6	142	PSR 5B OFF FOR COMPRESSOR WASH
07/01/2011	PMO	27.6	78.75	Impact loss due to curtailment on 5B
07/08/2011	FMO	75.2	142	PSR 5D OFF FOR OFFLINE COMPRESSOR WASH
07/08/2011	PMO	75.2	78.75	Impact loss due to curtailment on 5D
07/10/2011	FMO	144.6	142	PSR 5B HRSG INSPECTION
07/10/2011	PMO	144.6	78.75	Impact loss due to curtailment on 5B
07/17/2011	FMO	155.5	142	PSR 5A OFF FOR HRSG INSPECTION
07/17/2011	PMO	155.5	78.75	Impact loss due to curtailment on 5A
07/17/2011	FFO	0.7	142	5B CT BFP trip Low NPSH
07/17/2011	PFO	0.7	78.75	Impact loss due to curtailment on 5B
07/17/2011	FFO	0.9	142	5B CT runback to FSNL bearing cooling pressure
07/17/2011	PFO	0.9	78.75	Impact loss due to curtailment on 5B
07/17/2011	FFO	3.4	142	5B CT runback to FSNL Bearing Cooling Pressure
07/17/2011	PFO	3.4	78.75	Impact loss due to curtailment on 5B
07/24/2011	FMO	141.1	142	PSR 5C OFF FOR HRSG INSPECTION
07/24/2011	PMO	141.1	78.75	Impact loss due to curtailment on 5C

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2011

To: Dec-2011

PLANT / UNIT: SANFORD 4 & 5 CC 05

PSR 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
07/27/2011	FFO	0.8	142	PSR 5A TRIP-Cardox Release
07/27/2011	PFO	0.8	78.75	Impact loss due to curtailment on 5A
09/27/2011	FFO	0.4	142	5A Exciter Overtemp, AC Failures
09/27/2011	PFO	0.4	78.75	Impact loss due to curtailment on 5A
09/27/2011	FMO	48.0	142	PSR 5D OFF FOR EXPANSION JOINT REPAIR
09/27/2011	PMO	48.0	78.75	Impact loss due to curtailment on 5D

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

GPIF Units
Actual Performance Data (ACRONYMS) for 2011

ACRONYMS	DESCRIPTION
"R"	Mark VI "R" Processor
1A2	Unit 1 Pump A2
1B	Unit 1 Pump B
2B1	Unit 2 Pump B1
2A	Unit 2 Combustion Turbine (sub unit A)
2A CT - 2A 230	Combustion Turbine (sub unit A) - 2A Collector Bus
2A HDP	2 Alpha High Differential Pressure
2B	Unit 2 Combustion Turbine (sub unit B)
2B CT - 2A 230	Combustion Turbine (sub unit B) - 2A Collector Bus
2B MSR	2 Bravo Moisture Separator Reheater
2C	Unit 2 Combustion Turbine (sub unit C)
2C CT - 2A 230	Combustion Turbine (sub unit C) - 2A Collector Bus
2D	Unit 2 Combustion Turbine (sub unit D)
2E	Unit 2 Combustion Turbine (sub unit E)
2F	Unit 2 Combustion Turbine (sub unit F)
3 CTB	Unit 3 Combustion Turbine (sub unit B)
3A	Unit 3 Combustion Turbine (sub unit A)
3B	Unit 3 Combustion Turbine (sub unit B)
3C	Unit 3 Combustion Turbine (sub unit C)
3D	Unit 3 Combustion Turbine (sub unit D)
3ST	Unit 3 Steam Turbine
41AC-1	Breaker 1 for Power Supply to Exciter
41AC-2	Breaker 2 for Power Supply to Exciter
4A	Unit 4 Combustion Turbine (sub unit A)
4A SGFP	4A Steam Generator Feedwater Pump
4B	Unit 4 Combustion Turbine (sub unit B)
4C	Unit 4 Combustion Turbine (sub unit C)
4D	Unit 4 Combustion Turbine (sub unit D)
4KV	4 Thousand Volts
5A	Unit 5 Combustion Turbine (sub unit A)
5B	Unit 5 Combustion Turbine (sub unit B)
5C	Unit 5 Combustion Turbine (sub unit C)
5D	Unit 5 Combustion Turbine (sub unit D)
5ST	Unit 5 Steam Turbine
8A	Unit 8 Combustion Turbine (sub unit A)
8B	Unit 8 Combustion Turbine (sub unit B)
8C	Unit 8 Combustion Turbine (sub unit C)
8D	Unit 8 Combustion Turbine (sub unit D)
8X	Unit 8 Steam Turbine
89SS	Static Start Switch
ACV-3	Automatic Control Valve # 3
ACV-408	Air Control Valve Tag 408
AUX	Auxiliary
BFP	Boiler Feed Pump
BFPT	Boiler Feed Pump Turbine
BRG	Bearing
BSGG	Unit B, main steam section of HRSG
CEA	Control Element Assembly
CEA 38	Control Element Assembly Number 38
CEA 65	Control Element Assembly Number 65
Circ	Circulating (water pump)
com	Communication
comm	Communication
CRH	Cold Reheat

GPIF Units
Actual Performance Data (ACRONYMS) for 2011

ACRONYMS	DESCRIPTION
CT	Combustion Turbine
CT C	Combustion Turbine (sub unit C)
CTG SRV	Speed Ratio Valve on Combustion Turbine (gas system)
CV-4-1510	Control Valve Number 4-1510
CW	Circulating Water
CWP	Circulating Water Pump
DFS	Debris Filtration System
diff	Differential
DLN	Dry Low Nox
DX	DeXcitation
EFOR	Equivalent Forced Outage Rate
EHC	Hydraulic
ESGA	System code for Ft. Myers 2E HRSG
EXP	Expansion
Fa	Failed
FGT	Florida Gas Transmission
FME	Foreign Material Exclusion
FPI	Fluorescent penetrant inspection
FSGJ	F is the unit (2F) SGJ is the system designator
FSNL	Full Speed No Load
FRV	Feedwater Regulating Valve
GE	General Electric
GSU	Generator Step Up
Haz	Hazardous
HI	High
HMI	Human Machine Interface
HP	High Pressure
HRH	Hot Reheat
HRSG	Heat Recovery Steam Generator
HTF	Heat Transfer Fluid
I/O	Input / Output
IBH	Inlet Bleed Heat Valve
ID	Induced Draft
Instr.	Instrumentation
IP	Intermediate Pressure
LCI	Load Commutating Inverter
LO	Low
LP	Low Pressure
MFIV	Main Feed Isolation Valve
MF PP	Main Feed Pump
MG	Motor Generator
MOF	Maintenance Outage Factor
mof	maintenance outage factor
MOF/AA	Maintenance Outage Factor / Atomizing Air
MSR	Moisture Separator Reheater
MSSV	Main Steam Safety Valve
MW	Megawatt
MUV	Motor actuated <u>U</u> nidirectional <u>V</u> alve
NO	No
O/H	Overhaul
OMC	Outside Management Control
POF	Planned Outage Factor
PEL	Planned Energy Loss
PFM	Ft. Myers

GPIF Units
Actual Performance Data (ACRONYMS) for 2011

ACRONYMS	DESCRIPTION
PM1	Gas Valve Number 1
PM3	Gas Valve Number 3
MAJOR	Major Overhaul
PM320102662	Manatee Unit 3 GADS #20102662
PMG	Martin
PMT	Manatee
ND	Neurtal Disconnect
Pmp	Pump
PSL	St Lucie
PSR	Sanford
PT	Potential transformer
PWR	Power
R	Repair
R0	Row 0 blades on steam turbine
R1	Row 1 blades on steam turbine
RFC	Ready For Control
RFO	Refueling Outage
RPS	Reactor Protection System
RSD	Reserve Shutdown
RSV	Reheat Stop Valve
RSV1	Reheat Stop Valve Number 1
S/U	Startup
SGG	Main Steam - High Pressure
SGJ-ACV-10	System Designator Air Control Valve
SL1-23	St Lucie Unit 1 cycle 23 refueling outage
SL2-19	St Lucie Unit 2 cycle 19 refueling outage
SNO	Short Notice Outage
SNOW	Short Notice Outage
STARS	Strategic Anti Rotation Stall Surge testing
ST	Steam Turbine
ST1	Steam Turbine Number 1
ST2	Steam Turbine Number 2
STG or SG	Steam Generator
STM 1	Steam Turbine Number 1
STM 2	Steam Turbine Number 2
TC or T/Cs	Thermal/Couples
TCW HX	Turbine Cooling Water Heat Exchanger
U1	Unit 1
U2	Unit 2
UEL	Unplanned Energy Loss
Vi	Roman Numeral 6
WO	Work
WW	Water wash
XFMR	Transformer