

**Eric Fryson**

**From:** Sue Batchelder [Sue.Batchelder@arlaw.com]  
**Sent:** Friday, January 27, 2012 3:00 PM  
**To:** Filings@psc.state.fl.us  
**Cc:** mfriedman@SFFlaw.com; reilly.steve@leg.state.fl.us; Bart Fletcher; David Bernstein; Andrew McBride; Kenneth Curtin  
**Subject:** LABRADOR UTILITIES, INC. RATE ACTION (Docket. No. 11-0264-WS): LETTER DATED 01/27/12 PROVIDING RESPONSE TO PETITIONER'S LETTER DATED 01/17/12  
**Attachments:** 0568\_001.pdf

Electronic Filing

a. Person Responsible for this electronic filing:

David S. Bernstein, Esq.  
 Adams and Reese LLP  
 150 Second Avenue North, Suite 1700  
 St. Petersburg, Florida 33701  
 Direct: (727) 502-8215  
 E-Fax: (727) 502-8915  
[David.Bernstein@arlaw.com](mailto:David.Bernstein@arlaw.com)

b. Docket No. 11-02640-WS

In Re: Application for increase in water and wastewater rates in Pasco County by Labrador Utilities, Inc.

c. Document being filed on behalf of FOREST LAKE ESTATES CO-OP, INC.

d. There are a total **14** pages

e. The document attached for electronic filing is Intervener, FOREST LAKE ESTATES CO-OP, INC's, LETTER DATED 01/27/12 PROVIDING RESPONSE TO PETITIONER'S LETTER DATED 01/17/12

Thank you for your cooperation and attention to this matter.

ADAMS AND REESE LLP

Baton Rouge | Birmingham | Houston | Jackson | Memphis | Mobile | Nashville | New Orleans | Sarasota | St. Petersburg | Tampa | Washington, D.C.

The contents of this e-mail and its attachments are intended solely for the addressee(s). In addition, this e-mail transmission may be confidential and it may be subject to privilege protecting communications between attorneys and their clients. If you are not the named addressee, or if this message has been addressed to you in error, you are directed not to read, disclose, reproduce, distribute, disseminate or otherwise use this transmission. Delivery of this message to any person other than the intended recipient(s) is not intended in any way to waive privilege or confidentiality. If you have received this transmission in error, please alert the sender by reply e-mail. Treasury Circular 230 requires that we inform you that any statements regarding tax matters made herein, including attachments, cannot be relied upon for the purpose of avoiding tax penalties, and such statements are not intended to be used or referred to in any marketing or promotional materials. Additionally, Adams and Reese LLP does not and will not impose any limitation on the disclosure of the tax treatment or tax structure of any transactions to which such statements relate.

DOCUMENT NUMBER-DATE

00580 JAN 27 09

1/27/2012

FPSC-COMMISSION CLERK

January 27, 2012

Via E-Filing

Ann Cole, Commission Clerk  
Office of Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Blvd  
Tallahassee, Florida 32399-0850

Re: PSC Docket No. 11-0264-WS; Application for increase in water and wastewater rates in Pasco County by Labrador Utilities, Inc.

Dear Ms. Cole:

The above referenced law firm represents Forest Lake Estates Co-Op, Inc. (the "Co-Op"), the owner of the mobile home park ("Park") which is the subject matter of PSC Docket No. 11-0264-WS Application for Increase in Water and Wastewater rates in Pasco County filed by Labrador Utilities, Inc. ("Docket"). On January 17, 2012, counsel for the Petitioner, Labrador Utilities, Inc. ("Labrador"), filed in the Docket correspondence in response to Staff's December 21, 2011 request for information which included attached thereto a privileged and confidential engineering Recommendation Report ("Report") prepared at the request of Co-Op and provided to Labrador only to aid mediation efforts in a separate civil lawsuit entitled *Forest Lake Estates Co-Op, Inc. v. Labrador Utilities, Inc.*, Case No. 51-08-CA-4033-ES/B, in the Sixth Judicial Circuit in and for Pasco County, Florida ("Civil Action"). Please find attached hereto as **Exhibit "A"** an email to counsel for Labrador in the Civil Action dated October 28, 2011 making clear that the Report is privileged and confidential and being disclosed only in anticipation of a mediation in the Civil Action. As Labrador's attorney knows full well, Labrador acted improperly by releasing this confidential Report. That fact should not be ignored by the PSC. Moreover, Labrador's accompanying letter attaching the confidential Report is misleading and false in several aspects.

First, Labrador's counsel's accompanying letter mischaracterized the rationale behind releasing the confidential Report in anticipation of mediation by implying that Co-Op and Labrador were somehow not in a dispute over the improper and substandard water and wastewater services provided by Labrador to the Park. The contrary is in fact the truth in that Labrador has failed, despite repeated demands, to provide adequate water and wastewater services to the Park. This failure by Labrador is the exact reason why Co-Op was compelled to sue Labrador in the Civil Action and has been in a hostile litigation for years with Labrador.

DOCUMENT NUMBER-DATE

00580 JAN 27 09

Consequently, Labrador, far from being cooperative, has failed to address valid and repeated complaints by the Co-Op, its resident owners, and its renters concerning the improper and substandard service and quality provided by Labrador thereby necessitating the Civil Action and the Co-Op retaining its own engineer to outline Labrador's blatant deficiencies.

Second, in addition to improperly releasing the confidential Report and mischaracterizing the whole rationale behind the Report, Labrador also grossly and wantonly mischaracterized the findings of the Report in an attempt to mislead the Commission. Labrador attempts to mislead this Commission by stating that the Report "contains no specific recommendations regarding the operation of the Labrador WWTP, which would indicate that the plant was being operated properly." On the contrary, the Report clearly states in pertinent part on page 8 in "Conclusions and Recommendations" that:

"there is overwhelming evidence that the operations of the wastewater - collection, treatment, and disposal LUI-operated facility that serve Forest Lake Estates have the potential to generate significant malodorous conditions in the community and that a comprehensive odor control evaluation and improvement program is needed to mitigate the odor issues with the LUI facilities."

Consistent with this diagnosis, the Report then provides four specific suggestions which Labrador should employ to remediate the nuisance caused by Labrador's deficient wastewater services. These include:

1. Minimizing or preventing production of odorous compounds;
2. Treating odorous compounds within the liquid phase;
3. Containing and treating foul air (treatment should not be just with odor masking measures and especially when toxic gases are the cause of odors); and,
4. Enhancing atmospheric dispersion of foul air.

The reason for the mediation was to discuss the remedies outlined by the Report and hopefully have Labrador implement one, several, or all of the remedies in order to finally provide a level of service and quality that the residents of the Park deserve and are entitled thereto. However, Labrador mentions none of these suggestions, but instead, in order to attempt to gain a rate increase, creates the false impression that Co-Op and its engineer somehow approves of the deplorable operating conditions and deficient service provided by Labrador. As a result, Labrador's deception in this regard is just further evidence of Labrador's lack of candor and willingness to correct its deficient service and quality.

Sincerely,

*Andrew J. McBride*

*KM*

Kenneth M. Curtin

cc:

**Martin S. Friedman, Esq., Sundstrom, Friedman & Fumero, LLP (w/enc. – via electronic filing)**  
**Bart Fletcher, Division of Economic Regulation (w/enc. – via electronic filing)**  
**Martha Brown, Esq., Office of General Counsel (w/enc. – via electronic filing)**  
**Stephen C. Reilly, Associate Public Counsel (w/enc. – via electronic filing)**

**Kenneth Curtin**

---

**From:** Kenneth Curtin  
**Sent:** Friday, October 28, 2011 3:35 PM  
**To:** Joseph W. Etter IV (jwe@kubickidraper.com)  
**Cc:** David Bernstein  
**Subject:** Forest Lake v. Labrador Utilities  
**Attachments:** 0332\_001.pdf


**CONFIDENTIAL FOR SETTLEMENT PURPOSES ONLY**

Joe:

As we discussed on the phone, please find attached my client's engineer's Recommendation Report involving the excessive odor issue emanating from Labrador Utilities, Inc.'s wastewater plant. I would like to arrange for a mediation/settlement conference between you, me, and our respective clients to discuss possible remedies to the odor issue which would be mutually acceptable by both parties and will hopefully eliminate or at least greatly alleviate the excessive odors. At this mediation/settlement conference, I believe it will be appropriate and useful to have both my client's engineer and any engineering representatives that your client desires to participate. Further, I believe it would be useful to conduct the mediation/settlement conference either at my client's clubhouse or somewhere reasonably close to the actual wastewater facility in the eventuality it becomes necessary for our respective clients and engineers to visit the facility to discuss possible remedies to the odor issue.

At any rate, please review, discuss with your client, and contact me so we can arrange for such a mediation/settlement conference.


Kenneth M. Curtin, Esquire  
Adams and Reese LLP  
101 E. Kennedy Boulevard, Suite 4000  
Tampa, Florida 33602  
Main: (813) 402-2880  
Fax: (813) 402-2887  
Direct: (813) 227-5521  
E-Fax: (813) 227-5621  
150 Second Avenue North, Suite 1700  
St. Petersburg, Florida 33701  
Main: (727) 502-8200  
Fax: (727) 502-8282  
Direct: (727) 502-8261  
E-Fax: (727) 502-8961  
[kenneth.curtin@arlaw.com](mailto:kenneth.curtin@arlaw.com)  
[www.adamsandreese.com](http://www.adamsandreese.com)



1/27/2012

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

### **Recommendation Report**

Date: 27 September 2011  
To: Kenneth M. Curtin, Esq. – Forest Lake Estates Co-Op, Inc.  
From: Greg Menniti, P.E. (PA,OH,WV) – Geosyntec Consultants   
Copies to: J. Chris Herin, P.G. – Geosyntec Consultants  
Subject: Inspection of the Wastewater System for Forest Lake's Mobile Home Park  
Subject Site: Forest Lake Estates, 6429 Forest Lake Drive, Zephyrhills, Florida

---

Forest Lake Estates Co-Op, Inc. (FLEC) retained Geosyntec Consultants, Inc. (Geosyntec) to provide environmental consulting services. Geosyntec understands that FLEC is concerned with an odor nuisance caused by the Labrador Utilities, Inc. (LUI) wastewater facility which is adjacent to the Forest Lake Estates Community. Geosyntec's primary assignment has been to review and tour LUI's wastewater facility from an engineering perspective in an effort to uncover operational issues which could contribute to the odor nuisance concerns caused by LUI, including, for example, where the LUI facility may be in need of updating. The review was also to address whether LUI's facility was functioning in a way which can be considered adequate for servicing the Forest Lake Estates Community. If it was found not to be adequate, then Geosyntec was also to provide recommendations for updating the LUI facility with the goal of it being better equipped to meet the needs of the Forest Lake Estates Community without causing objectionable odors.

Pursuant to the above, this report incorporates recommendations, and also addresses what may be done to reduce odor from the LUI facility.

To date, Geosyntec has conducted the following services for the Client:

- **Review of Additional Site-Related Data** – Geosyntec reviewed Site information provided by you. This information included correspondence with involved agencies and with LUI regarding the LUI facility. Aside from correspondence, Geosyntec reviewed permit-related documentation (influent/effluent flow information, discharge monitoring reports, etc.), recent operation reports, and recent inspection documentation (including notices of violations issued by the State) for the LUI facility, together with correspondence of residents' complaint regarding the odor issues at the facility.

OCT 10 2011

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

- **Visit the Subject Site – Mr. Greg Menniti** visited the Subject Site and the LUI facility on April 28, 2011 to become better familiar with Site features and perform an onsite engineering review of the facility.

### INTRODUCTION

Odors have been rated as the foremost concern of the public relative to the implementation of wastewater-treatment facilities. The control of odors has become a major consideration in the design and operation of wastewater – collection, treatment, and disposal facilities, especially with respect to the public acceptance of these facilities <sup>(1)</sup>.

Odorous substances include a large variety of compounds. The reduced sulfur family of compounds is the major problem in most wastewater systems, and hydrogen sulfide (H<sub>2</sub>S) is often the most common offender. Microbial processes occur in wastewater conveyance and treatment systems that result in compounds associated with foul odors. In the absence of adequate available dissolved oxygen (D.O.), in temperate as well as tropical climates organically polluted wastewater is typically metabolized by sulfate reducing bacteria and problems of H<sub>2</sub>S generation can be prevalent.

Temperature and time will help determine how soon fermentation and sulfate reduction will begin in wastewater systems, whether in about one hour in warm climates or one day in colder climates. Malodorous conditions will also ensue because of the volatile nature of H<sub>2</sub>S, resulting in its transfer from the wastewater into the air. Wastewater collection systems can reach H<sub>2</sub>S concentrations ranging between 10 to 1000 parts-per-million by volume (ppmv) in pump station wet well air space and/or at force mains discharge locations.

Because H<sub>2</sub>S is one of the most objectionable odors to humans, with an odor threshold of approximately 0.001 ppmv in air, controlling H<sub>2</sub>S formation within the wastewater system at extremely low concentrations presents a formidable challenge. Unfortunately once formed, H<sub>2</sub>S does not remain stationary, but impacts life and property far removed from the wastewater conveyance and treatment system.

The importance of odors at low concentrations in human terms is related primarily to the psychological stress these produce. Offensive odors can cause poor appetite for food, lowered water consumption, impaired respiration, nausea and vomiting, and mental perturbation. In extreme situations, offensive odors can lead to the deterioration of personal and community

engineers | scientists | innovators

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

pride, interfere with human relations, discourage capital investment, lower socioeconomic status, and deter growth. Also, some odorous compounds (e.g., H<sub>2</sub>S) are toxic at elevated concentrations. These problems can result in a decline in market and rental property values, tax revenues, payrolls, and sales <sup>(1)</sup>.

### ODOR CONTROL PRACTICES

Many wastewater facility operators and engineers believe odor control is synonymous with "foul air treatment." Actually, foul air treatment is often the most costly type of odor control. Other types or categories of odor control should normally be evaluated first to decide if foul air treatment can be avoided.

There are sufficient valid engineering and scientific tools available today to allow fully workable odor control solutions at wastewater facilities. An advisable and cost-effective approach is to conduct a thorough evaluation of potential odor problems and to assess the odor control measures of their effectiveness.

Considerable information is needed to conduct an odor control evaluation, and information about the wastewater entering the treatment facility is crucial. The details of the upstream collection system (including the operation of upstream pumping stations); the sources, kinds, and amounts of wastewater; and other information are all vital.

Where there are chronic odor problems at treatment facilities, approaches to solving these problems may include:

- Control of odor-causing compounds in wastewaters discharged to the collection system and treatment plant that creates odor problems;
- Control of odors generated in the wastewater-collection system;
- Control of odors generated in wastewater treatment facilities;
- Application of chemicals to the liquid (wastewater) phase;
- Installation of odor containment and treatment facilities; and,
- Use of odor masking and neutralizing agents.



*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

As mentioned earlier, odorous substances include a large variety of compounds and hydrogen sulfide is often the most common offender. But other sulfides, disulfides, and mercaptans are also frequent problem compounds because the associated odor thresholds are almost all in the part-per-billion range or less. Reduced sulfur compounds, amines, aldehydes, ketones, ammonia and various organic acids can also cause odor problems.

The first line of defense against odor problems is to design and operate the entire wastewater system to produce the absolute minimum quantity of odorous compounds. Upstream controls need to be explored because most often it is less costly to solve the odor problem upstream. Control measures could include:

- Pretreatment of specific locations within the system. To use the LUI facility as an example, this could possibly be done at all the pump stations within the Forest Lake Estates sanitary sewer system and at the recreational vehicle area.
- Minimizing slug loads of wastewater into the treatment facility by replacing the constant speed pumps at the pumping stations with variable speed pumps.
- Keeping the wastewater pH well above 7 to minimize hydrogen sulfide off-gassing. A pH of 8 would usually be adequate, but pH 9 may sometime be required.
- Operating upstream pump stations to maintain aerobic conditions in the wastewater.

At the pumping stations there should be minimum turbulence of the wastewater because turbulence promotes off-gassing of odorous compounds. Drop inlets into the wet well can and should be avoided. In stations with constant-speed pumps (like the one at Forest Lake Estates), the use of sloping approach pipes with inverts at or slightly below the low water level are desirable (even though its crown may be submerged at the high water level). However, if the inlet pipe crown remains submerged for an extended period, foul air will be trapped in the influent pipe, and the foul air will be forced out of manholes upstream from the pump stations. Variable-speed pumping is highly desirable because matching water elevations in sewer and wet well allows smooth, nonturbulent entry into the wet well.

The pump station wet well should also be operated to minimize stagnation and the settling of solids. These deposits are anaerobic and produce odorous compounds that diffuse into the liquid above and thence into the air. Stagnation also allows biofilm/bio-slime layers to form on

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

submerged walls of the wet wells and on wetted surfaces, including the inside surface of the collection sewers and force mains that also can produce odors.

In general, it important to keep the collection system pipe velocities high enough to keep the domestic wastewater aerobic, promote scour, and eliminate odor-producing deposits in the pipes. Force main velocities of 3.4 to 4.0 ft/s occurring at least once per day and frequent wet well cleaning are also advisable to minimize problems.

As evidenced in Patrick Flynn's June 08, 2009 e-mail to Tom Gucciardo regarding Mr. Johnston's odor complaints,

*"... Mr. Johnston's complaints correlate with the diurnal flow pattern at this time of year. The twice a day peak flow pattern may push raw wastewater to the surge tanks after the wastewater experiences a significant detention time in the collection system, caused primarily by the low occupancy of the community at this time of year but also because individuals are using less water in their homes. ..."*

the minimization of stagnation within the wastewater collection system and pumping station wet wells along with the proper operation of these systems are critically important to minimize the odors from the wastewater facilities at Forest Lake Estates.

**Odor Control Practices in the Wastewater-Collection System**

There is also a host of chemicals that can be added to wastewater to inhibit or treat odorous compounds, thus minimizing off-gassing and subsequent odor problems. LUI has been applying the Siemens Water Technologies odor control product "Bioxide®" into the wastewater stream at the pump station wet well prior to its delivery to the wastewater treatment facility via a force main.

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

As stated in Siemens Bioxide® technical literature,

*" How BIOXIDE® solution works*

*BIOXIDE® solution is a process which controls hydrogen sulfide odors and corrosion biologically. Introduction of nitrate oxygen via addition of BIOXIDE® solution into a waste stream creates an environment in which certain naturally occurring bacteria thrive. These bacteria utilize the dissolved hydrogen sulfide which is present as a part of their metabolism, thereby cost effectively removing any dissolved hydrogen sulfide from the wastewater. As a result, BIOXIDE® solution both removes dissolved hydrogen sulfide and prevents its formation."*

wastewater in sewers is capable of microbial oxidation of dissolved H<sub>2</sub>S under anoxic conditions (nitrates present but not D.O), but chemical oxidation is either non-existent or occurs at a very low rate. The observed rate of microbial anoxic sulfide oxidation rates were only 16-21% of aerobic rates (Yang *et al.* 2005). For nitrate to work effectively, at least 2 hours of detention time is needed upstream from the problem area. <sup>(3)</sup>

Although we were unable to verify the detention time without the design drawings and calculations, which LUI refused to provide, we suspect that there may not be sufficient detention time within the collection system from where the BIOXIDE® solution is added to the wastewater treatment facility for the solution to be fully effective.

**Odor Control Practices at the Wastewater-Treatment Facility**

LUI's odor management practices also include odor containment and treatment at the wastewater treatment facility. Their odor containment included the installation of covers over the headworks and surge tanks, as well as collection piping and air handling equipment for containing and directing odorous gases to activated-carbon adsorbers.

With the large variation in pollutant concentrations coming to the treatment facility over the course of the day, the containment of foul air is not always easy and simply covering the surge tanks and attempting to pull the foul air through a number of activated-carbon adsorbers is not an effective way of containing and treating the foul air emanating from the LUI wastewater treatment facility.

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

A good first step in designing a foul air treatment system is to develop a reliable containment and ventilation system that brings all the foul air to the treatment device. Containment and ventilation is not easily achieved however, because of the large volume of air introduced into the surge tanks purges and dilutes the gases from the wastewater stream (which may be heavier than air). Odor containment of these tanks would require the installation of tightly fitting covers, as well as, air handling and treatment equipment large enough to maintain a slight negative pressure (vacuum) within the containment and is one of the factors why foul air treatment is often the most costly type of odor control and should be avoided unless absolutely necessary.

LUI's odor management practices also include the use of odor masking and/or neutralization at the wastewater treatment facility. This practice involves adding chemicals into the offgases to mask an offensive odor with a less offensive odor. Typically, enough masking chemical is added to try to overpower the offensive odor. Masking chemicals, however, do not modify or neutralize the offensive odors. Neutralization involves finding chemical compounds that can be combined with the odorous gases in the vapor state so that the combined gases cancel each other's odor, produce an odor of lower intensity, or eliminate the odorous compounds. Although odor masking and neutralization may have served as short-term mitigative measures, with varying degrees of success, this approach should not be used to mask toxic gases such as H<sub>2</sub>S. The key to long-term odor management is to identify the source(s) of the odors and implement corrective measures beyond odor masking.

Although not observed during our site visit to the LUI facility, other typical significant sources of odors at the wastewater treatment facility could include; the sludge-thickening areas, during times when the aerobic digesters are decanted; the sludge-loadout areas, when the sludge is being processed in the roll-off boxes; and at the grit and screening area, when the LUI facility does not use covered airtight containers to store the grit and screenings, especially in the warmer months. These sources should also be addressed as part of a comprehensive odor control evaluation of the facility during the design phase of any odor control improvement program.

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

**Movement of Odors from Wastewater Treatment Facilities**

There is one additional reference, included within the fourth edition of Metcalf & Eddy, Wastewater Engineering Treatment and Reuse Manual, that describes a meteorological condition that correlated with an overwhelming number of odor complaints from the LUI wastewater treatment facility. This may explain why the odors can be observed throughout the community and not at the wastewater treatment facility.

*"Under quiescent meteorological conditions, odorous gases that develop at treatment facilities tend to hover over the point of generation, because the odorous gases are more dense than air. Depending on the local meteorological conditions, it has been observed that odors may be measured at undiluted concentrations at great distances from the point of generation. The following events appear to happen: (1) in the evening or early morning hours, under quiescent meteorological conditions, a cloud of odors will develop over the wastewater treatment unit prone to the release of odors; and (2) the concentrated cloud of odors can then be transported (i.e., pushed along) without breaking up, over great distances by the weak evening or early morning breezes, as they develop. In some cases, odors have been detected at distances of up to 25 km from their source. This transport phenomenon has been termed the puff movement of odors (Tchobanoglous and Schroeder, 1985). The puff movement of odors was first described by Wilson (1975). The most common method used to mitigate the effects of the odor puff is to install barriers to induce turbulence, thus breaking up and dispersing the cloud of concentrated odors, and/or to use wind generators to maintain a minimum velocity across the source."* <sup>(1)</sup>

**CONCLUSIONS AND RECOMMENDATIONS**

Based on our review, we find there is overwhelming evidence that the operations of the wastewater – collection, treatment, and disposal LUI-operated facility that serve Forest Lake Estates have the potential to generate significant malodorous conditions in the community and that a comprehensive odor control evaluation and improvement program is needed to mitigate the odor issues with the LUI facilities.

The information contained herein provides a general overview of some of the potential improvements needed to the LUI wastewater facility infrastructure regarding the odor issues. Considerably more information is needed to conduct a comprehensive odor control evaluation, and information about the design and operations of the LUI facility (which LUI refused to

engineers | scientists | innovators

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

provide) and wastewater entering the LUI treatment facility is crucial. The details of the upstream collection system (including the operation of upstream pumping stations); the sources, kinds, and amounts of wastewater; and other information regarding the design and construction of the LUI physical facility are all vital.

There are generally four odor control strategies that should be utilized to control odors at the wastewater facilities. These are, in order of likely effectiveness:

- Minimizing or preventing production of odorous compounds;
- Treating odorous compounds within the liquid phase;
- Containing and treating foul air (treatment should not be just with odor masking measures and especially when toxic gases are the cause of odors); and
- Enhancing atmospheric dispersion of foul air.

The specific method of odor control and treatment that should be applied will vary with local conditions and regulatory requirements. However, because odor-control measures are expensive, the cost of making process changes or modifications to the LUI facilities to eliminate odor development should always be evaluated and compared to the cost of various alternative odor-control measures before adoption is suggested. With thorough attention to details, such as the use of submerged inlets and weirs, the elimination of physical conditions leading to the formation of odors, proper chemical loadings, containment of odor sources, off-gas treatment, and good housekeeping, the routine release of odors at wastewater treatment facilities can be minimized.

\* \* \* \* \*

*Privileged and Confidential Work Product  
Prepared at the Request of Counsel*

**REFERENCES**

1. Metcalf & Eddy, Inc., 2003. *Wastewater Engineering: Treatment and Reuse*, 4<sup>th</sup> Edition. The McGraw-Hill Companies. New York, New York.
2. Viessman, Warren Jr. and Hammer, Mark J., 2003. *Water Supply and Pollution Control*, 7<sup>th</sup> Edition. Pearson Education, Inc., Upper Saddle River, NJ.
3. Speece, R. E., 2008. *Anaerobic Biotechnology and Odor/Corrosion Control for Municipalities and Industries*. Archae Press, Nashville, Tennessee.
4. Jones, Garr M., 2008. *Pumping Station Design*, 3<sup>rd</sup> Edition. Butterworth-Heinemann, Burlington, MA.
5. Water Environment Federation (WEF) and American Society of Civil Engineers (ASCE), 1998. *ASCE Manual of Practice No. 76, WEF Manual of Practice No. 8 Design of Municipal Wastewater Treatment Plants*, 4<sup>th</sup> Edition, Volumes 1, 2, & 3. WEF / ASCE. Alexandria, VA / Reston, VA.
6. Reynolds, Tom D. and Richards, Paul A., 1996. *Unit Operations and Processes in Environmental Engineering*, 2<sup>nd</sup> Edition. PWS Publishing Co., Boston, MA.
7. EPA, 1992, *Detection, Control and Correction of Hydrogen Sulfide Corrosion in Existing Wastewater Systems*. EPA 832-R-92-001. September.
8. EPA, 1974. *Process Design Manual for Sulfide Control in Sanitary Sewerage Systems*
9. EPA, 2005. *Guide for Evaluating Capacity, Management, Operation, and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems*, EPA 305-B-05-002 [http://www.epa.gov/npdes/pubs/cmom\\_guide\\_for\\_collection\\_systems.pdf](http://www.epa.gov/npdes/pubs/cmom_guide_for_collection_systems.pdf)
10. American Society of Civil Engineers, 2007, *ASCE Manual of Practice No. 60, WEF Manual of Practice No. FD-5 Gravity Sanitary Sewer Design and Construction*, WEF / ASCE. Alexandria, VA / Reston, VA.