



RECEIVED FPSC
MAR 30 AM 11:58
COMMISSION
CLERK

March 30, 2012

VIA HAND DELIVERY

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Ten-Year Site Plan as of December 31, 2011*

Dear Ms. Cole:

Pursuant to Rule 25-22.071, F.A.C., please find enclosed for filing the original and twenty-five (25) copies of Progress Energy Florida, Inc.'s 2012 Ten-Year Site Plan.

Thank you for your assistance in this matter. Please feel free to call me at (727) 820-5184 should you have any questions.

Sincerely,

John T. Burnett

COM _____
APA _____
ECR _____
GCL 2
RAD 22
SRC _____
ADM _____
OPC _____
CLK 1-original

JTB:at
Enclosures

DOCUMENT NUMBER-DATE

01878 MAR 30 2012

FPSC-COMMISSION CLERK

Progress Energy Florida, Inc. Ten-Year Site Plan

April 2012

2012-2021

**Submitted to:
Florida Public Service Commission**



DOCUMENT NUMBER-DATE
01878 MAR 30 2012
FPSC-COMMISSION CLERK

TABLE OF CONTENTS

| | Page |
|---|-------------|
| List of Required Schedules..... | iii |
| List of Tables and Figures..... | iv |
| Code Identification Sheet..... | v |
| Introduction..... | 1 |
| | |
| <u>CHAPTER 1 DESCRIPTION OF EXISTING FACILITIES</u> | |
| Existing Facilities Overview..... | 1-1 |
| Service Area Map (Figure 1.1)..... | 1-3 |
| Existing Generating Facilities (Schedule 1)..... | 1-4 |
| | |
| <u>CHAPTER 2 FORECAST OF ELECTRIC POWER DEMAND AND ENERGY CONSUMPTION</u> | |
| Overview..... | 2-1 |
| Energy Consumption and Demand Forecast Schedules..... | 2-2 |
| History and Forecast of Energy Consumption and Number of Customers by Customer Class (Sch. 2.1-2.3).... | 2-3 |
| History and Forecast of Base Summer Peak Demand (MW) (Sch. 3.1)..... | 2-6 |
| History and Forecast of Base Winter Peak Demand (MW) (Sch. 3.2)..... | 2-7 |
| History and Forecast of Base Annual Net Energy for Load (GWh) (Sch. 3.3)..... | 2-8 |
| Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month (Sch. 4)... | 2-9 |
| Fuel Requirements and Energy Sources..... | 2-10 |
| Fuel Requirements (Sch. 5)..... | 2-11 |
| Energy Sources (GWh) (Sch. 6.1)..... | 2-12 |
| Energy Sources (Percent) (Sch. 6.2)..... | 2-13 |
| Forecasting Methods and Procedures..... | 2-14 |
| Introduction..... | 2-14 |
| Forecast Assumptions..... | 2-14 |
| Customer, Energy, and Demand Forecast (Figure 2.1)..... | 2-15 |
| General Assumptions..... | 2-16 |
| Short-Term Economic Assumptions..... | 2-18 |
| Long-Term Economic Assumptions..... | 2-19 |
| Forecast Methodology..... | 2-20 |
| Energy and Customer Forecast..... | 2-21 |
| Peak Demand Forecast..... | 2-24 |

TABLE OF CONTENTS (Continued)

Conservation 2-26

 Residential Programs..... 2-27

 Commercial/Industrial (C/I) Programs..... 2-29

 Research and Development Programs..... 2-31

CHAPTER 3 FORECAST OF FACILITIES REQUIREMENTS

Resource Planning Forecast..... 3-1

 Overview of Current Forecast..... 3-1

 Total Capacity Resources Of Power Plants and Purchased Power Contracts (Table 3.1)..... 3-3

 Qualifying Facility Generation Contracts (Table 3.2)..... 3-4

 Forecast of Capacity, Demand and Scheduled Maintenance at Time of Summer Peak (Sch. 7.1)..... 3-5

 Forecast of Capacity, Demand and Scheduled Maintenance at Time of Winter Peak (Sch. 7.2)..... 3-6

 Planned and Prospective Generating Facility Additions and Changes (Sch. 8)..... 3-7

 Status Report and Specifications of Proposed Generating Facilities (Sch. 9)..... 3-8

 Status Report and Specifications of Proposed Directly Associated Transmission Lines (Sch. 10)..... 3-10

Integrated Resource Planning Overview..... 3-16

 Integrated Resource Planning (IRP) Process Overview (Figure 3.1)..... 3-17

 The Integrated Resource Planning (IRP) Process..... 3-18

 Key Corporate Forecasts..... 3-20

 Ten-year Site Plan (TYSP) Resource Additions..... 3-21

 Renewable Energy..... 3-21

 Plan Considerations..... 3-22

Transmission Planning..... 3-23

 List of Proposed Bulk Transmission Line Additions (Table 3.3)..... 3-24

CHAPTER 4 ENVIRONMENTAL AND LAND USE INFORMATION

Preferred Sites..... 4-1

Levy County Nuclear Power Plant – Levy County..... 4-1

 Levy County Nuclear Power Plant (Levy County) (Figure 4.1)..... 4-4

**LIST OF
REQUIRED SCHEDULES**

| <u>Schedule</u> | <u>Page</u> |
|--|--------------------|
| 1 Existing Generating Facilities..... | 1-4 |
| 2.1 History and Forecast of Energy Consumption and Number of Customers by Customer Class (Rural and Residential and Commercial)..... | 2-3 |
| 2.2 History and Forecast of Energy Consumption and Number of Customers by Customer Class (Industrial and Other)..... | 2-4 |
| 2.3 History and Forecast of Energy Consumption and Number of Customers by Customer Class (Net Energy for Load)..... | 2-5 |
| 3.1 History and Forecast of Summer Peak Demand (MW) - Base Case..... | 2-6 |
| 3.2 History and Forecast of Winter Peak Demand (MW) - Base Case..... | 2-7 |
| 3.3 History and Forecast of Annual Net Energy for Load (GWh) - Base Case..... | 2-8 |
| 4 Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month..... | 2-9 |
| 5 Fuel Requirements..... | 2-11 |
| 6.1 Energy Sources (GWh)..... | 2-12 |
| 6.2 Energy Sources (Percent)..... | 2-13 |
| 7.1 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak..... | 3-5 |
| 7.2 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak..... | 3-6 |
| 8 Planned and Prospective Generating Facility Additions and Changes..... | 3-7 |
| 9 Status Report and Specifications of Proposed Generating Facilities..... | 3-8 |
| 10 Status Report and Specifications of Proposed Directly Associated Transmission Lines..... | 3-10 |

LIST OF
TABLES AND FIGURES

| <u>Tables</u> | | <u>Page</u> |
|-----------------------|---|--------------------|
| 3.1 | Total Capacity Resources of Power Plants and Purchased Power Contracts..... | 3-3 |
| 3.2 | Qualifying Facility Generation Contracts..... | 3-4 |
| 3.3 | List of Proposed Bulk Transmission Line Additions..... | 3-24 |
| | | |
| <u>Figures</u> | | <u>Page</u> |
| 1.1 | Service Area Map..... | 1-3 |
| 2.1 | Customer, Energy, and Demand Forecast..... | 2-15 |
| 3.1 | Integrated Resource Planning (IRP) Process Overview..... | 3-17 |
| 4.1.a. | Levy County Nuclear Power Plant (Levy County)..... | 4-4 |
| 4.1.b. | Levy County Nuclear Power Plant (Levy County) – Aerial View..... | 4-5 |

CODE IDENTIFICATION SHEET

Generating Unit Type

ST - Steam Turbine - Non-Nuclear
NP - Steam Power - Nuclear
GT - Gas Turbine
CT - Combustion Turbine
CC - Combined Cycle
SPP - Small Power Producer
COG - Cogeneration Facility

Fuel Type

NUC - Nuclear (Uranium)
NG - Natural Gas
RFO - No. 6 Residual Fuel Oil
DFO - No. 2 Distillate Fuel Oil
BIT - Bituminous Coal
MSW - Municipal Solid Waste
WH - Waste Heat
BIO - Biomass

Fuel Transportation

WA - Water
TK - Truck
RR - Railroad
PL - Pipeline
UN - Unknown

Future Generating Unit Status

A - Generating unit capability increased
D - Generating unit capability decreased
FC - Existing generator planned for conversion to another fuel or energy source
P - Planned for installation but not authorized; not under construction
RP - Proposed for repowering or life extension
RT - Existing generator scheduled for retirement
T - Regulatory approval received but not under construction
U - Under construction, less than or equal to 50% complete
V - Under construction, more than 50% complete

INTRODUCTION

Section 186.801 of the Florida Statutes requires electric generating utilities to submit a Ten-Year Site Plan (TYSP) to the Florida Public Service Commission (FPSC). The TYSP includes historical and projected data pertaining to the utility's load and resource needs as well as a review of those needs. Florida Power Corporation doing business as (d/b/a) Progress Energy Florida, Inc.'s TYSP is compiled in accordance with FPSC Rules 25-22.070 through 22.072, Florida Administrative Code.

Progress Energy Florida, Inc.'s (PEF) TYSP is based on the projections of long-term planning requirements that are dynamic in nature and subject to change. These planning documents should be used for general guidance concerning PEF's planning assumptions and projections, and should not be taken as an assurance that particular events discussed in the TYSP will materialize or that particular plans will be implemented. Information and projections pertinent to periods further out in time are inherently subject to greater uncertainty.

This TYSP document contains four chapters as indicated below:

- **CHAPTER 1 - DESCRIPTION OF EXISTING FACILITIES**

This chapter provides an overview of PEF's generating resources as well as the transmission and distribution system.

- **CHAPTER 2 - FORECAST OF ELECTRICAL POWER DEMAND AND ENERGY CONSUMPTION**

Chapter 2 presents the history and forecast for load and peak demand as well as the forecast methodology used. Demand-Side Management (DSM) savings and fuel requirement projections are also included.

- **CHAPTER 3 - FORECAST OF FACILITIES REQUIREMENTS**

The resource planning forecast, transmission planning forecast as well as the proposed generating facilities and bulk transmission line additions status are discussed in Chapter 3.

- **CHAPTER 4 - ENVIRONMENTAL AND LAND USE INFORMATION**

Preferred and potential site locations along with any environmental and land use information are presented in this chapter.

CHAPTER 1

*DESCRIPTION OF
EXISTING FACILITIES*



CHAPTER 1
DESCRIPTION OF EXISTING FACILITIES

EXISTING FACILITIES OVERVIEW

OWNERSHIP

Florida Power Corporation d/b/a Progress Energy Florida, Inc. (PEF or the Company) is a wholly owned subsidiary of Progress Energy, Inc. (Progress Energy). Congress enacted legislation in 2005 repealing the Public Utilities Holding Company Act of 1935 (PUHCA) effective February 8, 2006. Subsequent to that date, Progress Energy is no longer subject to regulation by the Securities and Exchange Commission as a public utility holding company.

AREA OF SERVICE

PEF has an obligation to serve approximately 1.6 million customers in Florida. Its service area covers approximately 20,000 square miles in west central Florida and includes the densely populated areas around Orlando, as well as the cities of Saint Petersburg and Clearwater. PEF is interconnected with 22 municipal and nine rural electric cooperative systems. PEF is subject to the rules and regulations of the Federal Energy Regulatory Commission (FERC), the Nuclear Regulatory Commission (NRC), and the Florida Public Service Commission (FPSC). PEF's Service Area is shown in Figure 1.1.

TRANSMISSION/DISTRIBUTION

The Company is part of a nationwide interconnected power network that enables power to be exchanged between utilities. The PEF transmission system includes approximately 5,000 circuit miles of transmission lines. The distribution system includes approximately 18,000 circuit miles of overhead distribution conductors and approximately 13,000 circuit miles of underground distribution cable.

ENERGY MANAGEMENT and ENERGY EFFICIENCY


The Company's residential Energy Management program represents a demand response type of program where participating customers help manage future growth and costs. Approximately 400,000 customers participated in the residential Energy Management program at the end of

2011, contributing about 639 MW of winter peak-shaving capacity for use during high load periods. PEF's currently approved DSM programs consist of six residential programs, eight commercial and industrial programs, one research and development program and six solar pilot programs.

TOTAL CAPACITY RESOURCE

As of December 31, 2011, PEF had total summer capacity resources of 11,828 MW consisting of installed capacity of 9,948 MW (excluding Crystal River Unit 3 joint ownership) and 1,880 MW of firm purchased power. Additional information on PEF's existing generating resources can be found in Schedule 1 and Table 3.1.

FIGURE 1.1
PROGRESS ENERGY FLORIDA
County Service Area Map



PROGRESS ENERGY FLORIDA

SCHEDULE I
EXISTING GENERATING FACILITIES

AS OF DECEMBER 31, 2011

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) |
|-----------------------------|----------|-------------------|-----------|----------|----------|--------------------|--------------------|--------------------|--------------------------|-----------------------------|----------------------|--------------------------|--------------------------|
| PLANT NAME | UNIT NO. | LOCATION (COUNTY) | UNIT TYPE | FUEL PRI | FUEL ALT | FUEL TRANSPORT PRI | FUEL TRANSPORT ALT | ALT. FUEL DAYS USE | COM'L IN-SERVICE MO/YEAR | EXPECTED RETIREMENT MO/YEAR | GEN MAX NAMEPLATE KW | NET CAPABILITY SUMMER MW | NET CAPABILITY WINTER MW |
| STEAM | | | | | | | | | | | | | |
| ANCLOTE | 1 | PASCO | ST | RFO | NG | PL | PL | *** | 10/74 | | 556,200 | 501 | 517 |
| ANCLOTE | 2 | PASCO | ST | RFO | NG | PL | PL | *** | 10/78 | | 556,200 | 510 | 530 |
| CRYSTAL RIVER | 1 | CITRUS | ST | BIT | | RR | WA | | 10/66 | | 440,550 | 375 | 376 |
| CRYSTAL RIVER | 2 | CITRUS | ST | BIT | | RR | WA | | 11/69 | | 523,800 | 498 | 498 |
| CRYSTAL RIVER | 3 * | CITRUS | NP | NUC | | TK | | | 3/77 | | 890,460 | 789 | 805 |
| CRYSTAL RIVER | 4 | CITRUS | ST | BIT | | WA | RR | | 12/82 | | 739,260 | 712 | 721 |
| CRYSTAL RIVER | 5 | CITRUS | ST | BIT | | WA | RR | | 10/84 | | 739,260 | 710 | 721 |
| SUWANNEE RIVER | 1 | SUWANNEE | ST | NG | RFO | PL | TK/RR | *** | 11/53 | **** | 34,500 | 28 | 28 |
| SUWANNEE RIVER | 2 | SUWANNEE | ST | NG | RFO | PL | TK/RR | *** | 11/54 | **** | 37,500 | 30 | 30 |
| SUWANNEE RIVER | 3 | SUWANNEE | ST | NG | RFO | PL | TK/RR | *** | 10/56 | **** | 75,000 | 71 | 73 |
| | | | | | | | | | | | | 4,224 | 4,299 |
| COMBINED-CYCLE | | | | | | | | | | | | | |
| BARTOW | 4 | PINELLAS | CC | NG | DFO | PL | TK | *** | 6/09 | | 1,253,000 | 1,133 | 1,235 |
| HINES ENERGY COMPLEX | 1 | POLK | CC | NG | DFO | PL | TK | *** | 4/99 | | 546,500 | 462 | 528 |
| HINES ENERGY COMPLEX | 2 | POLK | CC | NG | DFO | PL | TK | *** | 12/03 | | 548,250 | 490 | 563 |
| HINES ENERGY COMPLEX | 3 | POLK | CC | NG | DFO | PL | TK | *** | 11/05 | | 561,000 | 488 | 564 |
| HINES ENERGY COMPLEX | 4 | POLK | CC | NG | DFO | PL | TK | *** | 12/07 | | 610,000 | 472 | 544 |
| TIGER BAY | 1 | POLK | CC | NG | | PL | | | 8/97 | | 278,100 | 205 | 227 |
| | | | | | | | | | | | | 3,250 | 3,661 |
| COMBUSTION TURBINE | | | | | | | | | | | | | |
| AVON PARK | P1 | HIGHLANDS | GT | NG | DFO | PL | TK | *** | 12/68 | **** | 33,790 | 24 | 35 |
| AVON PARK | P2 | HIGHLANDS | GT | DFO | | TK | | *** | 12/68 | **** | 33,790 | 24 | 35 |
| BARTOW | P1, P3 | PINELLAS | GT | DFO | | WA | | *** | 5/72, 6/72 | | 111,400 | 85 | 108 |
| BARTOW | P2 | PINELLAS | GT | NG | DFO | PL | WA | *** | 6/72 | | 55,700 | 43 | 57 |
| BARTOW | P4 | PINELLAS | GT | NG | DFO | PL | WA | *** | 6/72 | | 55,700 | 49 | 61 |
| BAYBORO | P1-P4 | PINELLAS | GT | DFO | | WA | | *** | 4/73 | | 226,800 | 174 | 233 |
| DEBARY | P1-P6 | VOLUSIA | GT | DFO | | TK | | *** | 12/75-4/76 | | 401,220 | 309 | 379 |
| DEBARY | P7-P9 | VOLUSIA | GT | NG | DFO | PL | TK | *** | 10/92 | | 345,000 | 247 | 287 |
| DEBARY | P10 | VOLUSIA | GT | DFO | | TK | | *** | 10/92 | | 115,000 | 82 | 97 |
| HIGGINS | P1-P2 | PINELLAS | GT | NG | DFO | PL | TK | *** | 3/69, 4/69 | **** | 67,580 | 45 | 45 |
| HIGGINS | P3-P4 | PINELLAS | GT | NG | DFO | PL | TK | *** | 12/70, 1/71 | **** | 85,850 | 60 | 71 |
| INTERCESSION CITY | P1-P6 | OSCEOLA | GT | DFO | | PL,TK | | *** | 5/74 | | 340,200 | 282 | 370 |
| INTERCESSION CITY | P7-P10 | OSCEOLA | GT | NG | DFO | PL | PL,TK | *** | 10/93 | | 460,000 | 328 | 379 |
| INTERCESSION CITY | P11 ** | OSCEOLA | GT | DFO | | PL,TK | | *** | 1/97 | | 165,000 | 143 | 161 |
| INTERCESSION CITY | P12-P14 | OSCEOLA | GT | NG | DFO | PL | PL,TK | *** | 12/00 | | 345,000 | 229 | 278 |
| RIO PINAR | P1 | ORANGE | GT | DFO | | TK | | *** | 11/70 | **** | 19,290 | 12 | 15 |
| SUWANNEE RIVER | P1, P3 | SUWANNEE | GT | NG | DFO | PL | TK | *** | 10/80, 11/80 | | 122,400 | 104 | 134 |
| SUWANNEE RIVER | P2 | SUWANNEE | GT | DFO | | TK | | *** | 10/80 | | 61,200 | 51 | 66 |
| TURNER | P1-P2 | VOLUSIA | GT | DFO | | TK | | *** | 10/70 | **** | 38,580 | 20 | 26 |
| TURNER | P3 | VOLUSIA | GT | DFO | | TK | | *** | 8/74 | | 71,200 | 56 | 77 |
| TURNER | P4 | VOLUSIA | GT | DFO | | TK | | *** | 8/74 | | 71,200 | 61 | 78 |
| UNIV. OF FLA. | P1 | ALACHUA | GT | NG | | PL | | | 1/94 | | 43,000 | 46 | 47 |
| | | | | | | | | | | | | 2,474 | 3,039 |
| TOTAL RESOURCES (MW) | | | | | | | | | | | | 9,948 | 10,999 |

* REPRESENTS PEFOWNSHIP OF UNIT WHICH IS APPROXIMATELY 918%.

** THE 143 MW SUMMER CAPABILITY (JUNE THROUGH SEPTEMBER) IS OWNED BY GEORGIA POWER COMPANY

*** APPROXIMATELY 2 TO 8 DAYS OF OIL USE TYPICALLY TARGETED FOR ENTIRE PLANT. RFO TO BE PHASED OUT WITH UNIT RETIREMENTS OR UNIT GAS CONVERSIONS

**** SUWANNEE STEAMUNITS ESTIMATED TO BE SHUTDOWN BY 6/2016. PEAKERS at AVON PARK, HIGGINS, RIO PINAR, TURNER P1 & P2 ARE ESTIMATED TO BE PLACED IN COLD STAND-BY OR RETIRED BY 6/2016.

CHAPTER 2

***FORECAST OF
ELECTRIC POWER DEMAND
AND ENERGY CONSUMPTION***



CHAPTER 2
FORECAST OF ELECTRIC POWER DEMAND
AND
ENERGY CONSUMPTION

OVERVIEW

The information presented in the following Schedules 2, 3, and 4 represents PEF's history and forecast of customers, energy sales (GWh), and peak demand (MW). PEF's customer growth is expected to average 1.5 percent between 2012 and 2021, which is slightly more than the ten-year historical average of 1.2 percent. County population growth rate projections from the University of Florida's Bureau of Economic and Business Research (BEBR) were incorporated into this projection. The severe housing crisis witnessed both nationwide and in Florida since 2007 has dampened the PEF historical ten-year growth rate significantly as total customer growth turned negative for a twenty-one month period during 2008, 2009 and 2010. Economic conditions going forward look more amenable to improved customer growth due to lower housing prices, improved housing affordability and a large retiring baby-boomer population.

Net energy for load (NEL) was flat between 2002 and 2011 due primarily to the recent economic recession and the associated weak economy that followed, and is continuing to bear down on the retail and wholesale sectors. The 2012 to 2021 period is expected to improve by an average growth rate of 1.4 percent per year due to expected higher economic growth that drives the retail jurisdiction back to more normal NEL growth rates. Going forward, projected NEL growth continues to reflect the FPSC approved DSM energy savings targets.

Summer net firm demand grew slightly during the last ten years but was dampened by the recessionary impacts. The projected ten year period summer net firm demand growth rate of 1.3 percent is primarily driven by a stronger economy improving net firm retail demand.

ENERGY CONSUMPTION AND DEMAND FORECAST SCHEDULES

The below schedules have been provided on the following pages:

| <u>SCHEDULE</u> | <u>DESCRIPTION</u> |
|------------------------|--|
| 2.1, 2.2 and 2.3 | History and Forecast of Energy Consumption and Number of Customers by Customer Class |
| 3.1 | History and Forecast of Summer Peak Demand (MW) |
| 3.2 | History and Forecast of Winter Peak Demand (MW) |
| 3.3 | History and Forecast of Annual Net Energy for Load (GWh) |
| 4 | Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month |

PROGRESS ENERGY FLORIDA

**SCHEDULE 2.1
HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
|------|-----------------------|--------------------------|--------|--------------------------------|--|--------|--------------------------------|--|
| YEAR | RURAL AND RESIDENTIAL | | | | COMMERCIAL | | | |
| | PEF POPULATION | MEMBERS PER HOUSEHOLD | GWh | AVERAGE NO. OF CUSTOMERS | AVERAGE KWh CONSUMPTION PER CUSTOMER | GWh | AVERAGE NO. OF CUSTOMERS | AVERAGE KWh CONSUMPTION PER CUSTOMER |
| 2002 | 3,197,823 | 2.457 | 18,754 | 1,301,515 | 14,409 | 11,420 | 150,577 | 75,842 |
| 2003 | 3,264,521 | 2.451 | 19,429 | 1,331,914 | 14,587 | 11,553 | 154,294 | 74,876 |
| 2004 | 3,339,365 | 2.447 | 19,347 | 1,364,677 | 14,177 | 11,734 | 158,780 | 73,898 |
| 2005 | 3,428,268 | 2.454 | 19,894 | 1,397,012 | 14,240 | 11,945 | 161,001 | 74,190 |
| 2006 | 3,504,907 | 2.448 | 20,021 | 1,431,743 | 13,983 | 11,975 | 162,774 | 73,568 |
| 2007 | 3,532,104 | 2.448 | 19,912 | 1,442,853 | 13,800 | 12,184 | 162,837 | 74,821 |
| 2008 | 3,561,743 | 2.458 | 19,328 | 1,449,041 | 13,339 | 12,139 | 162,569 | 74,669 |
| 2009 | 3,564,397 | 2.473 | 19,399 | 1,441,325 | 13,459 | 11,883 | 161,390 | 73,632 |
| 2010 | 3,621,408 | 2.495 | 20,524 | 1,451,466 | 14,140 | 11,896 | 161,674 | 73,579 |
| 2011 | 3,573,037 | 2.460 | 19,238 | 1,452,454 | 13,245 | 11,892 | 162,071 | 73,374 |
| 2012 | 3,594,716 | 2.461 | 18,539 | 1,460,673 | 12,692 | 11,636 | 163,139 | 71,326 |
| 2013 | 3,635,569 | 2.462 | 18,674 | 1,476,673 | 12,646 | 11,672 | 164,884 | 70,789 |
| 2014 | 3,695,931 | 2.463 | 18,979 | 1,500,581 | 12,648 | 11,816 | 167,897 | 70,376 |
| 2015 | 3,766,648 | 2.464 | 19,370 | 1,528,672 | 12,671 | 12,015 | 171,659 | 69,993 |
| 2016 | 3,828,742 | 2.465 | 19,722 | 1,553,242 | 12,697 | 12,228 | 175,567 | 69,649 |
| 2017 | 3,889,195 | 2.466 | 20,077 | 1,577,127 | 12,730 | 12,394 | 179,280 | 69,132 |
| 2018 | 3,948,512 | 2.467 | 20,438 | 1,600,532 | 12,770 | 12,521 | 182,609 | 68,567 |
| 2019 | 4,007,195 | 2.468 | 20,811 | 1,623,661 | 12,817 | 12,638 | 185,883 | 67,989 |
| 2020 | 4,065,737 | 2.469 | 21,188 | 1,646,714 | 12,867 | 12,757 | 189,130 | 67,451 |
| 2021 | 4,122,852 | 2.469 | 21,576 | 1,669,847 | 12,921 | 12,878 | 192,375 | 66,942 |

PROGRESS ENERGY FLORIDA

SCHEDULE 2.2
HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) |
|------|------------|--------------------------------|--|----------------------------------|--|--|--|
| YEAR | INDUSTRIAL | | | RAILROADS AND RAILWAYS GWh | STREET & HIGHWAY LIGHTING GWh | OTHER SALES TO PUBLIC AUTHORITIES GWh | TOTAL SALES TO ULTIMATE CONSUMERS GWh |
| | GWh | AVERAGE NO. OF CUSTOMERS | AVERAGE KWh CONSUMPTION PER CUSTOMER | | | | |
| 2002 | 3,835 | 2,535 | 1,512,821 | 0 | 28 | 2,822 | 36,859 |
| 2003 | 4,001 | 2,643 | 1,513,810 | 0 | 29 | 2,946 | 37,958 |
| 2004 | 4,069 | 2,733 | 1,488,840 | 0 | 28 | 3,016 | 38,194 |
| 2005 | 4,140 | 2,703 | 1,531,632 | 0 | 27 | 3,171 | 39,176 |
| 2006 | 4,160 | 2,697 | 1,542,455 | 0 | 27 | 3,249 | 39,432 |
| 2007 | 3,819 | 2,668 | 1,431,409 | 0 | 26 | 3,341 | 39,282 |
| 2008 | 3,786 | 2,587 | 1,463,471 | 0 | 26 | 3,276 | 38,555 |
| 2009 | 3,285 | 2,487 | 1,320,869 | 0 | 26 | 3,230 | 37,824 |
| 2010 | 3,219 | 2,481 | 1,297,461 | 0 | 26 | 3,260 | 38,925 |
| 2011 | 3,243 | 2,408 | 1,346,761 | 0 | 25 | 3,200 | 37,598 |
| 2012 | 3,151 | 2,400 | 1,312,917 | 0 | 25 | 3,065 | 36,416 |
| 2013 | 3,057 | 2,400 | 1,273,750 | 0 | 24 | 3,062 | 36,489 |
| 2014 | 2,969 | 2,400 | 1,237,083 | 0 | 24 | 3,155 | 36,943 |
| 2015 | 3,049 | 2,400 | 1,270,417 | 0 | 24 | 3,298 | 37,756 |
| 2016 | 3,066 | 2,400 | 1,277,500 | 0 | 23 | 3,432 | 38,471 |
| 2017 | 3,110 | 2,400 | 1,295,833 | 0 | 23 | 3,547 | 39,151 |
| 2018 | 3,198 | 2,400 | 1,332,500 | 0 | 23 | 3,640 | 39,820 |
| 2019 | 3,285 | 2,400 | 1,368,750 | 0 | 23 | 3,732 | 40,489 |
| 2020 | 3,374 | 2,400 | 1,405,833 | 0 | 23 | 3,824 | 41,166 |
| 2021 | 3,413 | 2,400 | 1,422,083 | 0 | 23 | 3,916 | 41,806 |

PROGRESS ENERGY FLORIDA

SCHEDULE 2.3
HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS

| (1) | (2) | (3) | (4) | (5) | (6) |
|------|----------------------------|--------------------------------|-------------------------------|-------------------------------------|------------------------------|
| YEAR | SALES FOR RESALE GWh | UTILITY USE & LOSSES GWh | NET ENERGY FOR LOAD GWh | OTHER CUSTOMERS (AVERAGE NO.) | TOTAL NO. OF CUSTOMERS |
| 2002 | 3,173 | 2,535 | 42,567 | 21,155 | 1,475,783 |
| 2003 | 3,359 | 2,594 | 43,911 | 21,665 | 1,510,516 |
| 2004 | 4,301 | 2,773 | 45,268 | 22,437 | 1,548,627 |
| 2005 | 5,195 | 2,507 | 46,878 | 22,701 | 1,583,417 |
| 2006 | 4,220 | 2,389 | 46,041 | 23,182 | 1,620,396 |
| 2007 | 5,598 | 2,753 | 47,633 | 24,010 | 1,632,368 |
| 2008 | 6,619 | 2,484 | 47,658 | 24,738 | 1,638,935 |
| 2009 | 3,696 | 2,604 | 44,124 | 24,993 | 1,630,195 |
| 2010 | 3,493 | 3,742 | 46,160 | 25,212 | 1,640,833 |
| 2011 | 2,712 | 2,180 | 42,490 | 25,228 | 1,642,161 |
| 2012 | 2,635 | 2,483 | 41,534 | 25,186 | 1,651,398 |
| 2013 | 2,112 | 2,372 | 40,973 | 25,248 | 1,669,205 |
| 2014 | 3,017 | 2,592 | 42,552 | 25,696 | 1,696,574 |
| 2015 | 3,353 | 2,524 | 43,633 | 26,346 | 1,729,077 |
| 2016 | 2,684 | 2,441 | 43,596 | 27,002 | 1,758,211 |
| 2017 | 2,068 | 2,604 | 43,823 | 27,703 | 1,786,510 |
| 2018 | 2,068 | 2,645 | 44,533 | 28,289 | 1,813,830 |
| 2019 | 2,640 | 2,725 | 45,854 | 28,865 | 1,840,809 |
| 2020 | 2,683 | 2,727 | 46,576 | 29,438 | 1,867,682 |
| 2021 | 2,608 | 2,766 | 47,180 | 30,010 | 1,894,632 |

PROGRESS ENERGY FLORIDA

SCHEDULE 3.1
HISTORY AND FORECAST OF SUMMER PEAK DEMAND (MW)
BASE CASE

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (OTH) | (10) |
|------|--------|-----------|--------|---------------|-----------------------------------|-----------------------------|-----------------------------------|-----------------------------|-------------------------------|--------------------|
| YEAR | TOTAL | WHOLESALE | RETAIL | INTERRUPTIBLE | RESIDENTIAL LOAD MANAGEMENT | RESIDENTIAL CONSERVATION | COMM. / IND LOAD MANAGEMENT | COMM. / IND CONSERVATION | OTHER DEMAND REDUCTIONS | NET FIRM DEMAND |
| 2002 | 9,423 | 1,203 | 8,220 | 305 | 392 | 155 | 43 | 160 | 75 | 8,294 |
| 2003 | 8,883 | 887 | 7,996 | 300 | 355 | 170 | 44 | 162 | 75 | 7,776 |
| 2004 | 9,585 | 1,071 | 8,514 | 531 | 331 | 186 | 39 | 164 | 110 | 8,224 |
| 2005 | 10,352 | 1,118 | 9,234 | 448 | 310 | 204 | 38 | 167 | 110 | 9,074 |
| 2006 | 10,149 | 1,257 | 8,892 | 329 | 307 | 224 | 37 | 171 | 66 | 9,016 |
| 2007 | 10,933 | 1,544 | 9,389 | 334 | 291 | 241 | 45 | 178 | 110 | 9,735 |
| 2008 | 10,595 | 1512 | 9,083 | 500 | 284 | 256 | 66 | 193 | 110 | 9,186 |
| 2009 | 10,856 | 1618 | 9,238 | 262 | 291 | 272 | 84 | 213 | 110 | 9,624 |
| 2010 | 10,241 | 1272 | 8,969 | 271 | 304 | 298 | 96 | 233 | 110 | 8,929 |
| 2011 | 9,970 | 934 | 9,036 | 227 | 317 | 330 | 99 | 253 | 110 | 8,634 |
| 2012 | 10,393 | 1,093 | 9,300 | 275 | 329 | 360 | 103 | 269 | 135 | 8,922 |
| 2013 | 10,276 | 804 | 9,472 | 257 | 334 | 387 | 107 | 283 | 191 | 8,717 |
| 2014 | 10,363 | 705 | 9,658 | 241 | 339 | 413 | 111 | 294 | 191 | 8,773 |
| 2015 | 10,607 | 705 | 9,902 | 253 | 344 | 437 | 116 | 302 | 191 | 8,964 |
| 2016 | 10,659 | 555 | 10,104 | 254 | 349 | 457 | 120 | 310 | 191 | 8,978 |
| 2017 | 10,969 | 656 | 10,313 | 263 | 389 | 475 | 124 | 316 | 191 | 9,210 |
| 2018 | 11,164 | 656 | 10,508 | 267 | 394 | 491 | 128 | 322 | 191 | 9,370 |
| 2019 | 11,620 | 906 | 10,714 | 283 | 399 | 506 | 132 | 328 | 191 | 9,781 |
| 2020 | 11,825 | 906 | 10,919 | 298 | 404 | 523 | 137 | 333 | 191 | 9,939 |
| 2021 | 11,923 | 806 | 11,117 | 306 | 409 | 538 | 141 | 337 | 191 | 10,000 |

Historical Values (2002 - 2011):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2012 - 2021):

Cols. (2) - (4) = forecasted peak without load control, conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

PROGRESS ENERGY FLORIDA

SCHEDULE 3.2
HISTORY AND FORECAST OF WINTER PEAK DEMAND (MW)
BASE CASE

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (OTH) | (10) |
|---------|--------|-----------|--------|---------------|-----------------------------------|-----------------------------|-----------------------------------|------------------------------|-------------------------------|--------------------|
| YEAR | TOTAL | WHOLESALE | RETAIL | INTERRUPTIBLE | RESIDENTIAL LOAD MANAGEMENT | RESIDENTIAL CONSERVATION | COMM / IND. LOAD MANAGEMENT | COMM. / IND. CONSERVATION | OTHER DEMAND REDUCTIONS | NET FIRM DEMAND |
| 2001/02 | 10,684 | 1,624 | 9,060 | 285 | 822 | 284 | 24 | 122 | 189 | 8,957 |
| 2002/03 | 11,553 | 1,538 | 10,015 | 271 | 795 | 312 | 27 | 123 | 191 | 9,833 |
| 2003/04 | 9,324 | 1,167 | 8,157 | 498 | 788 | 342 | 26 | 123 | 262 | 7,284 |
| 2004/05 | 10,831 | 1,600 | 9,231 | 575 | 779 | 371 | 26 | 124 | 283 | 8,673 |
| 2005/06 | 10,699 | 1,467 | 9,232 | 298 | 762 | 413 | 26 | 125 | 239 | 8,855 |
| 2006/07 | 9,897 | 1,576 | 8,321 | 304 | 671 | 453 | 26 | 127 | 262 | 8,055 |
| 2007/08 | 10,965 | 1,828 | 9,137 | 234 | 763 | 487 | 34 | 133 | 278 | 9,036 |
| 2008/09 | 12,093 | 2,229 | 9,864 | 268 | 759 | 522 | 71 | 148 | 291 | 10,034 |
| 2009/10 | 13,699 | 2,189 | 11,510 | 230 | 651 | 567 | 80 | 163 | 322 | 11,686 |
| 2010/11 | 11,348 | 1,625 | 9,723 | 271 | 661 | 633 | 94 | 180 | 214 | 9,357 |
| 2011/12 | 11,589 | 1,392 | 10,197 | 257 | 639 | 720 | 99 | 183 | 249 | 9,442 |
| 2012/13 | 11,554 | 1,193 | 10,361 | 241 | 649 | 810 | 103 | 190 | 305 | 9,256 |
| 2013/14 | 11,351 | 805 | 10,546 | 226 | 659 | 905 | 107 | 194 | 306 | 8,954 |
| 2014/15 | 12,129 | 1,305 | 10,824 | 237 | 669 | 1,001 | 111 | 199 | 309 | 9,604 |
| 2015/16 | 12,385 | 1,306 | 11,079 | 238 | 679 | 1,079 | 115 | 202 | 311 | 9,761 |
| 2016/17 | 12,483 | 1,156 | 11,327 | 247 | 757 | 1,159 | 120 | 205 | 313 | 9,682 |
| 2017/18 | 12,732 | 1,156 | 11,576 | 251 | 767 | 1,238 | 124 | 208 | 315 | 9,829 |
| 2018/19 | 13,232 | 1,406 | 11,826 | 265 | 777 | 1,315 | 128 | 210 | 317 | 10,220 |
| 2019/20 | 13,475 | 1,406 | 12,069 | 279 | 787 | 1,389 | 132 | 213 | 319 | 10,356 |
| 2020/21 | 13,714 | 1,406 | 12,308 | 287 | 797 | 1,458 | 136 | 216 | 321 | 10,497 |

Historical Values (2002 - 2011):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2012 - 2021):

Cols. (2) - (4) forecasted peak without load control and conservation.

Cols. (5) - (9) = Represent cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

PROGRESS ENERGY FLORIDA

SCHEDULE 3.3
HISTORY AND FORECAST OF ANNUAL NET ENERGY FOR LOAD (GWh)
BASE CASE

| (1) | (2) | (3) | (4) | (OTH) | (5) | (6) | (7) | (8) | (9) |
|------|--------|-----------------------------|------------------------------|--------------------------------|--------|-----------|-------------------------|------------------------|--------------------------|
| YEAR | TOTAL | RESIDENTIAL CONSERVATION | COMM. / IND. CONSERVATION | OTHER ENERGY REDUCTIONS* | RETAIL | WHOLESALE | UTILITY USE & LOSSES | NET ENERGY FOR LOAD | LOAD FACTOR (%) ** |
| 2002 | 43,860 | 377 | 352 | 564 | 36,859 | 3,173 | 2,535 | 42,567 | 50.0 |
| 2003 | 45,233 | 402 | 357 | 564 | 37,957 | 3,359 | 2,595 | 43,911 | 47.7 |
| 2004 | 46,833 | 426 | 360 | 780 | 38,193 | 4,301 | 2,774 | 45,268 | 56.5 |
| 2005 | 48,474 | 455 | 363 | 779 | 39,177 | 5,195 | 2,506 | 46,878 | 52.3 |
| 2006 | 47,399 | 484 | 365 | 509 | 39,432 | 4,220 | 2,389 | 46,041 | 52.1 |
| 2007 | 49,310 | 511 | 387 | 779 | 39,282 | 5,598 | 2,753 | 47,633 | 52.3 |
| 2008 | 49,208 | 543 | 442 | 565 | 38,556 | 6,619 | 2,483 | 47,658 | 53.1 |
| 2009 | 45,978 | 583 | 492 | 779 | 37,824 | 3,696 | 2,604 | 44,124 | 44.5 |
| 2010 | 48,135 | 638 | 557 | 779 | 38,925 | 3,493 | 3,742 | 46,160 | 45.3 |
| 2011 | 44,574 | 691 | 614 | 779 | 37,597 | 2,712 | 2,181 | 42,490 | 46.7 |
| 2012 | 43,867 | 737 | 662 | 934 | 36,416 | 2,635 | 2,483 | 41,534 | 50.1 |
| 2013 | 43,737 | 782 | 707 | 1,275 | 36,489 | 2,112 | 2,372 | 40,973 | 50.5 |
| 2014 | 45,386 | 825 | 734 | 1,275 | 36,943 | 3,017 | 2,592 | 42,552 | 54.3 |
| 2015 | 46,527 | 860 | 758 | 1,275 | 37,756 | 3,353 | 2,524 | 43,633 | 51.9 |
| 2016 | 46,549 | 894 | 781 | 1,278 | 38,471 | 2,684 | 2,441 | 43,596 | 50.8 |
| 2017 | 46,821 | 921 | 801 | 1,275 | 39,151 | 2,068 | 2,604 | 43,823 | 51.7 |
| 2018 | 47,576 | 947 | 820 | 1,275 | 39,820 | 2,068 | 2,645 | 44,533 | 51.7 |
| 2019 | 48,940 | 972 | 839 | 1,275 | 40,489 | 2,640 | 2,725 | 45,854 | 51.2 |
| 2020 | 49,710 | 998 | 857 | 1,278 | 41,166 | 2,683 | 2,727 | 46,576 | 51.2 |
| 2021 | 50,354 | 1,023 | 875 | 1,275 | 41,806 | 2,608 | 2,766 | 47,180 | 51.3 |

* Column (OTH) includes Conservation Energy For Lighting and Public Authority Customers, Customer-Owned Self-service Cogeneration.

** Load Factors for historical years are calculated using the actual winter peak demand except the 2004 and 2007 historical load factors which are based on the actual summer peak demand.

Load Factors for future years are calculated using the net firm winter peak demand (Schedule 3.2)

PROGRESS ENERGY FLORIDA

SCHEDULE 4

PREVIOUS YEAR ACTUAL AND TWO-YEAR FORECAST OF PEAK DEMAND
AND NET ENERGY FOR LOAD BY MONTH

| (1) MONTH | (2) ACTUAL | | (4) FORECAST | | (6) FORECAST | |
|--------------|---------------|--------|-----------------|--------|-----------------|--------|
| | (3) 2011 | | (5) 2012 | | (7) 2013 | |
| | PEAK DEMAND | NEL | PEAK DEMAND | NEL | PEAK DEMAND | NEL |
| | MW | GWh | MW | GWh | MW | GWh |
| JANUARY | 9,585 | 3,296 | 10,551 | 3,173 | 10,363 | 3,129 |
| FEBRUARY | 7,395 | 2,754 | 8,561 | 2,797 | 8,355 | 2,728 |
| MARCH | 6,133 | 2,987 | 7,637 | 3,002 | 7,476 | 2,955 |
| APRIL | 8,187 | 3,535 | 7,923 | 3,020 | 7,828 | 2,977 |
| MAY | 8,443 | 3,884 | 8,882 | 3,761 | 8,741 | 3,704 |
| JUNE | 9,277 | 4,253 | 9,377 | 4,037 | 9,161 | 3,972 |
| JULY | 8,917 | 4,395 | 9,582 | 4,256 | 9,356 | 4,186 |
| AUGUST | 9,196 | 4,553 | 9,629 | 4,292 | 9,415 | 4,229 |
| SEPTEMBER | 8,207 | 3,992 | 9,012 | 3,878 | 8,800 | 3,835 |
| OCTOBER | 7,176 | 3,187 | 8,429 | 3,371 | 8,307 | 3,354 |
| NOVEMBER | 5,854 | 2,789 | 6,922 | 2,831 | 6,828 | 2,817 |
| DECEMBER | 5,043 | 2,865 | 7,979 | 3,116 | 7,869 | 3,087 |
| TOTAL | | 42,490 | | 41,534 | | 40,973 |

NOTE: Recorded Net Peak demands and System requirements including off-system wholesale contracts.

FUEL REQUIREMENTS AND ENERGY SOURCES

PEF's actual and projected nuclear, coal, oil, and gas requirements (by fuel unit) are shown in Schedule 5. PEF's two-year actual and ten-year projected energy sources by fuel type are presented in Schedules 6.1 and 6.2, in GWh and percent (%) respectively. PEF's fuel requirements and energy sources reflect a diverse fuel supply system that is not dependent on any one fuel source. Near term natural gas consumption is projected to increase as plants and purchases with tolling agreements are added to meet future load growth and natural gas generation costs reflect relatively attractive natural gas commodity pricing.

PROGRESS ENERGY FLORIDA

SCHEDULE 5
FUEL REQUIREMENTS

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|-------------------|--------------------|--------------------------------|--------------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | | | | -ACTUAL- | | | | | | | | | | | |
| FUEL REQUIREMENTS | | | UNITS | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 |
| (1) | NUCLEAR | | TRILLION BTU | 0 | 0 | 0 | 0 | 12 | 82 | 77 | 82 | 74 | 82 | 76 | 130 |
| (2) | COAL | | 1,000 TON | 5,201 | 4,663 | 5,107 | 5,749 | 5,998 | 4,170 | 4,330 | 4,421 | 4,393 | 4,150 | 3,998 | 3,254 |
| (3) | RESIDUAL | TOTAL | 1,000 BBL | 1,289 | 389 | 321 | 128 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (4) | | STEAM | 1,000 BBL | 1,289 | 380 | 321 | 128 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | CC | 1,000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CT | 1,000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | DIESEL | 1,000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | DISTILLATE | TOTAL | 1,000 BBL | 862 | 256 | 551 | 351 | 411 | 208 | 247 | 280 | 362 | 504 | 530 | 340 |
| (9) | | STEAM | 1,000 BBL | 65 | 61 | 102 | 84 | 85 | 78 | 72 | 75 | 79 | 78 | 73 | 140 |
| (10) | | CC | 1,000 BBL | 5 | 8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CT | 1,000 BBL | 792 | 187 | 449 | 268 | 327 | 130 | 175 | 204 | 283 | 426 | 456 | 200 |
| (12) | | DIESEL | 1,000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (13) | NATURAL GAS | TOTAL | 1,000 MCF | 182,956 | 183,363 | 175,677 | 165,093 | 171,088 | 165,826 | 174,010 | 172,365 | 182,818 | 191,103 | 202,902 | 182,124 |
| (14) | | STEAM | 1,000 MCF | 19,544 | 23,033 | 24,843 | 23,887 | 31,287 | 28,513 | 30,460 | 31,332 | 32,474 | 30,146 | 28,879 | 23,162 |
| (15) | | CC | 1,000 MCF | 152,468 | 151,176 | 137,724 | 129,559 | 127,998 | 129,341 | 134,724 | 131,618 | 139,756 | 149,453 | 161,774 | 149,273 |
| (16) | | CT | 1,000 MCF | 10,944 | 9,154 | 13,110 | 11,647 | 11,803 | 7,972 | 8,826 | 9,415 | 10,588 | 11,504 | 12,249 | 9,689 |
| OTHER (SPECIFY) | | | | | | | | | | | | | | | |
| (17) | OTHER, DISTILLATE | ANNUAL FIRM INTERCHANGE | 1,000 BBL | N/A | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (18) | OTHER, NATURAL GAS | ANNUAL FIRM INTERCHANGE, CC | 1,000 MCF | N/A | N/A | 10,980 | 10,498 | 12,736 | 10,259 | 2,753 | 0 | 0 | 0 | 0 | 0 |
| (18.1) | OTHER, NATURAL GAS | ANNUAL FIRM INTERCHANGE, CT | 1,000 MCF | N/A | N/A | 11,126 | 8,519 | 9,392 | 6,411 | 8,584 | 10,444 | 11,150 | 9,578 | 9,512 | 6,322 |
| (19) | OTHER, COAL | ANNUAL FIRM INTERCHANGE, STEAM | 1,000 TON | N/A | N/A | 215 | 239 | 207 | 74 | 16 | 0 | 0 | 0 | 0 | 0 |

PROGRESS ENERGY FLORIDA

SCHEDULE 6.1
ENERGY SOURCES (GWh)

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|----------------|----------------------------|--------|-------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | | | -ACTUAL- | | | | | | | | | | | |
| ENERGY SOURCES | | | UNITS | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 |
| (1) | ANNUAL FIRM INTERCHANGE 1/ | | GWh | 2,017 | 1,917 | 1,038 | 828 | 908 | 510 | 666 | 879 | 970 | 792 | 734 | 376 |
| (2) | NUCLEAR | | GWh | 0 | 0 | 0 | 0 | 1,178 | 8,271 | 7,730 | 8,271 | 7,474 | 8,271 | 7,608 | 13,129 |
| (3) | COAL | | GWh | 12,115 | 10,809 | 11,614 | 13,205 | 13,802 | 9,240 | 9,591 | 9,824 | 9,781 | 9,128 | 8,752 | 6,996 |
| (4) | RESIDUAL | TOTAL | GWh | 683 | 187 | 204 | 82 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | STEAM | GWh | 683 | 187 | 204 | 82 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CC | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | CT | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | | DIESEL | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (9) | DISTILLATE | TOTAL | GWh | 381 | 81 | 152 | 86 | 107 | 44 | 67 | 73 | 103 | 150 | 155 | 69 |
| (10) | | STEAM | GWh | 36 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CC | GWh | 4 | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (12) | | CT | GWh | 341 | 75 | 152 | 86 | 107 | 44 | 67 | 73 | 103 | 150 | 155 | 69 |
| (13) | | DIESEL | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (14) | NATURAL GAS | TOTAL | GWh | 23,692 | 23,571 | 22,646 | 21,124 | 21,620 | 21,265 | 22,379 | 22,022 | 23,454 | 24,759 | 26,566 | 23,857 |
| (15) | | STEAM | GWh | 1,609 | 1,826 | 2,120 | 2,026 | 2,746 | 2,478 | 2,721 | 2,816 | 2,935 | 2,687 | 2,555 | 2,023 |
| (16) | | CC | GWh | 21,241 | 20,775 | 19,387 | 18,077 | 17,838 | 18,059 | 18,861 | 18,361 | 19,573 | 21,058 | 22,950 | 20,981 |
| (17) | | CT | GWh | 842 | 970 | 1,139 | 1,022 | 1,035 | 729 | 797 | 845 | 945 | 1,014 | 1,060 | 854 |
| (18) | OTHER 2/ | | | | | | | | | | | | | | |
| | QF PURCHASES | | GWh | 2,916 | 2,423 | 2,614 | 2,397 | 1,462 | 1,465 | 1,465 | 1,462 | 1,464 | 1,462 | 1,467 | 1,462 |
| | RENEWABLES | | GWh | 1,215 | 1,243 | 1,297 | 1,291 | 1,291 | 1,291 | 1,294 | 1,291 | 1,291 | 1,291 | 1,294 | 1,291 |
| | IMPORT FROM OUT OF STATE | | GWh | 3,161 | 2,275 | 1,969 | 1,959 | 2,184 | 1,546 | 403 | 0 | 0 | 0 | 0 | 0 |
| | EXPORT TO OUT OF STATE | | GWh | -20 | -16 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (19) | NET ENERGY FOR LOAD | | GWh | 46,160 | 42,490 | 41,534 | 40,973 | 42,552 | 43,633 | 43,596 | 43,823 | 44,533 | 45,854 | 46,576 | 47,180 |

1/ NET ENERGY PURCHASED (+) OR SOLD (-) WITHIN THE FRCC REGION

2/ NET ENERGY PURCHASED (+) OR SOLD (-).

PROGRESS ENERGY FLORIDA

SCHEDULE 6.2
ENERGY SOURCES (PERCENT)

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|----------------|---------------------------------------|--------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| -ACTUAL- | | | | | | | | | | | | | | | |
| ENERGY SOURCES | | | UNITS | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 |
| (1) | ANNUAL FIRM INTERCHANGE ^{1/} | | % | 4.4% | 4.5% | 2.5% | 2.0% | 2.1% | 1.2% | 1.5% | 2.0% | 2.2% | 1.7% | 1.6% | 0.8% |
| (2) | NUCLEAR | | % | 0.0% | 0.0% | 0.0% | 0.0% | 2.8% | 19.0% | 17.7% | 18.9% | 16.8% | 18.0% | 16.3% | 27.8% |
| (3) | COAL | | % | 26.2% | 25.4% | 28.0% | 32.2% | 32.4% | 21.2% | 22.0% | 22.4% | 22.0% | 19.9% | 18.8% | 14.8% |
| (4) | RESIDUAL | TOTAL | % | 1.5% | 0.4% | 0.5% | 0.2% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (5) | | STEAM | % | 1.5% | 0.4% | 0.5% | 0.2% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (6) | | CC | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (7) | | CT | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (8) | | DIESEL | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (9) | DISTILLATE | TOTAL | % | 0.8% | 0.2% | 0.4% | 0.2% | 0.3% | 0.1% | 0.2% | 0.2% | 0.2% | 0.3% | 0.3% | 0.1% |
| (10) | | STEAM | % | 0.1% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (11) | | CC | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (12) | | CT | % | 0.7% | 0.2% | 0.4% | 0.2% | 0.3% | 0.1% | 0.2% | 0.2% | 0.2% | 0.3% | 0.3% | 0.1% |
| (13) | | DIESEL | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (14) | NATURAL GAS | TOTAL | % | 51.3% | 55.5% | 54.5% | 51.6% | 50.8% | 48.7% | 51.3% | 50.3% | 52.7% | 54.0% | 57.0% | 50.6% |
| (15) | | STEAM | % | 3.5% | 4.3% | 5.1% | 4.9% | 6.5% | 5.7% | 6.2% | 6.4% | 6.6% | 5.9% | 5.5% | 4.3% |
| (16) | | CC | % | 46.0% | 48.9% | 46.7% | 44.1% | 41.9% | 41.4% | 43.3% | 41.9% | 44.0% | 45.9% | 49.3% | 44.5% |
| (17) | | CT | % | 1.8% | 2.3% | 2.7% | 2.5% | 2.4% | 1.7% | 1.8% | 1.9% | 2.1% | 2.2% | 2.3% | 1.8% |
| (18) | OTHER ^{2/} | | | | | | | | | | | | | | |
| | QF PURCHASES | | % | 6.3% | 5.7% | 6.3% | 5.8% | 3.4% | 3.4% | 3.4% | 3.3% | 3.3% | 3.2% | 3.1% | 3.1% |
| | RENEWABLES | | % | 2.6% | 2.9% | 3.1% | 3.2% | 3.0% | 3.0% | 3.0% | 2.9% | 2.9% | 2.8% | 2.8% | 2.7% |
| | IMPORT FROM OUT OF STATE | | % | 6.8% | 5.4% | 4.7% | 4.8% | 5.1% | 3.5% | 0.9% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| | EXPORT TO OUT OF STATE | | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (19) | NET ENERGY FOR LOAD | | % | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% |

^{1/} NET ENERGY PURCHASED (+) OR SOLD (-) WITHIN THE FRCC REGION.

^{2/} NET ENERGY PURCHASED (+) OR SOLD (-)

FORECASTING METHODS AND PROCEDURES

INTRODUCTION


Accurate forecasts of long-range electric energy consumption, customer growth, and peak demand are essential elements in electric utility planning. Accurate projections of a utility's future load growth require a forecasting methodology with the ability to account for a variety of factors influencing electric energy usage over the planning horizon. PEF's forecasting framework utilizes a set of econometric models to achieve this end. This section will describe the underlying methodology of the customer, energy, and peak demand forecasts including the principal assumptions incorporated within each. Also included is a description of how DSM impacts the forecast, the development of high and low forecast scenarios, and a review of DSM programs.

Figure 2.1, entitled "Customer, Energy and Demand Forecast," gives a general description of PEF's forecasting process. Highlighted in the diagram is a disaggregated modeling approach that blends the impacts of average class usage, as well as customer growth, based on a specific set of assumptions for each class. Also accounted for is some direct contact with large customers. These inputs provide the tools needed to frame the most likely scenario of the Company's future demand.

FORECAST ASSUMPTIONS

The first step in any forecasting effort is the development of assumptions upon which the forecast is based. A collaborative effort among Progress Energy Departments develops these assumptions including the research efforts of a number of external sources. These assumptions specify major factors that influence the level of customers, energy sales, or peak demand over the forecast horizon. The following set of assumptions forms the basis for the forecast presented in this document.

FIGURE 2.1
Customer, Energy, and Demand Forecast



GENERAL ASSUMPTIONS

1. Normal weather conditions for energy sales are assumed over the forecast horizon using a sales-weighted “modified” 20-year average of conditions at seven weather stations across Florida (Saint Petersburg, Tampa, Orlando, Winter Haven, Gainesville, Daytona Beach, and Tallahassee). For kilowatt-hour (kWh) sales projections, the normal weather calculation begins with a historical 20-year average of the service area weighted billing month degree-days then removes the two largest outliers from this average for each of the 12 months for both the heating season and cooling season. Seasonal peak demand projections are based on a 30-year historical average of system-weighted temperatures at time of seasonal peak at the Tampa, Orlando, and Tallahassee weather stations; the other weather stations are not used in developing the historic average because they lack the historic hourly data needed for peak-weather normalization.
2. The population projections produced by the BEBR at the University of Florida as published in "Florida Population Studies," Bulletin No. 159 (June 2011) provided the basis for development of the customer forecast. This year's projection incorporates the results of the 2010 decennial census for Florida counties which includes a 'back-cast' of the years 1991-2009 for each county. The PEF methodology aggregates a 29 county area representative of the retail service territory. National and Florida economic projections produced by S&P's Moody's Analytics in their August 2011 forecast provided the basis for development of the energy forecast.
3. Within the PEF service area, the phosphate mining industry is the dominant sector in the industrial sales class. Four major customers accounted for over 30 percent of the industrial class MWh sales in 2011. These energy intensive customers mine and process phosphate-based fertilizer products for the global marketplace. The supply and demand (price) for their products are dictated by global conditions that include, but are not limited to, foreign competition, national/international agricultural industry conditions, exchange-rate fluctuations, and international trade pacts. The price of the raw mined commodity often dictates production levels. Load and energy consumption at the PEF-served mining or chemical processing sites depend heavily on plant operations, which are heavily influenced by these global as well as the local conditions, including environmental regulations. Going forward, a weaker U.S. currency

value on the foreign exchange is expected to help the industry in two ways. First, American farm commodities have become more competitive overseas which has contributed to higher crop production at home. Second, a weak U.S. dollar results in U.S. fertilizer producers to become more price competitive relative to foreign producers. The PEF forecast reflects a decline in electric energy consumption to account for a projected self-service generating facility in 2013 removing electrical requirements from PEF. A risk to this projection lies in the price of energy, which is a major cost of both mining and producing phosphoric fertilizers. Fuel charges embedded in PEF's rates versus competitors' rates play a role as to where a mining customer directs output from self-owned generation facilities. This can reduce load for the utility.

4. PEF supplies load and energy service to wholesale customers on a "full," "partial," and "supplemental" requirement basis. Full requirements (FR) customers' demand and energy are assumed to grow at a rate that approximates their historical trend. However, the impact of the current recession has reduced short term growth expectations. Contracts for this service include the cities of Chattahoochee, Mt. Dora and Williston. Partial requirements (PR) customer load is assumed to reflect the current contractual obligations reflected by the nature of the stratified load they have contracted for, plus their ability to receive dispatched energy from power marketers any time it is more economical for them to do so. Contracts for PR service included in this forecast are with the Reedy Creek Improvement District (RCID), Seminole Electric Cooperative, Inc. (SECI), and the cities of New Smyrna Beach, Tallahassee, Gainesville, Homestead and Winter Park.

PEF has negotiated several power sales agreements with SECI beginning in various years over the ten-year horizon. An existing contractual arrangement is a "supplemental" service contract providing energy over and above stated levels they commit to supply themselves. Stratified partial requirements agreements over the next ten years include two base sales, two intermediate sales, a peaking sale and an average sale. Finally, an agreement to provide interruptible service at a SECI metering site has also been included in this projection.

5. This forecast assumes that PEF will successfully renew all future franchise agreements.

6. This forecast incorporates demand and energy reductions required to meet the approved goals set on August 16, 2011, by the FPSC.
7. Expected energy and demand reductions from customer-owned self-service cogeneration facilities are also included in this forecast. This projection assumes an increase of over 70 MW of self-service generation in the early years of the forecast horizon from three customers. PEF will supply the supplemental load of self-service cogeneration customers. While PEF offers "standby" service to all cogeneration customers, the forecast does not assume an unplanned need for power at time of peak.
8. This forecast assumes that the regulatory environment and the obligation to serve our retail customers will continue throughout the forecast horizon. Regarding wholesale customers, the forecast does not plan for generation resources unless a long-term contract is in place. FR customers are typically assumed to renew their contracts with PEF except those who have given notice to terminate. PR contracts are typically projected to terminate as terms reach their expiration date.

SHORT-TERM ECONOMIC ASSUMPTIONS

The economic outlook for this forecast was developed in the summer of 2011 as the nation continued to struggle out of the Great Recession. Consumer confidence and sentiment surveys completed by the University of Michigan and The Conference Board at that time showed record low readings from nationwide polling after the S&P credit downgrade of the federal government's debt.

The forecast assumptions try to weigh and balance varying views of future economic outlooks. One view sees an improvement, or at least the end of declining trends in several economic series. This view suggests that eventually, a de-leveraging American consumer will begin to spend again, confidence will return, and job growth will return. Another view anticipates an increasingly weaker national picture driven by the potential collapse of the Euro-Zone economies' fiscal situation. Policies requiring severe austerity measures to reduce sovereign debt levels are expected to lead to weak growth in Europe as well as in the U.S. This view suggests that a continued de-leveraging of

the American consumer and tight credit standards dim hopes for a healthy short-term recovery. Also, weak growth in personal consumption negates any need to boost employment levels under this view.

The Federal Reserve Board policy of “quantitative easing” remained in place due to observed weakness in the U.S. economy. Recently published state median household income data by the U.S. Commerce Department (September 2011) showed Florida declining for the second straight year in 2010. While the overall Florida employment situation appears to have turned positive, the construction, manufacturing and government employment sectors continue to shrink.

In summary, the short term assumptions underlying this forecast are based on an economic outlook that involves a slower than normal recovery. Financial instability around the globe and the unwillingness of the U.S. federal government to work together and solve both the stagnant economy and long-term debt reduction will likely stifle private sector decision-making until after the 2012 presidential election at the earliest.

LONG-TERM ECONOMIC ASSUMPTIONS

The long term economic outlook assumes that changes in economic and demographic conditions, as well as technological change impacting the electric utility industry, will follow a trended behavior pattern. The main focus involves identifying these trends. No attempt is made to predict business cycle fluctuations or rapid penetration of a significant technological breakthrough impacting electric utility energy sales during this period.

Population Growth Trends

This forecast assumes Florida will experience slower new resident migration and population growth over parts of the long term, as reflected in the BEBR projections. Florida's climate and low cost of living have historically attracted a major share of the retirement population from the eastern half of the United States. Florida is expected to continue to be an attractive state for the increasing population of baby-boom generation retirees. Working against this significant trend will be several aesthetic and economic factors. First, the enormous growth in population and

corresponding development of the 1980s, 1990s, and early 2000s made portions of Florida less desirable and less affordable for retirement living. This perceived diminished quality of retiree life, along with increasing competition from neighboring states, will cause a slight decline in Florida's share of these prospective new residents over the long term. Second, and to a lesser extent, there is a lingering fear for safety and expense from hurricane damage.

Economic Growth Trends

The Florida economy has always relied upon agriculture, tourism and development to serve as its economic growth engine. Recent efforts have been made to further diversify into the bioscience-related industries with some success. Setbacks, such as the severe financial crisis and the ending of a large piece of NASA's space flight industry, however, have left Florida significantly challenged. Declining revenues have forced budget cutbacks in most government departments and delays or cancelation of many state-supported projects. As with every previous recession, however, conditions are anticipated to improve and economic growth is assumed to return.

As a state with growing energy needs and a rapidly increasing average-aged population, Florida stands to benefit from strides currently being made in the health, technology and energy sectors. The nation has also realized the economic benefits that come from trade. Several Florida ports are being expanded to handle larger shipping vessels that will travel through an expanded Panama Canal. Florida has developed close trading ties with South America which has several countries that have developed into major emerging markets. Renewing economic ties with Cuba is now a reasonable possibility that could benefit the state. These trends along with an eventual turnaround in the state housing sector will lead to the assumed level of economic growth in the forecast.

FORECAST METHODOLOGY

The PEF forecast of customers, energy sales, and peak demand is developed using customer class-specific econometric models. These models are expressly designed to capture class-specific variation over time. By modeling customer growth and average energy usage individually, subtle changes in existing customer usage are better captured as well as growth

from new customers. Peak demand models are projected on a disaggregated basis as well. This allows for appropriate handling of individual assumptions in the areas of wholesale contracts, load management, interruptible service and changes in self-service generation capacity.

ENERGY AND CUSTOMER FORECAST

In the retail jurisdiction, customer class models have been specified showing a historical relationship to weather and economic/demographic indicators using monthly data for sales models and annual data for customer models. Sales are regressed against "driver" variables that best explain monthly fluctuations over the historical sample period. Forecasts of these input variables are either derived internally or come from a review of the latest projections made by several independent forecasting concerns. The external sources of data include Moody's Economy.Com and the University of Florida's BEBR. Internal company forecasts are used for projections of electricity price, weather conditions, and the length of the billing month. Normal weather, which is assumed throughout the forecast horizon, is based on a twenty-year modified average of heating and cooling degree-days by month as measured at several weather stations throughout Florida for energy projections and temperatures around the hour of peak for the firm retail demand forecast. Projections of PEF's demand-side management (conservation) programs are also incorporated as reductions to the forecast. Specific sectors are modeled as follows:

Residential Sector

Residential kWh usage per customer is modeled as a function of real median household income, cooling degree-days, heating degree-days, the real price of electricity to the residential class and the average number of billing days in each sales month. This equation captures significant variation in residential usage caused by economic cycles, weather fluctuations, electric price movements, and sales month duration. Projections of kWh usage per customer combined with the customer forecast provide the forecast of total residential energy sales. The residential customer forecast is developed by correlating annual customer growth with PEF service area population growth. County level population projections for counties in which PEF serves residential customers are provided by the BEBR.

Commercial Sector

Commercial MWh energy sales are forecast based on commercial sector (non-agricultural, non-manufacturing and non-governmental) employment, the real price of electricity to the commercial class, the average number of billing days in each sales month and heating and cooling degree-days. The measure of cooling degree-days utilized here differs slightly from that used in the residential sector reflecting different temperature base sensitivities, when heating and cooling load become observable. Commercial customers are projected as a function of the number of residential customers served.

Industrial Sector

Energy sales to this sector are separated into two sub-sectors. A significant portion of industrial energy use is consumed by the phosphate mining industry. Because this one industry is such a large share of the total industrial class, it is separated and modeled apart from the rest of the class. The term "non-phosphate industrial" is used to refer to those customers who comprise the remaining portion of total industrial class sales. Both groups are impacted significantly by changes in economic activity. However, adequately explaining sales levels requires separate explanatory variables. Non-phosphate industrial energy sales are modeled using Florida manufacturing employment and a Florida industrial production index, the real price of electricity to the industrial class, and the average number of sales month billing days.

The industrial phosphate mining industry is modeled using customer-specific information with respect to expected market conditions. Since this sub-sector is comprised of only four customers, the forecast is dependent upon information received from direct customer contact. PEF industrial customer representatives provide specific phosphate customer information regarding customer production schedules, inventory levels, area mine-out, and start-up predictions, and changes in self-service generation or energy supply situations over the forecast horizon.

Street Lighting

Electricity sales to the street and highway lighting class have remained flat for years but have declined recently. A continued decline is expected as improvements in lighting efficiency are projected. The number of accounts, which has dropped by more than one-third since 1995 due to

most transferring to public authority ownership, is expected to decline further before leveling off in the intermediate term. A simple time-trend was used to project energy consumption and customer growth in this class.

Public Authorities

Energy sales to public authorities (SPA), comprised mostly of government operated services, is also projected to grow with the size of the service area. The level of government services, and thus energy use per customer, can be tied to the population base, as well as to the state of the economy. Factors affecting population growth will affect the need for additional governmental services (i.e. public schools, city services, etc.) thereby increasing SPA energy usage per customer. Government employment has been determined to be the best indicator of the level of government services provided. This variable, along with heating and cooling degree-days (class specific), the real price of electricity and the average number of sales month billing days, results in a significant level of explained variation over the historical sample period. Intercept shift variables are also included in this model to account for the large change in school-related energy use in the billing months of January, July, and August. The SPA customer forecast is projected linearly as a function of a time-trend. Recent budget issues have also had an impact on the near-term pace of growth.

Sales for Resale Sector

The Sales for Resale sector encompasses all firm sales to other electric power entities. This includes sales to other utilities (municipal or investor-owned) as well as power agencies (rural electric authority or municipal).

Seminole Electric Cooperative, Inc. (SECI) is a wholesale, or sales for resale, customer of PEF on both a supplemental contract basis and contract demand basis. Under the supplemental contract, PEF provides service for those energy requirements above the level of generation capacity served by either SECI's own facilities or its firm purchase obligations. Monthly supplemental energy is developed using an average historical load shape of total SECI load in the PEF control area, subtracting out the level of SECI "committed" capacity from each hour. Beyond supplemental service, PEF has several agreements with SECI to serve various types of stratified demand levels deemed by their resource planners as necessary.

The municipal sales for resale class includes a number of customers, divergent not only in scope of service, (i.e. full or partial requirement), but also in composition of ultimate consumers. Each customer is modeled separately in order to accurately reflect its individual profile. Three of the customers in this class are municipalities whose full energy requirements are supplied by PEF. The full requirement customers' energy projections grow at a rate that approximates their historical trend with additional information coming from the respective city officials. PEF serves partial requirement service (PR) to municipalities such as New Smyrna Beach, Homestead, Gainesville, Tallahassee and Winter Park, and another power provider RCID. In each case, these customers contract with PEF for a specific level and type of demand needed to provide their particular electrical system with an appropriate level of reliability. The energy forecast for each contract is derived using its historical load factors where enough history exists, or typical load factors for a given type of contracted stratified load.

PEAK DEMAND FORECAST

The forecast of peak demand also employs a disaggregated econometric methodology. For seasonal (winter and summer) peak demands, as well as each month of the year, PEF's coincident system peak is separated into five major components. These components consist of potential firm retail load, conservation and load management program capability, wholesale demand, company use demand, and interruptible demand.

Potential firm retail load refers to projections of PEF retail hourly seasonal net peak demand (excluding the non-firm interruptible/curtailable/standby services) before any historical cumulative effects of company-aided conservation activity or the activation of PEF's General Load Reduction Plan. The historical values of this series are constructed to show the size of PEF's firm retail net peak demand assuming no utility induced conservation or load control had ever taken place. The value of constructing such a "clean" series enables the forecaster to observe and correlate the underlying trend in retail peak demand to total system customer levels and coincident weather conditions at the time of the peak without the impacts of year-to-year variation in conservation activity or load control reductions. Seasonal peaks are projected using historical seasonal peak data regardless of which month the peak occurred. The projections become the potential retail demand

projection for the months of January (winter) and August (summer) since this is typically when the seasonal peaks occur. The non-seasonal peak months are projected the same as the seasonal peaks, but the analysis is limited to the specific month being projected.

Energy conservation and direct load control estimates are consistent with PEF's DSM goals that have been established by the FPSC. These estimates are incorporated into the MW forecast. Projections of dispatchable and cumulative non-dispatchable DSM impacts are subtracted from the projection of potential firm retail demand resulting in a projected series of retail monthly peak demand figures.

Sales for Resale demand projections represent load supplied by PEF to other electric suppliers such as SECI, RCID, and other electric transmission and distribution entities. The SECI supplemental demand projection is based on SECI's projection of total load in the PEF control area. The level of MW to be served by PEF is dependent upon the amount of generation resources SECI supplies itself or contracts from others. For Partial Requirement demand projections, contracted MW levels dictate the level of monthly demands. The Full Requirement municipal demand forecast is estimated for individual cities using historically trended growth rates adjusted for current economic conditions.

PEF "company use" at the time of system peak is estimated using load research metering studies and is assumed to remain stable over the forecast horizon as it has historically. The interruptible and curtailable service (IS and CS) load component is developed from historic trends, as well as the incorporation of specific information obtained from PEF's large industrial accounts by account executives.

Each of the peak demand components described above is a positive value except for the DSM program MW impacts and IS and CS load. These impacts represent a reduction in peak demand and are assigned a negative value. Total system firm peak demand is then calculated as the arithmetic sum of the five components.

CONSERVATION

On August 16, 2011, the PSC issued Order No. PSC-11-0347-PAA-EG, Modifying and Approving the Demand Side Management Plan of PEF. In this Order, the FPSC modified PEF's DSM Plan to consist of those existing programs in effect as of the date of the Order.

The following tables show the 2010 and 2011 achievements from PEF's existing set of DSM programs.

Residential Conservation Savings Cumulative Achievements

| Year | Summer MW | Winter MW | GWh Energy |
|-------------|------------------|------------------|-------------------|
| | Achieved | Achieved | Achieved |
| 2010 | 43 | 85 | 58 |
| 2011 | 82 | 160 | 110 |

Commercial Conservation Savings Cumulative Achievements

| Year | Summer MW | Winter MW | GWh Energy |
|-------------|------------------|------------------|-------------------|
| | Achieved | Achieved | Achieved |
| 2010 | 36 | 32 | 66 |
| 2011 | 65 | 61 | 132 |

Total Conservation Savings Cumulative Achievements

| Year | Summer MW | Winter MW | GWh Energy |
|-------------|------------------|------------------|-------------------|
| | Achieved | Achieved | Achieved |
| 2010 | 79 | 116 | 124 |
| 2011 | 148 | 221 | 242 |

PEF's currently approved DSM programs consist of six residential programs, eight commercial and industrial programs, one research and development program, and six solar pilot programs. The programs are subject to periodic monitoring and evaluation for the purpose of ensuring that

all demand-side resources are acquired in a cost-effective manner and that the program savings are durable. The following is a brief description of these programs.

RESIDENTIAL PROGRAMS

Home Energy Check

This energy audit program provides customers with an analysis of their current energy use and recommendations on how they can save on their electricity bills through low-cost or no-cost energy-saving practices and measures. The Home Energy Check program offers PEF customers the following types of audits: Type 1: Free Walk-Through Audit (Home Energy Check); Type 2: Customer-Completed Mail-In Audit (Do It Yourself Home Energy Check); Type 3: Online Home Energy Check (Internet Option)-a customer-completed audit; Type 4: Phone Assisted Audit – a customer assisted survey of structure and appliance use; Type 5: Computer Assisted Audit; Type 6: Home Energy Rating Audit (Class I, II, III); Type 7: Student Mail In Audit - a student-completed audit. The Home Energy Check program serves as the foundation of the Home Energy Improvement program in that the audit is a prerequisite for participation in the energy saving measures offered in the Home Energy Improvement program.

Home Energy Improvement

This is the umbrella program to increase energy efficiency for existing residential homes. It combines efficiency improvements to the thermal envelope with upgrades to electric appliances. The program provides incentives for attic insulation upgrades, duct testing and repair, and high efficiency electric heat pumps. Additional measures within this program include spray-in wall insulation, central AC 14 SEER non-electric heat, and supply and return plenum duct seal, proper sizing of high efficiency HVAC, HVAC commissioning, reflective roof coating for manufactured homes, reflective roof for single-family homes, window film or screen, and replacement windows.

Residential New Construction

This program promotes energy efficient new home construction in order to provide customers with more efficient dwellings combined with improved environmental comfort. The program

provides education and information to the design and building community on energy efficient equipment and construction. It also facilitates the design and construction of energy efficient homes by working directly with the builders to comply with program requirements. The program provides incentives to the builder for high efficiency electric heat pumps and high performance windows. The highest level of the program incorporates the U.S. Environmental Protection Agency's Energy Star Homes Program and qualifies participants for cooperative advertising. Additional measures within the Residential New Construction program include HVAC commissioning, window film or screen, reflective roof for single-family homes, attic spray-on foam insulation, conditioned space air handler, and energy recovery ventilation.

Low Income Weatherization Assistance

This umbrella program seeks to improve energy efficiency for low-income customers in existing residential dwellings. It combines efficiency improvements to the thermal envelope with upgrades to electric appliances. The program provides incentives for attic insulation upgrades, duct testing and repair, reduced air infiltration, water heater wrap, HVAC maintenance, high efficiency heat pumps, heat recovery units, and dedicated heat pump water heaters.

Neighborhood Energy Saver

This program consists of 12 measures including compact fluorescent bulb replacement, water heater wrap and insulation for water pipes, water heater temperature check and adjustment, low-flow faucet aerator, low-flow showerhead, refrigerator coil brush, HVAC filters, and weatherization measures (i.e. weather stripping, door sweeps, etc.). In addition to the installation of new conservation measures, an important component of this program is educating families on energy efficiency techniques and the promotion of behavioral changes to help customers control their energy usage.

Residential Energy Management (EnergyWise)

This program allows PEF to reduce peak demand and thus defer generation construction. Peak demand is reduced by interrupting service to selected electrical equipment with radio-controlled switches installed on the customer's premises. These interruptions are at PEF's option, during

specified time periods, and coincident with hours of peak demand. Participating customers receive a monthly credit on their electricity bills prorated above 600 kWh per month.

COMMERCIAL/INDUSTRIAL (C/I) PROGRAMS

Business Energy Check

This energy audit program provides commercial and industrial customers with an assessment of the current energy usage at their facilities, recommendations on how they can improve the environmental conditions of their facilities while saving on their electricity bills, and information on low-cost energy efficiency measures. The Business Energy Check consists of a free walk-through audit and a paid walk-through audit. Small business customers also have the option to complete a Business Energy Check online at Progress Energy's website. In most cases, this program is a prerequisite for participation in the other C/I programs.

Better Business

This is the umbrella efficiency program for existing commercial and industrial customers. The program provides customers with information, education, and advice on energy-related issues as well as incentives on efficiency measures. The Better Business program promotes energy efficient HVAC, building retrofit measures (in particular, ceiling insulation upgrade, duct leakage test and repair, energy-recovery ventilation, and Energy Star cool roof coating products), demand-control ventilation, efficient compressed air systems, efficient motors, efficient indoor lighting, green roof, occupancy sensors, packaged AC steam cleaning, roof insulation, roof-top unit recommissioning, thermal energy storage and window film or screen.

Commercial/Industrial New Construction

The primary goal of this program is to foster the design and construction of energy efficient buildings. The new construction program: 1) provides education and information to the design community on all aspects of energy efficient building design; 2) requires that the building design, at a minimum, surpass the State of Florida energy code; 3) provides financial incentives for specific energy efficient equipment; and 4) provides energy design awards to building design

teams. Incentives will be provided for high efficiency HVAC equipment, energy recovery ventilation, Energy Star cool roof coating products, demand-control ventilation, efficient compressed air systems, efficient motors, efficient indoor lighting, green roof, occupancy sensors, roof insulation, thermal energy storage and window film or screen.

Innovation Incentive

This program promotes a reduction in demand and energy by subsidizing energy conservation projects for PEF customers. The intent of the program is to encourage legitimate energy efficiency measures that reduce peak demand and/or energy, but are not addressed by other programs. Energy efficiency opportunities are identified by PEF representatives during a Business Energy Check audit. If a candidate project meets program specifications, it may be eligible for an incentive payment, subject to PEF approval.

Commercial Energy Management (Rate Schedule GSLM-1)

This direct load control program reduces PEF's demand during peak or emergency conditions. As described in PEF's DSM Plan, this program is currently closed to new participants. It is applicable to existing program participants who have electric space cooling equipment suitable for interruptible operation and are eligible for service under the Rate Schedule GS-1, GST-1, GSD-1, or GSDD-1. The program is also applicable to existing participants who have any of the following electrical equipment installed on permanent residential structures and utilized for domestic (household) purposes: 1) water heater(s), 2) central electric heating systems(s), 3) central electric cooling system(s), and or 4) swimming pool pump(s). Customers receive a monthly credit on their bills depending on the type of equipment in the program and the interruption schedule.

Standby Generation

This demand control program reduces PEF's demand based upon the indirect control of customer generation equipment. This is a voluntary program available to all commercial, industrial, and agricultural customers who have on-site generation capability of at least 50 kW, and are willing to reduce their demand when PEF deems it necessary. Customers participating in the Standby

Generation program receive a monthly credit on their electric bills according to their demonstrated ability to reduce demand at PEF's request.

Interruptible Service

This direct load control program reduces PEF's demand at times of capacity shortage during peak or emergency conditions. The program is available to qualified non-residential customers with an average billing demand of 500 kW or more, who are willing to have their power interrupted. PEF will have remote control of the circuit breaker or disconnect switch supplying the customer's equipment. In return for the ability to interrupt load, customers participating in the Interruptible Service program receive a monthly credit applied to their electric bills.

Curtable Service

This load control program reduces PEF's demand at times of capacity shortage during peak or emergency conditions. The program is available to qualified non-residential customers with an average billing demand of 500 kW or more, who are willing to curtail 25 percent of their average monthly billing demand. Customers participating in the Curtable Service program receive a monthly credit applied to their electric bills.

RESEARCH AND DEVELOPMENT PROGRAMS

Technology Development

The primary purpose of this program is to establish a system to "Aggressively pursue research, development and demonstration projects jointly with others as well as individual projects" (Rule 25-17.001(5)(f), Florida Administration Code). In accordance with the rule, the Technology Development program facilitates the research of innovative technologies and continued advances within the energy industry. PEF will undertake certain development, educational and demonstration projects that have potential to become DSM programs. Examples of such projects include the evaluation of Premise Area Networks that provide an increase in customer awareness of efficient energy usage while advancing demand response capabilities. Additional projects include the evaluation of off-peak generation with energy storage for on-peak demand

consumption, small-scale wind and smart charging for plug-in hybrid electric vehicles. In most cases, each demand reduction and energy efficiency project that is proposed and investigated under this program requires field-testing with customers.

DEMAND-SIDE RENEWABLE PORTFOLIO

Solar Water Heating for the Low-income Residential Customers Pilot

This pilot program is designed to assist low-income families with energy costs by incorporating a solar thermal water heating system in their residence while it is under construction. PEF will collaborate with non-profit builders to provide low-income families with a residential solar thermal water heater. The solar thermal system will be provided at no cost to the non-profit builders or the residential participants.

Solar Water Heating with Energy Management

This program represents an updated version of the previous residential Renewable Energy Program. It encourages residential customers to install new solar thermal water heating systems on their residence with the requirement for customers to participate in our residential Energy Management program (EnergyWise). Participants will receive a one-time \$550 rebate designed to reduce the upfront cost of the renewable energy system, plus a monthly bill credit associated with their participation in the residential Energy Management program.

Residential Solar Photovoltaic Pilot

This pilot encourages residential customers to install new solar photovoltaic (PV) systems on their home. A PEF audit is required prior to system installation to qualify for this rebate. Participating customers will receive a one-time rebate of up to \$20,000 to reduce the initial investment required to install a qualified renewable solar PV system. The rebate is based on the wattage of the PV (DC) power rating.

Commercial Solar Photovoltaic Pilot

This pilot encourages commercial customers to install new solar PV systems on their facilities. A PEF energy audit is required prior to system installation to qualify for this rebate. The program provides participating commercial customers with a tiered rebate to reduce the initial investment

in a qualified solar PV system. The rebate is based on the PV dc power rating of the unit installed. The total incentives per participant will be limited to \$130,000, based on a maximum installation of 100 kW.

Photovoltaic For Schools Pilot

This pilot is designed to assist schools with energy costs while promoting energy education. This program provides participating public schools with new solar photovoltaic systems at no cost to the school. The primary goals of the program are to:

- Eliminate the initial investment required to install a solar PV system
- Increase renewable energy generation on PEF's system
- Increase participation in existing residential Demand Side Management measures through energy education
- Increase solar education and awareness in PEF communities and schools

The program will be limited to an annual target of one system with a rating up to 100 KW installed on a post secondary public school and ten 10 KW systems with battery backup option installed on public K-12 schools, preferably serving as emergency shelters.

Research and Demonstration Pilot

The purpose of this program is to research technology and establish Research and Design initiatives to support the development of renewable energy pilot programs. Demonstration projects will provide real-world field testing to assist in the development of these initiatives. The program will be limited to a maximum annual expenditure equal to 5% of the total Demand-Side Renewable Portfolio annual expenditures.

CHAPTER 3
**FORECAST OF
FACILITIES REQUIREMENTS**



CHAPTER 3
FORECAST OF FACILITIES REQUIREMENTS

RESOURCE PLANNING FORECAST

OVERVIEW OF CURRENT FORECAST

Supply-Side Resources

PEF has a summer total capacity resource of 11,828 MW (see Table 3.1). This capacity resource includes nuclear (789 MW), fossil steam (3,435 MW), combined-cycle plants (3,250 MW), combustion turbines (2,474 MW; 143 MW of which is owned by Georgia Power for the months June through September), utility purchased power (412 MW), independent power purchases (785 MW), and non-utility purchased power (683 MW). Table 3.2 presents PEF's firm capacity contracts with Renewable and Cogeneration Facilities.

Demand-Side Programs

Total DSM resources are presented in Schedules 3.1 and 3.2 of Chapter 2. These programs include Non-Dispatchable DSM, Interruptible Load, and Dispatchable Load Control resources.

Capacity and Demand Forecast

PEF's forecasts of capacity and demand for the projected summer and winter peaks can be found in Schedules 7.1 and 7.2, respectively. PEF's forecasts of capacity and demand are based on serving expected growth in retail requirements in its regulated service area and meeting commitments to wholesale power customers who have entered into supply contracts with PEF. In its planning process, PEF balances its supply plan for the needs of retail and wholesale customers and endeavors to ensure that cost-effective resources are available to meet the needs across the customer base.

Base Expansion Plan

PEF’s planned supply resource additions and changes are shown in Schedule 8 and are referred to as PEF’s Base Expansion Plan. This plan includes the return to service of Crystal River 3 in 2014, a planned installation of a combined cycle facility in 2019 at an undesignated site and the addition of Levy Unit 1 in 2021. Levy Unit 2 is not included in this ten-year planning horizon but has a planned in-service date of 2022. These additions depend, in part, on projected load growth, and obtaining all necessary state and federal permits under current schedules. Changes in these or other factors could impact PEF’s Base Expansion Plan.

PEF’s Base Expansion Plan projects the need for additional capacity with proposed in-service dates during the ten-year period from 2012 through 2021. The planned capacity additions, together with purchases from Qualifying Facilities (QF), Investor Owned Utilities, and Independent Power Producers help the PEF system meet the energy requirements of its customer base. The capacity needs identified in this plan may be impacted by PEF’s ability to extend or replace existing purchase power, cogeneration and QF contracts and to secure new renewable purchased power resources in their respective projected timeframes. Status reports and specifications for the planned new generation facilities are included in Schedule 9. The planned transmission lines associated with PEF Bulk Electric System (BES) are shown in Schedule 10.

TABLE 3.1
PROGRESS ENERGY FLORIDA
TOTAL CAPACITY RESOURCES OF
POWER PLANTS AND PURCHASED POWER CONTRACTS
AS OF DECEMBER 31, 2011

| PLANTS | NUMBER OF UNITS | SUMMER NET DEPENDABLE CAPABILITY (MW) |
|--|--------------------|---|
| Nuclear Steam | | |
| Crystal River | <u>1</u> | <u>789</u> (1) |
| Total Nuclear Steam | 1 | 789 |
| Fossil Steam | | |
| Crystal River | 4 | 2,295 |
| Anclote | 2 | 1,011 |
| Suwannee River | <u>3</u> | <u>129</u> |
| Total Fossil Steam | 9 | 3,435 |
| Combined Cycle | | |
| Bartow | 1 | 1,133 |
| Hines Energy Complex | 4 | 1,912 |
| Tiger Bay | <u>1</u> | <u>205</u> |
| Total Combined cycle | 6 | 3,250 |
| Combustion Turbine | | |
| DeBary | 10 | 638 |
| Intercession City | 14 | 982 (2) |
| Bayboro | 4 | 174 |
| Bartow | 4 | 177 |
| Suwannee | 3 | 155 |
| Turner | 4 | 137 |
| Higgins | 4 | 105 |
| Avon Park | 2 | 48 |
| University of Florida | 1 | 46 |
| Rio Pinar | <u>1</u> | <u>12</u> |
| Total Combustion Turbine | 47 | 2,474 |
| Total Units | 63 | |
| Total Net Generating Capability | | 9,948 |
| <i>(1) Adjusted for sale of approximately 8.2% of total capacity</i> | | |
| <i>(2) Includes 143 MW owned by Georgia Power Company (Jun-Sep)</i> | | |
| Purchased Power | | |
| Firm Qualifying Facility | 13 | 683 |
| Investor Owned Utilities | 2 | 412 |
| Independent Power Producers | 2 | 785 |
| TOTAL CAPACITY RESOURCES | | 11,828 |

TABLE 3.2

**PROGRESS ENERGY FLORIDA
FIRM RENEWABLES
AND COGENERATION CONTRACTS**

AS OF DECEMBER 31, 2011

| Facility Name | Firm Capacity (MW) |
|-------------------------------------|---------------------------|
| Dade County Resource Recovery | 43 |
| El Dorado | 114.2 |
| Lake Cogen | 110 |
| Lake County Resource Recovery | 12.8 |
| LFC Jefferson | 8.5 |
| LFC Madison | 8.5 |
| Mulberry | 115 |
| Orange Cogen (CFR-Biogen) | 74 |
| Orlando Cogen | 79.2 |
| Pasco County Resource Recovery | 23 |
| Pinellas County Resource Recovery 1 | 40 |
| Pinellas County Resource Recovery 2 | 14.8 |
| Ridge Generating Station | 39.6 |
| TOTAL | 682.6 |

PROGRESS ENERGY FLORIDA

SCHEDULE 7.1

FORECAST OF CAPACITY, DEMAND AND SCHEDULED MAINTENANCE
AT TIME OF SUMMER PEAK

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) |
|------|---|---|----------------------------|-----------------------|--------------------------------|--------------------------------------|--------------------------------------|-----------------------------|--------------------------|-------------------------------------|-----------------------------|
| | TOTAL ^a INSTALLED CAPACITY | FIRM ^b CAPACITY IMPORT | FIRM CAPACITY EXPORT | QF ^c MW | TOTAL CAPACITY AVAILABLE | SYSTEM FIRM SUMMER PEAK DEMAND | RESERVE MARGIN BEFORE MAINTENANCE | RESERVE MARGIN % OF PEAK | SCHEDULED MAINTENANCE | RESERVE MARGIN AFTER MAINTENANCE | RESERVE MARGIN % OF PEAK |
| YEAR | MW | MW | MW | MW | MW | MW | MW | % OF PEAK | MW | MW | % OF PEAK |
| 2012 | 9,805 | 2,025 | 0 | 173 | 12,003 | 8,922 | 3,081 | 35% | 789 | 2,292 | 26% |
| 2013 | 9,815 | 1,915 | 0 | 173 | 11,903 | 8,717 | 3,186 | 37% | 789 | 2,397 | 27% |
| 2014 | 9,825 | 1,784 | 0 | 173 | 11,782 | 8,773 | 3,009 | 34% | 789 | 2,220 | 25% |
| 2015 | 9,980 | 1,784 | 0 | 173 | 11,936 | 8,964 | 2,972 | 33% | 0 | 2,972 | 33% |
| 2016 | 9,666 | 1,371 | 0 | 173 | 11,209 | 8,978 | 2,231 | 25% | 0 | 2,231 | 25% |
| 2017 | 9,666 | 1,371 | 0 | 173 | 11,209 | 9,210 | 1,999 | 22% | 0 | 1,999 | 22% |
| 2018 | 9,666 | 1,371 | 0 | 173 | 11,209 | 9,370 | 1,839 | 20% | 0 | 1,839 | 20% |
| 2019 | 10,433 | 1,371 | 0 | 173 | 11,976 | 9,781 | 2,195 | 22% | 0 | 2,195 | 22% |
| 2020 | 10,433 | 1,371 | 0 | 173 | 11,976 | 9,939 | 2,037 | 20% | 0 | 2,037 | 20% |
| 2021 | 11,525 | 1,371 | 0 | 173 | 13,068 | 10,000 | 3,068 | 31% | 0 | 3,068 | 31% |

Notes:

- a. Total Installed Capacity does not include the 143 MW to Southern Company from Intercession City, P11.
- b. FIRM Capacity Import includes Cogeneration, Utility and Independent Power Producers, and Short Term Purchase Contracts.
- c. QF includes Firm Renewables

PROGRESS ENERGY FLORIDA

SCHEDULE 7.2
 FORECAST OF CAPACITY, DEMAND AND SCHEDULED MAINTENANCE
 AT TIME OF WINTER PEAK

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) |
|---------|--------------------------------|---|----------------------------|-----------------------|--------------------------------|--------------------------------------|--------------------------------------|-----------------------------|--------------------------|-------------------------------------|-----------------------------|
| | TOTAL INSTALLED CAPACITY | FIRM ^a CAPACITY IMPORT | FIRM CAPACITY EXPORT | QF ^b MW | TOTAL CAPACITY AVAILABLE | SYSTEM FIRM WINTER PEAK DEMAND | RESERVE MARGIN BEFORE MAINTENANCE | RESERVE MARGIN % OF PEAK | SCHEDULED MAINTENANCE | RESERVE MARGIN AFTER MAINTENANCE | RESERVE MARGIN % OF PEAK |
| YEAR | MW | MW | MW | MW | MW | MW | MW | % OF PEAK | MW | MW | % OF PEAK |
| 2011/12 | 10,999 | 1,761 | 0 | 173 | 12,933 | 9,442 | 3,491 | 37% | 805 | 2,686 | 28% |
| 2012/13 | 10,999 | 2,108 | 0 | 173 | 13,281 | 9,256 | 4,025 | 43% | 805 | 3,220 | 35% |
| 2013/14 | 11,019 | 1,867 | 0 | 173 | 13,059 | 8,954 | 4,105 | 46% | 805 | 3,300 | 37% |
| 2014/15 | 11,173 | 1,867 | 0 | 173 | 13,214 | 9,604 | 3,610 | 38% | 0 | 3,610 | 38% |
| 2015/16 | 11,173 | 1,867 | 0 | 173 | 13,214 | 9,762 | 3,452 | 35% | 0 | 3,452 | 35% |
| 2016/17 | 10,815 | 1,454 | 0 | 173 | 12,443 | 9,682 | 2,761 | 29% | 0 | 2,761 | 29% |
| 2017/18 | 10,815 | 1,454 | 0 | 173 | 12,443 | 9,829 | 2,614 | 27% | 0 | 2,614 | 27% |
| 2018/19 | 10,815 | 1,454 | 0 | 173 | 12,443 | 10,220 | 2,223 | 22% | 0 | 2,223 | 22% |
| 2019/20 | 11,691 | 1,454 | 0 | 173 | 13,318 | 10,356 | 2,962 | 29% | 0 | 2,962 | 29% |
| 2020/21 | 11,691 | 1,454 | 0 | 173 | 13,318 | 10,498 | 2,820 | 27% | 0 | 2,820 | 27% |

Notes:

a. FIRM Capacity Import includes Cogeneration, Utility and Independent Power Producers, and Short Term Purchase Contracts.

b. QF includes Firm Renewables

PROGRESS ENERGY FLORIDA

SCHEDULE 8
 PLANNED AND PROSPECTIVE GENERATING FACILITY ADDITIONS AND CHANGES

AS OF JANUARY 1, 2012 THROUGH DECEMBER 31, 2021

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|----------------|----------|-------------------|-----------|------|-----|----------------|-----|---------|------------------|---------------------|------------------------|-----------------------------|-----------|---------------------|--------------------|
| PLANT NAME | UNIT NO. | LOCATION (COUNTY) | UNIT TYPE | FUEL | | FUEL TRANSPORT | | START | COM'L IN-SERVICE | EXPECTED RETIREMENT | GEN. MAX. NAMEPLATE KW | NET CAPABILITY ^a | | STATUS ^b | NOTES ^c |
| | | | | PRI | ALT | PRI | ALT | MO./YR | MO./YR | MO./YR | | SUMMER MW | WINTER MW | | |
| ANCLOTE | 1 | PASCO | ST | NG | | PL | | | 4/2013 | | | 10 | 10 | FC | (1) |
| ANCLOTE | 2 | PASCO | ST | NG | | PL | | | 12/2013 | | | 10 | 10 | FC | (1) |
| CRYSTAL RIVER | 3 | CITRUS | NP | | | | | | 11/2014 | | | 789 | 805 | P | (2) |
| CRYSTAL RIVER | 3 | CITRUS | NP | | | | | | 1/2015 | | | 154 | 154 | A | (3) |
| SUWANNEE RIVER | 1-3 | SUWANNEE | ST | | | | | | | d. | | (129) | (131) | P | (1) |
| HIGGINS | P1-4 | PINELLAS | GT | | | | | | | d. | | (105) | (116) | P | (1) |
| TURNER | P1-2 | VOLUSIA | GT | | | | | | | d. | | (20) | (26) | P | (1) |
| AVON PARK | P1-2 | HIGHLANDS | GT | | | | | | | d. | | (48) | (70) | P | (1) |
| RIO PINAR | P1 | ORANGE | GT | | | | | | | d. | | (12) | (15) | P | (1) |
| UNKNOWN | 1 | UNKNOWN | CC | | | | | 01/2016 | 6/2019 | | | 767 | 875 | P | (1) |
| LEVY | 1 | LEVY | NP | | | | | 01/2015 | 6/2021 | | | 1092 | 1120 | p | (1) |

a. Net capability of Crystal River 3 represents approximately 91.8% PEF Ownership.

b. See page v. for Code Legend of Future Generating Unit Status.

c. NOTES

- (1) Planned, Prospective, or Committed project.
- (2) Return to Service
- (3) Planned uprates.

d. Suwannee 1-3, Higgins P1-4, Turner P1-2, Avon Park P1-2, Rio Pinar P1 are expected to be shut down by 6/2016.

PROGRESS ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES
AS OF JANUARY 1, 2012

| | | |
|--|-------------------------|----------------|
| (1) Plant Name and Unit Number: | Undesignated CCI | |
| (2) Capacity | | |
| a. Summer: | 767 | |
| b. Winter: | 875 | |
| (3) Technology Type: | COMBINED CYCLE | |
| (4) Anticipated Construction Timing | | |
| a. Field construction start date: | 1/2016 | |
| b. Commercial in-service date: | 6/2019 | (EXPECTED) |
| (5) Fuel | | |
| a. Primary fuel: | NATURAL GAS | |
| b. Alternate fuel: | DISTILLATE FUEL OIL | |
| (6) Air Pollution Control Strategy: | SCR and CO Catalyst | |
| (7) Cooling Method: | Cooling Tower | |
| (8) Total Site Area: | UNKNOWN | ACRES |
| (9) Construction Status: | PLANNED | |
| (10) Certification Status: | PLANNED | |
| (11) Status with Federal Agencies: | PLANNED | |
| (12) Projected Unit Performance Data | | |
| a. Planned Outage Factor (POF): | | 7.7 % |
| b. Forced Outage Factor (FOF): | | 6.4 % |
| c. Equivalent Availability Factor (EAF): | | 86.5 % |
| d. Resulting Capacity Factor (%): | | 68.3 % |
| e. Average Net Operating Heat Rate (ANOHR): | | 6,913 BTU/kWh |
| (13) Projected Unit Financial Data | | |
| a. Book Life (Years): | | 25 |
| b. Total Installed Cost (In-service year \$/kW): | | 1,648.02 |
| c. Direct Construction Cost (\$/kW): | (\$2012) | 1,327.51 |
| d. AFUDC Amount (\$/kW): | | 147.40 |
| e. Escalation (\$/kW): | | 173.11 |
| f. Fixed O&M (\$/kW-yr): | (\$2012) | 6.95 |
| g. Variable O&M (\$/MWh): | (\$2012) | 3.40 |
| h. K Factor: | | NO CALCULATION |

NOTES:

Total Installed Cost includes gas expansion, transmission interconnection and integration

\$/kW values are based on Summer capacity.

Fixed O&M cost does not include firm gas transportation costs

PROGRESS ENERGY FLORIDA

SCHEDULE 9
STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES
AS OF JANUARY 1, 2012

| | | |
|--|------------------------------|----------------|
| (1) Plant Name and Unit Number: | Levy County Unit No. 1 | |
| (2) Capacity | | |
| a. Summer: | 1092 | |
| b. Winter: | 1120 | |
| (3) Technology Type: | ADVANCED LIGHT WATER NUCLEAR | |
| (4) Anticipated Construction Timing | | |
| a. Field construction start date: | 1/2015 | |
| b. Commercial in-service date: | 6/2021 | (EXPECTED) |
| (5) Fuel | | |
| a. Primary fuel: | URANIUM | |
| b. Alternate fuel: | -- | |
| (6) Air Pollution Control Strategy: | N/A | |
| (7) Cooling Method: | COOLING TOWER | |
| (8) Total Site Area: | 3100 | ACRES |
| (9) Construction Status: | PLANNED | |
| (10) Certification Status: | PLANNED | |
| (11) Status with Federal Agencies: | PLANNED | |
| (12) Projected Unit Performance Data | | |
| a. Planned Outage Factor (POF): | | 5.1 % |
| b. Forced Outage Factor (FOF): | | 3.0 % |
| c. Equivalent Availability Factor (EAF): | | 92.0 % |
| d. Resulting Capacity Factor (%): | | 91.0 % |
| e. Average Net Operating Heat Rate (ANOHR): | | 9,715 BTU/kWh |
| (13) Projected Unit Financial Data | | |
| a. Book Life (Years): | | 40 |
| b. Total Installed Cost (In-service year \$/kW): | | 8,530.93 |
| c. Direct Construction Cost (\$/kW): | (\$2012) | 7,668.97 |
| d. AFUDC Amount (\$/kW): | | (Note 1) |
| e. Escalation (\$/kW): | | 861.95 |
| f. Fixed O&M (\$/kW-yr): | (\$2012) | 64.70 |
| g. Variable O&M (\$/MWh): | (\$2012) | 3.19 |
| h. K Factor: | | NO CALCULATION |

NOTES:

¹ Carrying costs per F.S. 366.93 and Rule 25-6.0423, F.A.C.

These estimates are under review

\$/kW values are based on Summer capacity.

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

- | | |
|---|--|
| (1) POINT OF ORIGIN AND TERMINATION: | Levy - Central Florida South Substation |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | Existing and new transmission line rights-of-way |
| (4) LINE LENGTH: | 50 miles |
| (5) VOLTAGE: | 500 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | Levy, Central Florida South |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

- | | |
|---|------------------------------------|
| (1) POINT OF ORIGIN AND TERMINATION: | Levy - Crystal River Substation |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | New transmission line right-of-way |
| (4) LINE LENGTH: | 10 miles |
| (5) VOLTAGE: | 500 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | Levy |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

- | | |
|---|------------------------------------|
| (1) POINT OF ORIGIN AND TERMINATION: | Levy - Citrus Substation |
| (2) NUMBER OF LINES: | 2 |
| (3) RIGHT-OF-WAY: | New transmission line right-of-way |
| (4) LINE LENGTH: | 10 miles |
| (5) VOLTAGE: | 500 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | Levy |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

- | | |
|---|--|
| (1) POINT OF ORIGIN AND TERMINATION: | Crystal River - Brookridge Substation |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | Existing and new transmission line rights-of-way |
| (4) LINE LENGTH: | 35 miles |
| (5) VOLTAGE: | 230 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | N/A |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

| | |
|---|--|
| (1) POINT OF ORIGIN AND TERMINATION: | Brookridge - Brooksville West Substation |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | Existing and new transmission line rights-of-way |
| (4) LINE LENGTH: | 4 miles |
| (5) VOLTAGE: | 230 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | N/A |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |

PROGRESS ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

LEVY COUNTY NUCLEAR POWER PLANT

- | | |
|---|--|
| (1) POINT OF ORIGIN AND TERMINATION: | Kathleen - Lake Tarpon Substation |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | Existing and new transmission line rights-of-way |
| (4) LINE LENGTH: | 45 miles |
| (5) VOLTAGE: | 230 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/2021 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | TBD |
| (8) SUBSTATIONS: | N/A |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |


INTEGRATED RESOURCE PLANNING OVERVIEW

PEF employs an Integrated Resource Planning (IRP) process to determine the most cost-effective mix of supply- and demand-side alternatives that will reliably satisfy our customers' future demand and energy needs. PEF's IRP process incorporates state-of-the-art computer models used to evaluate a wide range of future generation alternatives and cost-effective conservation and dispatchable demand-side management programs on a consistent and integrated basis.

An overview of PEF's IRP Process is shown in Figure 3.1. The process begins with the development of various forecasts, including demand and energy, fuel prices, and economic assumptions. Future supply- and demand-side resource alternatives are identified and extensive cost and operating data are collected to enable these to be modeled in detail. These alternatives are optimized together to determine the most cost-effective plan for PEF to pursue over the next ten years to meet the Company's reliability criteria. The resulting ten-year plan, the Integrated Optimal Plan, is then tested under different relevant sensitivity scenarios to identify variances, if any, which would warrant reconsideration of any of the base plan assumptions. If the plan is judged robust and works within the corporate framework, it evolves as the Base Expansion Plan. This process is discussed in more detail in the following section titled "The Integrated Resource Planning (IRP) Process".

The IRP provides PEF with substantial guidance in assessing and optimizing the Company's overall resource mix on both the supply side and the demand side. When a decision supporting a significant resource commitment is being developed (e.g. plant construction, power purchase, DSM program implementation), the Company will move forward with directional guidance from the IRP and delve much further into the specific levels of examination required. This more detailed assessment will typically address very specific technical requirements and cost estimates, detailed corporate financial considerations, and the most current dynamics of the business and regulatory environments.

FIGURE 3.1
Integrated Resource Planning (IRP) Process Overview



THE INTEGRATED RESOURCE PLANNING (IRP) PROCESS

Forecasts and Assumptions

The evaluation of possible supply- and demand-side alternatives, and development of the optimal plan, is an integral part of the IRP process. These steps together comprise the integration process that begins with the development of forecasts and collection of input data. Base forecasts that reflect PEF's view of the most likely future scenario are developed. Additional future scenarios along with high and low forecasts may also be developed. Computer models used in the process are brought up-to-date to reflect this data, along with the latest operating parameters and maintenance schedules for PEF's existing generating units. This establishes a consistent starting point for all further analysis.

Reliability Criteria

Utilities require a margin of generating capacity above the firm demands of their customers in order to provide reliable service. Periodic scheduled outages are required to perform maintenance and inspections of generating plant equipment and to refuel nuclear plants. At any given time during the year, some capacity may be out of service due to unanticipated equipment failures resulting in forced outages of generation units. Adequate reserve capacity must be available to accommodate these outages and to compensate for higher than projected peak demand due to forecast uncertainty and abnormal weather. In addition, some capacity must be available for operating reserves to maintain the balance between supply and demand on a moment-to-moment basis.

PEF plans its resources in a manner consistent with utility industry planning practices, and employs both deterministic and probabilistic reliability criteria in the resource planning process. A Reserve Margin criterion is used as a deterministic measure of PEF's ability to meet its forecasted seasonal peak load with firm capacity. PEF plans its resources to satisfy a 20 percent Reserve Margin criterion.

Loss of Load Probability (LOLP) is a probabilistic criterion that measures the probability that a company will be unable to meet its load throughout the year. While Reserve Margin considers the peak load and amount of installed resources, LOLP takes into account generating unit sizes, capacity mix, maintenance scheduling, unit availabilities, and capacity assistance available from other utilities. A standard probabilistic reliability threshold commonly used in the electric utility

industry, and the criterion employed by PEF, is a maximum of one day in ten years loss of load probability.

PEF has based its resource planning on the use of dual reliability criteria since the early 1990s, a practice that has been accepted by the FPSC. PEF's resource portfolio is designed to satisfy the 20 percent Reserve Margin requirement and probabilistic analyses are periodically conducted to ensure that the one day in ten years LOLP criterion is also satisfied. By using both the Reserve Margin and LOLP planning criteria, PEF's resource portfolio is designed to have sufficient capacity available to meet customer peak demand, and to provide reliable generation service under expected load conditions. PEF has found that resource additions are typically triggered to meet the 20 percent Reserve Margin thresholds before LOLP becomes a factor.

Supply-Side Screening

Potential supply-side resources are screened to determine those that are the most cost-effective. Data used for the screening analysis is compiled from various industry sources and PEF's experiences. The wide range of resource options is pre-screened to set aside those that do not warrant a detailed cost-effectiveness analysis. Typical screening criteria are costs, fuel source, technology maturity, environmental parameters (e.g. possible climate legislation), and overall resource feasibility.

Economic evaluation of generation alternatives is performed using the Strategist[®] optimization program. This optimization tool evaluates revenue requirements for specific resource plans generated from multiple combinations of future resource additions that meet system reliability criteria and other system constraints. All resource plans are then ranked by system revenue requirements.

Demand-Side Screening

Like supply-side resources, data for large numbers of potential demand-side resources are also collected. These resources are pre-screened to eliminate those alternatives that are still in research and development, addressed by other regulations (e.g. building code), or not applicable to PEF's customers. Strategist[®] is updated with cost data and load impact parameters for each potential DSM measure to be evaluated.

The Base Optimal Supply-Side Plan is used to establish avoidable units for screening future demand-side resources. Each future demand-side alternative is individually tested in this plan over the ten-year planning horizon to determine the benefit or detriment that the addition of this demand-side resource provides to the overall system. Strategist[®] calculates the benefits and costs for each demand-side measure evaluated and reports the appropriate ratios for the Rate Impact Measure (RIM), the Total Resource Cost Test (TRC), and the Participant Test.

Resource Integration and the Integrated Optimal Plan

The cost-effective generation alternatives and the demand-side portfolios developed in the screening process can then be optimized together to formulate integrated optimal plans. The optimization program considers all possible future combinations of supply- and demand-side alternatives that meet the Company's reliability criteria in each year of the ten-year study period and reports those that provide both flexibility and reasonable revenue requirements (rates) for PEF's ratepayers.

Developing the Base Expansion Plan

The integrated optimized plan that provides the lowest revenue requirements may then be further tested using sensitivity analysis. The economics of the plan may be evaluated under high and low forecast scenarios for fuel, load and financial assumptions, or any other sensitivities which the planner deems relevant. From the sensitivity assessment, the plan that is identified as achieving the best balance of flexibility and cost is then reviewed within the corporate framework to determine how the plan potentially impacts or is impacted by many other factors. If the plan is judged robust under this review, it would then be considered the Base Expansion Plan.

KEY CORPORATE FORECASTS

Load Forecast

The assumptions and methodology used to develop the base case load and energy forecast are described in Chapter 2 of this TYSP.

Fuel Forecast

The base case fuel price forecast was developed using short-term and long-term spot market price projections from industry-recognized sources. The base cost for coal is based on the existing

contracts and spot market coal prices and transportation arrangements between PEF and its various suppliers. For the longer term, the prices are based on spot market forecasts reflective of expected market conditions. Oil and natural gas prices are estimated based on current and expected contracts and spot purchase arrangements as well as near-term and long-term market forecasts. Oil and natural gas commodity prices are driven primarily by open market forces of supply and demand. Natural gas firm transportation cost is determined primarily by pipeline tariff rates.

Financial Forecast

The key financial assumptions used in PEF's most recent planning studies were 47 percent debt and 53 percent equity capital structure, projected cost of debt of 3.05 percent, and an equity return of 10.5 percent. The assumptions resulted on a weighted average cost of capital of 7.00 percent and an after-tax discount rate of 6.47 percent.

TEN-YEAR SITE PLAN (TYSP) RESOURCE ADDITIONS

The planned units in this TYSP includes a diverse fuel resource that includes the return to service and associated uprates to the Crystal River Nuclear Unit No. 3 in 2014/15, the installation of combined cycle 2x1 G at a location that has not yet been chosen, as well as Levy Unit 1 in 2021. The second Levy Unit is beyond this ten-year planning horizon but is planned for the year 2022. Purchase power agreements with Vandolah Power Company, LLC will also supply additional peaking generation. Additionally, PEF anticipates the retirements of older, smaller steam and combustion turbines in the year 2016.

Through its ongoing planning process, PEF will continue to evaluate the timetables for all projected resource additions and assess alternatives for the future considering, among other things, projected load growth, fuel prices, and lead times in the construction marketplace, project development timelines for new fuels and technologies, and environmental compliance considerations. The Company will continue to examine the merits of new generation alternatives and adjust its resource plans accordingly to ensure optimal selection of resource additions based on the best information available.

RENEWABLE ENERGY

PEF continues to make purchases from the following facilities listed by fuel type:

Municipal Solid Waste Facilities:

- Lake County Resource Recovery (12.8 MW)
- Metro-Dade County Resource Recovery (43 MW)
- Pasco County Resource Recovery (23 MW)
- Pinellas County Resource Recovery (54.8 MW)

Waste Heat from Exothermic Processes:

- PCS Phosphate (As Available)

Waste Wood, Tires, and Landfill Gas:

- Ridge Generating Station (39.6 MW)

Photovoltaics

- PEF owned installations (approximately 930 kW)
- PEF's Net Metering Tariff includes over 8.1 MW of solar PV

In addition, PEF has contracts with U.S. EcoGen (60 MW), TransWorld Energy (40 MW), and FB Energy (60 MW). U.S. Ecogen will utilize an energy crop, while the FB Energy facility and the TransWorld Energy facility will utilize wood products as their fuel source.

PEF has also signed several As-Available contracts utilizing biomass and solar PV technologies.

PEF continues to seek out renewable suppliers that can provide reliable capacity and energy at economic rates. PEF continues to keep an open Request for Renewables (RFR) soliciting proposals for renewable energy projects. PEF's open RFR continues to receive interest and to date has logged over 290 responses. PEF will continue to submit renewable contracts in compliance with FPSC rules.

PLAN CONSIDERATIONS

Load Forecast

In general, higher-than-projected load growth would shift the need for new capacity to an earlier year and lower-than-projected load growth would delay the need for new resources. The Company's resource plan provides the flexibility to shift certain resources to earlier or later in-service dates should a significant change in projected customer demand begin to materialize.

TRANSMISSION PLANNING

PEF's transmission planning assessment practices are developed to test the ability of the planned system to meet the reliability criteria as outlined in the FERC Form 715 filing, and to assure the system meets PEF, Florida Reliability Coordinating Council, Inc. (FRCC), and NERC criteria. This involves the use of load flow and transient stability programs to model various contingency situations that may occur, and determining if the system response meets the reliability criteria. In general, this involves running simulations for the loss of any single line, generator, or transformer. PEF normally runs this analysis for system peak and off-peak load levels for possible contingencies, and for both summer and winter. Additional studies are performed to determine the system response to credible, but less probable criteria. These studies include the loss of multiple generators or lines, combinations of each, and some load loss is permissible under these more severe disturbances. These credible, but less probable scenarios are also evaluated at various load levels, since some of the more severe situations occur at average or minimum load conditions. In particular, critical fault clearing times are typically the shortest (most severe) at minimum load conditions, with just a few large base load units supplying the system needs.

As noted in the PEF reliability criteria, some remedial actions are allowed to reduce system loadings, in particular, sectionalizing is allowed to reduce loading on lower voltage lines for bulk system contingencies, but the risk to load on the sectionalized system must be reasonable (it would not be considered prudent to operate for long periods with a sectionalized system). In addition, the number of remedial action steps and the overall complexity of the scheme are evaluated to determine overall acceptability.

PEF presently uses the following reference documents to calculate and manage Available Transfer Capability (ATC), Total Transfer Capability (TTC) and Transmission Reliability Margin (TRM) for required transmission path postings on the Florida OASIS:

- <http://www.oatioasis.com/FPC/FPCdocs/ATCID.docx>.

- <http://www.oatioasis.com/FPC/FPCdocs/TRMID.docx>

PEF uses the following reference document to calculate and manage Capacity Benefit Margin (CBM):

- <http://www.oatioasis.com/FPC/FPCdocs/CBMID.docx>

PEF proposed bulk transmission line additions are summarized in the following Table 3.3. PEF has listed only the larger transmission projects. These projects may change depending upon the outcome of PEF's final corridor and specific route selection process.

TABLE 3.3
PROGRESS ENERGY FLORIDA
LIST OF PROPOSED BULK TRANSMISSION LINE ADDITIONS
2012 – 2021

| MVA RATING WINTER | LINE OWNERSHIP | TERMINALS | | LINE LENGTH (CKT-MILES) | COMMERCIAL IN-SERVICE DATE (MO./YEAR) | NOMINAL VOLTAGE (kV) |
|-------------------|----------------|-------------------|-------------------|-------------------------|---------------------------------------|----------------------|
| 1370 | PEF | INTERCESSION CITY | Gifford | 13 | 5/31/2013 | 230 |
| 1000 | PEF | KATHLEEN | ZEPHYRHILLS N | 11 | 5/31/2012 | 230 |
| 2870 | PEF | LEVY | CENTRAL FLA SOUTH | 50*** | 5/31/2021 | 500 |
| 2870 | PEF | LEVY | CRYSTAL RIVER | 10*** | 5/31/2021 | 500 |
| 2870 | PEF | LEVY | CITRUS #1 | 10*** | 12/1/2021 | 500 |
| 2870 | PEF | LEVY | CITRUS #2 | 10*** | 12/1/2021 | 500 |
| 1195 | PEF | CRYSTAL RIVER | BROOKRIDGE | 35*** | 12/1/2021 | 230 |
| 1195 | PEF | BROOKRIDGE | BROOKSVILLE WEST | 4*** | 12/1/2021 | 230 |
| 1195 | PEF | KATHLEEN | LAKE TARPON | 45*** | 12/1/2021 | 230 |

***Each of these projects is part of one or more transmission options for the Levy County Nuclear Power Plant project. Out of several options under consideration, the final option has yet to be chosen, and thus the above list of projects is subject to change.

CHAPTER 4

***ENVIRONMENTAL AND
LAND USE INFORMATION***



CHAPTER 4
ENVIRONMENTAL AND LAND USE INFORMATION

PREFERRED SITES

PEF's base expansion plan includes the potential installation of a combined cycle facility at an undesignated existing location and nuclear power at the Levy Site. The installation of a nuclear power at the Levy County greenfield site is planned for in 2021 and a second unit beyond the planning horizon for this TYSP, or in 2022. PEF continues to evaluate available options for future supply alternatives. Appropriate permitting requirements for PEF's preferred site are discussed in the following site description.

LEVY COUNTY NUCLEAR POWER PLANT – LEVY COUNTY

PEF has named a site in southern Levy County as the preferred location for construction of new generation. The Company is planning the construction of nuclear generation at this site with an installation of a nuclear power unit at the Levy County greenfield site is planned for in 2021 and a second unit beyond the planning horizon for this TYSP, or in 2022.

The Levy County site (see Figures 4.1 a & b) is approximately 3,100 acres and located eight miles inland from the Gulf of Mexico and roughly ten miles north of the existing PEF Crystal River Energy Complex.

The site is about 2.5 miles from the Cross Florida Barge Canal, from which the Levy units may draw their makeup water to supply the on-site cooling water system. The Levy County Plant, together with the necessary associated site facilities, will occupy approximately ten percent of the 3,100 acre site and the remaining acreage will be preserved as an exclusionary boundary around the developed plant site and a buffer preserve. PEF purchased an additional 2,100 acre tract contiguous with the southern boundary of the Levy site that secures access to a water supply for the site from the Cross Florida Barge Canal as well as transmission corridors from the plant site. The property for many years had been used for silviculture and was designated as Forestry/Rural Residential. The surrounding area land use is predominantly vacant, commercial forestry lands.

This site was chosen based on several considerations including availability of land and water resources, access to the electric transmission system, and environmental considerations. First, the Levy County site had access to an adequate water supply. Second, the site is at a relatively high elevation, which provides additional protection from wind damage and flooding. Third, unlike a number of other sites considered, the Levy site has more favorable geotechnical qualities, which are critical to siting a nuclear power plant. Fourth, the Levy site provides geographical separation from other electrical generating facilities. Even though the Crystal River Energy Complex site has many favorable qualities, adding new nuclear generating capacity to the Crystal River Energy Complex at this time would result in a significant concentration of PEF's generating assets in one geographical location. This increases the likelihood of a significant generation loss from a single event and a potential large-scale impact on the PEF system. The Levy County location also would assist in avoiding a potential loss from a single significant transmission system event that might result in a large-scale impact on the PEF system.

PEF's assessment of the Levy County site addressed whether any threatened and endangered species or archeological and cultural resources would be adversely impacted by the development of the site for nuclear generation units and related facilities. No significant issues were identified in PEF's evaluations of the property.

The proximity of the Levy County site to the PEF's existing Crystal River Unit 3 nuclear plant provides opportunities for efficiencies in shared support functions. The Levy unit will be located on a greenfield site where site and transmission infrastructure must be constructed along with the buildings necessary for the power units. The site will include cooling towers, intake and discharge structures, containment buildings, auxiliary buildings, turbine buildings, diesel generators, warehouses, related site work and infrastructure, including roads, transmission lines, and a transmission substation. The Company submitted a Site Certification Application (SCA) to the Florida Department of Environmental Protection (FDEP) on June 2, 2008, for the entire site, including plants and associated facilities for the units. Site certification hearings were completed in March 2009, and the Siting Board approved the final certification in August 2009.

Nuclear power is a clean source of electric power generation. Electric power generation from nuclear fuel produces no sulfur dioxide (SO₂), nitrogen oxide (NO_x), green house gases (GHG), or other emissions. Therefore, it will have a positive effect on the surrounding air quality.

Water discharged from nuclear plants must meet federal Clean Water Act requirements and state water-quality standards. Before operating, a nuclear plant's licensing process requires an environmental impact statement that carefully examines and resolves all potential impacts to water quality from the operation of the plant. These issues include concerns about the discharge of waste water and the impacts on aquatic life in cooling water used by the plant.

Transmission modifications will be required to accommodate the Levy County Nuclear Power Plant.

FIGURE 4.1.a.
Levy County Nuclear Power Plant (Levy County)



FIGURE 4.1.b.

Levy County Nuclear Power Plant (Levy County) – Aerial View

