

REQUEST TO ESTABLISH DOCKET

(Please type or print. File original *plus* 1 copy with CLK.)

RECEIVED-FPSC
APR 18 PM 3:51
COMMISSION CLERK

Date:	4/18/2012	Docket No.:	120103-EI
1. From Division / Staff:	GCL / Murphy		
2. OPR:	ECR Dowds, Wu		
3. OCR:	GCL Murphy		
4. Suggested Docket Title:	Petition of Progress Energy Florida, Inc. to Modify Scope of Existing Environmental Program		
5. Program/Module/Submodule Assignment:	A3D		
6. Suggested Docket Mail List.			
a. Provide NAMES/ACRONYMS, if registered company.		<input checked="" type="checkbox"/> Provided as an Attachment	
Company Code, if applicable:	Parties (include address, if different from MCD):	Representatives (name and address):	
EI 801	Progress Energy Florida, Inc.	Same as Docket No 120007-EI	
b. Provide COMPLETE NAME AND ADDRESS for all others. (match representatives to companies)			
Company Code, if applicable:	Interested persons, if any, (include address, if different from MCD):	Representatives (name and address):	
	See comment below	See comment below	
7. Check one:	<input checked="" type="checkbox"/> Supporting Documentation Attached		<input type="checkbox"/> To be provided with Recommendation
Comments: Petition was originally filed in Docket No. 120007-EI; all parties and interested parties in that Docket should be listed as interested parties in the new docket with the same contact information.			

DOCUMENT NUMBER
02399 APR 18 2012
FPSC-COMMISSION CLERK

GCL

Hopping Green & Sams

Attorneys and Counselors

Writer's Direct Dial Number
(850) 425-2359

March 29, 2012

RECEIVED-FPSC
MAR 29 AM 11:12
COMMISSION
CLERK

BY HAND DELIVERY

Ann Cole
Office of the Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Docket No. 120007-EI
Petition of Progress Energy Florida, Inc., to Modify Scope of Existing
Environmental Program


Dear Ms. Cole:

On behalf of Progress Energy Florida, Inc. ("PEF"), I have enclosed for filing the original and fifteen copies of the PEF's Petition to Modify Scope of Existing Environmental Program.

Please stamp and return the enclosed extra copy of this filing. If you have any questions regarding this filing, please call either of us at 222-7500.

Very truly yours,

HOPPING GREEN & SAMS, PA.

By: 
Gary V. Perko

GVP/mee
Enclosure

cc: all counsel of record

DOCUMENT NUMBER - 0775
01831 MAR 29 2012
FPSC-COMMISSION CLERK

M
A
R 12
L
D
C
M
PC
K

BEFORE THE PUBLIC SERVICE COMMISSION

In re: Environmental Cost Recovery Clause

DOCKET NO. 120007-EI

FILED: March 29, 2012

**PROGRESS ENERGY FLORIDA, INC.'S PETITION TO MODIFY
SCOPE OF EXISTING ENVIRONMENTAL PROGRAM**

Progress Energy Florida, Inc. ("PEF" or "Company"), pursuant to Section 366.8255, Florida Statutes, and Florida Public Service Commission Order Nos. PSC-94-0044-FOF-EI and PSC-99-2513-FOF-EI, hereby petitions the Commission to modify the scope of its previously approved Integrated Clean Air Compliance Program to encompass additional activities such that the costs associated with such activities may be recovered through the Environmental Cost Recovery Clause ("ECRC"). In support, PEF states:

1. Petitioner. PEF is a public utility subject to the regulatory jurisdiction of the Commission under Chapter 366, Florida Statutes. The Company's principal offices are located at 299 First Avenue North, St. Petersburg, Florida.
2. Service. All notices, pleadings and other communications required to be served on the petitioner should be directed to:

Gary V. Perko
Hopping Green & Sams, P.A.
119 S. Monroe St., Suite 300
P.O. Box 6526 (32314)
Tallahassee, FL 32301
Tel. 850.222.7500
Fax. 850.224.8551
gperko@hgslaw.com

John T. Burnett
Dianne M. Triplett
Progress Energy Services Co., LLC
299 First Avenue North, PEF-151
St. Petersburg, FL 33701
john.burnett@pgnmail.com
dianne.triplett@pgnmail.com

3. Cost Recovery Eligibility. As further discussed below, the U.S. Environmental Protection Agency ("EPA") recently issued new air emission standards for coal and oil-fired electric generating units ("EGUs"). As a result of the new regulations, PEF will incur costs for

DOCUMENT NUMBER - 027

01831 MAR 29 2012

FPSC-COMMISSION CLERK

new environmental compliance activities related to its previously approved Integrated Clean Air Compliance Program. As detailed below, the new compliance activities meet the criteria for cost recovery established by the Commission in Order No. PSC-94-0044-FOF-EI in that:

- (a) all expenditures will be prudently incurred after April 13, 1993;
- (b) the activities are legally required to comply with a governmentally imposed environmental regulation that was created, became effective, or whose effect was triggered after the company's last test year upon which rates are based; and
- (c) none of the expenditures are being recovered through some other cost recovery mechanism or through base rates.

The information provided below for each program satisfies the minimum filing requirements established in Part VI of Order No. PSC-99-2513-FOF-EI.

4. PEF's Approved Integrated Clean Air Compliance Plan. In the 2007 ECRC Docket, the Commission approved PEF's Integrated Clean Air Compliance Plan (Plan D) as a reasonable and prudent means to comply with the requirements of the Clean Air Interstate Rule (CAIR), the Clean Air Mercury Rule (CAMR), the Clean Air Visibility Rule (CAVR), and related regulatory requirements. See Order No. PSC-07-0922-FOF-EI, at 8 (Nov. 16, 2007). In each subsequent ECRC docket, the Commission approved PEF's annual review of the Integrated Clean Air Compliance Plan, concluding that the Plan remains the most cost-effective alternative for achieving and maintaining compliance with the applicable air quality regulatory requirements. See Order No. PSC-11-0553-FOF-EI, at 13-14 (Dec. 7, 2011); Order No. PSC-10-0683-FOF-EI, at 6-7 (Nov. 15, 2010); Order No. PSC-09-0759-FOF-EI, at 18 (Nov. 18, 2009); Order No. 08-0775-FOF-EI, at 11 (Nov. 24, 2008).

5. New Environmental Requirements. As the Commission is aware, in February 2008, the U.S Circuit Court of Appeals for the District of Columbia vacated the CAMR regulation and rejected EPA's delisting of coal-fired EGUs from the list of emission sources that are subject to Section 112 of the Clean Air Act. See Order No. PSC-09-0759-FOF-EI, at pp. 15, 18 (Nov. 18, 2009). As a result, in lieu of CAMR, the EPA was required to adopt new emissions standards for control of hazardous air pollutant emissions from coal-fired EGUs. Id. The EPA issued its proposed rule to replace CAMR on March 16, 2011, with publication following in the *Federal Register* on May 3, 2011. See 76 Fed. Reg. 24976 (May 3, 2011). Following the public comment period on the proposed rule, the EPA released the final rule on December 21, 2011, with publication in the *Federal Register* following on February 16, 2012. See 77 Fed. Reg. 9304 (Feb. 26, 2012).

6. The final rule establishes new Mercury and Air Toxics Standards ("MATS") for emissions of various metals and acid gases from both coal and oil-fired EGUs, including, potentially, units at PEF's Crystal River Plant (Units 1, 2, 4, and 5), Anclote Plant (Units 1 and 2), and Suwannee Plant (Units 1, 2, and 3). The Clean Air Act generally provides a 3-year time frame to comply with MATS, although the permitting agency has the authority to add one year, and the President has the authority to add up to two additional years.

7. New Compliance Activities for Anclote Units 1 and 2. Anclote Units 1 and 2 currently have a maximum summer rating of 500MW and 510 MW, respectively. The current natural gas firing capability for each unit is limited to 40% of the total heat input. Because the balance of the heat input is from heavy fuel oil, the units would be subject to the new MATS for oil-fired EGUs. However, PEF has determined that the most cost-effective compliance option

for PEF's Anclote Units 1 and 2 is to convert the units to fire 100% natural gas and thereby remove the units from the scope of the new MATS regulation.

8. PEF considered two compliance alternatives for the Anclote units. The first option would achieve compliance with the new MATS through use of emissions controls, specifically low NOx burners and an electrostatic precipitator ("ESP"). The second option would achieve compliance through conversion of the units to operation on natural gas as the single fuel.¹ After estimating the capital costs and unit performance implications of the two options, PEF determined that the natural gas option has economic benefits in terms of both capital costs and fuel savings. Based on conservative cost estimates associated with the emissions controls that would be necessary to achieve oil-fired compliance, the capital cost of the gas conversion is expected to be at least \$12 million less than the capital costs for the emissions controls. PEF also estimated the fuel cost differential of the two options, primarily to ensure that implementation of the gas conversion would not cause an increase in system fuel costs. The analysis demonstrates that the net impact on system cost is positive (savings), indicating an additional benefit.

9. Preliminary studies indicate that the addition of three levels of fuel gas burners in combination with the existing natural gas burners will be required to provide full output on 100% natural gas. Thermal analysis of the boiler for operation on 100% natural gas indicates that a portion of the lower horizontal superheater will need to be removed to limit heat absorption and manage superheater tube metal temperatures. In addition, the gas supply line measurement and regulation ("M&R") facilities will require upgrades to support operation on 100% gas. Finally,

¹ A third option, discontinuation of heavy fuel oil use without conversion, was rejected because of its negative effect on fleet capacity and the resulting requirement to purchase or construct additional generation to meet reserve margin and operational requirements, including potential system reliability impacts

the finishing horizontal superheater for each unit will require metallurgy upgrades to accommodate the peak temperatures resultant from the gas conversion. While the additional burners and the replacement superheater form the majority of the boiler work required, other areas of the boiler and its control system may require configuration changes to complete the conversion based on ongoing boiler engineering analysis and condition assessment.

10. Cost Estimates. PEF expects to incur approximately \$79 million in total capital costs to convert the Anclote units to fire 100% natural gas. PEF expects to incur approximately \$26 million in 2012 and the remainder (approximately \$53 million) in 2013. PEF currently anticipates that both converted units will be placed in service by the end of 2013.

11. Prudence of Expenditures. As discussed above, in order to ensure that the costs incurred to comply with the new regulation are prudent and reasonable, PEF performed a comparative analysis and determined that the natural gas conversion project is the most cost-effective compliance option for Anclote Units 1 and 2. To ensure that actual expenditures are reasonable, PEF will competitively bid procurement of major boiler equipment to boiler original equipment manufacturers (OEMs).

12. No Base Rates Recovery of Program Costs. None of the costs for which PEF seeks recovery by this Petition were included in the MFRs that PEF filed in its last ratemaking proceeding in Docket No. 090079-EI. Therefore, the costs are not recovered in PEF's base rates.

13. No Change in Current ECRC Factors. PEF does not seek to change the ECRC factors currently in effect for 2012. The Company proposes to include in its estimated true-up filing for 2012 all program costs incurred subsequent to the filing of this petition through the end of 2012. PEF expects that all of these costs will be subject to audit by the Commission and that

the appropriate allocation of program costs to rate classes will be addressed in connection with subsequent filings.


14. No Material Facts in Dispute. PEF is not aware of any dispute regarding any of the material facts contained in this petition. The information provided in this petition demonstrates that the programs for which approval is requested meets the requirements of Section 366.8255 and applicable Commission orders for recovery through the ECRC.

WHEREFORE, PEF requests that the Commission modify the scope of PEF's previously approved Integrated Clean Air Compliance Program to encompass additional activities associated with the Anclote MATS compliance project described above, such that the costs associated with such activities reasonably may be recovered through the ECRC.

RESPECTFULLY SUBMITTED this 29th day of March, 2012.

John T. Burnett
Associate General Counsel
Dianne M. Triplett
Associate General Counsel
PROGRESS ENERGY SERVICE
COMPANY, LLC
Post Office Box 14042
St. Petersburg, FL 33733-4042
PEF-151

HOPPING GREEN & SAMS, P.A.

By: 
Gary V. Perko
119 S. Monroe St., Ste. 300 (32301)
P.O. Box 6526
Tallahassee, FL 32314
gperko@hgslaw.com
Tel.: (850) 425-2359
Fax: (850) 224-8551

Attorneys for PROGRESS ENERGY FLORIDA, INC.

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished to all counsel of record and interested parties as listed below via regular U.S. mail this 29th day of March, 2012.

Martha Carter Brown, Esquire
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

J. Jeffrey Wahlen, Esquire
James D. Beasley, Esquire
Ausley Law Firm
Post Office Box 391
Tallahassee, Florida 32302

J.R. Kelly, Esquire
Patricia Christensen, Esquire
Charles J. Rehwinkel, Esquire
Office of Public Counsel
c/o The Florida Legislature
111 West Madison Street, Room 812
Tallahassee, Florida 32399

Jeffrey A. Stone, Esquire
Russell A. Badders, Esquire
Beggs & Lane Law Firm
Post Office Box 12950
Pensacola, Florida 32591-2950

Karen S. White, Staff Attorney
c/o AFLSA/JACL-ULT
139 Barnes Drive, Suite 1
Tyndall AFB, Florida 32403-5319

Keef Law Firm
Vicki Gordon Kaufman/John C. Moyle, Jr.
118 North Gadsden Street
Tallahassee, Florida 32301

John T. Butler, Esquire
Florida Power & Light Co.
700 Universe Boulevard
Juno Beach, Florida 33408-0420


Florida Power & Light Co.
215 S. Monroe Street, Suite 810
Tallahassee, Florida 32301

Paul Lewis, Jr.
Progress Energy Florida, Inc.
106 East College Avenue, Suite 800
Tallahassee, Florida 32301-7740

Susan Ritenour, Esquire
Gulf Power Company
One Energy Place
Pensacola, Florida 32520-0780

Paula K. Brown, Esquire
Regulatory Affairs
Tampa Electric Company
Post Office Box 111
Tampa, Florida 33601-0111

R. Alexander Glenn, Esquire
John T. Burnett, Esquire
Dianne M. Triplett, Esquire
Progress Energy Service Company, LLC
Post Office Box 14042
St. Petersburg, Florida 33733



Attorney