

State of Florida



# Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD  
TALLAHASSEE, FLORIDA 32399-0850

**-M-E-M-O-R-A-N-D-U-M-**

RECEIVED-FPSC  
12 AUG - 8 PM 3: 52  
COMMISSION  
CLERK

---

**DATE:** August 8, 2012  
**TO:** Ann Cole, Commission Clerk, Office of Commission Clerk  
**FROM:** James E. McRoy, Utility System/Engineering Specialist, Division of Engineering  
**RE:** Docket No. 120078-SU; Application for staff-assisted rate case in Brevard County by TKCB.

---

Attached is a response from the Utility to the Department of Environmental Protection (DEP) in regard to their May 22, 2012, Compliance Inspection Report (CEI). Please place the attached document in the docket file.

Should you have any questions regarding this matter, please contact me.

Attachment

DOCUMENT NUMBER-DATE

05413 AUG-8 2012

FPSC-COMMISSION CLERK

Gr 7/27  
CA 7/27  
JP

RECEIVED-DEP  
CENTRAL DISTRICT OFFICE  
2012 JUL 24 AM 10: 01

DATE: July 23, 2012

TO: DEP (CLARENCE ANDERSON)

FROM: JERRY PADRICK

RE: SUNLAKE ESTATES WASTEWATER PLANT (OCD-C-WW-12-0391)

Mr. Anderson,

This letter is a response to the inspection report conducted on 05/22/2012 by Tom Powers. The following corrective action will be taken.

1. The grit and sand in the surge tank will be cleaned and we have received a bid of over 3,000 dollars to do so; however, as you may be aware, we are in the process of obtaining an increase of fees from our customers via the Public Service Commission. This will be our first increase ever and the plant has been in operation since 1983. We are requesting that we be allowed the time to receive this increase to cover the cost. As per Public Service Commission, this should take place by the first of the year of 2013. This cost has been submitted to the Public Service Commission.
2. As stated in number 1, we are also requesting time for the communitor as well.
3. As per the seepage of wastewater, I will be repairing as needed. They are not bad leaks but I will keep an eye on it.
4. As stated in number 1, we have received 3 bids for the entire perimeter fence, averaging 6500 dollars, including the north fence to be repaired when we receive the go ahead from the Public Service Commission, but for now we will temporarily fix the north fence.
5. Ground water deficiencies have been corrected and sent to Marsha Johnson over a week ago.

Thank you. Should there be any further questions, please contact me.

Jerry Padrick (321-508-4714) or Thad Terry (321-639-1124)



DOCUMENT NUMBER-DATE  
05413 AUG-8 09  
EPSC-COMMISSION CLERK