



John T. Butler
Assistant General Counsel – Regulatory
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5639
(561) 691-7135 (Facsimile)
E-mail: john.butler@fpl.com

April 22, 2013

Ms. Ann Cole
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

RECEIVED-FPSC
13 APR 22 AM 11: 08
COMMISSION
CLERK

Re: Docket No. 130001-EI

Dear Ms. Cole:

As requested by the Commission Staff, Florida Power & Light Company hereby files the original and ten (10) copies of the GPIF Actual Unit Performance Data Schedules covering the month of March 2013.

These schedules are being filed at the same time but separately from its monthly filing of the A Schedules.

If there are any questions regarding this transmittal, please contact me at 561-304-5639.

COM _____
AFD H
APA _____
ECO _____
ENG _____
GCL _____
IDM _____
TEL _____
CLK _____

Sincerely,

A handwritten signature in blue ink, appearing to read "John T. Butler".

John T. Butler

Copy to: All parties of record

DOCUMENT NUMBER-DATE

02099 APR 22 2013


FPSC-COMMISSION CLERK

CERTIFICATE OF SERVICE
Docket No. 130001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished by hand delivery (*) or United States mail this 22nd day of April 2013, to the following:

| | |
|--|---|
| Martha F. Barrera, Esq.* Division of Legal Services Florida Public Service Commission 2540 Shumard Oak Blvd Tallahassee, Florida 32399-0850 | Michael Barrett Division of Economic Regulation Florida Public Service Commission 2540 Shumard Oak Blvd Tallahassee, Florida 32399-0850 |
| James D. Beasley, Esq. J. Jeffrey Wahlen, Esq. Ausley & McMullen Attorneys for Tampa Electric P.O. Box 391 Tallahassee, Florida 32302 | John T. Burnett, Esq. Dianne M. Triplett, Esq. Attorneys for PEF P.O. Box 14042 St. Petersburg, Florida 33733-4042 |
| J. R. Kelly, Esq. Patricia Christensen, Esq. Charles Rehwinkel, Esq. Joseph A. McGlothlin, Esq. Erik L. Sayler, Esq. Office of Public Counsel c/o The Florida Legislature 111 West Madison Street, Room 812 Tallahassee, Florida 32399 | Beth Keating, Esq. Gunster Law Firm Attorneys for FPUC 215 So. Monroe St., Suite 601 Tallahassee, Florida 32301-1804 |
| Jeffrey A. Stone, Esq. Russell A. Badders, Esq. Beggs & Lane Attorneys for Gulf Power P.O. Box 12950 Pensacola, FL 32591-2950 | James W. Brew, Esq. / F. Alvin Taylor, Esq. Attorney for White Springs Brickfield, Burchette, Ritts & Stone, P.C 1025 Thomas Jefferson Street, NW Eighth Floor, West Tower Washington, DC 20007-5201 |
| Jon C. Moyle, Esq. Moyle Law Firm, P.A. 118 N. Gadsden St. Tallahassee, FL 32301 Counsel for FIPUG | |

By:



John T. Butler
Fla. Bar No. 283479

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: FORT MYERS 02 | | | | | | | | | | | | PFM 02 | | |
|---------------------|-----------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|---|----------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | | |
| 1. EAF (%) | 99.5 | 96.3 | 98.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 98.1 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. UH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. PFOH | 0.63 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.63 |
| 12. LR PF (MW) | 55 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 55 |
| 13. PMOH | 22.57 | 149.33 | 79.77 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 251.67 |
| 14. LR PM (MW) | 221.32 | 221.8 | 221.38 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 221.62 |
| 15. NSC | 1327 | 1327 | 1327 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1327 |
| 16. OPER BTU (MBTU) | 5404820 | 5054877 | 5582877 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 16042574 |
| 17. NET GEN | 742268 | 694086 | 760902 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2197256 |
| 18. ANOHR (BTU/KWH) | 7281 | 7283 | 7337 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 7301 |
| 19. NOF (%) | 75.2 | 77.8 | 77.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 76.7 |
| 20. NPC (MW) | 1570 | 1570 | 1570 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1570 |

| | | |
|--------------------|--|------------------------|
| 21. ANOHR EQUATION | | ANOHR = A + B (N.O.F.) |
| | | A = 0 B ≠ 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

ISSUED BY: FLORIDA POWER & LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

DOCUMENT NUMBER-DATE

02099 APR 22 2013

FPSC-COMMISSION CLERK

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: SCHERER 04 | | | | | | | | | | | | PSG | 04 |
|---------------------|--------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | |
| 1. EAF (%) | 100 | 100 | 100 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. UH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. PFCH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12. LR PF (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 13. PMOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 14. LR PM (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15. NSC | 855 | 855 | 855 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 855 |
| 16. OPER BTU (MBTU) | 5464506 | 4939847 | 5841339 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 16245792 |
| 17. NET GEN | 532587 | 472197 | 586645 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1571429 |
| 18. ANOHR (BTU/KWH) | 10260 | 10462 | 10309 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10338 |
| 19. NOF (%) | 83.7 | 82.2 | 89.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 86.1 |
| 20. NPC (MW) | 882 | 882 | 882 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 882 |

| | |
|--------------------|------------------------|
| 21. ANOHR EQUATION | ANOHR = A + B (N.O.F.) |
| | A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: ST LUCIE 01 | | | | | | | | | | | | PSL 01 | | |
|---------------------|---------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|---|----------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | | |
| 1. EAF (%) | 100 | 100 | 37.4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 78.5 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 744 | 672 | 277.85 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1693.85 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. UH | 0 | 0 | 465.15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 465.15 |
| 6. POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. FOH | 0 | 0 | 465.15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 465.15 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. PFOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12. LR PF (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 13. PMOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 14. LR PM (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15. NSC | 981 | 981 | 981 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 981 |
| 16. OPER BTU (MBTU) | 7660834 | 6919132 | 2861520 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 17441485 |
| 17. NET GEN | 746897 | 674896 | 280168 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1701760 |
| 18. ANOHR (BTU/KWH) | 10257 | 10255 | 10214 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10249 |
| 19. NOF (%) | 102.3 | 102.3 | 102.6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 102.4 |
| 20. NPC (MW) | 981 | 981 | 981 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 981 |

| | | |
|--------------------|--|------------------------------|
| 21. ANOHR EQUATION | | ANOHR = A + B (N.O.F.) |
| | | A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2013 TO: Dec-2013

| | | PLANT / UNIT: ST LUCIE 02 | | | | | | | | | | | | PSL 02 |
|-----|-----------------|---------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|----------|
| | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | |
| 1. | EAF (%) | 100 | 100 | 100 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 |
| 2. | PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. | SH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 4. | RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. | UH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. | POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. | FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. | MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. | PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. | LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. | PFOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12. | LR PF (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 13. | PMOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 14. | LR PM (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15. | NSC | 968 | 968 | 968 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 968 |
| 16. | OPER BTU (MBTU) | 6849798 | 6187107 | 6839926 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 19876830 |
| 17. | NET GEN | 757524 | 684128 | 758001 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2199653 |
| 18. | ANOHR (BTU/KWH) | 9042 | 9044 | 9024 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 9036 |
| 19. | NOF (%) | 105.2 | 105.2 | 105.4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 105.3 |
| 20. | NPC (MW) | 968 | 968 | 968 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 968 |

| | | |
|-----|----------------|------------------------|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.) |
| | | A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: | TURKEY POINT 03 | | | | | | | | | | | | PTN 03 | | |
|-----|-----------------|-----------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|---|----------|
| | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | | |
| 1. | EAF (%) | 98 | 47 | 52.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 66.5 |
| 2. | PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. | SH | 744 | 334.7 | 412.3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1491 |
| 4. | RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. | UH | 0 | 337.3 | 330.7 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 668 |
| 6. | POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. | FOH | 0 | 337.3 | 330.7 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 668 |
| 8. | MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. | PPOH | 49.18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 49.18 |
| 10. | LR PP (MW) | 208.01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 208.01 |
| 11. | PFOH | 0 | 33.6 | 36.28 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 69.88 |
| 12. | LR PF (MW) | 0 | 395 | 424.3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 410.21 |
| 13. | PMOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 14. | LR PM (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15. | NSC | 693 | 693 | 693 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 693 |
| 16. | OPER BTU (MBTU) | 5636592 | 2509870 | 2938701 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11085164 |
| 17. | NET GEN | 597091 | 260592 | 310201 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1167884 |
| 18. | ANOHR (BTU/KWH) | 9440 | 9831 | 9474 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 9492 |
| 19. | NOF (%) | 115.8 | 112.3 | 108.6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 113 |
| 20. | NPC (MW) | 693 | 693 | 693 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 693 |

| | | |
|-----|----------------|------------------------|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.) |
| | | A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: TURKEY POINT 04 | | | | | | | | | | | | PTN 04 |
|---------------------|-------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd |
| 1. EAF (%) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. UH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 6. POH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 7. FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. PFOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12. LR PF (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 13. PMOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 14. LR PM (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15. NSC | 693 | 693 | 693 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 693 |
| 16. OPER BTU (MBTU) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 17. NET GEN | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18. ANOHR (BTU/KWH) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 19. NOF (%) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 20. NPC (MW) | 693 | 693 | 693 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 693 |

| | |
|--------------------|--|
| 21. ANOHR EQUATION | ANOHR = A + B (N.O.F.) A = 0 B = 0 |
|--------------------|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | | PLANT / UNIT: TURKEY POINT #6 05 | | | | | | | | | | | | TP5 05 | |
|-----|-----------------|----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
| | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | |
| 1. | EAF (%) | 100 | 99.8 | 94.3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 98 |
| 2. | PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. | SH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 4. | RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. | UH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. | POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. | FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. | MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. | PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. | LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. | PFOH | 0.33 | 5.47 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 5.8 |
| 12. | LR PF (MW) | 112 | 258.6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 250.08 |
| 13. | PMOH | 0 | 0 | 184.52 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 184.52 |
| 14. | LR PM (MW) | 0 | 0 | 287.77 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 287.77 |
| 15. | NSC | 1034 | 1034 | 1034 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1034 |
| 16. | OPER BTU (MBTU) | 3798948 | 3764282 | 4110863 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11664094 |
| 17. | NET GEN | 534019 | 533061 | 584865 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1651945 |
| 18. | ANOHR (BTU/KWH) | 7114 | 7043 | 7029 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 7081 |
| 19. | NOF (%) | 69.4 | 76.7 | 76.1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 74 |
| 20. | NPC (MW) | 1179 | 1179 | 1179 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1179 |

| | | |
|-----|----------------|------------------------|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.) |
| | | A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: MANATEE UNIT 3 CC 03 | | | | | | | | | | | | PM3 - 03 |
|---------------------|------------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|----------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd |
| 1. EAF (%) | 96.8 | 99.4 | 90.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 95.3 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5. UH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. POH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7. FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10. LR PP (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11. PFOH | 2.75 | 0 | 2.92 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 5.67 |
| 12. LR PF (MW) | 259.75 | 0 | 259.75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 259.75 |
| 13. PMOH | 87.05 | 9.12 | 288.48 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 384.65 |
| 14. LR PM (MW) | 278.3 | 431 | 259.75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 268.01 |
| 15. NSC | 1039 | 1039 | 1039 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1039 |
| 16. OPER BTU (MBTU) | 3937187 | 3643039 | 4073794 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11664020 |
| 17. NET GEN | 566467 | 523478 | 591271 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1681216 |
| 18. ANOHR (BTU/KWH) | 6950 | 6959 | 6890 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 6932 |
| 19. NOF (%) | 73.3 | 75 | 76.6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 74.9 |
| 20. NPC (MW) | 1187 | 1187 | 1187 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1187 |

| | |
|--------------------|--|
| 21. ANOHR EQUATION | ANOHR = A + B (N.O.F.) A = 0 B = 0 |
|--------------------|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2013 TO: Dec-2013

| | PLANT / UNIT: MARTIN-UNIT 8 08 | | | | | | | | | | | | PM8 | 08 |
|---------------------|--------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd | |
| 1. EAF (%) | 84.3 | 93.5 | 70.9 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 82.6 |
| 2. PH | 744 | 672 | 743 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2159 |
| 3. SH | 744 | 672 | 530.62 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1946.62 |
| 4. RSH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6. UH | 0 | 0 | 212.38 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 212.38 |
| 6. POH | 0 | 0 | 212.38 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 212.38 |
| 7. FOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8. MOH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9. PPOH | 0 | 0 | 3.33 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3.33 |
| 10. LR PP (MW) | 0 | 0 | 634.69 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 634.69 |
| 11. PFOH | 336.48 | 0 | 8.8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 345.28 |
| 12. LR PF (MW) | 269.23 | 0 | 265.75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 269.14 |
| 13. PMOH | 125.52 | 174.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 299.72 |
| 14. LR PM (MW) | 265.75 | 265.75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 265.75 |
| 15. NSC | 1063 | 1063 | 1063 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1063 |
| 16. OPER BTU (MBTU) | 3744008 | 3840841 | 3506546 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11091395 |
| 17. NET GEN | 536838 | 670264 | 511746 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1618838 |
| 18. ANOHR (BTU/KWH) | 6974 | 6735 | 6852 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 6851 |
| 19. NOF (%) | 67.9 | 79.8 | 90.7 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 78.2 |
| 20. NPC (MW) | 1180 | 1180 | 1180 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1180 |
| 21. ANOHR EQUATION | | | | | | | | | | | | | | ANOHR = A + B (N.O.F.) A = 0 B = 0 |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
From: Jan-2013 To: Dec-2013

PLANT / UNIT: FORT MYERS 02 PFM 02

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|--------------------------------------|
| 01/25/2013 | FMO | 22.6 | 145 | 2E CT MOF |
| 01/25/2013 | PMO | 22.6 | 67.47 | Impact loss due to curtailment on 2E |
| 01/25/2013 | PMO | 22.6 | 8.86 | Impact loss due to curtailment on 2E |
| 01/26/2013 | PFO | 0.6 | 55 | 2C CT EFOR |
| 02/11/2013 | FMO | 51.6 | 145 | 2C CT MOF |
| 02/11/2013 | PMO | 51.6 | 67.47 | Impact loss due to curtailment on 2C |
| 02/11/2013 | PMO | 51.6 | 8.86 | Impact loss due to curtailment on 2C |
| 02/17/2013 | FMO | 74.1 | 145 | 2D CT MOF |
| 02/17/2013 | PMO | 74.1 | 67.47 | Impact loss due to curtailment on 2D |
| 02/17/2013 | PMO | 74.1 | 8.86 | Impact loss due to curtailment on 2D |
| 02/28/2013 | FMO | 23.7 | 145 | 2F MOF |
| 02/28/2013 | PMO | 23.7 | 67.47 | Impact loss due to curtailment on 2F |
| 02/28/2013 | PMO | 23.7 | 8.86 | Impact loss due to curtailment on 2F |
| 02/28/2013 | FMO | 22.6 | 145 | 2B CT MOF |
| 02/28/2013 | PMO | 22.6 | 8.86 | Impact loss due to curtailment on 2B |
| 02/28/2013 | PMO | 22.6 | 67.47 | Impact loss due to curtailment on 2B |
| 03/05/2013 | FMO | 40.4 | 145 | 2D CT MOF |
| 03/05/2013 | PMO | 40.4 | 67.47 | Impact loss due to curtailment on 2D |
| 03/05/2013 | PMO | 40.4 | 8.86 | Impact loss due to curtailment on 2D |
| 03/22/2013 | FMO | 17.1 | 145 | 2C CT MOF |
| 03/22/2013 | PMO | 17.1 | 67.47 | Impact loss due to curtailment on 2C |
| 03/22/2013 | PMO | 17.1 | 8.86 | Impact loss due to curtailment on 2C |

- (1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
From: Jan-2013 To: Dec-2013

PLANT / UNIT: ST LUCIE 01 PSL 01

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|---|
| 03/12/2013 | FFO | 465.2 | 981 | U1 UEL Unplanned Auto Scram due to 1B MSIV failure 03121: |

- (1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2013 To: Dec-2013

PLANT / UNIT: TURKEY POINT 03 PTN 03

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|---|
| 01/29/2013 | PPO | 49.2 | 208 | Unit 3 planned downpower for Turbine Valve testing |
| 02/11/2013 | FFO | 74.8 | 693 | Unit 3 Auto Trip due to loss of condenser vacuum |
| 02/15/2013 | PFO | 33.6 | 395 | Unit 3 power ascension following unplanned Auto Trip |
| 02/18/2013 | FFO | 516.1 | 693 | Unit 3 unplanned manual trip due to 3A RCP seal failure |
| 03/11/2013 | PFO | 2.9 | 692 | Unit 3 power ascension following the RCP seal replacement |
| 03/11/2013 | FFO | 21.1 | 693 | Unit 3 Turbine Trip due to #3 Control valve abnormal response |
| 03/12/2013 | FFO | 56.1 | 693 | Unit 3 Auto reactor trip |
| 03/14/2013 | PFO | 33.4 | 401 | Unit 3 power ascension following Auto reactor trip |

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
From: Jan-2013 To: Dec-2013

PLANT / UNIT: TURKEY POINT 04

PTN 04

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|--------|---------------|--|
| 01/01/2013 | FPO | 2159.0 | 693 | Unit 4 Cycle 27 Refueling / Extended power uprate outage |

- (1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:
ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2013 To: Dec-2013

PLANT / UNIT: TURKEY POINT #5 05 TP5 05

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|--|
| 01/17/2013 | PFO | 0.3 | 112 | 5A BFP EMERGENCY STOP PUSH BUTTON MISTAKENLY |
| 02/03/2013 | FFO | 6.5 | 147 | CT "5D" tripped on 2/3/13 |
| 02/03/2013 | PFO | 5.5 | 111.5 | Impact loss due to curtailment on 5D |
| 03/15/2013 | FMO | 31.6 | 147 | 5C Install LF Pump SNOW |
| 03/15/2013 | PMO | 31.6 | 111.5 | Impact loss due to curtailment on 5C |
| 03/17/2013 | FMO | 30.1 | 147 | 5B Gas Orifice Calibration SNOW |
| 03/17/2013 | PMO | 30.1 | 111.5 | Impact loss due to curtailment on 5B |
| 03/18/2013 | FMO | 78.6 | 147 | 5A 1st Quarter Rainbow Inspection |
| 03/18/2013 | PMO | 78.6 | 111.5 | Impact loss due to curtailment on 5A |
| 03/25/2013 | FMO | 30.3 | 147 | 5D CT & Duct Burner Gas Transmitter Calibrations |
| 03/25/2013 | PMO | 30.3 | 111.5 | Impact loss due to curtailment on 5D |

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2013 To: Dec-2013

PLANT / UNIT: MANATEE UNIT 3 CC 03 PM3 03

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|--|
| 01/07/2013 | FMO | 31.8 | 152 | 3A SRV Valve replace |
| 01/07/2013 | PMO | 31.8 | 107.75 | Impact loss due to curtailment on 3A |
| 01/08/2013 | FMO | 29.1 | 152 | 3D SRV Valve replace |
| 01/08/2013 | PMO | 29.1 | 107.75 | Impact loss due to curtailment on 3D |
| 01/17/2013 | FMO | 32.5 | 152 | 3A SRV VALVE |
| 01/17/2013 | PMO | 32.5 | 107.75 | Impact loss due to curtailment on 3A |
| 01/27/2013 | FFO | 2.8 | 152 | PMT 3B Trip |
| 01/27/2013 | PFO | 2.8 | 107.75 | Impact loss due to curtailment on 3B |
| 02/18/2013 | FMO | 9.1 | 431 | Hydrogen Leak |
| 03/07/2013 | FMO | 271.8 | 152 | 3D Compressor Borescope Inspection |
| 03/07/2013 | PMO | 271.8 | 107.75 | Impact loss due to curtailment on 3D |
| 03/18/2013 | FFO | 2.9 | 152 | 3B Trip On Combustion Issues - Lean Blow Out |
| 03/18/2013 | PFO | 2.9 | 107.75 | Impact loss due to curtailment on 3B |
| 03/26/2013 | FMO | 16.7 | 152 | 3B Compressor Borescope Inspection |
| 03/26/2013 | PMO | 16.7 | 107.75 | Impact loss due to curtailment on 3B |

- (1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO.:
 ORDER NO.:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 From: Jan-2013 To: Dec-2013

PLANT / UNIT: MARTIN-UNIT 8 08 PM8 08

| DATE | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION |
|------------|----------------|-------|---------------|--|
| 01/01/2013 | FMO | 97.1 | 157 | 8A EVENT MOF |
| 01/01/2013 | PMO | 97.1 | 108.75 | Impact loss due to curtailment on 8A |
| 01/05/2013 | FFO | 4.2 | 157 | 8D CT TRIP due to 8C LIGHTNING ARRESTOR failure on hig |
| 01/05/2013 | PFO | 4.2 | 108.75 | Impact loss due to curtailment on 8D |
| 01/05/2013 | FFO | 29.6 | 157 | 8C FORCED OUTAGE LIGHTNING ARRESTOR |
| 01/05/2013 | PFO | 29.6 | 108.75 | Impact loss due to curtailment on 8C |
| 01/05/2013 | PFO | 2.1 | 22 | 8D Runback DUE TO HIGH RH TEMPS |
| 01/10/2013 | FFO | 306.9 | 157 | 8A Main Steam Altemporator - failed plug |
| 01/10/2013 | PFO | 306.9 | 108.75 | Impact loss due to curtailment on 8A |
| 01/23/2013 | FMO | 28.4 | 157 | 8A TESTING FOR BOG DOWN PROBLEMS |
| 01/23/2013 | PMO | 28.4 | 108.75 | Impact loss due to curtailment on 8A |
| 02/13/2013 | FMO | 174.2 | 157 | 8C Task MOF-HP Desuperheater inspection |
| 02/13/2013 | PMO | 174.2 | 108.75 | Impact loss due to curtailment on 8C |
| 03/01/2013 | FFO | 4.9 | 157 | 8A CT #5 Can LF False Start drain line |
| 03/01/2013 | PFO | 4.9 | 108.75 | Impact loss due to curtailment on 8A |
| 03/08/2013 | FFO | 3.9 | 157 | 8C CT Overtemp Trip |
| 03/08/2013 | PFO | 3.9 | 108.75 | Impact loss due to curtailment on 8C |
| 03/23/2013 | PPO | 1.5 | 108.75 | Impact loss due to curtailment on 8D |
| 03/23/2013 | FPO | 215.7 | 157 | 8D CT OUTAGE |
| 03/23/2013 | PPO | 0.8 | 108.75 | Impact loss due to curtailment on 8A |
| 03/23/2013 | FPO | 215.1 | 157 | 8A CT OUTAGE |
| 03/23/2013 | FPO | 214.3 | 435 | 8X STEAM TURBINE OUTAGE |
| 03/23/2013 | FPO | 213.1 | 157 | 8B CT OUTAGE |
| 03/23/2013 | FPO | 212.4 | 157 | 8C CT OUTAGE |

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:

SUSPENDED:

EFFECTIVE:

DOCKET NO.:

ORDER NO.:

GPIF Units
Actual Performance Data (ACRONYMS) for 2013

| ACRONYMS | DESCRIPTION |
|----------------|---|
| "R" | Mark VI "R" Processor |
| 1A2 | Unit 1 Pump A2 |
| 1B | Unit 1 Pump B |
| 2B1 | Unit 2 Pump B1 |
| 2A | Unit 2 Combustion Turbine (sub unit A) |
| 2A CT - 2A 230 | Combustion Turbine (sub unit A) - 2A Collector Bus |
| 2A HDP | 2 Alpha High Differential Pressure |
| 2B | Unit 2 Combustion Turbine (sub unit B) |
| 2B CT - 2A 230 | Combustion Turbine (sub unit B) - 2A Collector Bus |
| 2B MSR | 2 Bravo Moisture Separator Reheater |
| 2C | Unit 2 Combustion Turbine (sub unit C) |
| 2C CT - 2A 230 | Combustion Turbine (sub unit C) - 2A Collector Bus |
| 2D | Unit 2 Combustion Turbine (sub unit D) |
| 2E | Unit 2 Combustion Turbine (sub unit E) |
| 2F | Unit 2 Combustion Turbine (sub unit F) |
| 3 CTB | Unit 3 Combustion Turbine (sub unit B) |
| 3A | Unit 3 Combustion Turbine (sub unit A) |
| 3B | Unit 3 Combustion Turbine (sub unit B) |
| 3C | Unit 3 Combustion Turbine (sub unit C) |
| 3D | Unit 3 Combustion Turbine (sub unit D) |
| 3ST | Unit 3 Steam Turbine |
| 41AC-1 | Breaker 1 for Power Supply to Exciter |
| 41AC-2 | Breaker 2 for Power Supply to Exciter |
| 4A | Unit 4 Combustion Turbine (sub unit A) |
| 4A SGFP | 4A Steam Generator Feedwater Pump |
| 4B | Unit 4 Combustion Turbine (sub unit B) |
| 4C | Unit 4 Combustion Turbine (sub unit C) |
| 4D | Unit 4 Combustion Turbine (sub unit D) |
| 4KV | 4 Thousand Volts |
| 5A | Unit 5 Combustion Turbine (sub unit A) |
| 5B | Unit 5 Combustion Turbine (sub unit B) |
| 5C | Unit 5 Combustion Turbine (sub unit C) |
| 5D | Unit 5 Combustion Turbine (sub unit D) |
| 5ST | Unit 5 Steam Turbine |
| 8A | Unit 8 Combustion Turbine (sub unit A) |
| 8B | Unit 8 Combustion Turbine (sub unit B) |
| 8C | Unit 8 Combustion Turbine (sub unit C) |
| 8D | Unit 8 Combustion Turbine (sub unit D) |
| 8X | Unit 8 Steam Turbine |
| 89SS | Static Start Switch |
| 89ND | Neutral disconnect switch on the generator |
| AA | Anhydrous Ammonia |
| ABV | Air Block Valve |
| ACV-3 | Automatic Control Valve # 3 |
| ACV-408 | Air Control Valve Tag 408 |
| ASGJ-BV-27ED | A (unit 2A) SGJ (hot reheat to condenser) BV (block valve) 27 (#) ED (valve bypass) |
| AUX | Auxiliary |
| BFP | Boiler Feed Pump |
| BFPT | Boiler Feed Pump Turbine |
| BRG | Bearing |
| BRK | Breaker |
| BSGG | Unit B, main steam section of HRSG |
| CBV | Compressor Bleed Valve |

GPIF Units
Actual Performance Data (ACRONYMS) for 2013

| ACRONYMS | DESCRIPTION |
|--------------|--|
| CEA | Control Element Assembly |
| CEA 38 | Control Element Assembly Number 38 |
| CEA 65 | Control Element Assembly Number 65 |
| CEDM | Control Element Drive Mechanism |
| Circ | Circulating (water pump) |
| com | Communication |
| comm | Communication |
| CRH | Cold Reheat |
| CT | Combustion Turbine |
| CT C | Combustion Turbine (sub unit C) |
| CTG SRV | Speed Ratio Valve on Combustion Turbine (gas system) |
| CV-4-1510 | Control Valve Number 4-1510 |
| CW | Circulating Water |
| CWP | Circulating Water Pump |
| DCS | Distributed Control System |
| DEH | Digital Electro Hydraulic |
| DFS | Debris Filtration System |
| diff | Differential |
| DLN | Dry Low Nox |
| DP | Differential Pressure |
| DWATT XDUCER | Megawatt transducer |
| DX | DeXcitation |
| EFOR | Equivalent Forced Outage Rate |
| EHC | Hydraulic |
| EOC | End of cycle |
| EPU | Extended Power Uprate |
| ESGA | System code for Ft. Myers 2E HRSG |
| EXP | Expansion |
| Fa | Failed |
| FGT | Florida Gas Transmission |
| FME | Foreign Material Exclusion |
| FPI | Fluorescent penetrant inspection |
| FSGJ | F is the unit (2F) SGJ is the system designator |
| FSNL | Full Speed No Load |
| FRV | Feedwater Regulating Valve |
| FW | Feedwater |
| FWC | Feedwater Control |
| GCV | Gas Control Valve |
| GE | General Electric |
| GSU | Generator Step Up |
| Haz | Hazardous |
| HI | High |
| HMI | Human Machine Interface |
| HP | High Pressure |
| HRH | Hot Reheat |
| HRSG | Heat Recovery Steam Generator |
| HTF | Heat Transfer Fluid |
| I/O | Input / Output |
| IBH | Inlet Bleed Heat Valve |
| ID | Induced Draft |
| IGV | Inlet guide vanes |
| Instr. | Instrumentation |
| IP | Intermediate Pressure |
| ISO | Isolation |

GPIF Units
Actual Performance Data (ACRONYMS) for 2013

| ACRONYMS | DESCRIPTION |
|-------------|--|
| LCI | Load Commutating Inverter |
| LCO | Limiting Conditions for Operation |
| LF | Liquid Fuel |
| LL | Low Low |
| LO | Low |
| LP | Low Pressure |
| MFIV | Main Feed Isolation Valve |
| MF PP | Main Feed Pump |
| MG | Motor Generator |
| MOF | Maintenance Outage Factor |
| mof | maintenance outage factor |
| MOF/AA | Maintenance Outage Factor / Atomizing Air |
| MOV | Motorized Operating Valve |
| MSR | Moisture Separator Reheater |
| MSSV | Main Steam Safety Valve |
| MSIV | Main Steam Isolation Valves |
| MW | Megawatt |
| MUV | Motor actuated <u>Unidirectional Valve</u> |
| NO | No |
| O/H | Overhaul |
| OLWW | Off-Line Water Wash |
| OMC | Outside Management Control |
| P&C | Protect and Control |
| POF | Planned Outage Factor |
| PEL | Planned Energy Loss |
| PFM | Ft. Myers |
| PM1 | Gas Valve Number 1 |
| PM3 | Gas Valve Number 3 |
| MAJOR | Major Overhaul |
| PM320102662 | Manatee Unit 3 GADS #20102662 |
| PMG | Martin |
| MS | Main Steam |
| PMT | Manatee |
| ND | Neuratal Disconnect |
| Pmp | Pump |
| PSL | St Lucie |
| PSR | Sanford |
| PT | Potential transformer |
| PWR | Power |
| R | Repair |
| R0 | Row 0 blades on steam turbine |
| R1 | Row 1 blades on steam turbine |
| RCP | Reactor Coolant Pump |
| RFC | Ready For Control |
| RFO | Refueling Outage |
| RH | Reheat |
| RPS | Reactor Protection System |
| RSD | Reserve Shutdown |
| RSV | Reheat Stop Valve |
| RSV1 | Reheat Stop Valve Number 1 |
| RV | Release Valve |
| S/U | Startup |
| SGFP | Steam Generator Feed Pump |

GPIF Units
Actual Performance Data (ACRONYMS) for 2013

| ACRONYMS | DESCRIPTION |
|------------|--|
| SGG | Main Steam - High Pressure |
| SGJ-ACV-10 | System Designator Air Control Valve |
| SH | Super heat |
| SL1-23 | St Lucie Unit 1 cycle 23 refueling outage |
| SL2-19 | St Lucie Unit 2 cycle 19 refueling outage |
| SNO | Short Notice Outage |
| SNOW | Short Notice Outage Work |
| SRV | Speed Ratio Valve |
| STARS | Strategic Anti Rotation Stall Surge testing |
| ST | Steam Turbine |
| ST1 | Steam Turbine Number 1 |
| ST2 | Steam Turbine Number 2 |
| STG or SG | Steam Generator |
| STM 1 | Steam Turbine Number 1 |
| STM 2 | Steam Turbine Number 2 |
| T-Ave | Temperature Average |
| TC or T/Cs | Thermal/Couples |
| TCW HX | Turbine Cooling Water Heat Exchanger |
| TMOF | Task MOF |
| U1 | Unit 1 |
| U2 | Unit 2 |
| UEL | Unplanned Energy Loss |
| ULPM1 | Ultra Lean Pre-Mix Valve # 1 |
| VCMI | Communication interface board for Mark 6 ovation system |
| Vi | Roman Numeral 6 |
| VLV | Valve |
| Wobbee | Water warms up gas fired units to 35 MWs. After that, permissive Wobbee takes it to base load. |
| WO | Work |
| WW | Water wash |
| XFMR | Transformer |