

Robert L. McGee, Jr. One Energy Place
Regulatory & Pricing Manager Pensacola, Florida 32520-0780

Tel 850.444.6530
Fax 850.444.6026
RLMCGEE@southernco.com

April 2, 2014



Ms. Carlotta Stauffer, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0850

Dear Ms. Stauffer:

RE: Docket No. 130202-EI

Attached for electronic filing in the above referenced docket is:

1. Petition of Gulf Power Company.
2. Prepared direct testimony and exhibit of John N. Floyd.

Sincerely,

A handwritten signature in blue ink that reads "Robert L. McGee, Jr." The signature is written in a cursive, flowing style.

Robert L. McGee, Jr.
Regulatory and Pricing Manager

md

Attachments

cc: Florida Public Service Commission
Lee Eng Tan, Sr Attorney, Office of the General Counsel (5 copies)
Beggs and Lane
Jeffrey A. Stone, Esq.

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Commission review of numeric
conservation goals (Gulf Power Company).

Docket No.: 130202-EI
Filed: April 2, 2014

**PETITION FOR APPROVAL OF
NUMERIC CONSERVATION GOALS BY GULF POWER COMPANY**

Gulf Power Company ("Gulf Power," "Gulf," or "the Company"), by and through its undersigned attorneys, files this petition with proposed numeric conservation goals and requests that the Florida Public Service Commission ("Commission") accept, approve and adopt Gulf Power's proposed numeric conservation goals as the numeric goals established by the Commission for Gulf Power Company pursuant to section 366.82, Florida Statutes, and Rules 25-17.001 and 25-17.0021, Florida Administrative Code. In support of this petition, the Company states:

1. Gulf Power is a public utility subject to the jurisdiction of the Commission pursuant to Chapter 366 of the Florida Statutes. Gulf Power's General Offices are located at One Energy Place, Pensacola, Florida 32520.

2. Copies of all notices and pleadings with respect to this petition should be furnished to:

Robert L. McGee, Jr.
Regulatory & Pricing Manager
Gulf Power Company
One Energy Place
Pensacola, Florida
32520-0780
(850) 444-6530
(850) 444-6026(facsimile)

Jeffery A. Stone, Esq.
Russell A. Badders, Esq.
Steven R. Griffin, Esq.
Beggs & Lane
501 Commendencia Street
Pensacola, Florida 32502
(850) 432-2451
(850) 469-3331(facsimile)

3. The agency affected by this petition is:

Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

4. Gulf Power is subject to section 366.82, Florida Statutes, part of the Florida Energy Efficiency and Conservation Act ("FEECA"), which requires the Commission to adopt appropriate goals to increase the efficiency of energy consumption, increase the development of demand side renewable energy systems, reduce and control the growth rates of electric consumption and weather sensitive peak demand, and encourage the development of demand side renewable energy resources.

5. Docket No. 130202-EI is one of seven that has been opened by the Commission to establish numeric conservation goals for each of the seven Florida FEECA utilities pursuant to section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code. As a result of Gulf's evaluations, the Company proposes the following numeric conservation goals which Gulf has determined to be reasonably achievable in the residential, commercial and industrial classes within Gulf Power's service area over a ten-year period.

6. Gulf Power Company's proposed conservation goals for years 2015 through 2024 are set forth below:

Residential

<u>Year</u>	<u>Summer Peak MW Reduction (at Generator)</u>	<u>Winter Peak MW Reduction (at Generator)</u>	<u>Annual GWh Reduction (at Generator)</u>
2015	2.3	1.3	2.3
2016	3.2	1.8	3.2
2017	4.1	2.3	4.2
2018	5.0	2.9	5.1
2019	5.9	3.4	6.0
2020	6.7	3.8	6.8
2021	7.5	4.3	7.6
2022	8.1	4.6	8.3
2023	8.8	5.0	8.9
2024	9.3	5.3	9.5

Commercial/Industrial

<u>Year</u>	<u>Summer Peak MW Reduction (at Generator)</u>	<u>Winter Peak MW Reduction (at Generator)</u>	<u>Annual GWh Reduction (at Generator)</u>
2015	.3	.1	.8
2016	.4	.1	1.2
2017	.5	.1	1.5
2018	.6	.2	1.8
2019	.7	.2	2.2
2020	.8	.2	2.5
2021	.9	.2	2.7
2022	.9	.3	3.0
2023	1.0	.3	3.2
2024	1.1	.3	3.4

7. The testimony of John N. Floyd, filed contemporaneously with this petition, along with the exhibit and schedules attached thereto, sets forth the Company's ten year projections of the total cost-effective winter and summer peak MW demand reduction and the annual GWh savings which are reasonably achievable through implementation of demand side measures in

Gulf Power's service area for the residential, commercial and industrial classes.


8. As demonstrated by the testimony of witness Floyd, the Company's proposed numeric conservation goals for the period 2015 through 2024 are reasonable and are consistent with the requirements of section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code.

9. Gulf knows of no material facts in dispute regarding the relief requested herein. There is no agency decision, so Gulf cannot state when or how it received notice of the agency decision.

10. Gulf is entitled to relief pursuant to Sections 366.81 and 366.82, Florida Statutes, and Rule 25-17.0021.

WHEREFORE, Gulf Power Company requests that the Florida Public Service Commission enter an order approving and establishing the Company's proposed numeric conservation goals for the period 2015 through 2024 pursuant to section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code, and grant such other relief as is just and reasonable under the facts and law as determined by the Commission.

Respectfully submitted this 2nd day of April, 2014.



JEFFREY A. STONE

Florida Bar No. 325953

RUSSELL A. BADDERS

Florida Bar No. 007455

STEVEN R. GRIFFIN

Florida Bar No. 0627569

Beggs & Lane

P. O. Box 12950

Pensacola, FL 32591

(850) 432-2451

Attorneys for Gulf Power Company

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

**COMMISSION REVIEW OF NUMERIC
CONSERVATION GOALS**

Docket No. 130202-EI

**PREPARED DIRECT TESTIMONY AND
EXHIBIT OF
JOHN N. FLOYD**

FILED APRIL 2, 2014



1 GULF POWER COMPANY

2 Before the Florida Public Service Commission
3 Prepared Direct Testimony and Exhibit of
4 John N. Floyd
5 Docket No. 130202-EI
6 Date of Filing: April 2, 2014

7 Q. Please state your name, business address, employer and position.

8 A. My name is John N. Floyd and my business address is One Energy Place,
9 Pensacola, Florida 32520. I am employed by Gulf Power Company (Gulf
10 or the Company) as the Energy Sales and Efficiency Manager.

11 Q. Mr. Floyd, please describe your educational background and business
12 experience.

13 A. I received a Bachelor Degree in Electrical Engineering from Auburn
14 University in 1985. After serving four years in the U.S. Air Force, I began
15 my career in the electric utility industry at Gulf Power in 1990 and have
16 held various positions with the Company in Power Generation, Metering,
17 Power Delivery and Marketing. In my present position, I am responsible
18 for the development and implementation of Gulf's customer program
19 offerings including the programs included in the Company's Demand-side
20 Management (DSM) Plan.

21
22 Q. Have you previously testified before this Commission?

23 A. Yes.
24
25

1 Q. Mr. Floyd, what is the purpose of your testimony?

2 A. The purpose of my testimony is to propose seasonal peak demand and
3 annual energy conservation goals for Gulf Power for the period
4 2015 – 2024 as required by the Florida Energy Efficiency and
5 Conservation Act (FEECA).

6

7 Q. Please describe how your testimony is organized.

8 A. My testimony is organized as follows:

9 Section 1: Proposed Goals and Accomplishments

10 Section 2: Process to Develop Goals

11 Section 3: Statutory Adherence

12 Section 4: Sensitivities

13 Section 5: Renewable Pilots

14 Section 6: Conclusions

15

16 Q. Have you prepared an exhibit in support of your testimony?

17 A. Yes, I have. This exhibit was prepared under my direction and control,
18 and the information contained therein is true and correct to the best of my
19 knowledge.

20 Counsel: We ask that Mr. Floyd's exhibit consisting of 18 schedules be
21 marked for identification as:

22 Exhibit No. ____ (JNF-1)

23

24

25

1 **Section 1: Proposed Goals and Accomplishments**

2
3 Q. What residential and commercial/industrial goals are appropriate and
4 reasonably achievable for Gulf Power Company for seasonal peak
5 demand and energy conservation for the period 2015 through 2024?

6 A. The Company's proposed seasonal peak demand and annual energy
7 conservation goals for the period 2015 through 2024 are contained in
8 Schedule 1 of my exhibit (JNF-1). In total, Gulf is proposing a summer
9 peak demand goal of 68 MW, winter peak demand goal of 37 MW, and
10 cumulative annual energy conservation goal of 84 GWh. These goals are
11 based upon costs derived from Gulf's generation, transmission, and
12 distribution planning processes and represent the total cost-effective
13 winter and summer peak MW demand reductions and the annual GWh
14 savings at the generator which are reasonably achievable through
15 implementation of demand-side programs in Gulf Power's service area for
16 the residential and commercial/industrial customer classes. The basis for
17 the goals is the MW and GWh associated with projected adoption of
18 measures that passed both the Rate Impact Measure (RIM) and the
19 Participant's Test (PT).

20
21 Q. How do Gulf's recommended goals compare to current goals?

22 A. The cumulative annual energy conservation goals being proposed for the
23 period 2015 through 2024 are significantly lower than the goals currently
24 approved in Commission Order No. PSC-09-0855-FOF-EG. A
25 comparison of the goals can be found in Schedule 2 of my exhibit.

1 Q. Please explain why there is such a significant decrease in the
2 recommended goal level compared to Gulf's current goal.

3 A. There are several factors that contribute to these proposed goals being
4 significantly lower than current goals. First, these proposed goals are
5 based on Gulf's 2013 generation planning process in which the next
6 planned generating unit addition is in 2023 compared to a 2014 projected
7 unit addition that was used for the 2009 goal setting. These proposed
8 goals are also based on the achievable potential of measures that pass
9 the RIM cost-effectiveness criterion which ensures no cross-subsidy
10 occurs between participating and non-participating customers. The
11 currently approved goals are based on the Total Resource Cost (TRC)
12 cost-effectiveness criterion which does not provide any protections against
13 cross-subsidies or upward rate pressure. Finally, almost half of the current
14 goals are not based on any cost-effectiveness criteria, but instead are
15 based on the technical potential for certain residential measures that were
16 initially excluded from Gulf's Technical Potential Study due to the potential
17 for high free-ridership.

18

19 Q. How is it that nearly one-half of Gulf's current goals derive from measures
20 that were not based on any cost-effectiveness criteria?

21 A. In Order No. PSC-09-0855-FOF-EG, the Commission assigned Gulf
22 approximately 200 GWh of energy goals beyond what was evaluated as
23 cost-effective under the TRC test. This additional energy goal was based
24 on the technical potential of certain measures that had been previously
25 screened out due to the potential for high free-ridership. Gulf subsequently

1 petitioned for reconsideration of this decision on the ground that this
2 additional energy goal did not represent what was reasonably achievable,
3 but instead was only technically feasible without regard to whether it was
4 cost-effective to achieve. The Commission ultimately denied Gulf's motion
5 for reconsideration and affirmed the rulings embodied in the 2009 goals
6 order. See Order No. PSC-10-0198-FOF-EG.

7
8 Q. Aside from seeking reconsideration of the 2009 goals order, did Gulf
9 engage in any other efforts to mitigate the rate impacts of the 2009 goals
10 to its customers?

11 A. Yes. In Docket No. 100154-EG Gulf sought approval of a DSM Plan
12 which was designed to achieve the goals established in the 2009 goals
13 order. Included within Gulf's DSM Plan filing was a "Rate Impact
14 Mitigation" proposal wherein Gulf identified a small group of programs and
15 measures that could be deferred. Deferral of these programs and
16 measures would have reduced the long term rate impact of the Plan by
17 some 50% while still achieving 350 GWh over ten years –almost seven
18 times larger than Gulf's previous goal.

19
20 Q. Did the Commission approve Gulf's Rate Impact Mitigation proposal?

21 A. No. While the Commission acknowledged that Gulf's approach in
22 developing its Rate Impact Mitigation proposal was appropriate, the
23 Commission ultimately declined to adopt the proposal on the grounds that
24 the proposal would not enable Gulf to meet its newly established goals.
25 See Order No. PSC-11-0114-PAA-EG.

1 Q. Did the Commission have occasion to address rate impacts associated
2 with other FEECA utilities' DSM Plans?

3 A. It did. Shortly after approving Gulf's DSM Plan, the Commission entered
4 proposed agency action orders modifying and approving demand side
5 management plans for Florida Power & Light Company and Progress
6 Energy Florida, Inc. See Order Nos. PSC-11-0346-PAA-EG and PSC-11-
7 0347-PAA-EG. In both cases the Commission determined that the plans
8 submitted by the utilities would effect undue rate impacts on customers.
9 Consequently, the Commission modified the proposed DSM plans to only
10 include programs the Commission had previously approved for the two
11 utilities as a result of the 2004 goal setting proceeding, finding that those
12 programs were cost-effective and would accomplish the intent of FEECA.
13 Those programs were determined to be cost-effective using the PT and
14 the RIM test.

15
16 Q. Please describe Gulf's progress toward achieving the goals set forth in
17 Order No. PSC-09-0855-FOF-EG for the period 2010-2019.

18 A. Schedule 3 of my exhibit provides a summary of the Company's progress
19 toward goal achievement. Notwithstanding the concerns expressed
20 above, Gulf has endeavored to achieve the goals set in 2009. On a
21 cumulative basis, Gulf is ahead of the goals set in Order No. PSC-09-
22 0855-FOF-EG and has achieved the annual goals since 2012.

23
24
25

1 Q. What impact has achievement of these goals had on the cost to Gulf's
2 customers?

3 A. The cost of energy efficiency programs associated with these higher goals
4 has more than doubled since 2010. These additional costs are borne by
5 all of Gulf's customers each year through increased Energy Conservation
6 Cost Recovery (ECCR) charges. Although there has been substantial
7 energy savings associated with these additional costs, these program
8 expenses are creating cross-subsidies between non-participating and
9 participating customers because almost all of the programs required to
10 achieve these goals fail the RIM test. This results in upward rate pressure
11 for all customers over time.

12
13 Q. Please elaborate on what you mean by cross-subsidies and their effect on
14 rate pressure.

15 A. Energy efficiency programs offered through the Company's approved
16 DSM Plan are a unique aspect of the Company's business in that the
17 costs to offer these programs, including incentives paid to customers, are
18 borne by all of the Company's customers, not just the customers who are
19 voluntarily participating in the program. The Company depends on the
20 energy and demand savings benefits, in the form of avoided cost savings,
21 from customers' voluntary participation in the efficiency programs to offset
22 the cost impacts of these programs. When these energy and demand
23 saving benefits are greater than the cost impacts borne by all customers,
24 then a non-participating customer is not subsidizing any costs and is, in
25 fact, benefited by lower utility cost which causes downward rate pressure

1 over time. If the demand and energy savings of participating customers do
2 not completely offset the cost impacts, including incentives paid to
3 customers, the deficiency is re-distributed to all customers in the form of a
4 cross-subsidy resulting in upward rate pressure over time. This is the
5 essence of the RIM cost-effectiveness test and why it should be
6 considered in setting energy efficiency and conservation goals.

7
8 Q. What actions can the Commission take in this proceeding to ensure that
9 Gulf's goals for the period 2015-2024 do not impose such high cost on
10 Gulf's customers in the future?

11 A. The Commission can and should set goals based on the amount of cost-
12 effective achievable potential utilizing the RIM test. This will ensure the
13 benefits of energy and demand reductions are greater than the cost
14 impacts borne by both participating and non-participating customers such
15 that both groups of customers are better off as a result.

16
17 Q. Please describe how Gulf has historically endeavored to meet the intent of
18 the FEECA statute.

19 A. Gulf has a long history of leadership and innovation in the area of energy
20 efficiency. Beginning in 1975, before the FEECA statute existed, Gulf
21 introduced customers to the value of energy efficient construction with the
22 GoodCents Home program. This program, now called EarthCents home,
23 has long been the standard for energy efficient construction in Northwest
24 Florida. An example of Gulf's innovation is the Company's *EnergySelect*
25 program. Originally offered in 1995, Gulf introduced customers to the

1 concept of home energy management combined with variable pricing,
2 including critical peak pricing (CPP) with its Energy*Select* program. When
3 first introduced, Energy*Select* was not only a new program for Gulf, but
4 also was the first CPP program offered in the nation.

5
6 In addition to equipment-based programs, Gulf has placed great emphasis
7 over the years on customer education through our audit programs and
8 outreach activities. As Energy Experts, Gulf's employees provide valuable
9 advice and recommendations to customers regarding energy use and
10 equipment decisions. Gulf's educational efforts extend into classrooms
11 and community settings, including low-income communities, where energy
12 efficiency information helps shape customers of the future and aids
13 customers who may not have access to sound and reliable energy advice.

14
15
16 **Section 2: Process to Develop Goals**

17
18 Q. Please describe the process used to develop Gulf's recommended
19 seasonal peak demand and annual energy conservation goals.

20 A. Gulf developed proposed goals based on the progressive process of
21 1) updating the full technical potential for energy efficiency savings;
22 2) determining the subset of that technical potential that is cost-effective
23 under both the RIM and TRC cost-effectiveness tests as compared to the
24 cost of Gulf's next planned generating unit addition from the Company's
25 2013 Ten Year Site Plan; and 3) determining the reasonably achievable

1 market potential of both the RIM-based and the TRC-based evaluations
2 considering the circumstances of our service area, existing programmatic
3 activity, and historical experience.

4
5 Q. Please describe what is meant by technical potential for energy and
6 demand savings and how it is used in the goal setting process.

7 A. Technical potential represents the amount of energy and demand savings
8 that is technically feasible without regard to cost, customer acceptance,
9 cost-effectiveness or other real-world constraints. Technical potential
10 begins with a comprehensive list of energy efficiency measures that are
11 technically feasible to implement. The energy and demand savings of
12 each measure is multiplied by the applicable customer base to calculate
13 what is technically possible without any regard to whether it is in the best
14 interest of the customer or if a customer would even voluntarily adopt the
15 measure. In this sense, technical potential is somewhat of a theoretical
16 construct that just provides a starting point for the balance of the process.
17 It certainly does not represent cost-effective potential that could be
18 reasonably achieved.

19
20 Q. How did Gulf determine the appropriate technical potential for this docket?

21 A. The Company and the other FEECA utilities worked together, with input
22 from the Southern Alliance for Clean Energy (SACE), to consistently
23 update the technical potential results from a study conducted by Itron that
24 was used in the 2009 goals proceeding. This study included a
25 comprehensive list of energy efficiency measures that are commercially

1 available for implementation. The process used for updating Gulf's
2 technical potential consisted of three steps: 1) adjust, as necessary,
3 existing measures from the 2009 study, 2) add new measures and
4 3) adjust for customer growth and DSM achievements. This process is
5 summarized in a diagram found in Schedule 4 of my exhibit.

6

7 Q. Please describe each step in more detail.

8 A. The first step involved identifying measures made obsolete by new
9 building codes and standards. These "baseline" measures represent the
10 starting point from which to calculate the incremental energy and demand
11 savings associated with higher efficiency measures. Each baseline
12 measure was reviewed to determine if it was still relevant based on
13 updates to codes and standards. If it was determined to be obsolete, it
14 was removed and a new baseline was set based on current codes or
15 standards. At the end of this step, 5 measures were removed due to their
16 obsolescence.

17

18 The next step involved identifying new commercially-viable measures that
19 were not included in the previous study. The energy and demand savings
20 impacts of these measures, along with the costs of the measures, were
21 determined using a combination of experience from the utilities and third
22 party information. This information was added to the existing technical
23 potential resulting in 7 residential, 15 commercial and 5 industrial
24 measures being added to the technical potential. After the first two steps,
25 the comprehensive measure list included 285 total unique measures. Of

1 this total, 62 were residential energy efficiency measures, 91 commercial
2 efficiency measures and 122 industrial efficiency measures. Demand
3 Response and demand-side renewables comprised 10 measures included
4 in the technical potential measure list. A comprehensive list of measures
5 including those that were removed and added can be found in Schedule 5
6 of my exhibit.

7
8 After adjustments were made for obsolete and new measures, the
9 technical potential was adjusted for growth in Gulf's customer base as well
10 as DSM achievements since the last technical potential assessment was
11 completed.

12
13 Q. What were the results of Gulf's updated technical potential?

14 A. After the updates were made, the energy efficiency demand and energy
15 values represented by Gulf's technical potential are 720 MW of summer
16 demand, 448 MW of winter demand and 3,253 GWh of energy. The
17 demand response values include 285 MW of summer demand and 247
18 MW of winter demand. Finally, the solar photovoltaic technical potential
19 resulted in 1,481 MW of summer demand, 240 MW of winter demand and
20 4,017 GWh of energy. All of these results are summarized in Schedule 6
21 of my exhibit.

22
23 Q. How do these technical potential results compare to Gulf's results in the
24 last goals proceeding?

25 A. The updated technical potential results reflect slightly lower overall

1 potential based primarily on adjustments due to codes and standard
2 changes. A summary comparing the technical potential from the last
3 proceeding to Gulf's updated technical potential can be found in Schedule
4 7 of my exhibit.

5
6 Q. What was the next step in developing Gulf's proposed DSM goals?

7 A. The next step in the process was to determine the amount of technical
8 potential that is cost-effective. This amount is called economic potential.

9
10 Q. Please describe what is meant by economic potential.

11 A. Economic potential is the amount of technical potential determined to be
12 cost-effective by applying Commission approved cost-effectiveness tests
13 to the measures in the technical potential. These are the RIM, TRC, and
14 PT cost-effectiveness tests. This Commission has requested two sets of
15 economic potential, one based on a set of measures that pass the RIM
16 and the PT test and another based on a set of measures that pass the
17 TRC and the PT test. These two evaluations are not mutually exclusive. In
18 practice, most of the measures included in the RIM & PT evaluation also
19 pass the TRC test.

20
21 Q. Please describe the three cost-effectiveness tests in more detail.

22 A. The PT, or Participant's Test, as the name implies, measures cost-
23 effectiveness from the perspective of the participating customer. This test
24 considers bill savings and incentives as benefits and out-of-pocket
25

1 expenses as costs. It is important that any measure included in any final
2 DSM Plan be cost-effective to the participant.

3
4 The RIM, or Rate Impact Measure, test evaluates the cost-effectiveness of
5 a measure from a non-participant's perspective. In this way, it measures
6 whether cross-subsidy occurs between non-participating and participating
7 customers that ultimately results in upward rate pressure. The RIM test
8 considers avoided capacity and fuel costs as a benefit compared to costs
9 of program implementation including customer incentives and utility
10 revenue decreases. When benefits exceed costs in the RIM test,
11 implementation of the efficiency measure or program will not result in
12 cross-subsidy and will cause downward pressure on utility rates. This is
13 why the test is sometimes referred to as the "no-losers test." Use of the
14 RIM test in goal setting is essential to ensure that cross-subsidy and
15 upward rate pressure do not occur.

16
17 The TRC, or Total Resource Cost, test looks at cost-effectiveness of an
18 efficiency measure from the joint perspective of the utility and customer
19 base as a whole. In this way, TRC only measures whether total costs are
20 increased or decreased. The TRC test considers the same benefits as the
21 RIM test while only including program implementation (not including
22 customer incentives) and total equipment expenses as costs. Importantly,
23 the TRC test does not provide any measure of rate pressure or cross-
24 subsidy. For this reason, the TRC test should never be used without
25 simultaneous consideration of the RIM test results to ensure non-

1 participating customers are not subsidizing customers who are voluntarily
2 participating in an efficiency program.

3

4 Q. Please describe the process Gulf used to determine the economic
5 potential.

6 A. Gulf evaluated the cost-effectiveness of all measures in the updated
7 technical potential utilizing the Company's most recent generation,
8 transmission, and distribution planning assumptions. These "base case"
9 assumptions include projections of fuel costs and avoided generation
10 costs on which the Company's 2013 Ten Year Site Plan was produced.
11 Each measure's demand and energy savings characteristics and costs
12 were used along with the avoided cost benefits to calculate the cost-
13 effectiveness of the measure according to the RIM, TRC, and PT
14 formulas. If the result of the cost-effectiveness test was positive, or
15 greater than 1.0, then that measure was deemed to be cost-effective at
16 this phase of the process and the measure's technical potential for energy
17 and demand savings was included in the economic potential. Certain
18 measures were determined to be cost-effective under one or more of the
19 cost-effectiveness tests, but not all. A summary of the Economic Potential
20 for the RIM & PT criteria and TRC & PT criteria is provided in Schedule 8
21 of my Exhibit. A complete list of measures for the Economic Potential in
22 both evaluations is included in Schedule 9 of my exhibit.

23

24

25

1 Q. What avoided generating unit did Gulf use in the base case analysis?

2 A. Consistent with Gulf's April 2013 Ten Year Site Plan filing, a 750 MW
3 combined cycle unit with an in-service date of 2023 was used for the cost-
4 effectiveness evaluations.

5
6 Q. Please describe the other assumptions used in the base case analysis.

7 A. The base case analysis for evaluating the cost-effectiveness of measures
8 in this study includes projections of fuel costs, load and energy sales, and
9 generation costs over the planning period. The fuel cost projections used
10 for planning purposes are developed using a collaborative process
11 between Southern Company's Planning Coordination Team and the
12 modeling vendor, CRA International. The load and energy forecast is
13 developed based on a number of inputs including projections of economic
14 growth, customer growth, and appliance codes. Generation costs are
15 based on current projections of capital, operating, and environmental
16 compliance expenses associated with the next planned generation unit
17 needed to satisfy the load requirements. These cost inputs are used to
18 develop the avoided cost values used in evaluation of the measures
19 included in the Technical Potential Study.

20
21 Q. What was the final step in developing Gulf's proposed DSM goals?

22 A. The final step in the process was to determine the amount of the
23 economic potential that is reasonably achievable in the marketplace over
24 the ten year planning horizon. This amount is called achievable potential
25 and serves as the proposed goals.

1 Q. How did Gulf determine the achievable potential for each set of measures
2 included in the economic potential?

3 A. For each measure that was deemed cost-effective in either the RIM & PT
4 or TRC & PT portfolios, customer adoption projections were developed
5 based on the level of economic benefit provided to the customer. In order
6 to maximize the projected adoption of these cost-effective measures,
7 incentives were applied to increase the economic benefit to the customer.
8 For the RIM & PT portfolio, the incentive was set at the amount to create a
9 two-year payback for the customer or the maximum amount that would
10 keep the measure RIM passing. For the TRC & PT portfolio, the incentive
11 was set at an amount to create a two-year payback to the customer. Gulf
12 considered previous adoption projections from the 2009 Achievable
13 Potential Study and historical program experience to aid in projecting
14 customer adoption at these incentive levels.

15

16 Q. What is free-ridership and how did Gulf take into account the effects of
17 free-ridership in its analysis?

18 A. In this context, free-ridership is the adoption of an energy efficiency
19 measure that would have occurred absent any utility program. As required
20 by Commission rule, the goals set for energy and demand reductions must
21 account for the effects of free-ridership. In the base case, measures that
22 had a customer payback of less than two years without any utility incentive
23 were considered to already present the customer with a reasonable
24 economic proposition and therefore did not require additional incentives
25 through a utility program. The selection of a two year payback criterion is

1 consistent with assumptions used in the Energy Information
2 Administration's Load and Demand Side Management (LDSM) submodule
3 of the Electricity Market Module of the National Energy Modeling System.
4 The LDSM model documentation characterizes the use of a two year
5 payback level as being "based on general utility practice."

6
7 If included as part of a utility's goal, the expense associated with
8 promotion of these measures would be an unnecessary cost burden on all
9 utility customers since these measures would likely be adopted even
10 without a utility program.

11
12 Q. What is the achievable potential during the period 2015-2024 for both the
13 RIM & PT and TRC & PT evaluations?

14 A. The achievable potential is 84 GWh for the RIM & PT evaluation. For the
15 TRC & PT evaluation, the achievable potential is 268 GWh. A summary of
16 the achievable potential results for both evaluations can be found in
17 Schedule 10 of my exhibit. A full list of measures included in the
18 achievable potential for each evaluation is included in Schedule 11 of my
19 Exhibit. The achievable potential for demand and energy reductions is
20 based on projecting customer adoption of measures in the updated
21 technical potential study found to be cost-effective by each of the RIM &
22 PT and TRC & PT evaluations; that is, customer adoption of measures
23 determined to have economic potential.

24
25

1 Q. How were renewable technologies identified and evaluated?

2 A. Renewable technologies were handled in two ways for the technical and
3 achievable potential studies. First, solar thermal water heating and
4 photovoltaic (PV) pool pumps were included in the energy efficiency study
5 since they both directly replace specific end-use loads and can be
6 modeled like other efficiency measures. Neither of these measures is
7 cost-effective under the TRC or RIM test and, therefore, no achievable
8 potential for these measures is included in Gulf's proposed goals.

9
10 The technical potential for rooftop PV initially assessed by Itron in 2009
11 was adjusted to reflect known new installations and customer growth since
12 that time. Cost-effectiveness tests were applied to rooftop PV based on
13 the actual system installed costs participating customers have
14 experienced during the course of the renewable pilot programs. Rooftop
15 PV does not pass either of the Commission standards for
16 cost-effectiveness and, therefore, no achievable potential for this measure
17 is included in Gulf's proposed goals.

18
19 Q. How was demand response considered in the development of Gulf's
20 proposed goals?

21 A. Like the process for PV, the technical potential for demand response was
22 based on an update of Itron's projection in 2009. For the balance of the
23 process, however, Gulf utilized actual program experience with the
24 company's *EnergySelect* program to ultimately project the achievable
25 potential. This program, unlike traditional demand response programs,

1 also provides energy savings which are reflected in the Company's
2 proposed goals.

3

4 Q. Which evaluation of achievable potential should be used to set Gulf's
5 energy and demand reduction goals for the period 2015-2024?

6 A. The evaluation of achievable potential based on measures that are cost-
7 effective under both the RIM and PT tests should be used to set Gulf's
8 energy and demand reduction goals. This combination of tests ensures
9 first that a participating customer will benefit from adoption of the
10 efficiency measure and that benefits of efficiency savings outweigh the
11 costs in a way that causes downward pressure on electric rates. This
12 evaluation can be thought of as a subset of the TRC evaluation that not
13 only ensures total costs are reduced, but also ensures that participating
14 customers are not subsidized by non-participants. These two principles
15 are critical in an energy efficiency policy that also recognizes the
16 importance of electricity rates for the economic development of the utility
17 area.

18

19 Q. Why is consideration of economic development appropriate in energy
20 efficiency goal setting?

21 A. Economic development is an important aspect of the utility business as
22 increased sales provide contributions towards the fixed costs of the utility
23 system. This, in turn, benefits all customers. This Commission has been a
24 strong proponent of utility-sponsored economic development initiatives for
25 these very reasons and has approved such initiatives in a variety of

1 regulatory settings. In fact, the Commission recently approved three new
2 economic development rate riders in connection with the settlement of
3 Gulf's latest base rate case. See Order No.PSC-13-0670-S-EI. The
4 importance of considering economic development in establishing energy
5 efficiency goals is highlighted by the Commission's own rules.

6
7 Rule 25-17.001(7) clearly states that implementation of FEECA should not
8 restrict growth necessary to support economic development and, instead,
9 should enhance economic growth through lowering energy costs from
10 what they would otherwise be absent cost-effective energy efficiency
11 goals.

12
13 The primary means of achieving this objective through the goal setting
14 process is by use of the RIM test in setting energy and demand reduction
15 goals. The RIM test ensures that all customers benefit through lower
16 electricity rates over time. This is the only cost-effectiveness test that can
17 achieve this objective.

18
19 Q. What is the annual bill impact for an average residential customer using
20 1,200 kWh per month?

21 A. The projected annual bill impacts for each of the achievable potential
22 evaluations are provided in Schedule 12 of my exhibit. These bill impacts
23 reflect projected ECCR expenses associated with implementation of each
24 evaluated achievable potential of energy and demand savings. In 2015,
25 the company's proposed RIM portfolio is projected to impact a residential

1 customer's annual bill by \$8.71, a significant decrease from the bill impact
2 of the currently approved goals. This increases to \$12.60 in 2024
3 assuming monthly usage of 1,200 kWh. Comparatively, the TRC portfolio
4 is projected to impact a residential customer's annual bill by \$23.34 in
5 2015, increasing to \$66.82 by 2024, again assuming monthly usage of
6 1,200 kWh. These projected expenses are modeled in a similar way as
7 the achievable potential estimates themselves and are not based on a set
8 of proposed DSM programs designed to meet the demand and energy
9 values determined by the achievable potential. More specifically, the cost
10 estimates reflected in the bill impacts are based on multiplying the
11 projected adoption by the maximum incentive determined for each cost-
12 effective measure and are not intended to represent the actual costs
13 associated with programs that will ultimately be developed to achieve the
14 goals.

15
16
17 **Section 3: Statutory Adherence**

18
19 Q. Has Gulf Power provided an adequate assessment of the full technical
20 potential of all available demand-side conservation and efficiency
21 measures, including demand-side renewable energy systems?

22 A. Yes. Through a mutually agreed-upon process for updating the Itron
23 Technical Potential Study, an adequate assessment of the full technical
24 potential of all available demand-side conservation and energy efficiency
25 measures, including demand-side renewables has been completed. This

1 assessment included the evaluation of 285 individual end-use energy
2 efficiency, demand response and solar photovoltaic measures.

3

4 Q. Section 366.82(3), Florida Statutes, requires the Commission to evaluate
5 the full technical potential of supply-side conservation and efficiency
6 measures. Does Gulf Power's Technical Potential Study evaluate supply-
7 side conservation and efficiency measures and, if not, why?

8 A. Gulf Power has not conducted an assessment of supply-side conservation
9 and efficiency opportunities in the same manner as the demand-side
10 opportunities have been evaluated. Gulf does recognize that these
11 opportunities may exist and, in fact, considers energy efficiency in
12 selecting supply-side projects in all generation, transmission, and
13 distribution functions consistent with the requirements of Rule 25-
14 17.001(5). However, the Commission has not developed guidelines for
15 such an evaluation that would provide a methodical approach to
16 identifying, quantifying, and proposing goals for supply-side conservation
17 and efficiency measures. For this reason, Gulf Power does not believe
18 that consideration of supply-side conservation and efficiency measures is
19 appropriate in this proceeding.

20

21 Q. Has Gulf Power provided an adequate assessment of the achievable
22 potential of all available demand-side conservation and efficiency
23 measures, including demand-side renewable energy systems?

24 A. Yes. Beginning with the updated technical potential results, Gulf
25 performed cost-effectiveness screening in accordance with Commission

1 rules and determined energy efficiency measures that are cost-effective
2 for goal setting purposes. Gulf projected the reasonably achievable
3 potential for energy and demand savings of these cost-effective
4 measures.

5
6 All demand-side renewable energy systems were evaluated using the
7 same cost-effectiveness standards as other energy efficiency measures.
8 No renewable measures are cost-effective under these standards and,
9 therefore, none are reflected in the achievable potential results. In past
10 FEECA proceedings, the Commission determined that it was appropriate
11 to set goals equal to zero in cases where no DSM measures were found
12 to be cost-effective. See Order Nos. PSC-00-0588-FOF-EG; PSC-00-
13 0587-FOF-EG; PSC-04-0768-PAA-EG; PSC-04-0767-PAA-EG. Given
14 that no renewable measures passed the Commission's approved cost-
15 effectiveness criteria, setting renewable goals at a level above zero in this
16 proceeding would not be appropriate. A summary of the achievable
17 potential results can be found in Schedule 10 of my exhibit.

18

19 Q. What cost-effectiveness test or tests should the Commission use to set
20 DSM goals for Gulf Power?

21 A. The Commission should use the combination RIM and PT cost-
22 effectiveness tests to set goals for Gulf Power. This combination of tests
23 provides an appropriate balance between participating and non-
24 participating customer benefits and ensures downward pressure on overall

25

1 electric rates while still supporting significant conservation activities over
2 the period 2015 through 2024.

3
4 Using the combination of RIM and PT cost-effectiveness tests to establish
5 goals for Gulf Power is consistent with the requirements of section
6 366.82(3), Florida Statutes, to consider impacts to participating customers
7 as well as non-participating customers, together comprising the general
8 body of customers.

9
10 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs and
11 benefits to customers participating in the measure?

12 A. Yes. The measures included in development of the goals reflect the costs
13 and benefits to the participating customers. This is done by performing
14 the participant cost test and ensuring that all measures contemplated for
15 inclusion in the goals pass this test.

16
17 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs and
18 benefits to the general body of ratepayers as a whole, including utility
19 incentives and participant contributions?

20 A. Yes. By passing the RIM test, Gulf's proposed goals reflect costs and
21 benefits that minimize overall rate impacts for the general body of
22 customers, whether or not they participate in one of the resulting
23 conservation programs. In addition, by only including measures that also
24 pass PT, these proposed goals adequately consider participant
25 contributions as a component of overall customer impact.

1 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs
2 imposed by state and federal regulations on the emission of greenhouse
3 gases?

4 A. Yes. Gulf is not incurring costs associated with existing state or federal
5 regulations on the emissions of greenhouse gases and, therefore, Gulf
6 has appropriately not included assumptions of costs of greenhouse gas
7 emissions in the development of proposed goals. Gulf's DSM evaluations
8 are consistent with assumptions used in determining the next generating
9 unit identified in the Company's 2013 Ten Year Site Plan.

10
11 Q. What is Gulf Power's position relative to the Commission establishing
12 incentives to promote both customer-owned and utility-owned energy
13 efficiency and demand-side renewable energy systems?

14 A. Prior to 2009, the Commission's preference for relying on the combination
15 of RIM and PT in the evaluation and approval of utility conservation
16 programs provided the necessary structure to ensure that the interests of
17 all stakeholders were balanced. In practice, these tests provided
18 incentives to customers through the payment of rebates, to the general
19 body of customers by preventing cross-subsidization between DSM
20 program participants and non-participants, and to the utility by ensuring
21 that incorporation of DSM in the resource planning process results in net
22 benefits that put downward pressure on rates. Therefore, reliance on the
23 RIM test in goal-setting obviates the need for utility incentives.

24
25

1 **Section 4: Sensitivities**

2
3 Q. Has Gulf completed any sensitivities to the evaluations performed in this
4 proceeding?

5 A. Yes. Gulf has performed additional cost-effectiveness screening on the
6 energy efficiency measures included in the technical potential for
7 alternative fuel cost projections and free-ridership periods. The purpose of
8 these additional evaluations was to determine how sensitive the economic
9 potential is to these factors. The first sensitivity was performed for two
10 additional fuel cost scenarios, "low fuel" and "high fuel." Since fuel cost
11 projections are an input in the cost-effectiveness evaluations, different fuel
12 cost assumptions can increase or decrease the avoided cost benefits of
13 each measure's savings, and, consequently, the cost-effectiveness
14 results. Each of these fuel cost projections represent a planning scenario
15 utilized by Gulf Power in the resource planning process. These high and
16 low fuel cost projections have the most impact on the RIM evaluations with
17 a range of -22% to +14% changes in the economic potential for energy
18 savings. The TRC evaluation is much less sensitive with a range of -2% to
19 +4% change in economic potential compared to the base case analysis. A
20 summary of these results can be found in Schedule 13 of my exhibit.

21
22 The second sensitivity was for shorter and longer free-ridership periods.
23 For this evaluation, Gulf calculated the economic potential utilizing a one-
24 year (shorter) and three-year (longer) payback period to determine how
25 sensitive the economic potential is to these free-ridership periods. This

1 evaluation was completed by removing measures from the economic
2 potential for which customer payback was less than one or three years
3 without any utility-provided incentive. The shorter and longer free-rider
4 period evaluations have the most impact on the TRC evaluation with a
5 range of -25% to +33% change in the economic potential. The RIM
6 evaluation is less sensitive with a range of -22% to +16% change in the
7 economic potential compared to the base case. A summary of these
8 results can be found in Schedule 14 of my exhibit.

9
10
11 **Section 5: Renewable Pilots**

12
13 Q. Please describe Gulf's current solar pilot programs.

14 A. Gulf's DSM Plan currently includes four solar pilot programs. These
15 programs include rooftop PV systems for residential and commercial
16 customers, PV systems for schools, solar thermal water heating (STWH)
17 systems for residential customers, and STWH systems for low-income
18 customers.

19
20 The Company's PV pilot program provides residential and commercial
21 customers an incentive for installation of a solar energy system on their
22 home or business. Customers installing qualifying systems receive \$2/watt
23 with a maximum per-customer incentive of \$10,000.

1 Gulf's Solar for Schools pilot program provides capital funding to
2 supplement deployment of PV systems up to 10 kW in qualifying public
3 education facilities served by Gulf Power. This program offers the added
4 benefit of providing resources to enable the data collected from the
5 installed systems to be used in the schools' energy curriculum.

6
7 Gulf's STWH pilot program provides an incentive to residential customers
8 to install a STWH system. Customers installing qualifying systems receive
9 up to a \$1,000 incentive.

10
11 The STWH for Low-Income pilot program facilitates the installation of
12 STWH systems in qualifying low-income housing. Through the program
13 the STWH systems are provided at no additional expense to the
14 customers. This program offers up to 15 system installations per year.

15
16 Q. How have these pilot programs performed since their approval in early
17 2011?

18 A. Annual participation for these programs can be found in Schedule 15 of
19 my exhibit. Participation in the PV pilot program has been fully subscribed
20 each year. Participation in the STWH rebate and low-income STWH pilot
21 programs has fallen well short of projected participation in each of the
22 program years. Finally, the Solar for Schools pilot program has performed
23 as projected in 2012 and 2013.

24
25

1 Q. Please describe the Company's PV pilot program performance in more
2 detail.

3 A. Reservations for incentives under this pilot program are made available
4 annually prior to the beginning of the program year. Each year the
5 program has been fully subscribed shortly after the new program year
6 funding becomes available. If any reservations are cancelled, those funds
7 are once again made available for additional customer reservations.
8 Through 2013, 132 PV systems have been installed in Gulf's service area
9 under this program. Through March 2014, reservations for an additional
10 51 PV systems have been received. The installed cost of PV systems
11 installed under this program has decreased consistent with the national
12 trend of declining solar PV costs. Based on the information collected in the
13 solar pilot programs, a more stable and viable solar contractor base has
14 developed in Gulf Power's service area. As the pilot programs began,
15 there were several contractors installing systems on a one-time basis.
16 However, in recent years, a base of contractors installing multiple
17 installations has been established. These contractors are actively
18 competing for market share and providing customers more competitive
19 options for system equipment and design, installed costs, and other
20 services to meet customers' needs and expectations.

21
22 Q. Please describe the Company's STWH rebate and Low-Income STWH
23 program performance in more detail.

24 A. Like the PV program, reservations for rebates under the STWH program
25 are made available annually prior to the beginning of the program year. In

1 no year has the number of reservations for installations of STWH systems
2 approached the projections. Gulf developed the projections for likely
3 installations under this program based on results of a 2008 STWH pilot
4 program with the same rebate level. Unlike the improvements in panel
5 efficiencies for PV systems, STWH technology has seen virtually no
6 change or improvement in the last six years. Gulf has not recognized any
7 increase in the STWH contractor base over the course of the pilot
8 program. Additionally, the costs for STWH systems installed under this
9 program actually increased between 2011 and 2013 program years.
10 Customers are seemingly unwilling to make such a significant investment
11 in a system for water heating when other alternatives, such as heat pump
12 water heating, are much more cost-effective.

13
14 Even in the STWH for low-income program where, working through low-
15 income organizations, the systems are installed for free, it has been
16 difficult to find customers willing to accept the risk and long-term
17 operational costs associated with the STWH systems. In 2011, 15
18 systems were installed working with two low-income housing agencies. In
19 2012, 14 systems were installed with two agencies, and in 2013 only 1
20 system was installed. Additional planned installations for 2013 were
21 cancelled by the low-income agency due to lack of interest. Currently, 14
22 installations are planned for 2014. Low-income housing providers have
23 been reluctant and in some cases unwilling to install the solar thermal
24 water heating systems on low-income housing recognizing their customer
25

1 base will not have the ability to pay for up keep and maintenance costs of
2 the installed systems.

3

4 Q. Please describe the Company's Solar for Schools program performance in
5 more detail.

6 A. The schools program is designed to provide a PV system up to 10KW for
7 one public education institution each year. The program was initially
8 designed to supplement the E-Shelter program being managed by the
9 Florida Solar Energy Center (FSEC). Due to the launch of the E-Shelter
10 program in 2011, no schools were identified for Gulf's program in 2011. In
11 2012 and 2013, one PV system was installed each year under the
12 program. For 2014, Gulf is currently working on a PV installation with a
13 school that had initially been selected under the E-Shelter program, but
14 was dropped due to installation difficulty. Identification of schools for the
15 program has been more difficult than expected. Schools are often
16 reluctant to install the systems on roofs due to wind loading and
17 maintenance concerns. Consequently, all systems installed to date have
18 been ground mount systems which are more expensive and more difficult
19 to site due to land availability, proximity to load centers, and shading
20 considerations.

21

22 Q. Has Gulf collected any additional information about customers who have
23 participated in these pilot programs?

24 A. Yes. Gulf has conducted customer surveys during the course of the pilot
25 programs. For the PV and STWH programs, most of the responding

1 customers were satisfied with the program enrollment and rebate process
2 as well as contractor performance. Additionally, 76% of the customers
3 participating in the solar pilot programs have annual incomes above the
4 Northwest Florida median of \$47,800 and 63% have home values greater
5 than the Northwest Florida median of \$170,000.

6
7 Q. What expenses has Gulf incurred as a result of these programs?

8 A. Expenses for these programs can be found in Schedule 16 of my exhibit.
9 Expenses have tracked with participation. Due to lower participation than
10 anticipated in the STWH programs, Gulf's expenditures have been below
11 the total spending cap established by the Commission in each year.

12

13 Q. For customers who have participated in the pilot programs, how have
14 installed equipment costs for both PV and STWH systems trended since
15 these programs began?

16 A. Equipment cost information collected during the pilot is provided in
17 Schedule 17 of my exhibit. The cost of systems installed under the PV
18 pilot program has decreased from an average of \$5.54 per watt in 2011 to
19 \$3.42 per watt for systems being installed in 2014. This decrease reflects
20 the national trend of declining solar PV costs.

21

22 Installation costs for STWH systems actually increased from the beginning
23 of the pilot program through 2013. Costs for systems projected to be
24 installed in 2014 indicate a slight decrease to near 2011 levels. Gulf

25

1 cannot determine whether this increase is a result of intentional markups
2 because of the incentive or inflationary cost pressures.

3

4 Q. Based on the results of the pilot, have the cost-effectiveness results of
5 these programs improved?

6 A. For roof-top PV, the cost-effectiveness from the participant's perspective
7 has improved. This is in part due to panel cost decreases, the rebate
8 provided under the pilot program, and the increasing competitiveness of
9 area solar installers. Under both the RIM and TRC tests, however, PV
10 remains non-cost effective. For the RIM test, the peak demand avoided
11 cost savings does not outweigh the revenue impact thus failing this
12 standard even with no incentive. For the TRC test, these same avoided
13 cost savings do not outweigh the total cost of these systems.

14

15 For STWH, the cost-effectiveness results have not improved materially
16 over the course of the pilot program. The cost-effectiveness results of
17 these technologies are shown in Schedule 18 of my exhibit.

18

19 Q. What would systems have to cost for them to be cost-effective?

20 A. The cost of installed PV would have to be below \$2 per watt to be cost-
21 effective under the TRC test at Gulf's current avoided cost. Since the RIM
22 test does not consider equipment cost, there is no cost point at which PV
23 would be cost-effective at Gulf's current avoided cost.

24

25

1 For STWH, the installed cost of an average system would have to be
2 below \$1,925 to be cost-effective under TRC. With actual costs over
3 \$5,000, costs would have to decline precipitously for these systems to
4 become cost-effective.

5
6 Q. Should the Company's existing solar pilot programs be extended and, if
7 so, should any modifications be made to them?

8 A. Based on the results of the pilot, Gulf recommends not continuing the pilot
9 programs past 2014. Neither the PV nor the STWH technologies are cost-
10 effective under the RIM or TRC test and therefore cause a cross-subsidy
11 to occur and ultimately cost Gulf's general body of customers more than
12 the benefits realized by these systems. This is not to say that PV systems
13 cannot be cost-effective to the participating customer. In fact, the
14 decreases in system costs have improved the cost-effectiveness of PV
15 systems to the point that additional ratepayer subsidized funding is not
16 appropriate.

17
18 Q. Aside from extending the existing solar pilot programs, are there other
19 actions Gulf Power could take to promote renewable energy in Florida?

20 A. Yes. Gulf can increase efforts around education on alternative energy
21 sources, including solar, through the existing Energy Education
22 component of Gulf's DSM Plan. As these technologies evolve, customer
23 education is an increasingly important aspect of the service the company
24 provides to all customers. Helping customers understand the opportunities
25 and limitations associated with alternatives like PV can lead to a better

1 customer experience as well as continued discovery of ways these
2 technologies can be incorporated into the utility grid. Increasing the focus
3 on these alternatives in our school-based and community education efforts
4 can help accomplish this goal.

5
6 Gulf can also work with area low-income agencies to seek educational
7 opportunities for this customer base. As PV costs continue to decline,
8 customers in lower income brackets may have opportunities to leverage
9 the benefits of renewable energy alternatives. Increased customer
10 education among this customer base can help ensure successful
11 development of these projects.

12
13
14 **Section 5: Conclusions**

15
16 Q. What is your recommendation to the Commission regarding appropriate
17 goals for the company?

18 A. My recommendation is that the Commission set goals for energy efficiency
19 and demand-side renewables based on all measures that are cost-
20 effective under the combination of the RIM and PT tests including the
21 effects of free-ridership based on a two-year payback criterion. This policy
22 will ensure all Demand-Side Management activity is evaluated consistent
23 with supply-side resources for the purposes of meeting customer energy
24 and demand needs in a least cost manner that effects lower electricity
25 rates than would otherwise result. This policy is also consistent with the

1 Commission's recognition of the importance of implementing FEECA in a
2 manner that supports economic growth and economic development.

3

4 Q. Does this conclude your testimony?

5 A. Yes.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24


25

AFFIDAVIT

STATE OF FLORIDA)
)
COUNTY OF ESCAMBIA)


Docket No. 130202-EI

Before me the undersigned authority, personally appeared John N. Floyd, who being first duly sworn, deposes, and says that he is the Energy Sales and Efficiency Manager of Gulf Power Company, a Florida corporation, that the foregoing is true and correct to the best of his knowledge, information, and belief. He is personally known to me.



John N. Floyd
Energy Sales and Efficiency Manager

Sworn to and subscribed before me this 31st day of March, 2014.



Notary Public, State of Florida at Large
Commission No. EE 150873
My Commission Expires Dec. 17, 2015



MELISSA A. DARNES
MY COMMISSION # EE 150873
EXPIRES: December 17, 2015
Bonded Thru Budget Notary Services

Proposed Numeric Conservation Goals -- Savings at the Generator

	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	Total
Residential											
Annual Energy (GWh)	2.3	3.2	4.2	5.1	6.0	6.8	7.6	8.3	8.9	9.5	62.1
Summer System Peak (MW)	2.3	3.2	4.1	5.0	5.9	6.7	7.5	8.1	8.8	9.3	60.9
Winter System Peak (MW)	1.3	1.8	2.3	2.9	3.4	3.8	4.3	4.6	5.0	5.3	34.8
Commercial/Industrial											
Annual Energy (GWh)	0.8	1.2	1.5	1.8	2.2	2.5	2.7	3.0	3.2	3.4	22.2
Summer System Peak (MW)	0.3	0.4	0.5	0.6	0.7	0.8	0.9	0.9	1.0	1.1	7.1
Winter System Peak (MW)	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.3	0.3	1.9
Total											
Annual Energy (GWh)	3.2	4.4	5.7	7.0	8.2	9.3	10.3	11.3	12.1	12.9	84.3
Summer System Peak (MW)	2.6	3.5	4.6	5.6	6.6	7.5	8.3	9.1	9.8	10.4	68.0
Winter System Peak (MW)	1.4	1.9	2.5	3.0	3.6	4.0	4.5	4.9	5.3	5.6	36.7

Note: Totals may not add due to rounding.

GULF POWER COMPANY
Comparison of Current Goals and Proposed Goals
at the Generator

Residential Annual Energy Reduction (GWh)					Residential Summer Peak Reduction (MW)					Residential Winter Peak Reduction (MW)				
Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change
2015	50.2	2.3	(47.9)	-95%	2015	12.8	2.3	(10.5)	-82%	2015	10.9	1.3	(9.6)	-88%
2016	53.6	3.2	(50.4)	-94%	2016	14.0	3.2	(10.8)	-77%	2016	12.1	1.8	(10.3)	-85%
2017	55.4	4.2	(51.2)	-92%	2017	14.7	4.1	(10.6)	-72%	2017	12.7	2.3	(10.4)	-82%
2018	56.2	5.1	(51.1)	-91%	2018	14.9	5.0	(9.9)	-66%	2018	13.3	2.9	(10.4)	-78%
2019	56.7	6.0	(50.7)	-89%	2019	15.1	5.9	(9.2)	-61%	2019	13.7	3.4	(10.3)	-75%
Commercial/Industrial Annual Energy Reduction (GWh)					Commercial/Industrial Summer Peak Reduction (MW)					Commercial/Industrial Winter Peak Reduction (MW)				
Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change
2015	11.7	0.8	(10.9)	-93%	2015	2.9	0.3	(2.6)	-91%	2015	1.0	0.1	(0.9)	-93%
2016	12.3	1.2	(11.1)	-91%	2016	3.0	0.4	(2.6)	-88%	2016	1.2	0.1	(1.1)	-92%
2017	12.7	1.5	(11.2)	-88%	2017	3.2	0.5	(2.7)	-85%	2017	1.1	0.1	(1.0)	-88%
2018	12.5	1.8	(10.7)	-85%	2018	3.1	0.6	(2.5)	-81%	2018	1.1	0.2	(0.9)	-86%
2019	11.9	2.2	(9.7)	-82%	2019	3.1	0.7	(2.4)	-78%	2019	1.1	0.2	(0.9)	-83%
Total Annual Energy Reduction (GWh)					Total Summer Peak Reduction (MW)					Total Winter Peak Reduction (MW)				
Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change	Year	Current	Proposed	Difference	% change
2015	61.9	3.2	(58.7)	-95%	2015	15.7	2.6	(13.1)	-84%	2015	11.9	1.4	(10.5)	-88%
2016	65.9	4.4	(61.5)	-93%	2016	17.0	3.5	(13.5)	-79%	2016	13.3	1.9	(11.4)	-86%
2017	68.1	5.7	(62.4)	-92%	2017	17.9	4.6	(13.3)	-75%	2017	13.8	2.5	(11.3)	-82%
2018	68.7	7.0	(61.7)	-90%	2018	18.0	5.6	(12.4)	-69%	2018	14.4	3.0	(11.4)	-79%
2019	68.6	8.2	(60.4)	-88%	2019	18.2	6.6	(11.6)	-64%	2019	14.8	3.6	(11.2)	-76%

Note: Totals may not add due to rounding.

**Comparison of Achieved kW and kWh Reductions
with Public Service Commission Established Goals
at the Generator
Annual Comparison**

Residential									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	35.0	-100%	0.00	7.5	-100%	0.00	5.9	-100%
2011	28.30	37.6	-25%	7.24	8.3	-13%	7.04	6.5	8%
2012	63.66	40.6	57%	19.29	9.4	105%	19.49	7.4	163%
2013	69.69	43.8	59%	22.70	10.5	116%	23.49	8.5	176%
Commercial/Industrial									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	3.2	-100%	0.00	1.2	-100%	0.00	0.5	-100%
2011	11.67	5.6	108%	5.13	1.6	221%	2.89	0.6	382%
2012	12.59	7.7	64%	14.54	2.1	592%	7.63	0.8	854%
2013	25.63	9.5	170%	7.46	2.4	211%	3.96	0.9	340%
Total (including Solar)									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	38.2	-100%	0.00	8.7	-100%	0.00	6.4	-100%
2011	40.37	43.2	-7%	12.55	9.9	27%	10.03	7.1	41%
2012	76.65	48.3	59%	34.02	11.5	196%	27.23	8.2	232%
2013	95.68	53.3	80%	30.35	12.9	135%	27.55	9.4	193%


Note: Totals may not add due to rounding.

**Comparison of Achieved kW and kWh Reductions
with Public Service Commission Established Goals
at the Generator
Cumulative Comparison**

Residential									
GWh Energy Reduction				Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	35.0	-100%	0.00	7.5	-100%	0.00	5.9	-100%
2011	28.30	72.6	-61%	7.24	15.8	-54%	7.04	12.4	-43%
2012	91.96	113.2	-19%	26.53	25.2	5%	26.53	19.8	34%
2013	161.65	157.0	3%	49.23	35.7	38%	50.02	28.3	77%
Commercial/Industrial									
GWh Energy Reduction				Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	3.2	-100%	0.00	1.2	-100%	0.00	0.5	-100%
2011	11.67	8.8	33%	5.13	2.8	83%	2.89	1.1	163%
2012	24.26	16.5	47%	19.67	4.9	301%	10.52	1.9	454%
2013	49.89	26.0	92%	27.13	7.3	272%	14.48	2.8	417%
Total (including Solar)									
GWh Energy Reduction				Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2010	0.00	38.2	-100%	0.00	8.7	-100%	0.00	6.4	-100%
2011	40.37	81.4	-50%	12.55	18.6	-33%	10.03	13.5	-26%
2012	117.02	129.7	-10%	46.57	30.1	55%	37.26	21.7	72%
2013	212.70	183.0	16%	76.92	43.0	79%	64.81	31.1	108%

Note: Totals may not add due to rounding.

Technical Potential Update Process



Technical Potential Measure List

Energy Efficiency Measures

Residential Energy Efficiency

- 1 14 SEER Split-System Heat Pump
- 2 15 SEER Split-System Air Conditioner
- 3 15 SEER Split-System Heat Pump
- 4 17 SEER Split-System Air Conditioner
- 5 17 SEER Split-System Heat Pump
- 6 19 SEER Split-System Air Conditioner
- 7 AC Heat Recovery Units
- 8 AC Maintenance (Indoor Coil Cleaning)
- 9 AC Maintenance (Outdoor Coil Cleaning)
- 10 Ceiling R-0 to R-19 Insulation
- 11 Ceiling R-19 to R-38 Insulation
- 12 CFL (18-Watt integral ballast), 0.5 hr/day
- 13 CFL (18-Watt integral ballast), 2.5 hr/day
- 14 CFL (18-Watt integral ballast), 6.0 hr/day
- 15 Default Window with Sunscreen
- 16 Double Pane Clear Windows to Double Pane Low-E Windows
- 17 Duct Repair
- 18 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 19 Energy Star CW CEE Tier 2 (MEF=2.0)
- 20 Energy Star CW CEE Tier 3 (MEF=2.2)
- 21 Energy Star Desktop PC
- 22 Energy Star DVD Player
- 23 Energy Star DW (EF=0.68)
- 24 Energy Star Laptop PC
- 25 Energy Star Set-Top Box
- 26 Energy Star TV
- 27 Energy Star VCR
- 28 Faucet Aerators
- 29 HE Freezer
- 30 HE Refrigerator - Energy Star version of above
- 31 HE Room Air Conditioner - EER 11
- 32 HE Room Air Conditioner - EER 12
- 33 Heat Pump Water Heater (EF=2.9)
- 34 Heat Trap
- 35 High Efficiency One Speed Pool Pump (1.5 hp)
- 36 Low Flow Showerhead
- 37 Pipe Wrap
- 38 Proper Refrigerant Charging and Air Flow
- 39 PV-Powered Pool Pumps
- 40 Radiant Barrier
- 41 Reflective Roof
- 42 RET 2L4'T8, 1EB
- 43 ROB 2L4'T8, 1EB
- 44 Sealed Attic w/Sprayed Foam Insulated Roof Deck
- 45 Sealed Attics
- 46 Solar Water Heat
- 47 Two Speed Pool Pump (1.5 hp)

Florida Public Service Commission
Docket No. 130202-EI
Gulf Power Company
Witness: John N. Floyd
Exhibit No. _____ (JNF-1)
Schedule 5
Page 1 of 7

Technical Potential Measure List

- 48 Variable-Speed Pool Pump (<1 hp)
- 49 Wall 2x4 R-0 to Blow-In R-13 Insulation
- 50 Water Heater Blanket
- 51 Water Heater Temperature Check and Adjustment
- 52 Water Heater Timeclock
- 53 Weather Strip/Caulk w/Blower Door
- 54 Window Film
- 55 Window Tinting
- 56 LED (12-Watt), 0.5 hr/day
- 57 LED (12-Watt), 2.5 hr/day
- 58 LED (12-Watt), 6.0 hr/day
- 59 LED (13-Watt) Outdoor
- 60 Fridge Appliance Recycling
- 61 Freeze Appliance Recycling
- 62 Smart Plug

Commercial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Air Handler Optimization
- 3 Anti-sweat (humidistat) controls
- 4 Ceiling Insulation
- 5 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 6 CFL Hardwired, Modular 18W
- 7 CFL Screw-in 18W
- 8 Chiller Tune Up/Diagnostics
- 9 Compressor VSD retrofit
- 10 Continuous Dimming
- 11 Convection Oven
- 12 Cool Roof - Chiller
- 13 Cool Roof - DX
- 14 Copier Power Management Enabling
- 15 Demand Control Ventilation (DCV)
- 16 Demand controlled circulating systems
- 17 Demand Defrost Electric
- 18 Demand Hot Gas Defrost
- 19 Duct/Pipe Insulation
- 20 DX Coil Cleaning
- 21 DX Packaged System, EER=11.9, 10 tons
- 22 DX Tune Up/ Advanced Diagnostics
- 23 Efficient Compressor Motor
- 24 Efficient Fryer
- 25 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 26 EMS - Chiller
- 27 EMS Optimization
- 28 Energy Recovery Ventilation (ERV)
- 29 Energy Star or Better Copier
- 30 Energy Star or Better Monitor
- 31 Evaporator fan controller for MT walk-ins
- 32 Floating head pressure controls
- 33 Freezer-Cooler Replacement Gaskets
- 34 Geothermal Heat Pump, EER=13, 10 tons

Technical Potential Measure List

- 35 HE PTAC, EER=9.6, 1 ton
- 36 Heat Pump Water Heater (air source)
- 37 Heat Recovery Unit
- 38 Heat Trap
- 39 High Bay T5
- 40 High Efficiency Chiller Motors
- 41 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 42 High Pressure Sodium 250W Lamp
- 43 High R-Value Glass Doors
- 44 High-efficiency fan motors
- 45 Hot Water Pipe Insulation
- 46 Hybrid Dessicant-DX System (Trane CDQ)
- 47 LED Display Lighting
- 48 LED Exit Sign
- 49 Lighting Control Tuneup
- 50 Monitor Power Management Enabling
- 51 Multiplex Compressor System
- 52 Night covers for display cases
- 53 Occupancy Sensor
- 54 Occupancy Sensor (hotels)
- 55 Optimize Controls
- 56 Outdoor Lighting Controls (Photocell/Timeclock)
- 57 Oversized Air Cooled Condenser
- 58 Packaged HP System, EER=11.7, 10 tons
- 59 PC Manual Power Management Enabling
- 60 PC Network Power Management Enabling
- 61 Premium T8, EB, Reflector
- 62 Premium T8, Electronic Ballast
- 63 Printer Power Management Enabling
- 64 PSMH, 250W, Magnetic Ballast
- 65 Refrigeration Commissioning
- 66 ROB Premium T8, 1EB
- 67 ROB Premium T8, EB, Reflector
- 68 Roof Insulation
- 69 Separate Makeup Air / Exhaust Hoods AC
- 70 Solar Water Heater
- 71 Strip curtains for walk-ins
- 72 Thermal Energy Storage (TES)
- 73 Variable Speed Drive Control
- 74 Vending Misers (cooled machines only)
- 75 VSD for Chiller Pumps and Towers
- 76 Window Film (Standard)
- 77 LED Linear Tube 22W
- 78 Flood LED 14W
- 79 LED (12-Watt)
- 80 LED High Bay 83W
- 81 Outdoor LED 104W
- 82 Run Time Optimizer
- 83 Dehumidification Hybrid Desiccant Heat Pump
- 84 Ice Machine
- 85 0.5 Faucet Aerator (DI)

Technical Potential Measure List

- 86 1.0 gpm Faucet Aerator (DI)
- 87 1.5 gpm Showerhead (DI)
- 88 Server Virtualization
- 89 Griddle
- 90 Steamer
- 91 Holding Cabinet

Industrial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Aerosole Duct Sealing - Chiller
- 3 Air conveying systems
- 4 Bakery - Process
- 5 Bakery - Process (Mixing) - O&M
- 6 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 7 CFL Hardwired, Modular 18W
- 8 CFL Screw-in 18W
- 9 Chiller Tune Up/Diagnostics
- 10 Clean Room - Controls
- 11 Clean Room - New Designs
- 12 Comp Air - ASD (100+ hp)
- 13 Comp Air - ASD (1-5 hp)
- 14 Comp Air - ASD (6-100 hp)
- 15 Comp Air - Motor practices-1 (100+ HP)
- 16 Comp Air - Motor practices-1 (1-5 HP)
- 17 Comp Air - Motor practices-1 (6-100 HP)
- 18 Comp Air - Replace 100+ HP motor
- 19 Comp Air - Replace 1-5 HP motor
- 20 Comp Air - Replace 6-100 HP motor
- 21 Compressed Air - Controls
- 22 Compressed Air - System Optimization
- 23 Compressed Air - Sizing
- 24 Compressed Air - O&M
- 25 Cool Roof - Chiller
- 26 Cool Roof - DX
- 27 Direct drive Extruders
- 28 Drives - EE motor
- 29 Drives - Optimization process (M&T)
- 30 Drives - Process Control
- 31 Drives - Process Controls (batch + site)
- 32 Drives - Scheduling
- 33 Drying (UV/IR)
- 34 Duct/Pipe Insulation
- 35 Duct/Pipe Insulation - Chiller
- 36 DX Coil Cleaning
- 37 DX Packaged System, EER=11.9, 10 tons
- 38 DX Tune Up / Advanced Diagnostics
- 39 Efficient Curing ovens
- 40 Efficient desalter
- 41 Efficient drives
- 42 Efficient drives - rolling
- 43 Efficient electric melting

Technical Potential Measure List

- 44 Efficient grinding
- 45 Efficient Machinery
- 46 Efficient practices printing press
- 47 Efficient Printing press (fewer cylinders)
- 48 Efficient processes (welding, etc.)
- 49 Efficient Refrigeration - Operations
- 50 EMS - Chiller
- 51 EMS Optimization - Chiller
- 52 Extruders/injection Moulding-multipump
- 53 Fans - ASD (100+ hp)
- 54 Fans - ASD (1-5 hp)
- 55 Fans - ASD (6-100 hp)
- 56 Fans - Controls
- 57 Fans - Motor practices-1 (100+ HP)
- 58 Fans - Motor practices-1 (1-5 HP)
- 59 Fans - Motor practices-1 (6-100 HP)
- 60 Fans - O&M
- 61 Fans - Replace 100+ HP motor
- 62 Fans - Replace 1-5 HP motor
- 63 Fans - Replace 6-100 HP motor
- 64 Fans - System Optimization
- 65 Fans - Improve Components
- 66 Gap Forming papermachine
- 67 Geothermal Heat Pump, EER=13, 10 tons
- 68 Heat Pumps - Drying
- 69 Heating - Optimization process (M&T)
- 70 Heating - Process Control
- 71 Heating - Scheduling
- 72 High Bay T5
- 73 High Consistency forming
- 74 High Efficiency Chiller Motors
- 75 Hybrid Dessicant - DX System (Trane CDQ)
- 76 Injection Moulding - Direct drive
- 77 Injection Moulding - Impulse Cooling
- 78 Intelligent extruder (DOE)
- 79 Light cylinders
- 80 Machinery
- 81 Membranes for wastewater
- 82 Near Net Shape Casting
- 83 New transformers welding
- 84 O&M - Extruders/Injection Moulding
- 85 O&M/drives spinning machines
- 86 Occupancy Sensor
- 87 Optimization control PM
- 88 Optimization Refrigeration
- 89 Optimize Controls
- 90 Optimize drying process
- 91 Other Process Controls (batch + site)
- 92 Power recovery
- 93 Premium T8, Electronic Ballast
- 94 Process control

Technical Potential Measure List

- 95 Process Drives - ASD
- 96 Process optimization
- 97 Pumps - ASD (100+ hp)
- 98 Pumps - ASD (1-5 hp)
- 99 Pumps - ASD (6-100 hp)
- 100 Pumps - Controls
- 101 Pumps - Motor practices-1 (100+ HP)
- 102 Pumps - Motor practices-1 (1-5 HP)
- 103 Pumps - Motor practices-1 (6-100 HP)
- 104 Pumps - O&M
- 105 Pumps - Replace 100+ HP motor
- 106 Pumps - Replace 1-5 HP motor
- 107 Pumps - Replace 6-100 HP motor
- 108 Pumps - Sizing
- 109 Pumps - System Optimization
- 110 Refinery Controls
- 111 Replace V-belts
- 112 Roof Insulation
- 113 Roof Insulation - Chiller
- 114 Top-heating (glass)
- 115 VSD for Chiller Pumps and Towers
- 116 Window Film (Standard)
- 117 Window Film (Standard) - Chiller
- 118 Run Time Optimizer
- 119 Dehumidification Hybrid Desiccant Heat Pump
- 120 LED Linear Tube 22W
- 121 Flood LED 14W
- 122 LED High Bay 83W (400W equivalent)

Demand Response Measures

Residential Demand Response

- 1 In home display with peak threshold warning system and pre-set control strategies
- 2 On-Off Switching via low-power wireless communication technology
- 3 Smart Thermostats
- 4 Switch - Cycling Program
- 5 Switch - Shedding Program

Commercial/Industrial Demand Response

- 1 Automated control strategies
- 2 Direct load control system

Demand Side Renewable Measures

Residential PhotoVoltaic

- 1 Rooftop solar PV

Commercial PhotoVoltaic

- 1 PV Mounted on Commercial Parking Lot Shade Structures
- 2 Rooftop solar PV

Technical Potential Measure List

Residential Measures Removed from Technical Potential

- 1 14 SEER Split-System Air Conditioner
- 2 14 SEER Split-System Heat Pump
- 3 HVAC Proper Sizing
- 4 High Efficiency CD (EF=3.01 w/moisture sensor)

Residential Measures Added to Technical Potential

- 1 LED (12-Watt), 0.5 hr/day
- 2 LED (12-Watt), 2.5 hr/day
- 3 LED (12-Watt), 6.0 hr/day
- 4 LED (13-Watt) Outdoor
- 5 Fridge Appliance Recycling
- 6 Freezer Appliance Recycling
- 7 Smart Plug

Commercial Measures Removed from Technical Potential

- 1 High Efficiency Water Heater (electric)

Commercial Measures Added to Technical Potential

- 1 LED Linear Tube 22W
- 2 Flood LED 14W
- 3 LED (12-Watt)
- 4 LED High Bay 83W
- 5 Outdoor LED 104W
- 6 Run Time Optimizer
- 7 Dehumidification Hybrid Desiccant Heat Pump
- 8 Ice Machine
- 9 0.5 Faucet Aerator (DI)
- 10 1.0 gpm Faucet Aerator (DI)
- 11 1.5 gpm Showerhead (DI)
- 12 Server Virtualization
- 13 Griddle
- 14 Steamer
- 15 Holding Cabinet

Industrial Measures Added to Technical Potential

- 1 Run Time Optimizer
- 2 Dehumidification Hybrid Desiccant Heat Pump
- 3 LED Linear Tube 22W
- 4 Flood LED 14W
- 5 LED High Bay 83W (400W equivalent)

**Table 1
Summary of Energy Efficiency Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	1,796	455	300
Commercial/Industrial	1,457	265	148
Total	3,253	720	448

**Table 2
Summary of Demand Response Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	N/A	201	213
Commercial/Industrial	N/A	84	34
Total	N/A	285	247

**Table 3
Summary of Solar Photovoltaic Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	2,559	929	169
Commercial/Industrial	1,458	552	70
Total	4,017	1,481	240

Note: Totals may not add due to rounding.

Technical Potential Results Compared to 2009 Goals Proceeding

	2009	2014	Variance
Summer Peak Demand (MW)	2,546	2,486	(60)
Winter Peak Demand (MW)	981	934	(47)
Annual Energy (GWH)	7,283	7,270	(13)

Summary of Energy Efficiency Economic Potential Results

	Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC
Residential	793	1,477	345	351	167	181
Commercial/Industrial	359	1,372	120	248	66	115
Total	1,153	2,849	465	599	233	296

Note: Totals may not add due to rounding.

Economic Potential Measure List

RIM Portfolio

Residential Energy Efficiency

- 1 15 SEER Split-System Air Conditioner
- 2 15 SEER Split-System Heat Pump
- 3 17 SEER Split-System Air Conditioner
- 4 17 SEER Split-System Heat Pump
- 5 19 SEER Split-System Air Conditioner
- 6 AC Heat Recovery Units
- 7 AC Maintenance (Indoor Coil Cleaning)
- 8 AC Maintenance (Outdoor Coil Cleaning)
- 9 Ceiling R-0 to R-19 Insulation
- 10 Ceiling R-19 to R-38 Insulation
- 11 Default Window With Sunscreen
- 12 Double Pane Clear Windows to Double Pane Low-E Windows
- 13 Duct Repair
- 14 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 15 HE Room Air Conditioner - EER 11
- 16 HE Room Air Conditioner - EER 12
- 17 Proper Refrigerant Charging and Air Flow
- 18 Radiant Barrier
- 19 Reflective Roof
- 20 Sealed Attic w/Sprayed Foam Insulated Roof Deck
- 21 Sealed Attics
- 22 Wall 2x4 R-0 to Blow-In R-13 Insulation
- 23 Window Film
- 24 Window Tinting

TRC Portfolio

Residential Energy Efficiency

- 1 15 SEER Split-System Air Conditioner
- 2 15 SEER Split-System Heat Pump
- 3 17 SEER Split-System Heat Pump
- 4 AC Maintenance (Indoor Coil Cleaning)
- 5 AC Maintenance (Outdoor Coil Cleaning)
- 6 Ceiling R-0 to R-19 Insulation
- 7 CFL (18-Watt integral ballast), 0.5 hr/day
- 8 CFL (18-Watt integral ballast), 2.5 hr/day
- 9 CFL (18-Watt integral ballast), 6.0 hr/day
- 10 Default Window With Sunscreen
- 11 Double Pane Clear Windows to Double Pane Low-E Windows
- 12 Duct Repair
- 13 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 14 Energy Star CW CEE Tier 2 (MEF=2.0)
- 15 Energy Star Desktop PC
- 16 Energy Star DVD Player
- 17 Energy Star Laptop PC
- 18 Energy Star Set-Top Box
- 19 Energy Star TV
- 20 Energy Star VCR
- 21 Faucet Aerators
- 22 Freezer Appliance Recycling
- 23 Fridge Appliance Recycling
- 24 HE Freezer
- 25 HE Refrigerator - Energy Star version of above
- 26 HE Room Air Conditioner - EER 11
- 27 HE Room Air Conditioner - EER 12
- 28 Heat Pump Water Heater (EF=2.9)
- 29 Heat Trap
- 30 High Efficiency One Speed Pool Pump (1.5 hp)
- 31 LED (12-Watt), 2.5 hr/day
- 32 LED (12-Watt), 6.0 hr/day
- 33 LED (13-Watt) Outdoor
- 34 Low Flow Showerhead
- 35 Pipe Wrap
- 36 Proper Refrigerant Charging and Air Flow
- 37 PV-Powered Pool Pumps
- 38 Radiant Barrier
- 39 Reflective Roof
- 40 RET 2L4'T8, 1EB
- 41 ROB 2L4'T8, 1EB
- 42 Smart Plug
- 43 Two Speed Pool Pump (1.5 hp)
- 44 Variable-Speed Pool Pump (<1 hp)
- 45 Water Heater Blanket
- 46 Water Heater Temperature Check and Adjustment
- 47 Water Heater Timeclock
- 48 Weather Strip/Caulk w/Blower Door
- 49 Window Film
- 50 Window Tinting

Economic Potential Measure List

RIM Portfolio

Commercial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Ceiling Insulation
- 3 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 4 Chiller Tune Up/Diagnostics
- 5 Cool Roof - Chiller
- 6 Cool Roof - DX
- 7 Copier Power Management Enabling
- 8 Dehumidification Hybrid Desiccant Heat Pump
- 9 Demand Control Ventilation (DCV)
- 10 Duct/Pipe Insulation
- 11 DX Coil Cleaning
- 12 DX Tune Up/ Advanced Diagnostics
- 13 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 14 EMS - Chiller
- 15 Energy Recovery Ventilation (ERV)
- 16 Energy Star or Better Copier
- 17 Energy Star or Better Monitor
- 18 Flood LED 14W
- 19 Geothermal Heat Pump, EER=13, 10 tons
- 20 High Efficiency Chiller Motors
- 21 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 22 LED (12-Watt)
- 23 LED High Bay 83W
- 24 LED Linear Tube 22W
- 25 Monitor Power Management Enabling
- 26 PC Manual Power Management Enabling
- 27 PC Network Power Management Enabling
- 28 Printer Power Management Enabling
- 29 Roof Insulation
- 30 Separate Makeup Air/Exhaust Hoods AC
- 31 Steamer
- 32 Thermal Energy Storage (TES)
- 33 VSD for Chiller Pumps and Towers
- 34 Window Film (Standard)

TRC Portfolio

Commercial Energy Efficiency

- 1 0.5 Faucet Aerator (DI)
- 2 1.0 gpm Faucet Aerator (DI)
- 3 1.5 gpm Faucet Aerator (DI)
- 4 Aerosole Duct Sealing
- 5 Air Handler Optimization
- 6 Anti-sweat (humidistat) controls
- 7 Ceiling Insulation
- 8 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 9 CFL Hardwired, Modular 18W
- 10 CFL Screw-in 18W
- 11 Chiller Tune Up/Diagnostics
- 12 Compressor VSD retrofit
- 13 Continuous Dimming
- 14 Cool Roof - Chiller
- 15 Cool Roof - DX
- 16 Copier Power Management Enabling
- 17 Dehumidification Hybrid Desiccant Heat Pump
- 18 Demand Control Ventilation (DCV)
- 19 Demand controlled circulating systems
- 20 Demand Defrost Electric
- 21 Demand Hot Gas Defrost
- 22 DX Coil Cleaning
- 23 DX Tune Up/Advanced Diagnostics
- 24 Efficient compressor motor
- 25 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 26 EMS - Chiller
- 27 EMS Optimization
- 28 Energy Recovery Ventilation (ERV)
- 29 Energy Star or Better Copier
- 30 Energy Star or Better Monitor
- 31 Evaporator fan controller for MT walk-ins
- 32 Floating head pressure controls
- 33 Flood LED 14W
- 34 Freezer-Cooler Replacement Gaskets
- 35 Geothermal Heat Pump, EER=13, 10 tons
- 36 Griddle
- 37 HE PTAC, EER=9.6, 1 ton
- 38 Heat Pump Water Heater (air source)
- 39 Heat Recovery Unit
- 40 Heat Trap
- 41 High Bay T5
- 42 High Efficiency Chiller Motors
- 43 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 44 High Pressure Sodium 250W Lamp

Economic Potential Measure List

- 45 High R-Value Glass Doors
- 46 High-efficiency fan motors
- 47 Holding Cabinet
- 48 Hot Water Pipe Insulation
- 49 Hybrid Dessicant-DX System (Trane CDQ)
- 50 Ice Machine
- 51 LED (12-Watt)
- 52 LED Display Lighting
- 53 LED High Bay 83W
- 54 LED Linear Tube 22W
- 55 Lighting Control Tuneup
- 56 Monitor Power Management Enabling
- 57 Multiplex Compressor System
- 58 Night covers for display cases
- 59 Occupancy Sensor
- 60 Occupancy Sensor (hotels)
- 61 Optimize Controls
- 62 Outdoor LED 104W
- 63 Outdoor Lighting Controls (Photocell/Timeclock)
- 64 Oversized Air Cooled Condenser
- 65 PC Manual Power Management Enabling
- 66 PC Network Power Management Enabling
- 67 Premium T8, EB, Reflector
- 68 Premium T8, Electronic Ballast
- 69 Printer Power Management Enabling
- 70 PSMH, 250W, magnetic ballast
- 71 Refrigeration Commissioning
- 72 ROB Premium T8, 1EB
- 73 ROB Premium T8, EB, Reflector
- 74 Roof Insulation
- 75 Run Time Optimizer
- 76 Separate Makeup Air / Exhaust Hoods AC
- 77 Server Virtualization
- 78 Solar Water Heater
- 79 Steamer
- 80 Strip curtains for walk-ins
- 81 Thermal Energy Storage (TES)
- 82 Variable Speed Drive Control
- 83 Vending Misers (cooled machines only)
- 84 VSD for Chiller Pumps and Towers
- 85 Window Film (Standard)

RIM Portfolio

Industrial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Aerosole Duct Sealing - Chiller
- 3 CFL Hardwired, Modular 18W
- 4 CFL Screw-in 18W
- 5 Chiller Tune Up/Diagnostics
- 6 Comp Air - Motor practices-1 (100+ HP)
- 7 Comp Air - Motor practices-1 (1-5 HP)
- 8 Comp Air - Motor practices-1 (6-100 HP)
- 9 Comp Air - Replace 100+ HP motor
- 10 Comp Air - Replace 1-5 HP motor

TRC Portfolio

Industrial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Aerosole Duct Sealing - Chiller
- 3 Air conveying systems
- 4 Bakery - Process
- 5 Bakery - Process (Mixing) - O&M
- 6 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 7 CFL Hardwired, Modular 18W
- 8 CFL Screw-in 18W
- 9 Chiller Tune Up/Diagnostics
- 10 Clean Room - Controls

Economic Potential Measure List

- | | | | |
|----|---|----|---|
| 11 | Comp Air - Replace 6-100 HP motor | 11 | Clean Room - New Designs |
| 12 | Compressed Air - Controls | 12 | Comp Air - ASD (100+ hp) |
| 13 | Compressed Air - System Optimization | 13 | Comp Air - ASD (6-100 hp) |
| 14 | Compressed Air - Sizing | 14 | Comp Air - Motor practices-1 (100+ HP) |
| 15 | Compressed Air - O&M | 15 | Comp Air - Motor practices-1 (1-5 HP) |
| 16 | Cool Roof - Chiller | 16 | Comp Air - Motor practices-1 (6-100 HP) |
| 17 | Cool Roof - DX | 17 | Comp Air - Replace 100+ HP motor |
| 18 | Dehumidification Hybrid Desiccant Heat Pump | 18 | Comp Air - Replace 6-100 HP motor |
| 19 | Drives - Optimization process (M&T) | 19 | Compressed Air - Controls |
| 20 | Duct/Pipe Insulation | 20 | Compressed Air - System Optimization |
| 21 | Duct/Pipe Insulation - Chiller | 21 | Compressed Air- Sizing |
| 22 | DX Coil Cleaning | 22 | Compressed Air-O&M |
| 23 | DX Tune Up/Advanced Diagnostics | 23 | Cool Roof - Chiller |
| 24 | Efficient Curing ovens | 24 | Cool Roof - DX |
| 25 | Efficient Refrigeration - Operations | 25 | Dehumidification Hybrid Desiccant Heat Pump |
| 26 | EMS Optimization - Chiller | 26 | Direct drive Extruders |
| 27 | Fans - Controls | 27 | Drives - EE motor |
| 28 | Fans - Motor practices-1 (100+ HP) | 28 | Drives - Optimization process (M&T) |
| 29 | Fans - Motor practices-1 (1-5 HP) | 29 | Drives - Process Control |
| 30 | Fans - Motor practices-1 (6-100 HP) | 30 | Drives - Process Controls (batch + site) |
| 31 | Fans - O&M | 31 | Drives - Scheduling |
| 32 | Fans - Replace 100+ HP motor | 32 | Drying (UV/IR) |
| 33 | Fans - Replace 1-5 HP motor | 33 | DX Coil Cleaning |
| 34 | Fans - Replace 6-100 HP motor | 34 | DX Tune Up/ Advanced Diagnostics |
| 35 | Fans - Improve Components | 35 | Efficient Curing ovens |
| 36 | Flood LED 14W | 36 | Efficient desalter |
| 37 | Geothermal Heat Pump, EER=13, 10 tons | 37 | Efficient drives |
| 38 | Heating - Optimization process (M&T) | 38 | Efficient drives - rolling |
| 39 | High Bay T5 | 39 | Efficient electric melting |
| 40 | High Efficiency Chiller Motors | 40 | Efficient grinding |
| 41 | Hybrid Dessicant-DX System (Trane CDQ) | 41 | Efficient Machinery |
| 42 | LED High Bay 83W (400W equivalent) | 42 | Efficient practices printing press |
| 43 | LED Linear Tube 22W | 43 | Efficient Printing press (fewer cylinders) |
| 44 | Machinery | 44 | Efficient processes (welding, etc.) |
| 45 | Membranes for wastewater | 45 | Efficient Refrigeration - Operations |
| 46 | New transformers welding | 46 | EMS - Chiller |
| 47 | O&M/drives spinning machines | 47 | EMS Optimization - Chiller |
| 48 | Optimization Refrigeration | 48 | Extruders/injection Moulding-multipump |
| 49 | Optimize Controls | 49 | Fans - ASD (100+ hp) |
| 50 | Premium T8, Elecctronic Ballast | 50 | Fans - ASD (6-100 hp) |
| 51 | Pumps - Controls | 51 | Fans - Controls |
| 52 | Pumps - Motor practices-1 (100+ HP) | 52 | Fans - Motor practices-1 (100+ HP) |
| 53 | Pumps - Motor practices-1 (1-5 HP) | 53 | Fans - Motor practices-1 (1-5 HP) |
| 54 | Pumps - Motor practices-1 (6-100 HP) | 54 | Fans - Motor practices-1 (6-100 HP) |
| 55 | Pumps - O&M | 55 | Fans - O&M |
| 56 | Pumps - Replace 100+ HP motor | 56 | Fans - Replace 100+ HP motor |
| 57 | Pumps - Replace 1-5 HP motor | 57 | Fans - Replace 6-100 HP motor |
| 58 | Pumps - Replace 6-100 HP motor | 58 | Fans - System Optimization |
| 59 | Pumps - Sizing | 59 | Fans - Improve Components |
| 60 | Pumps - System Optimization | 60 | Flood LED 14W |
| 61 | Replace V-belts | 61 | Gap Forming papermachine |
| 62 | Roof Insulation | 62 | Heat Pumps - Drying |
| 63 | Roof Insulation - Chiller | 63 | Heating - Optimization process (M&T) |
| 64 | Run Time Optimizer | 64 | Heating - Process Control |
| 65 | Window Film (Standard) | 65 | Heating - Scheduling |

Economic Potential Measure List

66 Window Film (Standard) - Chiller

- 66 High Bay T5
- 67 High Consistency forming
- 68 High Efficiency Chiller Motors
- 69 Hybrid Dessicant-DX System (Trane CDQ)
- 70 Injection Moulding - Direct drive
- 71 Injection Moulding - Impulse Cooling
- 72 Intelligent extruder (DOE)
- 73 LED High Bay 83W (400W equivalent)
- 74 LED Linear Tube 22W
- 75 Light cylinders
- 76 Machinery
- 77 Membranes for wastewater
- 78 Near Net Shape Casting
- 79 New transformers welding
- 80 O&M - Extruders/Injection Moulding
- 81 O&M/drives spinning machines
- 82 Occupancy Sensor
- 83 Optimization control PM
- 84 Optimization Refrigeration
- 85 Optimize Controls
- 86 Optimize drying process
- 87 Other Process Controls (batch + site)
- 88 Power recovery
- 89 Premium T8, Electronic Ballast
- 90 Process control
- 91 Process Drives - ASD
- 92 Process optimization
- 93 Pumps - ASD (100+ hp)
- 94 Pumps - ASD (6-100 hp)
- 95 Pumps - Controls
- 96 Pumps - Motor practices-1 (100+ HP)
- 97 Pumps - Motor practices-1 (1-5 HP)
- 98 Pumps - Motor practices-1 (6-100 HP)
- 99 Pumps - O&M
- 100 Pumps - Replace 100+ HP motor
- 101 Pumps - Replace 6-100 HP motor
- 102 Pumps - Sizing
- 103 Pumps - System Optimization
- 104 Refinery Controls
- 105 Replace V-belts
- 106 Roof Insulation
- 107 Roof Insulation - Chiller
- 108 Run Time Optimizer
- 109 Top-heating (glass)
- 110 VSD for Chiller Pumps and Towers
- 111 Window Film (Standard)
- 112 Window Film (Standard) - Chiller

**Table 1
Summary of Energy Efficiency Achievable Potential Results**

	Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC
Residential						
Max Incentive (maximum or 2 yr payback)	49	146	23	45	3	19
Commercial/Industrial						
Max Incentive (maximum or 2 yr payback)	22	109	7	22	2	7
Total						
Max Incentive (maximum or 2 yr payback)	71	255	30	67	5	26

**Table 2
Summary of Demand Response Achievable Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Demand Response			
Achievable Potential	13	38	32

Achievable Potential Measure List

RIM Portfolio

Residential Energy Efficiency

- 1 15 SEER Split-System Air Conditioner
- 2 17 SEER Split-System Heat Pump
- 3 AC Maintenance (Indoor Coil Cleaning)
- 4 AC Maintenance (Outdoor Coil Cleaning)
- 5 Default Window With Sunscreen
- 6 Double Pane Clear Windows to Double Pane Low-E Windows
- 7 Duct Repair
- 8 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 9 HE Room Air Conditioner - EER 11
- 10 HE Room Air Conditioner - EER 12
- 11 Proper Refrigerant Charging and Air Flow
- 12 Radiant Barrier
- 13 Reflective Roof
- 14 Window Tinting

TRC Portfolio

Residential Energy Efficiency

- 1 15 SEER Split-System Air Conditioner
- 2 15 SEER Split-System Heat Pump
- 3 17 SEER Split-System Heat Pump
- 4 AC Maintenance (Indoor Coil Cleaning)
- 5 AC Maintenance (Outdoor Coil Cleaning)
- 6 Default Window With Sunscreen
- 7 Double Pane Clear Windows to Double Pane Low-E Windows
- 8 Duct Repair
- 9 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 10 Energy Star CW CEE Tier 2 (MEF=2.0)
- 11 HE Room Air Conditioner - EER 11
- 12 HE Room Air Conditioner - EER 12
- 13 Heat Pump Water Heater (EF=2.9)
- 14 LED (12-Watt), 6.0 hr/day
- 15 LED (13-Watt) Outdoor
- 16 Low Flow Showerhead
- 17 Proper Refrigerant Charging and Air Flow
- 18 PV-Powered Pool Pumps
- 19 Radiant Barrier
- 20 Reflective Roof
- 21 Variable-Speed Pool Pump (<1 hp)
- 22 Water Heater Timeclock
- 23 Weather Strip/Caulk w/Blower Door
- 24 Window Film
- 25 Window Tinting

RIM Portfolio

Commercial Energy Efficiency

- 1 Ceiling Insulation
- 2 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 3 Chiller Tune Up/Diagnostics
- 4 Cool Roof - Chiller
- 5 Cool Roof - DX
- 6 Dehumidification Hybrid Desiccant Heat Pump
- 7 Demand Control Ventilation (DCV)
- 8 DX Tune Up/ Advanced Diagnostics
- 9 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 10 Energy Recovery Ventilation (ERV)
- 11 Flood LED 14W
- 12 Geothermal Heat Pump, EER=13, 10 tons
- 13 LED (12-Watt)
- 14 LED High Bay 83W

TRC Portfolio

Commercial Energy Efficiency

- 1 Air Handler Optimization
- 2 Ceiling Insulation
- 3 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 4 CFL Hardwired, Modular 18W
- 5 Chiller Tune Up/Diagnostics
- 6 Compressor VSD retrofit
- 7 Continuous Dimming
- 8 Cool Roof - Chiller
- 9 Cool Roof - DX
- 10 Dehumidification Hybrid Desiccant Heat Pump
- 11 Demand Control Ventilation (DCV)
- 12 Demand controlled circulating systems
- 13 DX Tune Up/ Advanced Diagnostics
- 14 Electronically Commutated Motors (ECM) on an Air Handler Unit

Achievable Potential Measure List

- 15 LED Linear Tube 22W
- 16 Roof Insulation
- 17 Separate Makeup Air/Exhaust Hoods AC

- 15 EMS - Chiller
- 16 EMS Optimization
- 17 Energy Recovery Ventilation (ERV)
- 18 Evaporator fan controller for MT walk-ins
- 19 Flood LED 14W
- 20 Geothermal Heat Pump, EER=13, 10 tons
- 21 Griddle
- 22 HE PTAC, EER=9.6, 1 ton
- 23 Heat Pump Water Heater (air source)
- 24 Heat Recovery Unit
- 25 High Efficiency Chiller Motors
- 26 High Pressure Sodium 250W Lamp
- 27 High R-Value Glass Doors
- 28 High-efficiency fan motors
- 29 Holding Cabinet
- 30 Hybrid Dessicant-DX System (Trane CDQ)
- 31 LED (12-Watt)
- 32 LED Display Lighting
- 33 LED High Bay 83W
- 34 LED Linear Tube 22W
- 35 Lighting Control Tuneup
- 36 Multiplex Compressor System
- 37 Occupancy Sensor
- 38 Occupancy Sensor (hotels)
- 39 Outdoor LED 104W
- 40 Outdoor Lighting Controls (Photocell/Timeclock)
- 41 Oversized Air Cooled Condenser
- 42 Premium T8, EB, Reflector
- 43 Premium T8, Electronic Ballast
- 44 ROB Premium T8, 1EB
- 45 ROB Premium T8, EB, Reflector
- 46 Roof Insulation
- 47 Run Time Optimizer
- 48 Separate Makeup Air / Exhaust Hoods AC
- 49 Server Virtualization
- 50 Solar Water Heater
- 51 Variable Speed Drive Control
- 52 VSD for Chiller Pumps and Towers
- 53 Window Film (Standard)

Achievable Potential Measure List

RIM Portfolio

Industrial Energy Efficiency

- 1 CFL Hardwired, Modular 18W
- 2 Dehumidification Hybrid Desiccant Heat Pump
- 3 Flood LED 14W
- 4 Hybrid Dessicant-DX System (Trane CDQ)
- 5 LED High Bay 83W (400W equivalent)
- 6 LED Linear Tube 22W

TRC Portfolio

Industrial Energy Efficiency

- 1 CFL Hardwired, Modular 18W
- 2 Chiller Tune Up/Diagnostics
- 3 Clean Room - Controls
- 4 Clean Room - New Designs
- 5 Cool Roof - Chiller
- 6 Cool Roof - DX
- 7 Dehumidification Hybrid Desiccant Heat Pump
- 8 Direct drive Extruders
- 9 Drives - Process Controls (batch + site)
- 10 Drying (UV/IR)
- 11 Efficient Curing ovens
- 12 Efficient desalter
- 13 Efficient drives - rolling
- 14 Efficient electric melting
- 15 Efficient grinding
- 16 Efficient Printing press (fewer cylinders)
- 17 Efficient processes (welding, etc.)
- 18 EMS - Chiller
- 19 Extruders/injection Moulding-multipump
- 20 Fans - Controls
- 21 Fans - System Optimization
- 22 Flood LED 14W
- 23 Heat Pumps - Drying
- 24 Hybrid Dessicant-DX System (Trane CDQ)
- 25 Injection Moulding - Direct drive
- 26 Injection Moulding - Impulse Cooling
- 27 LED High Bay 83W (400W equivalent)
- 28 LED Linear Tube 22W
- 29 Light cylinders
- 30 Machinery
- 31 Membranes for wastewater
- 32 New transformers welding
- 33 O&M/drives spinning machines
- 34 Occupancy Sensor
- 35 Optimization Refrigeration
- 36 Optimize drying process
- 37 Other Process Controls (batch + site)
- 38 Process optimization
- 39 Pumps - System Optimization
- 40 Run Time Optimizer
- 41 VSD for Chiller Pumps and Towers

		Annual Bill Impact for 1,200 kWh/Month Residential Customer									
		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
RIM Portfolio/Proposed Goals		\$ 8.71	\$ 9.20	\$ 9.80	\$10.41	\$10.94	\$11.35	\$11.73	\$12.05	\$12.34	\$12.60
TRC Portfolio		\$23.34	\$28.99	\$35.25	\$41.59	\$47.27	\$52.10	\$56.50	\$60.30	\$63.76	\$66.82

Summary of the Economic Potential Fuel Sensitivity Results

	# of Passing Measures		Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC	RIM	TRC
Residential								
Base	190	218	793	1,477	345	351	167	181
Low Fuel	165	207	666	1,422	303	341	116	176
High Fuel	193	232	804	1,591	348	382	172	201
Commercial/Industrial								
Base	576	1,950	359	1,372	120	248	66	115
Low Fuel	406	1,936	230	1,357	95	243	65	111
High Fuel	898	1,996	509	1,376	151	249	77	116
Total								
Base	766	2,168	1,153	2,849	465	599	233	296
Low Fuel	571	2,143	897	2,779	399	584	181	287
High Fuel	1,091	2,228	1,313	2,967	499	631	249	317

Note: Totals may not add due to rounding.

Summary of the Economic Potential Free-Ridership Sensitivity Results

	# of Passing Measures		Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC	RIM	TRC
Residential								
1 year Payback	72	136	453	1,080	206	296	42	138
2 year Payback	64	109	364	727	168	223	43	96
3 year Payback	50	82	262	586	128	176	43	94
Commercial/Industrial								
1 year Payback	231	901	269	896	78	168	17	55
2 year Payback	216	694	257	759	73	148	17	46
3 year Payback	185	527	224	535	63	110	14	38
Total								
1 year Payback	303	1,037	722	1,975	284	464	60	194
2 year Payback	280	803	621	1,486	240	371	59	142
3 year Payback	235	609	486	1,121	191	286	57	131

Note: Totals may not add due to rounding.

Solar Pilot Participation History

	2010	2011	2012	2013	2014*
Solar PV	-	42	46	44	51
Solar Thermal Water Heating	-	32	22	22	5
Solar Thermal Water Heating - Low Income	-	15	14	1	14
Solar for Schools	-	-	1	1	1

* Projected values based on current enrollments and reservations.

Solar Pilot Expense History (000s)

	2010	2011	2012	2013	2014*
Administrative Expenses	\$ -	\$ 161	\$ 174	\$ 234	\$ 32
Solar PV	\$ -	\$ 424	\$ 430	\$ 435	\$ 320
Solar Thermal Water Heating	\$ -	\$ 44	\$ 22	\$ 22	\$ 3
Solar Thermal Water Heating - Low Income	\$ -	\$ 74	\$ 66	\$ 5	\$ -
Solar for Schools	\$ -	\$ 70	\$ 56	\$ 83	\$ -
Total	\$ -	\$ 773	\$ 748	\$ 779	\$ 355

* YTD February 2014

Solar PV Historical Customer Equipment Costs (\$/Watt)

	2011	2012	2013	2014*
Average System Cost (w/out batteries)	\$ 5.54	\$ 4.75	\$ 4.27	\$ 3.42

* Projected values based on current enrollments and reservations.

Solar Thermal Water Heating Historical Customer Equipment Costs (\$/System)

	2011	2012	2013	2014*
Average System Cost	\$ 5,742	\$ 5,972	\$ 6,018	\$ 5,480

* Projected values based on current enrollments and reservations.

Solar PV & STWH Cost Effectiveness Results

	RIM*	TRC
Solar PV	0.88	0.67
STWH - (Single Family)	0.74	0.56

* Results shown above did not include incentive payments

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

IN RE: **Commission review of numeric
conservation goals**)

Docket No.: **130202-EI**

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing was furnished by electronic mail this 2nd day of April, 2014 to the following:

Ausley Law Firm
James D. Beasley
J. Jeffrey Wahlen
Ashley M. Daniels
Post Office Box 391
Tallahassee, FL 32302
jbeasley@ausley.com
adaniels@ausley.com

Florida Department of Agriculture
and Consumer Services
Office of General Counsel
Steven L. Hall
407 South Calhoun Street, Suite 520
Tallahassee, FL 32399
Steven.Hall@FreshFromFlorida.com

Florida Industrial Power Users Group
c/o Moyle Law Firm
Jon C. Moyle, Jr.
Karen Putnal
118 North Gadsden Street
Tallahassee, FL 32301
jmoyle@moylelaw.com
kputnal@moylelaw.com

Florida Power & Light Company
John T. Butler
Jessica A. Cano
700 Universe Boulevard (LAW/JB)
Juno Beach, FL 33408-0420
John.Butler@fpl.com
Jessica.Cano@fpl.com

Florida Power & Light Company
Kenneth Hoffman
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1858
Ken.Hoffman@fpl.com

Florida Public Utilities Company
Cheryl M. Martin
1641 Worthington Road
Suite 220
West Palm Beach, FL 33409-6703
Cheryl.Martin@fpuc.com

Florida Power & Light Company
Kevin Donaldson
4200 West Flagler Street
Miami, FL 33134
Kevin.Donaldson@fpl.com

Office of Public Counsel
Erik Saylor
c/o The Florida Legislature
111 W. Madison Street, Room 812
Tallahassee, FL 32393
Saylor.erik@leg.state.fl.us

Duke Energy Florida, Inc.
Matthew R. Bernier
Dianne Triplett
106 East College Avenue,
Suite 800
Tallahassee, FL 32301-7740
Matthew.bernier@duke-energy.com
Dianne.triplett@duke-energy.com

JEA
Hopping Green & Sams
Gary V. Perko
P. O. Box 6526
Tallahassee, FL 32314
gperko@hgslaw.com
blewis@hgslaw.com

Southern Alliance for Clean Energy
c/o George Cavros, Esq.
120 East Oakland Park Blvd.
Suite 105
Fort Lauderdale, FL 33334
george@cavros-law.com

Tampa Electric Company
Ms. Paula K. Brown
Regulatory Affairs
P. O. Box 111
Tampa, FL 33601-0111
Regdept@tecoenergy.com

Gunster Law Firm
Beth Keating
215 South Monroe Street
Suite 601
Tallahassee, FL 32301-1839
bkeating@gunster.com

Florida Retail Federation
Robert Scheffel Wright
John T. LaVia
c/o Gardner Law Firm
1300 Thomaswood Drive
Tallahassee, FL 32308
schef@gbwlegal.com
jlavia@gbwlegal.com

JEA
Mr. P. G. Para
21 West Church Street, Tower 16
Jacksonville, FL 32202-3158
parapg@jea.com

Office of the General Counsel
Charles Murphy
Lee Eng Tan
2540 Shumard Oak Blvd
Tallahassee, FL 32399-0850
cmurphy@psc.state.fl.us
ltan@psc.state.fl.us

Orlando Utilities Commission
Mr. W. Christopher Browder
Post Office Box 3193
Orlando, FL 32802-3192
cbrowder@ouc.com

Sierra Club
Diana A. Csank
50 F Street NW, 8th Floor
Washington, DC 20001
Diana.Csank@SierraClub.org

PCS Phosphate – White Springs
c/o Brickfield Law Firm
James W. Brew/F. Alvin Taylor
Eighth Floor, West Tower
1025 Thomas Jefferson St, NW
Washington, DC 20007
jbrew@bbrslaw.com
ataylor@bbrslaw.com

Earthjustice
Alisa Coe
David G. Guest
111 S. Martin Luther King Jr. Blvd.
Tallahassee, FL 32301
acoe@earthjustice.org
dguest@earthjustice.org
bbeard@earthjustice.org



JEFFREY A. STONE

Florida Bar No. 325953

jas@beggsllane.com

RUSSELL A. BADDERS

Florida Bar No. 007455

rab@beggsllane.com

STEVEN R. GRIFFIN

Florida Bar No. 0627569

srg@beggsllane.com

BEGGS & LANE

P. O. Box 12950

Pensacola FL 32591-2950

(850) 432-2451

Attorneys for Gulf Power