



FRIEDMAN,  
FRIEDMAN & LONG, P.A.  
ATTORNEYS & COUNSELORS

May 20, 2014

Carlotta S. Stauffer, Commission Clerk  
Office of Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399

RE: Docket No. 130265; Application for a Staff Assisted Rate Case in Charlotte County by  
Little Gasparilla Water Utility, Inc.  
Our File No.: 35019.04

Dear Ms. Stauffer:

Little Gasparilla Water Utility, Inc. previously sent responses to the Staff's Second Data Request dated April 30, 2014 directly to Sonica Bruce, and I understand that she is sending them to you for including in the docket. Apparently one page from those responses was omitted from the filing. Thus, attached are responses to Data Requests 9 through 12 (and the end of 8).

Should you have any questions concerning this filing, please do not hesitate to give me call.

Very truly yours,

A handwritten signature in blue ink, appearing to read "Martin S. Friedman", written in a cursive style.

MARTIN S. FRIEDMAN  
For the Firm

MSF/

cc: Jack Boyer (via e-mail)  
Sonica Bruce (via e-mail)

a time due to cash flow. We have been cleaning annually and are hoping to stretch out the need to replace, before the interconnect is complete. This will save \$20,000 on membranes, \$1,000 on transportation and \$2,500 on installation. Total savings of \$23,500

9) Billing Cycle? No. We will try to stay quarterly for the cost savings

10) Boat Dock Water Meters (included #10) we highlighted docks before 2000 that should not be included) Also will address in question #25 with new easements as well.

11) Salvage value, we believe this to be more of a liability to remove from the Island at \$600 pr barge trip plus disassembling and loading. Only time will tell? There is not much demand for strait saltwater plants. We are the only one operating at this time in Florida and as far as we know in the county? Will pursue.

12) Charlotte County (a) This is the metering with backflows and by pass, as well as the line for the tie-in. estimated cost of \$30,000 backflow assembly, tie in and \$6,000 meter.(\$36,000 total)

(b) Attached #12b is an email from Gary Hubbard stating there will be NO cost in annual calibration.

(c) LGWU will be responsible for collecting and then paying CCU. This is monitored by #9 pg 7 (d) Wheeling charge?