

State of Florida



## Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD  
TALLAHASSEE, FLORIDA 32399-0850

**-M-E-M-O-R-A-N-D-U-M-**

---

**DATE:** September 22, 2014  
**TO:** Carlotta S. Stauffer, Commission Clerk, Office of Commission Clerk  
**FROM:** Clayton Lewis, US Engineering Specialist, Division of Engineering  
**RE:** DN 140122 - EI Petition to modify transmission structure inspection cycle, by Tampa Electric Company.

---

Please file the attached response from Tampa Electric Company to staff providing additional information in support of its petition in the above mentioned docket file.

Thank you.

## Terri Jones

---

**From:** Patti Zellner  
**Sent:** Monday, September 22, 2014 10:01 AM  
**To:** Terri Jones  
**Subject:** FW: Docket No. 140122 - Exhibit A  
**Attachments:** SAIDI table.xlsx

---

**From:** Clayton Lewis  
**Sent:** Monday, September 22, 2014 9:58 AM  
**To:** Patti Zellner  
**Cc:** Laura King  
**Subject:** FW: Docket No. 140122 - Exhibit A

Patti,

Please forward the email response and attachment the clerk's office for filing in Docket No. 140122.

Thank you

---

**From:** Stiles II, Billy J. [<mailto:wjstiles@tecoenergy.com>]  
**Sent:** Thursday, September 11, 2014 4:12 PM  
**To:** Clayton Lewis  
**Subject:** RE: Docket No. 140122 - Exhibit A

Clayton, please see the attached table. Call me if you have any questions.

Billy

Wilbur J. Stiles, II  
Manager Regulatory Affairs  
Tampa Electric Company  
106 E. College Avenue  
Suite 630  
Tallahassee, FL 32301  
Office: 850-681-6785  
Mobile: 850-294-6589  
FAX: 850-681-9808  
Email: [wjstiles@tecoenergy.com](mailto:wjstiles@tecoenergy.com)



---

**From:** Clayton Lewis [mailto:CLewis@PSC.STATE.FL.US]  
**Sent:** Thursday, September 11, 2014 9:05 AM  
**To:** Stiles II, Billy J.  
**Cc:** Laura King  
**Subject:** Docket No. 140122 - Exhibit A

\*\*\*\*\* This email is from an external sender. Be cautious about clicking links or opening attachments from unknown sources. \*\*\*\*\*

---

Good Morning Mr. Stiles,

I am trying to finalize the recommendation and a couple of questions popped up about Exhibit A. May we please have the data table used to create Exhibit A?

Here is the link to the filing: <http://www.floridapsc.com/library/FILINGS/14/02783-14/02783-14.pdf>

I will be in the office until noon today.

Thank you, sir

*Clayton K. Lewis*  
*Division of Engineering*  
*850 413-6578*

---

NOTICE: This email is intended only for the individual(s) to whom it is addressed and may contain confidential information. If you have received this email by mistake, please notify the sender immediately, delete this email from your system and do not copy or disclose it to anyone else. Although we take precautions to protect against viruses, we advise you to take your own precautions to protect against viruses as we accept no liability for any which remain.

	Year							
	2006	2007	2008	2009	2010	2011	2012	2013
Transmission SAIDI impact (minutes)	2.81	1.59	4.91	7.35	4.55	4.46	6.89	1.20
Distribution SAIDI impact (minutes)	69.16	76.80	65.55	76.69	84.20	75.96	78.07	85.05