

FLORIDA PUBLIC SERVICE COMMISSION

VOTE SHEET

November 25, 2014

Item 19

FILED NOV 25, 2014  
DOCUMENT NO. 06499-14  
FPSC - COMMISSION CLERK

Docket No. 140122-EI – Petition to modify transmission structure inspection cycle, by Tampa Electric Company.

**Issue 1:** Should TECO be allowed to modify its Transmission Structure Inspection Cycle from a six-year cycle to an eight-year cycle for transmission poles?

**Recommendation:** Yes. Since many repairs and replacements have been performed during the first complete cycle, increasing the transmission structure inspection cycle from six to eight years does not appear to be a detriment to overall system reliability. The projected savings are \$108,000 per year. Therefore, staff recommends that TECO should be allowed to increase its transmission structure inspection cycle from six to eight years.

**APPROVED**


RECEIVED-FPSC  
14 NOV 25 PM 2:13  
COMMISSION  
CLERK

COMMISSIONERS ASSIGNED: All Commissioners

COMMISSIONERS' SIGNATURES

MAJORITY

DISSENTING



\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**REMARKS/DISSENTING COMMENTS:**

Vote Sheet

November 25, 2014

Item 19

**Docket No. 140122-EI** – Petition to modify transmission structure inspection cycle, by Tampa Electric Company.

(Continued from previous page)

**Issue 2:** Should this docket be closed?

**Recommendation:** Yes. If no person whose substantial interests are affected by the proposed agency action files a protest within 21 days of the issuance of the order, this docket should be closed upon the issuance of a consummating order.

**APPROVED**