



Matthew R. Bernier  
SENIOR COUNSEL

June 12, 2015

**VIA ELECTRONIC FILING**

Ms. Carlotta Stauffer, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

*Re: Summary of Mulberry Cogen Event on June 1, 2015; Undocketed*

Dear Ms. Stauffer:

Pursuant to FPSC Rule 25-17.086, "Periods During Which Purchases are Not Required," Duke Energy Florida (DEF) is providing notice to the Florida Public Service Commission that a DEF outage affected the Mulberry Cogen facility on June 1, 2015. The Mulberry Cogen facility is interconnected to the DEF transmission system at DEF's Mulberry substation. At approximately 1911 hours on June 1, 2015, the Mulberry Cogen to Homeland 69 kV transmission line tripped out. Field patrols indicated that a contributing cause of the line trip was a bird nest that fell and came in contact with energized equipment at Noralyn substation. Restoration of service was completed at approximately 2335 hours on June 1, 2015. Mulberry Cogen was promptly notified and the unit resumed normal operation.

Thank you for your assistance in this matter. Should you have any questions, please feel free to call me at (850) 521-1428.

Sincerely,

*/s/ Matthew R. Bernier*

Matthew R. Bernier

MRB/db