



Matthew R. Bernier  
SENIOR COUNSEL

June 25, 2015

**VIA ELECTRONIC FILING**

Ms. Carlotta Stauffer, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

*Re: Summary of Orange Cogen Event on June 24, 2015; Undocketed*

Dear Ms. Stauffer:

Pursuant to FPSC Rule 25-17.086, "Periods During Which Purchases are Not Required," Duke Energy Florida (DEF) is providing notice to the Florida Public Service Commission that a DEF outage affected the Orange Cogen facility on June 24, 2015. The Orange Cogen facility is interconnected to the DEF transmission system at DEF's Orange Switching substation.

At approximately 1715 hours on June 24, 2015, Orange Cogen tripped offline. Field patrols reported severe weather in the area and equipment damage that caused the conductor on the Homeland to Orange Cogen Switching Station 69 kV line to fall across Highway 17. Restoration of service was completed at approximately 1911 hours on June 24, 2015. Orange Cogen was promptly notified and the unit resumed normal operation.

Thank you for your assistance in this matter. Should you have any questions, please feel free to call me at (850) 521-1428.

Sincerely,

/s/ Matthew R. Bernier

Matthew R. Bernier

MRB/db