



DIANNE M. TRIPLETT
ASSOCIATE GENERAL COUNSEL

July 20, 2015

VIA ELECTRONIC FILING

Ms. Carlotta Stauffer, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No.: 150001
Performance Data Report for June 2015

Dear Ms. Stauffer:

Enclosed for filing in the above docket is Duke Energy Florida's Performance Data Report for June 2015.

If you have any questions, please do not hesitate to contact me at (727) 820-4692.

Sincerely,

A handwritten signature in black ink that reads "Dianne M. Triplett".

Dianne M. Triplett
Associate General Counsel

DMT/db
Enclosure

cc: Daniel Lee, Division of Engineering, FPSC
Parties of Record

Duke Energy Florida, Inc.

CERTIFICATE OF SERVICE

Docket No. 150001-EI

I HEREBY CERTIFY that a true copy of Duke Energy Florida, Inc.'s Performance Data Report for the month of June 2015 has been furnished to the following individuals via e-mail on this 20th day of July, 2015.



Attorney

<p>Suzanne Brownless, Esq. Danijela Janjic, Esq. John Villafrate, Esq. Office of General Counsel Florida Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 sbrownle@psc.state.fl.us djanjic@psc.state.fl.us jvillafr@psc.state.fl.us</p> <p>James D. Beasley, Esq. J. Jeffrey Wahlen, Esq. Ashley M. Daniels, Esq. Ausley McMullen Law Firm P.O. Box 391 Tallahassee, FL 32302 jbeasley@ausley.com jwahlen@ausley.com adaniels@ausley.com</p> <p>Jeffrey A. Stone, Esq. Russell A. Badders, Esq. Steven R. Griffin, Esq. Beggs & Lane P.O. Box 12950 Pensacola, FL 32591 jas@beggslane.com rab@beggslane.com srg@beggslane.com</p> <p>Jon C. Moyle, Jr., Esq. Moyle Law Firm, P.A. 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com</p> <p>Kenneth Hoffman Florida Power & Light Company 215 S. Monroe Street, Suite 810 Tallahassee, FL 32301-1858 ken.hoffman@fpl.com</p>	<p>Mike Cassel Aleida Socarras Florida Public Utilities Company/Florida Division of Chesapeake Utilities Corporation 1750 SW 14th Street, Suite 200 Fernandina Beach, FL 32034 mcassel@fpuc.com asocarras@chpk.com</p> <p>Robert Scheffel Wright, Esq. John T. LaVia, III, Esq. c/o Gardner Law Firm 1300 Thomaswood Drive Tallahassee, FL 32308 schef@gbwlegal.com jlavia@gbwlegal.com</p> <p>Robert L. McGee, Jr. Gulf Power Company One Energy Place Pensacola, FL 32520-0780 rlmcgee@southernco.com</p> <p>Beth Keating, Esq. Gunster, Yoakley & Stewart, P.A. 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com</p> <p>Charles J. Rehwinkel Erik Saylor / John Truitt Patty Christensen / J.R. Kelly Office of Public Counsel c/o The Florida Legislature 111 West Madison Street, Room 812 Tallahassee, FL 32399-1400 rehwinkel.charles@leg.state.fl.us saylor.erik@leg.state.fl.us kelly.jr@leg.state.fl.us Christensen.patty@leg.state.fl.us Truitt.john@leg.state.fl.us</p>	<p>Ms. Paula K. Brown Manager, Regulatory Coordination Tampa Electric Company P.O. Box 111 Tampa, FL 33601 regdept@tecoenergy.com</p> <p>Raoul G. Cantero, III, Esq. White & Case, LLP Southeast Financial Center, Suite 4900 200 South Biscayne Boulevard Miami, FL 33131-2352 rcantero@whitecase.com</p> <p>James W. Brew, Esq. Owen J. Kopon, Esq. Laura A. Wynn, Esq. Stone Matheis Xenopoulos & Brew, PC 1025 Thomas Jefferson Street NW 8th Floor, West Tower Washington, DC 20007 jbrew@smxblaw.com ojk@smxblaw.com laura.wynn@smxblaw.com</p> <p>John T. Butler, Esq. Maria Moncada, Esq. Florida Power & Light Company 700 Universe Boulevard (LAW/JB) Juno Beach, FL 33408-0420 john.butler@fpl.com maria.moncada@fpl.com</p>
---	--	--

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2015

Bartow CC	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	91.68	93.44	56.55	87.01	96.26	97.92							86.99
2. PH	744	672	743	720	744	720							4,343
3. SH	669.9	591.6	406.2	614.5	726.7	692.3							3,701.0
4. RSH	12.2	36.4	14.0	12.0	0.6	14.7							89.8
5. UH	61.9	44.1	322.9	93.5	16.8	13.1							552.2
6. POH	58.3	0.5	222.8	80.9	0.0	0.0							362.4
7. FOH	0.0	0.0	0.0	12.6	1.5	0.7							14.8
8. MOH	3.6	43.7	100.1	0.0	15.3	12.5							175.0
9. PPOH	0.0	0.0	0.0	3.6	0.0	0.0							3.6
10. LR PP (MW)	0.0	0.0	0.0	1.0	0.0	0.0							1.0
11. PFOH	0.0	0.0	0.0	0.0	57.3	14.9							72.2
12. LR PF (MW)	0.0	0.0	0.0	0.0	119.1	137.6							122.9
13. PMOH	0.0	0.0	0.0	3.4	34.8	0.0							38.2
14. LR PM (MW)	0.0	0.0	0.0	27.0	144.5	0.0							134.0
15. NSC (MW)	1076	1076	1076	1076	1076	1076							1076
16. OPER MBTU	4,903,737	4,237,148	3,398,094	4,781,803	5,375,275	5,100,215							27,796,273
17. NET GEN (MWH)	670,768	556,814	368,790	666,724	679,053	691,381							3,633,530
18. ANOHR (BTU/KWH)	7,310.6	7,609.6	9,214.2	7,172.1	7,915.8	7,376.9							7,649.9
19. NOF (%)	84.50	79.43	76.62	101.02	87.01	92.99							87.34
20. NPC (MW)	1076	1076	1076	1076	1076	1076							1076

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2015

CRYSTAL RIVER 4	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	90.53	99.17	98.74	96.48	89.10	93.62							94.53
2. PH	744	672	743	720	744	720							4,343
3. SH	674.9	672.0	743.0	720.0	693.0	681.8							4,184.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	69.1	0.0	0.0	0.0	51.1	38.2							158.4
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
8. MOH	69.1	0.0	0.0	0.0	51.1	38.2							158.4
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
11. PFOH	0.0	17.4	10.3	19.7	0.0	8.3							55.6
12. LR PF (MW)	0.0	220.6	167.3	336.1	0.0	335.2							268.7
13. PMOH	10.5	1.5	18.2	128.0	238.7	34.0							430.9
14. LR PM (MW)	93.0	93.2	271.9	89.2	89.6	80.6							96.6
15. NSC (MW)	712	712	712	712	712	712							712
16. OPER MBTU	3,448,203	3,378,381	4,227,341	4,046,621	3,625,009	3,566,531							22,292,087
17. NET GEN (MWH)	332,848	319,716	412,868	398,291	351,041	349,885							2,164,649
18. ANOHR (BTU/KWH)	10,359.7	10,566.8	10,239.0	10,160.0	10,326.5	10,193.4							10,298.2
19. NOF (%)	69.26	66.82	78.04	77.69	71.15	72.08							72.65
20. NPC (MW)	712	712	712	712	712	712							712

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA – YEAR 2015

CRYSTAL RIVER 5	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	100.00	99.64	98.87	91.76	97.54	99.45							97.87
2. PH	744	672	743	720	744	720							4,343
3. SH	75.3	404.0	743.0	670.1	744.0	720.0							3,356.4
4. RSH	668.7	268.0	0.0	0.0	0.0	0.0							936.7
5. UH	0.0	0.0	0.0	49.9	0.0	0.0							49.9
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	0.0	0.0	0.0	49.9	0.0	0.0							49.9
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
11. PFOH	0.0	0.0	17.0	28.3	0.0	0.0							45.3
12. LR PF (MW)	0.0	0.0	91.0	88.4	0.0	0.0							89.4
13. PMOH	0.0	3.7	24.9	53.0	65.3	33.6							180.4
14. LR PM (MW)	0.0	471.6	177.5	78.5	199.4	83.6							144.8
15. NSC (MW)	710	710	710	710	710	710							710
16. OPER MBTU	441,979	2,042,258	4,217,136	3,835,333	4,045,552	3,716,334							18,298,591
17. NET GEN (MWH)	43,107	198,635	422,693	381,022	406,415	367,972							1,819,844
18. ANOHR (BTU/KWH)	10,253.1	10,281.5	9,976.8	10,065.9	9,954.2	10,099.5							10,055.0
19. NOF (%)	80.61	69.25	80.13	80.09	76.94	71.98							76.37
20. NPC (MW)	710	710	710	710	710	710							710

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA – YEAR 2015

HINES Power Block 1	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	99.50	71.61	0.00	43.94	95.97	100.00							68.43
2. PH	744	672	743	720	744	720							4,343
3. SH	737.1	478.5	0.0	316.3	714.0	720.0							2,966.0
4. RSH	5.2	2.8	0.0	0.0	0.0	0.0							8.0
5. UH	1.6	190.8	743.0	403.7	30.0	0.0							1,369.0
6. POH	0.0	190.8	743.0	392.0	0.0	0.0							1,325.8
7. FOH	0.0	0.0	0.0	11.6	1.0	0.0							12.6
8. MOH	1.6	0.0	0.0	0.0	29.0	0.0							30.6
9. PPOH	1.8	0.0	0.0	0.0	0.0	2.8							4.6
10. LR PP (MW)	66.0	0.0	0.0	0.0	0.0	59.1							61.8
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
13. PMOH	15.3	0.0	0.0	0.0	0.0	0.0							15.3
14. LR PM (MW)	72.0	0.0	0.0	0.0	0.0	0.0							72.0
15. NSC (MW)	528	528	528	462	462	462							528
16. OPER MBTU	2,524,187	1,694,595	0	1,028,254	2,150,728	2,339,254							9,737,018
17. NET GEN (MWH)	338,209	229,988	0	140,888	312,850	310,748							1,332,683
18. ANOHR (BTU/KWH)	7,463.4	7,368.2	0.0	7,298.4	6,874.6	7,527.8							7,306.3
19. NOF (%)	86.90	91.03	0.00	96.40	94.84	93.42							91.88
20. NPC (MW)	528	528	528	462	462	462							528

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA – YEAR 2015

HINES Power Block 2	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	0.00	0.00	0.00	0.00	0.25	47.87							7.98
2. PH	744	672	743	720	744	720							4,343
3. SH	0.0	0.0	0.0	0.0	1.8	344.7							346.5
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	744.0	672.0	743.0	720.0	742.2	375.3							3,996.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	744.0	672.0	743.0	720.0	742.2	375.3							3,996.5
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	2.0							2.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	50.9							50.9
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	563	563	563	490	490	490							563
16. OPER MBTU	0	0	0	0	1,844	1,249,778							1,251,622
17. NET GEN (MWH)	0	0	0	0	0	157,237							157,237
18. ANOHR (BTU/KWH)	0.0	0.0	0.0	0.0	0.0	7,948.4							7,960.1
19. NOF (%)	0.00	0.00	0.00	0.00	0.00	93.10							92.18
20. NPC (MW)	563	563	563	490	490	490							563

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2015

HINES Power Block 3	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	97.81	100.00	100.00	59.68	68.07	100.00							87.47
2. PH	744	672	743	720	744	720							4,343
3. SH	686.9	672.0	743.0	429.7	506.4	720.0							3,758.1
4. RSH	40.8	0.0	0.0	0.0	0.0	0.0							40.8
5. UH	16.3	0.0	0.0	290.3	237.6	0.0							544.1
6. POH	0.0	0.0	0.0	290.3	207.7	0.0							498.0
7. FOH	16.3	0.0	0.0	0.0	29.9	0.0							46.2
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	0.0	0.0	1.3	0.0	5.5	6.1							12.8
10. LR PP (MW)	0.0	0.0	34.4	0.0	41.3	40.0							40.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	564	564	564	488	488	488							564
16. OPER MBTU	2,324,063	2,343,971	2,594,096	1,459,831	1,712,240	2,334,811							12,769,011
17. NET GEN (MWH)	327,307	336,232	367,462	204,252	224,249	329,233							1,788,735
18. ANOHR (BTU/KWH)	7,100.6	6,971.3	7,059.5	7,147.2	7,635.4	7,091.7							7,138.6
19. NOF (%)	84.48	88.71	87.69	97.40	90.74	93.70							89.72
20. NPC (MW)	564	564	564	488	488	488							564

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2015

HINES Power Block 4	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan - Jun Period
1. EAF	100.00	100.00	100.00	95.40	98.58	99.64							98.94
2. PH	744	672	743	720	744	720							4,343
3. SH	732.4	639.2	743.0	686.9	733.4	698.0							4,232.9
4. RSH	11.6	32.8	0.0	0.0	0.0	20.3							64.7
5. UH	0.0	0.0	0.0	33.1	10.6	1.7							45.4
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	0.0	0.0	0.0	33.1	10.6	1.7							45.4
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	3.2	0.0	1.8	0.0	0.0	7.5							12.4
10. LR PP (MW)	50.2	0.0	41.0	0.0	0.0	30.2							36.8
11. PFOH	0.0	0.0	0.0	0.0	0.0	9.9							9.9
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	44.0							44.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	544	544	544	472	472	472							544
16. OPER MBTU	2,483,314	2,124,343	2,559,465	2,278,724	2,559,512	2,214,581							14,219,939
17. NET GEN (MWH)	359,310	308,121	367,129	319,896	339,415	308,507							2,002,378
18. ANOHR (BTU/KWH)	6,911.3	6,894.5	6,971.6	7,123.3	7,541.0	7,178.4							7,101.5
19. NOF (%)	90.18	88.61	90.83	98.67	98.05	93.64							93.13
20. NPC (MW)	544	544	544	472	472	472							544

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	2/1/2015	FMO	264.80	164.0	HEAT RECOVERY STEAM GENERATOR TO GAS TURBINE CON.
BCC 4A	2/21/2015	FMO	22.27	164.0	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4A	4/6/2015	FFO	22.00	164.0	GAS TURBINE - LUBE OIL SYSTEM - GENERAL
BCC 4A	4/8/2015	FFO	34.00	164.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS
BCC 4A	5/14/2015	PFO	17.00	6.0	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4A	6/23/2015	PFO	8.92	0.5	GAS TURBINE - IGNITION SYSTEM
BCC 4B	1/16/2015	PO	384.25	165.0	GAS TURBINE - LUBE OIL SYSTEM - GENERAL
BCC 4B	3/27/2015	FMO	86.07	165.0	TOTAL UNIT PERFORMANCE TESTING
BCC 4B	4/28/2015	FFO	11.00	165.0	GENERATOR VOLTAGE CONTROL
BCC 4B	5/4/2015	FFO	10.00	165.0	PILOT FUEL NOZZLES/VANES
BCC 4B	5/14/2015	PFO	17.00	6.0	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4B	6/22/2015	FFO	3.17	165.0	GAS TURBINE - COOLING AND SEAL AIR SYSTEM
BCC 4C	3/8/2015	FMO	285.60	167.0	GAS TURBINE - DIVERTER DAMPERS
BCC 4C	3/20/2015	FMO	7.35	167.0	GAS TURBINE - CONTROLS AND INSTRUMENTS
BCC 4C	3/22/2015	FMO	136.57	167.0	GAS TURBINE - DIVERTER DAMPERS
BCC 4C	4/15/2015	PPO	23.00	1.0	FEEDWATER PIPING DOWNSTRM OF FEEDWTR REG. VALVE
BCC 4C	4/16/2015	PMO	22.00	27.0	EMERGENCY GENERATOR TRIP DEVICES
BCC 4C	5/14/2015	PFO	17.00	1.0	CIRCULATING WATER PRIMING SYSTEM
BCC 4C	5/15/2015	FMO	8.50	167.0	OTHER CLOSED COOLING WATER SYSTEM PROBLEMS
BCC 4C	5/26/2015	FMO	85.92	167.0	CLOSED COOLING WATER HEAT EXCHANGERS
BCC 4C	6/18/2015	FFO	1.05	167.0	OPERATOR ERROR
BCC 4D	3/20/2015	FMO	132.82	163.0	GAS TURBINE - BOROSCOPE INSPECTION
BCC 4D	4/6/2015	FFO	16.00	163.0	GAS TURBINE - LUBE OIL SYSTEM - GENERAL
BCC 4D	5/14/2015	PFO	17.00	6.0	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4D	5/16/2015	FMO	3.65	163.0	CLOSED COOLING WATER INSTRUMENTATION
BCC 4S	1/16/2015	FMO	9.23	417.0	TURBINE OVERSPEED TRIP TEST
BCC 4S	3/8/2015	PO	621.77	417.0	OTHER COMBINED CYCLE PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4S	4/3/2015	PO	160.25	417.0	OTHER COMBINED CYCLE PROBLEMS
BCC 4S	5/4/2015	PFO	10.00	144.5	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
BCC 4S	5/4/2015	PFO	34.52	144.5	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
BCC 4S	5/5/2015	PFO	51.25	144.5	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
BCC 4S	5/14/2015	PFO	17.00	144.5	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4S	5/15/2015	PFO	8.00	144.5	GAS TURBINE - CONTROLS AND INSTRUMENTS
BCC 4S	5/16/2015	PMO	3.65	144.5	GAS TURBINE - CONTROLS AND INSTRUMENTS
BCC 4S	5/26/2015	PMO	85.92	144.5	GAS TURBINE - LUBE OIL COOLERS
BCC 4S	6/11/2015	FMO	32.08	417.0	OTHER COMBINED CYCLE PROBLEMS
BCC 4S	6/18/2015	PFO	4.00	305.5	HEAT RECOVERY STEAM GENERATOR TO GAS TURBINE CON..
BCC 4S	6/18/2015	PFO	1.05	144.6	CONDENSATE/HOTWELL PUMPS
BCC 4S	6/22/2015	PFO	3.00	144.6	OTHER GAS TURBINE AUXILIARY SYSTEM PROBLEMS
BCC 4S	6/23/2015	PFO	7.85	144.5	UNIT AUXILIARIES TRANSFORMER
BCC 4S	6/23/2015	PFO	1.92	144.4	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
BCC 4S	6/24/2015	PFO	17.00	120.5	COMBINED CYCLE INSTRUMENTS AND CONTROLS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/1/2015	PMO	10.50	93.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
1/2/2015	FMO	69.08	712.0	PLATEN SUPERHEATER LEAKS
2/3/2015	PFO	3.33	54.9	CIRCULATING WATER PUMP MOTORS
2/20/2015	PFO	7.92	93.0	PULVERIZER FEEDERS
2/24/2015	PMO	1.48	93.1	PULVERIZER MILLS
2/25/2015	PFO	6.17	473.9	PULVERIZER MILLS
3/17/2015	PMO	4.00	259.0	CEMS - CERTIFICATION AND RECERTIFICATION
3/18/2015	PMO	5.35	474.0	CEMS - CERTIFICATION AND RECERTIFICATION
3/19/2015	PMO	3.88	259.1	CEMS - CERTIFICATION AND RECERTIFICATION
3/20/2015	PMO	4.95	73.9	CEMS - CERTIFICATION AND RECERTIFICATION
3/23/2015	PFO	2.00	473.8	COAL CONVEYERS AND FEEDERS
3/24/2015	PFO	8.25	93.0	PULVERIZER FEEDERS
4/7/2015	PMO	6.18	284.0	FORCED DRAFT FANS
4/8/2015	PMO	7.95	284.0	FORCED DRAFT FANS
4/9/2015	PFO	17.60	331.0	FEEDWATER BOOSTER PUMP
4/20/2015	PMO	24.05	65.0	PULVERIZER MILLS
4/21/2015	PMO	10.25	65.0	PULVERIZER MILLS
4/22/2015	PFO	2.08	379.1	COAL CONVEYERS AND FEEDERS
4/22/2015	PMO	24.05	65.0	PULVERIZER MILLS
4/28/2015	PMO	25.80	65.0	PULVERIZER MILLS
4/29/2015	PMO	29.75	65.0	PULVERIZER MILLS
5/1/2015	PMO	6.00	65.0	PULVERIZER MILLS
5/4/2015	PMO	7.12	236.0	CLOSED COOLING WATER HEAT EXCHANGERS
5/6/2015	PMO	7.50	236.0	CLOSED COOLING WATER HEAT EXCHANGERS
5/12/2015	PMO	8.72	284.0	CONDENSATE/HOTWELL PUMPS
5/13/2015	PMO	6.70	283.9	CONDENSATE/HOTWELL PUMPS
5/14/2015	PMO	202.70	65.0	PULVERIZER MILLS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
5/28/2015	FMO	51.05	712.0	INDUCED DRAFT FANS
6/11/2015	PFO	4.75	65.1	COAL CONVEYERS AND FEEDERS
6/17/2015	PMO	18.00	27.0	CONVECTION PASS WALL LEAKS (WATER TUBES ONLY)
6/18/2015	PMO	15.98	141.0	CONVECTION PASS WALL LEAKS (WATER TUBES ONLY)
6/19/2015	FMO	38.22	712.0	CONVECTION PASS WALL LEAKS (WATER TUBES ONLY)
6/24/2015	PFO	3.50	702.0	COMBUSTION/STEAM CONDITION CONTROLS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
2/25/2015	PMO	3.67	472.0	GENERATOR LIQUID COOLING SYSTEM
3/17/2015	PMO	7.18	63.0	CIRCULATING WATER PUMPS
3/18/2015	PMO	0.38	63.0	CIRCULATING WATER PUMPS
3/18/2015	PMO	8.90	234.0	FORCED DRAFT FANS
3/19/2015	PMO	7.75	234.0	FORCED DRAFT FANS
3/26/2015	PFO	5.78	91.0	FOREIGN OBJECT IN MILL
3/29/2015	PFO	11.23	91.0	PULVERIZER MILLS
3/31/2015	PMO	0.65	63.4	CIRCULATING WATER PUMPS
4/1/2015	PMO	6.67	63.0	CIRCULATING WATER PUMPS
4/1/2015	PFO	6.55	91.1	PULVERIZER FIRES
4/1/2015	PMO	2.23	90.9	PULVERIZER MILLS
4/1/2015	PMO	6.97	63.0	CIRCULATING WATER PUMPS
4/7/2015	PMO	7.68	91.0	PULVERIZER MILLS
4/7/2015	PMO	11.80	91.0	PULVERIZER MILLS
4/8/2015	PMO	7.57	91.0	PULVERIZER MOTORS AND DRIVES
4/9/2015	PFO	16.92	91.0	OTHER HIGH PRESSURE HEATER PROBLEMS
4/12/2015	FFO	31.37	710.0	SWITCHYARD CIRCUIT BREAKERS
4/13/2015	FFO	18.55	710.0	SWITCHYARD CIRCUIT BREAKERS
4/18/2015	PFO	2.63	63.1	PULVERIZER FEEDERS
4/19/2015	PFO	1.38	90.9	PULVERIZER FEEDERS
4/19/2015	PFO	0.80	91.4	PULVERIZER FEEDERS
4/28/2015	PMO	10.05	63.0	PULVERIZER MILLS
5/7/2015	PMO	8.45	410.0	CIRCULATING WATER PIPING
5/8/2015	PMO	7.50	234.0	CLOSED COOLING WATER HEAT EXCHANGERS
5/9/2015	PMO	6.00	233.9	CLOSED COOLING WATER HEAT EXCHANGERS
5/12/2015	PMO	5.03	91.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
5/18/2015	PMO	2.67	63.1	PULVERIZER FEEDERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
5/19/2015	PMO	4.00	63.0	PULVERIZER FEEDERS
5/20/2015	PMO	3.00	63.0	PULVERIZER FEEDERS
5/21/2015	PMO	28.62	186.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
6/4/2015	PMO	5.63	186.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
6/4/2015	PMO	21.58	63.0	OTHER PULVERIZER PROBLEMS
6/11/2015	PMO	2.75	63.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
6/18/2015	PMO	3.65	63.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1A	1/1/2015	PPO	1.80	66.0	INTAKE GRATING FOULING
HEP 1A	2/21/2015	PO	1314.92	151.0	GAS TURBINE - HIGH PRESSURE TURBINE SHAFT
HEP 1A	4/17/2015	FFO	12.42	151.0	TURBINE SUPERVISORY SYSTEM
HEP 1A	5/16/2015	FMO	88.67	151.0	GAS TURBINE - LUBE OIL COOLERS
HEP 1A	6/6/2015	PPO	1.83	64.0	INTAKE GRATING FOULING
HEP 1A	6/30/2015	PPO	1.00	64.0	INTAKE GRATING FOULING
HEP 1B	1/1/2015	PPO	1.80	66.0	INTAKE GRATING FOULING
HEP 1B	1/12/2015	FMO	5.00	151.0	OTHER LP STEAM SYSTEM PROBLEMS
HEP 1B	2/21/2015	PO	1339.33	151.0	GAS TURBINE - HIGH PRESSURE TURBINE SHAFT
HEP 1B	4/17/2015	FFO	4.98	151.0	BLADE PATH TEMPERATURE SPREAD
HEP 1B	5/12/2015	FFO	3.00	151.0	SERVICE AIR COMPRESSORS
HEP 1B	6/6/2015	PPO	1.83	65.0	INTAKE GRATING FOULING
HEP 1B	6/30/2015	PPO	1.00	64.0	INTAKE GRATING FOULING
HEP ST1	1/1/2015	PPO	1.80	66.0	INTAKE GRATING FOULING
HEP ST1	1/11/2015	PMO	44.08	72.0	OTHER LOW PRESSURE TURBINE PROBLEMS
HEP ST1	2/21/2015	PO	1323.22	160.0	INSPECTION
HEP ST1	4/17/2015	FFO	17.20	160.0	TURBINE SUPERVISORY SYSTEM
HEP ST1	6/6/2015	PPO	1.83	50.0	INTAKE GRATING FOULING
HEP ST1	6/30/2015	PPO	1.00	47.0	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Hines Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 2A	1/1/2015	FFO	3563.92	154.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP 2A	5/29/2015	FFO	18.50	154.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP 2A	5/30/2015	FFO	252.22	154.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP 2A	6/9/2015	FFO	2.40	154.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 2A	6/10/2015	FFO	81.70	154.0	OTHER HP STEAM VALVES
HEP 2A	6/13/2015	FFO	11.58	154.0	DESUPERHATER/ATTEMPERATOR INSTRUMENTS (NOT LOCAL)
HEP 2A	6/16/2015	FFO	25.33	154.0	CONDENSATE/HOTWELL PUMPS
HEP 2A	6/18/2015	FFO	8.83	154.0	OTHER INTERMEDIATE PRESSURE TURBINE PROBLEMS
HEP 2A	6/22/2015	PPO	2.00	55.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG; ZEBRA MUSSELS)
HEP 2B	1/1/2015	FFO	3518.42	154.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP 2B	5/27/2015	FFO	309.05	154.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP 2B	6/9/2015	FFO	21.53	154.0	HP DRUM
HEP 2B	6/10/2015	FFO	21.32	154.0	OTHER MAIN STEAM VALVES (INCLUDING VENT AND DRAIN.
HEP 2B	6/11/2015	FFO	1.00	154.0	CONDENSATE/HOTWELL PUMP MOTOR
HEP 2B	6/11/2015	FFO	62.33	154.0	CONDENSATE SYSTEM CONTROLS AND INSTRUMENTATION
HEP 2B	6/14/2015	FFO	10.25	154.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 2B	6/16/2015	FFO	24.50	154.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 2B	6/18/2015	FFO	8.93	154.0	OTHER INTERMEDIATE PRESSURE TURBINE PROBLEMS
HEP 2B	6/22/2015	PPO	2.00	55.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP ST2	1/1/2015	FFO	4023.87	182.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
HEP ST2	6/17/2015	FFO	15.95	182.0	OTHER INTERMEDIATE PRESSURE TURBINE PROBLEMS
HEP ST2	6/22/2015	PPO	2.00	44.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	1/20/2015	FFO	6.47	155.0	GENERATOR VOLTAGE SUPPLY SYSTEM
HEP 3A	1/27/2015	FFO	6.75	155.0	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 3A	1/28/2015	FFO	5.50	155.0	GAS TURBINE VIBRATION
HEP 3A	3/29/2015	PPO	1.25	37.0	CONDENSER TUBE SHEET FOULING
HEP 3A	4/18/2015	PO	490.28	155.0	GAS TURBINE - BOROSCOPE INSPECTION
HEP 3A	5/9/2015	FFO	15.42	155.0	START-UP FEEDWATER PUMP
HEP 3A	5/10/2015	FFO	0.25	155.0	START-UP FEEDWATER PUMP
HEP 3A	5/23/2015	PPO	5.50	42.0	INTAKE GRATING FOULING
HEP 3A	6/4/2015	PPO	6.08	49.0	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3B	1/20/2015	FFO	6.42	155.0	GENERATOR VOLTAGE SUPPLY SYSTEM
HEP 3B	1/27/2015	FFO	2.57	155.0	FEEDWATER PUMP
HEP 3B	1/27/2015	FFO	4.45	155.0	FEEDWATER PUMP
HEP 3B	3/29/2015	PPO	1.25	37.0	CONDENSER TUBE SHEET FOULING
HEP 3B	4/18/2015	PO	492.22	155.0	GAS TURBINE - BOROSCOPE INSPECTION
HEP 3B	5/9/2015	FFO	0.25	155.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 3B	5/9/2015	FFO	24.25	155.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 3B	5/10/2015	FFO	31.67	155.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 3B	5/12/2015	FFO	2.17	155.0	BLADE PATH TEMPERATURE SPREAD
HEP 3B	5/12/2015	FFO	20.08	155.0	NOX STACK EMISSIONS - GAS TURBINE UNITS
HEP 3B	5/23/2015	PPO	5.50	42.0	INTAKE GRATING FOULING
HEP 3B	6/4/2015	PPO	6.08	48.0	CONDENSER TUBE AND WATER BOX CLEANING
HEP ST3	1/20/2015	FFO	6.45	178.0	GENERATOR VOLTAGE SUPPLY SYSTEM
HEP ST3	1/27/2015	FFO	10.15	178.0	FEEDWATER PUMP
HEP ST3	3/29/2015	PPO	1.25	30.0	CONDENSER TUBE SHEET FOULING
HEP ST3	4/18/2015	PO	509.67	178.0	INSPECTION
HEP ST3	5/23/2015	PPO	5.50	40.0	INTAKE GRATING FOULING
HEP ST3	6/4/2015	PPO	6.08	25.0	CONDENSER TUBE AND WATER BOX CLEANING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	1/1/2015	PPO	0.95	52.9	INTAKE GRATING FOULING
HEP 4A	1/10/2015	PPO	1.17	48.0	INTAKE GRATING FOULING
HEP 4A	1/22/2015	PPO	1.08	53.0	INTAKE GRATING FOULING
HEP 4A	3/28/2015	PPO	1.75	45.0	CONDENSER TUBE SHEET FOULING
HEP 4A	4/19/2015	FFO	2.80	151.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP 4A	4/19/2015	FFO	29.62	151.0	OTHER TURBINE VALVES
HEP 4A	4/21/2015	FFO	1.12	151.0	TURBINE SUPERVISORY SYSTEM
HEP 4A	4/21/2015	FFO	1.12	151.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 4A	5/4/2015	FFO	17.08	151.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP 4A	6/20/2015	PPO	5.00	38.0	GAS TURBINE PERFORMANCE TESTING - INDIVID. ENGINES
HEP 4A	6/20/2015	PFO	6.00	38.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP 4A	6/21/2015	PFO	5.25	38.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP 4B	1/1/2015	PPO	0.95	52.9	INTAKE GRATING FOULING
HEP 4B	1/10/2015	PPO	1.17	48.0	INTAKE GRATING FOULING
HEP 4B	1/22/2015	PPO	1.08	53.0	INTAKE GRATING FOULING
HEP 4B	3/28/2015	PPO	1.75	47.0	CONDENSER TUBE SHEET FOULING
HEP 4B	4/19/2015	FFO	2.80	151.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP 4B	4/19/2015	FFO	29.62	151.0	OTHER TURBINE VALVES
HEP 4B	5/4/2015	FFO	7.50	151.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP 4B	6/7/2015	FFO	3.17	151.0	OTHER GAS TURBINE EXHAUST PROBLEMS
HEP 4B	6/14/2015	FFO	2.08	151.0	OTHER GAS TURBINE EXHAUST PROBLEMS
HEP 4B	6/20/2015	PFO	5.00	38.0	GAS TURBINE PERFORMANCE TESTING - INDIVID. ENGINES
HEP 4B	6/20/2015	PFO	6.00	38.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP 4B	6/21/2015	PFO	5.25	38.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP ST4	1/1/2015	PPO	0.93	46.1	INTAKE GRATING FOULING
HEP ST4	1/10/2015	PPO	1.17	52.0	INTAKE GRATING FOULING
HEP ST4	1/22/2015	PPO	1.08	46.0	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2015

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST4	3/28/2015	PPO	1.75	32.0	CONDENSER TUBE SHEET FOULING
HEP ST4	4/19/2015	FFO	2.80	170.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP ST4	4/19/2015	FFO	29.62	170.0	OTHER TURBINE VALVES
HEP ST4	5/4/2015	FFO	7.50	170.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP ST4	6/7/2015	PFO	3.17	90.0	OTHER GAS TURBINE EXHAUST PROBLEMS
HEP ST4	6/20/2015	PPO	5.00	28.0	GAS TURBINE PERFORMANCE TESTING - INDIVID. ENGINES
HEP ST4	6/20/2015	PPO	6.00	28.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)
HEP ST4	6/21/2015	PPO	5.25	28.0	CIRCULATING WATER BIOLOGICAL CONDITIONS (EG, ZEBRA MUSSELS)