FILED SEP 08, 2015 DOCUMENT NO. 05581-15 FPSC - COMMISSION CLERK



Hublic Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: September 8, 2015

- TO: Carlotta S. Stauffer, Commission Clerk, Office of Commission Clerk
- **FROM:** Kelley F. Corbari, Senior Attorney, Office of the General Counsel
- **RE: Docket No. 140219-WU** Application for staff-assisted rate case in Polk County by Alturas Utilities, LLC.

Attached please find a copy of correspondence received from Alturas Utilities, LLC in regard to the above-referenced docket file. Please file the attached correspondence in the <u>documents</u> tab of the docket file.

Thank you for your assistance in this matter. Should you have any questions, please do not hesitate to contact me.

KFC

Kelley Corbari

From:	L SZABO <l.szabo@rogers.com></l.szabo@rogers.com>
Sent:	Tuesday, September 08, 2015 9:12 AM
То:	Kelley Corbari
Cc:	l.szabo@rogers.com
Subject:	Alturas meter test
Attachments:	Alturas meter test.xls

Good Morning Ms. Kelley,

I hope you had a chance to relax and enjoy the Labor Day weekend.

I have just realized I did not send you the result of the FRWA Alturas meter test.

Regards,

Leslie Szabo

FLOW METER ACCURACY RECORD FLORIDA RURAL WATER ASSOCIATION 2970 WELLINGTON CR. W. STE. 101 TALLAHASSEE, FLORIDA 32308

SYSTEM NAME: SYSTEM ADDRESS:	Altururs Utilities	County:	Polk		
SITE CONTACT/PHO	DNE Wiley Pratt	Phone:	863-651-0259	•	
PWS. ID #	6530057	LOCATION	Water Plant		
Test performed @	GPM	PUMP INFO	POE		
METER MODEL:	Water Specialties	SERIAL NUMBER ON	METER: 901123		
	aterial <u>4" Galvanized Pipe Se</u>		_		
DISCHARGE PIPE D	IAMETER: od / wt WT 4.50	00 / OD 0.237			
Transducer Spacing	3.150 inchs				
Transducer distance fr	om meter upstream/downstream	$1^{*} - 1^{*}$			
METHOD OR EQUIP	MENT USED FOR TEST:	Fuji			
DATE OF THIS MET	ER TEST: 8/25/2015				
INITIAL MET	TER READING AT START OF TEST	Γ: 37226900			
FINAL M	ETER READING AT END OF TEST	г: 37227300	Total Gals. 400		
INITIAL READIN	G ON CALIBRATED TEST METER	R:			
	G ON CALIBRATED TEST METER		Total Gals. <u>331</u>		
AVERAGE % OF ERROR BETWEEN FLOWMETER TESTED AND CALIBRATED TEST METER: 20.8 %					
COMMENTS: Meters need	d to be repairded or replaced if the meter is	10 % + or - between flowmeter tea	isted and Calibrated test mete	нГ	
NAME OF PERSON CO COMPANY NAME: DAYTIME TELEPHON	PMPLETING TEST/ FORM: FLORIDA RURAL WATER ASSOCI E: <u>(850)668-2746</u>	······	_		
SIGNATURE: Moises V	'illalpando	DATE:	8/25/2015		