



STATE OF FLORIDA PERMIT APPLICATION TO CONSTRUCT, REPAIR, MODIFY, OR ABANDON A WELL.

- Southwest
Northwest
St. Johns River
South Florida
Suwannee River

THIS FORM MUST BE FILLED OUT COMPLETELY.


The water well contractor is responsible for completing this form and forwarding the permit to the appropriate delegated county where applicable.

CHECK BOX FOR APPROPRIATE DISTRICT. ADDRESS ON BACK OF PERMIT FORM.

Permit No. P200901409-12
Florida Unique I.D.
Permit Stipulations Required (See attached) See attached.
62-524 Quad #
Delineation #
CUP/WUP Application No.
ABOVE THIS LINE FOR OFFICIAL USE ONLY

C4

1. RMS Timberlands LLC, 14E Quince Rd, Canavert FL 32533 587-2113
2. Camp Road S.W. corner of Intersection w/ Bratt Rd. Century, FL
3. Francis Xavier Harrington 7262
Well Drilling Contractor License No. Telephone No.
1985 Cape Lane Address
Pensacola FL 32526 City State Zip
4. NE 1/4 of NE 1/4 of Section 19
5. Township 5N Range 31W




7. Number of proposed wells 4 Check the use of well: Domestic Monitor (type) Groundwater
Irrigation (type) Public Water Supply (type) List Other
Distance from septic system 7500 ft. Description of facility Vacant land Estimated start of construction date 6/2/09

8. Application for: New Construction Repair/Modify Abandonment
9. Estimated: Well Depth 50' Casing Depth 40' Screen Interval from 40 to 50
Casing Material: Blk-Steel / Gal / PVC Casing Diameter 2" Seal Material Fine Sand
10. If applicable: Proposed From 38 to 0 Seal Material Neat Cement
Grouting Interval From to Seal Material



11. Telescoping Casing or Liner (check one) Diameter
Blk-Steel / Galvanized / PVC Other (specify):
12. Method of Construction: Rotary Cable Tool Combination
Auger Other (specify):
13. Indicate total No. of wells on site 4 List number of unused wells on site 0
14. Is this well or any other well or water withdrawal on the owner's contiguous property covered under a Consumptive Water Use Permit (CUP/WUP) or CUP/WUP Application? No Yes
District well I.D. No.
Latitude 30.5607192 Longitude -87.2242219 GIS
Data obtained from GPS or map or survey (map datum NAD 27 NAD 83)



15. I hereby certify that I will comply with the applicable rules of Title 40, Florida Administrative Code, and that a water use permit or artificial recharge permit, if needed, has been or will be obtained prior to commencement of well construction. I further certify that all information provided on this application is accurate and that I will obtain necessary approval from other federal, state, or local governments, if applicable. I agree to provide a well completion report to the District within 30 days after drilling or the permit expiration, whichever occurs first.
Francis Xavier Harrington 7262 Signature of Contractor License No.
Paul [Signature] 5/29/09 Owner's or Agent's Signature Date

Approval Granted By: Yanni A. Abdau Issue Date: 5/29/09 Hydrologist Approval
Owner Number: Act # 121730000 Fee Received: \$ Receipt No.: 1335 Check No.: e-pay

THIS PERMIT NOT VALID UNTIL PROPERLY SIGNED BY AN AUTHORIZED OFFICER OR REPRESENTATIVE OF THE WMD. IT SHALL BE AVAILABLE AT THE WELL SITE DURING ALL DRILLING OPERATIONS. This permit is valid for 90 days from date of issue.

Hold at this area in front of meter address is visible through envelope window

Century, FL 32535

3

## SPECIFIC CONDITIONS

Well Permit No.: P200901409-12

In accordance with Section 40A-3.301 of the Florida Administrative Code (FAC), Northwest Florida Water Management District (NFWFMD) places the following specific conditions permit for this well:

1. As per Section 40A-3.517 (4), FAC, or Section 40A-3.531, FAC, the grout introduced into this well for the purpose of grouting casing or plugging of the well shall consist of a neat Portland cement grout consisting of a mixture of no more that six (6) gallons of water per 94 pound bag of Portland cement. **Bentonite shall not be used, under any circumstances, as an alternative material for the purpose of grouting a well. NFWFMD regulations prohibit the use of bentonite within NFWFMD jurisdictional boundaries.**
2. **If well point is temporary, the contractor must obtain an abandonment permit and the point must be properly plugged and abandoned within 24 hours of completion of construction.**