

Utilities, Inc. of Florida  
 Docket No. 160101-WS  
 Re: Staff's 6th ROGs, No. 162  
 Bear Lake disinfection byproducts data

**Data table provided by Walt Trierweiler, 2/8/2017**

Name	MCL	Units	MFR's	MFR's	UIF Response
			8/10/2016	8/10/2016	8/15/2015
Total Haloacetic Acids (HAA5)	60	ug/L	46.3	16.9	124
Total Trihalomethanes (TTHM)	80	ug/L	81.3	73.5	52

**Data table generated by Patrick Flynn, 2/9/2017**

**Sample location #1: 3701 Anna Drive**

Name	MCL	Units	Analysis Results	MFR's		UIF Response
				8/10/2016	8/10/2016	8/15/2015
Total Haloacetic Acids (HAA5)	60	ug/L	46.3	46.3	28.9	124
Total Trihalomethanes (TTHM)	80	ug/L	81.3	81.3	54.7	52

**Sample location #2: 1207 Alton Drive**

Name	MCL	Units	Analysis Results	MFR's		UIF Response
				8/10/2016	8/10/2016	8/15/2015
Total Haloacetic Acids (HAA5)	60	ug/L	46.9	46.9	31.5	112
Total Trihalomethanes (TTHM)	80	ug/L	73.5	73.5	57.3	71.7

LQAvg: Locational Quarterly Average value

LRAA: Locational Running Annual Average