



Florida Department of Environmental Protection

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

January 20, 2017

Patrick C. Flynn
Vice President of Operations
Utilities, Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714-4027
Ph: (866) 842-8432, x1359
pcflynn@uiwater.com

Re: Secondary Contaminants (Revised – Original letter sent July 10, 2015)
Lake Tarpon MHP
PWS-ID No. 6521000
Pinellas County

Dear Mr. Flynn:

The Department is in receipt of Secondary contaminant analysis results for samples collected on January 21, 2015, for the referenced water system. Review of these results show Manganese exceeded the Maximum Contaminant Level. No action, in response to the exceedance, will be required at this time.

Please be advised that the Department may, in the future, require follow-up action in the form of increased monitoring and/or water treatment plant modification if the degree of the exceedance, or customer complaints, warrant.

If you have any questions, please contact me at (813) 470-5784 or via e-mail at Gerald.Foster@DEP.state.fl.us

Sincerely,

A handwritten signature in blue ink that reads "Gerald B. Foster".

Gerald B. Foster
Environmental Consultant
Compliance Assurance Program
FDEP - Southwest District