

Utilities, Inc. of Florida

Docket No. 160101-WS

Prepared March 16, 2017

PCU Interconnection placed into service on December 21, 2016

	Total Pumped (mg)	Main and Hydrant Flushing	Flushing Water %
January 2016	5.666	2.198	39%
February	5.667	2.864	51%
March	6.114	3.363	55%
April	4.089	1.433	35%
May	3.967	1.429	36%
June	2.737	0.712	26%
July	2.919	0.608	21%
August	2.968	0.654	22%
September	2.842	0.626	22%
October	3.600	0.872	24%
November	3.596	0.992	28%
December*	2.476	1.571	63%
Annual Total	46.640	17.324	37%

	Total Purchased (mg)	Main / Hydrant Flushing (mg)	Flushing Water %
January 2017	14.657	11.718	80%
February	11.330	8.178	72%
Annual Total	25.986	19.896	77%

NOTE: *Flushing activity expanded greatly on 12/27/16 as a result of low chlorine residual values in the distribution system following the change in water source.