

Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Rick Scott
Governor

Celeste Philip, MD, MPH
State Surgeon General

Vision: To be the Healthiest State in the Nation

November 10, 2016

CYPRESS LAKE UTILITIES INC
PWS: Id. No. 6535055

RECEIVED
NOV 17 2016

UTILITIES INC. OF FLORIDA
200 WEATHERSFIELD AVENUE
ALTAMONTE SPRINGS, FL 32714

Dear Water System Owner:

A sanitary survey of your system conducted on November 10, 2016 indicates that the system is substantially in compliance with the public drinking water requirements listed in Chapter 62 Florida Administrative Code.

If you have any questions, please contact me at (863) 519-8330 ext. 2021.

Sincerely,

Henry Taghiof
Engineer III

**Florida Department of Health
in Polk County**
ENVIRONMENTAL ENGINEERING
2090 East Clower Street • Bartow, FL 33830-6741
PHONE: (863) 519-8330 • FAX: (863) 534-0245
www.MyPolkHealth.org



www.FloridaHealth.gov
TWITTER: HealthyFLA
FACEBOOK: FLDepartmentofHealth
YOUTUBE: fldoh
FLICKR: HealthyFla
PINTEREST: HealthyFla

Florida Health: the first accredited public health system in the U.S.

1901



Florida Department of Environmental Protection

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, Florida 33637-0926

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

June 10, 2016

Patrick Flynn, VP of Operations
Utilities, Inc. of Florida
200 Weathersfield Ave.
Altamonte Spring, FL 32714
pcflyn@uiwater.com

Re: Sanitary Survey
Forest Lake Estates
PWS ID #: 651-4842
Pasco County

Dear Mr. Flynn:

Department personnel conducted a Sanitary Survey of the above-referenced facility on May 31, 2016. Based on the information provided during and following the inspection, the facility was determined to be in compliance. Any non-compliance items which may have been identified at the time of the inspection have been corrected.

The Department appreciates your efforts to maintain this facility in compliance with state rules. Should you have any questions or comments, please contact Rose Taylor at (813) 470-5781, or via e-mail at rose.taylor@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink, appearing to read "J S Brock".

James S. Brock
Government Operations Consultant
Southwest District
Florida Department of Environmental Protection

JB/rt

ec: Lee Neal, Utilities Inc. of Florida, wln@uiwater.com
Rob Buono, Utilities Inc. of Florida, rabuono@uiwater.com



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803-3767

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

JONATHAN P. STEVERSON
SECRETARY

May 20, 2015

Mr. Patrick Flynn, Vice President
Lake Utility Services, Inc.
200 Weathersfield Avenue
Altamonte Springs, FL 32714
PCFlynn@UIWater.com

Re: Lake Utility Services
PW Facility ID #3354883
Lake County
SPCD-CAP-15-4516

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on April 14, 2015. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records, and any non-compliance items which may have been identified at the time of the inspection have been corrected.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Daniel Shideler at 407-897-4133 or via e-mail at Daniel.Shideler@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink that reads 'Danielle Bentzen'.

Danielle Bentzen, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Report (with attachments)

cc: Dominic Gentilucci, DVGentilucci@uiwater.com



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803-3767

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

JONATHAN P. STEVERSON
SECRETARY

May 15, 2015

Mr. Patrick Flynn
Lake Utility Services, Inc.
200 Weathersfield Avenue
Altamonte Springs, FL 32714
PCFlynn@UIWater.com

Re: Lake Utility Services South
PW Facility ID #3354881
Lake County
SPCD-CAP-15-4401

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on April 14, 2015. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records, and any non-compliance items which may have been identified at the time of the inspection have been corrected.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Daniel Shideler at 407-897-4133 or via e-mail at Daniel.Shideler@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink that reads 'Danielle Bentzen'.

Danielle Bentzen, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Report (with attachments)

cc: Dominic Gentilucci - DVGentilucci@uiwater.com



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803-3767

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

JONATHAN P. STEVERSON
SECRETARY

May 15, 2015

Mr. Patrick Flynn
Lake Utility Services, Inc.
200 Weathersfield Avenue
Altamonte Springs, FL 32714
PCFlynn@UIWater.com

Re: Pennbrooke Fairways
PW Facility ID #3354653
Lake County
SPCD-CAP-15-4400

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on April 15, 2015. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records, and any non-compliance items which may have been identified at the time of the inspection have been corrected.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Daniel Shideler at 407-897-4133 or via e-mail at Daniel.Shideler@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink that reads 'Danielle Bentzen'.

Danielle Bentzen, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Report (with attachments)

cc: Dominic Gentilucci, DVGentilucci@uiwater.com



Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

November 17, 2016

Patrick Flynn, Regional Director
Sanlando Utilities/Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, Florida 32714
PCFLYNN@UIWATER.COM

Re: Sanlando Utilities
PW #3591121
Seminole County

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on August 25, 2016. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection form is attached for your records.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Charles Johnson at 407-897-4329 or via e-mail at charles.d.johnson@dep.state.fl.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Reggie Phillips".

Reggie Phillips, Manager
Central District
Florida Department of Environmental Protection

Enclosure: Inspection Report

cc: Scott Gosnell, Area Manager, sgosnell@uiwater.com



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

JONATHAN P. STEVERSON
SECRETARY

January 30, 2015

Patrick C. Flynn, Director
Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
PCFLYNN@UIWATER.COM

Re: Golden Hills Golf & Turf WTP
PW Facility ID # 6424076
Marion County
SPCD-CAP-15-2487

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on December 31, 2014. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Manuel F. Cardona at (407) 897-4134 or via e-mail at Manuel.Cardona@dep.state.fl.us.

Sincerely,

A handwritten signature in black ink that reads 'Gary P. Miller'.

Gary Miller, Manager
Central District
Florida Department of Environmental Protection

Enclosure: Inspection Report

cc: Chuck Schwades, Area Manager [CGSCHWADES@UIWATER.COM]



Florida Department of Environmental Protection

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

September 29, 2016

Patrick Flynn, VP of Operations
Utilities, Inc of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
pcflyn@uiwater.com

Re: Summertree
Facility ID Number: 6511423
Pasco County

Dear Mr. Flynn:

Department personnel conducted a compliance inspection of the above-referenced potable water system on September 27, 2016. Based on Department observations and the information provided during the inspection, the system was determined to be in compliance. A copy of the inspection report is attached for your records.

The Department appreciates your efforts to maintain this system in compliance with state and federal rules. Should you have any questions or comments, please contact Kira Soroka at (813) 470-5964, or via e-mail at: kira.soroka@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink, appearing to read "JSB".

James S. Brock
Government Operations Consultant
Southwest District
Florida Department of Environmental Protection

JSB/ks/

cc: james.brock@dep.state.fl.us
kira.soroka@dep.state.fl.us



Florida Department of Environmental Protection

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Ryan E. Matthews
Interim Secretary

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, Florida 33637-0926

March 10, 2017

Mr. Patrick Flynn
Lake Tarpon Mobile Home Village
PCFLYNN@UIWATER.COM

Re: Lake Tarpon Mobile Home Village Water Treatment Plant
Facility ID Number 652-1000
Pinellas County

Dear Mr. Flynn:

Department personnel conducted a sanitary survey inspection of the above-referenced facility on March 3, 2017. Based on the information provide during and after the inspection, the water system is determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records.

The Department appreciates your efforts to maintain this water system in compliance with state and federal rules. Should you have any questions or comments, please contact Gerald Foster at (813) 470-5784 or via e-mail at: Gerald.Foster@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink, appearing to read "JSB".

James S. Brock
Government Operations Consultant
Compliance Assurance Program
FDEP Southwest District Office



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

July 25, 2014

Patrick C. Flynn, District Manager
Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
pcflyn@uiwater.com

Re: Park Ridge PW facility id #3590993
Phillips Section PW facility id #3591008
Ravenna Park PW facility id #3591061
Seminole County
OCD-CAP-14-3754

Dear Mr. Flynn:

Department personnel conducted inspections of the above-referenced facilities on July 16, 2014. Based on the information provided during and following the inspections, the facilities were determined to be in compliance with the Department's rules and regulations. Copies of the inspection reports are attached for your records.

The Department appreciates your efforts to maintain these facilities in compliance with state and federal rules. Should you have any questions or comments, please contact Chris Rossing at 407-897-4172 or via e-mail at Chris.Rossing@dep.state.fl.us.

Sincerely,

Gary Miller, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Reports

cc: Scott Gosnell, Area Manager, sgosnell@uiwater.com
Kathy Sillitoe, Water Conservation Coordinator, kasillitoe@uiwater.com



Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Ryan E. Matthews
Interim Secretary

March 16, 2017

Patrick C. Flynn, District Manager
Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
pcflyn@uiwater.com

Re: Park Ridge
PW Facility ID #3590993
Seminole County

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on February 14, 2017. Based on the information provided during the inspection, the facility was determined to be in compliance with the Department's rules and regulations.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Brad Whidden at 407-897-4315 or via e-mail at Brad.Whidden@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink that reads "Christine Daniel".

Christine Daniel, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Report

cc: Scott Gosnell, Area Manager, sgosnell@uiwater.com



Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Ryan E. Matthews
Interim Secretary

March 16, 2017

Patrick C. Flynn, District Manager
Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
pcflyn@uiwater.com

Re: Ravenna Park
PW Facility ID #3591061
Seminole County

Dear Mr. Flynn:

Department personnel conducted an inspection of the above-referenced facility on February 14, 2017. Based on the information provided during the inspection, the facility was determined to be in compliance with the Department's rules and regulations.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Brad Whidden at 407-897-4315 or via e-mail at Brad.Whidden@dep.state.fl.us.

Sincerely,

A handwritten signature in blue ink that reads "Christine Daniel".

Christine Daniel, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Report

cc: Scott Gosnell, Area Manager, sgosnell@uiwater.com



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

CENTRAL DISTRICT
3319 MAGUIRE BOULEVARD, SUITE 232
ORLANDO, FLORIDA 32803

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

July 3 2014

Patrick C. Flynn, District Manager
Utilities Inc. of Florida
200 Weathersfield Avenue
Altamonte Springs, FL 32714
pcflynn@uiwater.com

Re: Weathersfield PW facility id #3591451
Oakland Shores PW facility id #3590912
Jansen S/D PW facility id #3590615
Bear Lake Manor PW facility id #3590069
Little Wekiva Estates PW facility id #3590762
Crystal Lake PW facility id #3590258
Seminole County
OCD-CAP-14-3369

Dear Mr. Flynn:

Department personnel conducted inspections of the above-referenced facilities on June 26, 2014. Based on the information provided during and following the inspections, the facilities were determined to be in compliance with the Department's rules and regulations. Copies of the inspection reports are attached for your records.

The Department appreciates your efforts to maintain these facilities in compliance with state and federal rules. Should you have any questions or comments, please contact Chris Rossing at 407-897-4172 or via e-mail at Chris.Rossing@dep.state.fl.us.

Sincerely,

A handwritten signature in black ink, appearing to read 'Gary P. Miller'.

Gary Miller, Manager
Central District
Florida Department of Environmental Protection

Enclosures: Inspection Reports

cc: Scott Gosnell, Area Manager, sgosnell@uiwater.com
Kathy Sillitoe, Water Conservation Coordinator, kasillitoe@uiwater.com

Greenawalt, Ryan

From: Greenawalt, Ryan
Sent: Thursday, January 08, 2015 10:02 AM
To: Patrick Flynn
Cc: Lee Neal; 'Steve Habery'
Subject: Orangewood sanitary survey inspection report
Attachments: 6511311 Orangewood SS; 12-19-2014.pdf

January 8, 2015

Utilities Inc. of Florida
Attn: Patrick Flynn
200 Weathersfield Ave.
Altamonte Springs, FL 32714
pcflyn@uiwater.com

Re: Sanitary Survey Inspection
Orangewood Water System
PWS ID #: 651-1311
Pasco County

Dear Mr. Flynn:

Department personnel conducted a sanitary survey inspection of the above-referenced facility on December 19, 2014. Based on the information provided during and following the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records and any non-compliance items which may have been identified at the time of the inspection have been corrected.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Ryan Greenawalt at (813) 470-5787, or by via e-mail at ryan.greenawalt@dep.state.fl.us.

Ryan J. Greenawalt
Environmental Specialist
Compliance Assurance Program

Florida Dept. of Environmental Protection, Southwest District
13051 N. Telecom Pkwy.
Temple Terrace, FL 33637
New Phone: 813-470-5787 x 45787
New Fax: 813-470-5993
E-mail: Ryan.Greenawalt@dep.state.fl.us

<http://survey.dep.state.fl.us/>



Please consider the environment before printing this email

PLEASE NOTE: Florida has a very broad public records law. Electronic communications regarding state business are public records available upon request. Your e-mail communications may therefore be subject to public disclosure.

