



Kevin I.C. Donaldson
Senior Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5170
(561) 691-7135 (Facsimile)
E-mail: Kevin.Donaldson@fpl.com

October 13, 2017

-VIA ELECTRONIC FILING-

Ms. Carlotta S. Stauffer
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

**RE: Docket No. 20170000-0T
Florida Power & Light Company ("FPL") Form PSC/EAG 13, Exhibit 1 Filing
Concerning Underground Residential Differential Charges**

Dear Ms. Stauffer:

Pursuant to Rule 25-6.078(3), F.A.C., enclosed please find FPL's Form PSC/EAG 13, Exhibit 1, reflecting the updated Overhead vs. Underground Charge Differential for a Low Density 210 Residential Lot Subdivision. As reflected on the enclosed Form, the current cost differential is less than 10% from FPL's last approved URD charge for a low density subdivision. Accordingly, FPL will not be filing an updated written URD policy and supporting data and analyses on or before April 1, 2018.

If there are any questions regarding this transmittal, please contact me at (561) 304-5170.

Sincerely,

/s/ Kevin I.C. Donaldson
Kevin I.C. Donaldson
Fla. Bar No. 0833401

Enclosure
cc: Greg Shafer, Director
Division of Economics

OVERHEAD VS. UNDERGROUND SUMMARY SHEET

Low Density 210 Lot Subdivision
 Cost per Service Lateral

BASE DIFFERENTIAL

<u>ITEM</u>	<u>CURRENT</u>			<u>APPROVED</u>	<u>CHANGE</u>
	<u>OVERHEAD</u>	<u>UNDERGROUND</u>	<u>DIFFERENTIAL</u>	<u>DIFFERENTIAL</u>	
LABOR	\$1,216.24	\$1,457.97	\$241.73	\$227.31	
MATERIAL	\$1,056.07	\$967.92	(\$88.15)	(\$85.96)	
TOTAL	\$2,272.31	\$2,425.89	\$153.58	\$141.35	8.7%

NOTE: BASE DIFFERENTIAL EXCLUDES OPERATIONAL COSTS (STORM & NON-STORM)

ADJUSTED DIFFERENTIAL

	<u>CURRENT</u>	<u>APPROVED</u>	<u>CHANGE</u>
Tier 1 (200 lots or more)	\$0.00	\$0.00	0%
Tier 2 (85 to 199 lots)	\$195.58	\$183.35	6.7%
Tier 3 (less than 85 lots)	\$278.58	\$266.35	4.6%

NOTE: ADJUSTED DIFFERENTIAL INCLUDES OPERATIONAL COSTS (STORM & NON-STORM)