



# RAPID ASSESSMENT OF DAMAGE

Date: 9-11-17 Circuit: Clower Southwest

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
7334	0	1	NO	1	3	N 87	Clower & Coolidge single phase down
9292	0		NO	0	0	N 90	MARIPOSA & De La Palma
NO #	1	2	NO	0	1	N 90	Guy Stub Pole @ P20 De La Palma CTY
9425	0	0	NO	0	0	N 91	Kissimmee & Hermosa Pole leaning switch pole (2 poles involved)
1181	0	0	NO	0	0	N	Pin Broke field phase S. Kissimmee
1186	0	0	NO	0	1	N	Henson Lane Pole leaning 2/3 pole post over broken pole
9	0	1	NO	0	0	N 92	2481 S. Kissimmee 1st Down
8403	0	0	NO	0	0	N 93	2400 Kissimmee Low Hanging Service
365	0	1	NO	0	0	N 94	110 S Broadway single phase down
7730	0	1	NO	0	0	N 94	Valencia & Broadway / Insulator floating
NO #	0	0	NO	0	0	N 95	105 Valencia Ct (limbs on Trans)
1749	1	1	YES	1	1	N 96	across from 965 S. Helen Circle
NO #	1	NO	NO	0	1	N 97	2280 E Helen Circle - leaning / pole behind is broken or leaning because of tree

5 1/2 days Total

Assessor Name: James Starling

Please Print Clearly

James Starling



# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_ Circuit: West Main

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
1298	N	0	0	0	0	0 <sup>100</sup>	pole leaning, Feeds wells Fargo
4439	N	1	0	3	1	Y <sup>101</sup>	concrete pole Top Broke OFF
6211	0	0	0	0	0	N <sup>102</sup>	CUT service To House 245 S Dublex
1333	N	3	1	3	1	N <sup>103</sup>	3 phase Down, also pole 5277. Es affected
6525	N	3	0	3	0	N <sup>104</sup>	Broadway + STEWART
7291	Y	3	0	3	1	N <sup>105</sup>	one pole EAST OF Broadway Top Broke out
5685	N	1	0	1	1	N <sup>106</sup>	STEWART + Wilson Ave, also pole 392
6775	N	1	0	1	1	N <sup>107</sup>	STEWART + FLA
1207	N	1	0	0	1	N <sup>108</sup>	one pole north of STEWART on Fla Ave
7877 390	N	1	0	0	0	N <sup>109</sup>	pole # affected 7877, 390
?	Y	3	1	1	0	N <sup>110</sup>	Behind Adult school on Broadway, Trees Fallen on Ground
9870 9867	N	1	0	1	0	N <sup>111</sup>	Broadway, pole Education Foundation Bldg

} over Job

Assessor Name: Dale Gray, Eddie W.

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/11/17 Circuit: AIR Base

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
12457	Y	3	0	0	0	0 119	3Ø Switch Pole broke at the bottom. 795 wire and solid blades L/A One pole north of Connersville sub
868	N	N	N	N	N	N 113	3Ø in line pole needs to be straightened. 2 poles north of Connersville sub
10409	N	N	N	N	N	N 114	Heavy X Arm pulled over by tree needs to be changed 3 pole East of 91 mine Rd on Gaskin Rd
10730	N	Y	N	N	Y	N 115	Primary has been pulled off insulators due to tree on 3Ø of primary 4 poles East of 91 mine Rd on Gaskin
	N	N	N	N	Y	N 116	limb on 3Ø of primary in front of lot 3 Gaskin Rd
12804	N	Y	yes	yes	Y	N 117	Single Ø pulled off on Thompson Rd voltage off feeder pole on Gaskin
12834	Y	Y 3Ø	N	N	N	N 118	Pole broke at bottom 3 poles south of Gaskin Rd at entrance of Sad Farm 3Ø in line pole 40'
12821	Y	Y 3Ø	N	N	N	N 119	Pole broke at bottom, 2 poles south of Gaskin Rd at entrance of Sad Farm L/A Bank 45'
904	Y	Y 3Ø	N	N	N	N 120	Pole needs to be braced with 1st pole south of Gaskin Rd at entrance of Sad Farm

Assessor Name: Sonny Passolman

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: 9/11/17 Circuit: Air Base

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	y	z	z	z	1	y	Heavy flooding in area
11153	y	y	n	n	n	y 121	Pole broke at bottom 30 in line pole 45' wood NW corner of airbase
11154	y	y	n	n	n	y 122	Pole broke at bottom, 30 in line pole 45' wood NW corner of Air Base
11155	y	y	n	n	n	y 123	Solid blade switch pole broke at bottom, 45' wood NW corner of Airbase Switch # 2415
11156	y	y	n	n	n	y 124	Pole needs to be straightend NW corner of Air base
11157	y	y	n	n	n	y 125	Pole is broke at bottom, 30 in line pole 45' wood NW corner of Air base
11141	y	y	n	n	n	y 126	Pole needs to <del>be</del> be pulled over and tanded its behind Kemira at Airbase
11140	y	y	n	n	n	y 127	Pole needs to be pulled over and refull out wire its behind Kemira At Air base
11110	n	y	n	n	n	n 128	Metal Roofing, is hanging on 30 of Primary 20 has burnt into at 710 mooney st Airbase
11144	n	n	n	n	n	y 129	Pole needs to be pulled over and fiber needs to be re Hung.
1331	n	n	n	n	n	n 130	Pole needs to be pulled over in front of 4002 Echo Ave At Air base
10962	n	n	n	n	n	n 131	Secondary Pole needs to be pulled back over at corner of mooney + Echo
12762	y	y	n	n	n	n 132	Pole is broke at bottom 30 in line pole 45' wood in front of armory at Air base
	n	n	n	n	n	n 133	Neutral is down one span before you turn into the <del>office</del> Shop at the Air base

Assessor Name: Edward Casselman

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: 9/11/17 Circuit: East Main

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
1150						162	810 Orange pole pulled over secondary down
1148						163	secondary damage 1090 Seminole
9456						164	primary neutral down First <sup>primary neutral down</sup> <del>burg</del>
9442						165	Limbon line at Georgia & Swearingen
9443						166	Ø on arm Georgia & Lightsey
9483	1	3			1	167	Kissingen & Belt
1117	Heavy Crossarm		50KVA		1	168	Cross arm broke Transformer Leaking (1185 Kissingen)
9277	✓	3				169	Kissingen & Clower Ø's Est west
9425	✓					170	switch pole leaning at Kissingen & Hermosa

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_ Circuit: East Main

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	4	Heavy flooding in area.
1602					1	150	need open 2 pot Bank, weather head damage (over)
5376						151	Tree limbs on Jackson Blvd
1509						152	Tree limbs on Wilson Davidson
<del>1540</del>							
1540						153	1290 Summerlin service feed down need to isolate
7275						154	1065 Secondary down need to isolate
4081						155	490 S. Jackson service down
3940						156	open cut out Jackson Wabash
1497			X	X		157	Secondary damage 675 S Wilson
1496			1	1		158	25 KVA Bad pot.
7299						159	need to remove Limb from service in alley way
7068						160	790 S. Jackson in alley way limbs on secondary cable
6784						161	Primary neutral down in alleyway 930 Jackson

Assessor Name: \_\_\_\_\_

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_

Circuit: \_\_\_\_\_

60 South - Connersville

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
997	N	0	0	0	limb	N 171	1/2 span south of pole 997 on 91 mile Rd limb on primary
10729 10728	N	1	0	0	1	N 172	Two poles, primary down 91 mile Rd 5 spans north of Gaskin Rd
10730	N	1	0	0	1	N 173	limb on line Gaskin Rd 4 spans EAST of 91 mile Rd
12739	N	0	0	0	1	N 174	limb on line lot 3 Ter. of mobil Home park
?	N	1	1	1	1	N 175	primary down Gaskin + Thompson Rd
1666	N	0	0	0	0	N 176	pole leaning 6141 Hwy 60 EAST
	N	0	0	0	1	N 177	930 80' Rd Tree on line
	Y	3	2	3	0	N 178	7 poles Down 1 span south of Cowp. Rd
	<del>Y</del>	<del>3</del>	<del>0</del>	<del>3</del>	<del>0</del>	<del>N</del>	Two Transformer on the Ground
	Y	3	0	3	0	N 179	3110 80' Rd 3 poles Down
	Y	3	0	0	0	N 180	1 pole Down 2 spans north of ABC Rd
1652	1	1	0	0	1	N 181	Guy stub Broke + 6974 ABC Rd, primary or lateral Down
10151	N	0	0	0	0	N 182	2 poles Down pole leaning ABC Rd

Assessor Name: \_\_\_\_\_

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: 9/16 Circuit: 3970 Gerber Dairy Rd

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
11917							Jumper to cutout for 4G Primary
							pole slightly leaning

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: McLeod - SW Substation

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
288	N	N	Z	N	1	N 183	Service to Holy Trinity Church on Ground
6343	45'	3φ	Z	3	Y	N 184	Stuart + Floral 45' wood, 1000' 4/0 AL, 2XARMS, 2SVCS
<del>1093</del> <del>993</del>	N	3φ	Z	Z	Z	N 185	1110 S Floral 3 chicken wings
6458	N	3φ	Z	Z	Z	N 186	1130 S Floral Leaning pole
6457	N	N	Z	Z	Z	N 187	1160 S. Floral Leaning pole, top chicken wing bent
2247	N	Y	Z	Z	Z	N 188	1190 S Floral, 1φ floating, pole leaning, st Lt damage Telephone down
6488	N	3φ	Z	Z	Z	N 189	3φ on Ground, 3 chicken wings, Telephone down, Neutral - 1290 S. Floral
7991	N	N	Z	Z	Z	N 190	Neutral down, 3 chicken wings 1325 S. Floral
7993	N	3φ	Z	Z	Z	Y 191	3 chicken wings, Fiber, Telephone, CT, SVCS - 1345 S Floral Ave <sup>st Lt wire down</sup>
287	N	N	Z	Z	Z	N 192	Svc to St Light down @ 225 W. Stuart
6467	N	N	Z	Z	Z	N 193	Dudley + Stuart, pole leaning, CT down
6452	N	N	Z	Z	Z	N 194	Leaning pole - 1 span South of Stuart + Dudley
285	N	Z	Z	Z	1	N 195	1185 S Dudley, straight pole, 2XARMS, hardware 2 SVCS down 1 Svc is a 4/0 to church McLeod Pres.

Assessor Name:

James Starling

Please Print Clearly

2



1175 S. Johnson Tree

Orly Tail Taylor  
Circuit Pole  
Pole S. Lakeview

# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: McLeod - SW Substation

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
12741	N	2	2	2	1	N 190	1195 S. Dudley, CTV, Tele down, Suc to <sup>u</sup> 1/2, Pole leaning
290	Y	2	2	2	2	N 197	495 Plumosa - 40' wood, 2 ARMS, 2 $\phi$ Primary, CTV, Tele
6472	N	2	2	2	1	N 195	2 $\phi$ pri down, neutral 485 Plumosa, CTV, Tele
6478	N	2	2	4	N	N 199	455 Plumosa - Pole leaning, 2 $\phi$ down
6780	Y	3	2	2	Y	N 252	695 W Stuart, 40' wood pole, ARM, CTV, Tele 3 $\phi$
283	N	1	2	2	Y	N 251	Single $\phi$ pull off down - Stuart & Irving
100	Y	2	2	2	Y	N 253	710 Garden - 30' wood w/ duplex down
13180	Y	2	2	2	Y	N 254	1085 S. Dudley - 35' wood, 4/0 Suc, CTV, Tele
6334	N	2	2	2	X	N 255	1075 S. Dudley - Leaning pole, Suc down
6352	N	2	2	2	Y	N 256	1045 S. Dudley - Leaning Pole, CTV, Tele
6285	N	2	2	2	2	N 257	815 W. McLeod - Flat braces swinging
5302	N	1	2	2	Y	N 258	865 W. McLeod - 1 $\phi$ Pri down Tele
711	N	2	2	2	2	N 259	2 Pole Leaning 825 W. McLeod rear of

Assessor Name:

James Starling

Please Print Clearly







# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: McLeod - SW Sub.

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
263	N	N	0	0	1	N 263	limb on primary
4939	N	N	0	Z	1	N 264	pulled Jack's limb on primary
264	N	N	N	1	N	N 265	pulled Jack, Dropped service corner of H. HET west & McLeod
4993	N	N	N	N	1	N 266	Two service cables Broke, Behind 1165 S Johnson
7231	N	N	N	1		N 267	STEWART + Mc Adoo
7264	Y	Y	1	1	1	N 268	primary Down, service cable's, corner of McAdoo & McLeod
7267	N	Y	0	0	0	N 269	pulled out of Insulator, south hood lawn
528	N	N	1	1	N	N 270	south' hood lawn
5037	N	Y	0	0	0	N 271	primary OFF Pin, In Front of 540 Phoenix 'A
7005	N	N	0	0	0	N 272	service Is Broke, 700 Azalea
1460	N	Z	0	0	0	N 273	Cross Arm's Broke, corner of sunset & Hooker
6764	Y	1	0	0	1	N 274	pole's Broke, sunset & Garden
2768	Y	1	0	0	1	N 275	pole Broke

6763

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: McLeod - SW Sub

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
7821	<sup>271</sup> N	N	0	0	0	N	Service Broke 745 GRACE CT
7820	<sup>276</sup> N	N	0	0	1	N	Service Broke, 740 SUNSET Dr
7808	<sup>280</sup> N	N	0	0	0	N	limb on line primary tautted, 680 sunset Dr
7974	<sup>278</sup> N	N	0	0	0	N	Service cable Broke, Imperial, 4 westover
345	<sup>279</sup> N	N	1	1	N	N	Transformer on the Ground, pole leaning, service Broke 730 WESTOVER

Assessor Name: \_\_\_\_\_

Please Print Clearly

# RAPID ASSESSMENT OF DAMAGE



Date: 9/12/17 Circuit: Wabash - Odum

Pole #	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area.
6303	N	0	N	N	0	Y 415	Boulevard & First - Fiber
6311	N	Z	N	N	1	Y 416	545 E Boulevard, Fiber, 2 Prim, Neutral, CTV, Tele,
1521	N	Z	N	N	1	Y 417	830 E Boulevard, 2 span Primary, CTV, Tele, down, light XAN M
6292	Y	Z	N	N	1	Y 418	755 E Boulevard & spans Primary Neutral, CTV, Tele,
1468	N	Z	N	N	1	Y 419	NE Corner of Oak & Boulevard, 2 pri, neutral, 37.5 TRANS.
							down Guy, Service down to 500 N OAK.
437A	N	Z	N	N	1	N 420	Pole to p.u. broke out @ 475 N. OAK AVE
4206	N	Z	N	N	1	N 421	585 N OAK Pole leaning, anchor pulled up, pulled down
6313	N	F	N	N	N	N 423	span guy down @ 1020 E. Gay St.
8108	N	1	N	1	1	N 424	Scott/M.L.K. 1Ø down a long Scott.
1072	Y	1	on Ground	1	1	N 425	Golfview/Macon/40 wood pole, 25kva, cut but bracket bent CTV 2-SVCIS down TELE
5781	N	N	N	N	N	N 426	3Ø Line on South Side of Garner bottom of bracket is floating f STAT FST if cable down.

\* Need Timmers 8 days - total

Assessor Name: James Starling

Please Print Clearly



2



1125 E Douglasway

# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: Wabash-Odom

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
5583	N	N	N	N	1	N 427	W Booker & S Tee 2 Sucs down on ground
2084	N	1	Y	Y	N	N 428	930 Tee Circle west - 1 p down on Ground
1413	N	1	Y	Y	N	N 429	Suc down 960 West Tee Circle
2085	N	1	Y	Y	Z	N 430	970 Tee Circle West - 1 p down, broken meter
2086	N	1	Y	Y	Z	N 431	1030 W Tee Circle - blown Arrestor
1414	N	1	N	N	Z	N 432	1040 W Tee Circle - Neutral down, 15kva angled
11905	N	Z	N	N	Z	N 433	1060 W Tee Circle - Pole Leaning 2nd ay down
11904	Y	Z	N	N	N	N 434	1075 W Tee Circle 35' wood pole, Suc Cable 1/2 down, down Guy
1/2 ?	N	Z	N	N	Y	N 435	S spans from 950 Tee Ave Tree on Primary in wooded Area
1/2 9249	Y	N	N	N	Y	N 436	Carver Village #43, 35 Wood pole, Suc Cable on Primary
1/2 2471	N	N	N	N	N	N 437	Spans E. of Hwy 17 on Gibbons, Top out of 45'
							wood pole broke, 3 p bracket on Ground
1/2 8146	N	N	N	N	N	N 438	Service to 1125 S. Virginia

Assessor Name:

James Starling

Please Print Clearly



3



# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: Wabash - Odom

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Z	Heavy flooding in area
8690	N	N	N	N	N	N 439	Pole leaning Secondary down @ 1295 Fairview
9562	N	N	N	N	N	N 440	Secondary down @ 1170 Fairview Ave

1/2

Assessor Name: James Starling  
Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/17 Circuit: Crown

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area.
3901	N	N	N	N	N	N	W is hanging from top of 2 to 3" from middle of At crown & Austin
7652	Y	Y	N	N	N	N	Broke pole out bottom in line 30 in front of 1920 60 west
1434	N	N	N	N	N	N	Broke vertical on transformer pole on service wire single on 60 west
6703	Y <sup>x2</sup>	Yes	N	Y	N	N	2 poles broke single primary & vertical down single on 60 west 4 to 5 span

Assessor Name: Edward Casselman

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/13/17 Circuit: 98 North - Odom

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
4605 <sup>464</sup>	N	N	Z	N	N	N	1050 Park Ave, broke Neutral Svc <sup>TV</sup> pole
* 3622 <sup>465</sup>	N	N	Z	N	N	N	Svc pulled base from pole @ 1730 Taylor Rd.
370 <sup>466</sup>	N	N	Z	Z	N	N	Both fuses blown on Wilson Ave @ Primary

Reds that start pull

Assessor Name: James Starling  
Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/13/17 Circuit: Judicial - Odorn

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	4	Heavy flooding in area
			Nothing		Nothing		

Assessor Name: James Sterling

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: 9/11/17 Circuit: 17 Bottom - 17 South

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
1/2 { 6612	N	N	Z	Z	1	N 134	1920 E Church St - Low Service
6359	N	Y	Z	Z	0	N 135	Single Phase pull off from North St South to Boulevard
1/2 6658	N	N	Z	Z	0	N 136	Restwood & Church / Suc reran Straighten Pole / Comcast span guy down Frontier phone cab down
<del>1 day</del>	<del>Y</del>	<del>N</del>	<del>Z</del>	<del>Z</del>	<del>1</del>	<del>N</del>	<del>35' wood Pole, Pal, CRT, telephone 3 services</del>
1 day 6696	Y	N	Z	Z	Y	N 137	35' wood Pole, Span guy, Suc, TV, Tele Church Boulevard
1 day 7382	Z	Z	Z	Z	Y	N 138	1420 E Seminole Trail - 3-30' wood
1/2 9590	0	N	Z	Z	Y	N 139	1590 E Hooker Street 2 Services down
1/2 7952	N	N	Z	Z	Y	N 140	3 Service under tree in Alleyway across <sup>from</sup> 1365 E. Street
1/2 9165	N	1	Z	1	Y	N 141	1465 Hackel Blvd - 1 φ down & Neutral down
1/2 9716	N	1	Z	N	N	N 142	1420 E Clinton 1 φ & neutral down
1/2 90#	N	N	Z	N	Y	N 143	Lot 109 Suc down on Ground
1/2 { 8656	N	N	Z	N	N	N 144	1685 Hwy 175 Pole leaning 2 Sucs Low
8657	N	N	Z	N	N	N 145	Hwy 175 & Cloner NW Corner Straighten Pole Pole is leaning has flying taps stretched

Total 6 1/2 days

Assessor Name: James Starling  
Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9-11-17 Circuit: Hwy 17 Bottom - 17 South

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
8861	Y	3	N	N	N	Y 14p	45' wood / 2 crossarms / 3 insulators / 3 Jugs / 3 set of bells

Lower  
Cable  
Bumpkins

Assessor Name: James Starling  
Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_ Circuit: 60 EAST - ODOM

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
✓ 474						81	Damage cable need to be isolated over
Tree 5559						82	Tree on line, behind Savannah Ct.
5546		3				83	336 all 3 down at main + Idlewood need wire 1000'
5631						84	Remove moss - long stick
✓ 5019						81	Remove moss -
✓ 5044						81	drop Service weatherhead repair (over)
5105		1					Isolate
5144						85	open cut out Peace River PK Rd.
Tree 10522						86	Limb on primary middle + Road (over)
Line 10503						87	Limb on single φ need to open cut out
Tree 4188						88	Limb on Pole Behind Auto ZONE over

Assessor Name: \_\_\_\_\_

Please Print Clearly





# RAPID ASSESSMENT OF DAMAGE

Date: 9/13/17 Circuit: 17TOP.0Dom

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
			No thing				

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 17 Top - South A

Circuit: \_\_\_\_\_

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	4	Heavy flooding in area.
8267	Y	0	0	0	0	N 400	pole broke 3 spans south Metromat Hwy 17
9815	Y	0	0	0	0	N 401	pole broke 2 spans north of F Austin Phillips Ln
8464	N	0	0	2	0	N 402	Bird Deterrent agst it phase (in area of pole # 8464)
1239	Y	3	0	0	0	N 403	5200 Hwy 17 s pole broke. IS still HOT
	N	1	1	1	1	N 404	2590 Hwy 17 s primary Down

Assessor Name: \_\_\_\_\_



# RAPID ASSESSMENT OF DAMAGE

Date: 9/12/12 Circuit: 17 Top - 17 South A Hornland

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	2	2	2	1	Y	Heavy flooding in area
1248	Y	1	1	1	N	N 405	pole broke, Transformer Down Hornland Ave
9111	Y	1	0	1	N	N 406	primary Down spans south 640 next to over pass
13010	N	N	0	0	0	N 407	Broke service cable martins' Grocery, Dropped
9357	N	N	0	2	0	N 408	Two Jack's Blown 640 & mimosa
1250	N	N	0	0	0	N 409	service Broke, 288 mimosa
1265	N	N	0	1	0	N 410	Blown Fuse on Transformer second church
9017	N	N	0	0	1	N 411	service Broke corner of second & church
9094	N	N	0	0	1	N 412	service Broke 4th st & old Barton Rd
9237	N	N	0	1	0	N 413	Blown Jack 389 4th st
9314	N	N	0	0	0	N 414	Lifted Jumper's mimosa, 4 = 4th st Hornland

Assessor Name:

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_ Circuit: 17 Top - 17 South

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	4	2	2	2	1	4	Heavy flooding in area
10298 718	N	0	0	0	0	N 98	4290 80' Rd pole leaning, Brake service
10251 10242	N	0	0	0	0	N 99	on 80' Rd 1/2 mile From Howland Gate Rd, poles leaning

Assessor Name: \_\_\_\_\_

Please Print Clearly







# RAPID ASSESSMENT OF DAMAGE

Date: \_\_\_\_\_ Circuit: 17 Top - 17 South

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
11683	N	N	0	0	0	N	Primary off insulator <sup>WETA + Reynolds</sup> <sub>to the east</sub>
776	N	N	0	0	0	N	Service Pole Broke <sup>WALLACE Rd</sup> <sub>SOUTH of 6001</sub>
706	N	N	0	0	0	0	Service cable Broke 3210 WALLACE rd.
* 10392	N	Y	0	0	0	0	Primary and Neutral down ( <del>WETA + Reynolds</del> ) #4 copper - 3370 WALLACE rd.
1312	N	N	0	0	0	0	leaning pole 3555 Reynolds rd.
11167	N	N	0	0	0	0	Service cable on ground 6680 <sup>pulls from</sup> <sub>11167 on snell rd.</sub>
11168	N	N	0	0	0	0	need new pole top pin on snell rd. west of 6767
2067	N	N	0	0	0	0	Broke service cable 8310 Perch lake rd. ←
* 10224	N	N	0	0	0	0	leaning pole Tree on Primary N. of
10144	Y	N	0	0	0	0	Broke pole 45 ft. wood 4 SPANS N of ABC rd <sub>on Pitt rd.</sub>

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9-13-17 Circuit: 17 Top - 17 South

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
	N	O	O	1	O	N	Blown Fuse no damage 6
907	N	O	O	O	O	N	LK Hendry Rd Brake neutral on service
3700	Y	N	O	O	O	N	Brake pole 35 Ft wood 6410 Garfield Rd.
13064	N	N	O	O	O	N	Bells pulled out of top 35 Ft wood 6050 Russo rd.
13060	N	N	O	O	O	N	needs new pole top pin N. of 6050 Russo rd.
3501	Y	N	O	O	O	N	Secondary wire and poledown 30 Ft pole 6541 sink Hole
* 3534	N	N	O	O	1	N	7512 sink Hole rd. Tree in primary
7823	N	N	O	O	O	N	Service pole brake at House
6260	Y	Y	O	O	O	N	40 wood 3 span of primary on the ground #6 copper
6239	Y	Y	O	O	O	N	40 wood " "
852	N	N	O	O	O	N	Leaning pole 8005 Walker lake rd.
10363	N	N	O	O	O	N	Brake Neutral 1 span #4 copper 5Nell rd
11215	N	N	O	O	O	N	Brake service pole 6140 Paris dr. East of Gorton Rd

Assessor Name: \_\_\_\_\_

Please Print Clearly



# RAPID ASSESSMENT OF DAMAGE

Date: 9/13/17

Circuit: Steward - Northwest

Pole #:	Pole Down?	Primary Down?	Transformer(s) Blown?	Fuse(s) Open?	Trees Down?	Fiber Down?	Comments
4321	Y	Z	Z	Z	1	Y	Heavy flooding in area
246 <sup>467</sup>	N	N	N	N	N	N	Svc to 800 Perham down
408	N	N	N	N	N	N	825 Ruby - Pole w/ svc broke 30' wood

Assessor Name: James Starling  
Please Print Clearly