



February 15, 2018

State of Florida
Public Service Commission

FILE SUBMITTED ELECTRONICALLY

RE: Docket No. 20170215-EU – Review of electric utility hurricane preparedness and restoration actions.

To Whom It May Concern:

The following document are responses to the Third Data Request dated January 19, 2018.

If you have any questions or need further clarification, please feel free to contact me at (352) 351-6600.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael Poucher", followed by a long horizontal line extending to the right.

Michael Poucher, P.E.
Director, Electric Utility

lpg

Attachment

COMMISSIONERS:
ART GRAHAM, CHAIRMAN
JULIE I. BROWN
DONALD J. POLMANN
GARY F. CLARK

STATE OF FLORIDA



OFFICE OF THE GENERAL COUNSEL
KEITH C. HETRICK
GENERAL COUNSEL
(850) 413-6199

Public Service Commission

January 19, 2018

STAFF'S THIRD DATA REQUEST
Via E-mail

To:

Municipal Group (AZubaly@publicpower.com)
Lee County (dennie.hamilton@lcec.net)
Cooperative Group (mhershel@feca.com)

Re: Docket No. 20170215-EU - Review of electric utility hurricane preparedness and restoration actions.

To Whom It May Concern:

By this letter, the Commission staff requests that each utility provide responses to the following data requests.

1. Please provide the following information for a specific example where storm hardened structures incurred damage and required repair or replacement due to Hurricane Irma.
 - a. A description of the damage incurred (i.e. broken pole, displaced underground vault, etc.). **One broken pole, seven spans of wire down, and insulators broken on adjacent poles.**
 - b. A description of the repair process, including a description of any temporary repairs that required a follow-up trip. **Removed the tree across the line, installed new pole, installed primary and secondary framing on new pole, replaced broken insulators on seven adjacent poles. Spliced primary conductor and re-hung, and re-hung secondary conductor.**
 - c. A description of the repair process if the facilities had not been hardened. **If the facilities had not been hardened, the pole would have still been damaged by a tree falling on it.**

Please file all responses electronically no later than February 19, 2018 from the Commission's website at www.floridapsc.com, by selecting the **Clerk's Office** tab and **Electronic Filing Web Form**. Please contact me at wtaylor@psc.state.fl.us or at 850.413.6175 if you have any legal questions, or contact Emily Knoblauch for technical questions at eknoblau@psc.state.fl.us or at 850.413.6632.

Sincerely,

/s/Wesley Taylor

Wesley Taylor
Attorney

WDT/as

cc: Office of Commission Clerk
Office of Public Counsel (kelly.jr@leg.state.fl.us, sayler.erik@leg.state.fl.us)