

COMMISSIONERS:  
ART GRAHAM, CHAIRMAN  
JULIE I. BROWN  
DONALD J. POLMANN  
GARY F. CLARK  
ANDREW GILES FAY

STATE OF FLORIDA



DIVISION OF ENGINEERING  
TOM BALLINGER  
DIRECTOR  
(850) 413-6910

# Public Service Commission

May 15, 2018

Mr. Troy Rendell  
Pine Harbour Waterworks, Inc.  
4939 Cross Bayou Blvd.  
New Port Richey, FL 34652  
trendell@uswatercorp.net

## STAFF'S SECOND DATA REQUEST VIA EMAIL & US MAIL

**Re: Docket No. 20180022 – WU - Application for staff-assisted rate case in Lake County by Pine Harbour Waterworks, Inc.**

Dear Mr. Rendell:

Please submit the following information to the Office of Commission Clerk, Florida Public Service Commission, 2540 Shumard Oak Blvd., Tallahassee, FL 32399-0850, by June 4, 2018.

1. Please provide three bid proposals or estimates for the replacement of the 44 meters. If less than three bid proposals or estimates were sought, please explain.
2. When were the replaced meters installed? Why were the meters replaced?
3. Please provide the size and quantity of all operational meters.
4. Please provide the total amount of treated water sold for each month of the calendar year 2017 (test year).
5. Please indicate the amount of treated water used for hydrant flushing, line flushing, plant usage or to extinguish a fire during the test year. Provide the dates, amount of treated water used, and a brief description of the event.
6. Please advise if there were any unusual circumstances such as fires or flushing for the following dates: 04/28/2017, 04/29/2017, 04/30/2017, 07/26/2017, 07/27/2017, 12/20/2017 and 12/21/2017. If an unusual event occurred, please describe it, provide the amount of water used, and the date it happened.
7. Were there any line breaks or water leaks in the system during the calendar year 2017 (test year)? If yes, were the leaks fixed? Please describe the incidents and provide the dates of the leaks.
8. Does Pine Harbour Waterworks, Inc. service the Breathe Easy Medical Facility and the Lake County Fire Rescue Station 72? If yes, please identify the meter size for each facility.

Mr. Troy Rendell  
Date: May 15, 2018  
Page 2

9. Has the finished drinking-water flow meter been calibrated recently? Please provide calibration records.
10. Please provide the meter odometer's increment reading, meter maximum operating pressure, maximum flow rate, and meter maximum reading.

Please contact me by phone at (850) 413-6226 or by email [lsalvado@psc.state.fl.us](mailto:lsalvado@psc.state.fl.us), if you have any questions.

Sincerely,



Luis Salvador, P.E.  
Engineering Specialist  
Division of Engineering  
Florida Public Service Commission

LS:tj

cc: Office of Commission Clerk (Docket No. 20180022-WU)