



[KW Resort Utilities Corp](#)

6630 Front Street
Key West, FL 33040
305.295.3301
FAX 305.295.0143
www.kwru.com

AIRVAC visit to KWRU

February 21, 2018 @ 10:00AM at KWRU WWTP

Jon Hartsock – Engineering Manager, Jon Mavrack Service Manager, John King Field Services South Florida, Chris Johnson KWRU President, Greg Wright KWRU Vice President

Meeting Notes:

Greg Wright to supply Jon Mavrack with Model of Yeoman purchased from RC Beach. Greg also will give the impeller diameter. Jon will utilize his AIRVAC supplier distributor relationship to leverage the best price quotation possible for the Yeoman pump.

Black magnetic tool is superior to grey magnetic tool.

Composite lids are highly thought of by field personnel. In the future KWRU will definitely consider using them.

For AIRVAC remote support: To allow remote access - Switch DB9 connectors

Also as an operational check there shall be an annual “dial in” from AIRVAC Rochester as an annual KWRU maintenance activity to ensure the communication equipment is working properly.

Jon installed the new AB – PanelView 600 the old (550) is still functioning and is now a spare on the shelf. Jon tested and then trained Chris Johnson how to use the new 600 interface. Chris will train KWRU staff.

To reinstall AB-PanelView 550, wire in DC power (Sola Power Supply 3 wire set up), and plug in dedicated communication cable.

VFD – AB525 probably best and would eliminate the need for the com modules.

Jon Hartsock said that he could help KWRU if we are interested in getting the inches of Hg vacuum level and sewerage tank level integrated into our SCADA system. KWRU will keep this in mind moving forward.

Jon H to provide an AIRVAC control panel complete quotation for future budgeting purposes. Jon advised that the quote will be the generic set up, KWRU will examine for any special needs and convey those back to Jon if necessary.