

PINE HARBOUR WATERWORKS, INC.

June 11, 2018

Office of Commission Clerk
Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399

Re: Docket No. 20180022-WU – Application for staff-assisted rate case in Lake County by Pine Harbour Waterworks, Inc.– Supplemental Response to Staff’s Second Data Request No. 9

Dear Commission Clerk,

Please find attached Pine Harbour Waterworks, Inc.’s (Pine Harbour) supplemental response to Staff’s Second Data Request No. 9.

9. Has the finished drinking-water flow meter been calibrated recently? Please provide calibration records.

Response: Please find attached the meter calibration test performed on May 23, 2018. Also see the e-mail from the Florida Rural Water Association (FRWA) of the same date. These were inadvertently filed in the wrong docket.

In addition, please find attached a proposal for a new well meter from Sunstate Meter & Supply, Inc. This is for the meter only, and does not include any labor or materials for installation.

If you have any questions, please do not hesitate to contact me at (727) 848-8292, ext. 245.

Respectfully Submitted,



Troy Rendell
Vice President
Investor Owned Utilities
// for Pine Harbour Waterworks, Inc.

Troy Rendell

From: Ron Derossett
Sent: Thursday, May 24, 2018 2:42 PM
To: Troy Rendell
Subject: FW: Pine Harbour Meter Test
Attachments: Pine Harbour Meter Test 5-23-18.pdf

FYI. I'll get some quotes

*Ron DeRossett
US Water Services Corporation
4939 Cross Bayou Blvd.
New Port Richey, FL 34652
Office: (727)848-8292
Cell: (904)540-9765
fax: (727)849-5467*

From: Tom Gustafson [mailto:Tom.Gustafson@frwa.net]
Sent: Wednesday, May 23, 2018 4:14 PM
To: RDeRossett@uswatercorp.net
Subject: Pine Harbour Meter Test

Ron,

The meter at Pine Harbor needs to be replaced, it was under registering by over 15%. Let me know when you would like to try and do the overnight log there for flow. Just needs to be hopefully a dry night!

Thanks

Tom Gustafson
FRWA
352-267-1302





**Florida Rural Water Association
St. Johns River Water Management District
Flow Meter Accuracy Report Form (EN-51)**



PERMIT INFORMATION

CONSUMPTIVE USE PERMIT NUMBER: _____ PERMITTEE NAME: Pine Harbour
PROJECT NAME: Pine Harbour

WELL/PUMP/STATION INFORMATION

DISTRICT ID: _____ NAME: Water Plant, Distribution Meter
METER MANUFACTURER: ZPM SERIAL NUMBER: 320304

ACCURACY TESTING

DATE OF TEST: 5/23/18
GALLONS PER MINUTE 146 SIZE/TYPE PIPE 6" Steel

STATION METER

Initial meter reading @ start of test: _____
19091000
Final meter reading @ end of test: _____
19091750
Total gallons: _____
750

TESTING METER

Initial meter reading @ start of test: _____
155
Final meter reading @ end of test: _____
1030
Total gallons: _____
875

DURATION OF TEST*: 5

*Should be at least 5 minutes.

PERCENT ACCURACY [(total gallons station meter/total gallons test meter)*100]: 85.71428571

PERCENT ERROR (percent accuracy-100): -14.2857143

TEST METER INFORMATION

METER MANUFACTURER: Panametric SERIAL NUMBER: 02983
DATE OF LAST CALIBRATION (test meter): 9-26-17

ATTACH DIAGRAM OR PHOTO OF TEST METER INSTALLATION POSITION (optional)

This is a free service provided by FRWA as a membership benefit.

TESTER INFORMATION

NAME OF PERSON PERFORMING TEST: TOM GUSTAFSON

PHONE NUMBER: 352-267-1302 EMAIL ADDRESS: TOM.GUSTAFSON@FRWA.NET

I certify that to the best of my knowledge and belief all of the information on this form is correct. I understand that making any material false statement on this form or in any attachments to it may result in revocation, in whole or in part, of the permit.

Notes: Meter was running erratically, dial was sporadically moving. Meter needs replacement and correct installation.

Troy Rendell

From: Ron Derossett
Sent: Friday, June 8, 2018 4:20 PM
To: Troy Rendell
Subject: Fwd: Sunstate Meter & Supply: Quote #14626
Attachments: sunstate-logo.png; sunstate-logo.png

----- Forwarded message -----

From: Tony Perez <tperez@uswatercorp.net>
Date: Fri, Jun 8, 2018, 4:12 PM
Subject: Fwd: Sunstate Meter & Supply: Quote #14626
To: Ron Derossett <rderossett@uswatercorp.net>

Quote for new meter at Pine Harbor

----- Forwarded message -----

From: Jeff Kimbrough <jeff@kimbroughsales.com>
Date: Fri, Jun 8, 2018, 2:56 PM
Subject: Sunstate Meter & Supply: Quote #14626
To: Tony Perez <tperez@uswatercorp.net>

Sunstate Meter & Supply, Inc.

14001 W. Newberry Road
Newberry, Fl. 32669

Jeff Kimbrough -- Sales Representative

Voice: 352-516-9791
Nextel:

Email: jeff@kimbroughsales.com
Fax: 352-735-3603

Account 202271

Quotation 14626

June 8th, 2018

Tony Perez

US Water Services - LEESBURG

4939 Cross Bayou Blvd.

New Port Richey, Fl. 34652

352-206-0657

Re: Neptune 6" HP Turbine Meter - Pine Harbor Replacement

Listed below are the prices that you have requested:

Part #	Description	Qty	Price	Ext
--------	-------------	-----	-------	-----

ET4DR7G8S1573 6" HP Turbine Gallon Meter 1 \$2,022.67 \$2,022.67

Total **\$2,022.67**

+Shipping

We appreciate your continued interest in our products. If you have any questions or if I can be of any further service please do not hesitate to contact me.

Jeff Kimbrough
Sunstate Meter & Supply, Inc.