

Merritt Island Utility Company

May 23, 2019

Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 20190116-SU - Application for staff-assisted rate case in Brevard County, and request for interim rate increase by Merritt Island Utility Company – Pro Forma Plant


Dear Commission Clerk:

Please find attached an invoice for an emergency lift station pump replacement. The lift station pump went bad just prior to the New Year's holiday. The pump had to be replaced. The failed pump was left in the lift station until after the holiday until it could be replaced.

Merritt Island requests this pump replacement be considered for pro-forma plant in the above referenced docket.

If you have any questions, please do not hesitate to contact me at (727) 848-8292, ext. 245.

Respectfully,



Troy Rendell
Vice President
Investor Owned Utilities
// for Merritt Island Utility Company




4939 Cross Bayou Boulevard
New Port Richey, FL 34652

Invoice

Invoice #	887412
Date	2/28/2019
Due Date	4/4/2019
Account #	3266
P.O. or W.A #	

Bill To
Merritt Island Utility Co., Inc c/o Joseph Gabay 4939 Cross Bayou Blvd. New Port Richey, FL 34652

Entered: 
 COA Code: 311
 Approved: WSP 2-5-20-19
 Paid: _____
 Date: _____

Project
3266-31.2 Ls pump #1 bad

Date	Description	Qty	Rate	Amount
12/31/2018	Lift station #1 at Colony Park in high level alarm. Upon arrival found pump #2 to be pulling high amperage. 30amp breaker was being tripped. Tried reversing leads to no avail. Switch leads from pump #2 to contactor #1 (only working contactor) Pump began moving water but the impeller was bent and making a noise. Lift station did pump down and left damaged pump running through holiday until permanent repairs can be made.			
	Labor	3.5	57.91	202.69
	Labor	4.5	52.01	234.05
	Labor	4.5	52.01	234.05
	Crane Truck	1	200.00	200.00
	Shop Consumables	1	15.78	15.78
1/3/2019	Lift station was found in high level alarm. Pulled pump #1 and determined pump was bad. Supervisor had a new S4N500M3-4 with a 7.25" impeller pump delivered. Placed pump in lift station, wired in, and pump began to pump station down.			
	Labor	9	57.91	521.19
	Labor	9	52.01	468.09
	Crane Truck	1	200.00	200.00
	Materials		5,046.92	5,046.92

Please remit payment to the above address. We appreciate your business! Questions about your bill? Phone: 727-848-8292 EXT 219 Toll free: 866-753-8292 EXT 219 Email: uswater-ar@uswatercorp.net	Total	\$7,122.77
	Payments/Credits	\$0.00
	Balance Due	\$7,122.77