



Matthew R. Bernier
ASSOCIATE GENERAL COUNSEL

July 24, 2019

VIA ELECTRONIC FILING

Adam J. Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Performance Data Report for June 2019*
Docket No. 20190001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above-referenced Docket is Duke Energy Florida, LLC's (DEF) complete Performance Data Report for June 2019, which has been supplemented to include additional pages inadvertently omitted from DEF's July 17, 2019, filing. Please use this report to replace the previously filed report.

Thank you for your assistance in this matter. Please feel free to call me at (850) 521-1428 should you have any questions concerning this filing.

Sincerely,

/s/ Matthew R. Bernier

Matthew R. Bernier

MRB/cmK
Attachment

cc: Director, Division of Engineering, FPSC

CERTIFICATE OF SERVICE

Docket No. 20190001-EI

I HEREBY CERTIFY that a true copy of the above-mentioned document has been furnished to the following individuals via e-mail on this 24th day of July, 2019.

/s/ Matthew R. Bernier

Attorney

<p>Suzanne Brownless Office of General Counsel FL Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 sbrownle@psc.state.fl.us</p> <p>J. Beasley / J. Wahlen / M. Means Ausley McMullen P.O. Box 391 Tallahassee, FL 32302 jbeasley@ausley.com jwahlen@ausley.com mmeans@ausley.com</p> <p>Steven Griffin Beggs & Lane P.O. Box 12950 Pensacola, FL 32591 srg@beggslane.com</p> <p>Russell A. Badders Gulf Power Company One Energy Place Pensacola, FL 32520 russell.badders@nexteraenergy.com</p> <p>Holly Henderson Gulf Power Company 215 S. Monroe St., Ste. 618 Tallahassee, FL 32301 holly_henderson@nexteraenergy.com</p> <p>Kenneth A. Hoffman Florida Power & Light Company 134 W. Jefferson Street Tallahassee, FL 32301-1713 ken_hoffman@fpl.com</p> <p>Jon C. Moyle, Jr. Moyle Law Firm, P.A. 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com mqualls@moylelaw.com</p>	<p>J.R. Kelly / P. Christensen / T. David / S. Morse Office of Public Counsel 111 W. Madison St., Room 812 Tallahassee, FL 32399-1400 kelly.jr@leg.state.fl.us christensen.patty@leg.state.fl.us david.tad@leg.state.fl.us morse.stephanie@leg.state.fl.us</p> <p>Ms. Paula K. Brown Regulatory Affairs Tampa Electric Company P.O. Box 111 Tampa, FL 33601-0111 regdept@tecoenergy.com</p> <p>Maria Moncada / Joel Baker Florida Power & Light Company 700 Universe Blvd. (LAW/JB) Juno Beach, FL 33408-0420 maria_moncada@fpl.com joel.baker@fpl.com</p> <p>James Brew / Laura Wynn Stone Law Firm 1025 Thomas Jefferson St., N.W. Suite 800 West Washington, DC 20007 jbrew@smxblaw.com law@smxblaw.com</p> <p>Robert Scheffel Wright / John T. LaVia, III c/o Gardner Law Firm 1300 Thomaswood Drive Tallahassee, FL 32308 schef@gbwlegal.com jlavia@gbwlegal.com</p> <p>Mike Cassel Florida Public Utilities Company 1750 S. 14th Street, Suite 200 Fernandina Beach, FL 32034 mcassel@fpuc.com</p> <p>Beth Keating Gunster, Yoakley & Stewart, P.A. 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com</p>
---	---

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

Bartow CC	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	98.52	97.86	62.26	85.22	96.60	99.79							89.89
2. PH	744	672	743	720	744	720							4,343
3. SH	603.9	593.9	485.5	612.3	712.0	695.1							3,702.7
4. RSH	129.0	65.0	8.7	1.3	12.5	24.9							241.4
5. UH	11.0	13.1	248.8	106.4	19.6	0.0							398.8
6. POH	0.0	0.0	133.5	70.6	0.0	0.0							204.0
7. FOH	8.5	13.1	0.0	14.1	9.1	0.0							44.8
8. MOH	2.5	0.0	115.4	21.7	10.5	0.0							150.1
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
11. PFOH	0.0	21.6	0.0	0.0	15.4	24.8							61.8
12. LR PF (MW)	0.0	67.0	0.0	0.0	187.0	67.0							96.8
13. PMOH	0.0	0.0	182.7	0.0	17.8	0.0							200.5
14. LR PM (MW)	0.0	0.0	187.0	0.0	187.0	0.0							187.0
15. NSC (MW)	1080	1080	1080	1080	1080	1080							1080
16. OPER MBTU	3,968,623	3,524,794	2,757,930	3,820,788	4,860,440	4,828,905							23,761,481
17. NET GEN (MWH)	519,987	458,412	365,538	483,493	640,960	630,820							3,099,210
18. ANOHR (BTU/KWH)	7,632.2	7,689.1	7,544.9	7,902.5	7,583.1	7,655.0							7,666.9
19. NOF (%)	79.72	71.47	69.72	73.11	83.36	84.03							77.50
20. NPC (MW)	1080	1080	1080	1080	1080	1080							1080

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

CRYSTAL RIVER 4	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	95.90	98.58	99.85	99.10	99.94	98.66							98.67
2. PH	744	672	743	720	744	720							4,343
3. SH	249.0	85.3	743.0	720.0	744.0	720.0							3,261.3
4. RSH	465.5	582.4	0.0	0.0	0.0	0.0							1,047.9
5. UH	29.6	4.2	0.0	0.0	0.0	0.0							33.8
6. POH	0.0	4.2	0.0	0.0	0.0	0.0							4.2
7. FOH	29.6	0.0	0.0	0.0	0.0	0.0							29.6
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	0.0	6.7	8.5	39.6	0.0	0.0							54.7
10. LR PP (MW)	0.0	93.0	93.0	108.4	0.0	0.0							104.1
11. PFOH	2.2	2.9	0.0	1.7	0.0	70.0							76.8
12. LR PF (MW)	284.4	93.0	0.0	188.0	0.0	98.2							105.3
13. PMOH	0.0	31.0	0.0	0.0	3.3	0.0							34.3
14. LR PM (MW)	0.0	93.0	0.0	0.0	93.1	0.0							93.0
15. NSC (MW)	712	712	712	712	712	712							712
16. OPER MBTU	917,440	391,844	3,216,166	3,273,475	3,558,000	3,435,077							14,792,002
17. NET GEN (MWH)	82,152	31,051	323,578	318,328	344,212	326,986							1,426,307
18. ANOHR (BTU/KWH)	11,167.6	12,619.4	9,939.4	10,283.3	10,336.7	10,505.3							10,370.8
19. NOF (%)	46.35	51.11	61.17	62.10	64.98	63.78							61.42
20. NPC (MW)	712	712	712	712	712	712							712

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

CRYSTAL RIVER 5	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	99.93	78.57	0.00	0.00	0.05	55.90							38.55
2. PH	744	672	743	720	744	720							4,343
3. SH	547.7	0.0	0.0	0.0	0.0	450.0							997.7
4. RSH	196.3	528.0	0.0	0.0	0.0	0.0							724.3
5. UH	0.0	144.0	743.0	720.0	743.6	270.0							2,620.6
6. POH	0.0	144.0	743.0	720.0	311.0	3.3							1,921.3
7. FOH	0.0	0.0	0.0	0.0	432.6	266.7							699.3
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
11. PFOH	1.0	0.0	0.0	0.0	0.0	355.3							356.3
12. LR PF (MW)	377.0	0.0	0.0	0.0	0.0	95.0							95.8
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	710	710	710	710	710	710							710
16. OPER MBTU	2,006,569	0	0	0	13,291	1,663,716							3,683,576
17. NET GEN (MWH)	185,022	0	0	0	0	148,500							333,522
18. ANOHR (BTU/KWH)	10,845.0	0.0	0.0	0.0	0.0	11,203.5							11,044.5
19. NOF (%)	47.58	0.00	0.00	0.00	0.00	46.48							47.08
20. NPC (MW)	710	710	710	710	710	710							710

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

HINES Power Block 1	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	47.59	89.85	98.58	39.42	76.10	99.20							74.94
2. PH	744	672	743	720	744	720							4,343
3. SH	356.2	588.3	669.0	260.0	562.9	555.8							2,992.2
4. RSH	25.7	17.4	66.4	28.5	5.0	164.2							307.3
5. UH	362.1	66.2	7.6	431.5	176.1	0.0							1,043.6
6. POH	0.0	0.0	0.0	391.9	158.6	0.0							550.6
7. FOH	6.7	0.0	7.6	39.6	5.8	0.0							59.7
8. MOH	355.4	66.2	0.0	0.0	11.8	0.0							433.3
9. PPOH	0.0	0.0	12.1	0.0	10.6	0.0							22.7
10. LR PP (MW)	0.0	0.0	68.1	0.0	50.6	0.0							59.9
11. PFOH	166.5	12.0	7.3	26.3	5.4	69.3							286.7
12. LR PF (MW)	82.0	82.0	85.1	78.4	51.3	41.0							71.3
13. PMOH	0.0	0.0	0.0	2.7	0.0	0.0							2.7
14. LR PM (MW)	0.0	0.0	0.0	78.1	0.0	0.0							78.1
15. NSC (MW)	490	490	490	490	490	490							490
16. OPER MBTU	872,136	1,738,925	1,939,335	666,151	1,699,555	1,636,821							8,552,922
17. NET GEN (MWH)	114,118	234,944	260,779	88,049	226,948	220,581							1,145,419
18. ANOHR (BTU/KWH)	7,642.4	7,401.4	7,436.7	7,565.7	7,488.7	7,420.5							7,467.1
19. NOF (%)	65.39	81.50	79.55	69.13	82.29	80.99							78.12
20. NPC (MW)	490	490	490	490	490	490							490

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

HINES Power Block 2	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	99.35	99.93	99.06	100.00	99.98	99.86							99.69
2. PH	744	672	743	720	744	720							4,343
3. SH	522.1	594.2	262.4	703.8	741.6	693.4							3,517.4
4. RSH	217.0	77.8	473.6	16.2	2.4	26.6							813.7
5. UH	4.8	0.0	7.0	0.0	0.0	0.0							11.8
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	4.8	0.0	0.0	0.0	0.0	0.0							4.8
8. MOH	0.0	0.0	7.0	0.0	0.0	0.0							7.0
9. PPOH	0.0	4.5	0.0	0.0	1.5	4.0							10.0
10. LR PP (MW)	0.0	51.1	0.0	0.0	56.4	126.0							81.9
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	512	512	512	512	512	512							512
16. OPER MBTU	1,575,600	1,841,414	767,331	2,404,824	2,515,630	2,265,725							11,370,524
17. NET GEN (MWH)	216,465	250,392	94,594	326,935	338,507	305,167							1,532,060
18. ANOHR (BTU/KWH)	7,278.8	7,354.1	8,111.8	7,355.7	7,431.5	7,424.5							7,421.7
19. NOF (%)	80.97	82.31	70.40	90.73	89.15	85.96							85.07
20. NPC (MW)	512	512	512	512	512	512							512

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

HINES Power Block 3	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	99.51	100.00	99.99	95.45	99.92	99.68							99.09
2. PH	744	672	743	720	744	720							4,343
3. SH	700.1	638.3	343.6	606.6	744.0	604.2							3,636.8
4. RSH	40.7	33.7	399.4	86.5	0.0	115.9							676.1
5. UH	3.2	0.0	0.0	26.9	0.0	0.0							30.1
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	3.2	0.0	0.0	23.9	0.0	0.0							27.1
8. MOH	0.0	0.0	0.0	3.0	0.0	0.0							3.0
9. PPOH	0.0	0.0	1.0	18.8	5.8	8.0							33.7
10. LR PP (MW)	0.0	0.0	52.2	54.8	55.0	127.3							72.0
11. PFOH	3.3	0.0	0.0	24.5	0.0	3.7							31.5
12. LR PF (MW)	75.3	0.0	0.0	80.4	0.0	49.6							76.3
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
15. NSC (MW)	516	516	516	516	516	516							516
16. OPER MBTU	2,287,431	1,840,031	1,054,849	1,858,493	2,424,687	1,893,691							11,359,182
17. NET GEN (MWH)	308,437	251,190	147,150	263,134	337,696	262,628							1,570,235
18. ANOHR (BTU/KWH)	7,416.2	7,325.3	7,168.5	7,062.9	7,180.1	7,210.5							7,234.1
19. NOF (%)	85.38	76.26	82.99	84.07	87.96	84.25							83.68
20. NPC (MW)	516	516	516	516	516	516							516

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2019

HINES Power Block 4	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Jan - Jun Period
1. EAF	99.64	99.77	98.79	99.78	99.60	100.00							99.59
2. PH	744	672	743	720	744	720							4,343
3. SH	677.2	637.2	680.2	678.2	738.9	603.6							4,015.4
4. RSH	64.8	33.4	62.8	41.8	2.9	116.4							322.1
5. UH	2.0	1.4	0.0	0.0	2.2	0.0							5.6
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	2.0	1.4	0.0	0.0	2.2	0.0							5.6
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PPOH	5.5	0.0	202.9	39.8	5.1	0.0							253.3
10. LR PP (MW)	62.4	0.0	21.2	21.0	59.3	0.0							22.8
11. PFOH	0.0	0.0	8.5	0.0	2.1	0.0							10.6
12. LR PF (MW)	0.0	0.0	38.7	0.0	55.1	0.0							42.0
13. PMOH	0.0	1.3	0.0	0.0	0.0	0.0							1.3
14. LR PM (MW)	0.0	78.1	0.0	0.0	0.0	0.0							78.1
15. NSC (MW)	516	516	516	516	516	516							516
16. OPER MBTU	2,212,083	1,913,058	2,029,918	2,065,703	2,421,807	1,882,729							12,525,299
17. NET GEN (MWH)	319,434	276,729	292,615	303,025	342,323	266,653							1,800,779
18. ANOHR (BTU/KWH)	6,925.0	6,913.1	6,937.2	6,816.9	7,074.6	7,060.6							6,955.5
19. NOF (%)	91.42	84.16	83.37	86.59	89.78	85.61							86.91
20. NPC (MW)	516	516	516	516	516	516							516

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	1/19/2019	FMO	14.00	185.0	OTHER CO REDUCTION PROBLEMS
BCC 4A	3/1/2019	PO	1135.93	185.0	MAJOR GAS TURBINE OVERHAUL
BCC 4A	4/18/2019	FFO	10.92	185.0	FLASHBACK (INCLUDING INSTRUMENTATION)
BCC 4A	4/19/2019	FFO	16.07	185.0	FLASHBACK (INCLUDING INSTRUMENTATION)
BCC 4B	2/11/2019	FFO	74.72	183.0	GAS TURBINE - STARTING SYSTEM (INCLUDING MOTOR)
BCC 4B	4/2/2019	FMO	117.52	183.0	GAS TURBINE - EXHAUST SYSTEM CHAMBER
BCC 4B	5/28/2019	FFO	1.42	183.0	GAS TURBINE - LUBE OIL PUMPS
BCC 4B	6/20/2019	FFO	26.67	183.0	GAS TURBINE - LUBE OIL PUMPS
BCC 4C	3/3/2019	FMO	558.70	187.0	MAJOR GAS TURBINE OVERHAUL
BCC 4C	4/2/2019	FMO	6.57	187.0	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	5/15/2019	FMO	57.67	187.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
BCC 4D	3/27/2019	FMO	73.15	186.0	GAS TURBINE - EXHAUST SYSTEM CHAMBER
BCC 4D	5/11/2019	FFO	2.77	186.0	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
BCC 4D	5/13/2019	FFO	0.70	186.0	COMBINED CYCLE INSTRUMENTS AND CONTROLS
BCC 4D	5/23/2019	FFO	46.20	186.0	OTHER GAS TURBINE FUEL SYSTEM PROBLEMS
BCC 4S	1/7/2019	FFO	30.10	339.0	CIRCULATING WATER PUMPS
BCC 4S	2/11/2019	PFO	74.72	67.0	GAS TURBINE - STARTING SYSTEM (INCLUDING MOTOR)
BCC 4S	3/3/2019	PMO	558.70	187.0	MAJOR GAS TURBINE OVERHAUL
BCC 4S	3/27/2019	PMO	73.10	187.0	GAS TURBINE - EXHAUST SYSTEM CHAMBER
BCC 4S	4/19/2019	FFO	1.23	339.0	CONTRACTOR ERROR
BCC 4S	4/19/2019	FFO	31.40	339.0	VIBRATION OF THE TURBINE GENERATOR UNIT
BCC 4S	5/11/2019	PFO	2.77	187.0	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
BCC 4S	5/15/2019	PMO	61.67	187.0	OTHER LP STEAM SYSTEM PROBLEMS
BCC 4S	5/23/2019	PFO	48.93	187.0	OTHER GAS TURBINE FUEL SYSTEM PROBLEMS
BCC 4S	5/28/2019	PFO	1.42	186.8	GAS TURBINE - CONTROLS AND INSTRUMENTS
BCC 4S	6/20/2019	PFO	85.73	67.0	BOILER WATER CONDITION (NOT FEEDWATER WATER QUALITY)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/20/2019	FFO	29.58	712.0	DESUPERHEATER/ATTEMPERATOR CONTROLS (NOT LOCAL CONTROLS)
1/26/2019	PFO	2.23	284.1	CONDENSATE VALVES
2/25/2019	PO	0.13	712.0	FEEDWATER CONTROLS
2/25/2019	PO	4.10	712.0	CONDENSATE/HOTWELL PUMPS
2/26/2019	PMO	27.50	93.0	PULVERIZER MILLS
2/28/2019	PMO	3.50	93.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
2/28/2019	PFO	2.90	93.1	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
2/28/2019	PPO	15.17	93.0	PULVERIZER MILLS
4/2/2019	PPO	4.58	93.1	PULVERIZER MILLS
4/2/2019	PFO	1.65	188.1	PULVERIZER MILLS
4/2/2019	PPO	0.57	92.9	PULVERIZER MILLS
4/3/2019	PPO	6.00	93.0	PULVERIZER MILLS
4/4/2019	PPO	6.67	93.0	PULVERIZER MILLS
4/9/2019	PPO	4.87	93.0	PULVERIZER MILLS
4/10/2019	PPO	5.13	93.1	PULVERIZER MILLS
4/11/2019	PPO	6.42	188.0	PULVERIZER MILLS
4/11/2019	PPO	1.32	93.0	PULVERIZER MILLS
4/26/2019	PPO	4.00	92.9	PULVERIZER COAL LEAK (PULVERIZER ONLY)
5/22/2019	PMO	3.33	92.9	PULVERIZER LUBE OIL SYSTEM
6/9/2019	PFO	67.00	93.0	HEATER DRAIN PUMPS
6/24/2019	PFO	1.00	74.0	INDUCED DRAFT FAN LUBRICATION SYSTEMS
6/29/2019	PFO	2.00	284.1	HEATER DRAIN PUMPS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/11/2019	PFO	1.00	377.0	OTHER PULVERIZER PROBLEMS
2/23/2019	PO	1918.02	710.0	BOILER - OTHER INTERNAL AND STRUCTURAL PROBLEMS
5/13/2019	FFO	360.93	710.0	GENERATOR ROTOR WINDINGS
5/29/2019	FFO	207.48	710.0	GENERATOR ROTOR WINDINGS
6/9/2019	PO	0.98	710.0	INDUCED DRAFT FAN MOTORS - VARIABLE SPEED
6/10/2019	PFO	6.00	520.0	COAL CONVEYERS AND FEEDERS
6/10/2019	PFO	2.48	233.9	COAL CONVEYERS AND FEEDERS
6/10/2019	PO	2.30	710.0	INDUCED DRAFT FAN MOTORS - VARIABLE SPEED
6/10/2019	FFO	122.83	710.0	FIRST SUPERHEATER LEAKS
6/16/2019	FFO	8.02	710.0	4000-7000-VOLT CIRCUIT BREAKERS
6/16/2019	PFO	129.87	72.0	HEATER DRAIN PUMP DRIVE
6/21/2019	PFO	12.00	282.0	CIRCULATING WATER PIPING
6/22/2019	PFO	151.63	72.0	HEATER DRAIN PUMP DRIVE
6/28/2019	PFO	53.33	120.0	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1A	1/1/2019	FMO	95.75	163.0	OTHER EXCITER PROBLEMS
HEP 1A	1/6/2019	FMO	83.48	163.0	LP TURBINE SHAFT SEALS
HEP 1A	2/8/2019	FMO	58.00	163.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 1A	3/3/2019	PPO	10.00	77.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1A	3/5/2019	PPO	2.08	73.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1A	3/11/2019	FFO	2.98	163.0	FEEDWATER PUMP/DRIVE LUBE OIL SYSTEM
HEP 1A	3/25/2019	FFO	0.45	163.0	FEEDWATER CONTROLS
HEP 1A	4/1/2019	FFO	6.05	163.0	OTHER TURBINE VALVES
HEP 1A	4/13/2019	PO	551.85	163.0	GENERAL GAS TURBINE UNIT INSPECTION
HEP 1A	5/6/2019	PO	0.52	163.0	FLASHBACK (INCLUDING INSTRUMENTATION)
HEP 1A	5/6/2019	PPO	8.00	21.0	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP 1A	5/7/2019	PFO	8.08	17.0	TURBINE CONTROL VALVES
HEP 1A	5/7/2019	FMO	16.62	163.0	TURBINE CONTROL VALVES
HEP 1A	5/17/2019	PPO	4.00	40.0	BOILER SAFETY VALVE TEST
HEP 1A	5/31/2019	PPO	2.00	73.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1A	6/10/2019	PFO	45.00	73.0	GAS TURBINE - COOLING AND SEAL AIR SYSTEM
HEP 1A	6/28/2019	FFO	0.83	163.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 1A	6/29/2019	FFO	8.58	163.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 1B	1/1/2019	FMO	95.75	169.0	OTHER EXCITER PROBLEMS
HEP 1B	1/6/2019	FMO	83.00	169.0	LP TURBINE SHAFT SEALS
HEP 1B	1/9/2019	FFO	20.00	169.0	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 1B	1/10/2019	FMO	534.42	169.0	GENERATOR LUBE OIL SYSTEM
HEP 1B	2/8/2019	FMO	42.27	169.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 1B	2/10/2019	FMO	16.73	169.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 1B	3/3/2019	PPO	10.00	83.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1B	3/5/2019	PPO	2.08	79.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1B	3/31/2019	FFO	40.02	169.0	EMERGENCY GENERATOR TRIP DEVICES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1B	4/5/2019	FFO	16.28	169.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	4/6/2019	FFO	8.32	169.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	4/8/2019	FFO	60.08	169.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	4/15/2019	PO	503.85	169.0	GENERAL GAS TURBINE UNIT INSPECTION
HEP 1B	5/6/2019	PO	109.47	169.0	GENERAL GAS TURBINE UNIT INSPECTION
HEP 1B	5/10/2019	FFO	0.40	169.0	OTHER GAS TURBINE PROBLEMS
HEP 1B	5/15/2019	FFO	11.12	169.0	GAS TURBINE - FUEL PIPING AND VALVES
HEP 1B	5/16/2019	FFO	3.00	169.0	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 1B	5/17/2019	PPO	4.00	47.0	BOILER SAFETY VALVE TEST
HEP 1B	5/31/2019	PPO	2.00	79.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 1B	6/10/2019	PFO	55.77	79.0	GAS TURBINE COMPRESSOR - BLEED VALVES
HEP 1B	6/18/2019	FFO	2.88	169.0	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 1B	6/28/2019	FFO	51.78	169.0	FEEDWATER PUMP DRIVE - MOTOR
HEP ST1	1/1/2019	FMO	95.75	158.0	OTHER EXCITER PROBLEMS
HEP ST1	1/6/2019	FMO	92.92	158.0	LP TURBINE SHAFT SEALS
HEP ST1	1/10/2019	PFO	525.83	82.0	GENERATOR LUBE OIL SYSTEM
HEP ST1	2/8/2019	PFO	15.73	82.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP ST1	2/8/2019	FMO	42.27	158.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP ST1	2/10/2019	FMO	18.42	158.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP ST1	3/3/2019	PPO	10.00	45.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST1	3/5/2019	PPO	2.08	46.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST1	3/11/2019	PFO	2.98	79.0	FEEDWATER PUMP/DRIVE LUBE OIL SYSTEM
HEP ST1	3/31/2019	PFO	22.63	86.0	EMERGENCY GENERATOR TRIP DEVICES
HEP ST1	4/1/2019	FFO	6.10	158.0	OTHER TURBINE VALVES
HEP ST1	4/5/2019	PFO	16.28	78.0	EMERGENCY GENERATOR TRIP DEVICES
HEP ST1	4/6/2019	PMO	8.08	78.0	EMERGENCY GENERATOR TRIP DEVICES
HEP ST1	4/8/2019	PFO	60.08	78.0	EMERGENCY GENERATOR TRIP DEVICES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST1	4/15/2019	PO	359.85	158.0	GENERAL GAS TURBINE UNIT INSPECTION
HEP ST1	5/1/2019	PO	108.00	158.0	GENERAL GAS TURBINE UNIT INSPECTION
HEP ST1	5/5/2019	PO	16.72	158.0	TURBINE HYDRAULIC SYSTEM FILTERS
HEP ST1	5/6/2019	PPO	8.00	92.0	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP ST1	5/7/2019	PFO	8.08	86.0	TURBINE CONTROL VALVES
HEP ST1	5/7/2019	FMO	18.87	158.0	TURBINE CONTROL VALVES
HEP ST1	5/8/2019	FFO	1.80	158.0	TURBINE TRIP DEVICES (INCLUDING INSTRUMENTS)
HEP ST1	5/8/2019	FFO	0.78	158.0	TURBINE TRIP DEVICES (INCLUDING INSTRUMENTS)
HEP ST1	5/17/2019	PPO	4.00	16.0	BOILER SAFETY VALVE TEST
HEP ST1	5/31/2019	PPO	0.00	#DIV/0!	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST1	6/10/2019	PFO	55.77	14.0	GAS TURBINE COMPRESSOR - BLEED VALVES
HEP ST1	6/28/2019	PFO	51.83	0.0	FEEDWATER PUMP DRIVE - MOTOR
HEP ST1	6/28/2019	FFO	2.58	158.0	OTHER DISTRIBUTIVE CONTROL SYSTEM PROBLEMS
HEP ST1	6/29/2019	FFO	11.28	158.0	TURBINE - MISCELLANEOUS DRAIN AND VENT VALVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 2A	1/1/2019	FFO	4.50	166.3	OTHER MISC. OPERATIONAL ENVIRONMENTAL LIMITS - GAS
HEP 2A	2/8/2019	PPO	4.50	60.3	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP 2A	3/2/2019	PO	331.28	166.3	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
HEP 2A	3/27/2019	FMO	7.00	166.3	OTHER CONDENSING SYSTEM CONTROLS AND INSTRUMENTS
HEP 2A	5/4/2019	PPO	1.50	65.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 2A	6/1/2019	PPO	4.00	123.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 2B	1/1/2019	FFO	4.53	174.3	OTHER MISC. OPERATIONAL ENVIRONMENTAL LIMITS - GAS
HEP 2B	2/8/2019	PPO	4.50	68.3	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP 2B	3/2/2019	PO	331.28	174.3	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
HEP 2B	3/27/2019	FMO	7.00	174.3	OTHER CONDENSING SYSTEM CONTROLS AND INSTRUMENTS
HEP 2B	5/4/2019	PPO	1.50	73.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 2B	6/1/2019	PPO	4.00	131.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST2	1/1/2019	FFO	5.47	171.3	OTHER MISC. OPERATIONAL ENVIRONMENTAL LIMITS - GAS
HEP ST2	2/8/2019	PPO	4.50	25.4	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP ST2	3/2/2019	PO	331.28	171.3	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
HEP ST2	3/27/2019	FMO	7.00	171.3	OTHER CONDENSING SYSTEM CONTROLS AND INSTRUMENTS
HEP ST2	5/4/2019	PPO	1.50	31.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST2	6/1/2019	PPO	4.00	123.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	3/6/2019	PPO	1.00	64.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3A	4/3/2019	FMO	6.42	173.3	DC PROTECTION DEVICES
HEP 3A	4/19/2019	PPO	9.83	67.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3A	4/20/2019	PPO	9.00	69.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3A	5/9/2019	PPO	3.00	64.4	BOILER SAFETY VALVE TEST
HEP 3A	5/30/2019	PPO	2.17	68.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3A	6/5/2019	PPO	8.00	130.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3A	6/11/2019	FFO	3.92	173.3	TURBINE TRIP DEVICES (INCLUDING INSTRUMENTS)
HEP 3A	6/16/2019	PFO	5.50	73.3	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
HEP 3B	1/31/2019	FFO	9.70	173.3	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 3B	3/6/2019	PPO	1.00	64.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3B	4/3/2019	FMO	2.67	173.3	DC PROTECTION DEVICES
HEP 3B	4/19/2019	PPO	9.83	67.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3B	4/20/2019	PPO	9.00	69.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3B	4/22/2019	FFO	15.68	173.3	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP 3B	4/25/2019	FFO	56.88	173.3	FUEL GAS COMPRESSOR HEAT EXCHANGERS
HEP 3B	5/7/2019	PPO	1.00	65.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3B	5/9/2019	PPO	3.00	64.4	BOILER SAFETY VALVE TEST
HEP 3B	5/30/2019	PPO	2.17	68.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 3B	6/5/2019	PPO	8.00	130.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST3	1/31/2019	PFO	9.70	75.3	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP ST3	3/6/2019	PPO	1.00	28.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST3	4/19/2019	PPO	9.83	27.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP ST3	4/20/2019	PPO	9.00	29.3	CLOSED COOLING WATER HEAT EXCHANGERS
HEP ST3	4/22/2019	PFO	15.67	84.3	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP ST3	4/25/2019	PFO	56.88	79.3	FUEL GAS COMPRESSOR HEAT EXCHANGERS
HEP ST3	5/7/2019	PPO	1.00	34.4	OTHER MISCELLANEOUS EXTERNAL PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST3	5/9/2019	PPO	3.00	34.3	BOILER SAFETY VALVE TEST
HEP ST3	5/30/2019	PPO	2.17	37.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST3	6/5/2019	PPO	8.00	121.3	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST3	6/11/2019	FFO	6.25	169.3	TURBINE TRIP DEVICES (INCLUDING INSTRUMENTS)
HEP ST3	6/16/2019	PFO	5.50	26.3	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	1/22/2019	PPO	1.50	75.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4A	1/23/2019	PPO	3.00	72.0	DISTRIBUTIVE CONTROL SYSTEM - PROCESS COMPUTER
HEP 4A	1/28/2019	PPO	2.00	70.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4A	3/1/2019	PFO	8.50	42.0	CIRCULATING WATER PUMP MOTORS
HEP 4A	3/6/2019	PPO	0.92	76.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4A	5/5/2019	PPO	0.98	73.9	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4A	5/24/2019	PPO	4.27	76.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4A	5/31/2019	FFO	6.50	176.0	GAS TURBINE - LUBE OIL PUMPS
HEP 4A	6/15/2019	FFO	28.17	176.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
HEP 4A	6/19/2019	FFO	11.97	176.0	TURBINE TURNING GEAR AND MOTOR
HEP 4A	6/20/2019	FFO	4.68	176.0	IP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 4B	1/20/2019	FFO	0.08	175.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 4B	1/20/2019	FFO	5.85	175.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 4B	1/20/2019	FFO	5.80	175.0	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
HEP 4B	1/22/2019	PPO	1.50	74.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4B	1/28/2019	PPO	2.00	69.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4B	2/24/2019	FFO	4.00	175.0	GAS TURBINE - IGNITION SYSTEM
HEP 4B	3/1/2019	PFO	8.50	41.0	CIRCULATING WATER PUMP MOTORS
HEP 4B	3/6/2019	PPO	0.92	76.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4B	5/5/2019	PPO	0.50	73.2	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4B	5/24/2019	PPO	4.27	75.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP 4B	6/16/2019	FFO	27.58	175.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
HEP 4B	6/20/2019	FFO	19.55	175.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 4B	6/21/2019	FFO	3.65	175.0	TURBINE CONTROL VALVES
HEP ST4	1/22/2019	PPO	1.50	0.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST4	1/23/2019	PPO	3.00	91.0	DISTRIBUTIVE CONTROL SYSTEM - PROCESS COMPUTER
HEP ST4	1/28/2019	PPO	2.00	18.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - June 2019

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST4	2/24/2019	PMO	4.00	78.0	GAS TURBINE - IGNITION SYSTEM
HEP ST4	3/1/2019	PFO	8.50	33.0	CIRCULATING WATER PUMP MOTORS
HEP ST4	3/6/2019	PPO	743.92	21.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST4	5/5/2019	PPO	1.00	22.9	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST4	5/24/2019	PPO	4.27	29.0	OTHER MISCELLANEOUS EXTERNAL PROBLEMS
HEP ST4	5/31/2019	PFO	6.50	55.0	GAS TURBINE - LUBE OIL PUMPS
HEP ST4	6/16/2019	FFO	27.58	165.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
HEP ST4	6/20/2019	FFO	0.78	165.0	TURBINE WATER INDUCTION
HEP ST4	6/20/2019	FFO	5.48	165.0	OTHER GAS TURBINE PROBLEMS
HEP ST4	6/20/2019	FFO	0.87	165.0	TURBINE WATER INDUCTION