

State of Florida



## Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD  
TALLAHASSEE, FLORIDA 32399-0850

**-M-E-M-O-R-A-N-D-U-M-**

---

**DATE:** April 7, 2020

**TO:** Adam J. Teitzman, Commission Clerk, Office of Commission Clerk

**FROM:** Kerri Johnson, Engineering Specialist I, Division of Engineering *KJ, MR, LK*

**RE:** Docket No. 20190166-WS - Application for increase in water rates in Highlands County by HC Waterworks, Inc.

---

Please file the attached "Follow-up to Lake Josephine Sanitary Survey" from U.S. Water Services Corporation, in the above mentioned docket file.

Thank you.

KJ/jp

Attachment

**From:** [Joann Parsons](#)  
**To:** [Joann Parsons](#)  
**Subject:** FW: Lake Josephine Sanitary Survey  
**Date:** Tuesday, April 07, 2020 12:55:30 PM

---

---

**From:** Troy Rendell [trendell@uswatercorp.net]  
**Sent:** Monday, April 06, 2020 9:02 AM  
**To:** Kerri Johnson  
**Subject:** RE: Lake Josephine Sanitary Survey

Good morning,

Yes – they have been corrected.

thanks

Troy Rendell  
Vice President - Investor Owned Utilities



4939 Cross Bayou Boulevard  
New Port Richey, FL 34652  
(Office) 727-848-8292 x245  
(Fax) 727-848-7701  
(E-Mail) [trendell@uswatercorp.net](mailto:trendell@uswatercorp.net)

---

**From:** Kerri Johnson [mailto:[KEJOHNSO@psc.state.fl.us](mailto:KEJOHNSO@psc.state.fl.us)]  
**Sent:** Monday, April 6, 2020 8:56 AM  
**To:** [trendell@uswatercorp.net](mailto:trendell@uswatercorp.net)  
**Subject:** Lake Josephine Sanitary Survey

Good morning Troy,

A sanitary survey conducted 1/29/2020, indicated there were two minor violations: (1) cracks in the well pad and (2) screen missing on a vent. Staff was wondering if HC is in the process of correcting those deficiencies?

Sincerely,

**Kerri Johnson**

Engineering Specialist  
Division of Engineering  
Florida Public Service Commission  
(850) 413-6836  
[Kerri.Johnson@psc.state.fl.us](mailto:Kerri.Johnson@psc.state.fl.us)