

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: June 15, 2020

TO: Adam J. Teitzman, Commission Clerk, Office of Commission Clerk

FROM: Jefferson Doehling, Engineering Specialist II, Division of Engineering

JD LK

RE: DN 20190195-WS - Application for transfer of water and wastewater systems of Regency Utilities, Inc., and transfer of Certificate Nos. 641-W and 551-S to Duval Waterworks, Inc., in Duval County.

Please file the attached email correspondence from Troy Rendell regarding inspection of Duval Waterworks' distribution system, in the above mentioned docket file.

JD/pz

Attachment

From: [Troy Rendell](#)
To: [Jeff Doehling](#)
Subject: RE: Docket No. 20190195 (Duval Waterworks) - Information Request
Date: Monday, June 15, 2020 11:37:14 AM

To our knowledge they have never inspected the distribution system. The fire system is not regulated by FDEP. The potable distribution system is under the mall parking lot (asphalt) and inside and under the mall. Access to inspect would next to impossible to do any type of inspection.

Troy Rendell
Vice President - Investor Owned Utilities



4939 Cross Bayou Boulevard
New Port Richey, FL 34652
(Office) 727-848-8292 x245
(Mobile) 727-777-2508
(Fax) 727-848-7701
(E-Mail) trendell@uswatercorp.net

From: Jeff Doehling [mailto:JDOEHLIN@psc.state.fl.us]
Sent: Monday, June 15, 2020 11:10 AM
To: Troy Rendell (trendell@uswatercorp.net)
Subject: Docket No. 20190195 (Duval Waterworks) - Information Request

Mr. Rendell,

Staff is preparing its recommendation, and had a question concerning DEP inspections of Duval Waterworks, Inc.'s (DWI) distribution system. We are aware that DWI does not have any DEP permits, as DWI does not have any treatment facilities. However, the DEP conducts inspections of the distribution system for other similar distribution only utilities. Does the DEP conduct periodic inspections of DWI's distribution system? If not, please explain why.

Respectfully,
Jeff Doehling

Jefferson Doehling
Engineering Specialist
Division of Engineering
Florida Public Service Commission