

**DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A**

PERMITTEE NAME: Utilities Inc of Florida ADDRESS: 200 Weathersfield Ave Altamonte Springs, FL 32714  FACILITY: Wekiva Hunt Club WRF LOCATION: 144 Ledbury Dr Longwood, FL 32779  COUNTY: SEMINOLE	PERMIT NUMBER: FL0036251 LIMIT: FINAL REPORT: Monthly FACILITY TYPE: DW GROUP: Domestic MONITORING GROUP: D-001  DESCRIPTION: Surface Water Discharge  MONITORING PERIOD: From: 08/01/2020 To: 08/31/2020
---	--

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	<b>Sample Measurement</b>		<b>0.063</b>						<b>0</b>	NOD	NOD
PARM Code 50050 Y Mon. Site: FLW-4	<b>Permit Requirement</b>		<b>0.87</b> (Annl Avg)	MGD						(1 Daily, when discharging)	(Recording Flow Meter with Totalizer)
Flow	<b>Sample Measurement</b>	<b>NOD</b>	<b>NOD</b>						<b>0</b>	NOD	NOD
PARM Code 50050 1 Mon. Site: FLW-4	<b>Permit Requirement</b>	<b>Report</b> (Daily Mx)	<b>Report</b> (Mo Avg)	MGD						(1 Daily, when discharging)	(Recording Flow Meter with Totalizer)
BOD, Carbonaceous 5 day, 20C	<b>Sample Measurement</b>				<b>NOD</b>	<b>NOD</b>			<b>0</b>	NOD	NOD
PARM Code 80082 A Mon. Site: EFA-1	<b>Permit Requirement</b>				<b>5.0</b> (Mo Avg)	<b>6.0</b> (Maximum)	mg/L			(1 Weekly)	(16-hr Flow Proportioned Composite)
Solids, Total Suspended	<b>Sample Measurement</b>				<b>NOD</b>	<b>NOD</b>			<b>0</b>	NOD	NOD
PARM Code 00530 A Mon. Site: EFA-1	<b>Permit Requirement</b>				<b>5.0</b> (Mo Avg)	<b>6.0</b> (Maximum)	mg/L			(1 Weekly)	(16-hr Flow Proportioned Composite)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Coliform, Fecal PARM Code 74055 Y Mon. Site: EFA-1	Sample Measurement					<1.0			0	NOD	NOD
	Permit Requirement					200.0 (Annl Avg)		#/100mL		(1 Weekly)	(Grab)
Coliform, Fecal PARM Code 74055 A Mon. Site: EFA-1	Sample Measurement					NOD	NOD		0	NOD	NOD
	Permit Requirement					200.0 (Mo Geomn)	800.0 (Maximum)	#/100mL		(1 Weekly)	(Grab)
pH PARM Code 00400 1 Mon. Site: EFD-1	Sample Measurement				NOD		NOD		0	NOD	NOD
	Permit Requirement				6.0 (Minimum)		8.5 (Maximum)	s.u.		(1 Daily, when discharging)	(Meter)
Chlorine, Total Residual PARM Code 50060 A Mon. Site: EFA-1	Sample Measurement				NOD				0	NOD	NOD
	Permit Requirement				0.5 (Minimum)			mg/L		(1 Daily, when discharging)	(Meter)
Chlorine, Total Residual PARM Code 50060 1 Mon. Site: EFD-1	Sample Measurement						NOD		0	NOD	NOD
	Permit Requirement						0.01 (Maximum)	mg/L		(1 Daily, when discharging)	(Grab)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Nitrogen, Total PARM Code 00600 Y Mon. Site: EFA-1	Sample Measurement					6.7			0	NOD	NOD
	Permit Requirement					Report (Annl Avg)		mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Nitrogen, Total PARM Code 00600 A Mon. Site: EFA-1	Sample Measurement						NOD		0	NOD	NOD
	Permit Requirement						Report (Mo Avg)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Nitrogen, Ammonia, Total (as N) PARM Code 00610 1 Mon. Site: EFD-1	Sample Measurement					NOD	NOD		0	NOD	NOD
	Permit Requirement					2.5 (Mo Avg)	3.0 (Maximum)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Nitrogen, Nitrate, Total (as N) PARM Code 00620 1 Mon. Site: EFD-1	Sample Measurement						NOD		0	NOD	NOD
	Permit Requirement						Report (Maximum)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Phosphorus, Total (as P) PARM Code 00665 1 Mon. Site: EFD-1	Sample Measurement					NOD	NOD		0	NOD	NOD
	Permit Requirement					0.4 (Mo Avg)	0.5 (Maximum)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Nitrogen, Nitrate, Total (as N) PARM Code 00620 P Mon. Site: EFD-1	Sample Measurement		NOD						0	NOD	NOD
	Permit Requirement		2805.0 (Mo Total)	lb/mth						(1 Weekly)	(Calculated)
Phosphorus, Total (as P) PARM Code 00665 P Mon. Site: EFD-1	Sample Measurement		NOD						0	NOD	NOD
	Permit Requirement		40.0 (Mo Total)	lb/mth						(1 Weekly)	(Calculated)
Oxygen, Dissolved (DO) PARM Code 00300 1 Mon. Site: EFD-1	Sample Measurement				NOD				0	NOD	NOD
	Permit Requirement				6.0 (Minimum)			mg/L		(1 Daily, when discharging)	(Grab)
LC50 Statre 96hr Acu Ceriodaphnia PARM Code TAN3B P Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 Annually)	(Grab)
LC50 Statre 96hr Acu Ceriodaphnia PARM Code TAN3B Q Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 See permit)	(Documents)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
LC50 Statre 96hr Acu Ceriodaphnia PARM Code TAN3B R Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 See permit)	(Documents)
LC50 Statre 96hr Acucyprinella Leedsi PARM Code TAN6H P Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 Annually)	(Grab)
LC50 Statre 96hr Acucyprinella Leedsi PARM Code TAN6H Q Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 See permit)	(Documents)
LC50 Statre 96hr Acucyprinella Leedsi PARM Code TAN6H R Mon. Site: EFD-1	Sample Measurement				MNR				0	NOD	NOD
	Permit Requirement				100.0 (Minimum)			percent		(1 See permit)	(Documents)
Flow PARM Code 50050 P Mon. Site: FLW-1	Sample Measurement		1.959						0	NOD	NOD
	Permit Requirement		2.9 (Annl Avg)	MGD						(1 Continuous)	(Recording Flow Meter with Totalizer)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow  PARM Code 50050 Q Mon. Site: FLW-1	Sample Measurement	2.104	2.412						0	NOD	NOD
	Permit Requirement	Report (Qtr Avg)	Report (Mo Avg)	MGD						(1 Continuous)	(Recording Flow Meter with Totalizer)
Percent Capacity, (TMADF/Permitted Capacity) x 100  PARM Code 00180 P Mon. Site: CAL-1	Sample Measurement					73			0	NOD	NOD
	Permit Requirement					Report (Mo Avg)	percent			(1 Monthly)	(Calculated)
BOD, Carbonaceous 5 day, 20C  PARM Code 80082 G Mon. Site: INF-1	Sample Measurement					223			0	NOD	NOD
	Permit Requirement					Report (Maximum)	mg/L			(1 Weekly)	(16-hr Flow Proportioned Composite)
Solids, Total Suspended  PARM Code 00530 G Mon. Site: INF-1	Sample Measurement					250			0	NOD	NOD
	Permit Requirement					Report (Maximum)	mg/L			(1 Weekly)	(16-hr Flow Proportioned Composite)
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Barner Cooks	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHERED AND EVALUATED THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Electronically Signed			TELEPHONE  (407) 625-8593	SUBMITTED ON  09/23/2020

**DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A**

PERMITTEE NAME: Utilities Inc of Florida ADDRESS: 200 Weathersfield Ave Altamonte Springs, FL 32714  FACILITY: Wekiva Hunt Club WRF LOCATION: 144 Ledbury Dr Longwood, FL 32779  COUNTY: SEMINOLE	PERMIT NUMBER: FL0036251 LIMIT: FINAL REPORT: Monthly FACILITY TYPE: DW GROUP: Domestic MONITORING GROUP: R-001  DESCRIPTION: RIBs  MONITORING PERIOD: From: 08/01/2020 To: 08/31/2020
---	---

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type	
Flow  PARM Code 50050 Y Mon. Site: FLW-2	Sample Measurement	0.029				0	5 Days/Week	Recording Flow Meter with Totalizer	
	Permit Requirement	0.4 (Annl Avg)	MGD				(5 Days/Week)	(Recording Flow Meter with Totalizer)	
Flow  PARM Code 50050 1 Mon. Site: FLW-2	Sample Measurement	0.084				0	5 Days/Week	Recording Flow Meter with Totalizer	
	Permit Requirement	Report (Mo Avg)	MGD				(5 Days/Week)	(Recording Flow Meter with Totalizer)	
BOD, Carbonaceous 5 day, 20C  PARM Code 80082 Y Mon. Site: EFA-1	Sample Measurement			<2.0		0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite	
	Permit Requirement			20.0 (Annl Avg)	mg/L		(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)	
BOD, Carbonaceous 5 day, 20C  PARM Code 80082 A Mon. Site: EFA-1	Sample Measurement			5.8	5.8	3.4	0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite
	Permit Requirement			60.0 (Maximum)	45.0 (Wkly Avg)	30.0 (Mo Avg)	mg/L	(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended PARM Code 00530 Y Mon. Site: EFA-1	Sample Measurement					<1.0			0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite
	Permit Requirement					20.0 (Annl Avg)		mg/L		(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)
Solids, Total Suspended PARM Code 00530 A Mon. Site: EFA-1	Sample Measurement				3.8	3.8	2.7		0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite
	Permit Requirement				60.0 (Maximum)	45.0 (Wkly Avg)	30.0 (Mo Avg)	mg/L		(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)
Coliform, Fecal PARM Code 74055 Y Mon. Site: EFA-1	Sample Measurement					<1.0			0	1 Bi-weekly; every 2 weeks	Grab
	Permit Requirement					200.0 (Annl Avg)		#/100mL		(1 Bi-weekly; every 2 weeks)	(Grab)
Coliform, Fecal PARM Code 74055 A Mon. Site: EFA-1	Sample Measurement					<1.0	<1.0		0	1 Bi-weekly; every 2 weeks	Grab
	Permit Requirement					200.0 (Mo Geomn)	800.0 (Maximum)	#/100mL		(1 Bi-weekly; every 2 weeks)	(Grab)
pH PARM Code 00400 A Mon. Site: EFA-1	Sample Measurement				6.8		7.2		0	5 Days/Week	Meter
	Permit Requirement				6.0 (Minimum)		8.5 (Maximum)	s.u.		(5 Days/Week)	(Meter)



Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Chlorine, Total Residual PARM Code 50060 A Mon. Site: EFA-1	Sample Measurement				1.0				0	5 Days/Week	Meter
	Permit Requirement				0.5 (Minimum)			mg/L		(5 Days/Week)	(Meter)
Nitrogen, Nitrate, Total (as N) PARM Code 00620 A Mon. Site: EFA-1	Sample Measurement						3.6		0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite
	Permit Requirement						12.0 (Maximum)	mg/L		(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)
Nitrogen, Total PARM Code 00600 Y Mon. Site: EFA-1	Sample Measurement						1.6		0	1 Bi-weekly; every 2 weeks	16-hr Flow Proportioned Composite
	Permit Requirement						10.0 (Annl Avg)	mg/L		(1 Bi-weekly; every 2 weeks)	(16-hr Flow Proportioned Composite)
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Barner Cooks	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHERED AND EVALUATED THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Electronically Signed			TELEPHONE  (407) 625-8593	SUBMITTED ON  09/23/2020

**DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A**

PERMITTEE NAME: Utilities Inc of Florida ADDRESS: 200 Weathersfield Ave Altamonte Springs, FL 32714  FACILITY: Wekiva Hunt Club WRF LOCATION: 144 Ledbury Dr Longwood, FL 32779  COUNTY: SEMINOLE	PERMIT NUMBER: FL0036251 LIMIT: FINAL REPORT: Monthly FACILITY TYPE: DW GROUP: Domestic MONITORING GROUP: R-002  DESCRIPTION: Public Access Reuse  MONITORING PERIOD: From: 08/01/2020 To: 08/31/2020
---	--

Parameter	Sample Measurement	Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Flow  PARM Code 50050 Y Mon. Site: FLW-3	Sample Measurement	2.369				0	1 Continuous	Recording Flow Meter with Totalizer
	Permit Requirement	2.9 (Annl Avg)	MGD				(1 Continuous)	(Recording Flow Meter with Totalizer)
Flow  PARM Code 50050 1 Mon. Site: FLW-3	Sample Measurement	2.733				0	1 Continuous	Recording Flow Meter with Totalizer
	Permit Requirement	Report (Mo Avg)	MGD				(1 Continuous)	(Recording Flow Meter with Totalizer)
BOD, Carbonaceous 5 day, 20C  PARM Code 80082 Y Mon. Site: EFA-1	Sample Measurement			2.3		0	1 Weekly	16-hr Flow Proportioned Composite
	Permit Requirement			20.0 (Annl Avg)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
BOD, Carbonaceous 5 day, 20C  PARM Code 80082 A Mon. Site: EFA-1	Sample Measurement			<2.0	<2.0	<2.0	1 Weekly	16-hr Flow Proportioned Composite
	Permit Requirement			60.0 (Maximum)	45.0 (Wkly Avg)	30.0 (Mo Avg)	mg/L	(1 Weekly)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended PARM Code 00530 B Mon. Site: EFB-1	Sample Measurement						<1.0		0	4 Days/Week	Grab
	Permit Requirement						5.0 (Maximum)	mg/L		(4 Days/Week)	(Grab)
Coliform, Fecal PARM Code 74055 A Mon. Site: EFA-1	Sample Measurement						<1.0		0	4 Days/Week	Grab
	Permit Requirement						25.0 (Maximum)	#/100mL		(4 Days/Week)	(Grab)
Coliform, Fecal, % less than detection PARM Code 51005 A Mon. Site: EFA-1	Sample Measurement				100				0	4 Days/Week	Calculated
	Permit Requirement				75.0 (MinTotMo)			percent		(4 Days/Week)	(Calculated)
pH PARM Code 00400 A Mon. Site: EFA-1	Sample Measurement				6.8		7.2		0	1 Continuous	Meter
	Permit Requirement				6.0 (Minimum)		8.5 (Maximum)	s.u.		(1 Continuous)	(Meter)
Chlorine, Total Residual PARM Code 50060 A Mon. Site: EFA-1	Sample Measurement				1.0				0	1 Continuous	Meter
	Permit Requirement				1.0 (Minimum)			mg/L		(1 Continuous)	(Meter)

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended PARM Code 00530 P Mon. Site: EFB-1	Sample Measurement						3.5		0	1 Continuous	Meter
	Permit Requirement						5.0 (Maximum)	mg/L		(1 Continuous)	(Meter)
Phosphorus, Total (as P) PARM Code 00665 Y Mon. Site: EFA-1	Sample Measurement					1.2			0	1 Weekly	16-hr Flow Proportioned Composite
	Permit Requirement					Report (Annl Avg)		mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Phosphorus, Total (as P) PARM Code 00665 A Mon. Site: EFA-1	Sample Measurement						2.9		0	1 Weekly	16-hr Flow Proportioned Composite
	Permit Requirement						Report (Maximum)	mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
Nitrogen, Total PARM Code 00600 Y Mon. Site: EFA-1	Sample Measurement					8.3			0	1 Weekly	16-hr Flow Proportioned Composite
	Permit Requirement					10.0 (Annl Avg)		mg/L		(1 Weekly)	(16-hr Flow Proportioned Composite)
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Barner Cooks	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHERED AND EVALUATED THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Electronically Signed			TELEPHONE  (407) 625-8593	SUBMITTED ON  09/23/2020

**DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A**

PERMITTEE NAME: Utilities Inc of Florida ADDRESS: 200 Weathersfield Ave Altamonte Springs, FL 32714  FACILITY: Wekiva Hunt Club WRF LOCATION: 144 Ledbury Dr Longwood, FL 32779  COUNTY: SEMINOLE	PERMIT NUMBER: FL0036251 LIMIT: FINAL REPORT: Monthly FACILITY TYPE: DW GROUP: Domestic MONITORING GROUP: RMP-Q  DESCRIPTION: Biosolids Quantity  MONITORING PERIOD: From: 08/01/2020 To: 08/31/2020
---	---

Parameter	Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type	
Biosolids Quantity (Transferred)	<b>38.1</b>				<b>0</b>	<b>1 Monthly</b>	<b>Calculated</b>	
PARM Code B0007 + Mon. Site: RMP-1	<b>Report (Mo Total)</b>	<b>dry tons</b>				<b>(1 Monthly)</b>	<b>(Calculated)</b>	
Biosolids Quantity (Landfilled)	<b>NOD</b>				<b>0</b>	<b>1 Monthly</b>	<b>Calculated</b>	
PARM Code B0008 + Mon. Site: RMP-1	<b>Report (Mo Total)</b>	<b>dry tons</b>				<b>(1 Monthly)</b>	<b>(Calculated)</b>	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Barner Cooks	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHERED AND EVALUATED THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Electronically Signed		TELEPHONE  (407) 625-8593	SUBMITTED ON  09/23/2020

## DAILY SAMPLE RESULTS - PART B

Permit Number:

**FL0036251-022-DW1P**

Facility:

**Wekiva Hunt Club WWTP**

Monitoring Period

From: August 1, 2020 To: August 31, 2020

Code	BOD, Carbonaceous 5 day, 20C	Chlorine, Total Residual (For Disinfection)	Coliform, Fecal	Nitrogen, Nitrate, Total (as N)	Nitrogen, Total	Phosphorus, Total (as P)	Solids, Total Suspended mg/L	pH	pH
	mg/L	mg/L	#/100mL	mg/L	mg/L	mg/L		s.u. (Min.)	s.u. (Max.)
Code	80082	50060	74055	620	600	665	530	400	400
Mon. Site	EFA-1	EFA-1	EFA-1	EFA-1	EFA-1	EFA-1	EFA-1	EFA-1	EFA-1
1		1.5						7.0	7.0
2		1.8						7.0	7.0
3		5.0	<1.0					7.0	7.0
4		1.2	<1.0					7.0	7.0
5	<2.0	1.1	<1.0		6.2	2.9		7.0	7.1
6	<2.0	1.1	<1.0, <1.0	3.6	4.5		3.8	6.9	7.1
7		4.0						7.0	7.0
8		2.8						6.9	7.0
9		1.6						6.8	7.1
10		3.7	<1.0					7.0	7.1
11		1.3	<1.0					7.0	7.2
12	<2.0	1.3	<1.0		2	1.2		7.0	7.1
13		1.5	<1.0					7.0	7.1
14		2.9						7.0	7.1
15		1.0						7.0	7.1
16		4.1						7.0	7.1
17		3.2	<1.0					7.0	7.1
18		3.5	<1.0					7.0	7.1
19	<2.0	2.2	<1.0		7.8	2.1		7.0	7.1
20	5.8	2.6	<1.0, <1.0	1.4	2.9		1.6	7.0	7.1
21		3.5						7.0	7.1
22		2.6						7.0	7.1
23		2.0						7.0	7.1
24		3.7	<1.0					7.0	7.1
25		1.0	<1.0					7.0	7.0
26	<2.0	3.4	<1.0		9.8	2.6		7.0	7.0
27		3.3	<1.0					7.0	7.0
28		3.6						7.0	7.0
29		4.0						6.9	7.0
30		3.3						7.0	7.0
31		4.0	<1.0					7.0	7.1
<b>Total</b>	<b>10.80</b>	<b>81.8</b>	<b>8.50</b>	<b>5.00</b>	<b>33.2</b>	<b>8.80</b>	<b>5.40</b>	<b>216.5</b>	<b>219.0</b>
<b>Mo. Avg.</b>	<b>&lt;2.0</b>	<b>2.6</b>	<b>&lt;1.0</b>	<b>2.50</b>	<b>5.5</b>	<b>2.20</b>	<b>2.70</b>	<b>7.0</b>	<b>7.1</b>

**PLANT STAFFING:**

Day Shift Operator	Class:	<u>    A    </u>	Certificate No:	<u>    12997    </u>	Name:	<u>    Frederick Rodgers    </u>
Day Shift Operator	Class:	<u>    A    </u>	Certificate No:	<u>    9611    </u>	Name:	<u>    Claude Stone    </u>
Day Shift Operator	Class:	<u>    B    </u>	Certificate No:	<u>    7676    </u>	Name:	<u>    Nathan Van Meter    </u>
Day Shift Operator	Class:	<u>    C    </u>	Certificate No:	<u>    25638    </u>	Name:	<u>    Wadner Metra    </u>
Day Shift Operator	Class:	<u>    C    </u>	Certificate No:	<u>    26093    </u>	Name:	<u>    Dean Cowart    </u>
Lead Operator	Class:	<u>    A    </u>	Certificate No:	<u>    7347    </u>	Name:	<u>    Barner Cooks    </u>

## DAILY SAMPLE RESULTS - PART B

Permit Number:

**FL0036251-022-DWIP**

Facility:

**Wekiva Hunt Club WWTP**

Monitoring Period

From: August 1, 2020 To: August 31, 2020

	Solids, Total Suspended	Solids, Total Suspended	Chlorine, Total Residual (For Dechlorinationmg /L	Nitrogen, Ammonia, Total (as N)	Nitrogen, Nitrate, Total (as N)	Oxygen, Dissolved (DO)	Phosphorus, Total (as P)	pH	pH
	(grab)	(meter)						(Min.)	(Max.)
Code	530	530	50060	610	620	300	665	400	400
Mon. Site	EFB-1	EFB-1	EFD-1	EFD-1	EFD-1	EFD-1	EFD-1	EFD-1	EFD-1
1		3.4							
2		2.9							
3	<1.0	3.5							
4	<1.0	1.3							
5	<1.0	1.6							
6	<1.0	1.5							
7		0.8							
8		1.0							
9		1.7							
10	<1.0	1.4							
11	<1.0	1.2							
12	<1.0	1.1							
13	<1.0	1.0							
14		1.0							
15		1.4							
16		1.2							
17	<1.0	1.4							
18	<1.0	1.0							
19	<1.0	0.8							
20	<1.0	0.7							
21		0.8							
22		0.8							
23		0.8							
24	<1.0	1.0							
25	<1.0	0.8							
26	<1.0	0.9							
27	<1.0	0.8							
28		0.6							
29		0.7							
30		0.9							
31	<1.0	1.0							
<b>Total</b>	<b>8.5</b>	<b>39.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>Mo. Avg.</b>	<b>&lt;1.0</b>	<b>1.3</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>

**PLANT STAFFING:**

Day Shift Operator	Class:	A	Certificate No:	12997	Name:	Frederick Rodgers
Day Shift Operator	Class:	A	Certificate No:	9611	Name:	Claude Stone
Day Shift Operator	Class:	B	Certificate No:	7676	Name:	Nathan Van Meter
Day Shift Operator	Class:	C	Certificate No:	25638	Name:	Wadner Metra
Day Shift Operator	Class:	C	Certificate No:	26093	Name:	Dean Cowart
Lead Operator	Class:	A	Certificate No:	7347	Name:	Barner Cooks

## DAILY SAMPLE RESULTS - PART B

Permit Number:

**FL0036251-022-DWIP**

Facility:

**Wekiva Hunt Club WWTP**

Monitoring Period

From: August 1, 2020 To: August 31, 2020

	Flow (Total Through Plant)	Flow (Rapid Infiltration Basins)	Flow (Public Access Reuse)	Flow (Surface Water Discharge)	BOD, Carbonaceous 5 day, 20C (Influent)	Solids, Total Suspended (Influent)			
Code	50050	50050	50050	50050	80082	530			
Mon. Site	FLW-1	FLW-2	FLW-3	FLW-4	INF-1	INF-1			
1	2.114	0.000	0.910	0.000					
2	2.118	0.000	3.114	0.000					
3	2.136	0.000	3.201	0.000					
4	2.076	0.000	3.453	0.000					
5	2.166	0.000	2.465	0.000	198	190			
6	2.103	0.000	2.335	0.000					
7	2.263	0.000	2.302	0.000					
8	2.381	0.000	2.129	0.000					
9	1.810	0.050	2.105	0.000					
10	2.534	0.000	2.484	0.000					
11	2.534	0.000	2.484	0.000					
12	2.534	0.000	2.486	0.000	206	168			
13	2.376	0.719	2.487	0.000					
14	2.553	0.000	3.540	0.000					
15	2.443	0.000	3.572	0.000					
16	2.390	0.017	3.580	0.000					
17	2.458	0.000	2.404	0.000					
18	2.273	0.000	1.694	0.000					
19	2.509	0.048	2.187	0.000	223	208			
20	2.472	0.000	2.750	0.000					
21	2.400	0.000	2.609	0.000					
22	2.837	0.000	3.288	0.000					
23	2.627	1.528	2.704	0.000					
24	2.688	0.000	2.719	0.000					
25	2.635	0.000	2.768	0.000					
26	2.660	0.252	3.078	0.000	193	250			
27	2.633	0.000	3.287	0.000					
28	2.612	0.000	3.136	0.000					
29	2.478	0.000	3.390	0.000					
30	2.443	0.000	3.109	0.000					
31	2.502	0.000	2.941	0.000					
<b>Total</b>	<b>74.8</b>	<b>2.6</b>	<b>84.7</b>	<b>0.0</b>	<b>820.0</b>	<b>816.0</b>			
<b>Mo. Avg.</b>	<b>2.4</b>	<b>0.1</b>	<b>2.7</b>	<b>0.0</b>	<b>205.0</b>	<b>204.0</b>			

**PLANT STAFFING:**

Day Shift Operator	Class:	A	Certificate No:	12997	Name:	Frederick Rodgers
Day Shift Operator	Class:	A	Certificate No:	9611	Name:	Claude Stone
Day Shift Operator	Class:	B	Certificate No:	7676	Name:	Nathan Van Meter
Day Shift Operator	Class:	C	Certificate No:	25638	Name:	Wadner Metra
Day Shift Operator	Class:	C	Certificate No:	26093	Name:	Dean Cowart
Lead Operator	Class:	A	Certificate No:	7347	Name:	Barner Cooks