



**Maria Jose Moncada**  
**Senior Attorney**  
**Florida Power & Light Company**  
**700 Universe Boulevard**  
**Juno Beach, FL 33408-0420**  
**(561) 304-5795**  
**(561) 691-7135 (Facsimile)**  
**E-mail: maria.moncada@fpl.com**

April 20, 2021

**-VIA ELECTRONIC FILING -**

Adam Teitzman  
Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850

**Re: Docket No. 20210001-EI**

Dear Mr. Teitzman:

Attached for electronic filing in the above docket is Florida Power & Light Company's GPIF Actual Unit Performance Data Schedules covering the month of March 2021. These schedules are being filed at the same time but separately from its monthly filing of the A Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

*s/ Maria Jose Moncada*  
Maria Jose Moncada

Attachments

cc: Counsel for Parties of Record (w/ attachments)

**CERTIFICATE OF SERVICE**

**Docket No. 20210001-EI**

**I HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished

by electronic service on this 20th day of April 2021 to the following:

Suzanne Brownless  
Division of Legal Services  
**Florida Public Service Commission**  
2540 Shumard Oak Blvd.  
Tallahassee, Florida 32399-0850  
sbrownle@psc.state.fl.us

Russell A. Badders  
Vice President & Associate General Counsel  
**Gulf Power Company**  
One Energy Place  
Pensacola, Florida 32520-0100  
russell.badders@nexteraenergy.com

Dianne M. Triplett  
299 First Avenue North  
St. Petersburg, Florida 33701  
dianne.triplett@duke-energy.com

Matthew R. Bernier  
Robert L. Pickels  
Duke Energy Florida  
106 East College Avenue, Suite 800  
Tallahassee, Florida 32301  
robert.pickels@duke-energy.com  
matthew.bernier@duke-energy.com  
FLRegulatoryLegal@duke-energy.com  
**Attorneys for Duke Energy Florida**

Beth Keating  
Gunster Law Firm  
215 South Monroe St., Suite 601  
Tallahassee, Florida 32301-1804  
bkeating@gunster.com  
**Attorneys for Florida Public Utilities  
Company**

Richard Gentry  
Patricia A. Christensen  
Charles J. Rehwinkel  
Mireille Fall-Fry  
Stephanie Morse  
Anastacia Pirrello  
**Office of Public Counsel**  
c/o The Florida Legislature  
111 West Madison St., Room 812  
Tallahassee, FL 32399-1400  
gentry.richard@leg.state.fl.us  
christensen.patty@leg.state.fl.us  
rehwinkel.charles@leg.state.fl.us  
fall-fry.mireille@leg.state.fl.us  
morse.stephanie@leg.state.fl.us  
pirrello.anastacia@leg.state.fl.us

James D. Beasley  
J. Jeffrey Wahlen  
Malcolm N. Means  
Ausley & McMullen  
P.O. Box 391  
Tallahassee, Florida 32302  
jbeasley@ausley.com  
jwahlen@ausley.com  
mmeans@ausley.com  
**Attorneys for Tampa Electric Company**

Paula K. Brown, Manager  
**Tampa Electric Company**  
Regulatory Coordinator  
Post Office Box 111  
Tampa, Florida 33601-0111  
regdept@tecoenergy.com

Mike Cassel  
Director/Regulatory and  
Governmental Affairs  
**Florida Public Utilities Company**  
208 Wildlight Ave.  
Yulee, Florida 32097  
mcassel@fpuc.com

Jon C. Moyle, Jr.  
Moyle Law Firm, P.A.  
118 North Gadsden Street  
Tallahassee, FL 32301  
jmoyle@moylelaw.com  
mqualls@moylelaw.com  
**Attorneys for Florida Industrial Power  
Group**

James W. Brew  
Laura Wynn Baker  
Stone Mattheis Xenopoulos & Brew, P.C.  
1025 Thomas Jefferson Street, NW  
Eighth Floor, West Tower  
Washington, DC 20007  
jbrew@smxblaw.com  
lwb@smxblaw.com  
**Attorneys for PCS Phosphate – White  
Springs**

By: s/Maria Jose Moncada  
Maria Jose Moncada  
Florida Bar No. 0773301

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: CAPE CANAVERAL 03 |         |         |     |     |     |     |     |     |     |     | PCC 03 |         |
|-----|-----------------|---------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|---------|
|     |                 | Jan                             | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd     |
| 1.  | EAF (%)         | 75.9                            | 76.4    | 90.7    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 81.1    |
| 2.  | PH              | 744                             | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 3.  | SH              | 744                             | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 4.  | RSH             | 0                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 5.  | UH              | 0                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 6.  | POH             | 0                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 7.  | FOH             | 0                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 8.  | MOH             | 0                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 9.  | PPOH            | 420.67                          | 249.18  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 669.85  |
| 10. | LR PP (MW)      | 435.98                          | 436.04  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 436     |
| 11. | PFOH            | 1.87                            | 0       | 3.9     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 5.77    |
| 12. | LR PF (MW)      | 435.25                          | 0       | 436     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 435.76  |
| 13. | PMOH            | 116.32                          | 226.3   | 202.93  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 545.55  |
| 14. | LR PM (MW)      | 436.02                          | 435.98  | 435.99  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 435.99  |
| 15. | NSC             | 1308                            | 1308    | 1308    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1308    |
| 16. | OPER BTU (MBTU) | 3311562                         | 2830766 | 3513687 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 9656015 |
| 17. | NET GEN         | 502424                          | 419419  | 520602  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1442445 |
| 18. | ANOHR (BTU/KWH) | 6591                            | 6749    | 6749    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 6694    |
| 19. | NOF (%)         | 51.6                            | 47.7    | 53.6    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 51.1    |
| 20. | NPC (MW)        | 1308                            | 1308    | 1308    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1308    |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: PORT EVERGLADES 05 |         |         |     |     |     |     |     |     |     |     | PPE 05 |         |
|-----|-----------------|----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|---------|
|     |                 | Jan                              | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd     |
| 1.  | EAF (%)         | 97.7                             | 99.7    | 61.2    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 85.8    |
| 2.  | PH              | 744                              | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 3.  | SH              | 744                              | 672     | 483.58  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1899.58 |
| 4.  | RSH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 5.  | UH              | 0                                | 0       | 259.42  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 259.42  |
| 6.  | POH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 7.  | FOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 8.  | MOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 9.  | PPOH            | 0                                | 0       | 288.43  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 288.43  |
| 10. | LR PP (MW)      | 0                                | 0       | 1183.97 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1183.97 |
| 11. | PFOH            | 2.87                             | 8.37    | 48      | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 59.23   |
| 12. | LR PF (MW)      | 417.52                           | 343.23  | 417.98  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 407.46  |
| 13. | PMOH            | 48                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 48      |
| 14. | LR PM (MW)      | 418                              | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 418     |
| 15. | NSC             | 1253.99                          | 1253.99 | 1253.99 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1253.99 |
| 16. | OPER BTU (MBTU) | 2815027                          | 3268382 | 2626479 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 8709889 |
| 17. | NET GEN         | 412143                           | 482517  | 391156  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1285816 |
| 18. | ANOHR (BTU/KWH) | 6830                             | 6774    | 6715    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 6774    |
| 19. | NOF (%)         | 44.2                             | 57.3    | 64.5    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 54      |
| 20. | NPC (MW)        | 1254                             | 1254    | 1254    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1254    |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: RIVIERA 05 |         |         |     |     |     |     | PRV 05 |     |     |     |     |         |
|-----|-----------------|--------------------------|---------|---------|-----|-----|-----|-----|--------|-----|-----|-----|-----|---------|
|     |                 | Jan                      | Feb     | Mar     | Apr | May | Jun | Jul | Aug    | Sep | Oct | Nov | Dec | Ytd     |
| 1.  | EAF (%)         | 100                      | 85.5    | 58.8    | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 81.3    |
| 2.  | PH              | 744                      | 672     | 743     | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 2159    |
| 3.  | SH              | 744                      | 672     | 622.72  | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 2038.72 |
| 4.  | RSH             | 0                        | 0       | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0       |
| 5.  | UH              | 0                        | 0       | 120.28  | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 120.28  |
| 6.  | POH             | 0                        | 0       | 120.28  | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 120.28  |
| 7.  | FOH             | 0                        | 0       | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0       |
| 8.  | MOH             | 0                        | 0       | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0       |
| 9.  | PPOH            | 0                        | 168     | 555.6   | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 723.6   |
| 10. | LR PP (MW)      | 0                        | 435.98  | 437.26  | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 436.96  |
| 11. | PFOH            | 0                        | 29.18   | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 29.18   |
| 12. | LR PF (MW)      | 0                        | 436.03  | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 436.03  |
| 13. | PMOH            | 0                        | 95.12   | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 95.12   |
| 14. | LR PM (MW)      | 0                        | 435.96  | 0       | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 435.96  |
| 15. | NSC             | 1308                     | 1308    | 1308    | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 1308    |
| 16. | OPER BTU (MBTU) | 2606522                  | 2201242 | 2431663 | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 7239427 |
| 17. | NET GEN         | 388957                   | 328698  | 365961  | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 1083616 |
| 18. | ANOHR (BTU/KWH) | 6701                     | 6697    | 6645    | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 6681    |
| 19. | NOF (%)         | 40                       | 37.4    | 44.9    | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 40.6    |
| 20. | NPC (MW)        | 1308                     | 1308    | 1308    | 0   | 0   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 1308    |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: WEST COUNTY ENER 03 |         |         |     |     |     |     |     |     |     |     | PWC 03 |          |
|-----|-----------------|-----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                               | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 98.6                              | 97.8    | 99.8    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 98.8     |
| 2.  | PH              | 744                               | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 3.  | SH              | 744                               | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 4.  | RSH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 5.  | UH              | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 6.  | POH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 7.  | FOH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 8.  | MOH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 9.  | PPOH            | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 10. | LR PP (MW)      | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 11. | PFOH            | 19.22                             | 13.03   | 4.55    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 36.8     |
| 12. | LR PF (MW)      | 103.61                            | 403.77  | 403.65  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 246.99   |
| 13. | PMOH            | 26.72                             | 30.68   | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 57.4     |
| 14. | LR PM (MW)      | 403.63                            | 403.74  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 403.69   |
| 15. | NSC             | 1211                              | 1211    | 1211    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1211     |
| 16. | OPER BTU (MBTU) | 3383118                           | 3677733 | 4386340 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 11447190 |
| 17. | NET GEN         | 480482                            | 519788  | 624947  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1625217  |
| 18. | ANOHR (BTU/KWH) | 7041                              | 7075    | 7019    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7043     |
| 19. | NOF (%)         | 53.3                              | 63.9    | 69.5    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 62.2     |
| 20. | NPC (MW)        | 1211                              | 1211    | 1211    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1211     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0                      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: FORT MYERS 02 |         |         |     |     |     |     |     |     |     |     | PFM 02 |          |
|-----|-----------------|-----------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                         | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 94.9                        | 88.9    | 69.2    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 84.2     |
| 2.  | PH              | 744                         | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 3.  | SH              | 744                         | 647.48  | 615.52  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2007     |
| 4.  | RSH             | 0                           | 24.52   | 81.07   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 105.58   |
| 5.  | UH              | 0                           | 0       | 46.41   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 46.42    |
| 6.  | POH             | 0                           | 0       | 46.42   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 46.42    |
| 7.  | FOH             | 0                           | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 8.  | MOH             | 0                           | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 9.  | PPOH            | 0                           | 72.75   | 233.17  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 305.92   |
| 10. | LR PP (MW)      | 0                           | 1341.93 | 1285.11 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1298.62  |
| 11. | PFOH            | 0                           | 1.23    | 8.07    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 9.3      |
| 12. | LR PF (MW)      | 0                           | 289.31  | 288.41  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 288.53   |
| 13. | PMOH            | 197.95                      | 117.23  | 58.25   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 373.43   |
| 14. | LR PM (MW)      | 331.67                      | 268.69  | 231.42  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 296.26   |
| 15. | NSC             | 1730                        | 1730    | 1730    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1730     |
| 16. | OPER BTU (MBTU) | 4939594                     | 4603573 | 4487155 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 14030322 |
| 17. | NET GEN         | 697380                      | 645203  | 615084  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1957667  |
| 18. | ANOHR (BTU/KWH) | 7083                        | 7135    | 7295    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7167     |
| 19. | NOF (%)         | 54.2                        | 57.6    | 57.8    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 56.4     |
| 20. | NPC (MW)        | 1730                        | 1730    | 1730    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1730     |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM



**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: ST LUCIE 01 PSL 01 |         |         |     |     |     |     |     |     |     |     |     |          |
|-----|-----------------|----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                              | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAF (%)         | 100                              | 100     | 100     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 100      |
| 2.  | PH              | 744                              | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2159     |
| 3.  | SH              | 744                              | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2159     |
| 4.  | RSH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 5.  | UH              | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 6.  | POH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 7.  | FOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 8.  | MOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 9.  | PPOH            | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. | LR PP (MW)      | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. | PFOH            | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 12. | LR PF (MW)      | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 13. | PMOH            | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 14. | LR PM (MW)      | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 15. | NSC             | 981                              | 981     | 981     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 981      |
| 16. | OPER BTU (MBTU) | 7662219                          | 6919923 | 7650883 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 22233025 |
| 17. | NET GEN         | 749483                           | 675728  | 746384  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2171595  |
| 18. | ANOHR (BTU/KWH) | 10223                            | 10241   | 10251   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 10238    |
| 19. | NOF (%)         | 102.7                            | 102.5   | 102.4   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 102.5    |
| 20. | NPC (MW)        | 981                              | 981     | 981     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 981      |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: ST LUCIE 02 PSL 02 |         |         |     |     |     |     |     |     |     |     |     |          |
|-----|-----------------|----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                              | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAF (%)         | 87.9                             | 100     | 100     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 95.8     |
| 2.  | PH              | 744                              | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2159     |
| 3.  | SH              | 669.15                           | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2084.15  |
| 4.  | RSH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 5.  | UH              | 74.85                            | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 74.85    |
| 6.  | POH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 7.  | FOH             | 74.85                            | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 74.85    |
| 8.  | MOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 9.  | PPOH            | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. | LR PP (MW)      | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. | PFOH            | 59.42                            | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 59.42    |
| 12. | LR PF (MW)      | 246.03                           | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 246.03   |
| 13. | PMOH            | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 14. | LR PM (MW)      | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 15. | NSC             | 987                              | 987     | 987     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 987      |
| 16. | OPER BTU (MBTU) | 6763261                          | 6920022 | 7651600 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 21334883 |
| 17. | NET GEN         | 664473                           | 684363  | 755480  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2104316  |
| 18. | ANOHR (BTU/KWH) | 10178                            | 10112   | 10128   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 10139    |
| 19. | NOF (%)         | 100.6                            | 103.2   | 103     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 102.3    |
| 20. | NPC (MW)        | 987                              | 987     | 987     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 987      |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: TURKEY POINT 03 |         |         |     |     |     |     |     |     |     |     | PTN 03 |          |
|-----|-----------------|-------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                           | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 97                            | 89.3    | 87.6    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 91.4     |
| 2.  | PH              | 744                           | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 3.  | SH              | 744                           | 672     | 660.82  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2076.82  |
| 4.  | RSH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 5.  | UH              | 0                             | 0       | 82.18   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 82.18    |
| 6.  | POH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 7.  | FOH             | 0                             | 0       | 82.18   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 82.18    |
| 8.  | MOH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 9.  | PPOH            | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 10. | LR PP (MW)      | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 11. | PFOH            | 54.38                         | 158.05  | 44.42   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 256.85   |
| 12. | LR PF (MW)      | 347.48                        | 380.52  | 188.03  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 340.24   |
| 13. | PMOH            | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 14. | LR PM (MW)      | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 15. | NSC             | 837                           | 837     | 837     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 837      |
| 16. | OPER BTU (MBTU) | 6517834                       | 5462918 | 5859202 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 17839954 |
| 17. | NET GEN         | 628984                        | 519762  | 566274  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1715020  |
| 18. | ANOHR (BTU/KWH) | 10362                         | 10510   | 10347   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 10402    |
| 19. | NOF (%)         | 101                           | 92.4    | 102.4   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 98.7     |
| 20. | NPC (MW)        | 837                           | 837     | 837     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 837      |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: TURKEY POINT 04 |         |         |     |     |     |     |     |     |     |     | PTN 04 |          |
|-----|-----------------|-------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                           | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 100                           | 100     | 93.6    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 97.8     |
| 2.  | PH              | 744                           | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 3.  | SH              | 744                           | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 4.  | RSH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 5.  | UH              | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 6.  | POH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 7.  | FOH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 8.  | MOH             | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 9.  | PPOH            | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 10. | LR PP (MW)      | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 11. | PFOH            | 0                             | 0       | 195.05  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 195.05   |
| 12. | LR PF (MW)      | 0                             | 0       | 207.02  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 207.02   |
| 13. | PMOH            | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 14. | LR PM (MW)      | 0                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 15. | NSC             | 844                           | 844     | 844     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 844      |
| 16. | OPER BTU (MBTU) | 6706472                       | 6055728 | 6259302 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 19021501 |
| 17. | NET GEN         | 658066                        | 592559  | 606798  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1857423  |
| 18. | ANOHR (BTU/KWH) | 10191                         | 10220   | 10315   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 10241    |
| 19. | NOF (%)         | 104.8                         | 104.5   | 96.8    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 101.9    |
| 20. | NPC (MW)        | 844                           | 844     | 844     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 844      |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0                      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: WEST COUNTY ENER 01 |         |         |     |     |     |     |     |     |     |     | PWC 01 |          |
|-----|-----------------|-----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                               | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 77.3                              | 94.8    | 97.5    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 89.7     |
| 2.  | PH              | 744                               | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159     |
| 3.  | SH              | 641.87                            | 659.92  | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2044.78  |
| 4.  | RSH             | 36.12                             | 12.08   | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 48.2     |
| 5.  | UH              | 66.01                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 66.02    |
| 6.  | POH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 7.  | FOH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 8.  | MOH             | 66.02                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 66.02    |
| 9.  | PPOH            | 168                               | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 168      |
| 10. | LR PP (MW)      | 510.36                            | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 510.36   |
| 11. | PFOH            | 11.22                             | 17.7    | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 28.92    |
| 12. | LR PF (MW)      | 388.81                            | 427.43  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 412.45   |
| 13. | PMOH            | 71.92                             | 86.37   | 54.63   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 212.92   |
| 14. | LR PM (MW)      | 493.31                            | 407.66  | 407.67  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 436.6    |
| 15. | NSC             | 1223                              | 1223    | 1223    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1223     |
| 16. | OPER BTU (MBTU) | 2589979                           | 3398043 | 4362222 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 10350244 |
| 17. | NET GEN         | 355588                            | 485337  | 631612  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1472537  |
| 18. | ANOHR (BTU/KWH) | 7284                              | 7001    | 6906    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7029     |
| 19. | NOF (%)         | 45.3                              | 60.1    | 69.5    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 58.9     |
| 20. | NPC (MW)        | 1223                              | 1223    | 1223    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1223     |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: WEST COUNTY ENER 02 |         |         |     |     |     |     |     |     |     |     | PWC 02 |         |
|-----|-----------------|-----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|---------|
|     |                 | Jan                               | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd     |
| 1.  | EAF (%)         | 95.3                              | 99.9    | 54.2    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 82.6    |
| 2.  | PH              | 744                               | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 3.  | SH              | 707.58                            | 672     | 500.25  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1879.83 |
| 4.  | RSH             | 36.42                             | 0       | 233     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 269.42  |
| 5.  | UH              | 0                                 | 0       | 9.75    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 9.75    |
| 6.  | POH             | 0                                 | 0       | 9.75    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 9.75    |
| 7.  | FOH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 8.  | MOH             | 0                                 | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 9.  | PPOH            | 0                                 | 0       | 664.35  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 664.35  |
| 10. | LR PP (MW)      | 0                                 | 0       | 608.08  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 608.08  |
| 11. | PFOH            | 9.62                              | 0.98    | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 10.6    |
| 12. | LR PF (MW)      | 447.96                            | 483.64  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 451.25  |
| 13. | PMOH            | 95.28                             | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 95.28   |
| 14. | LR PM (MW)      | 407.68                            | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 407.68  |
| 15. | NSC             | 1223                              | 1223    | 1223    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1223    |
| 16. | OPER BTU (MBTU) | 3036070                           | 3762836 | 2345129 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 9144035 |
| 17. | NET GEN         | 423516                            | 543264  | 335679  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1302459 |
| 18. | ANOHR (BTU/KWH) | 7169                              | 6926    | 6986    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7021    |
| 19. | NOF (%)         | 48.9                              | 66.1    | 54.9    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 56.7    |
| 20. | NPC (MW)        | 1223                              | 1223    | 1223    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1223    |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0                      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: TURKEY POINT #5 05 |         |         |     |     |     |     |     |     |     |     | TP5 05 |         |
|-----|-----------------|----------------------------------|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|---------|
|     |                 | Jan                              | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd     |
| 1.  | EAF (%)         | 77.5                             | 97.8    | 32.8    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 68.4    |
| 2.  | PH              | 744                              | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 3.  | SH              | 545.95                           | 615.52  | 283.38  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1444.85 |
| 4.  | RSH             | 75.68                            | 56.48   | 1.4     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 133.57  |
| 5.  | UH              | 122.37                           | 0       | 458.22  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 580.58  |
| 6.  | POH             | 0                                | 0       | 458.22  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 458.22  |
| 7.  | FOH             | 0                                | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 8.  | MOH             | 105.98                           | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 105.98  |
| 9.  | PPOH            | 0                                | 0       | 48.43   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 48.43   |
| 10. | LR PP (MW)      | 0                                | 0       | 541.69  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 541.69  |
| 11. | PFOH            | 35.28                            | 55.38   | 1.43    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 92.1    |
| 12. | LR PF (MW)      | 726.95                           | 339.72  | 314.73  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 487.63  |
| 13. | PMOH            | 162.07                           | 0       | 79.38   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 241.45  |
| 14. | LR PM (MW)      | 315.62                           | 0       | 314.01  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 315.09  |
| 15. | NSC             | 1256                             | 1256    | 1256    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1256    |
| 16. | OPER BTU (MBTU) | 1936233                          | 2624166 | 1524750 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 6085149 |
| 17. | NET GEN         | 248456                           | 361852  | 213453  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 823761  |
| 18. | ANOHR (BTU/KWH) | 7793                             | 7252    | 7143    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7387    |
| 19. | NOF (%)         | 36.2                             | 46.8    | 60      | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 45.4    |
| 20. | NPC (MW)        | 1256                             | 1256    | 1256    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1256    |

|     |                |                                       |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0 B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2021 TO: Dec-2021**

|     |                 | PLANT / UNIT: SANFORD 4 & 5 CC 05                          |         |         |     |     |     |     |     |     |     |     | PSR 05 |         |
|-----|-----------------|--|---------|---------|-----|-----|-----|-----|-----|-----|-----|-----|--------|---------|
|     |                 | Jan  | Feb     | Mar     | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd     |
| 1.  | EAF (%)         | 97.3   | 98.7    | 61.1    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 85.3    |
| 2.  | PH              | 744  | 672     | 743     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 2159    |
| 3.  | SH              | 614.72   | 568.23  | 369.52  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1552.47 |
| 4.  | RSH             | 129.28   | 103.77  | 89.58   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 322.63  |
| 5.  | UH              | 0  | 0       | 283.9   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 283.9   |
| 6.  | POH             | 0  | 0       | 283.9   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 283.9   |
| 7.  | FOH             | 0  | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 8.  | MOH             | 0  | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0       |
| 9.  | PPOH            | 0  | 0       | 19.22   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 19.22   |
| 10. | LR PP (MW)      | 0  | 0       | 286.7   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 286.7   |
| 11. | PFOH            | 33.18  | 3.17    | 1.9     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 38.25   |
| 12. | LR PF (MW)      | 286.78   | 357.75  | 340.97  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 295.35  |
| 13. | PMOH            | 47   | 32.18   | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 79.18   |
| 14. | LR PM (MW)      | 286.75   | 286.78  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 286.76  |
| 15. | NSC             | 1147   | 1147    | 1147    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1147    |
| 16. | OPER BTU (MBTU) | 2459527  | 2228022 | 1530755 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 6218304 |
| 17. | NET GEN         | 336278   | 305435  | 211997  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 853710  |
| 18. | ANOHR (BTU/KWH) | 7314   | 7295    | 7221    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7284    |
| 19. | NOF (%)         | 47.7   | 46.9    | 50      | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 47.9    |
| 20. | NPC (MW)        | 1147   | 1147    | 1147    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1147    |
| 21. | ANOHR EQUATION  | ANOHR = A + B (N.O.F.)<br>A = 0                      B = 0 |         |         |     |     |     |     |     |     |     |     |        |         |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.



**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2021 To: Dec-2021**  
**PLANT / UNIT: CAPE CANAVERAL 03 PCC 03**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 01/11/2021 | FMO            | 116.3 | 275           | PCC 3-3 SNO Tube Leak Repair                         |
| 01/11/2021 | PMO            | 116.3 | 161.03        | Impact loss due to curtailment on 33                 |
| 01/13/2021 | FPO            | 420.7 | 275           | PCC 3-2 Project 39310 2021 CT - ROLL-OUT/ROLL-IN     |
| 01/13/2021 | PPO            | 420.7 | 160.98        | Impact loss due to curtailment on 32                 |
| 01/23/2021 | FFO            | 1.9   | 275           | PCC 3-3 EFOR Turbine Speed Monitor                   |
| 01/23/2021 | PFO            | 1.9   | 161.03        | Impact loss due to curtailment on 33                 |
| 02/12/2021 | FMO            | 111.6 | 275           | PCC 3-2 SNO Tube Leak Repair                         |
| 02/12/2021 | PMO            | 111.6 | 160.98        | Impact loss due to curtailment on 32                 |
| 02/15/2021 | FPO            | 249.2 | 275           | PCC 3-3 PROJ 45930 Reliability                       |
| 02/15/2021 | PPO            | 249.2 | 161.03        | Impact loss due to curtailment on 33                 |
| 02/19/2021 | FMO            | 114.7 | 275           | PCC 3-2 SNO AIG Inspect and Clean                    |
| 02/19/2021 | PMO            | 114.7 | 160.98        | Impact loss due to curtailment on 32                 |
| 03/12/2021 | FFO            | 0.8   | 275           | PCC 3-1 EFOR Failed Start - SFC breaker didn't close |
| 03/12/2021 | PFO            | 0.8   | 160.98        | Impact loss due to curtailment on 31                 |
| 03/15/2021 | FFO            | 1.4   | 275           | PCC 3-1 EFOR Failed Start High Temp Spread           |
| 03/15/2021 | PFO            | 1.4   | 160.98        | Impact loss due to curtailment on 31                 |
| 03/19/2021 | FMO            | 202.9 | 275           | PCC 3-2 SNO AIG inspection and repair                |
| 03/19/2021 | PMO            | 202.9 | 160.98        | Impact loss due to curtailment on 32                 |
| 03/27/2021 | FFO            | 1.6   | 275           | PCC 3-3 EFOR BAB36 Position Fault                    |
| 03/27/2021 | PFO            | 1.6   | 161.03        | Impact loss due to curtailment on 33                 |

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2021 To: Dec-2021**  
**PLANT / UNIT: PORT EVERGLADES 05 PPE 05**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 01/02/2021 | FFO            | 0.5   | 275.33        | 52 EFOR - GV2 Cooling Air Valve failed             |
| 01/02/2021 | PFO            | 0.5   | 142.65        | Impact loss due to curtailment on 52               |
| 01/02/2021 | FFO            | 1.3   | 275.33        | 53 EFOR - ESV failed to open                       |
| 01/02/2021 | PFO            | 1.3   | 142.7         | Impact loss due to curtailment on 53               |
| 01/08/2021 | FMO            | 24.0  | 275.33        | 52 MOF - HP FW BV repairs                          |
| 01/08/2021 | PMO            | 24.0  | 142.65        | Impact loss due to curtailment on 52               |
| 01/14/2021 | FFO            | 1.1   | 275.33        | 51 EFOR - Blow Off Valve Limit Switch              |
| 01/14/2021 | PFO            | 1.1   | 142.65        | Impact loss due to curtailment on 51               |
| 01/16/2021 | FMO            | 24.0  | 275.33        | 53 Event MOF - LP Drum Level Control Valve repair  |
| 01/16/2021 | PMO            | 24.0  | 142.7         | Impact loss due to curtailment on 53               |
| 02/02/2021 | FFO            | 1.2   | 275.33        | 53 EFOR - High Blade Path Temp. Spread             |
| 02/02/2021 | PFO            | 1.2   | 142.7         | Impact loss due to curtailment on 53               |
| 02/03/2021 | PFO            | 2.0   | 108.33        | 51 Partial EFOR - HP blending valve failed to open |
| 02/07/2021 | FFO            | 1.3   | 275.33        | 53 EFOR - IP Drum Level High                       |
| 02/07/2021 | PFO            | 1.3   | 142.7         | Impact loss due to curtailment on 53               |
| 02/10/2021 | FFO            | 2.6   | 275.33        | 51 EFOR - HI-HI Dynamic Pressure                   |
| 02/10/2021 | PFO            | 2.6   | 142.65        | Impact loss due to curtailment on 51               |
| 02/19/2021 | FFO            | 1.3   | 275.33        | 53 EFOR - Vent Valve Pressure Error                |
| 02/19/2021 | PFO            | 1.3   | 142.7         | Impact loss due to curtailment on 53               |
| 03/18/2021 | FFO            | 48.0  | 275.33        | 52 - Tube Leak Caused Low HP Drum Level Trip       |
| 03/18/2021 | PFO            | 48.0  | 142.65        | Impact loss due to curtailment on 52               |
| 03/19/2021 | PPO            | 27.5  | 142.65        | Impact loss due to curtailment on 51               |
| 03/19/2021 | FPO            | 288.4 | 275.33        | 51 - 20 Day Block Outage - Spring 2021             |
| 03/20/2021 | PPO            | 7.7   | 142.65        | Impact loss due to curtailment on 52               |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: PORT EVERGLADES 05****PPE 05**

| <b>DATE</b> | <b>OUTAGE<br/>TYPE(1)</b> | <b>HOURS</b> | <b>(MW)<br/>AFFECTED</b> | <b>DESCRIPTION</b>                     |
|-------------|---------------------------|--------------|--------------------------|--|
| 03/20/2021  | FPO                       | 268.6        | 275.33                   | 52 - 20 Day Block Outage - Spring 2021 |
| 03/21/2021  | FPO                       | 260.9        | 428                      | ST - 20 Day Block Outage               |
| 03/21/2021  | FPO                       | 259.4        | 275.33                   | 53 - 20 Day Block Outage               |

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: RIVIERA****05****PRV 05**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>   |
|-------------|-----------------------|--------------|----------------------|--|
| 02/16/2021  | FFO                   | 26.1         | 275                  | PRV 52 EFOR / Full Forced - High Lube Oil dP               |
| 02/16/2021  | PFO                   | 26.1         | 160.98               | Impact loss due to curtailment on 52                       |
| 02/18/2021  | FMO                   | 95.1         | 275                  | PRV 52 Event MOF - High Lube Oil dP                        |
| 02/18/2021  | PMO                   | 95.1         | 160.98               | Impact loss due to curtailment on 52                       |
| 02/22/2021  | FPO                   | 683.8        | 275                  | PRV 52 POF - Combustor Inspection and Rotor Re-tension     |
| 02/22/2021  | PPO                   | 683.8        | 160.98               | Impact loss due to curtailment on 52                       |
| 02/27/2021  | FFO                   | 3.1          | 275                  | PRV 51 EFOR / Start-up Failure - High Turbine Outlet Temp  |
| 02/27/2021  | PFO                   | 3.1          | 160.98               | Impact loss due to curtailment on 51                       |
| 03/22/2021  | FPO                   | 37.0         | 275                  | PRV 52 POF - Combustor Inspection and Rotor Re-tension, Bz |
| 03/22/2021  | PPO                   | 37.0         | 160.98               | Impact loss due to curtailment on 52                       |
| 03/26/2021  | PPO                   | 2.3          | 160.98               | Impact loss due to curtailment on 51                       |
| 03/26/2021  | FPO                   | 123.1        | 275                  | PRV 51, POF, Combustor Inspection with Modified Hot Gas Pε |
| 03/26/2021  | PPO                   | 0.9          | 161.03               | Impact loss due to curtailment on 53                       |
| 03/26/2021  | FPO                   | 121.7        | 275                  | PRV 53, POF, Combustor Inspection with CVC Upgrade         |
| 03/26/2021  | FPO                   | 120.8        | 483                  | PRV 5ST, POF, Steam Turbine Valve Outage and Generator M   |
| 03/26/2021  | FPO                   | 120.3        | 275                  | PRV 52, POF, Combustor Inspection with CVC Upgrade         |

- (1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: WEST COUNTY ENERGY 03****PWC 03**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>   |
|-------------|-----------------------|--------------|----------------------|--|
| 01/02/2021  | FFO                   | 1.6          | 247                  | PWC 3A CT EFOR, CPFM Trip during shutdown                    |
| 01/02/2021  | PFO                   | 1.6          | 156.65               | Impact loss due to curtailment on 3A                         |
| 01/09/2021  | FMO                   | 15.3         | 247                  | PWC 3C MOF, Gen Breaker 3W488 SF6 pressure low alarm r       |
| 01/09/2021  | PMO                   | 15.3         | 156.7                | Impact loss due to curtailment on 3C                         |
| 01/25/2021  | PFO                   | 17.7         | 77                   | PWC 3B EFOR, IP FW Relief Valve Leaking By                   |
| 01/30/2021  | FMO                   | 11.4         | 247                  | PWC 3B SNOW, IP Feedwater Block Valve Packing Leak           |
| 01/30/2021  | PMO                   | 11.4         | 156.65               | Impact loss due to curtailment on 3B                         |
| 02/03/2021  | FFO                   | 3.1          | 247                  | PWC 3C EFOR / Full Forced - Aux Cooling Steam Control Val    |
| 02/03/2021  | PFO                   | 3.1          | 156.7                | Impact loss due to curtailment on 3C                         |
| 02/13/2021  | FMO                   | 30.7         | 247                  | PWC 3C Event MOF - Cooling Steam Drain Line Leak             |
| 02/13/2021  | PMO                   | 30.7         | 156.7                | Impact loss due to curtailment on 3C                         |
| 02/27/2021  | FFO                   | 9.9          | 247                  | PWC 3A EFOR / Start-up Failure - No Flame Detected / Igniter |
| 02/27/2021  | PFO                   | 9.9          | 156.65               | Impact loss due to curtailment on 3A                         |
| 03/08/2021  | FFO                   | 4.4          | 247                  | PWC 3B EFOR / Full Forced - Software Reverse Power Trip      |
| 03/08/2021  | PFO                   | 4.4          | 156.65               | Impact loss due to curtailment on 3B                         |
| 03/23/2021  | FFO                   | 0.2          | 247                  | PWC 3A EFOR, CPFM Trip on shutdown Anti Icing valve devia    |
| 03/23/2021  | PFO                   | 0.2          | 156.65               | Impact loss due to curtailment on 3A                         |

- (1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2021 To: Dec-2021**  
**PLANT / UNIT: FORT MYERS 02 PFM 02**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                                    |
|------------|----------------|-------|---------------|--|
| 01/03/2021 | FMO            | 94.9  | 192.5         | PFM 2A (EVENT MOF) REPAIR GENERATOR BREAKER    |
| 01/03/2021 | PMO            | 94.9  | 72.65         | Impact loss due to curtailment on 2A           |
| 01/03/2021 | PMO            | 94.9  | 23.38         | Impact loss due to curtailment on 2A           |
| 01/06/2021 | FMO            | 52.6  | 192.5         | PFM2C Event MOF - BFP Alignment                |
| 01/06/2021 | PMO            | 52.6  | 72.65         | Impact loss due to curtailment on 2C           |
| 01/06/2021 | PMO            | 52.6  | 23.38         | Impact loss due to curtailment on 2C           |
| 01/13/2021 | FMO            | 19.4  | 192.5         | 2D (EVENT MOF) REPLACE SH 1 LOWER HEADER DRAIN |
| 01/13/2021 | PMO            | 19.4  | 72.65         | Impact loss due to curtailment on 2D           |
| 01/13/2021 | PMO            | 19.4  | 23.38         | Impact loss due to curtailment on 2D           |
| 01/14/2021 | FMO            | 19.0  | 192.5         | 2E CT EVENT MOF - REPLACE ESGA-BV-447R         |
| 01/14/2021 | PMO            | 19.0  | 72.65         | Impact loss due to curtailment on 2E           |
| 01/14/2021 | PMO            | 19.0  | 23.38         | Impact loss due to curtailment on 2E           |
| 01/19/2021 | FMO            | 41.7  | 192.5         | 2C (EVENT MOF) Verify HP/IP BFP alignment.     |
| 01/19/2021 | PMO            | 41.7  | 72.65         | Impact loss due to curtailment on 2C           |
| 01/19/2021 | PMO            | 41.7  | 23.38         | Impact loss due to curtailment on 2C           |
| 02/02/2021 | FFO            | 0.8   | 192.5         | PFM 2C EFOR - BFP tripped low flow             |
| 02/02/2021 | PFO            | 0.8   | 72.65         | Impact loss due to curtailment on 2C           |
| 02/02/2021 | PFO            | 0.8   | 23.38         | Impact loss due to curtailment on 2C           |
| 02/10/2021 | FMO            | 43.6  | 192.5         | PFM 2F Task MOF - HP/IP BFP Alignment          |
| 02/10/2021 | PMO            | 43.6  | 72.65         | Impact loss due to curtailment on 2F           |
| 02/10/2021 | PMO            | 43.6  | 23.38         | Impact loss due to curtailment on 2F           |
| 02/15/2021 | FFO            | 0.4   | 192.5         | PFM 2D EFOR 89ND failed to open                |
| 02/15/2021 | PFO            | 0.4   | 72.65         | Impact loss due to curtailment on 2D           |
| 02/15/2021 | PFO            | 0.4   | 23.38         | Impact loss due to curtailment on 2D           |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2021 To: Dec-2021**  
**PLANT / UNIT: FORT MYERS 02 PFM 02**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                                 |
|------------|----------------|-------|---------------|---|
| 02/23/2021 | PMO            | 49.4  | 23.38         | Impact loss due to curtailment on 2E        |
| 02/23/2021 | PMO            | 49.5  | 72.65         | Impact loss due to curtailment on 2E        |
| 02/23/2021 | FMO            | 73.7  | 192.5         | 2E TASK MOF - Convert to Simple Cycle       |
| 02/25/2021 | FPO            | 352.3 | 140           | ST #1 POF                                   |
| 02/25/2021 | FPO            | 344.1 | 435           | ST #2 POF                                   |
| 02/25/2021 | FPO            | 337.6 | 192.5         | 2A POF                                      |
| 02/25/2021 | FPO            | 337.8 | 192.5         | 2F POF                                      |
| 02/25/2021 | FPO            | 338.8 | 192.5         | 2D POF                                      |
| 02/25/2021 | FPO            | 338.7 | 192.5         | 2C POF                                      |
| 03/06/2021 | FPO            | 47.8  | 192.5         | PFM 2E CT Planned outage                    |
| 03/06/2021 | FPO            | 46.4  | 192.5         | 2B CT POF                                   |
| 03/10/2021 | FMO            | 58.3  | 192.5         | 2B Task MOF - Combined cycle conversion     |
| 03/12/2021 | PMO            | 25.6  | 72.65         | Impact loss due to curtailment on 2B        |
| 03/12/2021 | PMO            | 17.4  | 23.38         | Impact loss due to curtailment on 2B        |
| 03/14/2021 | FFO            | 0.5   | 192.5         | PFM 2D Startup Failure 89ND Failure To Open |
| 03/14/2021 | PFO            | 0.5   | 72.65         | Impact loss due to curtailment on 2D        |
| 03/14/2021 | PFO            | 0.5   | 23.38         | Impact loss due to curtailment on 2D        |
| 03/24/2021 | FFO            | 2.0   | 192.5         | PFM 2C EFOR BFP tripped                     |
| 03/24/2021 | PFO            | 2.0   | 72.65         | Impact loss due to curtailment on 2C        |
| 03/24/2021 | PFO            | 2.0   | 23.38         | Impact loss due to curtailment on 2C        |
| 03/29/2021 | FFO            | 5.6   | 192.5         | PFM 2F CT EFOR GCV1 Tracking Fault          |
| 03/29/2021 | PFO            | 5.6   | 72.65         | Impact loss due to curtailment on 2F        |
| 03/29/2021 | PFO            | 5.6   | 23.38         | Impact loss due to curtailment on 2F        |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: ST LUCIE****02****PSL 02**

| <b>DATE</b> | <b>OUTAGE<br/>TYPE(1)</b> | <b>HOURS</b> | <b>(MW)<br/>AFFECTED</b> | <b>DESCRIPTION</b>                            |
|-------------|---------------------------|--------------|--------------------------|---|
| 01/14/2021  | PFO                       | 7.6          | 511.15                   | U2 UEL 2B2 4KV Breaker Down PWR 011421        |
| 01/14/2021  | FFO                       | 6.8          | 987                      | U2 UEL 2B2 4KV Breaker Offline Removal 011421 |
| 01/14/2021  | PFO                       | 39.1         | 154.37                   | U2 UEL 2B2 4KV Breaker Up Power 011421        |
| 01/20/2021  | FFO                       | 68.1         | 987                      | U2 UEL Auto Trip 2B2 MCC Trip 012021          |
| 01/23/2021  | PFO                       | 12.7         | 370.61                   | U2 UEL Auto Trip 2B2 MCC Trip Up Power 012321 |

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**



**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: TURKEY POINT 03****PTN 03**

| <b>DATE</b> | <b>OUTAGE<br/>TYPE(1)</b> | <b>HOURS</b> | <b>(MW)<br/>AFFECTED</b> | <b>DESCRIPTION</b>   |
|-------------|---------------------------|--------------|--------------------------|--|
| 01/01/2021  | PFO                       | 54.4         | 347.46                   | PYN Unit 3 Power ascension following condenser tube leak rej |
| 02/02/2021  | PFO                       | 158.1        | 380.52                   | PTN Unit 3 Unplanned power reduction due to condenser tube   |
| 03/01/2021  | FFO                       | 82.2         | 837                      | PTN Unit 3 Automatic Rx trip                                 |
| 03/04/2021  | PFO                       | 19.7         | 306.04                   | PTN Unit 3   |
| 03/24/2021  | PFO                       | 24.8         | 94.29                    | PYN Unit 3 Unplanned power sreduction due to turbine runbac  |

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: TURKEY POINT 04****PTN 04**

| <b>DATE</b> | <b>OUTAGE<br/>TYPE(1)</b> | <b>HOURS</b> | <b>(MW)<br/>AFFECTED</b> | <b>DESCRIPTION</b>   |
|-------------|---------------------------|--------------|--------------------------|--|
| 03/15/2021  | PFO                       | 195.1        | 207.02                   | PTN Unit 4 Power reduction to replace Condensate pump motr |

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: WEST COUNTY ENERGY 01****PWC 01**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>  |
|-------------|-----------------------|--------------|----------------------|---|
| 01/01/2021  | FPO                   | 2.7          | 482                  | PWC 1ST POF - Major Overhaul                                |
| 01/01/2021  | FPO                   | 11.6         | 247                  | PWC 1B POF - U1 ST Major Overhaul                           |
| 01/01/2021  | FPO                   | 13.9         | 247                  | PWC 1A POF - U1 ST Major Overhaul                           |
| 01/01/2021  | PPO                   | 5.2          | 160.65               | Impact loss due to curtailment on 1B                        |
| 01/01/2021  | PPO                   | 7.4          | 160.65               | Impact loss due to curtailment on 1A                        |
| 01/01/2021  | FPO                   | 3.7          | 482                  | PWC 1ST POF - Major Overhaul / Testing                      |
| 01/01/2021  | FPO                   | 156.4        | 247                  | PWC 1B POF Extension - Fuel Gas System Inspection           |
| 01/01/2021  | PPO                   | 156.4        | 160.65               | Impact loss due to curtailment on 1B                        |
| 01/01/2021  | FPO                   | 15.0         | 247                  | PWC 1C POF - U1 ST Major Overhaul / CT Tuning               |
| 01/01/2021  | PPO                   | 15.0         | 160.7                | Impact loss due to curtailment on 1C                        |
| 01/02/2021  | FPO                   | 11.0         | 247                  | PWC 1A POF - U1 ST Major Overhaul / CT Testing              |
| 01/02/2021  | PPO                   | 11.0         | 160.65               | Impact loss due to curtailment on 1A                        |
| 01/08/2021  | FMO                   | 97.4         | 247                  | PWC 1C MOF, Condensate Relief Valve and Recirc Valve Rep    |
| 01/08/2021  | PMO                   | 28.2         | 160.7                | Impact loss due to curtailment on 1C                        |
| 01/08/2021  | FMO                   | 69.2         | 482                  | PWC 1ST MOF, Condensate Recirc Valve Repairs                |
| 01/08/2021  | FMO                   | 107.5        | 247                  | PWC 1B MOF, Condensate Recirc Valve Repairs                 |
| 01/08/2021  | FMO                   | 66.0         | 247                  | PWC 1A MOF, Condensate Recirc Valve Repairs                 |
| 01/11/2021  | PMO                   | 38.3         | 160.65               | Impact loss due to curtailment on 1B                        |
| 01/15/2021  | FFO                   | 10.0         | 247                  | PWC 1A EFOR, Failure to Sync - Reverse Power Trip           |
| 01/15/2021  | PFO                   | 10.0         | 160.65               | Impact loss due to curtailment on 1A                        |
| 01/30/2021  | FMO                   | 13.0         | 247                  | PWC 1C SNOW, CT Anti-Icing Temperature Control Valve act.   |
| 01/30/2021  | PMO                   | 13.0         | 160.7                | Impact loss due to curtailment on 1C                        |
| 01/30/2021  | PFO                   | 1.2          | 235                  | PWC 1A EFOR, Startup Load Limit Raise Signal Inhibited      |
| 02/03/2021  | FFO                   | 13.0         | 247                  | PWC 1C EFOR / Start-up Failure - FG Valve Testing / Overspe |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: WEST COUNTY ENERGY 01****PWC 01**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>                                       |
|-------------|-----------------------|--------------|----------------------|--|
| 02/03/2021  | PFO                   | 13.0         | 160.7                | Impact loss due to curtailment on 1C                     |
| 02/04/2021  | FMO                   | 20.8         | 247                  | PWC 1C Event MOF - Anti-Icing Temp Control Valve Issue   |
| 02/04/2021  | PMO                   | 20.8         | 160.7                | Impact loss due to curtailment on 1C                     |
| 02/12/2021  | FMO                   | 35.1         | 247                  | PWC 1A Event MOF - TCA Feedwater Relief Valve            |
| 02/12/2021  | PMO                   | 35.1         | 160.65               | Impact loss due to curtailment on 1A                     |
| 02/18/2021  | FFO                   | 4.7          | 482                  | PWC 1ST EFOR / Full Forced - Reheat Stop Valve A EHC Lea |
| 02/19/2021  | FMO                   | 30.5         | 247                  | PWC 1C Event MOF - Feedwater Sensing Line Leak           |
| 02/19/2021  | PMO                   | 30.5         | 160.7                | Impact loss due to curtailment on 1C                     |
| 03/05/2021  | FMO                   | 54.6         | 247                  | PWC 1B Event MOF - Cooling Steam Leaks                   |
| 03/05/2021  | PMO                   | 54.6         | 160.65               | Impact loss due to curtailment on 1B                     |

- (1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: WEST COUNTY ENERGY 02****PWC 02**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>  |
|-------------|-----------------------|--------------|----------------------|---|
| 01/13/2021  | FFO                   | 5.2          | 482                  | PWC 2ST EFOR, ST Trip on startup due to high bearing vibrat |
| 01/19/2021  | FMO                   | 60.9         | 247                  | PWC 2A SNOW, Replace Ammonia Blower Fan                     |
| 01/19/2021  | PMO                   | 60.9         | 160.65               | Impact loss due to curtailment on 2A                        |
| 01/29/2021  | FMO                   | 34.4         | 247                  | PWC 2C, SNOW Generator Breaker Trip Coil Alarm Relay Reç    |
| 01/29/2021  | PMO                   | 34.4         | 160.7                | Impact loss due to curtailment on 2C                        |
| 01/29/2021  | FFO                   | 4.4          | 247                  | PWC 2A EFOR, Cooling Steam Presure Regulating Valve Fail    |
| 01/29/2021  | PFO                   | 4.4          | 160.65               | Impact loss due to curtailment on 2A                        |
| 02/14/2021  | FFO                   | 1.0          | 482                  | PWC 2ST EFOR / Full Forced - Loss of Vacuum                 |
| 03/03/2021  | PPO                   | 431.0        | 160.65               | Impact loss due to curtailment on 2B                        |
| 03/03/2021  | FPO                   | 441.1        | 247                  | PWC 2B POF, Annual Reliability CT Boroscope Inspection      |
| 03/21/2021  | PPO                   | 1.4          | 160.65               | Impact loss due to curtailment on 2A                        |
| 03/21/2021  | FPO                   | 244.4        | 247                  | PWC 2A POF, Annual Reliability CT Boroscope Inspection      |
| 03/21/2021  | FPO                   | 243.1        | 482                  | PWC 2ST POF, ST and BOP Annual Reliability                  |
| 03/21/2021  | FPO                   | 242.8        | 247                  | PWC 2C POF, Annual Reliability CT Boroscope Inspection      |

- (1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: TURKEY POINT #5 05****TP5 05**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>  |
|-------------|-----------------------|--------------|----------------------|---|
| 01/04/2021  | PMO                   | 4.0          | 122                  | Impact loss due to curtailment on 5C                          |
| 01/04/2021  | FMO                   | 86.2         | 192                  | PTF CT 5C MOF - Block SNOW                                    |
| 01/05/2021  | FMO                   | 87.1         | 488                  | PTF 5ST MOF - Block SNOW                                      |
| 01/05/2021  | FMO                   | 122.0        | 192                  | PTF CT 5D MOF - Block SNOW                                    |
| 01/05/2021  | FMO                   | 82.8         | 192                  | PTF CT 5B MOF - Block SNOW                                    |
| 01/05/2021  | FMO                   | 82.2         | 192                  | PTF CT 5A MOF - Block SNOW                                    |
| 01/08/2021  | PMO                   | 35.0         | 122                  | Impact loss due to curtailment on 5D                          |
| 01/22/2021  | FFO                   | 6.4          | 192                  | PTF CT 5C Start Up Failure - Atomizing Air Pressure Ratio Lov |
| 01/22/2021  | PFO                   | 6.4          | 122                  | Impact loss due to curtailment on 5C                          |
| 01/24/2021  | PMO                   | 100.6        | 122                  | Impact loss due to curtailment on 5D                          |
| 01/24/2021  | FMO                   | 118.0        | 192                  | PTF CT 5D MOF - HRSG Tube Leak Repairs                        |
| 01/24/2021  | FFO                   | 16.9         | 488                  | PTF 5ST Forced Outage - CRH Safety Relief Valve               |
| 01/24/2021  | FFO                   | 16.9         | 192                  | PTF CT 5A Forced Outage - CRH Safety Relief Valve             |
| 01/24/2021  | FFO                   | 16.4         | 192                  | PTF CT 5B Forced Outage - CRH Safety Relief Valve             |
| 01/24/2021  | FFO                   | 16.4         | 192                  | PTF CT 5C Forced Outage - CRH Safety Relief Valve             |
| 01/28/2021  | FMO                   | 24.5         | 488                  | PTF 5ST MOF - Block SNOW                                      |
| 01/28/2021  | FMO                   | 24.2         | 192                  | PTF CT 5A MOF - Block SNOW                                    |
| 01/28/2021  | FMO                   | 24.0         | 192                  | PTF CT 5B MOF - Block SNOW                                    |
| 01/28/2021  | FMO                   | 24.0         | 192                  | PTF CT 5D MOF - Block SNOW                                    |
| 01/28/2021  | FMO                   | 24.0         | 192                  | PTF CT 5C MOF - Block SNOW                                    |
| 01/30/2021  | FFO                   | 12.0         | 488                  | PTF 5ST Forced Outage - Collector Yard Breaker 52 Fail to Clr |
| 02/03/2021  | FFO                   | 7.9          | 192                  | PTF CT 5B Forced Outage - Ignitor Failure                     |
| 02/03/2021  | PFO                   | 7.9          | 122                  | Impact loss due to curtailment on 5B                          |
| 02/03/2021  | FFO                   | 4.5          | 192                  | PTF CT 5A Forced Outage - 89SS Failed to Close                |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: TURKEY POINT #5 05****TP5 05**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>                                     |
|-------------|-----------------------|--------------|----------------------|--|
| 02/03/2021  | PFO                   | 4.5          | 122                  | Impact loss due to curtailment on 5A                   |
| 02/05/2021  | FFO                   | 29.0         | 192                  | PTF CT 5C Forced Outage - Generator Lockout 86G - 27TN |
| 02/05/2021  | PFO                   | 29.0         | 122                  | Impact loss due to curtailment on 5C                   |
| 02/16/2021  | FFO                   | 12.5         | 192                  | PTF CT 5B Forced Outage - Ignitor Failure              |
| 02/16/2021  | PFO                   | 12.5         | 122                  | Impact loss due to curtailment on 5B                   |
| 02/17/2021  | FFO                   | 5.0          | 192                  | PTF CT 5D Forced Outage - PM1 Gas Control Valve        |
| 02/17/2021  | PFO                   | 5.0          | 122                  | Impact loss due to curtailment on 5D                   |
| 02/19/2021  | FFO                   | 1.0          | 192                  | PTF CT 5A Forced Outage - Turning Gear Failure         |
| 02/19/2021  | PFO                   | 1.0          | 122                  | Impact loss due to curtailment on 5A                   |
| 03/01/2021  | FPO                   | 52.8         | 192                  | PTF CT 5A POF - Annual Reliability Outage              |
| 03/01/2021  | FPO                   | 467.8        | 192                  | PTF CT 5C POF - Annual Reliability Outage              |
| 03/01/2021  | FPO                   | 470.5        | 192                  | PTF CT 5B POF - Annual Reliability Outage              |
| 03/01/2021  | FPO                   | 472.2        | 192                  | PTF CT 5D POF - Annual Reliability Outage              |
| 03/01/2021  | FPO                   | 474.6        | 488                  | PTF 5ST POF - Annual Reliability Outage                |
| 03/03/2021  | FPO                   | 444.3        | 192                  | PTF CT 5A POF - Annual Reliability Outage              |
| 03/20/2021  | PPO                   | 32.1         | 122                  | Impact loss due to curtailment on 5A                   |
| 03/23/2021  | FFO                   | 1.4          | 192                  | PTF CT 5D Forced Outage - 41SUS Main Breaker           |
| 03/23/2021  | PFO                   | 1.4          | 122                  | Impact loss due to curtailment on 5D                   |
| 03/26/2021  | FMO                   | 79.4         | 192                  | PTF CT 5A MOF - Lift Oil                               |
| 03/26/2021  | PMO                   | 79.4         | 122                  | Impact loss due to curtailment on 5A                   |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: SANFORD 4 & 5 CC 05****PSR 05**

| <b>DATE</b> | <b>OUTAGE TYPE(1)</b> | <b>HOURS</b> | <b>(MW) AFFECTED</b> | <b>DESCRIPTION</b>                                |
|-------------|-----------------------|--------------|----------------------|---|
| 01/07/2021  | FMO                   | 18.5         | 192                  | PSR 5C EVENT MOF - BFP LEAK REPAIR                |
| 01/07/2021  | PMO                   | 18.5         | 94.75                | Impact loss due to curtailment on 5C              |
| 01/08/2021  | FFO                   | 19.4         | 192                  | PSR 5A EFOR - STARTUP FAILURE - FUEL VALVE LEAK   |
| 01/08/2021  | PFO                   | 19.4         | 94.75                | Impact loss due to curtailment on 5A              |
| 01/10/2021  | FFO                   | 13.0         | 192                  | PSR 5A EFOR - STARTUP FAIL - GAS VALVE ISSUE      |
| 01/10/2021  | PFO                   | 13.0         | 94.75                | Impact loss due to curtailment on 5A              |
| 01/18/2021  | FFO                   | 0.8          | 192                  | PSR 5B EFOR - UNIT TRIP ON HIGH LP DRUM LEVEL     |
| 01/18/2021  | PFO                   | 0.8          | 94.75                | Impact loss due to curtailment on 5B              |
| 01/21/2021  | FMO                   | 28.5         | 192                  | PSR 5B EVENT MOF - REPLACE FUEL VALVE             |
| 01/21/2021  | PMO                   | 28.5         | 94.75                | Impact loss due to curtailment on 5B              |
| 02/05/2021  | FMO                   | 32.2         | 192                  | PSR 5D EVENT MOF- UNIT OFF TO CHANGE LIFT OIL HOS |
| 02/05/2021  | PMO                   | 32.2         | 94.75                | Impact loss due to curtailment on 5D              |
| 02/05/2021  | FFO                   | 0.7          | 192                  | PSR 5C MISSED RFC - UNIT MISSED RFC               |
| 02/05/2021  | PFO                   | 0.7          | 94.75                | Impact loss due to curtailment on 5C              |
| 02/10/2021  | FFO                   | 1.3          | 379                  | PSR 5ST EFOR - STARTUP FAILURE - TURBINE LATCH PR |
| 02/16/2021  | FFO                   | 1.1          | 379                  | PSR 5ST EFOR - STARTUP FAILURE - UNABLE TO LATCH  |
| 03/05/2021  | FFO                   | 1.1          | 379                  | PSR 5ST - EFOR- SYNCHRONIZATION ISSUE             |
| 03/11/2021  | FFO                   | 0.8          | 192                  | PSR 5B EFOR - NOT AVAILABLE - GAS YARD ISSUE      |
| 03/11/2021  | PFO                   | 0.8          | 94.75                | Impact loss due to curtailment on 5B              |
| 03/14/2021  | FPO                   | 283.9        | 379                  | PSR 5ST FULL PLANNED OUTAGE                       |
| 03/14/2021  | FPO                   | 283.9        | 192                  | PSR 5D FULL PLANNED OUTAGE                        |
| 03/14/2021  | FPO                   | 283.9        | 192                  | PSR 5C FULL PLANNED OUTAGE                        |
| 03/14/2021  | FPO                   | 283.9        | 192                  | PSR 5A FULL PLANNED OUTAGE                        |
| 03/14/2021  | FPO                   | 303.1        | 192                  | PSR 5B FULL PLANNED OUTAGE                        |

(1) **FFO - FULL FORCED OUTAGE**  
**PPO - PARTIAL PLANNED OUTAGE**  
**PMO - PARTIAL MAINTENANCE OUTAGE**  
**PO - PLANNED OUTAGE**  
**PFO - PARTIAL FORCED OUTAGE**  
**FMO - FULL MAINTENANCE OUTAGE**

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**



**ACTUAL PERFORMANCE DATA****COMPANY: FLORIDA POWER AND LIGHT****From: Jan-2021****To: Dec-2021****PLANT / UNIT: SANFORD 4 & 5 CC 05****PSR 05**

| <b>DATE</b> | <b>OUTAGE<br/>TYPE(1)</b> | <b>HOURS</b> | <b>(MW)<br/>AFFECTED</b> | <b>DESCRIPTION</b>                   |
|-------------|---------------------------|--------------|--------------------------|--------------------------------------|
| 03/25/2021  | PPO                       | 19.2         | 94.75                    | Impact loss due to curtailment on 5B |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

**FILED:**  
**SUSPENDED:**  
**EFFECTIVE:**  
**DOCKET NO.:**  
**ORDER NO.:**

**ISSUED BY: FLORIDA POWER & LIGHT CO.**

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS       | DESCRIPTION   |
|----------------|---|
| FTEs           | Full Time Equivalent Employees including: Headcount, O.T. i.e. Overtime, & Contractors  |
| "R"            | Mark VI "R" Processor   |
| 1A2            | Unit 1 Pump A2  |
| 1B             | Unit 1 Pump B   |
| 1SGG-ABV-7     | Ft. Myers Steam Turbine 1 steam inlet block valve (west side block valve)   |
| 2A             | Unit 2 Combustion Turbine (sub unit A)  |
| 2A CT - 2A 230 | Combustion Turbine (sub unit A) - 2A Collector Bus  |
| 2A HDP         | 2 Alpha High Differential Pressure  |
| 2B             | Unit 2 Combustion Turbine (sub unit B)  |
| 2B CT - 2A 230 | Combustion Turbine (sub unit B) - 2A Collector Bus  |
| 2B MSR         | 2 Bravo Moisture Separator Reheater   |
| 2B1            | Unit 2 Pump B1  |
| 2C             | Unit 2 Combustion Turbine (sub unit C)  |
| 2C CT - 2A 230 | Combustion Turbine (sub unit C) - 2A Collector Bus  |
| 2D             | Unit 2 Combustion Turbine (sub unit D)  |
| 2E             | Unit 2 Combustion Turbine (sub unit E)  |
| 2F             | Unit 2 Combustion Turbine (sub unit F)  |
| 3 CTB          | Unit 3 Combustion Turbine (sub unit B)  |
| 3A             | Unit 3 Combustion Turbine (sub unit A)  |
| 3B             | Unit 3 Combustion Turbine (sub unit B)  |
| 3C             | Unit 3 Combustion Turbine (sub unit C)  |
| 3D             | Unit 3 Combustion Turbine (sub unit D)  |
| 3SAR           | Three Step Aged Rotor   |
| 3ST            | Unit 3 Steam Turbine  |
| 41AC-1         | Breaker 1 for Power Supply to Exciter   |
| 41AC-2         | Breaker 2 for Power Supply to Exciter   |
| 4A             | Unit 4 Combustion Turbine (sub unit A)  |
| 4A SGFP        | 4A Steam Generator Feedwater Pump   |
| 4B             | Unit 4 Combustion Turbine (sub unit B)  |
| 4C             | Unit 4 Combustion Turbine (sub unit C)  |
| 4D             | Unit 4 Combustion Turbine (sub unit D)  |
| 4KV            | 4 Thousand Volts  |
| 5A             | Unit 5 Combustion Turbine (sub unit A)  |
| 5B             | Unit 5 Combustion Turbine (sub unit B)  |
| 5C             | Unit 5 Combustion Turbine (sub unit C)  |
| 5D             | Unit 5 Combustion Turbine (sub unit D)  |
| 5ST            | Unit 5 Steam Turbine  |
| 86G1           | Generator Protection Relay Lockout  |
| 89ND           | Neutral disconnect switch on the generator  |
| 89SS           | Static Start Switch   |
| 8A             | Unit 8 Combustion Turbine (sub unit A)  |
| 8B             | Unit 8 Combustion Turbine (sub unit B)  |
| 8C             | Unit 8 Combustion Turbine (sub unit C)  |
| 8D             | Unit 8 Combustion Turbine (sub unit D)  |
| 8X             | Unit 8 Steam Turbine  |
| A042           | Name given to the circular exhaust duct of the combustion turbine, before it transitions into the square inlet duct to the HRSG |

**GPIF Units**  
**Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS      | DESCRIPTION  |
|---------------|--|
| AA            | Anhydrous Ammonia  |
| AA Comp Disch | Atomizing Air Compressor Discharge   |
| AA HX         | Atomizing Air Heat Exchanger   |
| ABV           | Air Block Valve  |
| ACV 11        | Reverse Flow Valve in Auxiliary Steam Supply System  |
| ACV-3         | Automatic Control Valve # 3  |
| ACV-408       | Air Control Valve Tag 408  |
| AFW           | Auxiliary Feed Water   |
| AIG           | Ammonia Injection Grid   |
| ANOHR         | AVERAGE Net Operating Heat Rate  |
| ASGJ-BV-27ED  | A (unit 2A) SGJ (hot reheat to condenser) BV ( block valve) 27 (#) ED ( valve bypass)  |
| AUX           | Auxiliary  |
| AVR           | Automatic Voltage Regulator  |
| BAB36         | European designation for foundation mounted cabinet. 36 is the switch # located in that cabinet  |
| BBLs          | Barrels  |
| BFP           | Boiler Feed Pump   |
| BFPT          | Boiler Feed Pump Turbine   |
| BRG           | Bearing  |
| BRK           | Breaker  |
| BSGG          | Unit B, main steam section of HRSG   |
| BTU           | British Thermal Units  |
| CBV           | Compressor Bleed Valve   |
| CCW           | Closed Cooling Water   |
| CDM           | Combustion dynamics monitor  |
| CEA           | Control Element Assembly   |
| CEA 38        | Control Element Assembly Number 38   |
| CEA 65        | Control Element Assembly Number 65   |
| CED           | Compressor Exit Diffuser   |
| CEDM          | Control Element Drive Mechanism  |
| CEMS          | Continuous Emissions Monitoring System   |
| CF            | Capacity Factor  |
| Circ          | Circulating (water pump)   |
| com           | Communication  |
| comm          | Communication  |
| CPFM          | Combustor Pressure Fluctuation Monitor   |
| Cpk           | Process Capability Index – or process variability considering specs; ‘C <sub>pk</sub> should be 1.33 [4 sigma] or higher to satisfy most customers.’ |
| CPU#1         | Central Processing Unit #1   |
| CRH           | Cold Reheat  |
| CSGG-ABV-13   | Main Steam High Pressure Bypass Spray Isolation Valve  |
| CT            | Combustion Turbine   |
| CT C          | Combustion Turbine (sub unit C)  |
| CTG SRV       | Speed Ratio Valve on Combustion Turbine (gas system)   |
| CV-4-1510     | Control Valve Number 4-1510  |
| CVA           | Cyber (security) Vulnerability Assessment  |
| CW            | Circulating Water  |
| CWP           | Circulating Water Pump   |
| DCS           | Distributed Control System   |
| DEH           | Digital Electro Hydraulic  |
| DFS           | Debris Filtration System   |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS     | DESCRIPTION   |
|--------------|---|
| diff         | Differential  |
| DLN          | Dry Low Nox   |
| DP           | Differential Pressure   |
| DSH          | DeSuperHeater   |
| DSGA-ACV-408 | Ft. Myers 2D HP drum inlet feedwater control valve (HRSG – Heat Recovery Steam Generator) |
| DWATT        | Term used by General Electric as Auxiliary Megawatt Transducer                            |
| DWATT XDUCER | Megawatt transducer   |
| DX           | DeXcitation   |
| EAF          | Equivalent Availability Factor  |
| ECCS         | Emergency Core Cooling System   |
| EFOR         | Equivalent Forced Outage Rate   |
| EFPD         | Effective Full Power Days   |
| EHC          | Hydraulic   |
| EHD          | Enhanced Hot Day  |
| EJ           | Expansion Joint   |
| EOC          | End of cycle  |
| EPU          | Extended Power Uprate   |
| ESGA         | System code for Ft. Myers 2E HRSG   |
| ESGG         | System code for Ft. Myers 2E CT Main Steam (HP)   |
| ESV          | Emergency Stop Valves   |
| EXP          | Expansion   |
| Fa           | Failed  |
| FCBBS        | Florida Cost Based Broker System  |
| FENA         | Future Enterprise Network A   |
| FFO          | Full Forced Outage  |
| FGT          | Florida Gas Transmission  |
| FME          | Foreign Material Exclusion  |
| FMO          | Full Maintenance Outage   |
| FMPA         | Florida Municipal Power Agency  |
| FPI          | Fluorescent penetrant inspection  |
| FPO          | Full Planned Outage   |
| FPSC         | Florida Public Service Commission   |
| FRV          | Feedwater Regulating Valve  |
| FSGJ         | F is the unit (2F) SGJ is the system designator   |
| FSNL         | Full Speed No Load  |
| FW           | Feedwater   |
| FWA          | Boiler Feedwater  |
| FWC          | Feedwater Control   |
| GCV          | Gas Control Valve   |
| GE           | General Electric  |
| GPIF         | Generating Performance Incentive Factor   |
| GSU          | Generator Step Up   |
| GTE          | Generator Terminal Enclose  |
| GV2          | Cooling Valve   |
| Haz          | Hazardous   |
| HC           | Headcount   |
| HCO          | Hydraulic Clearance Optimization  |
| HDP          | Heater Drain Pump   |

**GPIF Units**  
**Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS | DESCRIPTION  |
|----------|--|
| HI       | High   |
| HMI      | Human Machine Interface  |
| HP       | High Pressure  |
| HRH      | Hot Reheat   |
| HRSG     | Heat Recovery Steam Generator                                      |
| HTF      | Heat Transfer Fluid  |
| I/O      | Input / Output   |
| IBH      | Inlet Bleed Heat Valve   |
| ID       | Induced Draft  |
| IGV      | Inlet guide vanes  |
| Instr.   | Instrumentation  |
| IP       | Intermediate Pressure  |
| IRP      | Integrated Resource Plan   |
| ISO      | Isolation  |
| kWh      | Kilowatt Hour  |
| LCI      | Load Commutating Inverter  |
| LCO      | Limiting Conditions for Operation                                  |
| LCV      | Level Control Valve  |
| LD       | Load   |
| LEFM     | Leading Edge Flow Meter  |
| LF       | Liquid Fuel  |
| LL       | Low Low  |
| LO       | Low  |
| LO       | Lube oil   |
| LOI      | Letter of Instruction  |
| LP       | Low Pressure   |
| LPSV     | Low Pressure Stop Valve  |
| LVDT     | Linear Variable Differential Transformer, essentially a positioner |
| MAJOR    | Major Overhaul   |
| MCC      | Motor Control Center   |
| MCF      | Million cubic feet   |
| MF PP    | Main Feed Pump   |
| MFIV     | Main Feed Isolation Valve  |
| MFW      | Main Feed Water  |
| MG       | Motor Generator  |
| MMBTU    | Million British Thermal Units                                      |
| MOF      | Maintenance Outage Factor  |
| MOF/AA   | Maintenance Outage Factor / Atomizing Air                          |
| MOV      | Motorized Operating Valve  |
| MP       | Main pressure  |
| MRE      | Manuel Reject  |
| MS       | Main Steam   |
| MS       | Main Steam   |
| MSIV     | Main Steam Isolation Valves  |
| MSR      | Moisture Separator Reheater  |
| MSSV     | Main Steam Safety Valve  |
| MTC      | Moderator Temperature Coefficient                                  |
| MTC      | Moderator Temperature Coefficient                                  |
| MUV      | Motor actuated <u>U</u> nidirectional <u>V</u> alve                |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS | DESCRIPTION  |
|----------|--|
| MW       | Megawatt   |
| MW       | Megawatt   |
| MWh      | Megawatt Hour  |
| ND       | Neutral Disconnect   |
| NEE      | NEXtera Energy   |
| NEL      | Net Energy for Load  |
| NHR      | Net Heat Rate  |
| NO       | No   |
| NSC      | Net Summer Continuous Capacity   |
| O/H      | Overhaul   |
| OBB      | Overboard bleed valve  |
| OLWW     | Off-Line Water Wash  |
| OMC      | Outside Management Control   |
| OS       | Off-system Sales   |
| OUC      | Orlando Utilities Commission   |
| P&C      | Protect and Control  |
| PDM      | Power Delivery Module  |
| PEL      | Planned Energy Loss  |
| PFM      | Ft. Myers  |
| PFO      | Partial Forced Outage  |
| PM1      | Gas Valve Number 1   |
| PM3      | Gas Valve Number 3   |
| PM-4     | Gas valve PM-4 (Gas valves on the 7FA turbine are referred to as PM-1 thru PM-4) |
| PMG      | Martin   |
| PMO      | Partial Maintenance Outage   |
| Pmp      | Pump   |
| PMT      | Manatee  |
| PO       | Planned Outage   |
| POF      | Planned Outage Factor  |
| PPA      | Purchased Power Agreement  |
| PPO      | Partial Planned Outage   |
| PSE      | Cooling Steam Supply   |
| PSF      | Cooling Steam Return   |
| PSL      | St Lucie   |
| PSR      | Sanford  |
| PT       | Potential transformer  |
| PWR      | Power  |
| QF       | Qualifying Facilities  |
| R        | Repair   |
| R0       | Row 0 blades on steam turbine  |
| R1       | Row 1 blades on steam turbine  |
| RAP      | Resource Assessment & Planning Dept.   |
| RCP      | Reactor Coolant Pump   |
| RCS      | Reactor Coolant System   |
| RFC      | Ready For Control  |
| RFO      | Refueling Outage   |
| RH       | Reheat   |
| RPS      | Reactor Protection System  |
| RSD      | Reserve Shutdown   |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2021**

| ACRONYMS   | DESCRIPTION  |
|------------|--|
| RSV        | Reheat Stop Valve  |
| RSV1       | Reheat Stop Valve Number 1   |
| RV         | Release Valve  |
| RW         | Repetitive Work  |
| RX         | Reactor  |
| S/U        | Startup  |
| SCR        | Selective Catalytic Reduction  |
| SDTC       | Steam Dump to Condenser  |
| SF6        | Name of gas used to minimize arc flashes in generator breakers                                 |
| SFC        | Static Frequency Starter   |
| SGFP       | Steam Generator Feed Pump  |
| SGG        | Main Steam - High Pressure   |
| SGJ-ACV-10 | System Designator Air Control Valve  |
| SH         | Super heat   |
| SIT        | Safety Injection Tank  |
| SL1-23     | St Lucie Unit 1 cycle 23 refueling outage  |
| SL2-19     | St Lucie Unit 2 cycle 19 refueling outage  |
| SNO        | Short Notice Outage  |
| SNOW       | Short Notice Outage Work   |
| SRV        | Speed Ratio Valve  |
| ST         | Steam Turbine  |
| ST1        | Steam Turbine Number 1   |
| ST2        | Steam Turbine Number 2   |
| STARS      | Strategic Anti Rotation Stall Surge testing  |
| STG or SG  | Steam Generator  |
| STM 1      | Steam Turbine Number 1   |
| STM 2      | Steam Turbine Number 2   |
| SUS        | Secondary Unit Substation  |
| T-Ave      | Temperature Average  |
| TC or T/Cs | Thermal/Couples  |
| TCA        | Turbine Cooling Air  |
| TCW HX     | Turbine Cooling Water Heat Exchanger   |
| TMOF       | Task MOF   |
| TVT        | Turbine Valve Testing  |
| TYSP       | Ten Year Site Plan   |
| U1         | Unit 1   |
| U2         | Unit 2   |
| UCSB       | Universal Controller version SB  |
| UEL        | Unplanned Energy Loss  |
| ULPM1      | Ultra Lean Pre-Mix Valve # 1   |
| UPS        | Unit Power Sales Agreement   |
| VCMI       | Communication interface board for Mark 6 ovation system  |
| VGW        | Variable Guide Vane  |
| Vi         | Roman Numeral 6  |
| VLV        | Valve  |
| VSV        | Variable Stator Vanes  |
| VTUR       | "V" stands for speed and "TUR" is for turbine  |
| WI         | Water Injection  |
| WO         | Work   |
| Wobbee     | Water warms up gas fired units to 35 MWs. After that, permissive Wobbee takes it to base load. |
| WW         | Water wash   |
| XFMR       | Transformer  |