



Christopher T. Wright
Senior Attorney – Regulatory
Florida Power & Light Company
700 Universe Blvd
Juno Beach, FL 33408-0420
Phone: (561) 691-7144
E-mail: Christopher.Wright@fpl.com
Florida Authorized House Counsel;
Admitted in Pennsylvania

August 9, 2021

VIA ELECTRONIC FILING

Mr. Adam J. Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 20210000-OT
Gulf Power Company 2021 Storm Protection Plan Annual Status Report
Response to Staff's Second Data Requests Nos. 1-2

Dear Mr. Teitzman:

Attached for filing in the above-referenced docket are the Gulf Power Company ("Gulf") responses to Staff's Second Data Requests Nos. 1-2 related to Gulf's 2021 Storm Protection Plan Annual Status Report.

If you or your staff have any question regarding this filing, please contact me at (561) 691-7144.

Respectfully submitted,



Christopher T. Wright
Authorized House Counsel No. 1007055

Enclosures

cc: Russell Badders
Penelope D. Buys (pbuys@psc.state.fl.us)

Florida Power & Light Company
700 Universe Boulevard, Juno Beach, FL 33408

QUESTION:

Please indicate the trim cycle for Gulf's Transmission Vegetation Management program.

RESPONSE:

Under the Storm Protection Plan, Gulf plans to inspect and maintain its entire transmission system, which is, on average, approximately 1,675 miles annually. A detailed description of Gulf's Vegetation Management – Transmission Program that complies with the North American Electric Reliability Corporation's vegetation management requirements is provided in Section IV(G) of Gulf's 2020-2029 Storm Protection Plan approved in Docket No. 20200070.

QUESTION:

Is Gulf's joint-use audit loading analysis part of its Distribution Inspection program? If not, what is the cycle of the audit?

RESPONSE:

Yes. Load analysis of all Gulf owned poles, including joint-use poles is a part of the Distribution Pole Inspection Program included in Gulf's 2020-2029 Storm Protection Plan approved in Docket No. 20200070.