

Dean, Mead, Egerton, Bloodworth, Capouano & Bozarth, P.A.
420 South Orange Avenue, Suite 700
P.O. Box 2346 (ZIP 32802-2346)
Orlando, FL 32801

(407) 841-1200
(407) 423-1831 Fax
www.deanmead.com

Attorneys and Counselors at Law
Orlando
Fort Pierce
Tallahassee
Viera/Melbourne
Vero Beach
Stuart (By Appointment)

MARTIN FRIEDMAN
407-310-2077
mfriedman@deanmead.com

February 8, 2024
via efileing

Adam Teitzman, Commission Clerk
Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 20230083-WS – Application for Increase in Water and Wastewater Rates in Orange County by Pluris Wedgefield, LLC.

Dear Mr. Teitzman:

On behalf of Pluris Wedgefield, LLC I just efiled the response to Staff's Sixth Data Request dated January 25, 2024. In doing so, I inadvertently omitted the exhibit referenced in the response to Ms. Harris' comments. That exhibit is attached hereto. I apologize for the omission.

Should you or Staff have any questions regarding this response please do not hesitate to contact me.

Very truly yours,

/s/ Martin S. Friedman
Martin Friedman

MSF:

Cc: Greg Davis (via email)



FLOWERS CHEMICAL LABORATORIES INC.

P.O. Box 150597, Altamonte Springs, FL 32715-0597
571 NW Mercantile Pl, Suite 111, Port St. Lucie, FL 34986
812 SW Harvey Green Dr, Madison, FL 32340
3980 Overseas Hwy, Suite 103, Marathon, FL 33050

Phone: 407-339-5984 E83018 (Main Lab)
Phone: 772-343-8006 E86562 (South Lab)
Phone: 850-973-6878 E82405 (North Lab)
Phone: 305-743-8598 E35834 (Keys Lab)

Pluris-Wedgefield-DW Attn- Joe Kuhns
1102 South Florida Ave
Lakeland, FL 33803

PO #: n/a
Client Project #: Wedgefield
Date Sampled: Dec 7, 2021
Dec 21, 2021; Invoice: 492333

Analysis Report

Lab #:	Sampled:	Desc:	Parameter	Result	Units	DF	MDL	PQL	QC Batch	Method	CAS #	Analyzed
492333DW1	12/07/21 09:00 AM	19520Glen Elm	Disinfectant Residual	0.190	mg/L	1.00	0.0200	0.0200	10484992	FT2000		12/09/21
			Bromodichloromethane	0.500 U	ug/L	1.00	0.500	1.00	10485897	EPA524.2	75-27-4	12/16/21
			Bromoform	0.500 U	ug/L	1.00	0.500	1.00	10485897	EPA524.2	75-25-2	12/16/21
			Chloroform	0.500 U	ug/L	1.00	0.500	1.00	10485897	EPA524.2	67-66-3	12/16/21
			Dibromochloromethane	0.500 U	ug/L	1.00	0.500	1.00	10485897	EPA524.2	124-48-1	12/16/21
			Total THM	0.500 U	ug/L	1.00	0.500	1.00	10485897	EPA524.2	2950	12/16/21

Lab #:	Sampled:	Desc:	Parameter	Result	Units	DF	MDL	PQL	QC Batch	Method	CAS #	Analyzed
492333DW2	12/07/21 09:00 AM	19520Glen Elm	Disinfectant Residual	0.180	mg/L	1.00	0.0200	0.0200	10484992	FT2000		12/09/21
			HAA_Extraction	40.0	ml	1.00			10485785	X552		12/16/21
			Bromoacetic acid	1.00 U	ug/L	1.00	1.00	5.00	10486111	EPA552.3	79-08-3	12/20/21
			Chloroacetic acid	2.00 U	ug/L	1.00	2.00	5.00	10486111	EPA552.3	79-11-8	12/20/21
			Dibromoacetic acid	3.51 I	ug/L	1.00	1.00	5.00	10486111	EPA552.3	631-64-1	12/20/21
			Dichloroacetic acid	1.00 U	ug/L	1.00	1.00	5.00	10486111	EPA552.3	79-43-6	12/20/21
			Total-HAA	3.51 I	ug/L	1.00	1.00	5.00	10486111	EPA552.3	2456	12/20/21
			Trichloroacetic acid	1.00 U	ug/L	1.00	1.00	5.00	10486111	EPA552.3	76-03-9	12/20/21

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

DISINFECTION BYPRODUCTS
62-550.310(3)

Report Number / Job ID: 22121688-001_____

Disinfectant Residual (mg/L): 0.08_____

PWS ID (From Page 1): 6588003_____

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	µg/L					20***			E
1011	Bromate	10	µg/L					5.0 or 1.0****			E

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	2.0	12/19/22	09:12	E84167
2451	Dichloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	12/19/22	09:12	E84167
2452	Trichloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	12/19/22	09:12	E84167
2453	Monobromoacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	12/19/22	09:12	E84167
2454	Dibromoacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	12/19/22	09:12	E84167
2456	Total Haloacetic Acids (HAA5)	60	µg/L	0.5	U	552.2	0.5	----	12/19/22	09:12	E84167

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/10/22	05:03	E84167
2942	Bromoform	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/10/22	05:03	E84167
2943	Bromodichloromethane	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/10/22	05:03	E84167
2944	Dibromochloromethane	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/10/22	05:03	E84167
2950	Total Trihalomethanes (TTHM)	80	µg/L	0.5	U	524.2	0.5	----	12/10/22	05:03	E84167

** Laboratories are required to adhere to the minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv).

*** Applicable to monitoring as prescribed in 40 CFR 141.132.(b)(2)(i)(B) and (b)(2)(ii).

**** Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 µg/L MRL for bromate.

NOTE: Do not round values. Report results to the accuracy, precision, and sensitivity of the analytical method used.

Reporting Format 62-550.730
Effective January 1995, Revised December 2012

Page 5 of 9

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

DISINFECTION BYPRODUCTS
62-550.310(3)

Report Number / Job ID: 23120595-001 _____

Disinfectant Residual (mg/L): 0.17 _____

PWS ID (From Page 1): 3480149 _____

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	µg/L					20***			E
1011	Bromate	10	µg/L					5.0 or 1.0****			E

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	µg/L	0.28	U	552.2	0.28	2.0	12/22/23	15:55	E83018
2451	Dichloroacetic Acid	N/A	µg/L	2.2	I	552.2	0.23	1.0	12/22/23	15:55	E83018
2452	Trichloroacetic Acid	N/A	µg/L	0.49	I	552.2	0.20	1.0	12/22/23	15:55	E83018
2453	Monobromoacetic Acid	N/A	µg/L	0.60	I	552.2	0.38	1.0	12/22/23	15:55	E83018
2454	Dibromoacetic Acid	N/A	µg/L	1.1	I	552.2	0.23	1.0	12/22/23	15:55	E83018
2456	Total Haloacetic Acids (HAA5)	60	µg/L	4.4	I	552.2	0.28	---	12/22/23	15:55	E83018

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	µg/L	1.9		524.2	0.5	1.0	12/20/23	13:32	E83018
2942	Bromoform	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/20/23	13:32	E83018
2943	Bromodichloromethane	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/20/23	13:32	E83018
2944	Dibromochloromethane	N/A	µg/L	0.5	U	524.2	0.5	1.0	12/20/23	13:32	E83018
2950	Total Trihalomethanes (TTHM)	80	µg/L	1.9		524.2	0.5	---	12/20/23	13:32	E83018

** Laboratories are required to adhere to the minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv).

*** Applicable to monitoring as prescribed in 40 CFR 141.132.(b)(2)(i)(B) and (b)(2)(ii).

**** Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 µg/L MRL for bromate.

NOTE: Do not round values. Report results to the accuracy, precision, and sensitivity of the analytical method used.

Reporting Format 62-550.730
Effective January 1995, Revised December 2012

Page 5 of 9

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.