



**John T. Burnett**  
**Vice President & General Counsel**  
**Florida Power & Light Company**  
**700 Universe Boulevard**  
**Juno Beach, FL 33408**  
**(561) 304-5253**

February 28, 2025

**VIA ELECTRONIC FILING**

Adam Teitzman, Commission Clerk  
Division of Commission Clerk and Administrative Services  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

Re: Docket No. 20250011-EI  
Petition by Florida Power & Light Company for Base Rate Increase

Dear Mr. Teitzman:

Attached for filing on behalf of Florida Power & Light Company ("FPL") in the above docket are the direct testimony and exhibits of FPL witness Andrew Whitley.

Please let me know if you have any questions regarding this submission.

Sincerely,

*s/ John T. Burnett*

---

John T. Burnett  
Vice President & General Counsel  
Florida Power & Light Company

(Document 10 of 30)

**CERTIFICATE OF SERVICE**

**Docket 20250011-EI**

**I HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished

by electronic service this 28th day of February 2025 to the following:

Shaw Stiller  
Timothy Sparks  
**Florida Public Service Commission**  
Office of the General Counsel  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850  
sstiller@psc.state.fl.us  
tsparks@psc.state.fl.us

Walt Trierweiler  
Mary A. Wessling  
Office of Public Counsel  
c/o The Florida Legislature  
111 W. Madison St., Rm 812  
Tallahassee, Florida 32399-1400  
trierweiler.walt@leg.state.fl.us  
wessling.mary@leg.state.fl.us  
**Attorneys for the Citizens  
of the State of Florida**

By: s/ John T. Burnett  
John T. Burnett

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET NO. 20250011-EI**

**FLORIDA POWER & LIGHT COMPANY**

**DIRECT TESTIMONY OF ANDREW W. WHITLEY**

**Filed: February 28, 2025**

**TABLE OF CONTENTS**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

**I. INTRODUCTION.....3**

**II. RESOURCE ADDITIONS.....9**

    A. *Resource Planning – Process Overview* ..... 9

    B. *FPL’s Planned Resource Additions (2026)* ..... 22

    C. *FPL’s Planned Resource Additions (2027)* ..... 27

    D. *FPL’s 2028 and 2029 Resource Needs* ..... 28

**III. UPDATE TO COST OF SERVICE METHODOLOGY .....31**

**IV. LARGE LOAD CONTRACT SERVICE.....33**

**V. INCENTIVE PAYMENT LEVELS FOR CDR & CILC .....34**

1 **I. INTRODUCTION**

2 **Q. Please state your name and business address.**

3 A. My name is Andrew W. Whitley. My business address is 700 Universe Blvd., Juno  
4 Beach, Florida 33408.

5 **Q. By whom are you employed and what is your position?**

6 A. I am employed by Florida Power & Light Company (“FPL” or the “Company”) as  
7 Engineering Manager in the Integrated Resource Planning (“IRP”) department of  
8 FPL’s Finance Business Unit.

9 **Q. Please describe your duties and responsibilities in that position.**

10 A. In my current position, I am responsible for the management and coordination of  
11 economic analyses that identify and evaluate resource alternatives to meet FPL’s  
12 resource needs and maintain system reliability. The analyses I oversee are designed to  
13 determine the magnitude and timing of resource needs for FPL’s system and are used  
14 to develop the Company’s integrated resource plan.

15 **Q. Please describe your educational background and professional experience.**

16 A. I graduated from Lehigh University in 2004 with a Bachelor of Science in Mechanical  
17 Engineering. I joined FPL in 2004 as part of the Power Delivery team, undertaking  
18 various engineering duties related to initiating new service to FPL customers and  
19 maintaining the reliability of customers’ existing services. In 2007, I joined the team  
20 now known as the IRP group. Since that time, I have been involved in and supported  
21 a variety of resource planning projects for FPL, including FPL’s Ten Year Site Plans  
22 (“TYSP”), solar base rate adjustments, need determination proceedings for new power  
23 plants under the Florida Power Plant Siting Act (including the Okeechobee Clean

1 Energy Center in 2015 and the Dania Beach Clean Energy Center in 2018), base rate  
2 proceedings, and the Demand-Side Management (“DSM”) Goals proceedings. I  
3 became the Manager of the IRP group in 2022 and have served as the project leader for  
4 FPL’s TYSPs since 2022.

5 **Q. Are you sponsoring any exhibits in this case?**

6 A. Yes. I am sponsoring the following exhibits:

- 7 • Exhibit AWW-1 Summary of FPL Resource Adequacy Study (Prepared by E3)
- 8 • Exhibit AWW-2 Load Forecasts Used in the Current Analyses
- 9 • Exhibit AWW-3 Fuel Cost Forecasts Used in the Current Analyses
- 10 • Exhibit AWW-4 CO<sub>2</sub> Compliance Cost Forecast Used in the Current Analyses
- 11 • Exhibit AWW-5 Economic Analysis Results for the Combined 2026 and 2027  
12 Solar and Battery Additions
- 13 • Exhibit AWW-6 Economic Analysis Results for the Combined 2028 and 2029  
14 Solar and Battery Additions
- 15 • Exhibit AWW-7 With Programs and Without Programs Resource Plans for  
16 CDR and CILC Incentive Payment Analysis
- 17 • Exhibit AWW-8 Analysis of the Current and Proposed Monthly Incentive  
18 Levels for the CDR & CILC Programs.

19 **Q. Are you sponsoring or co-sponsoring any Minimum Filing Requirements in this**  
20 **case?**

21 A. No.

1 **Q. What is the purpose of your testimony?**

2 A. The purpose of my testimony is to describe the resource planning process undertaken  
3 by FPL to identify optimal resource additions for the 2026-2029 period. Specifically,  
4 I identify FPL's system needs and detail how the battery storage and photovoltaic  
5 ("PV") solar resource options identified through the Company's resource planning  
6 process most cost-effectively promote the dependability and reliability of FPL's  
7 system. My testimony also describes how recent and ongoing changes in FPL's  
8 generation resource portfolio support the transition of FPL's production cost of service  
9 methodology from a 12 coincident peak ("CP") and 1/13<sup>th</sup> methodology to a 12 CP and  
10 25% methodology as detailed in the testimony of FPL witness DuBose. I also support  
11 the 3-gigawatt ("GW") maximum established under FPL's proposed Large Load  
12 Contract Service-1 ("LLCS-1") tariff, which is detailed in the testimony of FPL witness  
13 Cohen. Lastly, my testimony establishes the appropriate new monthly incentive  
14 payment levels for two of FPL's largest DSM programs: the Commercial/Industrial  
15 Demand Reduction ("CDR") and Commercial/Industrial Load Control ("CILC")  
16 programs.

17 **Q. Please summarize your testimony.**

18 FPL employs a comprehensive system planning analysis to identify reliable, timely,  
19 and cost-effective system additions that meet FPL's unique system needs and ensure  
20 sufficient capacity and energy are available to serve all FPL customers for every hour  
21 of the year. FPL undertook such an analysis in identifying utility-scale battery storage  
22 and PV solar additions that are proposed to enter service between 2026 and 2029.

1 As FPL’s system continues to incorporate additional cost-effective solar generation,  
2 the Company is continuing to adapt its resource planning to ensure that customers’  
3 reliability needs are met through available, dispatchable resources that provide value  
4 to customers. Just as FPL’s system has advanced and modernized over time, resource  
5 adequacy must also be modernized to consider conditions that affect the delivery of  
6 power in times of greatest need. To that end, FPL performed a comprehensive,  
7 stochastic loss of load probability (“LOLP”) analysis to ensure that FPL’s proposed  
8 system additions optimally address system needs for each hour of the year. The results  
9 of the stochastic LOLP analysis, which are detailed in my testimony, demonstrate that  
10 FPL has a need for resources to be added throughout years 2026 to 2029. Specifically,  
11 FPL must meet a 32,322 MW firm capacity need by 2027 in order to maintain its LOLP  
12 requirement in that year, and that reliability requirement increases to 34,102 MW in  
13 2030, representing an increase of 1,780 MW over that timeframe.

14  
15 The economic analyses presented through my testimony show that PV solar additions,  
16 combined with battery storage installations, most cost-effectively address the reliability  
17 needs identified through the stochastic analysis and generate significant customer  
18 savings. My testimony demonstrates that the deployment of 2,086 megawatts (“MW”) of  
19 PV solar facilities in 2026 and 2027, along with 2,239 MW of battery storage  
20 installations over that same time period, is expected to create \$1,942 million in  
21 cumulative present value revenue requirement (“CPVRR”) savings for FPL’s  
22 customers. The combination of solar and battery storage provides complementary  
23 benefits for FPL’s system, incorporating FPL’s most cost-effective generation resource



1 and, concurrently, allowing for continued reliable operation of the electric system  
2 during times when solar facilities are not generating. Together, these resources are less  
3 costly than new natural gas fired generation and, unlike natural gas generation, can be  
4 added in the near term to address FPL's current reliability needs.

5  
6 Not only are solar and battery storage optimal resources for the 2026 and 2027  
7 timeframe, they continue to be the best resource options to address FPL's reliability  
8 needs in the latter years of FPL's four-year plan. FPL's proposed 3,278 MW of solar  
9 installations and 1,192 MW of battery installations in 2028 and 2029 are expected to  
10 create \$2,213 million in CPVRR savings for customers, making them optimal resources  
11 as compared to other alternatives. These resources will continue the trend of providing  
12 fuel-free generation from solar combined with the flexibility and capacity from battery  
13 storage and will ensure FPL's bulk electric system is powered by reliable, cost-effective  
14 generation.

15  
16 With the continued deployment of cost-effective solar, FPL's net system peak  
17 continues to push further into the evening hours. This means that FPL's incremental  
18 generation resource needs are moving to a time of the day when FPL's solar generation  
19 is producing less output. This transformation in our generation fleet supports the  
20 transition to a 12 CP and 25% methodology as described in the testimony of FPL  
21 witness DuBose, as this methodology best reflects the realities of FPL's system and its  
22 incremental generation needs during peak hours.

23

1 Just as FPL's grid and resource supply continue to evolve, so does the nature of the  
2 customers who are being added to the system, requiring the Company to refine certain  
3 features of service and cost assignment. One such feature is the LLCS-1 tariff  
4 described in the testimony of FPL witness Cohen. Participation in this tariff, which is  
5 tailored to large load customers entering FPL's service area, must be capped in order  
6 to ensure that FPL has the generation supply resources needed to safely, reliably, and  
7 adequately serve all of its customers. The limitation of 3 GW for this service during  
8 the term of our proposed four-year plan, which my testimony supports, is a reasonable  
9 limitation given the resources that FPL could potentially add in the near-term to meet  
10 the needs of new customers with large electric loads.

11

12 The nature of FPL's system also affects the operational value and cost-effectiveness of  
13 FPL's CDR and CILC programs. Currently, the incentive levels for these programs do  
14 not align with the operational value that they provide to FPL and its general body of  
15 customers. As such, FPL proposes to lower the monthly incentive payment for the  
16 CDR program from its current level of \$8.76/kW to \$6.22/kW. FPL's CILC rate will  
17 be adjusted accordingly, as addressed by FPL witness Cohen. The revised incentive  
18 levels will ensure that the programs are still attractive to participants and do not burden  
19 non-participants with higher program costs than are needed to sustain the program.

1 **II. RESOURCE ADDITIONS**

2 **Q. What generation resource additions associated with FPL’s rate request is your**  
3 **testimony supporting?**

4 A. My testimony supports the prudence of FPL’s addition of utility-scale battery storage  
5 and solar generation proposed for years 2026 and 2027, as well as FPL’s need for  
6 further additions of these resources in years 2028 and 2029. These additions, which  
7 were specifically identified through FPL’s resource planning process as optimal and  
8 needed resources, will allow FPL to meet its capacity and energy requirements with  
9 reliable generation sources and are forecasted to generate billions of dollars in total  
10 savings for FPL’s customers compared to other alternatives.

11  
12 **A. Resource Planning – Process Overview**

13 **Q. How does FPL determine its future demand and energy needs and how best to**  
14 **meet those needs?**

15 A. There are three main goals of FPL’s resource planning process:  
16 1. Identify the timing of FPL’s resource needs. The timing of future resource  
17 needs is largely determined by reliability standards, including planning reserve  
18 margin, generation-only reserve margin, and LOLP.  
19 2. Identify the magnitude of these resource needs, *i.e.*, how many MW of capacity  
20 are needed to satisfy all reliability criteria.  
21 3. Identify the type of resources, either supply-side or demand-side, that can meet  
22 the capacity needs while adding other resources that improve system  
23 economics. On an economic basis, this selection is determined by the option

1 that is projected to result in the lowest electric rates for FPL’s customers while  
2 satisfying FPL’s reliability standards.

3 **Q. Please provide an overview of FPL’s resource planning process.**

4 A. FPL’s resource planning process can be summarized by the following four tasks:

5 • Task 1: Determine the magnitude and timing of FPL’s new resource needs to  
6 maintain a reliable system.

7 • Task 2: Identify the resource options and resource plans that are available to  
8 meet the determined magnitude and timing of FPL’s resource needs (*i.e.*,  
9 identify the available competing options and resource plans).

10 • Task 3: Evaluate the competing resource options and resource plans based on  
11 system economics and non-economic factors.

12 • Task 4: Select a resource plan to meet the identified need.

13 **Q. What are the reliability standards the Company uses to design its resource  
14 portfolio and determine the need for additional resources?**

15 A. FPL uses three specific reliability criteria in projecting its future resource needs. The  
16 first criterion is a minimum total planning reserve margin (“PRM”) of 20% for both  
17 summer and winter peak hours. The minimum 20% total PRM criterion was approved  
18 by the Commission in Order No. PSC-99-2507-S-EU issued in Docket No. 981890-  
19 EU.

20

21 The second reliability criterion used by FPL is an LOLP criterion. LOLP is a projection  
22 of how well an electric utility system may be able to meet its firm demand (*i.e.*, a  
23 measure of how often firm load may exceed available resources). In contrast to a

1 reserve margin approach that looks at the one summer peak hour and the one winter  
2 peak hour, the LOLP approach looks at the peak hourly demand for each day of the  
3 year. The LOLP approach takes into consideration the probability of individual  
4 generators being out-of-service due to scheduled maintenance or forced outages, the  
5 variability of load, the variability of production from intermittent generation resources,  
6 and the availability of duration-limited resources, such as battery storage and demand  
7 response programs. An LOLP analysis models each of these variables to generate a  
8 multitude of scenarios and the associated probability of a generation shortfall in these  
9 scenarios can be calculated. LOLP is typically expressed in terms of “numbers of times  
10 per year” that the system firm demand cannot be served. FPL’s LOLP criterion is a  
11 maximum of 0.1 days per year, or one day in ten years. This LOLP criterion is  
12 commonly used throughout the electric utility industry and is consistent with North  
13 American Electric Reliability Corporation reliability planning standards.

14

15 The third reliability criterion used by FPL is a minimum generation-only reserve  
16 margin (“GRM”) of 10%. The issue of having a sufficient generation component of  
17 the projected total reserve margin has been discussed annually in FPL’s TYSP since  
18 2011, and the GRM was adopted by FPL as a reliability criterion beginning in 2014.  
19 The GRM must be applied only after evaluating the amount of DSM in a resource plan.

20 **Q. Has FPL expanded its reliability analysis to account for features that are specific**  
21 **to FPL’s evolving system?**

22 A. Yes. FPL’s system has evolved over time such that the reliability analyses of the past  
23 do not sufficiently detect resource adequacy risks associated with FPL’s generation

1 profile. As I referenced earlier, FPL's incorporation of cost-effective solar has  
2 increased to the extent that the peak hour of the year – *i.e.*, the hour of greatest demand  
3 on the system – is no longer the most critical hour for determining reliability need.  
4 Now, the most critical time for capacity on FPL's system is at peak net demand, which  
5 occurs between 5:00 p.m. and 8:00 p.m., when solar facilities are providing less  
6 generation output. For these hours, as well as all other hours throughout the year, FPL  
7 needs additional, more modernized modeling analysis to determine its resource  
8 adequacy and identify where its greatest resource needs lie. Thus, for its 2025 resource  
9 planning, FPL added a stochastic LOLP analysis tailored to its system to identify  
10 (1) hourly periods of the year where there is increased likelihood for a loss of load, and  
11 (2) available resources that can remediate the potential for that loss.

12 **Q. How does stochastic LOLP modeling work?**

13 A. Stochastic LOLP modeling incorporates vast amounts of data to develop a granular  
14 view of a utility's system adequacy in hour-by-hour segments. This modeling  
15 incorporates significantly more data in assessing system reliability than a traditional  
16 LOLP analysis, providing a substantially wider range of load and generation conditions  
17 across numerous scenarios. Through this analysis, a utility can more effectively  
18 determine the sufficiency of its hourly generation supply throughout the year, which,  
19 in turn, allows it to identify any needed system additions.

20 **Q. How does the stochastic LOLP analysis differ from the reliability analyses FPL  
21 has previously used to identify resource needs?**

22 A. The stochastic LOLP analysis incorporates a tremendous volume of system-specific  
23 data to develop a probabilistic hourly load and supply projection and identify the

1 system's reliability needs. A traditional PRM analysis, however, provides a simplified  
2 look at system operation, examining only the peak demand hour at two times of the  
3 year – once in the winter and once in the summer – without considering the unique  
4 generation attributes of the utility's fleet. The PRM analysis therefore leaves an  
5 analytical shortcoming, particularly for systems that incorporate substantial renewable  
6 generation. For example, as FPL's solar generation portfolio has increased, the hours  
7 of the day with the least reserves are more likely to be found in the evening as the sun  
8 begins to set and solar generation decreases, which a PRM analysis does not fully  
9 reflect. In addition, the traditional PRM analysis also fails to capture the interactive  
10 effects of non-dispatchable generation and load, which have become increasingly  
11 challenging to predict and model. The stochastic LOLP analysis, on the other hand,  
12 accounts for and models these factors, assessing resource availability at every hour of  
13 the year and identifying the periods when reserves are most depleted, wherever they  
14 may fall.

15  
16 The stochastic modeling also presents a more sophisticated analysis than FPL's prior  
17 LOLP analyses. A traditional LOLP analysis models expected generation  
18 unavailability based upon historic forced outage rates, resulting in a cumulative  
19 probability matrix of potential unit outages. The stochastic LOLP analysis, however,  
20 simulates a random selection of plant outages, which better reflects the unpredictable  
21 nature of unavailable generation as observed in normal system operations.  
22 Additionally, a traditional LOLP analysis models an expected solar generation profile,  
23 whereas the stochastic LOLP analysis produces a reliability assessment that captures

1 the natural variability in solar production due to weather conditions. The stochastic  
2 LOLP model also better captures the synergistic interactions between load and non-  
3 dispatchable generation because it models the variability of each input separately.

4 **Q. Did FPL engage an outside consultant to assist in developing FPL’s stochastic**  
5 **LOLP analysis?**

6 A. Yes. To assist with determining the hourly reliability needs specific to its system, FPL  
7 engaged Energy and Environmental Economics, Inc. (“E3”), a consulting firm with  
8 experience advising state agencies, regulators, system operators and utilities on energy  
9 policies. E3 provided advanced stochastic LOLP modeling that accounted for  
10 variability in, among other things, generating resource availability, generating resource  
11 output, and system load. The modeling also included an hourly assessment of FPL’s  
12 system reliability. The scope of E3’s analysis assessed the marginal reliability benefits  
13 of resources with disparate generating characteristics, such as thermal generation, solar,  
14 battery storage, and demand response.

15 **Q. How were the inputs to the stochastic LOLP model developed?**

16 A. E3 coordinated with FPL and used hourly temperature data from representative weather  
17 stations to develop hourly load profiles using a machine learning algorithm trained on  
18 actual load and temperatures from 2003 to 2023. E3 also used historic satellite data to  
19 simulate hourly solar generation at each of its current and future solar generating sites  
20 for the 1980 to 2023 period, as well as actual historical generating unit availability data  
21 to calculate an expected forced outage rate and a mean time to repair for every  
22 generating unit in the FPL fleet. The model used these inputs to randomly select which  
23 units may experience an outage at any given time within the simulations.



1 **Q. What were the results of the stochastic LOLP analysis and how did FPL**  
2 **incorporate these results into its 2025 resource planning?**

3 A. The stochastic analysis revealed that LOLP vulnerabilities will arise if FPL's resource  
4 planning is not modified. As shown in Exhibit AWW-1, FPL needs 32,322 MW of  
5 firm capacity to be available in 2027 in order to maintain an LOLP of 0.1 days-per-  
6 year in that year – and the required reliability need to reach the same 0.1 threshold  
7 increases to 34,102 MW in 2030, representing an increase of 1,780 MW. The  
8 stochastic analysis shows that not adding sufficient generation resources during the  
9 2026 through 2029 time period to address the identified needs would cause FPL's  
10 LOLP to not meet the 0.1 days-per-year threshold and could potentially result in  
11 scenarios where FPL is unable to provide its customers with electricity, a circumstance  
12 that FPL's resource planning must address and avoid.

13  
14 To address the resource need demonstrated through the stochastic analysis, FPL's  
15 resource planning process identified resources to timely address the need, while  
16 maintaining all reliability criteria, and tested the cost-effectiveness of the available  
17 resource options.

18 **Q. What forecasts and assumptions did FPL use in its 2025 resource planning**  
19 **process?**

20 A. Every year, FPL updates its forecasts as part of its resource planning process and in  
21 support of filing its yearly TYSP, including considerations of supply-side efficiencies.  
22 In its 2025 resource planning work, which supports the resource additions identified in  
23 my testimony, FPL is using the following forecasts:

- 1           1. A forecast of projected hourly load, dated November 8, 2024, which is provided
- 2           with my testimony as Exhibit AWW-2;
- 3           2. A forecast of fuel prices (natural gas, coal, and oil), dated September 3, 2024,
- 4           which is provided with my testimony as Exhibit AWW-3; and
- 5           3. A forecast of carbon dioxide (“CO<sub>2</sub>”) compliance costs, dated September 28,
- 6           2022, which is provided with my testimony as Exhibit AWW-4.

7

8           FPL’s 2025 resource planning also reflects unit retirements that affect the Company’s

9           projected resource needs, including the retirement of Gulf Clean Energy Center Units

10          4 and 5 by the end of 2029.

11       **Q.    What is FPL’s process for selecting new resources to meet identified system**

12       **needs?**

13           FPL’s resource selection process is guided by the AURORA planning model and

14           incorporates the stochastic LOLP modeling results I detailed earlier. The AURORA

15           model utilizes sophisticated programming to conduct an extensive evaluation of

16           potential resource plans that can meet the Company’s reliability requirements. FPL

17           has presented the Commission with outputs from this model in numerous prior

18           proceedings, and it is being used to develop FPL’s 2025 TYSP.

1 To develop a resource plan that is specific to FPL’s needs, the AURORA model  
2 incorporates a number of forecasts and operating assumptions into its analysis  
3 including the following:

- 4 • The minimum 20% total Reserve Margin reliability criterion described earlier;
- 5 • Any additional resource needs from FPL’s other reliability criteria;
- 6 • Forecasts for peak load, energy, fuel prices, and environmental compliance  
7 costs;
- 8 • Projections of future incremental DSM demand and energy additions, based on  
9 FPL’s proposed DSM Plan, which will be filed by March 18, 2025;
- 10 • The existing capabilities of the units on FPL’s systems, and any planned  
11 changes to those units; and
- 12 • Projections of fixed and variable costs, and the operating characteristics of a  
13 variety of generation options to meet FPL’s resource needs in the future.

14  
15 FPL ran the AURORA model with these assumptions to identify and test the cost-  
16 effectiveness of resource additions for inclusion in this proceeding as well as the 2025  
17 TYSP.

18  
19 I reviewed the underlying assumptions and modeling methodology, and they are  
20 reasonable and consistent with how FPL has conducted forecasts for prior investments  
21 that have been approved by the Commission.

1 **Q. How does FPL forecast DSM and energy efficiency in its resource planning**  
2 **analysis?**

3 A. FPL’s resource planning assumes 100% achievement of its DSM and energy efficiency  
4 goals, which are approved by the Commission consistent with the Florida Energy  
5 Efficiency and Conservation Act (“FEECA”). Specifically, FPL accounts for the  
6 following projected DSM impacts as “line-item reductions” to the forecasts: (1) the  
7 impacts of incremental energy efficiency that have been implemented after the 2024  
8 summer peaks have occurred, (2) projected impacts from incremental energy efficiency  
9 and load management, and (3) the impacts from previous signups in FPL’s load  
10 management programs that will continue through 2034. Modeling DSM in this way  
11 reflects the full benefit associated with FPL’s Commission-approved DSM programs.

12 **Q. How have FPL’s prior DSM efforts affected its system?**

13 A. The Company’s DSM efforts through the end of 2024 have resulted in a cumulative  
14 summer peak reduction of 5,695 MW at the generator and an estimated cumulative  
15 energy savings of 102,684 GWh at the generator. Without these reductions FPL would  
16 have required the equivalent of approximately 68 new 100 MW generating units to  
17 meet its peak load.

18 **Q. How does FPL determine the cost-effectiveness of its potential resource options?**

19 A. FPL assesses the CPVRR of potential resource options to make this determination.  
20 CPVRR is a metric focused on total system economics and rate impacts and allows for  
21 a comparative evaluation of the cost-effectiveness of various resource options. FPL  
22 assesses the CPVRR of competing resource alternatives by comparing the alternatives’  
23 abilities to economically meet an identical system load. This enables FPL to rank

1 potential alternatives according to their respective impacts on both electricity rates and  
2 system revenue requirements. The CPVRR analysis therefore informs and furthers  
3 FPL’s objective of minimizing the Company’s projected levelized system average  
4 electric rate (*i.e.*, a Rate Impact Measure or “RIM” methodology), which is a tangible  
5 benefit to customers.

6 **Q. How many potential resource plans did the AURORA model evaluate for FPL’s**  
7 **system?**

8 A. After incorporating FPL’s input parameters, AURORA evaluated hundreds of possible  
9 resource plans that met FPL’s future resource needs using only generation or supply  
10 options. These resource plans included consideration of all potentially implementable  
11 generation resources, including solar, battery storage, and fossil options. The model  
12 identified utility-scale battery storage and solar resources as optimal additions based  
13 on their CPVRR relative to other resources and their ability to address input parameters  
14 specified for the model run.

15 **Q. How did FPL review the AURORA outputs in light of the stochastic LOLP**  
16 **analysis findings?**

17 A. FPL tested the resource additions identified by AURORA to determine the most cost-  
18 effective resources that could address FPL’s reliability needs as identified through the  
19 stochastic LOLP analysis. This testing procedure was a necessary and additive  
20 component of the resource planning process, as the AURORA model identifies  
21 resource options on the basis of the Company’s minimum reserve margin requirement,  
22 which is only analyzed at the system’s summer and winter peaks (*i.e.*, two peak hours  
23 per year).

1 **Q. What resource additions did FPL identify that most cost-effectively address the**  
2 **reliability needs identified through the stochastic LOLP analysis?**

3 A. FPL’s resource planning identified the following installations as the most cost-effective  
4 to meet FPL’s resource needs in the 2026 through 2029 timeframe:

- 5 • 1,419.5 MW of battery storage and 894 MW<sub>AC</sub> of solar in 2026;
- 6 • 819.5 MW of battery storage and 1,192 MW<sub>AC</sub> of solar in 2027;
- 7 • 596 MW of battery storage and 1,490 MW<sub>AC</sub> of solar in 2028; and
- 8 • 596 MW of battery storage and 1,788 MW<sub>AC</sub> of solar in 2029.

9

10 These proposed additions represent a greater than 50% reduction in planned solar for  
11 2026 and 2027 as compared to FPL’s 2024 TYSP, in favor of the reliable firm capacity  
12 provided by utility-scale battery storage, which more than doubles relative to the  
13 battery storage additions identified for 2026 and 2027 in FPL’s 2024 TYSP. Years  
14 2028 and 2029 represent similar decelerations of solar deployment in favor of  
15 additional MW of battery storage capacity as compared to the 2024 TYSP.

16 **Q. Is it your assessment that these are the optimal system additions for FPL in years**  
17 **2026 through 2029?**

18 A. Yes. These are the most cost-effective system additions to meet FPL’s reliability needs  
19 identified through the stochastic LOLP analysis and ensure sufficient capacity and  
20 generation production for every hour of the year. Consistent with my CPVRR analyses,  
21 which are described in my testimony below, these system additions meet FPL’s  
22 resource needs and are also projected to save customers several billions of dollars over  
23 the life of the assets.

1 **Q. Could purchasing power as needed be a reliable solution to address the resource**  
2 **needs identified by FPL’s LOLP modeling?**

3 A. No. Having consulted with FPL’s Energy Marketing and Trading business unit,  
4 purchasing power to address these needs would not be a viable solution. Purchasing  
5 power, either in the near- or long-term, would require that capacity be consistently  
6 available at the times FPL most requires it. However, the availability of power  
7 purchases would be extremely limited during any situation with higher-than-normal  
8 loads in Florida. Additionally, long-term power supply agreements often require power  
9 deliveries to be scheduled a day ahead or contain other scheduling limitations that  
10 would compromise FPL’s ability to flexibly meet hour-to-hour supply needs. Further,  
11 the supply of wholesale power available in the Florida market is limited and may  
12 become increasingly more so as utilities in the Southeast continue to anticipate (and  
13 potentially recognize) significant load growth. Therefore, to rely on as-needed  
14 purchases during times of system constraint would jeopardize FPL’s power supply  
15 availability, a circumstance that FPL must plan to avoid.

16 **Q. Is it your assessment that the battery storage and solar additions you identified**  
17 **are prudent compared to adding natural gas-fired generation?**

18 A. Yes. The addition of solar generation and battery storage is more cost-effective than  
19 constructing new natural gas generation. As demonstrated in my CPVRR analyses  
20 presented below, using natural gas-fired generation to address FPL’s reliability needs  
21 would increase costs for FPL customers by billions of dollars compared to the utility-  
22 scale battery storage and solar resources I identified.

1 **Q. Aside from being more costly, are there other reasons why adding natural gas-**  
2 **fired generation is not a suitable substitute for the solar and battery storage**  
3 **additions you identified?**

4 A. Yes. The potential to construct and bring natural gas generation to operation in the  
5 near term is severely limited. Combustion turbines (“CTs”) cannot be quickly  
6 implemented and require multiple years to construct and reach operation. Moreover,  
7 gas supply available to FPL is limited, and the additional infrastructure required to  
8 increase the availability of gas supply takes time and cost to develop. This makes CTs  
9 unsuitable for addressing reliability needs in the near term.

10  
11 Additionally, the components needed to construct new CTs have become increasingly  
12 difficult to timely obtain. Overseas demand and recent supply-chain issues have  
13 pushed the earliest realistic in-service date for CTs to late 2029 or early 2030. These  
14 in-service dates would lead to CTs being unable to meet FPL’s resource needs in the  
15 2026-2029 timeframe.

16

17 **B. *FPL’s Planned Resource Additions (2026)***

18 **Q. Please provide an overview of FPL’s current battery storage and solar portfolio.**

19 A. At this time, FPL has 469 MW of utility-scale, grid connected battery storage installed  
20 on its system at three separate locations and is currently constructing 522 MW of new  
21 battery storage adjacent to seven existing solar energy centers. As for FPL’s solar fleet,  
22 FPL had a total of approximately 7,038 MW<sub>AC</sub> (nameplate) of utility-owned solar  
23 generation as of the end of 2024, all of which are PV facilities. FPL also has 894



1 MW<sub>AC</sub> of solar generation in various stages of development that are expected to enter  
2 service in 2025, including those that are a part of the solar base rate adjustments  
3 approved in FPL's last base rate proceeding. These solar projects are spread throughout  
4 FPL's system, providing energy derived from cost-effective renewable solar resources  
5 throughout FPL's service area.

6 **Q. How has the addition of the solar facilities you mentioned contributed to FPL's**  
7 **system?**

8 A. Solar contributes to FPL's system, and has benefitted FPL's customers, in the following  
9 ways:

- 10 1. Solar provides a portion of its nameplate capacity as firm capacity during the  
11 times of FPL's system peaks.
- 12 2. Solar provides fuel-free (and emission-free) energy that reduces the fuel portion  
13 of customer bills. From 2021 through 2024, FPL customers have saved  
14 approximately \$942 million in avoided fuel expenses from solar installed on  
15 FPL's system.
- 16 3. Since 2023, solar production from new sites has also been eligible for a  
17 Production Tax Credit that reduces the cost of solar and is passed on directly to  
18 FPL's customers.

19 All three of these factors have led to solar being an economic resource option for FPL  
20 and continue to drive the cost-effectiveness of solar in FPL's resource plans.

1 **Q. What is FPL’s resource need for 2026?**

2 A. As identified in the stochastic LOLP analysis, FPL needs 1,663 MW of additional firm  
3 capacity to meet its LOLP requirement in 2027. To meet this need FPL must add firm  
4 capacity in 2026 so that it is positioned to meet the identified 2027 reliability need.

5 **Q. What resources does FPL plan to add in 2026 to address this need?**

6 A. FPL is proposing to add 1,419.5 MW of battery storage and 12 74.5 MW solar sites  
7 (894 MW) in 2026. Installation of these system additions is supported by FPL’s  
8 resource planning analysis, undertaken in accordance with the process I described  
9 earlier. FPL witness Oliver provides additional details concerning each of these  
10 proposed solar additions, as well as those in 2027.

11 **Q. How do these additions address the need identified in the stochastic LOLP  
12 analysis?**

13 A. In short, the MWs provided by the 2026 additions allow FPL to address the reliability  
14 need identified through the stochastic LOLP analysis by 2027, while also maintaining  
15 FPL’s adherence to all other reliability criteria. Adding these resources, along with  
16 additional resources in the first half of 2027, will bring FPL’s projected LOLP under  
17 the 0.1 days-per-year standard for 2027.

18  
19 The 2026 additions also provide two specific system needs identified through the  
20 stochastic LOLP analysis: (1) the additional need for stable, dispatchable capacity; and  
21 (2) the need for FPL to maintain sufficient generation to meet FPL’s increasingly higher  
22 load. The proposed battery storage additions will have the ability to quickly discharge  
23 energy to FPL’s system to address hourly operational requirements, which enhances

1 the reliability of FPL’s system. The facilities will also provide year-round capacity to  
2 promote system reliability regardless of the time of day or the weather conditions and  
3 enable low-cost energy to be stored and delivered when needed. In that way, the  
4 storage additions will serve as key resources that allow FPL to increase system  
5 reliability and flexibility by cost-effectively addressing times of peak energy  
6 consumption, which ordinarily occur in the evenings.

7  
8 The solar additions, combined with the battery storage, allow FPL to maintain  
9 sufficient generation resources to reliably meet the needs of an increasing customer  
10 base and higher loads. In addition to FPL’s peak demand growing, FPL’s net energy  
11 load (*i.e.*, the amount of energy on the system throughout the year) is also growing.  
12 FPL’s proposed solar additions help meet this increased energy need with energy that  
13 is produced cost-effectively and uses no fuel, thereby putting downward pressure on  
14 customer rates over the long-term.

15  
16 The 2026 additions can also be sited, constructed, and operational within a much  
17 shorter timeframe than other generation resources, such as CTs as I discussed above.

18 **Q. Are there additional considerations that support the inclusion of 1,419.5 MW of**  
19 **battery storage in 2026?**

20 A. Yes. The continued deployment of low-cost solar generation, which generates  
21 electricity during daytime hours, is complemented by storage in order to continue to  
22 push low-cost power to the grid when needed. With FPL’s typical net system peak

1 (after accounting for solar generation) occurring in the evening time, storage capacity  
2 enables FPL to dispatch lower-cost electricity during these net peak times.

3

4 Also, FPL's combined-cycle fleet most often undergoes maintenance during the  
5 shoulder months, which have been susceptible to high load conditions. The stable  
6 capacity provided by battery storage helps to address higher loads and unexpected  
7 events, which in turn promotes system reliability.

8

9 Battery storage also provides variable cost savings via energy arbitrage – *i.e.*, charging  
10 when energy is the cheapest and discharging to avoid more expensive generation.  
11 Energy arbitrage becomes even more pronounced when a system has large amounts of  
12 solar, as is the case with FPL. Solar drives down the price of energy during the day,  
13 and batteries can discharge in the early evening to avoid more expensive generation  
14 starting or ramping up, increasing generation resource cost-effectiveness to the benefit  
15 of customers.

16 **Q. Is the addition of the 2026 battery storage and solar facilities cost-effective?**

17 A. Yes, as detailed in my CPVRR analysis below and attached to my testimony in Exhibit  
18 AWW-5, these additions, along with the proposed 2027 additions, are projected to save  
19 customers nearly \$2 billion over the lives of the assets.

20

1 **C. FPL's Planned Resource Additions (2027)**

2 **Q. What is FPL's resource need for 2027?**

3 A. As identified in the stochastic LOLP analysis, FPL's total firm MW requirement  
4 increases by 626 MW from 2027 to 2028, and it must make additions in the beginning  
5 half of 2027 to address the identified 273 MW need for 2027 shown in Exhibit  
6 AWW-1.

7 **Q. Please detail FPL's proposed resource additions in 2027 to address this need.**

8 A. FPL's analysis supports the construction of 16 74.5 MW solar sites (1,192 MW) and  
9 another 819.5 MW of battery storage throughout 2027. Adding these resources (along  
10 with the 2026 additions) will allow FPL to meet its 0.1 days per year LOLP criterion  
11 throughout 2027.

12 **Q. How do the 2027 additions address the need identified in the stochastic LOLP  
13 analysis?**

14 A. These additions address the resource need identified for 2027 in the same manner I  
15 described for the 2026 additions above; that is, by providing the stable, dispatchable  
16 capacity and energy needed generation to meet FPL's identified system need. FPL's  
17 addition of 1,192 MW of new solar generation and 819.5 MW of battery storage in  
18 2027 allow FPL to maintain a 0.1 days-per-year LOLP throughout 2027. Additionally,  
19 even with the 2027 additions, FPL must add additional firm capacity in the first half of  
20 2028 to address a 19 MW shortfall identified for 2028.

1 **Q. Are FPL's 2026 and 2027 resource additions supported by a CPVRR analysis?**

2 A. Yes. FPL tested the cost-effectiveness of its 2026 and 2027 solar and battery storage  
3 additions to ensure they are the most cost-effective options to address the Company's  
4 identified reliability needs.

5 **Q. What was the result of that CPVRR analysis?**

6 A. The combination of FPL's planned 2026 and 2027 solar and battery storage additions  
7 result in \$1,942 million CPVRR savings for FPL's customers, as compared to an  
8 alternative plan that excludes the additions. This analysis demonstrates that the  
9 facilities provide substantial savings for FPL's customers while addressing FPL's  
10 identified reliability needs. Exhibit AWW-5 provides the results of the CPVRR  
11 analysis.

12

13

***D. FPL's 2028 and 2029 Resource Needs***

14 **Q. What is FPL's resource need for 2028 and 2029?**

15 A. As identified in the stochastic LOLP analysis, FPL's need for additional firm capacity  
16 continues to increase in years 2028 through 2030. Between 2028 and 2029 FPL's total  
17 reliability need increases from 32,948 MW to 33,544 MW, an increase of 596 MW.  
18 Between 2029 and 2030, FPL's total reliability need increases from 33,544 MW to  
19 34,102 MW, an increase of 558 MW. The stochastic LOLP analysis shows that without  
20 added resources in 2028 and 2029 to address this increasing growth, FPL will fall short  
21 of its 0.1 days-per-year LOLP standard.

1 **Q. Has FPL identified which resources best address these needs?**

2 A. Yes. Based on FPL's analysis the most cost-effective resources to meet those needs  
3 are 1,490 MW of solar in 2028 and 1,788 MW of solar in 2029, as well as 596 MW of  
4 battery storage in each of those years. These additions will allow FPL to maintain its  
5 0.1 LOLP standard in both 2028 and 2029. As with 2027, FPL must add resources  
6 earlier in 2028 and 2029 to address MW shortfalls in those years of 19 MW and  
7 104 MW, respectively. Additionally, as shown in Exhibit AWW-1, even with the  
8 proposed 2028 and 2029 additions, FPL will still have a reliability need in 2030 and  
9 beyond, which will have to be addressed in order to maintain an LOLP of 0.1 days-per-  
10 year.

11 **Q. What is driving FPL's projected system needs in 2028 and 2029, and how do the**  
12 **identified resources meet those needs?**

13 A. FPL's system is projected to continue growing throughout the 2028-2029 time period,  
14 such that energy from new cost-effective solar will be needed while capacity from  
15 battery storage will ensure that power can be reliably delivered to customers every hour  
16 of the year. As FPL's system continues to grow and leverage cost-effective solar  
17 generation, the requirement to maintain sufficient and readily dispatchable generation  
18 becomes increasingly necessary, as shown in the stochastic LOLP analysis.

19  
20 As with FPL's 2026 and 2027 additions, the resources identified for 2028 and 2029 are  
21 projected to address the capacity need identified in the stochastic LOLP analysis and  
22 ensure that FPL's other reliability criteria are met. Additionally, these resources can  
23 be constructed and operational in time to meet the identified needs.

1 **Q. Are the Company's identified resource additions in 2028 and 2029 forecasted to**  
2 **be cost-effective?**

3 A. Yes. Not only do the 2028 and 2029 additions contribute to FPL's ability to provide  
4 reliable power to customers over every hour of the year, they are also cost-effective  
5 compared to adding gas-fired CTs.

6 **Q. What are the projected CPVRR savings of a resource plan with the 2028 and 2029**  
7 **additions as compared to a resource plan without these additions?**

8 A. As demonstrated in Exhibit AWW-6, the projected CPVRR benefit to FPL's customers  
9 of adding the 2028 and 2029 additions compared to a plan that only adds CTs to address  
10 peak reserve margin needs is \$2,213 million.

11 **Q. Is FPL requesting approval for cost recovery associated with the 2028 and 2029**  
12 **additions you have identified?**

13 No, not in this proceeding. My testimony provides FPL's projected needs based on  
14 FPL's current resource planning. As discussed by FPL witnesses Bores, Laney, and  
15 Oliver, FPL's four-year plan proposes a Solar and Battery Base Rate Adjustment  
16 mechanism pursuant to which FPL would seek recovery for solar and battery storage  
17 facilities installed in 2028 and 2029 upon a showing of a resource or economic need  
18 based on updated information.



1                   **III.    UPDATE TO COST OF SERVICE METHODOLOGY**

2   **Q.    What production cost-of-service methodology is FPL proposing to use in this**  
3   **proceeding?**

4   A.    As detailed in the testimony of FPL witness DuBose, FPL is proposing to use a 12 CP  
5   and 25% allocation method for production plant to better align cost allocations among  
6   customer classes with changes to FPL’s portfolio of generation resources.

7   **Q.    What are the changes to FPL’s generation portfolio that support the revised cost**  
8   **of service methodology?**

9   A.    As I detailed earlier in my testimony, FPL has installed a significant amount of cost-  
10   effective solar generation and plans to continue expanding its development of solar  
11   resources. This expansion is pushing FPL’s critical time of peak to later in the evening,  
12   which is when incremental dispatchable generation is needed.

13  
14   With FPL’s implementation of more solar generation, FPL has begun using a “net peak  
15   load” methodology to assign firm capacity values to solar added to its system. This  
16   methodology takes the hourly shape of FPL’s load forecast, then subtracts the projected  
17   hourly solar generation from the load. The resulting shape shows FPL’s “net peak  
18   load” and represents the load that incremental generation additions must meet. As  
19   discussed previously, as more solar generation is added to FPL’s system, the time of  
20   the net peak shifts further into the evening – therefore, incremental solar additions have  
21   an incrementally lower firm capacity value as their generation declines in the peak  
22   evening hours. Despite this decline in firm capacity value for solar, solar generation


1 continues to be the most cost-effective resource for FPL’s system, based on the energy  
2 needs that it serves throughout the day.

3

4 As shown in Figure 1 below, FPL’s system peak in 2026, excluding solar generation,  
5 occurs at hour-ending 5:00 p.m. in the summer. However, after accounting for the  
6 projected output from FPL’s incremental solar additions through 2026, FPL’s net load  
7 peak shifts to hour-ending 8:00 p.m.

8

**FIGURE 1**



9

10 These changes in FPL’s system move the effective system peak later into the evening,  
11 and the types of customers and customer activities that cause the need for incremental  
12 generation during these times are different. These changing system dynamics and the  
13 changing times of FPL’s net load peak support the Company’s change in production  
14 cost-of-service methodology, as detailed by FPL witness DuBose.

15

1 **IV. LARGE LOAD CONTRACT SERVICE**

2 **Q. What tariff changes is FPL proposing to address the impacts of future large load**  
3 **customers?**

4 A. As explained in the testimony of FPL witness Cohen, FPL is proposing new rate  
5 schedules for future customers with a projected new or incremental load of 25 MW or  
6 more and a projected load factor of 85% or more. Those rate schedules, LLCS-1 and  
7 Large Load Contract Service-2 (“LLCS-2”), are designed to proactively address the  
8 potential scenario that future customers of this size request service within the FPL  
9 service area and, if so, to ensure that the general body of customers is protected from  
10 the higher costs to serve such large load customers. In order to serve a customer of this  
11 magnitude, FPL would need to make significant investments in new incremental  
12 generation capacity that, but for the customer’s request for service, would not otherwise  
13 be incurred or needed to serve the general body of customers.

14 **Q. Why is the maximum of 3 GW of demand appropriate for LLCS-1?**

15 A. As explained by FPL witness Cohen, rate schedule LLCS-1 will be available to serve  
16 a combined total of 3 GW of demand in three specific regions of the Company’s service  
17 area. These regions were selected based on their proximity to FPL’s transmission  
18 facilities and areas suitable for the incremental generation capacity necessary to serve  
19 up to a combined total load of 3 GW. In these regions FPL would be able to  
20 accommodate up to approximately 1 GW of new demand without significant network  
21 upgrades – thereby minimizing overall costs incurred – while still meeting all of FPL’s  
22 reliability criteria. Additionally, the 3 GW maximum for rate schedule LLCS-1 is  
23 appropriate because it corresponds to the amount of generation that FPL forecasts it

1 can reasonably and safely ramp up and deploy on its system starting in 2028 to serve  
2 up to 1 GW of new demand in each of the selected regions. The 3 GW maximum  
3 demand for schedule LLCS-1 therefore mitigates the potential for reliability issues and  
4 costly new system investment, and better ensures that FPL can safely dispatch system  
5 resources efficiently to meet the high load factor demand of these potential new large  
6 load customers.

7

8 **V. INCENTIVE PAYMENT LEVELS FOR CDR & CILC**

9 **Q. Please describe the CDR and CILC programs.**

10 A. The CDR and CILC programs are FPL's largest DSM programs for commercial and  
11 industrial customers. Voluntary participants in these programs agree to allow FPL to  
12 remotely lower a portion of the participant's served electric load as needed (for  
13 example, during a period of high electrical demand on FPL's system) in exchange for  
14 the participant receiving a reduction in their monthly bill.

15

16 The two programs have a combined demand reduction capability of slightly more than  
17 900 MW<sup>1</sup>. The CDR program is open to new participants. The CILC program was  
18 officially closed to new participants in the year 2000 and was essentially replaced by  
19 the CDR program, which offers a similar load management program to commercial and  
20 industrial customers.

---

<sup>1</sup> This value is the maximum summer peak value, calculated at the generator.

1 **Q. What are the current incentive payment levels for the two programs?**

2 A. The incentive payments are administered differently for each program. For the CDR  
3 program, the incentive is administered as a \$/kW credit on the monthly bill. The current  
4 CDR program monthly incentive is \$8.76/kW. For the CILC program, the incentive is  
5 administered as a percentage reduction of the base bill as discussed in the testimony of  
6 FPL witness Cohen.

7 **Q. How were the current incentive payment levels of the two programs set?**

8 A. The current incentive payment levels were set pursuant to FPL's 2021 base rate  
9 settlement agreement approved by Order No. PSC-2021-0446-S-EI. Paragraph 4(e) of  
10 that agreement set incentive payments for the CDR and CILC programs at the then-  
11 current level until, at least, "the effective date of new FPL base rates implemented  
12 pursuant to a general base rate proceeding." The Commission affirmed that a general  
13 base rate proceeding is the appropriate proceeding for setting incentive payments for  
14 these programs for FPL with the Commission's approval of stipulations in Order No.  
15 PSC-2024-0505-FOF-EG.

16 **Q. How does the current CDR rate compare with the rate that was in effect when  
17 most participants joined the program?**

18 A. Approximately 75% of the existing CDR participants joined the program during 2000  
19 to 2012. During this time period, the monthly incentive was initially \$4.75/kW then  
20 decreased to \$4.68/kW, representing just over 50% of its current amount.

1 **Q. Is FPL proposing to change the monthly incentive payments for both programs in**  
2 **this proceeding?**

3 A. Yes. FPL is proposing to change the incentives to align them with the value they  
4 provide to customers. My testimony discusses the proposed changes in incentive  
5 payments in terms of a \$/kW payment format. The CILC program's incentive payment  
6 is a percentage reduction of the base bill. FPL witness Cohen discusses how rates are  
7 designed for CILC customers, and those rates are shown in Exhibit TCC-6.

8 **Q. How large a factor are the incentive payments in relation to the overall costs of**  
9 **the programs?**

10 A. The programs have three cost components: (i) administrative costs, (ii) unrecovered  
11 revenue requirements, and (iii) monthly incentive payments. Using the CDR program  
12 as an example, the monthly incentive payments account for approximately 99% of the  
13 projected total CPVRR cost of the CDR program. Consequently, the monthly incentive  
14 payment is the primary "driver" of program costs.

15 **Q. How does FPL evaluate the economic value of the CDR and CILC programs?**

16 A. FPL analyzes the cost-effectiveness of each of its DSM programs, including the CDR  
17 and CILC programs, using three cost-effectiveness screening tests: (i) the RIM test,  
18 (ii) the Total Resource Cost ("TRC") test, and (iii) the Participant test.

19

20 For programs such as CDR, the RIM test is the cost-effectiveness test used to set an  
21 appropriate incentive level. The TRC test does not incorporate incentives into its  
22 calculation of costs, and therefore does not change as the value of incentive payments  
23 change. The Participant test measures the benefit to the participant against any

1 incremental costs the participant in a program incurs. For CDR, the participant does  
2 not incur any direct incremental costs to participate, resulting in an infinite cost-benefit  
3 ratio. For these reasons, FPL relies on the RIM test to analyze the appropriate incentive  
4 level for CDR in terms of economic value.

5 **Q. How does FPL determine the full value of the CDR and CILC programs?**

6 A. To make this determination, FPL evaluates the economics of two comparative resource  
7 plans developed using the AURORA optimization model. One resource plan, the  
8 “With Programs” plan, assumes the inclusion of all of the approximately 900 MW of  
9 demand reduction capability from existing CDR and CILC participants and the  
10 approximately 6 MW per year of projected new CDR participants. However, for  
11 purposes of the analysis, the projected monthly incentive payments for both existing  
12 and new participants are zeroed out. As a result, the “With Programs” resource plan  
13 accounts for all of the demand reduction benefits of the CDR and CILC programs but  
14 assumes no incentive payment costs.

15  
16 The second resource plan, the “Without Programs” plan, assumes that all the existing  
17 CDR and CILC MW, all projected new CDR sign-ups, and all incentive payments for  
18 both programs are removed from the resource plan starting in January 2026.<sup>2</sup> The  
19 AURORA model then selected the most cost-effective generation resources to replace  
20 the loss of 900+ MW of demand reduction capability.

---

<sup>2</sup> Note that the use of the January 2026 “exit” date assumption means all existing participants in the CDR and CILC programs would exit the programs with less than one year’s notice (which ignores the 5-year exit notice terms for both programs). Because of this assumed sudden loss of 900+ MW of demand reduction capability, replacement capacity needs to be added relatively quickly. As a result, the January 2026 exit assumption maximizes the projected value of the two programs for purposes of this analysis.

1 The projected CPVRR costs of the two resource plans were then compared. The  
2 projected CPVRR cost of the Without Programs resource plan, \$100,390 million, is  
3 higher than the projected CPVRR cost of the With Programs resource plan,  
4 \$99,322 million, because the Without Programs resource plan must add new resources  
5 to make up for the loss of the 900+ MW of demand reduction capability offered by the  
6 CDR and CILC programs. The two resource plans, and the projected CPVRR costs for  
7 each plan, are presented in Exhibit AWW-7.

8

9 The \$1,069 million ( $\$100,390 - \$99,322 = \$1,069$ ) CPVRR differential represents the  
10 projected benefits of the CDR and CILC programs through 2071. It also represents –  
11 after accounting for the administrative costs of the CDR and CILC programs – the  
12 amount of CPVRR cost that can be paid in the form of monthly incentive payments to  
13 CDR and CILC participants in the With Programs resource plan before both resource  
14 plans will have an identical CPVRR cost (assuming that there will be no future changes  
15 to the current projections of CDR and CILC benefits or program administrative costs).

16 **Q. What other considerations were taken into account when developing the proposed**  
17 **new monthly incentive payment for the two programs?**

18 A. Three other considerations were taken into account in establishing the proposed  
19 incentive payment levels for the programs. The first consideration for any DSM  
20 program, including these two programs, is that the maximum incentive level that should  
21 be considered is one that results in program costs exactly equaling program benefits  
22 (*i.e.*, a RIM benefit-to-cost ratio of 1.00). Such a result means that program participants  
23 will benefit from the program and that the utility's general body of customers should



1 be indifferent regarding whether the program is offered because electric rates are  
2 unchanged compared to what they would be if the DSM program had not been offered  
3 and the best generation alternative had been chosen instead.

4  
5 The second consideration is that, all else equal, it is preferable for a DSM program's  
6 RIM benefit-to-cost ratio to be greater than 1.00. In such a case, all customers benefit  
7 from the DSM program, not just the program participants. This consideration  
8 recognizes that paying the maximum incentive for a DSM program does not maximize  
9 the benefit to the general body of customers – it merely ensures that the general body  
10 is indifferent.

11  
12 The third consideration is how the demand response is credited in terms of capacity in  
13 FPL's system. Based on the stochastic LOLP analysis, demand response is limited to  
14 a certain percentage of its capacity, which, over time, degrades its potential to serve  
15 FPL's increasing load. Therefore, the further beyond 1.00 the RIM ratio is, the more  
16 assurance there is that the credit given to CDR customers does not outweigh its benefits  
17 to the general body of customers.

18 **Q. Taking these considerations into account, how did FPL determine the appropriate**  
19 **incentive level for these programs?**

20 A. First, cost-effectiveness calculations were performed for the current CDR monthly  
21 incentive level of \$8.76/kW (Scenario 1). These calculations are presented in Exhibit  
22 AWW-8. The left-hand side of Exhibit AWW-8 presents seven assumptions used in  
23 the calculations. Assumption (1) is the CPVRR difference between the With Programs

1 resource plan and the Without Programs resource plan that appears in Exhibit AWW-  
2 7, which is \$1,069 million. Assumption (2) is the projected CPVRR administrative  
3 cost of the combined CDR and CILC programs, which equates to \$10 million.  
4 Assumption (3) is the current monthly incentive level for CDR of \$8.76/kW.  
5 Assumptions (4) through (7) present other inputs used in calculations.

6

7 The right-hand side of Exhibit AWW-8 presents a table that shows the results of  
8 calculations for two scenarios. In Scenario 1, the projected RIM benefit-to-cost ratio  
9 for the 900+ MW of CDR and CILC with the current monthly incentive level of  
10 \$8.76/kW is shown: 1.06. This result shows that the program and its current incentive  
11 level is beneficial for participants but, with a RIM ratio of near 1.00, leaves the general  
12 body near the point at which they are indifferent to the program.

13

14 For that reason, and based on the three evaluative considerations discussed above, FPL  
15 determined that it was appropriate to lower the monthly CDR incentive level to  
16 \$6.22/kW. Scenario 2 in Exhibit AWW-8 shows the same calculations for the  
17 programs with the revised monthly incentive level, as well as the resulting RIM benefit-  
18 to-cost ratio of 1.49. This higher benefit-to-cost ratio provides a reasonable level of  
19 assurance that the programs will remain cost-effective for all customers for the  
20 expected 4-to-5-year period until the incentive levels are next reviewed. This value  
21 also ensures that CDR is still beneficial to participants and does not burden non-  
22 participants with higher program costs than are required for maintenance of the  
23 program. Moreover, as stated in the testimony of FPL witness Cohen, the annual

1 savings associated with the reduction in the credit for CILC and CDR customers is  
2 approximately \$22 million in 2026 and 2027.

3 **Q. How does the proposed monthly incentive level compare to the incentive level that**  
4 **existed at the time most of the CDR participants joined the program?**

5 A. As I referenced above, approximately 75% of the existing CDR participants joined the  
6 program during 2000 to 2012, when the monthly incentive was initially \$4.75/kW then  
7 decreased to \$4.68/kW. The proposed new CDR monthly incentive level of \$6.22/kW  
8 is nearly 31% higher than the incentive level that was in place when the majority of  
9 CDR participants joined the program.

10

11 Therefore, this proposed new incentive level will be sufficient to help ensure the cost-  
12 effectiveness of the CDR and CILC programs for a 4- to 5-year period, achieve future  
13 CDR program participation needed to meet FPL's approved DSM Goals, retain existing  
14 CDR and CILC participants, and ensure that non-participants are not bearing  
15 unnecessary program costs.

16 **Q. Does this conclude your direct testimony?**

17 A. Yes.

# Florida Power & Light Resource Adequacy Study

February 21, 2025



Energy+Environmental Economics



## Overview

---

**+ FPL asked E3 to perform a loss-of-load study of the FPL system using E3’s Renewable Energy Capacity Planning (RECAP) model to answer three key questions:**


1. What is the FPL system’s achieved reliability during 2027-2030 and 2035?
2. What is the contribution of each resource type to maintaining resource adequacy?
3. What is the nature, timing and duration of simulated loss-of-load events on the FPL system?

**+ This report summarizes the results of that study**

## RECAP Model Overview




# Overview of best practices in resource adequacy analysis



# Loss-of-load probability (LOLP) modeling is the foundation for understanding resource adequacy needs

- + LOLP modeling can be thought of as an organized way to analyze the potential for extreme weather and other events to cause a supply shortfall
- + LOLP captures factors that matter for reliability such as:
  - High loads due to extreme weather
  - Correlations between load and renewable conditions
  - Energy and capacity limitations
  - Dispatch behavior of energy-limited resources such as energy storage and demand response





# RECAP – Loss-of-Load-Probability Model




A loss-of-load-probability model is designed to study the reliability dynamics of an electric system

+ LOLP model simulates the operations of the electricity system under hundreds of scenarios to capture different conditions, including:


- load variability,
- weather variability,
- renewable output variable, and
- forced outage events

+ Key LOLP Modeling outputs:

- System reliability
- Target Planning Reserve Margin
- Capacity Shortfall
- Capacity Value of Resources




# RECAP Inputs and Outputs



# RECAP Workflow

Weather-matched load, wind and solar



**System Demand**  
(net of EE)  
simulated hourly across a broad range of weather conditions

**Variable Resources**  
(including BTM PV) simulated with weather-matched hourly profiles

Energy-limited resources dispatched time-sequentially



**Firm Resources**  
simulated based on rated capacity and outage rates

**Hydroelectric Resources**  
dispatched based on monthly capacity & energy limits

**Storage Resources**  
dispatched according to limits on duration and round-trip losses

**DR Programs**  
dispatched subject to limits on number of calls & duration

**Unserved Energy**  
identified based on any unmet demand



Each simulation analyzes conditions across hundreds to thousands of possible years using a Monte Carlo approach, where each year captures a different combination of underlying weather, load, wind & solar profiles; outage patterns; and energy-limited resource dispatch

## This study calculates FPL’s Total Resource Need (TRN) and Target Planning Reserve Margin (Target PRM) that achieves a 0.1 LOLE standard


- + Total Resource Need is the quantity of effective capacity needed to meet a defined reliability standard

- Defined for this study as “1 day in 10 years” or Loss-of-Load Expectation (“LOLE”) of 0.1 days/yr.

- + PRM is measured as the quantity of capacity needed above the median year peak load to meet the LOLE standard


- Calculated as  $(TRN - \text{Median Peak}) / \text{Median Peak}$
  - Serves as a simple and intuitive metric that can be utilized broadly in power system planning

- Considers load and resource conditions during *all hours of the year*



# Resource adequacy challenges are evolving, necessitating updates to historical analytical methods

- + Traditional resource adequacy planning relies on dispatchable resources to meet **gross peak demand**
- + As renewable penetration grows, planning to meet **net peak demand** becomes the pivotal challenge
- + Capturing thermal fleet unavailability is increasingly important as its capacity value may be affected by correlated outages




## Traditionally, resource accreditation was simple with conventional “firm” generating resources

### + PRM defined based on Installed Capacity method (ICAP)

- ❑ Covers annual peak load variation, operating reserve requirements, and thermal resource forced outages

### + Individual resources accredited based on nameplate capacity


- ❑ Small differences in forced outage rates
- ❑ No interactions among resources
- ❑ Forced outages also incorporated through performance penalties



$$\text{Installed Capacity} = \sum_{i=1}^n G_i$$

## ELCC approach adapts the PRM framework for a more diverse resource mix and calculates each resource type's contribution to the Total Resource Need

- + PRM defined based on need for Equivalent Perfect Capacity (PCAP)
  - ❑ Covers annual peak load variation and operating reserves only; forced outages addressed in resource accreditation
- + Individual resources accredited based on ELCC
  - ❑ Large differences in availability during key hours
  - ❑ Significant interactions among resources
  - ❑ ELCC values are dynamic based on resource portfolio



$$Portfolio\ ELCC = f(G_1, G_2, \dots, G_n)$$

## Measuring ELCC of a portfolio and individual resources

### + ELCC is a function of the portfolio of resources

- ❑ The function is a surface in multiple dimensions
- ❑ The Portfolio ELCC is the height of the surface at the point representing the total portfolio


$$\text{Portfolio ELCC} = f(G_1, G_2, \dots, G_n) \text{ (MW)}$$

- ❑ The Marginal ELCC of any individual resource is the gradient (or slope) of the surface along a single dimension – mathematically, the partial derivative of the surface with respect to that resource

$$\text{Marginal ELCC}_{G_1} = \frac{\partial f}{\partial G_1} (G_1, G_2, \dots, G_n) \text{ (\%)}$$

### + The functional form of the surface is unknowable


- ❑ Marginal ELCC calculations give us measurements of the contours of the surface at specific points
- ❑ It is impractical to map out the entire surface






## E3 used a marginal ELCC methodology to calculate each resource type's incremental contribution to system resource adequacy

- + No resource is “perfect”: ELCC measures all resources against equivalent perfect capacity
  - Demand response also accredited using ELCC based on modeled performance during critical hours
- + Accounts for all factors that can limit availability:
  - Hourly variability in output
  - Duration and/or use limitations
  - Temperature-related derates
  - Temperature-related forced outage rates
  - Energy availability
  - Correlated outage risk
- + Uses Perfect Capacity (PCAP) accounting as opposed to ICAP or UCAP



## RECAP's ELCC calculations capture diminishing capacity contribution of variable and dispatch-limited resources at higher penetrations




Solar and other **variable resources** exhibit declining value due to variability of production profiles

Storage and other **energy-limited resources** (e.g. DR) exhibit declining value due to limited ability to generate over sustained periods

## RECAP’s ELCC calculations capture interactive or “portfolio” effects from the addition of different types of resources to the portfolio



- + Different types of resources interact with each other, creating portfolio effects in which the total ELCC derived from the portfolio is greater than the sum of marginal ELCC values from individual resources
- + Resources with similar characteristics may compete with each other, leading to more rapid marginal ELCC declines
- + As penetrations of intermittent and energy-limited resource grow, the magnitude of these interactive effects increases and becomes a significant factor in system planning



# RECAP's ELCC calculations capture the shifting of critical hours from “gross peak” to “net peak” resulting from higher penetrations of solar energy


- + On a system with conventional resources, resource adequacy events typically coincide with peak load periods
- + ICAP accreditation is independent of the timing of peak load needs

- + On a system with high solar penetration, resource adequacy events typically occur after sundown when solar generation is low
- + Marginal ELCC accreditation captures resource performance during these new critical hours



## ELCC is increasingly used by utilities and ISOs across the country

- + Many ISO/RTOs and utilities are already using or considering a transition to ELCC for renewable (e.g., solar, wind) and/or energy limited resources (e.g., storage)



# Resource Adequacy Study Results for Florida Power & Light



Energy+Environmental Economics

# Reliability Results Summary

Model Year	Median Peak Load	Perfect Capacity Reserve Margin Target	Total Reliability Need	Portfolio Capacity Value (ELCC Methodology)	Capacity Shortfall	Achieved Loss of Load Expectation
	MW	% of Peak	Firm MW	Firm MW	Firm MW	Days per Year
2027 TYP <i>+1,400MW Batteries</i>	29,708	8.8%	32,322	32,049	(273)	0.11
2028	30,283		32,948	32,929	(19)	0.10
2029	30,831		33,544	33,440	(104)	0.13
2030	31,344		34,102	33,991	(112)	0.13
2035	34,847		37,914	36,696	(1,218)	0.33
<i>Derivation:</i>	<i>A</i>		<i>B</i>	$C = A \times (1+B)$	<i>D</i>	$E = D - C$

## Load & Resources Table 2027 – Ten-Year Site Plan (TYP) Portfolio

<i>LOLP-Derived Methodology</i>		2027		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	28,281	25,197	89%
2	Utility Solar (Fixed + Tracking)	8,946	1,407	16%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	2,125	83	4%
4	Storage	991	923	93%
5	Demand Response (DR)	1,951	1,703	87%
6	Portfolio Effect/Peak to Net Load Shift		1,348	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	42,294	30,659	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	29,708		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	32,322		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-1663</b>		

- + All resource accredited using a marginal ELCC methodology
- + For 2028 and beyond, utility solar and BTM solar marginal ELCC is derived from a single marginal solar value, allocated out based on the 2027 marginal values
- + For 2028 and beyond, Storage and DR marginal ELCC is derived from a single marginal storage value, allocated out based on the 2027 marginal storage and DR values

1) MWAC, assuming ILR = 1/0.85



## Load & Resources Table 2027 – TYP Portfolio +1,400 MW of Storage

<i>LOLP-Derived Methodology</i>		2027 +1,400 MW of Storage		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	28,281	25,197	89%
2	Utility Solar (Fixed + Tracking)	8,946	1,516	17%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	2,125	169	8%
4	Storage	<b>2,391</b>	1,808	76%
5	Demand Response (DR)	1,951	1,584	81%
6	Portfolio Effect/Peak to Net Load Shift		1,775	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	43,694	32,049	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	29,708		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	32,322		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-273</b>		

- + Additional 1,400 Nameplate MW of Storage relative to the 2027 TYP portfolio
- + This reduces the capacity shortfall by 1,390 Firm MW
- + Marginal ELCC of solar is higher with more storage
- + Marginal ELCC of storage and DR is lower with higher storage penetration

1) MW AC, assuming ILR = 1/0.85

# Load & Resources Table 2028

<i>LOLP-Derived Methodology</i>		2028		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	28,362	25,269	89%
2	Utility Solar (Fixed + Tracking)	9,840	1,424	14%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	2,593	176	7%
4	Storage	3,211	1,596	50%
5	Demand Response (DR)	1,945	1,038	53%
6	Portfolio Effect/Peak to Net Load Shift		3,425	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	45,951	32,929	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	30,283		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	32,948		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-19</b>		

+ Requirement grows by 626 MW due to load growth

+ Resources added:

- 81 MW more thermal
- 1,362 MW more solar reduces marginal ELCC by 1-3 percent
- 820 MW more storage reduces marginal ELCC by 26 percent
- Larger portfolio effect due to increased solar-storage penetration, diminished marginal ELCCs, and lower net peak loads during critical hours

1) MWAC, assuming ILR = 1/0.85

## Load & Resources Table 2029

<i>LOLP-Derived Methodology</i>		2029		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	28,197	25,122	89%
2	Utility Solar (Fixed + Tracking)	11,628	1,230	11%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	3,118	155	5%
4	Storage	3,807	1,614	42%
5	Demand Response (DR)	1,945	885	46%
6	Portfolio Effect/Peak to Net Load Shift		4,434	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	48,695	33,440	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	30,831		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	33,544		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-104</b>		

+ Requirement grows by 596 MW due to load growth

+ Resource changes from 2028:

- 165 MW less thermal
- 2,313 MW more solar reduces marginal ELCC by 2-3 percent
- 596 MW more storage reduces marginal ELCC by 8 percent
- DR marginal ELCC is also reduced due to higher storage penetration
- Larger portfolio effect due to increased solar-storage penetration, diminished marginal ELCCs, and lower net peak loads during critical hours

1) MWAC, assuming ILR = 1/0.85

# Load & Resources Table 2030

<i>LOLP-Derived Methodology</i>		2030		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	28,194	25,119	89%
2	Utility Solar (Fixed + Tracking)	13,416	897	7%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	3,704	116	3%
4	Storage	4,403	1,647	37%
5	Demand Response (DR)	1,944	781	40%
6	Portfolio Effect/Peak to Net Load Shift		5,430	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	51,661	33,991	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	31,344		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	34,102		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-112</b>		

+ Requirement grows by 558 MW due to load growth

+ Resource changes from 2029:

- 3 MW less thermal
- 2,374 MW more solar reduces marginal ELCC by 4-8 percent
- 596 MW more storage reduces marginal ELCC by 5 percent
- DR marginal ELCC is also reduced due to higher storage penetration
- Larger portfolio effect due to increased solar-storage penetration, diminished marginal ELCCs, and lower net peak loads during critical hours

1) MWAC, assuming ILR = 1/0.85

# Load & Resources Table 2035

<i>LOLP-Derived Methodology</i>		2035		
		Nameplate Capacity (MW)	Firm Capacity (MW)	Firm Capacity (% of Nameplate)
1	Thermal + Kingfisher 1/2	27,942	24,895	89%
2	Utility Solar (Fixed + Tracking)	24,517	382	2%
3	Behind-the-meter (BTM) Solar <sup>1</sup>	7,244	53	1%
4	Storage	7,383	1,786	24%
5	Demand Response (DR)	1,945	505	26%
6	Portfolio Effect/Peak to Net Load Shift		9,074	
7	<b>Portfolio ELCC</b> <i>(E3 Methodology)</i>	69,031	36,696	
8	Median Peak Demand ( <b>Grossed up for BTM PV &amp; Net of Energy Efficiency</b> )	34,847		
9	Median Peak Demand less DR	Not used		
10	<b>PCAP</b> Planning Reserve Margin (PRM)	8.8%		
11	Total Firm MW Requirement	37,914		
12	Firm Capacity Surplus / <b>Shortfall</b>	<b>-1,218</b>		

+ Requirement grows by 3,812 MW due to load growth

+ Resource changes from 2030:

- 252 MW less thermal
- 14,641 MW more solar reduces marginal ELCC to 2 percent
- 2,980 MW more storage reduces marginal ELCC to 24 percent
- DR marginal ELCC is also reduced due to higher storage penetration
- Larger portfolio effect due to increased solar-storage penetration, diminished marginal ELCCs, and lower net peak loads during critical hours



1) MW AC, assuming ILR = 1/0.85

# Effective Load Carrying Capability Results




Energy+Environmental Economics

# Solar and Storage Cumulative ELCC (Firm MW)




# Solar and Storage Marginal ELCC (% of Nameplate MW)

Solar Marginal ELCC at two Different Storage Penetrations  
(% of Solar Nameplate Capacity)



4-hr Storage Marginal ELCC at Three Different Solar Penetrations  
(% of Storage Nameplate Capacity)






# LOLP Heat Map in 2027

## + Observations


- Loss of load risk is mostly concentrated in summer evenings
- Outages also occur during shoulder months (spring and fall) when maintenance and forced outages occur simultaneously
- Loss of load occurs in late evenings, or during low solar periods

2027 Month-Hour Average Unserved Energy, (MWh)



## 2027 Portfolios,

Nameplate MW



Docket No. 20250011-EI  
 Load Forecasts Used in the Current Analyses  
 Exhibit AWW-2, Page 1 of 1

**Load Forecasts Used in the Current Analyses\***

(1)	(2)	(3)	
Year	Summer Peak (MW)	Winter Peak (MW)	Net Energy For Load (GWh)
2025	28,312	23,042	144,793
2026	28,664	23,323	144,931
2027	28,925	23,648	145,905
2028	29,333	24,136	148,562
2029	29,687	24,603	150,976
2030	29,982	25,011	153,094
2031	30,301	25,384	154,375
2032	30,823	25,852	156,728
2033	31,257	26,245	158,922
2034	31,677	26,638	160,473
2035	32,112	27,045	162,209
2036	32,547	27,461	164,006
2037	32,962	27,873	165,643
2038	33,356	28,281	167,117
2039	33,709	28,676	168,417
2040	34,027	29,060	169,482
2041	34,285	29,422	170,443
2042	34,348	29,590	169,858
2043	34,562	29,938	170,506
2044	34,731	30,269	170,984
2045	34,904	30,421	171,836
2046	35,078	30,573	172,692
2047	35,252	30,726	173,554
2048	35,427	30,880	174,419
2049	35,604	31,035	175,289
2050	35,781	31,190	176,163
2051	35,959	31,346	177,042
2052	36,138	31,503	177,926
2053	36,318	31,661	178,814
2054	36,499	31,820	179,707
2055	36,681	31,979	180,604
2056	36,863	32,140	181,506
2057	37,047	32,301	182,413
2058	37,232	32,463	183,324
2059	37,417	32,626	184,240
2060	37,604	32,789	185,161
2061	37,791	32,954	186,086
2062	37,980	33,119	187,016
2063	38,169	33,286	187,952
2064	38,360	33,453	188,891
2065	38,551	33,621	189,836
2066	38,743	33,790	190,786
2067	38,937	33,959	191,740
2068	39,131	34,130	192,700
2069	39,327	34,301	193,665
2070	39,523	34,474	194,634
2071	39,720	34,647	195,608

\* Load forecasts used in resource planning analyses do not include the projected impacts of existing load management programs or of incremental load management and energy conservation utility DSM programs. Those impacts are addressed as line item adjustments to the load forecasts in the resource planning models.

Docket No. 20250011-EI  
 Fuel Cost Forecasts Used in the Current Analyses  
 Exhibit AWW-3, Page 1 of 1

**Fuel Cost Forecasts Used in the Current Analyses  
 (September 3, 2024 Forecast, Nominal \$)**

<b>Year</b>	<b>FGT Firm Gas (\$/MMBTU)</b>	<b>Gulfstream Firm Gas (\$/MMBTU)</b>	<b>Sabal Trail Firm Gas (\$/MMBTU)</b>	<b>Residual Oil (\$/MMBTU)</b>	<b>Distillate Oil (\$/MMBTU)</b>	<b>Scherer 3 Coal Price (\$/MMBTU)</b>
2025	3.34	3.24	3.73	13.86	17.41	3.12
2026	3.77	3.60	4.24	13.38	17.26	3.20
2027	4.59	4.34	4.82	14.21	17.96	3.28
2028	4.70	4.37	4.73	14.45	18.42	3.62
2029	5.05	4.68	5.04	16.08	20.02	3.68
2030	5.11	4.72	5.10	16.17	20.48	3.70
2031	5.15	4.76	5.14	16.13	20.76	3.75
2032	5.43	5.05	5.42	16.22	21.10	3.80
2033	5.90	5.52	5.88	16.33	21.54	3.85
2034	6.12	5.73	6.09	16.37	21.96	3.90
2035	6.60	6.21	6.56	16.39	22.28	3.94
2036	6.82	6.43	6.78	16.41	22.66	3.99
2037	6.90	6.50	6.85	16.42	22.97	4.04
2038	7.05	6.66	7.01	16.52	23.50	4.10
2039	7.25	6.86	7.20	16.53	23.90	4.17
2040	7.62	7.22	7.56	16.58	24.45	4.24
2041	7.94	7.54	7.87	16.62	24.78	4.31
2042	8.19	7.79	8.12	16.64	25.31	4.38
2043	8.52	8.12	8.44	16.65	25.74	4.45
2044	8.74	8.34	8.66	16.67	26.34	4.52
2045	9.12	8.71	9.03	16.68	26.89	4.61
2046	9.90	9.49	9.79	16.68	27.38	4.68
2047	10.46	10.05	10.34	16.69	27.88	4.76
2048	11.05	10.64	10.92	16.69	28.39	4.85
2049	11.63	11.22	11.50	16.69	28.95	4.95
2050	12.33	11.92	12.18	16.72	29.58	5.05
2051	12.28	11.87	12.13	16.71	29.67	5.14
2052	12.23	11.81	12.08	16.69	29.76	5.24
2053	12.18	11.76	12.03	16.68	29.84	5.34
2054	12.13	11.71	11.98	16.67	29.93	5.43
2055	12.08	11.66	11.93	16.66	30.02	4.25
2056	12.03	11.61	11.88	16.65	30.12	5.63
2057	11.98	11.56	11.83	16.63	30.21	5.72
2058	11.92	11.51	11.78	16.62	30.30	5.82
2059	11.87	11.46	11.73	16.61	30.39	5.92
2060	11.82	11.41	11.68	16.60	30.48	6.01
2061	11.78	11.36	11.64	16.58	30.57	6.11
2062	11.73	11.31	11.59	16.57	30.66	6.21
2063	11.68	11.26	11.54	16.56	30.76	6.30
2064	11.63	11.21	11.49	16.55	30.85	6.40
2065	11.58	11.16	11.44	16.54	30.94	6.50
2066	11.53	11.12	11.39	16.52	31.03	6.59
2067	11.48	11.07	11.35	16.51	31.13	6.69
2068	11.43	11.02	11.30	16.50	31.22	6.79
2069	11.38	10.97	11.25	16.49	31.32	6.88
2070	11.34	10.92	11.21	16.48	31.41	6.98
2071	11.29	10.88	11.16	16.46	31.51	7.08

**CO<sub>2</sub> Compliance Cost Forecast Used in the Current Analyses  
(2022 Q4 ICF Forecast, Nominal \$)**

<b>Year</b>	<b>CO<sub>2</sub> Cost (\$/ton)</b>
2025	0.0
2026	0.0
2027	0.0
2028	0.0
2029	0.0
2030	0.0
2031	0.0
2032	0.0
2033	0.0
2034	0.0
2035	0.0
2036	3.3
2037	6.7
2038	10.3
2039	14.1
2040	18.0
2041	20.6
2042	23.7
2043	27.2
2044	31.3
2045	36.0
2046	40.1
2047	44.7
2048	49.9
2049	55.7
2050	62.1
2051	63.4
2052	64.7
2053	66.1
2054	67.5
2055	68.9
2056	70.3
2057	71.8
2058	73.3
2059	74.9
2060	76.4
2061	78.0
2062	79.7
2063	81.4
2064	83.1
2065	84.8
2066	86.6
2067	88.4
2068	90.3
2069	92.2
2070	94.1
2071	96.1

**Economic Analysis Results for the Proposed 2026 and 2027 Solar And Battery Additions**

<b>Common to all Plans Retirements / Additions</b>	<b>Year</b>	<b>Without Proposed 2026 and 2027 Solar And Battery Additions</b>	<b>Reserve Margin (%)</b>	<b>With Proposed 2026 and 2027 Solar And Battery Additions</b>	<b>Reserve Margin (%)</b>
Pea Ridge (12 MW)	2025	894 MW Solar	22.4	894 MW Solar	22.4
---	2026	522 MW Battery NWFL	22.1	522 MW Battery NWFL 894 MW Solar 1,419.5 MW Battery	24.1
Broward South (4 MW)	2027	---	21.1	1,192 MW Solar 819.5 MW Battery	27.2
Lansing Smith A (32 MW)	2028	1 x 2x0 Manatee CT (475 MW)	21.0	---	25.3
---	2029	1 x 2x0 Manatee CT (475 MW)	21.2	---	23.8
GCEC 4 (75 MW), GCEC 5 (75 MW), Perdido 1&2 (3 MW)	2030	1 x 2x0 Manatee CT (475 MW)	21.1	---	22.0
---	2031	1 x 2x0 Manatee CT (475 MW)	21.5	---	20.7
---	2032	1 x 2x0 Manatee CT (475 MW)	20.9	1 x 2x0 Manatee CT (475 MW)	20.0
---	2033	1 x 2x0 Manatee CT (475 MW)	20.8	2 x 2x0 Manatee CT (950 MW)	21.6
---	2034	1 x 2x0 Manatee CT (475 MW)	20.5	1 x 2x0 Manatee CT (475 MW)	21.2

CPVRR Costs =  
CPVRR Costs Difference from the Without Proposed Solar and Battery Additions Plan =

<b>\$108,841</b>
--

<b>\$106,899</b>
<b>(\$1,942)</b>

**Notes:**  
 CPVRR costs are in million \$ and are discounted at 8.15% (FPL's most recent WACC) for the years 2025 thru 2071  
 Negative values indicate CPVRR savings to customers  
 Analysis assumes new CT capacity is available in 2028 to put plans on equal footing; realistically new CT installations would not be available until late 2029 or early 2030 at the earliest

**Economic Analysis Results for the Proposed 2028 and 2029 Solar And Battery Additions**

<b>Common to all Plans Retirements / Additions</b>	<b>Year</b>	<b>Without Proposed 2028-2029 Solar And Battery Additions</b>	<b>Reserve Margin (%)</b>	<b>With Proposed 2028-2029 Solar And Battery Additions</b>	<b>Reserve Margin (%)</b>
Pea Ridge (12 MW)	2025	894 MW Solar	22.4	894 MW Solar	22.4
---	2026	522 MW Battery NWFL 894 MW Solar 1,419.5 MW Battery	24.1	522 MW Battery NWFL 894 MW Solar 1,419.5 MW Battery	24.1
Broward South (4 MW)	2027	1,192 MW Solar 819.5 MW Battery	27.2	1,192 MW Solar 819.5 MW Battery	27.2
Lansing Smith A (32 MW)	2028	---	25.3	1,490 MW Solar 596 MW Battery	26.6
---	2029	---	23.8	1,788 MW Solar 596 MW Battery	26.3
GCEC 4 (75 MW), GCEC 5 (75 MW), Perdido 1&2 (3 MW)	2030	---	22.0	---	24.5
---	2031	---	20.7	---	23.2
---	2032	1 x 2x0 Manatee CT (475 MW)	20.0	---	20.9
---	2033	2 x 2x0 Manatee CT (950 MW)	21.6	1 x 2x0 Manatee CT (475 MW)	20.8
---	2034	1 x 2x0 Manatee CT (475 MW)	21.2	1 x 2x0 Manatee CT (475 MW)	20.5

CPVRR Costs =  
CPVRR Costs Difference from the Without Proposed 2028-2029 Solar and Battery Additions Plan =

<b>\$106,899</b>
--

<b>\$104,686</b>
<b>(\$2,213)</b>

**Notes:**

CPVRR costs are in million \$ and are discounted at 8.15% (FPL's most recent WACC) for the years 2025 thru 2071

Negative values indicate CPVRR savings to customers

**With Programs and Without Programs Resource Plans for CDR and CILC Incentive Payment Analysis**

	(1)	(2)	(3)	(4)	(5)
<b>Year</b>	<b>Common to All Plans Retirements/Additions</b>	<b>"With Programs" Resource Plan</b>	<b>Reserve Margin (%)</b>	<b>"Without Programs" Resource Plan</b>	<b>Reserve Margin (%)</b>
2025	Pea Ridge (12 MW)	894 MW Solar	22.4	894 MW Solar	22.4
2026	---	894 MW Solar 522 MW Battery in NWFL 1,419.5 MW Battery	24.1	894 MW Solar 522 MW Battery in NWFL 1,519.5 MW Battery	20.1
2027	Broward South (4 MW)	1,192 MW Solar 819.5 MW Battery	27.2	1,192 MW Solar 819.5 MW Battery	23.1
2028	Lansing Smith A (32 MW)	1,490 MW Solar 596 MW Battery	26.6	1,490 MW Solar 596 MW Battery	22.6
2029	---	1,788 MW Solar 596 MW Battery	26.3	1,788 MW Solar 596 MW Battery	22.3
2030	GCEC 4 (75 MW), GCEC 5 (75 MW), Perdido 1&2 (3 MW)	2,235 MW Solar 596 MW Battery	25.8	2,235 MW Solar 596 MW Battery	21.8
2031	---	2,235 MW Solar 596 MW Battery	25.7	2,235 MW Solar 596 MW Battery	21.8
2032	---	2,235 MW Solar 596 MW Battery	24.5	2,235 MW Solar 596 MW Battery	20.7
2033	---	2,235 MW Solar 596 MW Battery	23.9	2,235 MW Solar 820 MW Battery	20.3
2034	---	2,235 MW Solar 596 MW Battery	23.0	2,235 MW Solar 2,980 MW Battery	21.4
	<b>CPVRR Cost of Resource Plans =</b>	<b>\$99,322</b>		<b>\$100,390</b>	
	<b>CPVRR Impact for Removing CDR + CILC =</b>	<b>---</b>		<b>\$1,069</b>	

Notes:

CPVRR costs are in million \$ and are discounted at 8.15% (FPL's most recent WACC) for the years 2025 thru 2071

**Analysis of the Current and Proposed Monthly Incentive Levels for the CDR & CILC Programs**

<b>Assumptions:</b>	
Assumption (1): Projected CPVRR Net Benefits for CDR & CILC (millions)	\$1,069
Assumption (2): CPVRR Admin Costs (millions)	\$10
Assumption (3): Current CDR Monthly Incentive Level (\$/kW)	\$8.76
Assumption (4): Discount rate	8.15%
Assumption (5): Average Monthly MW of CDR & CILC	792
Assumption (6): Time Period Over Which CPVRR Costs are Calculated	2025 thru 2071
Assumption (7): CPVRR Cost of \$1/kW Monthly Incentive Payment for 1 MW (see calculation below)	\$143,232

$$\begin{aligned}
 (1) & & (2) & & (3) & & (4) \\
 & & = (\text{Monthly Incentive} \times & & = (2) + & & = (1) / (3) \\
 & & \text{Assumption 5} \times & & \text{Assumption 2} & & \\
 & & \text{Assumption 7}) / 1,000,000 & & & & 
 \end{aligned}$$

<b>Scenario</b>	<b>CPVRR Net Benefits (Millions)</b>	<b>CPVRR Cost of Incentives Only (Millions)</b>	<b>CPVRR Total Cost: Incentives + Admin Costs (Millions)</b>	<b>RIM Benefit-to-Cost Ratio</b>
<b>Scenario 1: With Current Monthly Incentive Level of \$8.76/kW:</b>	\$1,069	\$994	\$1,004	<b>1.06</b>
<b>Scenario 2: With Proposed Monthly Incentive Level of \$6.22/kW:</b>	\$1,069	\$706	\$716	<b>1.49</b>

<b>Year</b>	<b>Annual Incentive Cost for 1 MW at \$1/kW-mo.</b>
2025	\$0
2026	\$12,000
2027	\$12,000
2028	\$12,000
2029	\$12,000
2030	\$12,000
2068	\$12,000
2069	\$12,000
2070	\$12,000
2071	\$12,000
<b>CPVRR =</b>	<b>\$143,232</b>

(Note: rows for years 2031 thru 2067 are not shown to save space; those annual values are identical to the annual values that are shown.)