

FILED 12/19/2025 DOCUMENT NO. 15498-2025 FPSC - COMMISSION CLERK

2548 BLAIRSTONE PINES DRIVE TALLAHASSEE, FLORIDA 32301

PHONE (850) 877-6555

www.sfflaw.com

December 19, 2025

Mr. Adam Teitzman, Clerk Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, FL 32399-0850

Re: NC Real Estate Projects, LLC dba Grenelefe Utility

Request for Staff Assisted Rate Increase – Staff's Seventh Data Request

Docket No. 20250023-WS

Dear Mr. Teitzman,

Attached is the FDEP Permit as part of the response to Staff Data Request #7.

Should you or any members of the Commission staff have any questions in this regard, please let us know.

Sincerely,

SUNDSTROM & MINDLIN, LLP

/s/ F. Marshall Deterding

F. Marshall Deterding Of Counsel

FMD/brf

cc: Jacob Imig
Jennifer Augspurger
Ailynee Ramirez-Abundez
Gary Smith, II
Laura King
Marissa Ramos
Matthew Sibley
Sonica Bruce
Garret Kelley
Jared Folkman
Joshua Cohn
Jason Cox

Gary Morse



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis Governor

Alexis A. Lambert Secretary

Southwest District 13051 N Telecom Pkwy, Suite 101 Temple Terrace, Florida 33637-0926

March 18, 2025

In the Matter of an Application for Permit by:

Grenelefe Resort WWTF Frederick House 3425 Turnberry Dr Lakeland, Florida 33803 Scott@roninassets.com File Number FLA013016-011-DW2P/RA Polk County Grenelefe Water Utilities

Enclosed is Permit Number FLA013016 to operate the Grenelefe Water Utilities, issued under Chapter 403, Florida Statutes (F.S.).

Monitoring requirements under this permit are effective on the first day of the second month following the effective date of the permit. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

NOTICE OF RIGHTS

Judicial Review

Upon issuance of this final permit, any party to this order has the right to seek judicial review of it under Section 120.68, F.S., by the filing of a notice of appeal under Florida Rules of Appellate Procedure 9.110 and 9.190 with the Clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice must be filed within 30 days after this order is filed with the Clerk of the Department.

EXECUTION AND CLERKING

Executed in Hillsborough County, Florida.
STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Gerald "JJ" Loesch

Environmental Administrator

Permitting and Waste Cleanup Program

Southwest District

Grenelefe Water Utilties FLA013016-011-DW2P Page 2

Attachment(s):

- 1. Permit
- 2. Discharge Monitoring Report (DMR)
- 3. Statement of Basis (SOB)
- 4. Administrative Order (AO)

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that this document and all attachments were sent on the filing date below to the following listed persons:

CC:

George McDonald, P.E., McDonald Group International Inc., gmcdonald@mcdonaldgroup.com

Jason Cox, NC Real Estate Projects, jason@roninassets.com

Erica Peck, DEP SWD, erica.peck@floridadep.gov

Gerald "JJ" Loesch, DEP SWD, gerald.loesch@floridadep.gov

Noah Cummings, DEP SWD, noah.cummings@floridadep.gov

FILING AND ACKNOWLEDGMENT

FILED, on this date, pursuant to Section 120.52, F. S., with the designated Department Clerk, receipt of which is hereby acknowledged.

Claulz

3/18/2025

Date



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis Governor

Alexis A. Lambert Secretary

Southwest District 13051 N Telecom Pkwy, Suite 101 Temple Terrace, Florida 33637-926

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:

NC Real Estate Projects, LLC

RESPONSIBLE OFFICIAL:

Frederick Scott House, Managing Member 3425 Turnberry Dr Lakeland, FL 33803 (954) 849-7284 scott@roninassets.com

FACILITY:

Grenelefe Resort WWTF 4501 Abbey Court Haines City, FL 33844-9720 Polk County

Latitude: 28°3' 45" N Longitude: 81°32' 42" W

PERMIT NUMBER: FLA013016

FILE NUMBER: FLA013016-009-DW2/NR ISSUANCE DATE: November 16, 2022

FILE NUMBER: FLA013016-011-DW2P/RA

REVISION DATE: March 18, 2025 **EXPIRATION DATE:** November 15, 2027

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. This permit is accompanied by an Administrative Order, pursuant to paragraphs 403.088(2)(e) and (f), Florida Statutes. Compliance with Administrative Order, AO-037SWD22, is a specific requirement of this permit. The abovenamed permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

An existing 0.680 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, **limited to operate at 0.340 MGD 3MRADF Type II, as long as R-001 is the only effluent disposal system**. The treatment plant consisting of: ten aeration basins of 682,187 gallons total volume, four clarifiers of 113,312 gallons total volume and 1,637 square feet of total surface area, seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), three pre-filter chlorine contact chambers of 21,654 gallons total volume, one post chlorine contact chamber of 19,947 gallons, one effluent pump wet well of 9,973 gallons, and three digesters of 54,442 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

Modifications:

Phase 1 Modifications

Replacement of headworks screen, upgrade out of service aeration tank to 45,970-gallon flow equalization tank.

Phase 2 Modifications

Phase 2 modifications will be completed to increase permitted capacity to 0.495 MGD. The phase 2 digester tank will be converted into a grit removal compartment with 9,248 gallons capacity. Phase 1 diffused aeration chamber will be converted into raw wastewater flow equalization chamber with 45,970 gallons capacity. A phase 1 mechanical aeration tank, phase 1 digester, phase 1 settling tank, and a phase 1 chlorine contact chamber will be converted into decant flow equalization unit with 95,930 gallons total. Conversion of one phase 3 mechanical aeration zone, one diffused aeration zone, and consolidation with the existing sludge digester to provide 164,465 gallons in total sludge digestion volume. Construction of 3 sequencing batch

FACILITY: Grenelefe Resort WWTF

reactors (SBRs) each with a volume of 250,000 gallons totaling 750,000 gallons. Expansion, modification, and consolidation of the 4 existing RIBs, into two RIBs designated the North and South RIBs.

Phase 3 Modifications

Construction of 3 additional 250,000 SBR chambers totaling 750,000 gallons. Conversion of one phase 1 aeration chamber to a decant equalization, total decant equalization volume will be 147,980 gallons. Conversion of two phase 2 aeration tanks to raw wastewater flow equalization, totaling 196,040 FEQ unit process capacity. Conversion of two phase 3 aeration chambers to sludge digestion, providing a total sludge digestion capacity of 410,529 gallons. Demolition of phase 3 sand filters and mudwell. Conversion of existing phase 3 25,000-gallon filter clearwell into a chlorine contact tank. Construction of three denitrification filters of 150 square feet each.

After Modifications

An existing 1 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, **limited to operate at 0.495 MGD 3MRADF Type II, until the effluent disposal capacity is increased**. The treatment plant consisting of: seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), two chlorine contact chambers totaling 44,947 gallons total volume, one effluent pump wet well of 9,973 gallons, six sequencing batch reactors (SBRs) totaling 1,500,000 gallons total volume, four decant flow equalization units totaling 147,980 gallons total volume, two flow equalization tanks totaling 196,040 gallons flow equalization capacity, three denitrification filters at 450 square feet total, and five digesters of 410,529 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

REUSE OR DISPOSAL:

Land Application R-001: An existing 0.340 MGD annual average daily flow (AADF) permitted capacity rapid infiltration basin (RIB) system. R-001 is a reuse system which consists of a four-cell RIB of 100,188 square feet of bottom surface area. R-001 is located approximately at latitude 28°3' 45" N, longitude 81°32' 42" W.

Modifications to Reuse

Expansion, modification, and consolidation of the 4 existing RIBs, into two RIBs designated the North and South RIBs totaling 0.495 MGD annual average daily flow permitted capacity.

After Modification

Land Application R-001: An existing 0.495 MGD annual average daily flow (AADF) permitted capacity rapid infiltration basin (RIB) system. R-001 is a reuse system which consists of a two-cell RIB of 216,188 square feet of bottom surface area. R-001 is located approximately at latitude 28°3' 45" N, longitude 81°32' 42" W.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part IX on pages 1 through 2020 of this permit.

FACILITY: Grenelefe Resort WWTF

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

1. During the period beginning on the effective date and lasting through the expiration date of this permit, the permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.B.7.:

		,	Recl	aimed Water Limitations	Monitoring Requirements			
Parameter	Units	Max. /Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow (Before Phase 2 Modifications)	MGD	Max Max	0.340 Report	Annual Average Monthly Average	5 Days/Week	Recording Flow Meter with Totalizer	FLW-01	See I.A.3
Flow (After Phase 2 Modifications)	MGD	Max	0.495	Annual Average	5 Days/Week	Recording Flow Meter with Totalizer	FLW-01	See I.A.3
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max	20.0 30.0	Annual Average Monthly Average	Every 2 weeks	Calculated	EFA-01	
BOD, Carbonaceous 5 day, 20C	mg/L	Max	60.0	Single Sample	Every 2 weeks	Grab	EFA-01	
Solids, Total Suspended	mg/L	Max Max	20.0 30.0	Annual Average Monthly Average	Every 2 weeks	Calculated	EFA-01	
Solids, Total Suspended	mg/L	Max	60.0	Single Sample	Every 2 weeks	Grab	EFA-01	
Coliform, Fecal	#/100mL	Max	200	Annual Average	Every 2 weeks	Calculated	EFA-01	
Coliform, Fecal	#/100mL	Max	800	Single Sample	Every 2 weeks	Grab	EFA-01	
рН	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	5 Days/Week	Meter	EFA-01	
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	5 Days/Week	Meter	EFA-01	See I.A.4
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Nitrogen, Total (Final)	mg/L	Max	10	Annual Average	Monthly	Calculated	EFA-01	See I.A.5 & I.A.6
Phosphorus, Total (as P) (Final)	mg/L	Max	6	Annual Average	Monthly	Calculated	EFA-01	See I.A.6
Nitrogen, Total (Interim)	mg/L	Max	Report	Single Sample	Monthly	Grab	EFA-01	See I.A.6.
Phosphorus, Total (as P) (Interim)	mg/L	Max	Report	Single Sample	Monthly	Grab	EFA-01	See I.A.5 & I.A.6

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	Flow meter prior to discharge to R-001.

PERMIT NUMBER: FLA013016-011-DW2P/RA

PERMITTEE: NC Real Estate Projects, LLC FACILITY: Grenelefe Resort WWTF

Monitoring Site Number	Description of Monitoring Site
EFA-01	Effluent sampling point after treatment and prior to Reuse system R-001.

- 3. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-600.200(25)]
- 4. The effluent limitation for the monthly geometric mean for fecal coliform is only applicable if 10 or more values are reported. If fewer than 10 values are reported, the monthly geometric mean shall be calculated and reported on the Discharge Monitoring Report to be used to calculate the annual average. All other fecal coliform effluent limitations included in permit condition I.A.1 apply regardless of the number of values reported. [62-600.440(5)(t)]
- 5. To report the "90th percentile,"
 - a. Place the bacteria results in ascending order (from lowest to highest value) and assign each sample a number, 1 for the lowest value.
 - b. Multiply the total number of samples by 0.9 to determine the 90th percentile level.
 - c. Report the value of the sample that corresponds to the 90th percentile level (e.g., 10 samples x 0.9 = 9, report the value of the 9th sample). If the 90th percentile level is not a whole number, rounding or interpolation should be used to determine the 90th percentile. When rounding, round down to the nearest whole number if the decimal is 0.4 or lower and round up to the nearest whole number if the decimal is 0.5 or higher (e.g., 12 samples x 0.9 = 10.8, report the value of the 11th sample if rounding).

[62-600.440(5)(a)3]

6. Total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-610.516][62-600.440(5)(c) and (6)(b)]

B. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning on the effective date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7.:

			Limitati	ons	Moni	toring Requiren	nents	
Parameter	Units	Max./ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	0.340(Before Mods) 0.495(After Mods) Report	3-Month Rolling Average Monthly Average	5 Days/Week	Recording Flow Meter with Totalizer	FLW-01	See I.B.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	Monthly	Calculated	FLW-01	
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	Monthly	8-hr FPC	INF-01	See I.B.3
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	Monthly	8-hr FPC	INF-01	See I.B.3

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

PERMITTEE: NC Real Estate Projects, I FACILITY: Grenelefe Resort WWTF

Monitoring Site Number	Description of Monitoring Site
FLW-01	Flow meter prior to discharge to R-001.
INF-01	Influent sampling point prior to treatment and ahead of the return activated sludge line.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-600.660(4)(a)]

- 4. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-600.200(25)]
- 5. The sample collection, analytical test methods, and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-600, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (November 10, 2020)" is available at https://floridadep.gov/dear/quality-assurance/content/quality-assurance-resources. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
 - a. The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - b. The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - c. If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-166]

- 6. The permittee shall provide safe access points for obtaining representative samples which are required by this permit. [62-600.650(2)]
- 7. Monitoring requirements under this permit are effective on the first day of the second month following the effective date of the permit. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Unless specified otherwise in this permit, monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below. DMRs shall be submitted for each required monitoring period including periods of no discharge.

FACILITY: Grenelefe Resort WWTF

REPORT Type on DMR	Monitoring Period	Submit by		
Monthly	first day of month - last day of month	28th day of following month		
Once Every Two Months	January 1 - February 28/29	March 28		
	March 1 - April 30	May 28		
	May 1 - June 30	July 28		
	July 1 - August 31	September 28		
	September 1 - October 31	November 28		
	November 1 - December 31	January 28		
Quarterly	January 1 - March 31	April 28		
	April 1 - June 30	July 28		
	July 1 - September 30	October 28		
	October 1 - December 31	January 28		
Semiannual	January 1 - June 30	July 28		
	July 1 - December 31	January 28		
Annual	January 1 - December 31	January 28		

The permittee may submit either paper or electronic DMR forms. If submitting electronic DMR forms, the permittee shall use the electronic DMR system approved by the Department (EzDMR) and shall electronically submit the completed DMR forms using the DEP Business Portal at https://www.fldepportal.com/go/. Reports shall be submitted to the Department by the twenty-eighth (28th) of the month following the month of operation. Data submitted in electronic format is equivalent to data submitted on signed and certified paper DMR forms.

If submitting paper DMR forms, the permittee shall make copies of the attached DMR forms, without altering the original format or content unless approved by the Department, and shall mail the completed DMR forms to the Department's Southwest District Office at the address specified in Permit Condition I.B.11. by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-600.680(1)]

- 8. During the period of operation authorized by this permit, reclaimed water or effluent shall be monitored annually for the primary and secondary drinking water standards contained in Chapter 62-550, F.A.C., and the Revised Total Coliform Rule contained in Rule 62-550.830, F.A.C., (except for asbestos, color, odor, and residual disinfectants). These monitoring results shall be reported to the Department annually on the DMR. During years when a permit is not renewed, a certification stating that no new non-domestic wastewater dischargers have been added to the collection system since the last reclaimed water or effluent analysis was conducted may be submitted with the signed DMR in lieu of performing the analysis. When such a certification is submitted with the DMR, monitoring not required this period should be noted on the DMR. The annual reclaimed water or effluent analysis report, and certification if applicable, shall be completed and submitted in a timely manner so as to be received by the Department at the address identified on the DMR by January 28 of each year. Approved analytical methods identified in Rule 62-620.100(3)(j), F.A.C., shall be used for the analysis. If no method is included for a parameter, methods specified in Chapter 62-550, F.A.C., shall be used. [62-600.660(2) and (3)(a)][62-600.680(2)][62-610.300(3)]
- 9. The permittee shall submit DEP Form 62-610.300(3)(a)2., Annual Reuse Report, using DEP Form 62-610.300(4)(a)2. on or before January 1 of each year. to the Department and the appropriate water management district on or before January 1 of each year. The form shall be submitted electronically to the Department using the Online Business Portal (https://www.fldepportal.com/DepPortal/go/home) [62-610.870(3)(a)]
- 10. The permittee of a publicly-owned facility shall submit an annual report regarding transactions or allocations of costs and expenditures on pollution mitigation among the utility's permitted wastewater systems, including the prevention of sanitary sewer overflows, collection and transmission system pipe leakages, and inflow and infiltration. This report may be combined with the annual report for the facility's collection system action plan required by Rule 62-600.705, F.A.C. The report shall be electronically submitted to the Department's Southwest District Office no later than June 30 of each calendar year. [62-600.700(4)]
- 11. The permittee shall submit an annual report summarizing the implementation of the facility's collection system action plan required by paragraph 62-600.704(2)(b), F.A.C. The report shall be electronically submitted to the Department's Southwest District Office no later than June 30 of each calendar year. [62-600.705(2)]

FACILITY: Grenelefe Resort WWTF

12. The permittee shall submit the following with any application for permit renewal or substantial permit revision:

- a. a copy of the facility's up-to-date power outage contingency plan required by subsection 62-600.705(1), F.A.C., for mitigating impacts to the facility's collection systems and pump stations; and,
- b. an electronic summary of the facility's up-to-date collection system action plan required by paragraph 62-600.705(2)(a), F.A.C.

[62-600.705(1) and (2)]

13. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's Southwest District Office at the address specified below:

Florida Department of Environmental Protection Southwest District 13051 N Telecom Pkwy, Suite 101 Temple Terrace, Florida 33637-926

Phone Number - (813) 470-5700 swd_dw@floridadep.gov

[62-620.305]

14. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]

II. BIOSOLIDS MANAGEMENT REQUIREMENTS

A. Basic Requirements

- 1. Biosolids generated by this facility may be transferred to BTF or disposed of in a Class I solid waste landfill. Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification. However, use of an alternative biosolids treatment facility requires submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]
- 2. The permittee shall monitor and keep records of the quantities of biosolids generated, received from source facilities, treated, distributed and marketed, land applied, used as a biofuel or for bioenergy, transferred to another facility, or landfilled. These records shall be kept for a minimum of five years. [62-640.650(4)(a)]
- 3. Biosolids quantities shall be monitored by the permittee as specified below. Results shall be reported on the permittee's Discharge Monitoring Report for Monitoring Group RMP-Q in accordance with Condition I.B.7.

				Biosolids Limitation	Monitoring Requirements			
Parameter	Units	Max. /Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-1	
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-2	

[62-640.650(5)(a)1]

4. Biosolids quantities shall be calculated as listed in Permit Condition II.A.3 and as described below:

PERMIT NUMBER: FLA013016-011-DW2P/RA

PERMITTEE: NC Real Estate Projects, LLC FACILITY: Grenelefe Resort WWTF

Monitoring Site Number	Description of Monitoring Site Calculations
RMP-1	Biosolids quantity (Transferred)
RMP-2	Biosolids quantity (Landfilled)

- 5. The treatment, management, transportation, use, land application, or disposal of biosolids shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-640.400(6)]
- 6. Storage of biosolids or other solids at this facility shall be in accordance with the Facility Biosolids Storage Plan. [62-640.300(4)]
- 7. Biosolids shall not be spilled from or tracked off the treatment facility site by the hauling vehicle. [62-640.400(9)]

B. Disposal

1. Disposal of biosolids, septage, and "other solids" in a solid waste disposal facility, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. [62-640.100(6)(t) & (c)]

C. Transfer

- 1. The permittee shall not be held responsible for treatment and management violations that occur after its biosolids have been accepted by a permitted biosolids treatment facility with which the source facility has an agreement in accordance with subsection 62-640.880(1)(c), F.A.C., for further treatment, management, or disposal. [62-640.880(1)(t)]
- 2. The permittee shall keep hauling records to track the transport of biosolids between the facilities. The hauling records shall contain the following information:

Source Facility

- 1. Date and time shipped
- 2. Amount of biosolids shipped
- 3. Degree of treatment (if applicable)
- 4. Name and ID Number of treatment facility
- 5. Signature of responsible party at source facility
- 6. Signature of hauler and name of hauling firm

Biosolids Treatment Facility or Treatment Facility

- 1. Date and time received
- 2. Amount of biosolids received
- 3. Name and ID number of source facility
- 4. Signature of hauler
- 5. Signature of responsible party at treatment facility

A copy of the source facility hauling records for each shipment shall be provided upon delivery of the biosolids to the biosolids treatment facility or treatment facility. The treatment facility permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of biosolids leaving the source facility and arriving at the biosolids treatment facility or treatment facility.

[62-640.880(4)]

D. Receipt

1. If the permittee intends to accept biosolids from other facilities, a permit revision is required pursuant to paragraph 62-640.880(2)(d), F.A.C. [62-640.880(2)(a)]

FACILITY: Grenelefe Resort WWTF

III. GROUND WATER REQUIREMENTS

A. Construction Requirements

1. The permittee shall give at least 72-hour notice to the Department's Southwest District Office, prior to the installation of any monitoring wells. [62-520.600(6)(h)]

- 2. Before construction of new ground water monitoring wells, a soil boring shall be made at each new monitoring well location to properly determine monitoring well specifications such as well depth, screen interval, screen slot, and filter pack. [62-520.600(6)(g)]
- 3. Within 30 days after installation of a monitoring well, the permittee shall submit to the Department's Southwest District Office well completion reports and soil boring/lithologic logs on the attached DEP Form(s) 62-520.900(3), Monitoring Well Completion Report. [62-520.600(6)] and .900(3)]
- 4. All piezometers and monitoring wells not part of the approved ground water monitoring plan shall be plugged and abandoned in accordance with Rule 62-532.500(5), F.A.C., unless future use is intended. [62-532.500(5)]

B. Operational Requirements

- 1. For the Part IV land application system(s), all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for Land Application Site R-001 shall extend horizontally 100 feet from the application site and vertically to the base of the shallow water table aquifer. [62-520.200(27)] [62-520.465]
- 2. The ground water minimum criteria specified in Rule 62-520.400 F.A.C., shall be met within the zone of discharge. [62-520.400 and 62-520.420(4)]
- 3. If the concentration for any constituent listed in Permit Condition III.B.6. in the natural background quality of the ground water is greater than the stated maximum, or in the case of pH is also less than the minimum, the representative background quality shall be the prevailing standard. [62-520.420(2)]
- 4. During the period of operation authorized by this permit, the permittee shall continue to sample ground water at the monitoring wells identified in Permit Condition III.B.5., below in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-520.600, F.A.C. [62-520.606] [62-610.516]
- 5. The following monitoring wells shall be sampled for Reuse System R-001 located at Land Application Site RIB-001:

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Latitude	Longitude	Depth (Feet)	Aquifer Monitored	Well Type	New or Existing
MWB-01	Background Well JMW-1 (15048)	28°3'41 "	81°32' 46"	15	Surficial	Background	Existing
MWC-01	Compliance Well JMW-2 (15043)	28°3' 41"	81°32' 46"	17	Surficial	Compliance	Existing
MWC-02	Compliance Well JMW-3 (15042)	28°3' 43"	81°32' 40"	18	Surficial	Compliance	Existing
MWC-05	Compliance Well JMW-6 (15041)	28°3' 29"	81°33' 03"	15	Surficial	Compliance	Existing

[62-520.606] [62-610.516]

6. The following parameters shall be analyzed for each monitoring well identified in Permit Condition III.B.5.:

FACILITY: Grenelefe Resort WWTF

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD	Report	ft	In Situ	Quarterly
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Quarterly
Solids, Total Dissolved (TDS)	500	mg/L	Grab	Quarterly
Arsenic, Total Recoverable	10	ug/L	Grab	Quarterly
Chloride (as Cl)	250	mg/L	Grab	Quarterly
Cadmium, Total Recoverable	5	ug/L	Grab	Quarterly
Chromium, Total Recoverable	100	ug/L	Grab	Quarterly
Lead, Total Recoverable	15	ug/L	Grab	Quarterly
Coliform, Fecal	4	#/100mL	Grab	Quarterly
рH	6.5-8.5	s.u.	In Situ	Quarterly
Sulfate, Total	250	mg/L	Grab	Quarterly
Turbidity	Report	NTU	Grab	Quarterly
Sodium, Total Recoverable	160	mg/L	Grab	Quarterly

[62-520.600(11)(t)] [62-600.670] [62-600.650(3)] [62-520.310(5)]

- 7. Water levels shall be recorded before evacuating each well for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.01 foot. [62-520.600(11)(c)] [62-610.510(3)(b)]
- 8. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. [62-160.216] [62-600.670(3)]
- 9. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's Southwest District Office as being more representative of ground water conditions. [62-520.310(5)]
- 10. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10) in accordance with Permit Condition I.B.7. [62-520.600(11)(t)] [62-600.676] [62-600.680(1)] [62-620.610(18)]
- 11. If any monitoring well becomes inoperable or damaged to the extent that sampling or well integrity may be affected, the permittee shall notify the Department's Southwest District Office within two business days from discovery, and a detailed written report shall follow within ten days after notification to the Department. The written report shall detail what problem has occurred and remedial measures that have been taken to prevent recurrence or request approval for replacement of the monitoring well. All monitoring well design and replacement shall be approved by the Department's Southwest District Office before installation. [62-520.600(6)(i)]

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

A. Part IV Rapid Infiltration Basins

- 1. Advisory signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518]
- 2. The maximum annual average loading rate to a four-cell Rapid Infiltration Basin (RIB) of 100,188 square feet of bottom surface area. shall be limited to 5.44 inches per day (as applied to the entire bottom area). [62-610.523(3)]
- 3. The four-cell Rapid Infiltration Basin (RIB) of 100,188 square feet of bottom surface area. normally shall be loaded for 7 days and shall be rested for 14 days. Infiltration ponds, basins, or trenches shall be allowed to dry during the resting portion of the cycle. [62-610.523(4)]
- 4. Rapid infiltration basins shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids. Basin bottoms shall be maintained to be level. [62-610.523(6) and (7)]

FACILITY: Grenelefe Resort WWTF

5. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. [62-610.514 and 62-610.414]

- 6. Overflows from emergency discharge facilities on storage ponds or on infiltration ponds, basins, or trenches shall be reported as abnormal events in accordance with Permit Condition IX.20. [62-610.800(5)]
- 7. Holding ponds are provided for reclaimed water storage, such ponds are subject to the requirements of Rule 62-610.414, F.A.C. [62-610.514(2)]
- 8. If subsurface drain systems are needed, they shall be designed in accordance with appropriate portions of paragraph 62-610.300(1)(c), F.A.C., concerning Natural Resources Conservation Services criteria for subsurface drains. The drainage system shall be designed so that the seasonal high-water table is drawn down to a minimum of 36 inches below pond bottoms during resting periods. The requirements of subsection 62-610.850(1), F.A.C., shall apply to discharges to surface waters from the drainage system. [62-610.517(2)(a)]
- 9. A setback distance of 500 feet shall be provided from the edge of the rapid infiltration basin, percolation pond, basin, or trench embankments, or from the edge of an absorption field to potable water supply wells that are existing or have been approved by the Department or by the Department of Health (but not yet constructed); Class I surface waters; or Class II surface waters. The setback distance to Class I and II surface waters shall be reduced to 100 feet if high-level disinfection is provided. Setback distance requirements apply to all Class II waters, regardless of Department classification. [62-610.521(2)]

V. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

- 1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of one or more operators certified in accordance with Chapter 62-602, F.A.C.
 - I. <u>Before Modification to meet the Total Nitrogen Limit</u>: In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 3 hours/day for 5 days/week and one weekend visit. The lead/chief operator must be a Class C operator, or higher.

II. <u>After Modification to meet the Total Nitrogen Limit:</u> In accordance with Chapter 62-699, F.A.C., this facility is a Category I, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 6 hours/day for 5 days/week and one visit on each weekend day. The lead/chief operator must be a Class C operator, or higher.

2. An operator meeting the lead/chief operator class for the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. [62-699.311(1)]

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

- 1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5)]
- 2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]

FACILITY: Grenelefe Resort WWTF

C. Recordkeeping Requirements

1. The permittee shall maintain the following records and make them available for inspection at the following address: on the site of the permitted facility.

- a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
- b. Copies of all reports required by this permit for at least three years from the date the report was prepared;
- c. Records of all data, including reports and documents, used to complete the application for this permit for at least three years from the date the application was filed;
- d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
- e. A copy of the current wastewater facility permit;
- f. Copies of the current operation and maintenance manuals for the wastewater facility and the collection/transmission systems owned or operated by the wastewater facility permittee as required by Chapters 62-600 and 62-604, F.A.C.;
- g. A copy of any required record drawings for the wastewater facility and the collection/transmission systems owned or operated by the wastewater facility permittee;
- h. Copies of the licenses of the current certified operators;
- i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed; and
- j. Records of biosolids quantities, treatment, monitoring, and hauling for at least five years.

[62-620.350, 62-604.500, 62-602.650, 62-640.650(4)]

VI. SCHEDULES

1. In accordance with section 403.088(2)(e) and (f), Florida Statutes, a compliance schedule for this facility is contained in Administrative Order AO-037SWD22 which is hereby incorporated by reference.

Action Item	Due Date
1) Collect monthly effluent samples and analyze for TN and TP and report as required by this permit and Discharge Monitoring Report.	First day of the second month following the permit issuance until September 31, 2025
2) Submit a proposal with the most feasible option to bring the TN and TP into compliance with the final limits being 10.0 mg/L and of 6.0 mg/L, respectively. If necessary, schedule a meeting with DEP SWD office to discuss the proposal.	Prior to September 31, 2025
3) Submit a proposal with the necessary modifications to the facility required to meet the treatment and disinfection requirements of 62-610.460, F.A.C., giving the facility the option to dispose of the effluent via a Part III Slow-Rate public	Prior to September 31, 2025

FACILITY: Grenelefe Resort WWTF

access reuse system (Irrigation). If necessary, schedule a meeting with DEP SWD office to discuss the proposal.	
4) Obtain the Department's approval for the proposal.	Prior to September 31, 2025
5) Implement the proposal.	Within twelve months of DEP approval and after obtaining a permit modification, if required.
6) Comply with the final limit for TN and TP or obtain Department approved regulatory relief	Within three months of completion of any modification if required.
7) Meet the facility classification and operator staffing requirement in accordance to Rule 62-699.310 (2) (a)1., F.A.C as a Category I, Type III, Class C facility.	Upon the date of completion for item 6.
8) Submit a Completion of Construction (COC) request for the modification listed in this permit on DEP Form 62-620.910(12) along with any necessary supplementary files.	Prior to placing into operation

- 2. The permittee is not authorized to discharge to waters of the state after the expiration date of this permit, unless:
 - a. The permittee has applied for renewal of this permit at least 180 days before the expiration date of this permit using the appropriate forms listed in Rule 62-620.910, F.A.C., and in the manner established in the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.; or
 - b. The permittee has made complete the application for renewal of this permit before the permit expiration date. [62-620.335(1)-(4)]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

1. This facility is not required to have a pretreatment program at this time. [62-625.506]

VIII. OTHER SPECIFIC CONDITIONS

- 1. Prior to placing the new facilities into operation or any individual unit processes into operation, for any purpose other than testing for leaks and equipment operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities. [62-620.630(2)]
- 2. Within six months after a facility is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that an operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form. [62-620.630(7)]
- 3. In the event that the wastewater facilities or equipment, including collection/transmission systems, no longer function as intended, are no longer safe in terms of public health and safety (including inactive or abandoned facilities), or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by paragraphs 62-600.400(2)(a) and 62-604.400(2)(c), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-600.410(5), 62-604.500(3) and 62-640.400(6)]
- 4. All collection/transmission systems shall be operated and maintained to provide uninterrupted service. All pump stations shall be operated and maintained to provide the emergency pumping capability requirements in paragraph 62-604.400(2)(a), F.A.C., the lightning and transient voltage surge protections in paragraph 62-604.400(2)(b),

FACILITY: Grenelefe Resort WWTF

F.A.C., and the design and signage requirements in paragraph 62-604.400(2)(d), F.A.C. Also, all equipment, pipes, manholes, pump stations, and other appurtenances necessary for the collection/transmission of domestic wastewater, including equipment provided pursuant to subsection 62-604.400(2), F.A.C., shall be maintained to function as intended. [62-604.500(2) and (3)]

- 5. The permittee shall evaluate and update the emergency response plan portion of the collection system operation and maintenance manual annually. The emergency response plan shall assess collection system security including cybersecurity; water quality monitoring for sanitary sewer overflows affecting surface waters; and hurricane and severe storm preparedness and response. [62-604.500(4)]
- 6. Collection/transmission systems shall be maintained to minimize excessive infiltration and inflow into the collection/transmission system, as well as excessive leakage from the collection/transmission system. The permittee shall take corrective actions when infiltration, inflow, or leakage is excessive. Infiltration and inflow are considered excessive if one or both cause or contribute to sanitary sewer overflows. Leakage, or exfiltration, is considered excessive if it causes or contributes to a violation of surface water quality standards or ground water quality standards. [62-604.500(5)]
- 7. All collection/transmission systems shall be operated and maintained to prevent sanitary sewer overflows. The permittee shall evaluate the cause of all sanitary sewer overflows and evaluate potential corrective measures to avoid future sanitary sewer overflows. Corrective actions shall be taken by the permittee if excessive inflow and infiltration causes or contributes to a sanitary sewer overflow. The owner/operator of a satellite collection system shall take corrective actions for a sanitary sewer overflow in the receiving collection system caused by excessive inflow and infiltration in the satellite collection system. [62-604.500(6)]
- 8. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(4)]
- 9. Cross-connection, as defined in Rule 62-550.200, F.A.C., between the wastewater facility, including the collection/transmission system, and a potable water system is prohibited. [62-550.360][62-604.130(3)]
- 10. The collection/transmission operation and maintenance manual shall be maintained and revised periodically in accordance with subsection 62-604.500(4), F.A.C., to reflect any alterations performed or to reflect experience resulting from operation. However, a new operation and maintenance manual is not required to be developed for each project if there is already an existing manual that is applicable to the facilities being constructed. [62-604.500(4)]
- 11. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.556] [62-620.610(26)]
- 12. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.

FACILITY: Grenelefe Resort WWTF

[62-604.130(5)]

13. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-610.518(1) and 62-600.400(2)(t)]

- 14. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
- 15. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. [62-620.310(4)]
- 16. The permittee shall provide verbal notice to the Department's Southwest District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's Southwest District Office in a written report within 7 days of the sinkhole discovery. [62-620.320(6)]
- 17. The permittee shall provide notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.
 - Notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility. If pretreatment becomes necessary, this permit may be modified to require the permittee to develop and implement a local pretreatment program in accordance with the requirements of Chapter 62-625, F.A.C.

[62-620.625(2)]

- 18. Prior to placing the new facilities into operation or any individual unit processes into operation, for any purpose other than testing for leaks and equipment operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities. [[62-620.630(2)]]
- 19. Within six months after a facility is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that an operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form. [[62-620.630(7)]]

IX. GENERAL CONDITIONS

- 1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
- 2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]

FACILITY: Grenelefe Resort WWTF

3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]

- 4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
- 5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
- 6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6)]
- 7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]
- 8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
- 9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

- 10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(16)]
- 11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon

FACILITY: Grenelefe Resort WWTF

request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11)]

- 12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12)]
- 13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13)]
- 14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. [62-620.610(14)]
- 15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15)]
- 16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]
- 17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17)]

- 18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-600, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.

FACILITY: Grenelefe Resort WWTF

e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.

f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.

[62-620.610(18)]

- 19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(15)]
- 20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; clean up actions taken and status; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance. For noncompliance events related to sanitary sewer overflows, bypass events, or unauthorized discharges, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (e.g., sanitary sewer overflow, bypass, unauthorized discharge); type of sanitary sewer overflow structure (e.g., manhole); the discharge location address and latitude/longitude; type of water discharged; discharge volumes and volumes recovered; volume discharged to surface waters and receiving waterbody name; types of human health and environmental impacts of the sanitary sewer overflow, bypass event, or unauthorized discharge (e.g., beach closure); whether the noncompliance was caused by a third party; and whether the noncompliance was related to wet weather. The written submission may be provided electronically using the Department's Business Portal at https://www.fldepportal.com/go/ (via "Submit" followed by "Report" or "Registration/Notification"). Notice required for public notice of pollution under paragraph (d) may be provided together with the written submission using the Business Portal. All noncompliance events related to sanitary sewer overflows or bypass events shall be submitted electronically.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or the effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice; and,
 - (4) Any unauthorized discharge to surface or ground waters, except for discharges to ground water of reclaimed water meeting Part III or Part V treatment standards under Chapter 62-610, F.A.C.
 - b. Oral reports as required by this subsection shall be provided as follows:
 - (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4., that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WATCH OFFICE TOLL FREE NUMBER (800)320-0519, as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Watch Office:
 - (a) Name, address, and telephone number of person reporting,
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge,
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased),
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater),
 - (e) Estimated amount of the discharge,
 - (f) Location or address of the discharge,
 - (g) Source and cause of the discharge,

PERMITTEE: NC Real Estate Projects, LLC PERMIT NUMBER: FLA013016-011-DW2P/RA FACILITY: Grenelefe Resort WWTF

(h) Whether the discharge was contained on-site, and cleanup actions taken to date,

- (i) Description of area affected by the discharge, including name of water body affected, if any; and,
- (j) Other persons or agencies contacted.
- (2) Oral reports, not otherwise required to be provided pursuant to subparagraph IX.20.b.(1), above, shall be provided to the Department within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.
- d. In accordance with Section 403.077, F.S., unauthorized releases or spills reportable to the State Watch Office pursuant to subparagraph (b)1. above shall also be reported to the Department within 24 hours from the time the permittee becomes aware of the discharge. The permittee shall provide to the Department information reported to the State Watch Office. Notice of unauthorized releases or spills may be provided to the Department through the Department's Public Notice of Pollution web page at https://floridadep.gov/pollutionnotice or by reporting electronically using the Department's Business Portal at https://www.fldepportal.com/go/ (via "Submit" followed by "Report" or "Registration/Notification").
 - (1) If, after providing notice pursuant to paragraph (d) above, the permittee determines that a reportable unauthorized release or spill did not occur or that an amendment to the notice is warranted, the permittee may submit a letter to the Department documenting such determination at pollution.notice@floridadep.gov.
 - (2) If, after providing notice pursuant to paragraph (d) above, the permittee discovers that a reportable unauthorized release or spill has migrated outside the property boundaries of the installation, the permittee must provide an additional notice to the Department that the release has migrated outside the property boundaries within 24 hours after its discovery of the migration outside of the property boundaries.
- e. Unless discharged to surface waters, a spill, release, discharge, upset or bypass involving reclaimed water meeting Part III or Part V treatment standards under Chapter 62-610, F.A.C., shall not be considered to endanger health or the environment and shall be reported under subsection (21) of this permit.

[62-620.610(26)] [62-620.100(3)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. [62-620.610(21)]

22. Bypass Provisions.

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
- b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (3) The permittee submitted notices as required under Permit Condition IX.22.c. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.

FACILITY: Grenelefe Resort WWTF

d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.b.(1) through (3) of this permit.

e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.b. through d. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
 - (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
 - (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology-based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and
 - (4) The permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

Executed in Hillsborough County, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Gerald "JJ" Loesch

Environmental Administrator

Permitting & Waste Cleanup Program

Southwest District

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed submit this report to: Department of Environmental Protection, Southwest District Office, Compliance Assurance Program, Attn: Domestic Wastewater, 13051 N Telecom Pkwy, Suite 101, Temple Terrace, FL 33637-0926, swd_dw@floridadep.gov

PERMITTEE NAME: MAILING ADDRESS:	NC Real Estate Projects, LLC 110 Wades Way, Unit 134	PERMIT NUMBER:	FLA013016-011-DW2P/RA		
	Mooresville, NC 28117	LIMIT:	Before Phase 4B Modifications	REPORT FREQUENCY:	Monthly
		CLASS SIZE:	N/A	PROGRAM:	Domestic
FACILITY:	Grenelefe Resort WWTF	MONITORING GROUP NUMBER:	R-001		
LOCATION:	4501 Abbey Court	MONITORING GROUP DESCRIPTION:	RIB, including Influent		
	Haines City, FL 33844-9720	RE-SUBMITTED DMR:	_		
	•	NO DISCHARGE FROM SITE:			
COUNTY:	Polk	MONITORING PERIOD From:	To:		
OFFICE:	Southwest District				

Parameter		Quantity or	Loading	Units	Qı	ality or Concentration	on	Units	No. Ex.	Frequency of Analysis	Sample Type
Flow (Before Phase 4B Modifications)	Sample Measurement										
PARM Code 50050 Y Mon, Site No. FLW-01	Permit Requirement		0.340 (An.Avg.)	MGD						5 Days/Week	Flow Meter
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. FLW-01	Permit Requirement		Report (Mo.Avg.)	MGD						5 Days/Week	Flow Meter
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon, Site No. EFA-01	Permit Requirement					20.0 (An.Avg.)		mg/L		Bi-weekly; every 2 weeks	8-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 A Mon. Site No. EFA-01	Permit Requirement					30.0 (Mo.Avg.)	60.0 (Max.)	mg/L		Bi-weekly; every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 Y Mon, Site No. EFA-01	Permit Requirement					20.0 (An.Avg.)		mg/L		Bi-weekly; every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 A Mon. Site No. EFA-01	Permit Requirement					30.0 (Mo.Avg.)	60.0 (Max.)	mg/L		Bi-weekly; every 2 weeks	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

FACILITY: Grenelefe Resort WWTF MONITORING GROUP NUMBER:

R-001

PERMIT NUMBER: FLA013016-011-DW2P/RA

MONITORING PERIOD

To: __ From: _____

Parameter		Quantity or Loading Units		Units		Quality or Concentration		Units	No. Ex.	1 1 1	Sample Type
Coliform, Fecal	Sample Measurement										
PARM Code 74055 Y Mon, Site No, EFA-01	Permit Requirement					200 (An.Avg.)		#/100mL		Bi-weekly; every 2 weeks	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 A Mon. Site No. EFA-01	Permit Requirement						800 (Max.)	#/100mL		Bi-weekly; every 2 weeks	Grab
рН	Sample Measurement										
PARM Code 00400 A Mon, Site No, EFA-01	Permit Requirement				6.0 (Min.)		8.5 (Max.)	s.u.		5 Days/Week	Meter
Chlorine, Total Residual (For Disinfection)	Sample Measurement										
PARM Code 50060 A Mon. Site No. EFA-01	Permit Requirement				0.5 (Min.)			mg/L		5 Days/Week	Meter
Nitrogen, Nitrate, Total (as N)	Sample Measurement										
PARM Code 00620 A Mon, Site No. EFA-01	Permit Requirement						12.0 (Max.)	mg/L		Bi-weekly; every 2 weeks	8-hr FPC
Nitrogen, Total (Interim)	Sample Measurement										
PARM Code 00600 A Mon, Site No, EFA-01	Permit Requirement						Report (Mo.Avg.)	mg/L		Monthly	8-hr FPC
Phosphorus, Total (as P) (Interim)	Sample Measurement										
PARM Code 00665 A Mon. Site No. EFA-01	Permit Requirement						Report (Max.)	mg/L		Monthly	8-hr FPC
Flow	Sample Measurement										
PARM Code 50050 P Mon. Site No. FLW-01	Permit Requirement	0.340 (3Mo.Avg.)	Report (Mo.Avg.)	MGD						5 Days/Week	Meter
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 1 Mon. Site No. FLW-01	Permit Requirement						Report (Mo.Avg.)	percent		Monthly	Calculated

FACILITY: Grenelefe Resort Center MONITORING GROUP R-001 PERMIT NUMBER: FLA013016-011-DW2P/RA NUMBER:

MONITORING PERIOD From: _____ To: ____

Parameter		Quantity o	or Loading	Units	Qı	ality or Concentrati	on	Units	No. Ex.	Frequency of Analysis	Sample Type
(Influent)	Sample Measurement										
PARM Code 80082 G	Permit Requirement						Report (Max.)	mg/L		Monthly	8-hr FPC
Solids, Total Suspended (Influent)	Sample Measurement										
PARM Code 00530 G	Permit Requirement						Report (Max.)	mg/L		Monthly	8-hr FPC
1											
<u> </u>											
											<u>-</u> 4

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed submit this report to: Department of Environmental Protection, Southwest District Office, Compliance Assurance Program, Attn: Domestic Wastewater, 13051 N Telecom Pkwy, Suite 101, Temple Terrace, FL 33637-0926, swd_dw@floridadep.gov

PERMITTEE NAME:	NC Real Estate Projects, LLC	PERMIT NUMBER:	FLA013016-011-DW2P/RA		
MAILING ADDRESS:	110 Wades Way, Unit 134				
	Mooresville, NC 28117	LIMIT:	After Phase 4B	REPORT FREQUENCY:	Monthly
			Modifications		
		CLASS SIZE:	N/A	PROGRAM:	Domestic
FACILITY:	Grenelefe Resort WWTF	MONITORING GROUP NUMBER:	R-001		
LOCATION:	4501 Abbey Court	MONITORING GROUP DESCRIPTION:	RIB, including Influent		
	Haines City, FL 33844-9720	RE-SUBMITTED DMR:			
		NO DISCHARGE FROM SITE:			
COUNTY:	Polk	MONITORING PERIOD	To:		
		From:			
OFFICE:	Southwest District				

Parameter		Quantity or Loading	Units	Quality or Concentration	1	Units	No. Ex.	Frequency of Analysis	Sample Type
Flow (After Phase 4B Modifications))	Sample Measurement								
PARM Code 50050 Y Mon, Site No. FLW-01	Permit Requirement	0.495 (An.Avg.)	MGD					5 Days/Week	Flow Meter
Flow	Sample Measurement								
PARM Code 50050 1 Mon, Site No. FLW-01	Permit Requirement	Report (Mo.Avg.)	MGD					5 Days/Week	Flow Meter
BOD, Carbonaceous 5 day, 20C	Sample Measurement								
PARM Code 80082 Y Mon. Site No. EFA-01	Permit Requirement			20.0 (An.Avg.)		mg/L		Bi-weekly; every 2 weeks	8-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement								
PARM Code 80082 A Mon. Site No. EFA-01	Permit Requirement			30.0 (Mo.Avg.)	60.0 (Max.)	mg/L		Bi-weekly; every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement								
PARM Code 00530 Y Mon. Site No. EFA-01	Permit Requirement			20.0 (An.Avg.)		mg/L		Bi-weekly; every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement								
PARM Code 00530 A Mon. Site No. EFA-01	Permit Requirement			30.0 (Mo.Avg.)	60.0 (Max.)	mg/L		Bi-weekly; every 2 weeks	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE	OFFICER OR AUTHORIZED SI	GNATURE OF PRINCIPAL EXECUTIVE OFFICER OF	R AUTHORIZED	TELEPHONE NO	DATE
			_		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

Grenelefe Resort WWTF FACILITY:

Mon. Site No. FLW-01

PARM Code 00180 1

Mon. Site No. FLW-01

(TMADF/Permitted Capacity) x

Percent Capacity,

100

MONITORING GROUP NUMBER: MONITORING PERIOD R-001

PERMIT NUMBER: FLA013016-011-DW2P/RA

To:

Report

(Mo.Avg.)

percent

From: _____ Frequency of Quantity or Loading Units Quality or Concentration Units No. Sample Type Parameter Analysis Ex. Coliform, Fecal Sample Measurement PARM Code 74055 Y Permit 200 #/100mL Bi-weekly; every Grab Mon. Site No. EFA-01 Requirement (An.Avg.) 2 weeks Coliform, Fecal Sample Measurement PARM Code 74055 A Permit 800 #/100mL Bi-weekly; every Grab Mon. Site No. EFA-01 Requirement 2 weeks (Max.) рΗ Sample Measurement PARM Code 00400 A Permit 6.0 8.5 5 Days/Week Grab s.u. Mon. Site No. EFA-01 Requirement (Min.) (Max.) Chlorine, Total Residual (For Sample Disinfection) Measurement PARM Code 50060 A Permit 0.5 5 Days/Week Meter mg/L Mon. Site No. EFA-01 Requirement (Min.) Nitrogen, Nitrate, Total (as N) Sample Measurement PARM Code 00620 A Permit 12.0 Bi-weekly; every 8-hr FPC mg/L Mon. Site No. EFA-01 2 weeks Requirement (Max.) Nitrogen, Total (Final) Sample Measurement PARM Code 00600 Y Permit 10 mg/L Monthly 8-hr FPC Mon. Site No. EFA-01 Requirement (An.Avg.) Phosphorus, Total (as P) (Final) Sample Measurement PARM Code 00665 A Permit 6 Monthly 8-hr FPC mg/L Mon. Site No. EFA-01 Requirement (Max.) Flow, total for the facility Sample Measurement PARM Code 50050 P 0.340 MGD 5 Days/Week Permit Report Flow Meter

Requirement

Measurement

Requirement

Sample

Permit

(3Mo.Avg.)

(Mo.Avg.)

Monthly

Calculated

FACILITY: Grenelefe Resort Center

MONITORING GROUP NUMBER:

R-001

PERMIT NUMBER: FLA013016-011-DW2P/RA

Sample Type

8-hr FPC

8-hr FPC

MONITORING PERIOD From: _____ To: ____ Frequency of Quantity or Loading Units Quality or Concentration Units No. Parameter Ex. Analysis BOD, Carbonaceous 5 day, 20C Sample (Influent) Measurement PARM Code 80082 G Report Permit mg/L Monthly Mon. Site No. INF-01 Requirement (Max.) Solids, Total Suspended (Influent) Sample Measurement PARM Code 00530 G Permit Report mg/L Monthly Mon. Site No. INF-01 (Max.) Requirement

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed submit this report to: Department of Environmental Protection, Southwest District Office, Compliance Assurance Program, Attn: Domestic Wastewater, 13051 N Telecom Pkwy, Suite 101, Temple Terrace, FL 33637-0926, swd_dw@floridadep.gov

PERMITTEE NAME:	NC Real Estate Projects, LLC	PERMIT NUMBER:	FLA013016-011-DW2P/RA		
MAILING ADDRESS:	110 Wades Way, Unit 134				
	Mooresville, NC 28117	LIMIT:	Final	REPORT FREQUENCY:	Monthly
		CLASS SIZE:	N/A	PROGRAM:	Domestic
FACILITY:	Grenelefe Resort WWTF	MONITORING GROUP NUMBER:	RMP-Q		
LOCATION:	4501 Abbey Court	MONITORING GROUP DESCRIPTION:	Biosolids Quantity		
	Haines City, FL 33844-9720	RE-SUBMITTED DMR:	•		
		NO DISCHARGE FROM SITE:			
COUNTY:	Polk	MONITORING PERIOD From:	To:		
OFFICE:	Southwest District			<u> </u>	

Parameter		Quantity o	or Loading	Units	Qı	ality or Concentrati	on	Units	No. Ex.	Frequency of Analysis	Sample Type
Biosolids Quantity (Transferred)	Sample Measurement										
PARM Code B0007 + Mon. Site No. RMP-1	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated
Biosolids Quantity (Landfilled)	Sample Measurement										
PARM Code B0008 + Mon. Site No. RMP-2	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed submit this report to: Department of Environmental Protection, Southwest District Office, Compliance Assurance Program, Attn: Domestic Wastewater, 13051 N Telecom Pkwy, Suite 101, Temple Terrace, FL 33637-0926, swd_dw@floridadep.gov

PERMITTEE NAME:	NC Real Estate Projects, LLC	PERMIT NUMBER:	FLA013016-011-DW2P/RA		
MAILING ADDRESS:	110 Wades Way, Unit 134				
	Mooresville, NC 28117	LIMIT:	Final	REPORT FREQUENCY:	Annually
		CLASS SIZE:	N/A	PROGRAM:	Domestic
FACILITY:	Grenelefe Resort WWTF	MONITORING GROUP NUMBER:	RWS-A		
LOCATION:	4501 Abbey Court	MONITORING GROUP DESCRIPTION:	Annual Reclaimed Water or Ef	fluent Analysis	
	Haines City, FL 33844-9720	RE-SUBMITTED DMR:		•	
	•	NO DISCHARGE FROM SITE:			
		MONITORING NOT REQUIRED:* □			
COUNTY:	Polk	MONITORING PERIOD From:	To:		
OFFICE:	Southwest District				

Parameter		Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Antimony, Total Recoverable (GWS = 6)**	Sample Measurement								
PARM Code 01268 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Arsenic, Total Recoverable (GWS = 10)	Sample Measurement								
PARM Code 00978 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Barium, Total Recoverable (GWS = 2,000)	Sample Measurement								
PARM Code 01009 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Beryllium, Total Recoverable (GWS = 4)	Sample Measurement								
PARM Code 00998 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Cadmium, Total Recoverable (GWS = 5)	Sample Measurement								
PARM Code 01113 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Chromium, Total Recoverable (GWS =100)	Sample Measurement								
PARM Code 01118 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC

^{*}THE "MONITORING NOT REQUIRED" CHECKBOX SHOULD BE SELECTED WHEN A CERTIFICATION STATEMENT IN ACCORDANCE WITH SUBSECTION 62-600.680(2), F.A.C., IS SUBMITTED WITH THIS DMR. SEE CERTIFICATION STATEMENT IN COMMENTS SECTION BELOW.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

□ NO NEW NON-DOMESTIC WASTEWATER DISCHARGERS HAVE BEEN ADDED TO THE COLLECTION SYSTEM SINCE THE LAST RECLAIMED WATER OR EFFLUENT ANALYSIS WAS CONDUCTED.

^{**}GROUND WATER STANDARD (GWS) FOR REFERENCE AND REVIEW ONLY.

SIGN AND DATE:

FACILITY: Grenelefe Resort WWTF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

NUMBER:

MONITORING PERIOD

From: _____ To: ____

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Cyanide, Free (amen. to chlorination)(GWS = 200)	Sample Measurement							
PARM Code 00722 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
Fluoride, Total (as F) (GWS = 4.0/2.0)	Sample Measurement							
PARM Code 00951 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC
Lead, Total Recoverable (GWS = 15)	Sample Measurement							
PARM Code 01114 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Mercury, Total Recoverable (GWS = 2)	Sample Measurement							
PARM Code 71901 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Nickel, Total Recoverable (GWS = 100)	Sample Measurement							
PARM Code 01074 P Mon, Site No, RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Nitrogen, Nitrate, Total (as N) (GWS = 10)	Sample Measurement							
PARM Code 00620 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC
Nitrogen, Nitrite, Total (as N) (GWS = 1)	Sample Measurement							
PARM Code 00615 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC
Nitrite plus Nitrate, Total 1 det. (as N)(GWS = 10)	Sample Measurement							
PARM Code 00630 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC
Selenium, Total Recoverable (GWS =50)	Sample Measurement							
PARM Code 00981 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Sodium, Total Recoverable (GWS = 160)	Sample Measurement							
PARM Code 00923 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC

FACILITY: Grenelefe Resort WWTF MONITORING GROUP NUMBER:

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

MONITORING PERIOD

To: _____ From: _____

Parameter	Quantity or Loading		Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Thallium, Total Recoverable (GWS = 2)	Sample Measurement							
PARM Code 00982 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
1,1-dichloroethylene (GWS = 7)	Sample Measurement							
PARM Code 34501 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
1,1,1-trichloroethane (GWS = 200)	Sample Measurement							
PARM Code 34506 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
1,1,2-trichloroethane (GWS = 5)	Sample Measurement							
PARM Code 34511 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
1,2-dichloroethane (GWS = 3)	Sample Measurement							
PARM Code 32103 P Mon, Site No, RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
1,2-dichloropropane (GWS = 5)	Sample Measurement							
PARM Code 34541 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
1,2,4-trichlorobenzene (GWS = 70)	Sample Measurement							
PARM Code 34551 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Benzene (GWS = 1)	Sample Measurement							
PARM Code 34030 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
Carbon tetrachloride (GWS = 3)	Sample Measurement							
PARM Code 32102 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
Cis-1,2-dichloroethene (GWS = 70)	Sample Measurement							
PARM Code 81686 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab

FACILITY: Grenelefe Resort WWTF MONITORING GROUP NUMBER: RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

MONITORING PERIOD From: _____ To: ____

Parameter		Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Dichloromethane (methylene	Sample								
chloride)(GWS = 5)	Measurement								
PARM Code 03821 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				
Ethylbenzene	Sample								
(GWS = 700)	Measurement								
PARM Code 34371 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				
Monochlorobenzene	Sample								
(GWS = 100)	Measurement								
PARM Code 34031 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				
1,2-dichlorobenzene	Sample								
(GWS = 600)	Measurement								
PARM Code 34536 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				
1,4-dichlorobenzene	Sample								
(GWS = 75)	Measurement								
PARM Code 34571 P	Permit				Report	ug/L	0	Annually	Grab
Mon, Site No. RWS-A	Requirement				(Max.)			•	
Styrene, Total	Sample								
(GWS = 100)	Measurement								
PARM Code 77128 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				
Tetrachloroethylene	Sample								
(GWS = 3)	Measurement								
PARM Code 34475 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)			•	
Toluene	Sample				<u> </u>				
(GWS = 1,000)	Measurement								
PARM Code 34010 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)			•	
1,2-trans-dichloroethylene	Sample				<u> </u>				
(GWS = 100)	Measurement								_
PARM Code 34546 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)			•	
Trichloroethylene	Sample								
(GWS = 3)	Measurement								
PARM Code 39180 P	Permit				Report	ug/L	0	Annually	Grab
Mon. Site No. RWS-A	Requirement				(Max.)				

FACILITY: Grenelefe Resort WWTF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

NUMBER:

MONITORING PERIOD

From: To:

Parameter Quantity or Loading Units Quality or Concentration Units Sample Type No. Frequency of Analysis Ex. Vinyl chloride Sample (GWS = 1)Measurement PARM Code 39175 P Permit 0 Grab Report ug/L Annually Mon. Site No. RWS-A Requirement (Max.) **Xylenes** Sample (GWS = 10,000)Measurement PARM Code 81551 P Permit ug/L 0 Grab Report Annually Mon. Site No. RWS-A Requirement (Max.) 2,3,7,8-tetrachlorodibenzo-p-Sample $dioxin(GWS = 3x10^{-5})$ Measurement PARM Code 34675 P Permit Report ug/L 0 Annually 24-hr FPC Mon. Site No. RWS-A Requirement (Max.) 2,4-dichlorophenoxyacetic acid Sample (GWS = 70)Measurement PARM Code 39730 P Permit ug/L 0 24-hr FPC Report Annually Mon. Site No. RWS-A Requirement (Max.) Silvex Sample (GWS = 50)Measurement PARM Code 39760 P Permit ug/L 0 24-hr FPC Report Annually Mon, Site No. RWS-A Requirement (Max.) Alachlor Sample (GWS = 2)Measurement PARM Code 39161 P Permit Report ug/L 0 24-hr FPC Annually Mon, Site No. RWS-A Requirement (Max.) Atrazine Sample (GWS = 3)Measurement PARM Code 39033 P ug/L 0 24-hr FPC Permit Report Annually Mon. Site No. RWS-A Requirement (Max.) Benzo(a)pyrene Sample (GWS = 0.2)Measurement PARM Code 34247 P Permit Report ug/L 0 Annually 24-hr FPC Mon. Site No. RWS-A Requirement (Max.) Carbofuran Sample (GWS = 40)Measurement PARM Code 81405 P Report ug/L 0 24-hr FPC Annually Mon. Site No. RWS-A Requirement (Max.) Chlordane (tech mix. and Sample metabolites)(GWS = 2)Measurement PARM Code 39350 P Permit ug/L 24-hr FPC Report 0 Annually Mon. Site No. RWS-A Requirement (Max.)

FACILITY: Grenelefe Resort WWTF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

NUMBER:

MONITORING PERIOD

From: _____ To: ____

Parameter		Quantity or Loading		Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Dalapon (GWS = 200)	Sample Measurement			-				
PARM Code 38432 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Bis(2-ethylhexyl)adipate (GWS = 400)	Sample Measurement							
PARM Code 77903 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Bis (2-ethylhexyl) phthalate (GWS = 6)	Sample Measurement			(iviax.)				
PARM Code 39100 P Mon. Site No. RWS-A	Permit Requirement	34.0		Report (Max.)	ug/L	0	Annually	24-hr FPC
Dibromochloropropane (DBCP) (GWS = 0.2)	Sample Measurement			(4.20)				
PARM Code 82625 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
Dinoseb (GWS = 7)	Sample Measurement							
PARM Code 30191 P Mon, Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Diquat (GWS = 20)	Sample Measurement							
PARM Code 04443 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Endothall (GWS = 100)	Sample Measurement							
PARM Code 38926 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Endrin (GWS = 2)	Sample Measurement							
PARM Code 39390 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Ethylene dibromide (1,2-dibromoethane)(GWS = 0.02)	Sample Measurement							
PARM Code 77651 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	Grab
Glyphosate (GWS = 0.7)	Sample Measurement							
PARM Code 79743 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	mg/L	0	Annually	24-hr FPC

FACILITY: Grenelefe Resort WWTF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

NUMBER:

MONITORING PERIOD

From: _____ To: ____

Parameter		Quantity or Loading		Units Quality or Concentration			Frequency of Analysis	Sample Type
Heptachlor (GWS = 0.4)	Sample Measurement						•	
PARM Code 39410 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Heptachlor epoxide (GWS = 0.2)	Sample Measurement			(144/1.)				
PARM Code 39420 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Hexachlorobenzene (GWS = 1)	Sample Measurement			(2.2.2.2)				
PARM Code 39700 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Hexachlorocyclopentadiene (GWS = 50)	Sample Measurement							
PARM Code 34386 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Gamma BHC (Lindane) (GWS = 0.2)	Sample Measurement							
PARM Code 39782 P Mon, Site No, RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Methoxychlor (GWS = 40)	Sample Measurement							
PARM Code 39480 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Oxamyl (vydate) (GWS = 200)	Sample Measurement							
PARM Code 38865 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Pentachlorophenol (GWS = 1)	Sample Measurement							
PARM Code 39032 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Picloram (GWS = 500)	Sample Measurement							
PARM Code 39720 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC
Polychlorinated Biphenyls (PCBs)(GWS = 0.5)	Sample Measurement							
PARM Code 39516 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L	0	Annually	24-hr FPC

FACILITY: Grenelefe Resort WWTF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA013016-011-DW2P/RA

NUMBER:

MONITORING PERIOD

From: To:

Quantity or Loading Units Quality or Concentration Units Sample Type Parameter No. Frequency of Analysis Ex. Simazine Sample (GWS = 4)Measurement PARM Code 39055 P Permit 0 24-hr FPC Report ug/L Annually Mon. Site No. RWS-A Requirement (Max.) Toxaphene Sample $(GW\hat{S} = 3)$ Measurement PARM Code 39400 P Permit ug/L 0 24-hr FPC Report Annually Mon. Site No. RWS-A Requirement (Max.) Trihalomethane, Total by Sample summation(GWS = 0.080)Measurement PARM Code 82080 P Permit Report mg/L 0 Annually Grab Mon. Site No. RWS-A Requirement (Max.) Radium 226 + Radium 228, Total Sample (GWS = 5)Measurement PARM Code 11503 P Permit pCi/L 0 24-hr FPC Report Annually Mon. Site No. RWS-A Requirement (Max.) Alpha, Gross Particle Activity Sample (GWS = 15)Measurement PARM Code 80045 P Permit pCi/L 0 24-hr FPC Report Annually Mon, Site No. RWS-A Requirement (Max.) Aluminum, Total Recoverable Sample (GWS = 0.2)Measurement PARM Code 01104 P Permit Report mg/L 0 24-hr FPC Annually Mon. Site No. RWS-A Requirement (Max.) Chloride (as Cl) Sample (GWS = 250)Measurement PARM Code 00940 P mg/L 0 24-hr FPC Permit Report Annually Mon. Site No. RWS-A Requirement (Max.) Iron, Total Recoverable Sample (GWS = 0.3)Measurement PARM Code 00980 P Permit Report mg/L 0 Annually 24-hr FPC Mon. Site No. RWS-A Requirement (Max.) Copper, Total Recoverable Sample (GWS = 1,000)Measurement PARM Code 01119 P Report ug/L 0 24-hr FPC Annually Mon. Site No. RWS-A Requirement (Max.) Manganese, Total Recoverable Sample (GWS = 50)Measurement PARM Code 11123 P Permit ug/L 24-hr FPC Report 0 Annually Mon. Site No. RWS-A Requirement (Max.)

FACILITY: Grenelefe Resort WWTF RWS-A

MONITORING GROUP NUMBER:

PERMIT NUMBER: FLA013016-011-DW2P/RA

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading Units		Quality or Con	centration	Units	No. Ex.	Frequency of Analysis	Sample Type
Silver, Total Recoverable (GWS = 100)	Sample Measurement								
PARM Code 01079 P Mon, Site No, RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
Sulfate, Total (GWS = 250)	Sample Measurement								
PARM Code 00945 P Mon, Site No, RWS-A	Permit Requirement				Report (Max.)	mg/L	0	Annually	24-hr FPC
Zinc, Total Recoverable (GWS = 5,000)	Sample Measurement								
PARM Code 01094 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	ug/L	0	Annually	24-hr FPC
pH (GWS = 6.5-8.5)	Sample Measurement								
PARM Code 00400 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	s.u.	0	Annually	Grab
Solids, Total Dissolved (TDS) (GWS = 500)	Sample Measurement								
PARM Code 70295 P Mon, Site No. RWS-A	Permit Requirement				Report (Max.)	mg/L	0	Annually	24-hr FPC
Foaming Agents (GWS = 0.5)	Sample Measurement								
PARM Code 01288 P Mon. Site No. RWS-A	Permit Requirement				Report (Max.)	mg/L	0	Annually	24-hr FPC

DAILY SAMPLE RESULTS - PART B

Permit Number:	FLA013016-011-DW2P/RA		Facility:	Grenelefe Resort WWTF
Monitoring Period	From:	To:		

	BOD, Carbonaceou s 5 day, 20C mg/L	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	Nitrogen, Nitrate, Total (as N) mg/L	Solids, Total Suspended mg/L	pH s.u.	Flow MGD	BOD, Carbonaceou s 5 day, 20C (Influent) mg/L	Solids, Total Suspended (Influent) mg/L	Total Nitrogen (As N) mg/L	Total Phosphorus (As P) mg/L
Code	80082	50060	74055	00620	00530	00400	50050	80082	00530	00600	00665
Mon. Site	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	FLW-01	INF-01	INF-01	EFA-01	EFA-01
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											
DI ANTE	STAFFING:				•				-		
Day Shift	Operator	Class:		Certificate No	»:		Name:				
Evening S	Shift Operator	Class:		Certificate No):		Name:				
	ft Operator	Class:		Certificate No			Name:				
Lead Ope		Class:		Certificate No			Name:				

Facility Name:	Grenelefe Resort WWTF		Monitoring Well ID:	MWB-01		
Permit Number:	FLA013016-011-DW2P/RA		Well Type:	Background	Report Frequency:	Quarterly
County:	Polk		Description:	Background Well	Program:	Domestic
0.65	C d D'T'		D 1 34 1D10	JMW-1 (15048)		
Office:	Southwest District		Re-submitted DMR:	Ш		
Monitoring Period	From:	To:	Date Sample Obtained:			
			Time Sample Obtained:			
Was the well purged be	fore sampling?Yes No					

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Quarterly				
Chloride (as Cl)	00940		Report	mg/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
рН	00400		Report	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		Report	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

Facility Name:	Grenelefe Resort WWTF			Monitoring Well ID:	MWC-01			
Permit Number:	FLA013016-011-DW2P/	RA		Well Type:	Compliance	Report Frequency:	Quarterly	
County:	Polk			Description:	Compliance Well	Program:	Domestic	
					JMW-2 (15043)			
Office:	Southwest District			Re-submitted DMR:				
Monitoring Period		From:	To:	Date Sample Obtained:				
				Time Sample Obtained:				
Was the well purged be	efore sampling?	Yes No						

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Quarterly				
Chloride (as Cl)	00940		250	mg/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		15	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		4	#/100mL	Grab	Quarterly				
рН	00400		6.5-8.5	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		160	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

Facility Name:	Grenelefe Resort WWTF		Monitoring Well ID:	MWC-02		
Permit Number:	FLA013016-011-DW2P/RA		Well Type:	Compliance	Report Frequency:	Quarterly
County:	Polk		Description:	Compliance Well	Program:	Domestic
				JMW-3 (15042)		
Office:	Southwest District		Re-submitted DMR:			
Monitoring Period	From:	To:	Date Sample Obtained:			
			Time Sample Obtained:			
Was the well purged be	fore sampling?Yes No					

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Quarterly				
Chloride (as Cl)	00940		250	mg/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		15	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		4	#/100mL	Grab	Quarterly				
рН	00400		6.5-8.5	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		160	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

Facility Name:	Grenelefe Resort WWTF			Monitoring Well ID:	MWC-05		
Permit Number:	FLA013016-011-DW2P/RA			Well Type:	Compliance	Report Frequency:	Quarterly
County:	Polk			Description:	Compliance Well JMW-6 (15041)	Program:	Domestic
Office:	Southwest District			Re-submitted DMR:			
Monitoring Period	From:		To:	Date Sample Obtained:			
				Time Sample Obtained:			
Was the well purged be	efore sampling?Yes	s No					

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Quarterly				
Chloride (as Cl)	00940		250	mg/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		15	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		4	#/100mL	Grab	Quarterly				
рН	00400		6.5-8.5	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		160	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. Facilities who submit their DMR(s) electronically through eDMR do not need to submit a hardcopy DMR. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different,

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used, unless indicated otherwise in the permit or on the DMR:

- 1. Results greater than or equal to the PQL shall be reported as the measured quantity.
- 2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
- 3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g., highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units. Data qualifier codes are not to be reported on Part A.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

L	CODE	DESCRIPTION/INSTRUCTIONS
	<	The compound was analyzed for but not detected.
	A	Value reported is the mean (average) of two or more determinations.
	J	Estimated value, value not accurate.
	Q	Sample held beyond the actual holding time.
ſ	Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that. Data qualifier codes are not to be reported on Part D.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharge by duration of discharge (converted into days). Record in million gallons per day (MGD). Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

STATEMENT OF BASIS FOR STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMIT NUMBER: FLA013016-011

FACILITY NAME: Grenelefe Water Utilties

FACILITY LOCATION: Abbey Court In Grenelefe, Haines City, FL 33844-9720

Polk County

NAME OF PERMITTEE: Grenelefe Water Utilities WWTF

PERMIT WRITER: Noah Cummings

1. SUMMARY OF APPLICATION

a. Chronology of Application

Application Number: FLA013016-011-DW2P

Application Submittal Date: October 28, 2024

b. Type of Facility

Domestic Wastewater Treatment Plant

Ownership Type: Private

SIC Code: 4952

c. Facility Capacity

Existing Permitted Capacity:

Proposed Increase in Permitted Capacity:

O.34 mgd Three Month Average Daily Flow
O.155 mgd Three Month Average Daily Flow
O.495 mgd Three Month Average Daily Flow

d. Description of Wastewater Treatment

An existing 0.680 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, limited to operate at 0.340 MGD 3MRADF Type II, as long as R-001 is the only effluent disposal system. The treatment plant consisting of: ten aeration basins of 682,187 gallons total volume, four clarifiers of 113,312 gallons total volume and 1,637 square feet of total surface area, seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), three pre-filter chlorine contact chambers of 21,654 gallons total volume, one post chlorine contact chamber of 19,947 gallons, one effluent pump wetwell of 9,973 gallons, and three digesters of 54,442 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

e. Description of Effluent Disposal and Land Application Sites (as reported by applicant)



2. SUMMARY OF SURFACE WATER DISCHARGE

This facility does not discharge to surface waters.

3. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to direct reclaimed water to Reuse System R-001, a rapid infiltration basin system, based on the following:

Parameter	Units	Max/	Limit	Statistical Basis	Rationale
		Min			
Flow (Before Phase	MGD	Max	0.340	Annual Average	62-600.700(2)(b) & 62-610.810(5) FAC
1 Modifications)	MOD	Max	Report	Monthly Average	62-600.700(2)(b) & 62-610.810(5) FAC
Flow (After Phase 2	MGD	Max	0.495	Annual Average	62-600.700(2)(b) & 62-610.810(5) FAC
Modifications)	MOD				
BOD, Carbonaceous	m a/I	Max	20.0	Annual Average	62-610.510 & 62-600.420(3)(a)1. FAC
5 day, 20C	mg/L	Max	30.0	Monthly Average	62-610.510 & 62-600.420(3)(a)2. FAC
BOD, Carbonaceous		Max	60.0	Single Sample	62-610.510 & 62-600.420(3)(a)4. FAC
5 day, 20C	mg/L				
Solids, Total	/T	Max	20.0	Annual Average	62-610.510 & 62-600.420(3)(b)1. FAC
Suspended	mg/L	Max	30.0	Monthly Average	62-610.510 & 62-600.420(3)(b)2. FAC

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Solids, Total Suspended	mg/L	Max	60.0	Single Sample	62-610.510 & 62-600.420(3)(b)4. FAC
Coliform, Fecal	#/100mL	Max	200	Annual Average	62-610.510 & 62-600.440(5)(a)1. FAC
Coliform, Fecal	#/100mL	Max	800	Single Sample	62-610.510 & 62-600.440(5)(a)4. FAC
pН		Min	6.0	Single Sample	62-600.445 FAC
	s.u.	Max	8.5	Single Sample	62-600.445 FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	62-610.510 & 62-600.440(5)(c) FAC
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	62-610.510(1) FAC
Nitrogen, Total	mg/L	Max	10	Annual Average	Lake Okeechobee Basin Management Action Plan June 2018
Phosphorus, Total (as P)	mg/L	Max	6	Annual Average	62-600.650(3)FAC
Nitrogen, Total	mg/L	Max	Report	Single Sample	62-600.650(3)FAC
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	62-600.650(3)FAC

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/	Limit	Statistic	Rationale
		Min		al Basis	
Flow	MGD	Max	0.340 (before	3-Month	62-600.700(2)(b) FAC
			modifications)	Rolling	
				Average	
			0.495 (after		
			modifications)		
Flow	MGD	Max	Report	Monthly	62-600.700(2)(b) FAC
				Average	
Percent Capacity,	percent	Max	Report	Monthly	62-600.405(4) FAC
(TMADF/Permitted	•		•	Average	
Capacity) x 100					
BOD,	mg/L	Max	Report	Single	62-600.660(1) FAC
Carbonaceous 5				Sample	
day, 20C (Influent)					
Solids, Total	mg/L	Max	Report	Single	62-600.660(1) FAC
Suspended (Influent)	•		•	Sample	
Monitoring	-	-	-	All	62-600 FAC & 62-699 FAC and/or BPJ of
Frequencies and				Paramet	permit writer
Sample Types				ers	
Sampling Locations	-	-	-	All	62-600, 62-610.412, 62-610.463(1), 62-
				Paramet	610.568, 62-610.613 FAC and/or BPJ of
				ers	permit writer

4. <u>IMPAIRMENT STATUS OF RECEIVING WATERS</u>

This facility does not discharge to surface waters. However, the R-001 land application system is located in a nutrient-impaired basin for Lake Okeechobee. When effluent is land applied it infiltrates into groundwater and has the potential to deliver nutrient loads to the aquifer and hydrologically connected surface waters. Monitoring for total nitrogen and total phosphorus is included for FLA013016-010 in permit condition I.A.1. in order to provide reasonable assurance that the discharge to ground waters will not cause or contribute to the nutrient impairment in the basin.

5. <u>DISCUSSION OF CHANGES TO PERMIT LIMITATIONS</u>

Wastewater Treatment:

Phase 1 Modifications

Replacement of headwork screen, upgrade out of service aeration tank to 45,970-gallon flow equalization tank.

After Phase 1 Modification

An existing 0.680 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, **limited to operate at 0.340 MGD 3MRADF Type II, as long as R-001 is the only effluent disposal system**. The treatment plant consisting of: One flow equalization tank totaling 45,970 gallons, ten aeration basins of 682,187 gallons total volume, four clarifiers of 113,312 gallons total volume and 1,637 square feet of total surface area, seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), three pre-filter chlorine contact chambers of 21,654 gallons total volume, one post chlorine contact chamber of 19,947 gallons, one effluent pump wet well of 9,973 gallons, and three digesters of 54,442 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

Phase 2 Modifications

Phase 2 modifications are completed with a permitted capacity increase to 0.495 in mind. The phase 2 digester tank will be converted into a grit removal compartment with 9,248 gallons capacity. Phase 1 diffused aeration chamber will be converted into raw wastewater flow equalization chamber with 45,970 gallons capacity. A phase 1 mechanical aeration tank, phase 1 digester, phase 1 settling tank, and a phase 1 chlorine contact chamber will be converted into decant flow equalization unit with 95,930 gallons total. Conversion of one phase 3 mechanical aeration zone, one diffused aeration zone, and consolidation with the existing sludge digester to provide 164,465 gallons in total sludge digestion volume. Construction of 3 sequencing batch reactors (SBRs) each with a volume of 250,000 gallons totaling 750,000 gallons.

Expansion, modification, and consolidation of the 4 existing RIBs, into two RIBs designated the North and South RIBs.

After Phase 2 Modification

An existing 0.680 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, limited to operate at 0.495 MGD 3MRADF Type II, as long as R-001 is the only effluent disposal system. The treatment plant consisting of: five aeration basins of 402,214 gallons total volume, seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), three pre-filter chlorine contact chambers of 21,654 gallons total volume, one post chlorine contact chamber of 19,947 gallons, one effluent pump wet well of 9,973 gallons, three sequencing batch reactors (SBRs) totaling 750,000 gallons total volume, three decant flow equalization units totaling 95,930 gallons total volume and three digesters of 164,465 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

Land Application R-001: An existing 0.495 MGD annual average daily flow (AADF) permitted capacity rapid infiltration basin (RIB) system. R-001 is a reuse system which consists of a two-cell RIB of 216,188 square feet of bottom surface area. R-001 is located approximately at latitude $28 \Box 3' 45"$ N, longitude $81 \Box 32' 42"$ W.

Phase 3 Modifications

Construction of 3 additional 250,000 SBR chambers totaling 750,000 gallons. Conversion of one phase 1 aeration chamber to a decant equalization, total decant equalization volume will be 147,980 gallons. Conversion of two phase 2 aeration tanks to raw wastewater flow equalization, totaling 196,040 FEQ unit process capacity. Conversion of two phase 3 aeration chambers to sludge digestion, providing a total sludge digestion capacity of 410,529 gallons. Demolition of phase 3 sand filters and mudwell. Conversion of existing phase 3 25,000-gallon filter clearwell into a chlorine contact tank. Construction of three denitrification filters of 150 square feet each.

After Phase 3 Modifications

An existing 1 million gallons per day (MGD) Three-Month Rolling Average Daily Flow (3MRADF), Type I, extended aeration domestic wastewater facility, **limited to operate at 0.495 MGD 3MRADF Type II, until the effluent disposal capacity is increased.** The treatment plant consisting of: seven deep bed automatic backwash filters of 448 square feet designated to handle 472 gallons per minute (GPM), two chlorine contact chambers totaling 44,947 gallons total volume, one effluent pump wet well of 9,973 gallons, six sequencing batch reactors (SBRs) totaling 1,500,000 gallons total volume, four decant flow equalization units totaling 147,980 gallons total volume, two flow equalization tanks totaling 196,040 gallons flow equalization capacity, three denitrification filters at 450 square feet total, and five digesters of 410,529 gallons total volume. This plant is operated to provide secondary treatment with basic disinfection.

REUSE OR DISPOSAL:

Land Application R-001: An existing 0.495 MGD annual average daily flow (AADF) permitted capacity rapid infiltration basin (RIB) system. R-001 is a reuse system which consists of a two-cell RIB of 216,188 square feet of bottom surface area. R-001 is located approximately at latitude $28 \square 3'$ 45" N, longitude $81 \square 32'$ 42" W.6.

BIOSOLIDS MANAGEMENT REQUIREMENTS

Biosolids generated by this facility may be transferred to BTF or disposed of in a Class I solid waste landfill.

See the table below for the rationale for the biosolids quantities monitoring requirements.

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
D: 1:1 0	4 .		D .	3.6 41.75 41	62 640 650(5)()1 F1 G
Biosolids Quantity	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
(Transferred)					
Biosolids Quantity	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
(Landfilled)	-		1	,	
Monitoring Frequency			All Para	meters	62-640.650(5)(a) FAC

7. GROUND WATER MONITORING REQUIREMENTS

Ground water monitoring requirements have been established in accordance with Chapters 62-520, 532, 600, 610, and 620, F.A.C.

8. PERMIT SCHEDULES

A schedule is included in section VI. of the wastewater permit.

9. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

10. ADMINISTRATIVE ORDERS (AO) AND CONSENT ORDERS (CO)

This permit is accompanied by AO-037SWD22, effective upon the issuance date of the permit, which includes a schedule of compliance. The AO is hereby incorporated by reference. The Grenelefe Resort WWTF is land applying effluent to a rapid infiltration basin located in the Lake Okeechobee Basin Management Action Plan area. The total nitrogen (TN) and total phosphorus (TP) limits must be met for the BMAP area. This facility must meet a TN limit of 10 mg/L and a TP limit of 6 mg/L by December 31, 2026. Until such time, the facility may operate under an interim limit for both TN and TP of report only.

11. REQUESTED VARIANCES OR ALTERNATIVES TO REQUIRED STANDARDS

No variances were requested for this facility.

12. THE ADMINISTRATIVE RECORD

The administrative record including application, draft permit, fact sheet, public notice (after release), comments received, and additional information is available for public inspection during normal business hours at the location specified in item 14. Copies will be provided at a minimal charge per page.

13. PROPOSED SCHEDULE FOR PERMIT ISSUANCE

Notice of Permit Issuance

January 2025

14. DEP CONTACT

Additional information concerning the permit and proposed schedule for permit issuance may be obtained during normal business hours from:

Noah Cummings Environmental Specialist I Southwest District Office 13051 N Telecom Pkwy, Suite 101 Temple Terrace, FL 33637-9260 Telephone No.: (813) 470 – 5777 Noah.Cummings@floridadep.gov

BEFORE THE STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Administrative Order No.: AO-037SWD22

IN THE MATTER OF:

Grenelefe Resort WWTF 4501 Abbey Court Haines City, FL 33844-9720 Polk County

Responsible Authority:

Mr. Jason Cox, Managing Member NC Real Estate Projects, LLC 110 Wades Way, Unit 134 Mooresville, NC 28117 (704) 996-4543 ndjasoncox@gmail.com

DEP Permit Application No: FLA013016-009-DW2P/NR

ORDER ESTABLISH COMPLIANCE SCHEDULE UNDER SECTION 403.088(2)(f), F.S.

I. STATUTORY AUTHORITY

The Department of Environmental Protection (Department) issues this order under the authority of Section 403.088, Florida Statutes. The Secretary of the Department has delegated this authority to the Director of District Management, who issues this order and makes the following findings fact.

II. FINDINGS OF FACT

- 1. NC Real Estate Projects, LLC (the "Permittee") is a "person" under Section 403.031, Florida Statutes (F.S.).
- 2. The Permittee owns and operates a domestic wastewater facility known as the Grenelefe Resort Center, located at Abbey Court in Grenelefe, Haines City, Florida 33842, Polk County, which land applies reclaimed water within the Lake Okeechobee watershed, a waters of the state as defined in Section 403.031(13), F.S.
- 3. The Permittee has filed a timely application for renewal of DEP Permit No. FLA013016 under Section 403.088(2), F.S.
- 4. Grenelefe Resort's land application will not meet the specific conditions I.A.1., of the DEP Permit Application No. FLA013016-009-DW2P/NR:

Parameter	Units	Max./ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Nitrogen, Total (Final Limit)								See I.Error!
(Timer Ering)	mg/L	Max	10.0	Annual	Monthly	Grab	EFA-01	Referen
				Average	·			ce source
								not

								found5
								& I.A.6
Phosphorus, Total (As P)								See
(Final Limit)								I.Error!
								Referen
	mg/L Max	Max	x 6.0	Annual Average	Monthly	Grab	EFA-01	ce
								source
								not
							found5	
								& I.A.6

- 5. The wastewater treatment facility will not meet the classification and staffing requirement in accordance to Rule 62-699.310 (2) (a)1., F.A.C as a Category I, Type III, Class C facility.
- 6. Sections 403.088(2)(e) and (f), F. S., authorize the Department to issue a permit for the discharge of wastes into waters of the state, accompanied by an order establishing a schedule for achieving compliance with all permit conditions if the specified criteria are met.

7. The Department finds that:

- (a) NC Real Estate Projects, LLC has not submitted a reasonable plan to achieve the applicable total nitrogen (TN) limit of 10.0 milligrams per liter (mg/L) and total phosphorus (TP) limit of 6.0 milligrams per liter (mg/L). The applicant will monitor the plant effluent for TN and TP, and then based on the evaluation of the data, recommend a plan of action to meet the final TN and TP limits, respectively;
- (t) NC Real Estate Projects, LLC needs permission to land apply reclaimed water within the Lake Okeechobee watershed for a period necessary to gather definitive data and determine a course of action for the facility to meet the applicable TN and TP limits;
- (c) NC Real Estate Projects, LLC land applies the reclaimed water into land application site R-001, consisting of a four-cell Rapid Infiltration Basin (RIB) of 100,188 square feet of bottom surface area, having a capacity of 0.34 MGD. There is no present, reasonable alternative means of land applying the reclaimed water outside the Lake Okeechobee watershed or reducing TN and TP in the reclaimed water, until a study is completed, and any determined facility upgrades are identified, permitted and constructed;
- (a) NC Real Estate Projects, LLC requests that an interim limit of Report for TN and TP be applied to the facility effluent until the required upgrades/modifications to meet the TN and TP limits are achieved on/by December 31, 2026;
- (e) NC Real Estate Projects, LLC requests that the facility be classified as a Category III, Class C facility until the required upgrades/modifications to meet the TN limit are achieved or/by December 31, 2026;
- (1) The granting of an operation permit will be in the public interest; or
- (g) The land application of the reclaimed water will not be unreasonably destructive to the quality of the receiving ground waters.

III. ORDER

Based on the foregoing findings of fact,

IT IS ORDERED,

- 1. NC Real Estate Projects, LLC shall be allowed to land apply the reclaimed water to the facility water reuse system.
- 2. NC Real Estate Projects, LLC shall provide relevant water quality data, physical circumstances, or other site-specific credible information needed to demonstrate reasonable assurance that the basin watershed will be protected, pursuant to subsections 62-620.320(6) and 62-4.070(3), and paragraph 62-620.620(1)(g), F.A.C.
- 3. NC Real Estate Projects, LLC shall comply with the requirements of this order, the permit and any subsequent revisions to the permit. This order establishes the interim requirement for TN and TP, interim classification of the facility and a schedule for compliance with respect to the monitoring requirements, land application limitation and facility classification.
- 4. During the interim period in which the permittee is working to bring the facility into compliance as required by this order, the following monitoring requirements for TN shall apply:

Parameter	Units	Max./Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number
Nitrogen, Total (Interim Limit)	mg/L	Max	Report	Annual Average	Monthly	Grab	EFA-01
Phosphorus, Total (as P) (Interim Limit)	mg/L	Max	Report	Annual Average	Monthly	Grab	EFA-01

- 5. During the interim period in which the permittee is working to bring the facility into compliance as required by this order, the facility will be classified as a Category III, Class C facility and will comply with the following specific condition V.A.1.I. of the permit.
 - a. **Before Modification to Meet the Total Nitrogen and Total Phosphorus Limits:** In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

 A Class C or higher operator 3 hours/day for 5 days/week and one weekend visit. The lead/chief operator must be a Class C operator, or higher.
- 6. Compliance schedule for the reclaimed water to meet the applicable TN limit and facility re-classification:

Action Item	Due Date
1) Collect monthly effluent samples and analyze for TN and TP and report as required by this permit and Discharge Monitoring Report.	First day of the second month following the permit issuance until September 31, 2025
2) Submit a proposal with the most feasible option to bring the TN and TP into compliance with the final limits being 10.0 mg/L and of 6.0 mg/L, respectively. If necessary, schedule a meeting with DEP SWD office to discuss the proposal.	Prior to September 31, 2025
4) Obtain the Department's approval for the proposal.	Prior to September 31, 2025
5) Implement the proposal.	Within twelve months of DEP approval and after obtaining a permit modification, if required.

6) Comply with the final limit for TN and TP or obtain Department approved regulatory relief	Within three months of completion of any modification if required.
7) Meet the facility classification and operator staffing requirement in accordance to Rule 62-699.310 (2) (a)1., F.A.C as a Category I, Type III, Class C facility.	Upon the date of completion for item 6.

- 7. The monitoring requirements, interim limit for TN and TP and interim facility classification listed above shall become effective on the first day of the second month following the permit issuance and will expire on December 31, 2026. NC Real Estate Projects, LLC shall comply with the final limit for TN and TP, and facility re-classification as required by permit conditions I.A.1 and V.A.1.II respectively no later December 31, 2026.
- 8. Except as otherwise provided in this order, Westgate International, Inc. shall maintain and operate the domestic wastewater facility in compliance with all other conditions of DEP Permit No. FLA013016
- 9. This order may be modified through revisions as set forth in Chapter 62-620, Florida Administrative Code.
- 10. Reports or other information required by this order shall be sent to:

Florida Department of Environmental Protection Southwest District Office 13051 N. Telecom Parkway, Suite 101 Temple Terrace, Florida 33637-0926

swd wf permitting@floridadep.gov

- 11. This order does not operate as a permit under Section 403.088, Florida Statutes. This order shall be incorporated by reference into DEP Permit No. FLA013016, which shall require compliance by the permittee with the requirements of this order.
- 12. Failure to comply with the requirements of this order shall constitute a violation of this order and DEP Permit No. FLA013016 and may subject the permittee to penalties as provided in Section 403.161, Florida Statutes.

IV. NOTICE OF RIGHTS

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000 or via electronic correspondence at Agency Clerk@FloridaDEP.gov.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within twenty-one days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within twenty-one days of publication of the notice or within twenty-one days of receipt of the written notice, whichever occurs first. Section 120.60(3), Florida Statutes, however, also allows that any person who has asked the Department in writing for notice of agency action may file a petition within twenty-one days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for an extension of time within twenty-one days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected and each agency's file or identification number, if known:
- (b) The name, address, any e-mail address, any facsimile number, and telephone number of the petitioner, if the petitioner is not represented by an attorney or a qualified representative; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This action is final and effective on the date filed with the Clerk of the Department unless a petition (or request for an extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this order will not be effective until further order of the Department.

Any party to this order has the right to seek judicial review of the order under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399 3000 or via electronic correspondence at Agency Clerk@FloridaDEP.gov, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when the final order is filed with the Clerk of the Department.

Executed in Temple Terrace, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Kelley M Boatwright
Southwest District Director
Florida Department of Environmental Protection
13051 North Telecom Parkway, Suite 101
Temple Terrace, Florida 33637

FILING AND ACKNOWLEDGEMENT

FILED on this date, under Section 120.52, Florida Statutes, with the designated Deputy Clerk, receipt of which is hereby acknowledged.

November 16, 2022
[Clerk] [Date]

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this Order and all copies were mailed or transmitted electronically or by facsimile before the close of business on November 16, 2022 to the listed persons.

<u>Catherine Lemonius</u> Name November 16, 2022 Date

Copies furnished to:

Mohammed Kader, U.S. Water Services Corp., mkader@uswatercorp.net
Keith Keegan, U.S. Water Services Corp., kkeegan@uswatercorp.net
Harry Householder, U.S. Water Services Corp., hhouseholder@uswatercorp.net
Melisa Rotteveel, Operator, mrotteveel@uswatercorp.net
Bobby Romeo, Operator, bromeo@uswatercorp.net
Paul Santana, Operator, psantana@uswatercorp.net
Anthony Andrade, SWFWMD, anthony.andrade@swfwmd.stste.fl.us
Erica Peck, DEP SWD, erica.peck@floridadep.gov
Lance Kautz, DEP SWD, lance.kautz@floridadep.gov

David Petti, DEP SWD, david.pette@floridadep.gov

Micah Minaberry, SWD DEP, micah.minaberry@floridadep.gov