

Robert L. McGee, Jr.
Regulatory & Pricing Manager

One Energy Place
Pensacola, Florida 32520-0780

Tel 850 444 6530
Fax 850 444 6026
RLMCGEE@southernco.com



February 27, 2015

Mr. Thomas Ballinger, Director
Division of Engineering
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0868

Dear Mr. Ballinger:

Attached are an original and seven copies of Gulf Power Company's Annual Distribution Service Reliability Report as required by Rule 25-6.0455, along with annual storm hardening initiatives as required in Order No. PSC-06-0781-PAA-EI and the status report on Gulf's Storm Hardening Plan as required by Paragraph 7 of the "Process to Engage Third party Attachers" Stipulated Agreement dated September 26, 2007 in Docket No. 070299-EI.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert L. McGee, Jr.".

Robert L. McGee, Jr.
Regulatory and Pricing Manager

md

Attachment

Cc w/attach: Ms. Carlotta Stauffer, Commission Clerk

RECEIVED-FPSC
15 MAR -2 AM 9:35
COMMISSION
CLERK

GULF POWER COMPANY

Reliability

and

Storm Hardening Initiatives

Report

March 2, 2015



Table of Contents

1.0	STATUS REPORT OF IMPLEMENTATION OF STORM HARDENING PLAN	4
1.1	2014 STORM HARDENING ACTIVITIES	4
2.0	WOOD POLE INSPECTION PROGRAM	7
2.1	WOOD POLE INSPECTION DESCRIPTION.....	7
2.2	2014 ACCOMPLISHMENTS	7
2.3	PROJECTED 2014 GOALS	7
3.0	VEGETATION MANAGEMENT PROGRAMS.....	7
3.1	DISTRIBUTION VEGETATION MANAGEMENT (VM) PLAN OVERVIEW	7
3.2	TRANSMISSION VEGETATION MANAGEMENT PLAN OVERVIEW	8
3.3	SUPPLEMENTAL VM PROGRAMS	8
3.4	COMPANY'S OVERALL VEGETATION MANAGEMENT SUMMARY	8
3.5	2013 DISTRIBUTION PERFORMANCE METRICS (SYSTEM WIDE).....	9
4.0	JOINT USE POLE ATTACHMENT AUDITS	10
4.1	ACTIVITY AND COSTS INCURRED FOR 2014 AND 2015 PROJECTIONS	10
4.2	JOINT USE ATTACHMENT AUDITS – DISTRIBUTION POLES	10
5.0	SIX-YEAR INSPECTION CYCLE FOR TRANSMISSION STRUCTURES	10
5.1	ACTIVITY AND COSTS INCURRED FOR 2013 AND 2014 PROJECTIONS	10
5.2	TRANSMISSION CIRCUIT, SUBSTATION AND OTHER EQUIPMENT INSPECTIONS.....	11
5.3	TRANSMISSION METAL POLE AND TOWER INSPECTIONS	11
5.4	TRANSMISSION POLE INSPECTIONS	12
6.0	STORM HARDENING ACTIVITIES FOR TRANSMISSION STRUCTURES.....	12
6.1	ACTIVITY AND COSTS INCURRED FOR 2014 AND 2015 PROJECTIONS	12
6.2	HARDENING OF EXISTING TRANSMISSION STRUCTURES (POLES)	13
7.0	DISTRIBUTION SUBSTATIONS.....	13
7.1	FIVE-YEAR PATTERNS/TRENDS IN RELIABILITY PERFORMANCE OF DISTRIBUTION SUBSTATIONS	13
7.2	DISTRIBUTION SUBSTATION RELIABILITY TRACKING	13
7.3	DISTRIBUTION SUBSTATION RELIABILITY PROBLEM IDENTIFICATION PROCESS	13
7.4	DISTRIBUTION SUBSTATION INSPECTIONS DURING NORMAL OPERATIONS	14
8.0	GEOGRAPHIC INFORMATION SYSTEM (GIS)	14
8.1	ACTIVITY AND COSTS INCURRED FOR 2014 AND 2015 PROJECTIONS	14
8.2	DISTRIBUTION OVERHEAD DATA INPUT	14
8.3	DISTRIBUTION UNDERGROUND DATA INPUT	15
9.0	POST STORM DATA COLLECTION AND FORENSIC ANALYSIS.....	15
9.1	ACTIVITY AND COSTS INCURRED FOR 2014 AND 2015 PROJECTIONS	15
10.0	OUTAGE DATA DIFFERENTIATING BETWEEN OVERHEAD AND UNDERGROUND SYSTEMS	16
10.1	ACTIVITIES AND COSTS INCURRED IN 2014 AND 2015 PROJECTIONS	16
11.0	COORDINATION WITH LOCAL GOVERNMENTS.....	17
11.1	ONGOING PROGRAMS.....	17
11.2	STORM PREPARATION.....	18
11.3	STORM RESTORATION	19
12.0	COLLABORATIVE RESEARCH.....	19

13.0	DISASTER PREPAREDNESS AND RECOVERY PLAN	19
13.1	ACTIVITY AND COSTS INCURRED FOR 2014 AND 2015 PROJECTIONS	19
13.2	DISASTER RECOVERY PLAN ACTIVITY	19
13.3	HURRICANE DRILL	20
14.0	STORM SEASON READY STATUS	20
15.0	2014 RELIABILITY PERFORMANCE	21
15.1	OVERALL PERFORMANCE	21
15.2	DATA TRACKING LEVEL	22
15.3	CRITICAL REVIEW OF DETAILED RELIABILITY DATA	23
15.4	IDENTIFICATION AND SELECTION OF DETAILED RELIABILITY DATA	23
15.5	GENERATION EVENTS – ADJUSTMENTS	23
15.6	TRANSMISSION EVENTS – ADJUSTMENTS	23
15.7	EXTREME WEATHER – ADJUSTMENTS	24
15.8	OTHER DISTRIBUTION ADJUSTMENTS	24
15.9	ADJUSTED RELIABILITY	24
15.9.1	<i>Outage Event Causes</i>	<i>24</i>
15.9.2	<i>Three Percent Feeder List</i>	<i>33</i>
15.9.3	<i>Regional Reliability Indices</i>	<i>34</i>
15.10	OVERHEAD – UNDERGROUND RELIABILITY	34
15.10.1	<i>Five-Year Patterns</i>	<i>34</i>
15.10.2	<i>Identification and Selection/Process Improvements</i>	<i>37</i>
15.10.3	<i>2014 Activities and Budget Allowances</i>	<i>37</i>
15.10.4	<i>Overhead (OH) and Underground (UG) Metrics</i>	<i>37</i>
15.11	RELIABILITY RELATED CUSTOMER COMPLAINTS	38
15.11.1	<i>Five-Year Patterns</i>	<i>38</i>
15.11.2	<i>Correlation of Reliability Related Customer Complaints to Indices</i>	<i>39</i>
15.11.3	<i>Identification and Selection/Process Improvements</i>	<i>39</i>

APPENDICES

APPENDIX 1	RELIABILITY DATA
APPENDIX 2	ANNUAL WOOD POLE INSPECTION REPORT
APPENDIX 3	FEEDER SPECIFIC DATA
APPENDIX 4	PURC REPORT ON COLLABORATIVE RESEARCH
APPENDIX 5	CROSS REFERENCE INDEX

1.0 Status Report of Implementation of Storm Hardening Plan

This section is intended to fulfill the requirement for filing a status report of Gulf Power Company's Storm Hardening Plan. A "Stipulation and Agreement" was signed between Gulf Power Company (Gulf or Company) and the Florida Cable Telecommunications Association (FCTA) on November 9, 2010. This agreement was revisited in November 2013 and signed again by Gulf and FCTA.

On May 1, 2013, Gulf Power Company filed its 2013-2015 Storm Hardening Plan update with the Florida Public Service Commission (FPSC) as required by Rule 25-6.0342, F.A.C., Docket No. 130139-El was opened to address the update. On December 3, 2013, the FPSC approved Gulf's 2013-2015 Storm Hardening Plan.

1.1 2014 Storm Hardening Activities

The following storm hardening activities were initiated and/or completed in the field during 2014:

Distribution

Gulf continued to hold meetings in order to enhance communications between Gulf's field personnel and third party attachers. Meeting notifications were sent to the following third party attachers:

1. AT&T,
2. Brighthouse Networks, LLC
3. Century Link
4. Century Tel/Madison River Communication
5. CHELCO
6. City of Pensacola
7. Comcast Joint Holdings, Inc.
8. Cox Communications Gulf Coast
9. Escambia County Schools
10. Frontier Communications NW, Inc.
11. GTC/Fairpoint Communications
12. Kentucky Data Link, Inc., dba Windstream
13. Knology, dba WOW (Way Out West)
14. Level 3 Communications, LLC
15. MediaCom
16. Southern Light, LLC
17. Springfield Cablevision Inc.
18. Valparaiso Broadband Communications

- 19. Walton County
- 20. Verizon

Gulf's permit administrator (ICON Consulting) and pole removal contractor (Davey Resource Group) also attended these meetings. Ongoing communication between all of these entities remains vital to the success of Gulf's storm hardening initiatives since detailed information on actual or proposed attachments is required to complete computer modeling of poles to determine the type and class to be installed.

During these meetings, Gulf reviewed:

- Planned major projects (both Company and customer driven);
- Grade B construction standards;
- Pole Inspection program (Osmose);
- Permitting criteria related to removing attachments;
- Pole removal program;
- Guying standards;
- In-service wood pole inspection tagging.

Organizational charts and maps identifying Gulf field personnel and areas of responsibility were provided to the third party attachers. The 2014 meetings were held during the first and third quarters of the year. Attendees at meetings held during the first quarter in Panama City and Pensacola included representation from:

- Gulf field personnel, special project engineers, technical services engineers, and their respective supervision and management
- AT&T
- Brighthouse Networks, LLC
- Century Link
- Comcast Joint Holdings, Inc.
- Cox Communications Gulf Coast
- Davey Resource Group
- ICON Consulting
- Knology, dba WOW (Way Out West)
- MediaCom
- Southern Light, LLC

Attendees at meetings held during the third quarter in Panama City and Pensacola included representation from:

- Gulf field personnel, special project engineers, technical services engineers, and their respective supervision and management
- AT&T
- Brighthouse Networks, LLC
- Century Link
- CHELCO
- Cox Communications
- Davey Resource Group
- ICON Consulting
- Mediacom

Prior to the 2014 hurricane season, representatives from Gulf, Century Link, and AT&T discussed their respective storm plans in the event of a major event. Since February 11, 2008, Gulf has assigned a liaison to AT&T during storm events and in 2012, a liaison was also assigned to Century Link. Such conversations will again occur in 2015 thus continuing smooth and timely flow of information. In the event of a storm, Gulf will be ready to communicate restoration status information so that others can then begin their own restoration work.

Gulf continues to focus on the distribution projects and objectives outlined as part of the 2013 – 2015 Storm Hardening Plan.

Distribution

- Critical infrastructure.
- Underground Network Improvements.
- Automated Overhead Faulted Circuit Indicators.
- Distribution Automation.
- Distribution Supervisory Control and Data Acquisition (DSCADA).

Transmission

- All critical lines were aurally inspected.
- Four separate aerial patrols of the total system were completed.
- Comprehensive walking/climbing and ground line inspections as part of the six-year inspection program were completed.

2.0 Wood Pole Inspection Program

2.1 Wood Pole Inspection Description

Gulf's 2014 Wood Pole Inspection Program was designed to comply with FPSC Order No. PSC-06-0144-PAA-EI (eight-year inspection cycle) and FPSC Order No. PSC-07-0078-PAA-EU (allowed certain deviations regarding CCA poles less than 15 years in age and poles surrounded by concrete and asphalt). In 2014, Gulf started the first year of the second eight-year inspection cycle, utilizing its existing wood pole inspection matrix. This matrix is based on pole age, treatment type and condition, and allows the selective excavation and boring of newer poles.

2.2 2014 Accomplishments

In 2014, a total of 27,204 poles were inspected with a rejection rate of 2.48%. See Appendix 2, titled "Annual Wood Pole Inspection Report" for details.

Gulf also completed change out of all poles identified as rejects from all inspections prior to 2014 and began changing out poles identified as rejects in the 2014 inspection.

2.3 Projected 2015 Goals

Gulf intends to continue its pole inspection program in 2015 to ensure the Company maintains an eight-year inspection cycle. The 2015 inspections will represent the second year of Gulf's second eight-year inspection cycle.

In addition, the remaining poles identified as rejects in the 2014 inspection will be changed out or reinforced in 2015. These poles will be upgraded to Grade B construction standards.

3.0 Vegetation Management Programs

3.1 Distribution Vegetation Management (VM) Plan Overview

In 2014, Gulf continued the Vegetation Management (VM) program approved by the FPSC in Order No. PSC 07-1022-FOF-EI. Gulf's vegetation management program consists of a three year cycle on main line feeders, four year cycle on laterals, and an annual cycle of inspections and correction on main line feeders.

3.2 *Transmission Vegetation Management Plan Overview*

Vegetation hazard removals continued to be the focus of Gulf's 2014 Transmission VM programs. Detailed ground patrols were performed on the transmission Right of Ways (ROW) in an effort to identify vegetation conditions requiring correction. All vegetation conditions identified by the 2014 patrols were corrected through vegetation removal or pruning activities. In 2014, Gulf was in full compliance with North American Electric Reliability Council (NERC) Standard FAC 003-1 and FAC 003-3.

3.3 *Supplemental VM Programs*

Gulf continues to use the **Distribution Lock-Out Report (DLOR)** which is a tracking process developed by Gulf to document and track distribution feeder lock-outs. This program continues to be an effective VM tool across the company. The data collected during field evaluations by Gulf engineers and forestry specialists helps identify the root causes of feeder breaker lock-outs. This enables us to modify and improve our VM management practices employed on Gulf's distribution system. The use of DLOR will continue to be a valued element of our future VM programs.

"Tree Gulf" was continued throughout 2014 as a tool to proactively report and address problem vegetation conditions that could pose a future threat to system reliability. "Tree Gulf" streamlined the internal reporting process and electronically produced work-orders directly to Forestry Services to inspect and correct potential vegetation related risks. This tool enabled every Gulf employee, including non-field personnel, the ability to easily report vegetation concerns through phone, radio, or email communication.

3.4 *Company's Overall Vegetation Management Summary*

During 2014, Gulf pruned 241 mainline miles. Additionally, 482 miles of main line primary were inspected and any vegetation conditions found to be out of specification were pruned or removed. Gulf also pruned 1,294 miles of lateral primary lines.

3.5 2013 Distribution Performance Metrics (System Wide)

1. Distribution VM Reliability

Outages & Interruptions	FEEDER			LATERAL		
	Unadjusted	Adjusted	Diff.	Unadjusted	Adjusted	Diff.
A) Number of Outages	14	9	5	1,484	1,076	408
B) Customer Interruptions	18,645	12,088	6,557	73,967	37,869	36,098
C) Outages Per Mile	0.0194	0.0125	0.0069	0.2883	0.2090	0.0793
D) CI Per Mile	25.80	16.72	9.08	14.37	7.36	7.01
E) Customer Minutes of Interruption	1,437,166.68	704,066.63	733,100.05	17,076,649.17	4,529,116.08	12,547,533.09

2. Distribution Performance

VM Miles Cleared and Contractor Cost	Plan (mi)	Actual (mi)	Plan (\$)	Actual (\$)
A) MATS Mainline Annual Trim Schedule (3 Year Cycle)	241	241	\$680,000	\$718,766
B) MICS Mainline Inspect & Correct Schedule (1 Year Cycle)	482	482	\$205,000	\$217,183
C) SALT Scheduled Annual Lateral Trim (4 Year Cycle)	1,287	1,294	\$4,379,620	\$4,158,423
D) TICKETS (T) Hot Spot Tickets Inspected and Worked Completed with Contract Cost	Feeder (T) 0	Lateral (T) 4,322	Feeder (\$) \$0.00	Lateral (\$) \$434,495

3. Total Distribution Vegetation Cost

VM Planned Vs Actual Program Costs	Plan (\$)	Actual (\$)
A) VM Contractor Costs (MATS, MICS, SALT, TICKETS, HERBICIDE, MOWING, MISCELLANEOUS)	\$5,918,006	\$5,900,277
B) VM Other Program Costs (Internal Labor and Miscellaneous)	\$30,000	\$33,492
C) Total Distribution Vegetation Cost	\$5,948,006	\$5,933,769

4.0 Joint Use Pole Attachment Audits

Gulf performs its joint use inventory audits, covering the overhead distribution system as required by FPSC Order No. PSC-06-0781-PAA-EI every five years. The most recent audit was completed on December 15, 2011. The next audit is scheduled for 2016.

4.1 Activity and Costs Incurred for 2014 and 2015 Projections

No additional costs were incurred in 2014 or are anticipated in 2015.

4.2 Joint Use Attachment Audits – Distribution Poles

(A) Number of company owned distribution poles (See Note 1)	200,506
(B) Number of company distribution poles leased: 8 Telecomm attachers on Gulf's poles (See Note 1)	136,692
(C) Number of owned distribution pole attachments: 7 CATV, numerous Government and other 3 rd party attachers on Gulf's poles (See Note 1)	159,714
(D) Number of leased distribution pole attachments: Foreign poles Gulf Power is attached to (See Note 1)	57,403
(E) Number of authorized attachments: Sum of all attachments to Gulf Power Company poles (See Note 1)	296,406
(F) Number of unauthorized attachments:	0
(G) Number of apparent NESC violations involving electric infrastructure	Note 2
(H) Number of apparent NESC violations involving 3 rd party facilities	Note 2

NOTES:

Note 1: Data has been updated based on the 2014 year end GIS data.

Note 2: Gulf Power does not collect this type of data as part of the joint use process. When Gulf becomes or is made aware of NESC violations, corrective measures are taken.

5.0 Six-Year Inspection Cycle for Transmission Structures

5.1 Activity and Costs Incurred for 2014 and 2015 Projections

In 2004, Gulf participated with Georgia Power Company, Alabama Power Company, and Mississippi Power Company to develop and adopt the Southern Company Transmission Line Inspection Guidelines. Based on these guidelines Gulf's Transmission Line Inspection Program is a combination of three separate programs; (1) a ground line treatment inspection which is performed by a contractor, (2) a comprehensive

walking inspection which is performed both by company line personnel and contractor line crews, and (3) aerial inspections. Gulf Power Company's transmission inspection program is based on two alternating twelve-year cycles which result in a structure being inspected at least every six years. As part of the Transmission Line Inspection Standards, Gulf performs at least four routine aerial patrols each year.

In 2014, Gulf Power spent a total of \$122,755 on a combination of comprehensive walking and ground line treatments for metal poles and towers. In addition to this amount, Gulf spent \$232,993 on a combination of comprehensive walking inspections and ground line treatments for wood and concrete poles. These amounts are shown in Section 5.3 and 5.4 respectively. All inspections are on schedule to meet the six-year timeline. Gulf performed four aerial inspections of its system with an actual cost of \$15,216.

5.2 *Transmission Circuit, Substation and Other Equipment Inspections*

Gulf has 56 substations which have transmission equipment in service and completed at least one inspection of these substations during 2014. The costs associated with inspections are not tracked separately from general maintenance expenses. Gulf transmission does not inspect by circuit.

5.3 *Transmission Metal Pole and Tower Inspections*

	2014 Activity		2014 Costs		2015	
	Goal	Actual	Budget	Actual	Goal	Budget
(A) Total Transmission Metal Poles and Towers Inspections	-	2,501	-	-	-	-
(B) Transmission Metal Poles and Towers	514	665	\$56,700	\$122,755	368	\$70,244
(C) Percent of transmission Metal Poles and Tower inspections completed	-	111%	-	-	-	-

5.4 Transmission Pole Inspections

	2014 Activity		2014 Costs		2015	
	Goal	Actual	Budget	Actual	Goal	Budget
(A) Total number of Transmission Poles	-	14,089	-	-	-	-
(B) Number of transmission poles inspected.	1,978	2,025	\$116,000	\$232,993	1,491	\$214,666
(C) Number of transmission poles passing inspection.	-	1,729	-	-	-	-
(D) Number of transmission poles failing strength test (overloaded)	-	N/A	-	-	-	-
(E) Number of transmission poles failing inspection (other reasons).	-	28	-	-	-	-
(F) Number of transmission poles corrected (strength failure)	-	0	-	-	-	-
(G) Number of transmission poles corrected (other reasons)	-	106	-	-	-	-
(H) Total transmission poles replaced	-	106	-	-	N/A (Note 1)	-

NOTES:

Note 1: Gulf uses current year inspections and prior years' inspections in determining the poles to be replaced in the current year. Therefore a goal for poles to be replaced in 2015 is not applicable.

6.0 Storm Hardening Activities for Transmission Structures

6.1 Activity and Costs Incurred for 2014 and 2015 Projections

Gulf Power Company has completed its storm guying on all wooden H-frame structures and will continue the replacement of wooden cross arms with steel cross arms on the transmission system. These activities will add additional strength capacity to the existing structures.

Gulf Power Company believes continuing with the wooden cross arm replacement program is the best alternative for existing transmission assets most at risk. The replacement of wooden cross arms with steel cross arms will continue in 2015 and is on schedule to meet the 2017 completion date.

6.2 Hardening of Existing Transmission Structures (Poles)

	2014 Activity		2014 Costs		2015	
	Goal	Actual	Budget	Actual	Goal	Budget
(A) Transmission structures hardened	200	200	(Note 1)	(Note 1)	170	(Note 1)
(B) Percent Transmission structures hardening completed	-	100%	-	-	-	-

Note 1: Actual dollars spent are incorporated into a budget for infrastructure replacement projects and not separated by hardening activity.

7.0 Distribution Substations

7.1 Five-Year Patterns/Trends in Reliability Performance of Distribution Substations

Gulf reviews each substation related outage, and actions are taken to reduce the possibility of a similar-caused outage occurring in the future. The review of data for the past five years does not show any trends or patterns affecting distribution substation reliability.

7.2 Distribution Substation Reliability Tracking

Each abnormal substation related outage is reviewed. Analyses are performed and corrections are made to reduce the potential for future outages as a result of a similar system disturbance.

7.3 Distribution Substation Reliability Problem Identification Process

In order to promote substation reliability, inspections are performed. These inspections include visual checks on all equipment including breakers, regulators, transformers and battery banks. The substation is verified to ensure proper signage. The fence is checked for security and proper grounding. Security lights are checked and weed problems are noted. Any abnormal condition is documented in Gulf Power's Standard Transmission Operation and Maintenance Program (STOMP) and scheduled for repair.

Along with substation inspections, equipment maintenance is performed on a regular cycle to maintain reliability. A detailed battery inspection is completed every six months with impedance tests performed every four

years. Preventative diagnostics on Oil Breakers are performed every two years. Preventative diagnostics on 12kV vacuum breakers are performed every four years. Preventative diagnostics on regulators are performed every year. A dissolved gas analysis is performed on transformers every year and power factor testing is performed every six years.

7.4 *Distribution Substation Inspections During Normal Operations*

Gulf inspected each of its distribution substations at least once during 2014.

8.0 Geographic Information System (GIS)

8.1 *Activity and Costs Incurred for 2014 and 2015 Projections*

Gulf completed its distribution facilities mapping transition to the Distribution Geographic Information System (DistGIS) in 2009. DistGIS data continues to be updated with any additions and changes as the associated work orders for maintenance, system improvements, and new business are completed.

The Transmission system has been completely captured in the Transmission GIS database. Transmission GIS continues to be updated with any additions and changes as the associated work orders for maintenance, system improvements, and new business are completed.

8.2 *Distribution Overhead Data Input*

All overhead distribution equipment has been captured in Gulf's DistGIS database including conductors, regulators, capacitors and switches. This includes protective devices such as reclosers, sectionalizers, fuses and transformers. DistGIS continues to be updated with any additions and changes as the associated work orders for maintenance, system improvements, and new business are completed. This on-going process provides Gulf with sufficient facility information for the collection of forensic data to assess the performance of the overhead system in the event of a major storm.

8.3 *Distribution Underground Data Input*

All underground distribution equipment has been captured in Gulf's DistGIS including conductors, regulators, capacitors and switches. This includes protective devices such as reclosers, sectionalizers, fuses and transformers. DistGIS continues to be updated with any additions and changes as the associated work orders for maintenance, system improvements, and new business are completed. This on-going process provides Gulf with sufficient facility information for the collection of forensic data to assess performance of the underground system in the event of a major storm.

9.0 Post Storm Data Collection and Forensic Analysis

9.1 *Activity and Costs Incurred for 2014 and 2015 Projections*

Distribution:

The 2014 storm season was uneventful; as such, there was no need to mobilize the forensic data collection process and contractor. In order to confirm the process GIS data was updated in the contractor's hand held computers and data collection was tested prior to storm season to ensure the data collection system was working properly and ready to deploy in the event of a storm.

Gulf will continue to confirm and test the process in 2015 to ensure the Company and contractors are ready to perform post-storm forensics if needed.

Transmission:

Gulf Power Company's Transmission department's forensics team will be led by the transmission engineering function. Utilizing an aerial patrol with a fixed wing aircraft, the team will capture an initial assessment of the level of damage to the transmission system. A follow-up aerial patrol utilizing helicopters will capture GPS coordinates for each failure and record the failures with the Transmission Line Inspection System (TLIS). When ground crews arrive on the scene, the construction inspector with the crew will be responsible for assessing all damage and making a determination as to the cause of the failure. Gulf's Transmission Engineering department will review all findings of the field inspection and determine if additional information should be gathered.

Gulf Power's existing Common Transmission Data Base (CTDB) will be utilized to capture all forensic information. The TLIS tool will be used to track all facility failures and create work orders to associate those failures

with the affected facilities. TLIS utilizes geographic mapping software to track the location of the facilities.

10.0 Outage Data Differentiating Between Overhead and Underground Systems

Gulf did experience outages and damage associated with both the overhead and underground systems including several FPSC excludable events in 2014. These outage events, including the ones excludable under the FPSC rules, did not produce any major storm related data for analysis.

10.1 Activities and Costs Incurred in 2014 and 2015 Projections

Gulf continues to keep records and analysis of data associated with overhead and underground outages, some of which is included in Section 15.10.4 of this report. That outage data includes:

- UG cable is:
 - direct buried
 - direct buried, but cable injected
 - in conduit
- Pole type is:
 - concrete
 - wood

This data is collected as each outage occurs using Gulf's Trouble Call Management System (TCMS). Data collected in 2014 is shown in the tables below. This data contains all outage event information including those events excluded under FPSC rules such as transmission outages, planned outages, and all other exclusions. The cost of collecting this data is minimal as existing systems and processes are utilized.

Customers	System	N	CI	CMI	Duration	SAIDI	SAIFI	CAIDI	L-Bar
444,047	Overhead	15,351	671,222	81,765,251.86	1,994,447.18	184.14	1.512	121.82	129.92
444,047	URD - Direct Burial	312	7,184	1,429,260.98	56,953.01	3.22	0.016	198.95	182.54
444,047	URD - In Conduit	241	3,819	642,604.06	37,262.31	1.45	0.009	168.27	154.62
444,047	URD - Injected	2	19	809.13	112.90	0.00	0.000	42.59	56.45
444,047	URD - Undetermined	908	17,168	3,435,662.00	149,495.24	7.74	0.039	200.12	164.64

Customers	Failure	N	CI	CMI	Duration	SAIDI	SAIFI	CAIDI	L-Bar
444,047	Pole - Wood	13	2,425	348,670.48	2,736.10	0.79	0.005	143.78	210.47

11.0 Coordination with Local Governments

Gulf is committed to coordinating with local governments on major projects and storm preparedness so that the customer will have the most reliable and efficient restoration of their electrical service. For all major projects, Gulf meets with governmental entities as appropriate to discuss the scope of the projects and coordinate activities involved with project implementation. Gulf also works very closely with the county Emergency Operation Centers (EOCs) in its service area for storm preparedness and restoration activities as needed and actively pursues a positive and cooperative relationship with the leadership in every community served.

In addition, Gulf maintains year-round contact with city and county officials to ensure cooperation in planning, good communications and coordination of activities. Gulf has designated employees in every community whose job is to keep in regular contact with city, county and business leadership.

The mission of Gulf Power is to safely provide exceptional customer value by delivering reliable, affordable and environmentally responsible electricity while strengthening our communities.

11.1 Ongoing Programs

Gulf has several employees with local government liaison responsibilities in Northwest Florida. District managers are located in Pensacola, Ft. Walton, and Panama City. Local managers, who report to the district managers, are located in Milton, Crestview, Niceville, and Chipley. These employees interact with city and county personnel on a daily/weekly basis regarding numerous issues, including emergency preparedness as needed. These employees are also actively involved in specific government/business committees that focus on emergency preparedness needs in Northwest Florida. Examples of those include:

- Gulf's Corporate Emergency Management Center Specialist is a Board Member of BRACE (Be Ready Alliance for Coordinating for Emergencies). BRACE is an Escambia County organization unique to Florida but part of a federal government directive that encourages communities to develop more effective preparedness programs for various types of disasters.

- Member of the Okaloosa County Emergency Management Committee. This Committee is a coordinated effort between government and business to address emergency preparedness issues on a monthly basis.

Gulf's Line Clearance Specialists and Forestry Services Technicians communicate routinely with members of the community, government officials, and military leaders concerning area vegetation management projects and other issues such as: (1) new customer and Gulf construction projects; (2) utility right-of-way maintenance; (3) major initial clearing projects (i.e. road additions and re-sizing projects, new distribution feeders, water and sewer projects, military projects and missions, etc.); and (4) storm preparation and recovery activities. Routine communications range from office and field visits to phone and radio conversations.

In addition to numerous planning meetings with the EOCs, Gulf personnel also participated in the following hurricane activities with governmental entities during 2014:

- Hurricane Drills
- All EOC Activations
- EOC Representative Training
- Statewide Exercises

Each year, Gulf conducts a storm drill. In 2014, the April 30th flood provided the opportunity for the Company to test its storm preparedness.

11.2 Storm Preparation

Thirteen Gulf employees are assigned to the county EOCs throughout Northwest Florida. Each of these employees has received federal certification under the National Incident Management System (NIMS) through the Federal Emergency Management Agency (FEMA). These EOC Representatives assist city and county agencies and officials during emergencies that warrant activation of the county EOCs. Gulf provides 24-hour coverage throughout the duration of the EOC activation and keeps the agencies and officials informed of the progress of electrical restoration efforts. All actions are based on Gulf Power's Emergency Operations Plan.

Gulf Power's Emergency Operations Plan includes ongoing communications, pre-storm communications, and post-storm communications supplied by the Corporate Communications Department. Company News Releases are delivered to the County EOCs at least twice daily during storm restoration events to keep local government agencies and officials apprised of the latest restoration activities.

11.3 Storm Restoration

Gulf maintains an active communication link with the activated EOCs for storm events. Gulf EOC Representatives coordinate pre-storm activities with the County EOCs to establish emergency communication links with local and state officials, the media, and restoration crews for all EOC activations.

Gulf strives to restore emergency services as safely and quickly as possible. In addition, Gulf continues to storm-harden critical infrastructure, and implement stronger construction standards as outlined in the 2013 – 2015 Storm Hardening Plan. Gulf's service area was affected by Winter Storm Leon on January 28 & 29 and a flood (over 20 inches of rain in 24 hours) on April 30, 2014. Restoration of the resulting outages was handled by the local district offices working with the Company Emergency Management Center (CEMC) staff to allocate resources as needed. It was therefore not necessary to fully activate Gulf's CEMC. Personnel were assigned to work with the local EOC's to facilitate communications.

12.0 Collaborative Research

As a member of the Public Utility Research Center (PURC), Gulf participates in the research activities for Storm Hardening as described by PURC management in Appendix 4.

13.0 Disaster Preparedness and Recovery Plan

Gulf Power continues to maintain a Disaster Preparedness and Recovery Plan (Gulf's Storm Restoration Procedures Manual).

13.1 Activity and Costs Incurred for 2014 and 2015 Projections

Gulf continues to provide annual refresher training (instructor lead and computer based) in the area of storm preparedness for various storm roles at minimal cost.

13.2 Disaster Recovery Plan Activity

Gulf's 2015 Storm Restoration Procedures Manual is currently being revised and reviewed by management. Any revisions to this manual will be incorporated by April 1, 2015. Storm assignments and training

schedules are being finalized with plans for training to be completed prior to hurricane season.

13.3 Hurricane Drill

Gulf's annual hurricane drill was scheduled for May 1, 2014. Prior to the drill the weather forecast for April 29th called for 1 – 6 inches of rain. What developed though was a historic event resulting in over 20 inches of rain in 24 hours and extensive damage to the communities that Gulf serves. The planned hurricane drill became an actual event when the storm escalated beyond what was expected. Restoration efforts were handled at a Corporate level with a partial activation of our CEMC staff.

The 2015 annual drill is scheduled for May 11th. Based on the lessons learned from both the flood and earlier ice event in 2014, we will discuss the changes and revisions we have added to our plans based on best practices.

14.0 Storm Season Ready Status

Storm Recovery Plan

Gulf uses the strategy described in its Storm Restoration Procedures Manual to respond to any natural disaster that may occur in our service area. The plan has previously proven to be very effective in recovering from multiple storms that have impacted Gulf and its customers. As part of its annual operations, Gulf reviews and refines its planning and preparations for the possibility of a natural disaster in the Florida panhandle. This planning is updated annually to build on what has worked well and to improve in areas that have not work as well as intended. In these updates, Gulf strives for continuous improvement by building on experiences from recovery efforts within northwest Florida as well as from lessons learned while assisting other utilities that have experienced natural disasters.

Gulf's plan has been encapsulated within a detailed and proprietary Storm Recovery Plan procedure manual.

The restoration procedures establish a plan of action to be utilized for the operation and restoration of generation, transmission, and distribution facilities during major disasters. Such disasters include hurricanes, tornadoes, and as we learned in 2014, ice and flood events that could cause widespread outages to Gulf's customers.

The overall objective is to restore electric service to Gulf's customers as quickly as possible while protecting the safety of everyone involved.

The company acquires support from a number of resources including but not limited to the Southeastern Electric Exchange (SEE) Mutual Assistance Group and Southern Company for distribution, logistics, and transmission assistance.

In the logistics and support areas, contracts are negotiated and confirmed with vendors for services such as food, lodging, materials, transportation, fuel and other support functions. Staging sites are secured, and if needed, agreements are negotiated and signed. Gulf's Supply Chain Management department ensures that materials on hand, along with available supplies from the material vendors, are sufficient to meet the anticipated demands of the storm season.

15.0 2014 Reliability Performance

15.1 Overall Performance

Gulf Power's 2014 Adjusted System Average Interruption Duration Index (SAIDI) is reported as 87.9 minutes, which is a decrease of 6.9 minutes over the 2013 results. In 2014, the Adjusted System Average Interruption Frequency Index (SAIFI) was 0.934 interruptions; down from the 2013 results of 1.080 interruptions, a decrease of 0.146 interruptions.

Gulf Power's Actual Metrics increased from 110.90 SAIDI to 196.54 SAIDI, a 77% increase. SAIFI increased from 1.410 to 1.575 a 12% increase. The large increase in SAIDI was driven primarily by Ice Storm Leon and the April Flood exclusions. Ice Storm Leon created 31.3 SAIDI minutes and the April Flood produced 51.3 SAIDI minutes – which accounts for 96.5% of the year over year increase.

The adjusted Customer Average Interruption Index (CAIDI) is reported as 94.1 minutes, a change from 87.8 minutes in 2013 (7.2% increase). The result is attributed to how CAIDI is calculated and not the reliability performance of the system. Both SAIFI and SAIDI performance improved as stated above in 2014 with a decline of 13.5% and 7.3% respectively in 2014. Due to the fact that SAIFI improved at a greater rate than SAIDI, CAIDI showed an increase, despite the fact that the adjusted CMI and CI both declined. Essentially, the size of the denominator in the CAIDI calculation declined faster than the numerator, showing a year over year increase mathematically, though overall performance improved.

The adjusted Momentary Average Interruption Frequency Index (MAIFIE) and associated momentary interruptions that Gulf Power's customers experienced decreased to 2.33 in 2014 compared to 3.07 in 2013. In 2014, the percent of customers experiencing more than 5 interruptions –

Customer Experiencing More Interruptions than 5 (CEMI5), decreased to 0.34% compared to 1.07% in 2013.

In addition to Gulf's improved performance shown in the above metrics the Company only logged 3 reliability related customer complaints in 2014 as seen in the FPSC Complaint Activity Tracking System.

Both actual and adjusted Average Duration of Outage Events (L-Bar) increased in 2014. Adjusted L-Bar increased from 111.42 to 115.75 in 2014, which can be attributed to a severe, one-day weather event that was not excludable under the FPSC rules on March 28th. A series of severe squalls with straight line winds up to 80 mph winds came through the service area causing both outages and hampering recovery. Approximately 17,030 customers lost power that one day. If this one day had met the criteria for exclusion under the FPSC rules, the adjusted L-bar would be 112.45 which is in line with historical performance.

Gulf Power's top five outage causes based on the total number of outage events for 2014 were Defective Equipment, Animals, Lightning, Vegetation, and Unknown. Outage events due to Lightning increased by 26%, but the associated SAIDI for the same events had a 0% increase over 2013. The other four top outage causes decreased below 2013 levels: Defective Equipment (-5%), Animals (-25%), Vegetation (-19%), and Unknown decreased (-22%).

Gulf had two distribution weather exclusions for 2014. These are listed in section 15.7.

In 2014, Gulf continued to seek improvements in the company's distribution reliability through continued focus on "root" causes maintenance and implementation of distribution automation. Gulf continues to focus on mitigating recurring trouble.

See Appendix 1 for 2014 actual data and adjusted data.

15.2 Data Tracking Level

Gulf continues to collect outage data down to the customer meter level using the Trouble Call Management System (TCMS).

15.3 Critical Review of Detailed Reliability Data

In 2014, Gulf was impacted by two severe storm events which did meet the FPSC exclusion criteria.

Gulf's adjusted system outages decreased over the previous year, and improvement was made in six of the top ten outage categories.

Gulf's Central District had an unusual decline in reliability metrics from 2013 to 2014. The 85% increase from 62.28 to 115.05 SAIDI can be attributed to the one day severe weather event on March 28th discussed previously. This event, which was not excludable under the FPSC rules, primarily affected the customers in the Central District. Of the approximate 17,030 customers who lost power that day, 12,938 were in Central District. During the 24 hour event Central District accumulated 2,228,682 CMI, or 19.49 SAIDI (by District). If this one day weather event had been removed from the adjusted numbers, Central District's SAIDI would have been 95.56, which is in line with recent performance (2012 – 110.06, 2011 – 89.90, 2010 – 115.30).

15.4 Identification and Selection of Detailed Reliability Data

The identification and selection of detailed reliability data continues to be a part of Gulf's TCMS process. Gulf's outage data collection captures information down to the customer level. As a result, Gulf can review data and the resulting reliability indices at the system level and by its three districts – Western, Central, and Eastern.

15.5 Generation Events – Adjustments

There were no generation events excluded from distribution reliability reporting in 2014.

15.6 Transmission Events – Adjustments

See Appendix 1 for transmission excluded events and associated outage causes and resolutions for 2014.

15.7 Extreme Weather – Adjustments

January 27-31 EOC Opened due to Ice Storm Leon

- N = 512
- CI = 52,104
- CMI = 13,891,913
- SAIDI = 31.29
- SAIFI = 0.117

April 29-May 2 EOC Opened due to severe flooding

- N = 972
- CI = 59,211
- CMI = 22,797,497
- SAIDI = 51.34
- SAIFI = 0.133

NOTES:

N = Number of Outage Tickets

CI = Customer Interruptions

CMI = Total Customer Minutes of Interruption

15.8 Other Distribution Adjustments

Please see Appendix 1 for the document exclusions table and details associated with planned outage exclusions.

15.9 Adjusted Reliability

15.9.1 Outage Event Causes

15.9.1.1 Five-Year Patterns

Below are trending tables that show the number of outages (N), SAIDI, and SAIFI along with their respective percentage of change. The tables show the percentage change over the past five years associated with the top outage causes. Each table is presented by District and for the whole Company.

Gulf is still in the process of analyzing the 2014 data to determine the need for any specific improvement activities beyond current programs and storm hardening initiatives which are underway.

Cause	Total						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	2,984	2,495	2,371	2,820	2,308	2,503
	% Change	-	-16%	-5%	19%	-18%	8%
Eastern	N	1,964	1,913	1,753	1,982	2,087	1,961
	% Change	-	-3%	-8%	13%	5%	-6%
Western	N	6,294	5,929	5,465	6,148	5,536	4,533
	% Change	-	-6%	-8%	12%	-10%	-18%
Company	N	11,242	10,337	9,589	10,950	9,931	8,997
	% Change	-	-8%	-7%	14%	-9%	-9%

Cause	Animal						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	942	847	843	1,174	778	701
	% Change	-	-10%	-1%	39%	-34%	-10%
Eastern	N	314	344	338	377	371	303
	% Change	-	10%	-2%	12%	-2%	-18%
Western	N	1,856	1,772	1,832	2,034	1,708	1,128
	% Change	-	-5%	3%	11%	-16%	-34%
Company	N	3,112	2,963	3,013	3,585	2,857	2,132
	% Change	-	-5%	2%	19%	-20%	-25%

Cause	Vegetation						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	274	253	259	265	335	298
	% Change	-	-8%	2%	2%	26%	-11%
Eastern	N	325	276	289	294	365	333
	% Change	-	-15%	5%	2%	24%	-9%
Western	N	844	811	813	795	891	663
	% Change	-	-4%	0%	-2%	12%	-26%
Company	N	1,443	1,340	1,361	1,354	1,591	1,294
	% Change	-	-7%	2%	-1%	18%	-19%

Cause	Lightning						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	469	299	385	334	241	431
	% Change	-	-36%	29%	-13%	-28%	79%
Eastern	N	352	305	282	343	334	418
	% Change	-	-13%	-8%	22%	-3%	25%
Western	N	1,259	965	860	1,198	877	978
	% Change	-	-23%	-11%	39%	-27%	12%
Company	N	2,080	1,569	1,527	1,875	1,452	1,827
	% Change	-	-25%	-3%	23%	-23%	26%

Cause	Other Weather						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	49	37	8	47	46	99
	% Change	-	-25%	-78%	488%	-2%	115%
Eastern	N	47	46	21	33	67	43
	% Change	-	-2%	-54%	57%	103%	-36%
Western	N	75	67	56	125	136	54
	% Change	-	-11%	-16%	123%	9%	-60%
Company	N	171	150	85	205	249	196
	% Change	-	-12%	-43%	141%	22%	-21%

Cause	Vehicle						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	66	57	57	64	51	75
	% Change	-	-14%	0%	12%	-20%	47%
Eastern	N	76	66	67	51	65	72
	% Change	-	-13%	2%	-24%	28%	11%
Western	N	133	141	125	160	156	142
	% Change	-	6%	-11%	28%	-3%	-9%
Company	N	275	264	249	275	272	289
	% Change	-	-4%	-6%	10%	-1%	6%

Cause	Defective Equipment						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	791	693	529	604	554	574
	% Change	-	-12%	-24%	14%	-8%	4%
Eastern	N	565	627	531	649	601	538
	% Change	-	11%	-15%	22%	-7%	-11%
Western	N	1,434	1,578	1,182	1,308	1,222	1,145
	% Change	-	10%	-25%	11%	-7%	-6%
Company	N	2,790	2,898	2,242	2,561	2,377	2,257
	% Change	-	4%	-23%	14%	-7%	-5%

Cause	Unknown						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	289	170	200	206	206	204
	% Change	-	-41%	18%	3%	0%	-1%
Eastern	N	200	136	154	160	186	151
	% Change	-	-32%	13%	4%	16%	-19%
Western	N	499	333	337	310	323	202
	% Change	-	-33%	1%	-8%	4%	-38%
Company	N	988	639	691	676	715	557
	% Change	-	-35%	8%	-2%	6%	-22%

Cause	All Other Causes						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	104	139	90	126	97	121
	% Change	-	34%	-35%	40%	-23%	25%
Eastern	N	85	113	71	75	98	103
	% Change	-	33%	-37%	6%	31%	5%
Western	N	194	262	260	218	223	221
	% Change	-	35%	-1%	-16%	2%	-1%
Company	N	383	514	421	419	418	445
	% Change	-	34%	-18%	-1%	0%	7%

The SAIDI and SAIFI Trend Tables for the top causes are shown below:

Cause	Total						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	106.63	115.30	89.90	110.06	62.28	115.05
	% Change	-	8%	-22%	22%	-43%	85%
Eastern	SAIDI	140.08	133.41	110.29	88.24	118.36	72.83
	% Change	-	-5%	-17%	-20%	34%	-39%
Western	SAIDI	157.47	168.02	123.49	128.04	99.67	81.49
	% Change	-	7%	-27%	4%	-22%	-18%
Company	SAIDI	140.01	145.65	111.46	113.20	94.82	87.91
	% Change	-	4%	-24%	2%	-16%	-7%

Cause	Total						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	1.082	1.578	1.086	1.163	0.792	1.074
	% Change	-	46%	-31%	7%	-32%	36%
Eastern	SAIFI	1.200	1.638	1.309	0.932	1.252	0.785
	% Change	-	37%	-20%	-29%	34%	-37%
Western	SAIFI	1.589	1.883	1.301	1.277	1.141	0.939
	% Change	-	19%	-31%	-2%	-11%	-18%
Company	SAIFI	1.359	1.742	1.247	1.159	1.080	0.934
	% Change	-	28%	-28%	-7%	-7%	-14%

Cause	Animal						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	10.08	8.82	7.66	14.85	8.58	5.32
	% Change	-	-13%	-13%	94%	-42%	-38%
Eastern	SAIDI	2.63	9.81	3.94	4.72	7.13	6.23
	% Change	-	273%	-60%	20%	51%	-13%
Western	SAIDI	13.81	13.53	7.81	7.96	6.96	3.62
	% Change	-	-2%	-42%	2%	-13%	-48%
Company	SAIDI	9.97	11.37	6.78	8.90	7.42	4.73
	% Change	-	14%	-40%	31%	-17%	-36%

Cause	Animal						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.177	0.183	0.132	0.231	0.144	0.093
	% Change	-	3%	-28%	75%	-38%	-35%
Eastern	SAIFI	0.033	0.104	0.080	0.045	0.087	0.072
	% Change	-	215%	-23%	-44%	93%	-17%
Western	SAIFI	0.133	0.172	0.121	0.131	0.128	0.056
	% Change	-	29%	-30%	8%	-2%	-56%
Company	SAIFI	0.119	0.157	0.113	0.135	0.122	0.070
	% Change	-	32%	-28%	20%	-10%	-43%

Cause	Vegetation						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	7.22	9.88	10.03	5.18	10.12	12.58
	% Change	-	37%	2%	-48%	95%	24%
Eastern	SAIDI	22.78	19.23	13.35	19.33	26.29	8.78
	% Change	-	-16%	-31%	45%	36%	-67%
Western	SAIDI	21.14	25.72	25.61	24.54	20.42	13.85
	% Change	-	22%	0%	-4%	-17%	-32%
Company	SAIDI	18.01	20.00	18.46	18.22	19.27	12.22
	% Change	-	11%	-8%	-1%	6%	-37%

Cause	Vegetation						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.088	0.077	0.106	0.047	0.090	0.106
	% Change	-	-13%	38%	-56%	92%	18%
Eastern	SAIFI	0.223	0.189	0.138	0.127	0.231	0.081
	% Change	-	-15%	-27%	-8%	82%	-65%
Western	SAIFI	0.204	0.219	0.222	0.161	0.210	0.142
	% Change	-	7%	1%	-28%	30%	-32%
Company	SAIFI	0.179	0.175	0.171	0.123	0.185	0.117
	% Change	-	-2%	-2%	-28%	50%	-37%

Cause	Lightning						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	21.23	17.39	29.37	23.16	11.77	20.80
	% Change	-	-18%	69%	-21%	-49%	77%
Eastern	SAIDI	44.16	15.87	26.52	25.77	20.94	20.23
	% Change	-	-64%	67%	-3%	-19%	-3%
Western	SAIDI	52.58	33.65	28.41	37.02	24.22	19.82
	% Change	-	-36%	-16%	30%	-35%	-18%
Company	SAIDI	42.41	24.92	28.17	30.57	20.18	20.18
	% Change	-	-41%	13%	9%	-34%	0%

Cause	Lightning						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.237	0.174	0.269	0.214	0.141	0.162
	% Change	-	-27%	55%	-20%	-34%	15%
Eastern	SAIFI	0.317	0.121	0.237	0.276	0.207	0.157
	% Change	-	-62%	96%	17%	-25%	-24%
Western	SAIFI	0.394	0.255	0.249	0.295	0.184	0.225
	% Change	-	-35%	-2%	19%	-38%	22%
Company	SAIFI	0.334	0.200	0.251	0.269	0.179	0.191
	% Change	-	-40%	26%	7%	-34%	7%

Cause	Other Weather						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	17.49	1.64	0.83	5.34	1.70	15.47
	% Change	-	-91%	-49%	543%	-68%	810%
Eastern	SAIDI	3.50	4.42	1.91	1.26	13.13	2.86
	% Change	-	26%	-57%	-34%	942%	-78%
Western	SAIDI	5.62	3.10	3.92	5.88	5.39	1.05
	% Change	-	-45%	27%	50%	-8%	-81%
Company	SAIDI	8.10	3.07	2.61	4.56	6.42	5.23
	% Change	-	-62%	-15%	75%	41%	-19%

Cause	Other Weather						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.092	0.012	0.003	0.053	0.014	0.129
	% Change	-	-87%	-75%	1667%	-74%	821%
Eastern	SAIFI	0.045	0.063	0.014	0.018	0.124	0.047
	% Change	-	40%	-78%	29%	589%	-62%
Western	SAIFI	0.071	0.025	0.029	0.032	0.052	0.020
	% Change	-	-65%	16%	10%	63%	-62%
Company	SAIFI	0.070	0.031	0.019	0.034	0.061	0.055
	% Change	-	-56%	-39%	79%	79%	-10%

Cause	Vehicle						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	10.65	8.55	7.99	9.98	3.12	21.48
	% Change	-	-20%	-7%	25%	-69%	589%
Eastern	SAIDI	25.97	8.97	13.88	5.90	11.28	11.25
	% Change	-	-66%	55%	-58%	91%	0%
Western	SAIDI	16.40	23.92	10.40	15.83	10.70	10.93
	% Change	-	46%	-57%	52%	-32%	2%
Company	SAIDI	17.40	16.15	10.67	11.77	8.90	13.73
	% Change	-	-7%	-34%	10%	-24%	54%

Cause	Vehicle						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.066	0.069	0.074	0.096	0.026	0.145
	% Change	-	5%	7%	30%	-73%	458%
Eastern	SAIFI	0.174	0.141	0.236	0.053	0.092	0.105
	% Change	-	-19%	67%	-78%	74%	14%
Western	SAIFI	0.137	0.168	0.102	0.138	0.114	0.076
	% Change	-	23%	-39%	35%	-17%	-33%
Company	SAIFI	0.129	0.136	0.130	0.105	0.086	0.101
	% Change	-	5%	-4%	-19%	-18%	17%

Cause	Defective Equipment						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	32.27	34.90	22.90	21.71	14.53	16.18
	% Change	-	8%	-34%	-5%	-33%	11%
Eastern	SAIDI	30.87	41.38	23.25	19.63	24.23	16.28
	% Change	-	34%	-44%	-16%	23%	-33%
Western	SAIDI	31.04	49.57	23.65	24.12	19.97	18.29
	% Change	-	60%	-52%	2%	-17%	-8%
Company	SAIDI	31.31	43.71	23.35	22.34	19.66	17.23
	% Change	-	40%	-47%	-4%	-12%	-12%

Cause	Defective Equipment						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.279	0.404	0.222	0.223	0.128	0.149
	% Change	-	45%	-45%	1%	-43%	16%
Eastern	SAIFI	0.264	0.456	0.280	0.170	0.221	0.177
	% Change	-	73%	-39%	-39%	30%	-20%
Western	SAIFI	0.290	0.546	0.225	0.254	0.200	0.188
	% Change	-	88%	-59%	13%	-21%	-6%
Company	SAIFI	0.281	0.487	0.239	0.224	0.187	0.175
	% Change	-	73%	-51%	-6%	-17%	-6%

Cause	Unknown						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	5.85	9.10	8.09	13.82	8.55	6.26
	% Change	-	56%	-11%	71%	-38%	-27%
Eastern	SAIDI	5.67	13.42	19.37	6.37	8.89	3.80
	% Change	-	137%	44%	-67%	40%	-57%
Western	SAIDI	7.91	10.08	11.35	7.43	5.43	8.68
	% Change	-	27%	13%	-35%	-27%	60%
Company	SAIDI	6.81	10.69	12.58	8.80	7.12	6.81
	% Change	-	57%	18%	-30%	-19%	-4%

Cause	Unknown						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.087	0.146	0.115	0.136	0.157	0.113
	% Change	-	68%	-21%	18%	15%	-28%
Eastern	SAIFI	0.066	0.129	0.206	0.130	0.107	0.062
	% Change	-	96%	60%	-37%	-18%	-42%
Western	SAIFI	0.140	0.146	0.141	0.130	0.101	0.100
	% Change	-	4%	-3%	-8%	-22%	-1%
Company	SAIFI	0.107	0.142	0.151	0.131	0.117	0.094
	% Change	-	33%	6%	-13%	-11%	-20%

Cause	All Other Causes						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	1.84	25.02	3.02	16.02	3.92	16.96
	% Change	-	1260%	-88%	431%	-76%	333%
Eastern	SAIDI	4.50	20.33	8.05	5.26	6.46	3.40
	% Change	-	352%	-60%	-35%	23%	-47%
Western	SAIDI	8.97	8.45	12.35	5.27	6.57	5.25
	% Change	-	-6%	46%	-57%	25%	-20%
Company	SAIDI	6.00	15.74	8.85	8.03	5.86	7.79
	% Change	-	162%	-44%	-9%	-27%	33%

Cause	All Other Causes						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.056	0.512	0.164	0.164	0.093	0.178
	% Change	-	814%	-68%	0%	-43%	91%
Eastern	SAIFI	0.078	0.435	0.117	0.114	0.182	0.084
	% Change	-	458%	-73%	-3%	60%	-54%
Western	SAIFI	0.219	0.353	0.211	0.137	0.151	0.132
	% Change	-	61%	-40%	-35%	10%	-13%
Company	SAIFI	0.141	0.415	0.175	0.138	0.144	0.131
	% Change	-	194%	-58%	-21%	4%	-9%

15.9.1.2 Identification and Selection/Process Improvements

Gulf continues to focus its process improvement efforts on the system wide top outage causes through its existing programs and storm hardening efforts.

15.9.1.3 2014 Activities and Budget Allowances

In general, it is not practical to provide an itemized list of all activities that Gulf has included in its budget that are related to distribution reliability. Gulf's budget and accounting systems do not separately categorize and track capital expenditures or Operating and Maintenance (O&M) expenses on the basis that they are related specifically to distribution reliability. Virtually all distribution functional capital projects and O&M expenses have been or will be undertaken as part of Gulf's commitment to provide customers with reliable and high quality electric service.

Gulf's Vegetation Management Program is an exception to the above. The activities and budgets associated with this program are provided in Section 3.0.

15.9.2 Three Percent Feeder List

15.9.2.1 Five-Year Patterns

Gulf Power had one feeder in the 2014 Actual report that appeared on the 2013 report. For the feeders listed on the 2014 Adjusted report none were present on last year's report.

The initial review of the reports showed that in all cases, the associated feeder problems were corrected at the time of the outage. In the case of East Bay 5542, which appears on both the Actual and Adjusted list for this year, all four outage events occurred in the same day as a result of one lightning strike. The line received lightning strike damage to both the wire and an insulator. There was an outage in the morning for 72 minutes on the damaged phase to make immediate repairs to the system. Later, the DCC operated all three phases of the breaker for approximately 5 minutes to restore the system to normal. The same day, the line was isolated again for 68 minutes to make additional permanent repairs and was operated one last time for 6 minutes to return the system to normal.

Additional reviews of the feeders will be conducted to determine if there are any specific improvements that need to be made to improve overall performance.

15.9.2.2 Identification and Selection/Process Improvements

Gulf continues to focus its process improvement efforts on the system wide top outage causes through its existing programs and storm hardening efforts.

15.9.2.3 2014 Activities and Budget Allowances

Please see the response to Section 15.9.1.3 for 2014 activities and budget allowances.

15.9.3 Regional Reliability Indices

15.9.3.1 Five-Year Patterns

Please see tables given in Section 15.9.1.1.

15.9.3.2 Identification and Selection/Process Improvements

Gulf continues to focus its process improvement efforts on the system wide top outage causes through its existing programs and storm hardening efforts.

15.9.3.3 2014 Activities and Budget Allowances

Please see the response to 15.9.1.3 for 2014 Activities and Budget allowances.

15.10 Overhead – Underground Reliability

15.10.1 Five-Year Patterns

NOTE: % Change is from one year to the next.

System	Overhead						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	2,672	2,207	2,097	2,539	2,030	2,296
	% Change	7%	-17%	-5%	21%	-20%	13%
Eastern	N	1,739	1,667	1,521	1,718	1,851	1,748
	% Change	-9%	-4%	-9%	13%	8%	-6%
Western	N	5,840	5,412	5,019	5,594	5,042	4,146
	% Change	-2%	-7%	-7%	11%	-10%	-18%
Company	N	10,251	9,288	8,637	9,851	8,923	8,190
	% Change	-1%	-9%	-7%	14%	-9%	-8%

System	Underground						
Region	Data	2009	2010	2011	2012	2013	2014
Central	N	312	288	274	281	278	207
	% Change	-3%	-8%	-5%	3%	-1%	-26%
Eastern	N	225	244	232	264	236	213
	% Change	3%	8%	-5%	14%	-11%	-10%
Western	N	454	517	446	554	494	387
	% Change	-12%	14%	-14%	24%	-11%	-22%
Company	N	991	1,049	952	1,009	1,008	807
	% Change	-6%	6%	-9%	6%	0%	-20%

System	Overhead						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	92.25	107.84	81.89	189.14	98.28	202.09
	% Change	7%	17%	-24%	131%	-48%	106%
Eastern	SAIDI	121.90	121.73	97.16	133.90	199.22	120.06
	% Change	-8%	0%	-20.00%	38%	49%	-40%
Western	SAIDI	148.13	157.26	115.31	191.25	146.23	122.91
	% Change	8%	6%	-27%	66%	-24%	-16%
Company	SAIDI	127.10	135.49	102.05	176.93	147.60	140.95
	% Change	4%	7%	-25%	73%	-17%	-5%

System	Underground						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIDI	14.38	7.45	8.02	19.82	22.14	18.51
	% Change	10%	-48%	8%	147%	12%	-16%
Eastern	SAIDI	18.18	11.67	13.13	34.96	23.47	18.66
	% Change	134%	-36%	13%	166%	-33%	-20%
Western	SAIDI	9.34	10.76	8.18	24.44	25.31	15.42
	% Change	0%	15%	-24%	199%	4%	-39%
Company	SAIDI	12.91	10.15	9.41	26.04	23.87	17.23
	% Change	31%	-21%	-7%	177%	-8%	-28%

System	Overhead						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.999	1.522	1.036	2.054	1.358	1.939
	% Change	-2%	52%	-32%	98%	-34%	43%
Eastern	SAIFI	1.135	1.573	1.241	1.537	2.165	1.371
	% Change	4%	39%	-21%	24%	41%	-37%
Western	SAIFI	1.542	1.814	1.256	1.963	1.757	1.472
	% Change	10%	18%	-31%	56%	-10%	-16%
Company	SAIFI	1.298	1.677	1.195	1.882	1.761	1.558
	% Change	6%	29%	-29%	57%	-6%	-12%

System	Underground						
Region	Data	2009	2010	2011	2012	2013	2014
Central	SAIFI	0.082	0.055	0.05	0.143	0.154	0.111
	% Change	-34%	-33%	-9%	186%	7%	-28%
Eastern	SAIFI	0.066	0.603	0.068	0.214	0.176	0.107
	% Change	71%	814%	-89%	215%	-18%	-39%
Western	SAIFI	0.047	0.068	0.045	0.143	0.142	0.080
	% Change	9%	45%	-34%	218%	0%	-44%
Company	SAIFI	0.061	0.064	0.052	0.163	0.155	0.097
	% Change	-3%	5%	-19%	213%	-5%	-38%

15.10.2 Identification and Selection/Process Improvements

Gulf continues to focus its process improvement efforts on the top outage causes system wide through its existing programs and storm hardening efforts.

15.10.3 2014 Activities and Budget Allowances

Please see Section 10.0.

15.10.4 Overhead (OH) and Underground (UG) Metrics

Please see Appendix 3 for specific feeder data for Gulf's overhead and underground lines.

The tables below represent reliability metrics for Gulf's overhead and underground system for 2014.

SYSTEM	REGION	Miles	Customers	N	Duration	CMI	CI
Overhead	CENTRAL	1,151	60,331	2,296	256,538	12,192,235	116,981
	EASTERN	1,539	61,291	1,748	189,268	7,358,589	84,035
	WESTERN	3,168	133,478	4,146	448,568	16,406,178	196,438
	SYSTEM	5,859	255,100	8,190	894,374	35,957,002	397,454
Underground	CENTRAL	438	52,156	207	40,506	965,353	5,794
	EASTERN	462	50,162	213	29,641	936,223	5,356
	WESTERN	955	76,342	387	76,896	1,177,405	6,114
	SYSTEM	1,854	178,659	807	147,043	3,078,981	17,264

SYSTEM	REGION	SAIDI	SAIFI	SAIDI / mile	L-Bar	CI / N	CAIDI
Overhead	CENTRAL	202.09	1.939	0.18	111.73	50.9	104.22
	EASTERN	120.06	1.371	0.08	108.28	48.1	87.57
	WESTERN	122.91	1.472	0.04	108.19	47.4	83.52
	SYSTEM	140.95	1.558	0.02	109.20	48.5	90.47
Underground	CENTRAL	18.51	0.111	0.04	195.68	28.0	166.61
	EASTERN	18.66	0.107	0.04	139.16	25.1	174.80
	WESTERN	15.42	0.080	0.02	198.70	15.8	192.58
	SYSTEM	17.23	0.097	0.01	182.21	21.4	178.35

Note: Total Customers above are from Gulf's Trouble Call Management System, which does not include non-metered accounts.

A review of the above data continues to reinforce observations made in previous Reliability Reports. The new construction growth of Gulf's underground distribution facilities continues to outpace overhead construction due to customer demand based on aesthetics. However, continued analysis of the available overhead and underground data along with associated metrics does not support the use of underground construction as a storm hardening option at this time.


15.11 Reliability Related Customer Complaints

15.11.1 Five-Year Patterns

Gulf Power management reviews a monthly report which supplies data on FPSC complaints and inquiries. Gulf Power's complaint activity as reflected in the FPSC Consumer Activity Report has remained at very low levels.

The graph below, based on the FPSC Consumer Activity Report, is provided to illustrate Gulf Power's customer complaint trend. The numbers represent Reliability Related Service Complaints that meet the FPSC Reliability Related Complaint Codes outlined in the January 2015, Reliability Report Meeting. Based on information from the FPSC Complaint Activity Tracking System, Gulf logged 3 complaints in 2014 that met the FPSC Reliability Related Complaint Codes.

Reliability Related Service Complaint History



**Chart based on Service Complaint codes that meet the FPSC Reliability Related Complaint Codes, outlined at the January 2015 Reliability Report Meeting. Codes are not available for the 2002 and 2003 data.*

15.11.2 Correlation of Reliability Related Customer Complaints to Indices

Due to improved reliability and low customer complaint Gulf has not determined that there is a correlation between reliability related customer complaints and the indices, besides the obvious. Management continues to review each complaint as they occur to determine if there are any deficiencies that need to be addressed in order to improve reliability or customer service.

15.11.3 Identification and Selection/Process Improvements

Due to Gulf's very low FPSC Consumer Activity Report complaints and no apparent correlation of reliability-related customer complaints to outage indices, Gulf has not implemented any programs to identify and select systemic actions to improve reliability based on customer complaints. Gulf will continue to review each complaint as they occur to determine if there are any system deficiencies and take corrective actions as needed.

Appendix 1

Form 102 - Actual Data

2014 Distribution Service Reliability Reports – Actual

Service Reliability Indices - Actual Gulf Power Company					
District or Service Area (a)	SAIDI (b)	CAIDI (c)	SAIFI (d)	MAIFle (e)	CEMI5 (f)
Central	183.82	110.43	1.665	3.45	1.69%
Eastern	113.65	89.62	1.268	2.20	1.96%
Western	247.04	146.20	1.690	3.39	2.08%
System Averages	196.54	124.78	1.575	3.10	1.95%

Appendix 1

2014 Distribution Reliability Reports Actual

	CENTRAL		EASTERN		WESTERN		SYSTEM	
SAIDI = System Average Interruption Index								
Total Number of Customer Minutes of Interruption (CMI)	21,021,764	183.82	12,944,077	113.65	53,307,748	247.04	87,273,588	196.54
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
CAIDI = Customer Average Interruption Duration Index								
Total Number of Customer Minutes of Interruption (CMI)	21,021,764	110.43	12,944,077	89.62	53,307,748	146.20	87,273,588	124.78
Total Number of Customer Interruptions (CI)	190,357		144,431		364,624		699,412	
SAIFI = System Average Interruption Frequency Index								
Total Number of Customer Interruptions (CI)	190,357	1.665	144,431	1.268	364,624	1.690	699,412	1.575
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
MAIFI= Momentary Average Interruption Frequency Index								
Total Number of Customer Momentary Interruption Events (CME)	394,607	3.45	250,341	2.20	731,823	3.39	1,376,771	3.10
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
CEMI5 = Customers Experiencing More Interruptions than 5								
Number of Customers Experiencing More Interruptions than 5	1,934	1.69%	2,231	1.96%	4,488	2.08%	8,653	1.95%
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
L-Bar								
Minutes of Interruption							2,238,271	133.12
Total Number of Outages							16,814	

Appendix 1

Causes of Outage Events - Actual			
Gulf Power Company			2014
Cause (a)	Number of Outage Events (N) (b)	Average Duration (L-Bar) (c)	Average Restoration Time (CAIDI) (d)
Animals	2,159	63.74	67.84
Vegetation	1,722	231.91	197.93
Lightning	2,532	236.60	193.63
Other Weather	360	337.40	187.70
Vehicle	290	184.93	135.79
Defective Equipment	2,438	152.83	103.66
Unknown	592	100.33	116.20
All Other Causes	6,721	73.67	62.05
System Totals	16,814	133.12	124.78

Appendix 1

3 Percent Feeder List Actual													
Utility Name: Gulf Power Company												Year: 2014	
Primary Circuit Id. No. or Name (a)	Sub-station Origin (b)	Location (c)	Number of Customers					Outage Events (N) (i)	Avg Duration (L-Bar) (j)	CAIDI (k)	Listed Last Year? (l)	No. of Years in the Last 5 (m)	Corrective Action Completion Date (n)
			Residential (d)	Commercial (e)	Industrial (f)	Other (g)	Total (h)						
6572	Bayou Chico	WESTERN	1,540	328			1,868	5	152	160	N	0	December 2014
8672	Hathaway	EASTERN	2,012	205			2,217	5	86	86	N	0	December 2014
9802	Caryville	EASTERN	145	40			185	5	132	132	N	0	December 2014
5542	East Bay	WESTERN	2,840	206			3,046	4	38	17	Y	1	December 2014
6432	Paxton	CENTRAL	167	45			212	4	40	40	N	0	December 2014
6532	Bayou Chico	WESTERN	1,791	263	1		2,055	4	173	196	N	0	December 2014
8392	Shipyard	EASTERN	1,363	126	1		1,490	4	55	82	N	1	December 2014
8712	Redwood	EASTERN	1,187	246			1,433	4	35	35	N	0	December 2014
7362	Innerarity	WESTERN	1,773	180			1,953	3	100	30	N	0	December 2014
7752	Bayou Marcus	WESTERN	1,947	144			2,091	3	357	359	N	0	December 2014

Appendix 1

Actual Data: Customer Minutes of Interruption (CMI), Customer Interruptions (CI) and Documented Exclusions

2014	Customer Minutes of Interruption (CMI)		Customer Interruptions (CI)	
	Value	% of Actual	Value	% of Actual
Reported Actual Data	87,273,588	100%	699,412	100%
Documented Exclusions				
Planned Service Interruptions	3,750,155	4%	62,650	9%
Named Storm	-	-	-	-
Tornadoes	1,242,299	1%	5,989	1%
Ice on Lines	-	-	-	-
Planned Load Management Events	-	-	-	-
Generation/Transmission Events	6,555,740	8%	104,740	15%
Extreme Weather/Fire (EOC Activation)	36,689,410	42%	111,315	16%
Reported Adjusted Data	39,035,984	45%	414,718	59%

*New chart per the Reliability Report Meeting held January 14, 2015

Appendix 1

Form 103 - Adjusted Data

2014 Distribution Service Reliability Reports – Adjusted

Service Reliability Indices - Adjusted Gulf Power Company					
District or Service Area (a)	SAIDI (b)	CAIDI (c)	SAIFI (d)	MAIFle (e)	CEMI5 (f)
Central	115.05	107.17	1.074	2.81	0.36 %
Eastern	72.83	92.79	0.785	1.94	0.43 %
Western	81.49	86.81	0.939	2.28	0.28 %
System Averages	87.91	94.13	0.934	2.33	0.34 %

Appendix 1

2014 Distribution Reliability Reports - Adjusted

	CENTRAL		EASTERN		WESTERN		SYSTEM	
SAIDI = System Average Interruption Index								
Total Number of Customer Minutes of Interruption (CMI)	13,157,589	115.05	8,294,812	72.83	17,583,583	81.49	39,035,984	87.91
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
CAIDI = Customer Average Interruption Duration Index								
Total Number of Customer Minutes of Interruption (CMI)	13,157,589	107.17	8,294,812	92.79	17,583,583	86.81	39,035,984	94.13
Total Number of Customer Interruptions (CI)	122,775		89,391		202,552		414,718	
SAIFI = System Average Interruption Frequency Index								
Total Number of Customer Interruptions (CI)	122,775	1.074	89,391	0.785	202,552	0.939	414,718	0.934
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
MAIFI= Momentary Average Interruption Frequency Index								
Total Number of Customer Momentary Interruption Events (CME)	321,356	2.81	220,527	1.94	491,777	2.28	1,033,660	2.33
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
CEMI5 = Customers Experiencing More Interruptions than 5								
Number of Customers Experiencing More Interruptions than 5	406	0.36%	485	0.43%	607	0.28%	1,498	0.34%
Total Number of Customers Served (C)	114,363		113,897		215,787		444,047	
L-Bar								
Minutes of Interruption							1,041,417	115.75
Total Number of Outages							8,997	

Appendix 1

Causes of Outage Events - Adjusted			
Gulf Power Company			2014
Cause (a)	Number of Outage Events (N) (b)	Average Duration (L-Bar) (c)	Average Restoration Time (CAIDI) (d)
Animals	2,132	63.69	67.75
Vegetation	1,294	123.39	104.64
Lightning	1,827	135.67	105.48
Other Weather	196	181.32	95.60
Vehicle	289	185.28	135.79
Defective Equipment	2,257	137.66	98.45
Unknown	557	85.95	72.51
All Other Causes	445	113.31	59.29
System Totals	8,997	115.75	94.13

2014 Distribution Service Reliability Reports – Adjusted

6

3 Percent Feeder List - Adjusted													
Utility Name: Gulf Power Company												Year: 2014	
Primary Circuit Id. No. or Name (a)	Sub-station Origin (b)	Location (c)	Number of Customers					Outage Events (N) (i)	Avg Duration (L-Bar) (j)	CAIDI (k)	Listed Last Year? (l)	No. of Years in the Last 5 (m)	Corrective Action Completion Date (n)
			Residential (d)	Commercial (e)	Industrial (f)	Other (g)	Total (h)						
5542	East Bay	WESTERN	2,840	206			3,046	4	38	17	N	0	December 2014
8392	Shipyard	EASTERN	1,363	126	1		1,490	4	55	82	N	0	December 2014
6572	Bayou Chico	WESTERN	1,540	328			1,868	3	53	54	N	0	December 2014
8712	Redwood	EASTERN	1,187	246			1,433	3	38	38	N	0	December 2014
6042	Beach Haven	WESTERN	1,606	138			1,744	2	195	158	N	0	December 2014
6432	Paxton	CENTRAL	167	45			212	2	61	61	N	0	December 2014
6532	Bayou Chico	WESTERN	1,791	263	1		2,055	2	40	44	N	0	December 2014
6742	Brentwood	WESTERN	1,710	78			1,788	2	51	50	N	0	December 2014
7542	Gulf Breeze	WESTERN	283	78			361	2	74	100	N	0	December 2014
8482	Greenwood	EASTERN	200	617			817	2	20	27	N	0	December 2014

Appendix 1

2014 Excluded Transmission Events Resulting in Customer Outages

Outage Event Description	Reason of Exclusion	N	CMI	CI	Duration
Transmission Outages	Transmission Outages	69	6,555,739.97	104,740	4,910.77

Event Code	Date	Reason of Exclusion	CMI	CI	Duration	Causation	Resolution
1017000	1/29/2014	Transmission	107,060	185	579	Major Storm	Manual
1030458	4/7/2014	Transmission	307,610	3,238	95	Failed Equipment	Manual
1030459	4/7/2014	Transmission	206,815	2,177	95	Failed Equipment	Manual
1031692	4/11/2014	Transmission	57,669	1,227	47	Relay Misoperation	Manual
1031694	4/11/2014	Transmission	26,320	560	47	Relay Misoperation	Manual
1032011	4/11/2014	Transmission	50,746	950	53	Relay Misoperation	Manual
1032012	4/11/2014	Transmission	129,660	2,678	48	Relay Misoperation	Manual
1033450	4/15/2014	Transmission	161,172	2,178	74	Animal	Manual
1033448	4/15/2014	Transmission	136,080	3,240	42	Animal	Manual
1037442	4/30/2014	Transmission	1,348,445	2,378	567	April Flood Event	April Flood Event
1038533	4/30/2014	Transmission	410,326	1,185	346	April Flood Event	April Flood Event
1042015	4/30/2014	Transmission	207,383	1,109	187	April Flood Event	April Flood Event
1043391	5/10/2014	Transmission	10,777	829	13	Deterioration	Supervisory
1043392	5/10/2014	Transmission	12,415	955	13	Deterioration	Supervisory
1043395	5/10/2014	Transmission	13,104	1,092	12	Deterioration	Supervisory
1043503	5/10/2014	Transmission	867	3	289	Deterioration	Manual
1045758	5/21/2014	Transmission	61,877	1,065	58	Animal	Manual
1046265	5/25/2014	Transmission	23,650	2,365	10	Lightning	Supervisory
1046267	5/25/2014	Transmission	16,100	1,610	10	Lightning	Supervisory
1046274	5/25/2014	Transmission	19,750	1,975	10	Lightning	Supervisory
1046281	5/25/2014	Transmission	1,830	183	10	Lightning	Supervisory
1046290	5/25/2014	Transmission	4,670	467	10	Lightning	Supervisory
1046279	5/25/2014	Transmission	22,540	805	28	Lightning	Supervisory
1049721	6/9/2014	Transmission	7,174	211	34	Deterioration	Manual
1049724	6/9/2014	Transmission	6,888	205	34	Deterioration	Manual
1051926	6/20/2014	Transmission	1,273	1,061	1	External Utility Trouble	External Utility Trouble
1056302	7/16/2014	Transmission	13,136	1,706	8	Deterioration	Supervisory
1056303	7/16/2014	Transmission	11,303	1,592	7	Deterioration	Supervisory
1056304	7/16/2014	Transmission	8,585	1,585	5	Deterioration	Supervisory
1056722	7/18/2014	Transmission	4,712	2,356	2	Lightning	Supervisory
1056724	7/18/2014	Transmission	1,413	471	3	Lightning	Supervisory
1056738	7/18/2014	Transmission	558	186	3	Lightning	Supervisory
1056718	7/18/2014	Transmission	5,952	1,984	3	Lightning	Supervisory
1056719	7/18/2014	Transmission	4,845	1,615	3	Lightning	Supervisory
1056721	7/18/2014	Transmission	1,616	808	2	Lightning	Supervisory
1058196	7/26/2014	Transmission	13,583	1,705	8	Unknown	Supervisory
1058533	7/27/2014	Transmission	1,025	212	5	External Utility Trouble	External Utility Trouble
1058534	7/27/2014	Transmission	1,001	207	5	External Utility Trouble	External Utility Trouble
1058536	7/27/2014	Transmission	265	69	4	External Utility Trouble	External Utility Trouble

Appendix 1

2014 Excluded Transmission Events Resulting in Customer Outages

1058552	7/27/2014	Transmission	56	18	3	External Utility Trouble	External Utility Trouble
1058693	7/27/2014	Transmission	2,296	328	7	Deterioration	Supervisory
1058644	7/27/2014	Transmission	21,539	3,077	7	Deterioration	Supervisory
1058645	7/27/2014	Transmission	11,788	1,684	7	Deterioration	Supervisory
1058649	7/27/2014	Transmission	17,199	2,457	7	Deterioration	Supervisory
1058650	7/27/2014	Transmission	15,925	2,275	7	Deterioration	Supervisory
1058654	7/27/2014	Transmission	11,487	1,641	7	Deterioration	Supervisory
1058664	7/27/2014	Transmission	20,048	2,864	7	Deterioration	Supervisory
1058669	7/27/2014	Transmission	13,748	1,964	7	Deterioration	Supervisory
1058677	7/27/2014	Transmission	6,202	886	7	Deterioration	Supervisory
1062734	8/16/2014	Transmission	24,213	3,459	7	Unknown	Supervisory
1062786	8/16/2014	Transmission	18,543	2,649	7	Unknown	Supervisory
1066186	9/2/2014	Transmission	40,068	1,431	28	Accidental Trouble	Manual
1066188	9/2/2014	Transmission	124,500	4,150	30	Accidental Trouble	Manual
1070191	9/17/2014	Transmission	23,940	1,710	14	Tree Cut - Public	Supervisory
1070198	9/17/2014	Transmission	10,313	239	43	Tree Cut - Public	Supervisory
1070182	9/17/2014	Transmission	6,402	1,067	6	Tree Cut - Public	Supervisory
1071020	9/22/2014	Transmission	5,324	2,420	2	Animal	Supervisory
1071021	9/22/2014	Transmission	6,051	2,631	2	Animal	Supervisory
1076005	10/19/2014	Transmission	131,617	1,716	77	Deterioration	Manual
1076006	10/19/2014	Transmission	125,446	1,596	79	Deterioration	Manual
1076007	10/19/2014	Transmission	127,201	1,592	80	Deterioration	Manual
1077391	10/28/2014	Transmission	480,480	1,716	280	Animal	Manual
1077392	10/28/2014	Transmission	456,432	1,776	257	Animal	Manual
1077393	10/28/2014	Transmission	408,000	2,125	192	Animal	Manual
1077394	10/28/2014	Transmission	264,344	1,384	191	Animal	Manual
1077398	10/28/2014	Transmission	512,489	2,686	191	Animal	Manual
1080195	11/15/2014	Transmission	33,269	67	497	External Utility Trouble	External Utility Trouble
1083012	11/30/2014	Transmission	127,003	2,746	46	Relay Misoperation	Supervisory
1083013	11/30/2014	Transmission	89,624	1,959	46	Relay Misoperation	Supervisory

Appendix 1

2014 Planned Outages Table

Outage Event Description	Reason of Exclusion	N	CMI	CI	Duration
Planned Outage	Planned Outage	6,178	3,750,155.44	62,650	428,546.21

Event Code	Date	Reason of Exclusion	CMI	CI	Duration
1011031	1/1/2014	Planned Outage	25.18	1	25.18
1011034	1/1/2014	Planned Outage	1.53	1	1.53
1011042	1/1/2014	Planned Outage	10.67	8	1.33
1011061	1/2/2014	Planned Outage	45.48	1	45.48
1011136	1/2/2014	Planned Outage	4,140.00	46	90
1011145	1/2/2014	Planned Outage	353.95	3	117.98
1011159	1/2/2014	Planned Outage	198.20	2	99.1
1011169	1/2/2014	Planned Outage	846.00	9	94
1011217	1/3/2014	Planned Outage	339.45	1	339.45
1011218	1/3/2014	Planned Outage	1,018.20	3	339.4
1011244	1/3/2014	Planned Outage	436.20	6	72.7
1011248	1/3/2014	Planned Outage	300.70	3	100.23
1011251	1/3/2014	Planned Outage	136.30	3	45.43
1011256	1/3/2014	Planned Outage	23.08	1	23.08
1011284	1/3/2014	Planned Outage	125.52	1	125.52
1011332	1/3/2014	Planned Outage	36.87	4	9.22
1011342	1/4/2014	Planned Outage	92.17	5	18.43
1011346	1/4/2014	Planned Outage	3,175.82	89	35.68
1011347	1/4/2014	Planned Outage	1,062.50	30	35.42
1011363	1/4/2014	Planned Outage	50.00	1	50
1011369	1/4/2014	Planned Outage	34.70	6	5.78
1011415	1/5/2014	Planned Outage	345.07	8	43.13
1011425	1/5/2014	Planned Outage	77.23	1	77.23
1011526	1/6/2014	Planned Outage	143.20	6	23.87
1011535	1/6/2014	Planned Outage	70.93	2	35.47
1011536	1/6/2014	Planned Outage	67.25	5	13.45
1011537	1/6/2014	Planned Outage	36.20	2	18.1
1011542	1/6/2014	Planned Outage	129.27	1	129.27
1011549	1/6/2014	Planned Outage	200.03	1	200.03
1011550	1/6/2014	Planned Outage	26.90	2	13.45
1011552	1/6/2014	Planned Outage	53.93	4	13.48
1011558	1/6/2014	Planned Outage	5.47	1	5.47
1011562	1/6/2014	Planned Outage	140.10	1	140.1
1011566	1/6/2014	Planned Outage	111.10	6	18.52
1011569	1/6/2014	Planned Outage	62.53	8	7.82
1011570	1/6/2014	Planned Outage	4.55	1	4.55
1011573	1/6/2014	Planned Outage	7.63	2	3.82
1011577	1/6/2014	Planned Outage	10.07	1	10.07
1011590	1/6/2014	Planned Outage	264.00	4	66
1011593	1/6/2014	Planned Outage	61.25	5	12.25
1011597	1/6/2014	Planned Outage	48.27	2	24.13
1011613	1/6/2014	Planned Outage	17.30	2	8.65

Appendix 1

2014 Planned Outages Table

1011616	1/6/2014	Planned Outage	459.57	17	27.03
1011890	1/7/2014	Planned Outage	98.00	4	24.5
1011918	1/7/2014	Planned Outage	1,913.33	175	10.93
1011961	1/7/2014	Planned Outage	16.08	1	16.08
1011967	1/7/2014	Planned Outage	25.92	1	25.92
1011985	1/7/2014	Planned Outage	51.15	3	17.05
1011987	1/7/2014	Planned Outage	89.42	5	17.88
1011994	1/7/2014	Planned Outage	27.88	1	27.88
1011995	1/7/2014	Planned Outage	25.75	5	5.15
1012003	1/7/2014	Planned Outage	14.08	1	14.08
1012007	1/7/2014	Planned Outage	86.33	5	17.27
1012016	1/7/2014	Planned Outage	38.20	4	9.55
1012019	1/7/2014	Planned Outage	88.73	4	22.18
1012020	1/7/2014	Planned Outage	22.10	1	22.1
1012026	1/7/2014	Planned Outage	53.05	3	17.68
1012028	1/7/2014	Planned Outage	18.95	3	6.32
1012048	1/7/2014	Planned Outage	31.47	2	15.73
1012064	1/7/2014	Planned Outage	12.53	2	6.27
1012078	1/7/2014	Planned Outage	78.93	8	9.87
1012087	1/7/2014	Planned Outage	42.23	2	21.12
1012105	1/7/2014	Planned Outage	116.10	9	12.9
1012106	1/7/2014	Planned Outage	6.40	1	6.4
1012107	1/7/2014	Planned Outage	24.20	3	8.07
1012117	1/7/2014	Planned Outage	62.65	3	20.88
1012120	1/7/2014	Planned Outage	74.07	4	18.52
1012122	1/7/2014	Planned Outage	49.35	3	16.45
1012139	1/7/2014	Planned Outage	55.33	2	27.67
1012149	1/7/2014	Planned Outage	29.27	2	14.63
1012371	1/8/2014	Planned Outage	29.08	1	29.08
1012377	1/8/2014	Planned Outage	51.52	1	51.52
1012380	1/8/2014	Planned Outage	13.43	1	13.43
1012381	1/8/2014	Planned Outage	9.27	1	9.27
1012388	1/8/2014	Planned Outage	1,014.52	29	34.98
1012390	1/8/2014	Planned Outage	20.37	2	10.18
1012393	1/8/2014	Planned Outage	25.00	12	2.08
1012396	1/8/2014	Planned Outage	14.88	1	14.88
1012399	1/8/2014	Planned Outage	503.83	10	50.38
1012413	1/8/2014	Planned Outage	324.42	17	19.08
1012415	1/8/2014	Planned Outage	369.10	3	123.03
1012416	1/8/2014	Planned Outage	12.60	1	12.6
1012419	1/8/2014	Planned Outage	26.12	1	26.12
1012427	1/8/2014	Planned Outage	252.10	6	42.02
1012428	1/8/2014	Planned Outage	42.08	1	42.08
1012435	1/8/2014	Planned Outage	507.60	6	84.6
1012442	1/8/2014	Planned Outage	95.33	4	23.83
1012444	1/8/2014	Planned Outage	27.67	2	13.83
1012446	1/8/2014	Planned Outage	35.30	3	11.77
1012448	1/8/2014	Planned Outage	104.88	7	14.98
1012450	1/8/2014	Planned Outage	358.63	14	25.62

Appendix 1

2014 Planned Outages Table

1012452	1/8/2014	Planned Outage	48.28	1	48.28
1012454	1/8/2014	Planned Outage	255.60	4	63.9
1012456	1/8/2014	Planned Outage	38.88	1	38.88
1012459	1/8/2014	Planned Outage	89.50	3	29.83
1012460	1/8/2014	Planned Outage	179.20	6	29.87
1012465	1/8/2014	Planned Outage	10.95	1	10.95
1012469	1/8/2014	Planned Outage	88.90	3	29.63
1012472	1/8/2014	Planned Outage	179.47	2	89.73
1012476	1/8/2014	Planned Outage	400.40	6	66.73
1012483	1/8/2014	Planned Outage	5.40	1	5.4
1012511	1/9/2014	Planned Outage	371.40	2	185.7
1012522	1/9/2014	Planned Outage	7,278.60	42	173.3
1012523	1/9/2014	Planned Outage	84.35	1	84.35
1012524	1/9/2014	Planned Outage	140.35	3	46.78
1012527	1/9/2014	Planned Outage	656.45	3	218.82
1012534	1/9/2014	Planned Outage	122.12	1	122.12
1012537	1/9/2014	Planned Outage	441.17	5	88.23
1012538	1/9/2014	Planned Outage	516.20	3	172.07
1012542	1/9/2014	Planned Outage	46.30	2	23.15
1012594	1/9/2014	Planned Outage	32,977.67	190	173.57
1012596	1/9/2014	Planned Outage	299.05	3	99.68
1012608	1/10/2014	Planned Outage	12.67	5	2.53
1012609	1/10/2014	Planned Outage	63.17	1	63.17
1012610	1/10/2014	Planned Outage	199.53	2	99.77
1012614	1/10/2014	Planned Outage	53.00	1	53
1012618	1/10/2014	Planned Outage	190.70	6	31.78
1012619	1/10/2014	Planned Outage	114.10	3	38.03
1012620	1/10/2014	Planned Outage	162.30	3	54.1
1012630	1/10/2014	Planned Outage	84.00	3	28
1012637	1/10/2014	Planned Outage	583.50	30	19.45
1012640	1/10/2014	Planned Outage	491.75	3	163.92
1012645	1/10/2014	Planned Outage	741.00	36	20.58
1013002	1/11/2014	Planned Outage	24.42	1	24.42
1013077	1/13/2014	Planned Outage	360.00	4	90
1013078	1/13/2014	Planned Outage	38.70	6	6.45
1013079	1/13/2014	Planned Outage	7.27	1	7.27
1013080	1/13/2014	Planned Outage	95.72	1	95.72
1013083	1/13/2014	Planned Outage	1,181.33	8	147.67
1013085	1/13/2014	Planned Outage	335.65	21	15.98
1013086	1/13/2014	Planned Outage	143.00	1	143
1013088	1/13/2014	Planned Outage	52.40	1	52.4
1013090	1/13/2014	Planned Outage	40.10	2	20.05
1013091	1/13/2014	Planned Outage	29.85	3	9.95
1013094	1/13/2014	Planned Outage	401.40	4	100.35
1013096	1/13/2014	Planned Outage	283.90	3	94.63
1013098	1/13/2014	Planned Outage	18.03	1	18.03
1013099	1/13/2014	Planned Outage	864.13	8	108.02
1013100	1/13/2014	Planned Outage	13.72	1	13.72
1013104	1/13/2014	Planned Outage	101.07	1	101.07

Appendix 1

2014 Planned Outages Table

1013105	1/13/2014	Planned Outage	441.30	9	49.03
1013114	1/13/2014	Planned Outage	453.63	62	7.32
1013119	1/13/2014	Planned Outage	159.10	3	53.03
1013162	1/13/2014	Planned Outage	52.13	4	13.03
1013298	1/14/2014	Planned Outage	479.78	11	43.62
1013303	1/14/2014	Planned Outage	16.77	1	16.77
1013304	1/14/2014	Planned Outage	307.85	3	102.62
1013305	1/14/2014	Planned Outage	368.00	1	368
1013308	1/14/2014	Planned Outage	488.40	4	122.1
1013317	1/14/2014	Planned Outage	52.00	2	26
1013318	1/14/2014	Planned Outage	3,327.33	14	237.67
1013329	1/14/2014	Planned Outage	30.00	2	15
1013331	1/14/2014	Planned Outage	452.00	4	113
1013335	1/14/2014	Planned Outage	154.40	1	154.4
1013336	1/14/2014	Planned Outage	741.20	3	247.07
1013341	1/14/2014	Planned Outage	83.72	1	83.72
1013342	1/14/2014	Planned Outage	22.47	2	11.23
1013344	1/14/2014	Planned Outage	297.00	1	297
1013346	1/14/2014	Planned Outage	217.00	1	217
1013349	1/14/2014	Planned Outage	14.45	1	14.45
1013358	1/14/2014	Planned Outage	162.60	2	81.3
1013363	1/14/2014	Planned Outage	8.23	1	8.23
1013371	1/14/2014	Planned Outage	14.78	1	14.78
1013374	1/14/2014	Planned Outage	14.00	1	14
1013379	1/14/2014	Planned Outage	308.10	3	102.7
1013382	1/14/2014	Planned Outage	307.13	2	153.57
1013385	1/14/2014	Planned Outage	869.25	9	96.58
1013386	1/14/2014	Planned Outage	21.18	1	21.18
1013389	1/14/2014	Planned Outage	424.00	3	141.33
1013391	1/14/2014	Planned Outage	284.07	4	71.02
1013417	1/14/2014	Planned Outage	125.15	1	125.15
1013423	1/14/2014	Planned Outage	141.55	3	47.18
1013424	1/14/2014	Planned Outage	248.00	2	124
1013427	1/14/2014	Planned Outage	50.42	5	10.08
1013428	1/14/2014	Planned Outage	255.00	3	85
1013452	1/14/2014	Planned Outage	20.03	1	20.03
1013462	1/14/2014	Planned Outage	219.73	1	219.73
1013467	1/15/2014	Planned Outage	2,146.00	2146	1
1013511	1/15/2014	Planned Outage	57.73	2	28.87
1013513	1/15/2014	Planned Outage	286.00	1	286
1013515	1/15/2014	Planned Outage	1,227.53	4	306.88
1013522	1/15/2014	Planned Outage	2,482.08	37	67.08
1013523	1/15/2014	Planned Outage	2,359.58	35	67.42
1013526	1/15/2014	Planned Outage	110.78	1	110.78
1013531	1/15/2014	Planned Outage	555.00	5	111
1013532	1/15/2014	Planned Outage	227.10	1	227.1
1013537	1/15/2014	Planned Outage	784.93	7	112.13
1013538	1/15/2014	Planned Outage	442.27	4	110.57
1013544	1/15/2014	Planned Outage	101.53	1	101.53

Appendix 1

2014 Planned Outages Table

1013545	1/15/2014	Planned Outage	378.10	38	9.95
1013547	1/15/2014	Planned Outage	115.00	1	115
1013554	1/15/2014	Planned Outage	94.35	3	31.45
1013555	1/15/2014	Planned Outage	117.67	1	117.67
1013563	1/15/2014	Planned Outage	169.40	7	24.2
1013564	1/15/2014	Planned Outage	240.00	4	60
1013567	1/15/2014	Planned Outage	429.20	2	214.6
1013568	1/15/2014	Planned Outage	86.00	1	86
1013570	1/15/2014	Planned Outage	53.67	4	13.42
1013576	1/15/2014	Planned Outage	673.07	2	336.53
1013577	1/15/2014	Planned Outage	119.20	3	39.73
1013584	1/15/2014	Planned Outage	60.70	1	60.7
1013585	1/15/2014	Planned Outage	122.23	1	122.23
1013587	1/15/2014	Planned Outage	119.82	1	119.82
1013599	1/15/2014	Planned Outage	54.47	4	13.62
1013602	1/15/2014	Planned Outage	412.85	3	137.62
1013608	1/15/2014	Planned Outage	165.92	11	15.08
1013616	1/16/2014	Planned Outage	1,849.98	7	264.28
1013618	1/16/2014	Planned Outage	477.40	3	159.13
1013631	1/16/2014	Planned Outage	87.30	3	29.1
1013636	1/16/2014	Planned Outage	322.00	7	46
1013641	1/16/2014	Planned Outage	67.12	1	67.12
1013643	1/16/2014	Planned Outage	18.82	1	18.82
1013644	1/16/2014	Planned Outage	30.20	1	30.2
1013645	1/16/2014	Planned Outage	281.42	5	56.28
1013646	1/16/2014	Planned Outage	1,742.22	17	102.48
1013651	1/16/2014	Planned Outage	125.52	1	125.52
1013652	1/16/2014	Planned Outage	248.60	2	124.3
1013653	1/16/2014	Planned Outage	159.90	3	53.3
1013654	1/16/2014	Planned Outage	340.00	4	85
1013669	1/16/2014	Planned Outage	65.53	4	16.38
1013670	1/16/2014	Planned Outage	65.58	1	65.58
1013674	1/16/2014	Planned Outage	11.50	1	11.5
1013681	1/16/2014	Planned Outage	32.97	1	32.97
1013687	1/16/2014	Planned Outage	46.50	10	4.65
1013696	1/16/2014	Planned Outage	168.03	2	84.02
1013697	1/16/2014	Planned Outage	464.40	18	25.8
1013703	1/16/2014	Planned Outage	128.43	2	64.22
1013716	1/16/2014	Planned Outage	74.50	5	14.9
1013733	1/17/2014	Planned Outage	2,562.15	9	284.68
1013736	1/17/2014	Planned Outage	37.67	4	9.42
1013737	1/17/2014	Planned Outage	5,665.07	188	30.13
1013741	1/17/2014	Planned Outage	134.90	6	22.48
1013742	1/17/2014	Planned Outage	329.43	2	164.72
1013743	1/17/2014	Planned Outage	657.20	4	164.3
1013745	1/17/2014	Planned Outage	608.27	4	152.07
1013751	1/17/2014	Planned Outage	59.07	4	14.77
1013753	1/17/2014	Planned Outage	183.43	2	91.72
1013762	1/17/2014	Planned Outage	55.43	2	27.72

Appendix 1

2014 Planned Outages Table

1013763	1/17/2014	Planned Outage	102.20	1	102.2
1013766	1/17/2014	Planned Outage	14,796.00	137	108
1013780	1/17/2014	Planned Outage	18.20	1	18.2
1013784	1/17/2014	Planned Outage	22.23	1	22.23
1013785	1/17/2014	Planned Outage	21.13	1	21.13
1013865	1/18/2014	Planned Outage	106.45	1	106.45
1013866	1/18/2014	Planned Outage	102.13	1	102.13
1013869	1/18/2014	Planned Outage	116.17	10	11.62
1013887	1/18/2014	Planned Outage	120.72	1	120.72
1013889	1/19/2014	Planned Outage	98.53	2	49.27
1013930	1/19/2014	Planned Outage	19.63	1	19.63
1013996	1/21/2014	Planned Outage	1,138.90	7	162.7
1014000	1/21/2014	Planned Outage	81.00	3	27
1014003	1/21/2014	Planned Outage	180.83	14	12.92
1014005	1/21/2014	Planned Outage	540.73	4	135.18
1014006	1/21/2014	Planned Outage	106.67	5	21.33
1014007	1/21/2014	Planned Outage	5,668.30	11	515.3
1014011	1/21/2014	Planned Outage	88.15	1	88.15
1014012	1/21/2014	Planned Outage	175.33	2	87.67
1014015	1/21/2014	Planned Outage	91.10	1	91.1
1014016	1/21/2014	Planned Outage	90.95	1	90.95
1014019	1/21/2014	Planned Outage	203.07	2	101.53
1014022	1/21/2014	Planned Outage	18.63	1	18.63
1014025	1/21/2014	Planned Outage	100.45	3	33.48
1014029	1/21/2014	Planned Outage	13.00	1	13
1014030	1/21/2014	Planned Outage	46.28	1	46.28
1014031	1/21/2014	Planned Outage	67.27	4	16.82
1014033	1/21/2014	Planned Outage	40.62	1	40.62
1014034	1/21/2014	Planned Outage	162.47	4	40.62
1014037	1/21/2014	Planned Outage	40.27	1	40.27
1014044	1/21/2014	Planned Outage	2,403.47	16	150.22
1014050	1/21/2014	Planned Outage	225.00	5	45
1014064	1/21/2014	Planned Outage	169.53	4	42.38
1014071	1/21/2014	Planned Outage	86.47	4	21.62
1014075	1/21/2014	Planned Outage	18.30	1	18.3
1014083	1/21/2014	Planned Outage	1,551.60	36	43.1
1014087	1/21/2014	Planned Outage	229.90	2	114.95
1014088	1/21/2014	Planned Outage	800.00	8	100
1014089	1/21/2014	Planned Outage	809.08	5	161.82
1014090	1/21/2014	Planned Outage	2,240.20	23	97.4
1014096	1/21/2014	Planned Outage	166.00	1	166
1014110	1/21/2014	Planned Outage	298.15	1	298.15
1014144	1/22/2014	Planned Outage	667.50	6	111.25
1014146	1/22/2014	Planned Outage	182.00	2	91
1014149	1/22/2014	Planned Outage	77.38	1	77.38
1014150	1/22/2014	Planned Outage	3,136.00	14	224
1014154	1/22/2014	Planned Outage	470.67	5	94.13
1014158	1/22/2014	Planned Outage	729.15	3	243.05
1014159	1/22/2014	Planned Outage	23.48	1	23.48

Appendix 1

2014 Planned Outages Table

1014161	1/22/2014	Planned Outage	92.40	3	30.8
1014163	1/22/2014	Planned Outage	84.00	4	21
1014165	1/22/2014	Planned Outage	58.00	1	58
1014170	1/22/2014	Planned Outage	16.38	1	16.38
1014171	1/22/2014	Planned Outage	68.00	2	34
1014172	1/22/2014	Planned Outage	410.48	11	37.32
1014173	1/22/2014	Planned Outage	320.97	2	160.48
1014174	1/22/2014	Planned Outage	125.50	10	12.55
1014177	1/22/2014	Planned Outage	596.70	17	35.1
1014180	1/22/2014	Planned Outage	1,265.40	74	17.1
1014190	1/22/2014	Planned Outage	787.15	7	112.45
1014193	1/22/2014	Planned Outage	60.00	2	30
1014194	1/22/2014	Planned Outage	101.80	3	33.93
1014202	1/22/2014	Planned Outage	76.70	1	76.7
1014206	1/22/2014	Planned Outage	562.83	5	112.57
1014211	1/22/2014	Planned Outage	26.67	1	26.67
1014274	1/23/2014	Planned Outage	143.90	3	47.97
1014277	1/23/2014	Planned Outage	1,110.20	7	158.6
1014278	1/23/2014	Planned Outage	1,413.00	9	157
1014286	1/23/2014	Planned Outage	197.00	1	197
1014287	1/23/2014	Planned Outage	645.00	3	215
1014295	1/23/2014	Planned Outage	13.67	1	13.67
1014299	1/23/2014	Planned Outage	153.00	3	51
1014301	1/23/2014	Planned Outage	1,005.40	4	251.35
1014304	1/23/2014	Planned Outage	90.00	6	15
1014305	1/23/2014	Planned Outage	188.90	2	94.45
1014306	1/23/2014	Planned Outage	31.00	1	31
1014311	1/23/2014	Planned Outage	31.38	1	31.38
1014314	1/23/2014	Planned Outage	430.70	6	71.78
1014317	1/23/2014	Planned Outage	255.10	2	127.55
1014318	1/23/2014	Planned Outage	125.60	1	125.6
1014323	1/23/2014	Planned Outage	128.58	5	25.72
1014324	1/23/2014	Planned Outage	7,448.00	38	196
1014326	1/23/2014	Planned Outage	72.00	2	36
1014330	1/23/2014	Planned Outage	142.30	2	71.15
1014331	1/23/2014	Planned Outage	132.00	4	33
1014335	1/23/2014	Planned Outage	20.30	2	10.15
1014337	1/23/2014	Planned Outage	294.00	7	42
1014338	1/23/2014	Planned Outage	56.00	2	28
1014341	1/23/2014	Planned Outage	1,668.00	10	166.8
1014343	1/23/2014	Planned Outage	153.63	2	76.82
1014346	1/23/2014	Planned Outage	45.47	2	22.73
1014347	1/23/2014	Planned Outage	72.00	3	24
1014350	1/23/2014	Planned Outage	691.83	5	138.37
1014355	1/23/2014	Planned Outage	60.73	2	30.37
1014357	1/23/2014	Planned Outage	798.00	21	38
1014362	1/23/2014	Planned Outage	20.00	1	20
1014363	1/23/2014	Planned Outage	54.00	3	18
1014365	1/23/2014	Planned Outage	47.73	2	23.87

Appendix 1

2014 Planned Outages Table

1014367	1/23/2014	Planned Outage	66.33	2	33.17
1014370	1/23/2014	Planned Outage	46.00	1	46
1014373	1/23/2014	Planned Outage	37.13	2	18.57
1014374	1/23/2014	Planned Outage	240.00	4	60
1014391	1/24/2014	Planned Outage	3,270.67	16	204.42
1014400	1/24/2014	Planned Outage	95.32	1	95.32
1014410	1/24/2014	Planned Outage	215.67	1	215.67
1014411	1/24/2014	Planned Outage	215.02	1	215.02
1014414	1/24/2014	Planned Outage	12.63	2	6.32
1014415	1/24/2014	Planned Outage	23.27	4	5.82
1014420	1/24/2014	Planned Outage	173.50	5	34.7
1014421	1/24/2014	Planned Outage	28.07	1	28.07
1014422	1/24/2014	Planned Outage	75.83	5	15.17
1014424	1/24/2014	Planned Outage	26.05	1	26.05
1014425	1/24/2014	Planned Outage	53.80	1	53.8
1014428	1/24/2014	Planned Outage	22.08	1	22.08
1014433	1/24/2014	Planned Outage	32.00	1	32
1014434	1/24/2014	Planned Outage	114.92	1	114.92
1014436	1/24/2014	Planned Outage	677.20	8	84.65
1014445	1/24/2014	Planned Outage	6,591.90	219	30.1
1014452	1/24/2014	Planned Outage	24.67	2	12.33
1014459	1/24/2014	Planned Outage	317.33	4	79.33
1014476	1/24/2014	Planned Outage	35.17	5	7.03
1014482	1/24/2014	Planned Outage	73.53	4	18.38
1014527	1/25/2014	Planned Outage	38.57	1	38.57
1014618	1/27/2014	Planned Outage	28.65	1	28.65
1014620	1/27/2014	Planned Outage	4,381.83	61	71.83
1014621	1/27/2014	Planned Outage	247.10	3	82.37
1014622	1/27/2014	Planned Outage	177.55	3	59.18
1014623	1/27/2014	Planned Outage	147.20	2	73.6
1014626	1/27/2014	Planned Outage	497.40	9	55.27
1014627	1/27/2014	Planned Outage	220.27	4	55.07
1014629	1/27/2014	Planned Outage	2,850.83	11	259.17
1014630	1/27/2014	Planned Outage	44.63	1	44.63
1014640	1/27/2014	Planned Outage	267.75	5	53.55
1014647	1/27/2014	Planned Outage	292.75	3	97.58
1014656	1/27/2014	Planned Outage	185.37	2	92.68
1014658	1/27/2014	Planned Outage	202.27	4	50.57
1014659	1/27/2014	Planned Outage	87.83	1	87.83
1014660	1/27/2014	Planned Outage	2,354.92	11	214.08
1014665	1/27/2014	Planned Outage	146.20	3	48.73
1014677	1/27/2014	Planned Outage	94.27	2	47.13
1014701	1/28/2014	Planned Outage	5.32	1	5.32
1014710	1/28/2014	Planned Outage	53.75	3	17.92
1014713	1/28/2014	Planned Outage	2,123.12	13	163.32
1014720	1/28/2014	Planned Outage	159.48	7	22.78
1014722	1/28/2014	Planned Outage	19.90	2	9.95
1014726	1/28/2014	Planned Outage	98.72	1	98.72
1014728	1/28/2014	Planned Outage	241.15	7	34.45

Appendix 1

2014 Planned Outages Table

1014739	1/28/2014	Planned Outage	47.60	4	11.9
1017536	1/29/2014	Planned Outage	101,530.23	278	365.22
1017559	1/29/2014	Planned Outage	227.65	3	75.88
1017619	1/29/2014	Planned Outage	35.10	3	11.7
1017696	1/29/2014	Planned Outage	51.45	7	7.35
1017776	1/29/2014	Planned Outage	1,914.30	54	35.45
1017795	1/29/2014	Planned Outage	73.10	2	36.55
1017843	1/29/2014	Planned Outage	2.65	1	2.65
1017901	1/29/2014	Planned Outage	4,564.57	74	61.68
1017903	1/29/2014	Planned Outage	2,581.73	68	37.97
1017931	1/29/2014	Planned Outage	1,407.00	63	22.33
1017982	1/30/2014	Planned Outage	668.67	17	39.33
1018027	1/30/2014	Planned Outage	10.58	5	2.12
1018126	1/30/2014	Planned Outage	253.53	4	63.38
1018137	1/30/2014	Planned Outage	1,116.00	3	372
1018141	1/30/2014	Planned Outage	42.30	1	42.3
1018151	1/30/2014	Planned Outage	17.68	1	17.68
1018227	1/30/2014	Planned Outage	74.95	3	24.98
1018282	1/31/2014	Planned Outage	126.93	8	15.87
1018289	1/31/2014	Planned Outage	40.70	3	13.57
1018290	1/31/2014	Planned Outage	139.50	5	27.9
1018296	1/31/2014	Planned Outage	25.40	1	25.4
1018301	1/31/2014	Planned Outage	44.98	1	44.98
1018302	1/31/2014	Planned Outage	26.70	2	13.35
1018304	1/31/2014	Planned Outage	97.70	3	32.57
1018307	1/31/2014	Planned Outage	3.30	2	1.65
1018313	1/31/2014	Planned Outage	236.25	1	236.25
1018328	1/31/2014	Planned Outage	34.23	1	34.23
1018339	1/31/2014	Planned Outage	139.93	4	34.98
1018341	1/31/2014	Planned Outage	215.25	7	30.75
1018421	2/1/2014	Planned Outage	129.00	10	12.9
1018477	2/1/2014	Planned Outage	93.60	9	10.4
1018545	2/3/2014	Planned Outage	125.00	4	31.25
1018552	2/3/2014	Planned Outage	337.65	9	37.52
1018554	2/3/2014	Planned Outage	45.07	4	11.27
1018556	2/3/2014	Planned Outage	1,417.08	19	74.58
1018559	2/3/2014	Planned Outage	263.73	2	131.87
1018561	2/3/2014	Planned Outage	30.07	1	30.07
1018564	2/3/2014	Planned Outage	839.85	11	76.35
1018568	2/3/2014	Planned Outage	899.92	5	179.98
1018569	2/3/2014	Planned Outage	228.00	2	114
1018575	2/3/2014	Planned Outage	15.60	1	15.6
1018583	2/3/2014	Planned Outage	16.88	1	16.88
1018590	2/3/2014	Planned Outage	853.33	8	106.67
1018600	2/3/2014	Planned Outage	58.13	2	29.07
1018602	2/3/2014	Planned Outage	104.27	4	26.07
1018603	2/3/2014	Planned Outage	153.27	4	38.32
1018604	2/3/2014	Planned Outage	11.52	1	11.52
1018609	2/3/2014	Planned Outage	147.07	2	73.53

Appendix 1

2014 Planned Outages Table

1018612	2/3/2014	Planned Outage	472.20	3	157.4
1018617	2/3/2014	Planned Outage	149.33	2	74.67
1018618	2/3/2014	Planned Outage	20.00	2	10
1018630	2/3/2014	Planned Outage	906.80	8	113.35
1018643	2/3/2014	Planned Outage	150.47	2	75.23
1018652	2/3/2014	Planned Outage	51.67	5	10.33
1018658	2/3/2014	Planned Outage	20.78	1	20.78
1018674	2/4/2014	Planned Outage	3.50	2	1.75
1018677	2/4/2014	Planned Outage	1,466.40	8	183.3
1018679	2/4/2014	Planned Outage	16.32	1	16.32
1018680	2/4/2014	Planned Outage	137.48	1	137.48
1018682	2/4/2014	Planned Outage	515.67	4	128.92
1018683	2/4/2014	Planned Outage	13.72	1	13.72
1018684	2/4/2014	Planned Outage	185.60	3	61.87
1018685	2/4/2014	Planned Outage	95.87	4	23.97
1018686	2/4/2014	Planned Outage	213.10	3	71.03
1018688	2/4/2014	Planned Outage	290.23	1	290.23
1018690	2/4/2014	Planned Outage	302.63	2	151.32
1018693	2/4/2014	Planned Outage	66.70	6	11.12
1018694	2/4/2014	Planned Outage	503.53	26	19.37
1018695	2/4/2014	Planned Outage	21.08	1	21.08
1018696	2/4/2014	Planned Outage	922.83	5	184.57
1018697	2/4/2014	Planned Outage	1,921.62	13	147.82
1018699	2/4/2014	Planned Outage	1,067.50	10	106.75
1018700	2/4/2014	Planned Outage	155.60	4	38.9
1018702	2/4/2014	Planned Outage	1,778.40	19	93.6
1018704	2/4/2014	Planned Outage	35.45	3	11.82
1018706	2/4/2014	Planned Outage	21.53	1	21.53
1018710	2/4/2014	Planned Outage	268.05	1	268.05
1018712	2/4/2014	Planned Outage	136.75	3	45.58
1018713	2/4/2014	Planned Outage	6.72	1	6.72
1018714	2/4/2014	Planned Outage	125.35	1	125.35
1018716	2/4/2014	Planned Outage	22.08	1	22.08
1018717	2/4/2014	Planned Outage	26.70	3	8.9
1018721	2/4/2014	Planned Outage	5,175.65	51	101.48
1018723	2/4/2014	Planned Outage	403.20	9	44.8
1018728	2/4/2014	Planned Outage	93.17	2	46.58
1018730	2/4/2014	Planned Outage	22.73	1	22.73
1018735	2/4/2014	Planned Outage	356.10	3	118.7
1018737	2/4/2014	Planned Outage	26.03	2	13.02
1018739	2/4/2014	Planned Outage	8,819.35	69	127.82
1018741	2/4/2014	Planned Outage	43.47	2	21.73
1018744	2/4/2014	Planned Outage	35.37	1	35.37
1018745	2/4/2014	Planned Outage	11.95	3	3.98
1018748	2/4/2014	Planned Outage	76.55	3	25.52
1018750	2/4/2014	Planned Outage	8.82	1	8.82
1018751	2/4/2014	Planned Outage	25.27	4	6.32
1018752	2/4/2014	Planned Outage	33.70	2	16.85
1018757	2/4/2014	Planned Outage	29.38	1	29.38

Appendix 1

2014 Planned Outages Table

1018762	2/4/2014	Planned Outage	1,042.53	7	148.93
1018765	2/4/2014	Planned Outage	68.25	3	22.75
1018769	2/4/2014	Planned Outage	31.70	1	31.7
1018772	2/4/2014	Planned Outage	799.58	5	159.92
1018774	2/4/2014	Planned Outage	165.35	3	55.12
1018776	2/4/2014	Planned Outage	217.87	2	108.93
1018779	2/4/2014	Planned Outage	190.35	3	63.45
1018783	2/4/2014	Planned Outage	41.00	3	13.67
1018786	2/4/2014	Planned Outage	280.50	3	93.5
1018903	2/5/2014	Planned Outage	21.70	1	21.7
1018904	2/5/2014	Planned Outage	532.93	4	133.23
1018906	2/5/2014	Planned Outage	1,170.10	6	195.02
1018908	2/5/2014	Planned Outage	20.88	1	20.88
1018909	2/5/2014	Planned Outage	335.20	3	111.73
1018910	2/5/2014	Planned Outage	407.20	8	50.9
1018911	2/5/2014	Planned Outage	80.17	2	40.08
1018912	2/5/2014	Planned Outage	151.33	1	151.33
1018913	2/5/2014	Planned Outage	10,203.88	71	143.72
1018915	2/5/2014	Planned Outage	154.07	1	154.07
1018916	2/5/2014	Planned Outage	153.97	1	153.97
1018918	2/5/2014	Planned Outage	71.77	1	71.77
1018922	2/5/2014	Planned Outage	410.33	5	82.07
1018923	2/5/2014	Planned Outage	101.13	2	50.57
1018927	2/5/2014	Planned Outage	147.50	5	29.5
1018929	2/5/2014	Planned Outage	82.30	2	41.15
1018930	2/5/2014	Planned Outage	18.18	1	18.18
1018932	2/5/2014	Planned Outage	17.02	1	17.02
1018934	2/5/2014	Planned Outage	584.47	4	146.12
1018936	2/5/2014	Planned Outage	43.40	1	43.4
1018939	2/5/2014	Planned Outage	260.43	2	130.22
1018941	2/5/2014	Planned Outage	11,841.27	169	70.07
1018948	2/5/2014	Planned Outage	11.10	1	11.1
1018958	2/5/2014	Planned Outage	36.08	1	36.08
1018961	2/5/2014	Planned Outage	700.50	5	140.1
1018964	2/5/2014	Planned Outage	255.00	2	127.5
1018965	2/5/2014	Planned Outage	513.75	5	102.75
1018979	2/5/2014	Planned Outage	68.58	1	68.58
1018995	2/5/2014	Planned Outage	300.10	6	50.02
1019061	2/5/2014	Planned Outage	82.07	1	82.07
1019068	2/6/2014	Planned Outage	127.25	3	42.42
1019069	2/6/2014	Planned Outage	218.65	1	218.65
1019072	2/6/2014	Planned Outage	199.58	1	199.58
1019090	2/6/2014	Planned Outage	713.87	4	178.47
1019092	2/6/2014	Planned Outage	90.73	1	90.73
1019095	2/6/2014	Planned Outage	305.37	2	152.68
1019096	2/6/2014	Planned Outage	68.88	1	68.88
1019097	2/6/2014	Planned Outage	21.68	1	21.68
1019098	2/6/2014	Planned Outage	42.35	3	14.12
1019108	2/6/2014	Planned Outage	194.87	2	97.43

Appendix 1

2014 Planned Outages Table

1019116	2/6/2014	Planned Outage	280.33	10	28.03
1019118	2/6/2014	Planned Outage	255.80	3	85.27
1019156	2/6/2014	Planned Outage	79.37	1	79.37
1019171	2/6/2014	Planned Outage	45.27	4	11.32
1019194	2/7/2014	Planned Outage	217.28	1	217.28
1019205	2/7/2014	Planned Outage	144.83	2	72.42
1019207	2/7/2014	Planned Outage	8.40	1	8.4
1019210	2/7/2014	Planned Outage	103.72	1	103.72
1019211	2/7/2014	Planned Outage	94.40	4	23.6
1019216	2/7/2014	Planned Outage	32.73	2	16.37
1019217	2/7/2014	Planned Outage	59.87	2	29.93
1019218	2/7/2014	Planned Outage	34.73	2	17.37
1019219	2/7/2014	Planned Outage	34.27	1	34.27
1019220	2/7/2014	Planned Outage	101.73	2	50.87
1019221	2/7/2014	Planned Outage	83.22	1	83.22
1019236	2/7/2014	Planned Outage	4.70	1	4.7
1019284	2/8/2014	Planned Outage	3.75	1	3.75
1019331	2/9/2014	Planned Outage	2,301.38	11	209.22
1019358	2/9/2014	Planned Outage	305.00	4	76.25
1019368	2/10/2014	Planned Outage	84.75	3	28.25
1019369	2/10/2014	Planned Outage	170.30	2	85.15
1019371	2/10/2014	Planned Outage	84.12	1	84.12
1019372	2/10/2014	Planned Outage	5.45	1	5.45
1019373	2/10/2014	Planned Outage	87.25	5	17.45
1019374	2/10/2014	Planned Outage	64.32	1	64.32
1019375	2/10/2014	Planned Outage	79.65	1	79.65
1019377	2/10/2014	Planned Outage	307.50	6	51.25
1019379	2/10/2014	Planned Outage	306.42	5	61.28
1019381	2/10/2014	Planned Outage	93.63	1	93.63
1019383	2/10/2014	Planned Outage	761.48	7	108.78
1019384	2/10/2014	Planned Outage	31.25	1	31.25
1019385	2/10/2014	Planned Outage	50.33	2	25.17
1019386	2/10/2014	Planned Outage	41.93	1	41.93
1019388	2/10/2014	Planned Outage	430.93	4	107.73
1019389	2/10/2014	Planned Outage	23.33	2	11.67
1019390	2/10/2014	Planned Outage	431.33	4	107.83
1019392	2/10/2014	Planned Outage	94.83	1	94.83
1019394	2/10/2014	Planned Outage	76.57	1	76.57
1019395	2/10/2014	Planned Outage	33.47	2	16.73
1019398	2/10/2014	Planned Outage	50.82	1	50.82
1019399	2/10/2014	Planned Outage	47.22	1	47.22
1019404	2/10/2014	Planned Outage	857.33	10	85.73
1019405	2/10/2014	Planned Outage	852.50	10	85.25
1019419	2/10/2014	Planned Outage	94.20	3	31.4
1019421	2/10/2014	Planned Outage	62.37	1	62.37
1019425	2/10/2014	Planned Outage	136.17	1	136.17
1019507	2/10/2014	Planned Outage	34.33	1	34.33
1019516	2/11/2014	Planned Outage	3,594.55	29	123.95
1019517	2/11/2014	Planned Outage	141.27	2	70.63

Appendix 1

2014 Planned Outages Table

1019522	2/11/2014	Planned Outage	294.00	6	49
1019523	2/11/2014	Planned Outage	17.45	3	5.82
1019526	2/11/2014	Planned Outage	1,375.50	18	76.42
1019608	2/12/2014	Planned Outage	330.28	7	47.18
1019641	2/12/2014	Planned Outage	129.00	3	43
1019643	2/12/2014	Planned Outage	185.85	7	26.55
1019644	2/12/2014	Planned Outage	298.28	11	27.12
1019659	2/12/2014	Planned Outage	108.10	6	18.02
1019664	2/12/2014	Planned Outage	25.92	1	25.92
1019669	2/12/2014	Planned Outage	21.60	1	21.6
1019707	2/13/2014	Planned Outage	293.40	3	97.8
1019716	2/13/2014	Planned Outage	84.30	1	84.3
1019722	2/13/2014	Planned Outage	128.87	4	32.22
1019726	2/13/2014	Planned Outage	144.93	4	36.23
1019729	2/13/2014	Planned Outage	370.17	10	37.02
1019733	2/13/2014	Planned Outage	1,816.73	28	64.88
1019738	2/13/2014	Planned Outage	15.75	1	15.75
1019740	2/13/2014	Planned Outage	192.40	12	16.03
1019742	2/13/2014	Planned Outage	44.52	1	44.52
1019743	2/13/2014	Planned Outage	212.40	4	53.1
1019749	2/13/2014	Planned Outage	14.52	1	14.52
1019750	2/13/2014	Planned Outage	21.20	2	10.6
1019752	2/13/2014	Planned Outage	384.93	4	96.23
1019757	2/13/2014	Planned Outage	106.70	6	17.78
1019763	2/13/2014	Planned Outage	37.53	4	9.38
1019767	2/13/2014	Planned Outage	34.25	1	34.25
1019781	2/13/2014	Planned Outage	165.30	19	8.7
1019789	2/13/2014	Planned Outage	6,029.25	15	401.95
1019849	2/14/2014	Planned Outage	894.83	7	127.83
1019858	2/14/2014	Planned Outage	1,548.00	9	172
1019860	2/14/2014	Planned Outage	1,190.00	7	170
1019862	2/14/2014	Planned Outage	346.23	2	173.12
1019872	2/14/2014	Planned Outage	345.00	5	69
1019873	2/14/2014	Planned Outage	243.00	3	81
1019879	2/14/2014	Planned Outage	1,968.40	57	34.53
1019886	2/14/2014	Planned Outage	326.95	3	108.98
1019894	2/14/2014	Planned Outage	19.00	1	19
1020048	2/15/2014	Planned Outage	3,651.33	8	456.42
1020084	2/15/2014	Planned Outage	10.50	3	3.5
1020186	2/16/2014	Planned Outage	248.45	3	82.82
1020191	2/16/2014	Planned Outage	48.62	1	48.62
1020208	2/17/2014	Planned Outage	197.87	4	49.47
1020210	2/17/2014	Planned Outage	31.73	1	31.73
1020211	2/17/2014	Planned Outage	15.13	1	15.13
1020219	2/17/2014	Planned Outage	133.90	2	66.95
1020221	2/17/2014	Planned Outage	190.00	5	38
1020225	2/17/2014	Planned Outage	455.82	7	65.12
1020226	2/17/2014	Planned Outage	426.07	4	106.52
1020229	2/17/2014	Planned Outage	811.30	6	135.22

Appendix 1

2014 Planned Outages Table

1020237	2/17/2014	Planned Outage	20.22	1	20.22
1020239	2/17/2014	Planned Outage	59.10	3	19.7
1020253	2/17/2014	Planned Outage	21.30	1	21.3
1020254	2/17/2014	Planned Outage	674.30	11	61.3
1020272	2/17/2014	Planned Outage	25.02	1	25.02
1020505	2/18/2014	Planned Outage	69.23	2	34.62
1020521	2/18/2014	Planned Outage	231.67	2	115.83
1020523	2/18/2014	Planned Outage	170.30	2	85.15
1020527	2/18/2014	Planned Outage	239.33	5	47.87
1020528	2/18/2014	Planned Outage	240.17	10	24.02
1020529	2/18/2014	Planned Outage	10.62	1	10.62
1020533	2/18/2014	Planned Outage	476.40	8	59.55
1020535	2/18/2014	Planned Outage	59.68	1	59.68
1020540	2/18/2014	Planned Outage	416.80	8	52.1
1020542	2/18/2014	Planned Outage	156.37	2	78.18
1020543	2/18/2014	Planned Outage	207.00	3	69
1020546	2/18/2014	Planned Outage	41.00	1	41
1020555	2/18/2014	Planned Outage	19.68	1	19.68
1020556	2/18/2014	Planned Outage	356.30	3	118.77
1020559	2/18/2014	Planned Outage	3,259.50	53	61.5
1020561	2/18/2014	Planned Outage	162.75	1	162.75
1020562	2/18/2014	Planned Outage	64.22	1	64.22
1020563	2/18/2014	Planned Outage	127.63	2	63.82
1020570	2/18/2014	Planned Outage	525.93	4	131.48
1020577	2/18/2014	Planned Outage	223.10	2	111.55
1020578	2/18/2014	Planned Outage	131.10	3	43.7
1020580	2/18/2014	Planned Outage	163.57	2	81.78
1020584	2/18/2014	Planned Outage	219.00	15	14.6
1020589	2/18/2014	Planned Outage	16.38	1	16.38
1020601	2/19/2014	Planned Outage	2,233.00	22	101.5
1020696	2/19/2014	Planned Outage	53.30	2	26.65
1020699	2/19/2014	Planned Outage	105.80	3	35.27
1020700	2/19/2014	Planned Outage	58.00	1	58
1020705	2/19/2014	Planned Outage	1,528.10	7	218.3
1020708	2/19/2014	Planned Outage	318.60	4	79.65
1020710	2/19/2014	Planned Outage	6,807.73	112	60.78
1020711	2/19/2014	Planned Outage	30.63	1	30.63
1020713	2/19/2014	Planned Outage	488.00	4	122
1020714	2/19/2014	Planned Outage	137.32	1	137.32
1020715	2/19/2014	Planned Outage	26.67	1	26.67
1020717	2/19/2014	Planned Outage	50.47	2	25.23
1020718	2/19/2014	Planned Outage	279.27	2	139.63
1020723	2/19/2014	Planned Outage	232.75	3	77.58
1020725	2/19/2014	Planned Outage	188.00	2	94
1020726	2/19/2014	Planned Outage	634.67	5	126.93
1020728	2/19/2014	Planned Outage	9,601.20	252	38.1
1020738	2/19/2014	Planned Outage	185.00	2	92.5
1020749	2/19/2014	Planned Outage	79.05	3	26.35
1020757	2/19/2014	Planned Outage	417.93	4	104.48

Appendix 1

2014 Planned Outages Table

1020760	2/19/2014	Planned Outage	417.73	4	104.43
1020765	2/19/2014	Planned Outage	828.00	3	276
1020767	2/19/2014	Planned Outage	174.08	5	34.82
1020771	2/19/2014	Planned Outage	187.70	1	187.7
1020772	2/19/2014	Planned Outage	282.13	16	17.63
1020775	2/19/2014	Planned Outage	161.70	6	26.95
1020778	2/19/2014	Planned Outage	285.43	2	142.72
1020814	2/20/2014	Planned Outage	223.28	1	223.28
1020820	2/20/2014	Planned Outage	88.00	20	4.4
1020827	2/20/2014	Planned Outage	556.00	139	4
1020830	2/20/2014	Planned Outage	364.12	7	52.02
1020833	2/20/2014	Planned Outage	37.43	2	18.72
1020835	2/20/2014	Planned Outage	100.20	1	100.2
1020836	2/20/2014	Planned Outage	43.28	1	43.28
1020838	2/20/2014	Planned Outage	5,150.60	182	28.3
1020849	2/20/2014	Planned Outage	87.65	1	87.65
1020852	2/20/2014	Planned Outage	27.80	6	4.63
1020853	2/20/2014	Planned Outage	17.87	4	4.47
1020855	2/20/2014	Planned Outage	623.25	5	124.65
1020856	2/20/2014	Planned Outage	88.85	3	29.62
1020857	2/20/2014	Planned Outage	86.90	2	43.45
1020859	2/20/2014	Planned Outage	9.30	1	9.3
1020862	2/20/2014	Planned Outage	458.05	3	152.68
1020864	2/20/2014	Planned Outage	83.53	2	41.77
1020865	2/20/2014	Planned Outage	18.10	1	18.1
1020867	2/20/2014	Planned Outage	120.27	1	120.27
1020870	2/20/2014	Planned Outage	11.48	1	11.48
1020871	2/20/2014	Planned Outage	686.13	4	171.53
1020873	2/20/2014	Planned Outage	16,434.60	86	191.1
1020882	2/20/2014	Planned Outage	46.45	1	46.45
1020883	2/20/2014	Planned Outage	46.62	1	46.62
1020884	2/20/2014	Planned Outage	79.63	2	39.82
1020885	2/20/2014	Planned Outage	410.40	3	136.8
1020888	2/20/2014	Planned Outage	68.37	2	34.18
1020925	2/20/2014	Planned Outage	181.95	9	20.22
1021679	2/21/2014	Planned Outage	34.03	1	34.03
1021688	2/21/2014	Planned Outage	24.00	1	24
1021697	2/21/2014	Planned Outage	50.78	1	50.78
1021707	2/21/2014	Planned Outage	30.45	1	30.45
1021723	2/21/2014	Planned Outage	343.40	4	85.85
1021738	2/21/2014	Planned Outage	45.02	1	45.02
1021744	2/21/2014	Planned Outage	70.40	1	70.4
1021754	2/21/2014	Planned Outage	89.27	4	22.32
1021756	2/21/2014	Planned Outage	97.75	5	19.55
1021789	2/21/2014	Planned Outage	76.65	21	3.65
1021792	2/21/2014	Planned Outage	108.60	3	36.2
1021794	2/21/2014	Planned Outage	133.17	1	133.17
1021795	2/21/2014	Planned Outage	399.80	3	133.27
1021798	2/21/2014	Planned Outage	4.92	1	4.92

Appendix 1

2014 Planned Outages Table

1021816	2/22/2014	Planned Outage	41.05	3	13.68
1022170	2/23/2014	Planned Outage	195.33	8	24.42
1022209	2/24/2014	Planned Outage	25.90	3	8.63
1022210	2/24/2014	Planned Outage	10.77	1	10.77
1022211	2/24/2014	Planned Outage	9.25	1	9.25
1022214	2/24/2014	Planned Outage	2,364.30	37	63.9
1022218	2/24/2014	Planned Outage	118.70	1	118.7
1022219	2/24/2014	Planned Outage	2,768.73	17	162.87
1022222	2/24/2014	Planned Outage	35.83	1	35.83
1022224	2/24/2014	Planned Outage	44.85	1	44.85
1022231	2/24/2014	Planned Outage	174.00	2	87
1022235	2/24/2014	Planned Outage	155.45	1	155.45
1022237	2/24/2014	Planned Outage	168.80	4	42.2
1022238	2/24/2014	Planned Outage	85.00	6	14.17
1022242	2/24/2014	Planned Outage	671.50	3	223.83
1022244	2/24/2014	Planned Outage	120.32	1	120.32
1022246	2/24/2014	Planned Outage	765.33	4	191.33
1022255	2/24/2014	Planned Outage	66.03	1	66.03
1022288	2/24/2014	Planned Outage	293.35	3	97.78
1022293	2/24/2014	Planned Outage	483.05	3	161.02
1022295	2/24/2014	Planned Outage	36.93	1	36.93
1022296	2/24/2014	Planned Outage	71.33	1	71.33
1022297	2/24/2014	Planned Outage	95.50	3	31.83
1022299	2/24/2014	Planned Outage	733.25	5	146.65
1022312	2/24/2014	Planned Outage	178.02	11	16.18
1022315	2/24/2014	Planned Outage	303.00	3	101
1022317	2/24/2014	Planned Outage	98.00	1	98
1022327	2/24/2014	Planned Outage	112.00	2	56
1022343	2/24/2014	Planned Outage	600.00	4	150
1022354	2/25/2014	Planned Outage	245.00	7	35
1022355	2/25/2014	Planned Outage	52.00	2	26
1022357	2/25/2014	Planned Outage	102.00	1	102
1022359	2/25/2014	Planned Outage	1,474.67	5	294.93
1022363	2/25/2014	Planned Outage	1,340.02	41	32.68
1022365	2/25/2014	Planned Outage	959.35	7	137.05
1022366	2/25/2014	Planned Outage	180.00	2	90
1022372	2/25/2014	Planned Outage	252.00	4	63
1022374	2/25/2014	Planned Outage	658.47	4	164.62
1022377	2/25/2014	Planned Outage	88.25	5	17.65
1022378	2/25/2014	Planned Outage	134.27	19	7.07
1022379	2/25/2014	Planned Outage	45.40	2	22.7
1022380	2/25/2014	Planned Outage	877.45	3	292.48
1022387	2/25/2014	Planned Outage	125.95	1	125.95
1022391	2/25/2014	Planned Outage	474.00	2	237
1022394	2/25/2014	Planned Outage	21.97	1	21.97
1022395	2/25/2014	Planned Outage	12.97	1	12.97
1022397	2/25/2014	Planned Outage	81.73	2	40.87
1022398	2/25/2014	Planned Outage	208.83	1	208.83
1022399	2/25/2014	Planned Outage	876.00	4	219

Appendix 1

2014 Planned Outages Table

1022403	2/25/2014	Planned Outage	813.20	12	67.77
1022411	2/25/2014	Planned Outage	361.35	3	120.45
1022420	2/25/2014	Planned Outage	107.00	1	107
1022425	2/25/2014	Planned Outage	136.45	3	45.48
1022426	2/25/2014	Planned Outage	44.98	1	44.98
1022430	2/25/2014	Planned Outage	961.33	5	192.27
1022431	2/25/2014	Planned Outage	15.02	1	15.02
1022432	2/25/2014	Planned Outage	118.00	2	59
1022447	2/25/2014	Planned Outage	17.63	2	8.82
1022454	2/25/2014	Planned Outage	10.23	2	5.12
1022465	2/25/2014	Planned Outage	703.17	10	70.32
1022757	2/26/2014	Planned Outage	26.83	2	13.42
1022765	2/26/2014	Planned Outage	133.07	4	33.27
1022772	2/26/2014	Planned Outage	17.77	2	8.88
1022775	2/26/2014	Planned Outage	316.73	4	79.18
1022776	2/26/2014	Planned Outage	211.10	3	70.37
1022778	2/26/2014	Planned Outage	71.80	4	17.95
1022783	2/26/2014	Planned Outage	581.40	4	145.35
1022790	2/26/2014	Planned Outage	70.80	6	11.8
1022791	2/26/2014	Planned Outage	104.58	1	104.58
1022794	2/26/2014	Planned Outage	1,133.80	6	188.97
1022796	2/26/2014	Planned Outage	80.90	2	40.45
1022797	2/26/2014	Planned Outage	114.55	3	38.18
1022800	2/26/2014	Planned Outage	42.00	1	42
1022802	2/26/2014	Planned Outage	180.80	4	45.2
1022803	2/26/2014	Planned Outage	17.95	1	17.95
1022851	2/27/2014	Planned Outage	641.00	4	160.25
1022857	2/27/2014	Planned Outage	158.92	1	158.92
1022859	2/27/2014	Planned Outage	179.87	4	44.97
1022860	2/27/2014	Planned Outage	11.10	6	1.85
1022863	2/27/2014	Planned Outage	348.00	6	58
1022865	2/27/2014	Planned Outage	9,455.30	69	137.03
1022874	2/27/2014	Planned Outage	17.27	1	17.27
1022875	2/27/2014	Planned Outage	88.00	1	88
1022876	2/27/2014	Planned Outage	276.00	3	92
1022884	2/27/2014	Planned Outage	101.75	1	101.75
1022885	2/27/2014	Planned Outage	369.00	3	123
1022886	2/27/2014	Planned Outage	558.00	6	93
1022888	2/27/2014	Planned Outage	14,934.00	131	114
1022900	2/27/2014	Planned Outage	5,380.42	25	215.22
1022902	2/27/2014	Planned Outage	291.00	4	72.75
1022907	2/27/2014	Planned Outage	19.72	1	19.72
1022909	2/27/2014	Planned Outage	37.25	1	37.25
1022911	2/27/2014	Planned Outage	35.80	1	35.8
1022913	2/27/2014	Planned Outage	27.05	1	27.05
1022918	2/27/2014	Planned Outage	205.00	1	205
1022923	2/27/2014	Planned Outage	109.30	1	109.3
1022924	2/27/2014	Planned Outage	3,537.45	63	56.15
1022931	2/27/2014	Planned Outage	47.13	2	23.57

Appendix 1

2014 Planned Outages Table

1022940	2/27/2014	Planned Outage	132.75	3	44.25
1023007	2/28/2014	Planned Outage	11.77	1	11.77
1023009	2/28/2014	Planned Outage	141.70	1	141.7
1023011	2/28/2014	Planned Outage	157.47	2	78.73
1023012	2/28/2014	Planned Outage	38.25	1	38.25
1023014	2/28/2014	Planned Outage	80.88	1	80.88
1023016	2/28/2014	Planned Outage	107.60	3	35.87
1023022	2/28/2014	Planned Outage	154.50	3	51.5
1023024	2/28/2014	Planned Outage	638.53	8	79.82
1023025	2/28/2014	Planned Outage	52.00	2	26
1023026	2/28/2014	Planned Outage	148.60	1	148.6
1023032	2/28/2014	Planned Outage	587.13	4	146.78
1023033	2/28/2014	Planned Outage	148.05	3	49.35
1023040	2/28/2014	Planned Outage	27.88	1	27.88
1023255	2/28/2014	Planned Outage	1,450.10	51	28.43
1023262	2/28/2014	Planned Outage	10,706.50	190	56.35
1023264	2/28/2014	Planned Outage	6,289.40	118	53.3
1023267	2/28/2014	Planned Outage	66.55	1	66.55
1023281	2/28/2014	Planned Outage	17.37	1	17.37
1023295	3/1/2014	Planned Outage	71.93	4	17.98
1023406	3/2/2014	Planned Outage	52.00	2	26
1023424	3/3/2014	Planned Outage	465.73	4	116.43
1023433	3/3/2014	Planned Outage	18.82	1	18.82
1023436	3/3/2014	Planned Outage	257.77	2	128.88
1023441	3/3/2014	Planned Outage	394.40	4	98.6
1023442	3/3/2014	Planned Outage	57.35	1	57.35
1023446	3/3/2014	Planned Outage	10.17	1	10.17
1023447	3/3/2014	Planned Outage	178.50	5	35.7
1023465	3/3/2014	Planned Outage	45.17	2	22.58
1023468	3/3/2014	Planned Outage	75.13	4	18.78
1023472	3/3/2014	Planned Outage	17.07	1	17.07
1023480	3/3/2014	Planned Outage	42.95	1	42.95
1023488	3/3/2014	Planned Outage	12.80	1	12.8
1023493	3/3/2014	Planned Outage	131.50	2	65.75
1023503	3/3/2014	Planned Outage	760.50	15	50.7
1023512	3/3/2014	Planned Outage	11.20	1	11.2
1023539	3/3/2014	Planned Outage	45.95	1	45.95
1023571	3/3/2014	Planned Outage	94.47	4	23.62
1023610	3/4/2014	Planned Outage	2,766.87	22	125.77
1023611	3/4/2014	Planned Outage	72.07	1	72.07
1023614	3/4/2014	Planned Outage	12.60	1	12.6
1023620	3/4/2014	Planned Outage	661.30	3	220.43
1023624	3/4/2014	Planned Outage	38.23	1	38.23
1023625	3/4/2014	Planned Outage	47.50	1	47.5
1023628	3/4/2014	Planned Outage	75.28	1	75.28
1023640	3/4/2014	Planned Outage	88.08	1	88.08
1023643	3/4/2014	Planned Outage	61.88	1	61.88
1023645	3/4/2014	Planned Outage	77.15	1	77.15
1023646	3/4/2014	Planned Outage	45.72	1	45.72

Appendix 1

2014 Planned Outages Table

1023647	3/4/2014	Planned Outage	51.50	3	17.17
1023653	3/4/2014	Planned Outage	24.42	1	24.42
1023664	3/4/2014	Planned Outage	153.13	2	76.57
1023677	3/4/2014	Planned Outage	74.43	7	10.63
1023679	3/4/2014	Planned Outage	46.55	1	46.55
1023699	3/5/2014	Planned Outage	77.97	2	38.98
1023709	3/5/2014	Planned Outage	104.00	2	52
1023710	3/5/2014	Planned Outage	662.72	17	38.98
1023711	3/5/2014	Planned Outage	22.88	1	22.88
1023715	3/5/2014	Planned Outage	78.90	1	78.9
1023718	3/5/2014	Planned Outage	23.30	2	11.65
1023722	3/5/2014	Planned Outage	33.83	1	33.83
1023723	3/5/2014	Planned Outage	6,155.20	48	128.23
1023725	3/5/2014	Planned Outage	240.00	3	80
1023726	3/5/2014	Planned Outage	17.93	1	17.93
1023728	3/5/2014	Planned Outage	11.10	3	3.7
1023730	3/5/2014	Planned Outage	178.85	3	59.62
1023733	3/5/2014	Planned Outage	411.20	8	51.4
1023739	3/5/2014	Planned Outage	114.97	1	114.97
1023740	3/5/2014	Planned Outage	192.00	2	96
1023741	3/5/2014	Planned Outage	213.90	3	71.3
1023744	3/5/2014	Planned Outage	152.30	3	50.77
1023749	3/5/2014	Planned Outage	409.85	7	58.55
1023750	3/5/2014	Planned Outage	10.57	1	10.57
1023757	3/5/2014	Planned Outage	29.00	3	9.67
1023762	3/5/2014	Planned Outage	152.62	1	152.62
1023764	3/5/2014	Planned Outage	46.92	1	46.92
1023767	3/5/2014	Planned Outage	36.13	2	18.07
1023769	3/5/2014	Planned Outage	364.40	6	60.73
1023772	3/5/2014	Planned Outage	243.60	4	60.9
1023775	3/5/2014	Planned Outage	451.00	11	41
1023795	3/5/2014	Planned Outage	350.10	6	58.35
1023804	3/5/2014	Planned Outage	19.52	1	19.52
1023823	3/6/2014	Planned Outage	105.00	1	105
1023833	3/6/2014	Planned Outage	138.67	4	34.67
1023880	3/6/2014	Planned Outage	175.23	2	87.62
1023901	3/6/2014	Planned Outage	368.40	9	40.93
1023927	3/7/2014	Planned Outage	863.32	17	50.78
1023931	3/7/2014	Planned Outage	54.18	1	54.18
1023933	3/7/2014	Planned Outage	261.00	3	87
1023934	3/7/2014	Planned Outage	433.77	11	39.43
1023936	3/7/2014	Planned Outage	80.77	1	80.77
1023939	3/7/2014	Planned Outage	138.83	1	138.83
1023941	3/7/2014	Planned Outage	354.20	3	118.07
1023942	3/7/2014	Planned Outage	21.47	2	10.73
1023945	3/7/2014	Planned Outage	361.50	5	72.3
1023949	3/7/2014	Planned Outage	948.67	8	118.58
1023950	3/7/2014	Planned Outage	14.47	4	3.62
1023952	3/7/2014	Planned Outage	126.00	6	21

Appendix 1

2014 Planned Outages Table

1023954	3/7/2014	Planned Outage	11,887.53	34	349.63
1023955	3/7/2014	Planned Outage	28.00	1	28
1023956	3/7/2014	Planned Outage	28.35	3	9.45
1023957	3/7/2014	Planned Outage	63.68	1	63.68
1023958	3/7/2014	Planned Outage	336.73	1	336.73
1023959	3/7/2014	Planned Outage	9,087.75	27	336.58
1023960	3/7/2014	Planned Outage	62.42	1	62.42
1023961	3/7/2014	Planned Outage	16.58	1	16.58
1023964	3/7/2014	Planned Outage	61.30	3	20.43
1023965	3/7/2014	Planned Outage	135.80	3	45.27
1023966	3/7/2014	Planned Outage	11.18	1	11.18
1023967	3/7/2014	Planned Outage	13.68	1	13.68
1023969	3/7/2014	Planned Outage	9.93	1	9.93
1023970	3/7/2014	Planned Outage	173.42	5	34.68
1023971	3/7/2014	Planned Outage	1,456.40	8	182.05
1023991	3/7/2014	Planned Outage	48.27	8	6.03
1024026	3/7/2014	Planned Outage	207.33	10	20.73
1024037	3/8/2014	Planned Outage	31.75	3	10.58
1024041	3/8/2014	Planned Outage	103.83	5	20.77
1024044	3/8/2014	Planned Outage	94.67	2	47.33
1024085	3/8/2014	Planned Outage	31.97	1	31.97
1024146	3/9/2014	Planned Outage	41.07	1	41.07
1024181	3/10/2014	Planned Outage	10.75	1	10.75
1024182	3/10/2014	Planned Outage	13.93	1	13.93
1024183	3/10/2014	Planned Outage	38.60	6	6.43
1024190	3/10/2014	Planned Outage	6.93	2	3.47
1024191	3/10/2014	Planned Outage	56.10	18	3.12
1024195	3/10/2014	Planned Outage	303.33	10	30.33
1024203	3/10/2014	Planned Outage	15.87	1	15.87
1024204	3/10/2014	Planned Outage	82.55	3	27.52
1024205	3/10/2014	Planned Outage	7.70	1	7.7
1024206	3/10/2014	Planned Outage	23.27	1	23.27
1024207	3/10/2014	Planned Outage	145.50	5	29.1
1024209	3/10/2014	Planned Outage	104.73	4	26.18
1024211	3/10/2014	Planned Outage	177.00	3	59
1024214	3/10/2014	Planned Outage	18.70	3	6.23
1024215	3/10/2014	Planned Outage	10.80	1	10.8
1024216	3/10/2014	Planned Outage	4.07	1	4.07
1024221	3/10/2014	Planned Outage	36.07	4	9.02
1024223	3/10/2014	Planned Outage	56.03	1	56.03
1024225	3/10/2014	Planned Outage	66.72	1	66.72
1024229	3/10/2014	Planned Outage	95.33	4	23.83
1024232	3/10/2014	Planned Outage	65.30	2	32.65
1024236	3/10/2014	Planned Outage	98.80	4	24.7
1024244	3/10/2014	Planned Outage	19.48	1	19.48
1024248	3/10/2014	Planned Outage	128.92	1	128.92
1024250	3/10/2014	Planned Outage	17.03	1	17.03
1024254	3/10/2014	Planned Outage	257.20	12	21.43
1024255	3/10/2014	Planned Outage	108.92	5	21.78

Appendix 1

2014 Planned Outages Table

1024256	3/10/2014	Planned Outage	221.67	10	22.17
1024257	3/10/2014	Planned Outage	249.15	11	22.65
1024259	3/10/2014	Planned Outage	620.67	4	155.17
1024270	3/10/2014	Planned Outage	148.78	1	148.78
1024272	3/10/2014	Planned Outage	4.60	2	2.3
1024276	3/10/2014	Planned Outage	164.77	2	82.38
1024284	3/10/2014	Planned Outage	57.70	2	28.85
1024292	3/11/2014	Planned Outage	199.50	7	28.5
1024318	3/11/2014	Planned Outage	534.80	4	133.7
1024321	3/11/2014	Planned Outage	371.17	10	37.12
1024323	3/11/2014	Planned Outage	367.33	5	73.47
1024324	3/11/2014	Planned Outage	825.07	4	206.27
1024326	3/11/2014	Planned Outage	1,090.60	3	363.53
1024327	3/11/2014	Planned Outage	583.40	3	194.47
1024328	3/11/2014	Planned Outage	274.45	3	91.48
1024330	3/11/2014	Planned Outage	338.80	33	10.27
1024334	3/11/2014	Planned Outage	669.00	9	74.33
1024338	3/11/2014	Planned Outage	268.17	10	26.82
1024341	3/11/2014	Planned Outage	410.60	3	136.87
1024342	3/11/2014	Planned Outage	89.00	4	22.25
1024343	3/11/2014	Planned Outage	22.80	6	3.8
1024344	3/11/2014	Planned Outage	104.27	4	26.07
1024348	3/11/2014	Planned Outage	558.13	16	34.88
1024349	3/11/2014	Planned Outage	23.40	2	11.7
1024350	3/11/2014	Planned Outage	13.90	2	6.95
1024353	3/11/2014	Planned Outage	15.97	2	7.98
1024359	3/11/2014	Planned Outage	86.33	4	21.58
1024364	3/11/2014	Planned Outage	448.33	4	112.08
1024366	3/11/2014	Planned Outage	980.00	49	20
1024371	3/11/2014	Planned Outage	105.27	2	52.63
1024375	3/11/2014	Planned Outage	271.60	6	45.27
1024377	3/11/2014	Planned Outage	175.30	2	87.65
1024381	3/11/2014	Planned Outage	45.67	4	11.42
1024384	3/11/2014	Planned Outage	155.45	3	51.82
1024408	3/11/2014	Planned Outage	1,332.00	74	18
1024433	3/12/2014	Planned Outage	100.40	2	50.2
1024434	3/12/2014	Planned Outage	51.58	1	51.58
1024444	3/12/2014	Planned Outage	1,254.40	21	59.73
1024445	3/12/2014	Planned Outage	44.67	4	11.17
1024447	3/12/2014	Planned Outage	26.32	1	26.32
1024451	3/12/2014	Planned Outage	31.00	1	31
1024452	3/12/2014	Planned Outage	245.20	4	61.3
1024621	3/12/2014	Planned Outage	62.53	1	62.53
1024623	3/12/2014	Planned Outage	55.75	1	55.75
1024624	3/12/2014	Planned Outage	651.75	5	130.35
1024626	3/12/2014	Planned Outage	142.95	9	15.88
1024627	3/12/2014	Planned Outage	98.80	6	16.47
1024628	3/12/2014	Planned Outage	268.23	2	134.12
1024629	3/12/2014	Planned Outage	39.10	3	13.03

Appendix 1

2014 Planned Outages Table

1024630	3/12/2014	Planned Outage	8.40	4	2.1
1024634	3/12/2014	Planned Outage	345.78	1	345.78
1024635	3/12/2014	Planned Outage	38.43	2	19.22
1024638	3/12/2014	Planned Outage	88.58	1	88.58
1024642	3/12/2014	Planned Outage	33.75	1	33.75
1024647	3/12/2014	Planned Outage	313.78	1	313.78
1024650	3/12/2014	Planned Outage	330.63	7	47.23
1024657	3/12/2014	Planned Outage	31.55	3	10.52
1024659	3/12/2014	Planned Outage	13.65	1	13.65
1024673	3/12/2014	Planned Outage	529.32	7	75.62
1024675	3/12/2014	Planned Outage	18.62	1	18.62
1024798	3/12/2014	Planned Outage	267.93	4	66.98
1024817	3/12/2014	Planned Outage	117.90	1	117.9
1024827	3/12/2014	Planned Outage	77.37	2	38.68
1024829	3/12/2014	Planned Outage	206.50	1	206.5
1024832	3/12/2014	Planned Outage	213.95	3	71.32
1024836	3/12/2014	Planned Outage	15.23	1	15.23
1024841	3/12/2014	Planned Outage	106.73	1	106.73
1024849	3/12/2014	Planned Outage	59.32	1	59.32
1024859	3/12/2014	Planned Outage	152.55	3	50.85
1024908	3/12/2014	Planned Outage	36.25	5	7.25
1024951	3/13/2014	Planned Outage	349.37	2	174.68
1024952	3/13/2014	Planned Outage	1,808.80	7	258.4
1024958	3/13/2014	Planned Outage	35.32	1	35.32
1024961	3/13/2014	Planned Outage	14.43	1	14.43
1024963	3/13/2014	Planned Outage	372.00	12	31
1024964	3/13/2014	Planned Outage	886.78	11	80.62
1024966	3/13/2014	Planned Outage	284.08	5	56.82
1024968	3/13/2014	Planned Outage	1,682.67	16	105.17
1024972	3/13/2014	Planned Outage	1,121.03	26	43.12
1024974	3/13/2014	Planned Outage	38.47	4	9.62
1024978	3/13/2014	Planned Outage	89.67	1	89.67
1024982	3/13/2014	Planned Outage	130.83	2	65.42
1024990	3/13/2014	Planned Outage	397.77	1	397.77
1024994	3/13/2014	Planned Outage	6.70	1	6.7
1025000	3/13/2014	Planned Outage	144.90	3	48.3
1025038	3/13/2014	Planned Outage	296.53	2	148.27
1025040	3/13/2014	Planned Outage	70.70	1	70.7
1025042	3/13/2014	Planned Outage	4,864.50	69	70.5
1025054	3/13/2014	Planned Outage	185.35	3	61.78
1025062	3/13/2014	Planned Outage	41.92	1	41.92
1025067	3/13/2014	Planned Outage	7,238.00	56	129.25
1025079	3/13/2014	Planned Outage	76.67	1	76.67
1025080	3/13/2014	Planned Outage	2,023.00	35	57.8
1025089	3/13/2014	Planned Outage	51.22	7	7.32
1025096	3/13/2014	Planned Outage	176.92	11	16.08
1025102	3/14/2014	Planned Outage	115.80	4	28.95
1025105	3/14/2014	Planned Outage	91.48	1	91.48
1025106	3/14/2014	Planned Outage	1,410.03	14	100.72

Appendix 1

2014 Planned Outages Table

1025111	3/14/2014	Planned Outage	25.80	1	25.8
1025114	3/14/2014	Planned Outage	61.68	1	61.68
1025119	3/14/2014	Planned Outage	135.15	3	45.05
1025123	3/14/2014	Planned Outage	554.67	4	138.67
1025132	3/14/2014	Planned Outage	65.60	3	21.87
1025133	3/14/2014	Planned Outage	78.13	2	39.07
1025137	3/14/2014	Planned Outage	853.20	8	106.65
1025144	3/14/2014	Planned Outage	16.13	2	8.07
1025148	3/14/2014	Planned Outage	5.05	3	1.68
1025161	3/14/2014	Planned Outage	11.20	2	5.6
1025165	3/14/2014	Planned Outage	247.60	24	10.32
1025166	3/14/2014	Planned Outage	806.33	2	403.17
1025173	3/14/2014	Planned Outage	531.97	2	265.98
1025209	3/15/2014	Planned Outage	20.27	1	20.27
1025353	3/16/2014	Planned Outage	84.38	1	84.38
1025398	3/16/2014	Planned Outage	135.05	3	45.02
1025471	3/17/2014	Planned Outage	683.40	68	10.05
1025575	3/17/2014	Planned Outage	52.00	1	52
1025580	3/17/2014	Planned Outage	155.67	4	38.92
1025584	3/17/2014	Planned Outage	13.72	1	13.72
1025612	3/17/2014	Planned Outage	120.88	1	120.88
1025614	3/17/2014	Planned Outage	100.00	5	20
1025616	3/17/2014	Planned Outage	48.90	2	24.45
1025622	3/17/2014	Planned Outage	42.02	1	42.02
1025631	3/17/2014	Planned Outage	193.47	1	193.47
1025634	3/17/2014	Planned Outage	29.97	1	29.97
1025636	3/17/2014	Planned Outage	69.70	2	34.85
1025662	3/17/2014	Planned Outage	130.70	3	43.57
1025678	3/18/2014	Planned Outage	210.00	2	105
1025682	3/18/2014	Planned Outage	525.00	3	175
1025695	3/18/2014	Planned Outage	346.77	2	173.38
1025697	3/18/2014	Planned Outage	46.35	1	46.35
1025702	3/18/2014	Planned Outage	435.93	4	108.98
1025703	3/18/2014	Planned Outage	28.37	1	28.37
1025704	3/18/2014	Planned Outage	200.72	1	200.72
1025705	3/18/2014	Planned Outage	2,588.73	103	25.13
1025740	3/18/2014	Planned Outage	103.28	1	103.28
1025744	3/18/2014	Planned Outage	368.80	16	23.05
1025746	3/18/2014	Planned Outage	379.30	3	126.43
1025747	3/18/2014	Planned Outage	374.67	4	93.67
1025753	3/18/2014	Planned Outage	1,498.80	24	62.45
1025755	3/18/2014	Planned Outage	159.40	3	53.13
1025766	3/18/2014	Planned Outage	780.60	3	260.2
1025773	3/18/2014	Planned Outage	31.22	1	31.22
1025774	3/18/2014	Planned Outage	68.25	1	68.25
1025778	3/18/2014	Planned Outage	26.75	15	1.78
1025790	3/18/2014	Planned Outage	53.73	4	13.43
1025808	3/18/2014	Planned Outage	23.70	1	23.7
1025811	3/18/2014	Planned Outage	26.32	1	26.32

Appendix 1

2014 Planned Outages Table

1025815	3/18/2014	Planned Outage	505.15	3	168.38
1025821	3/18/2014	Planned Outage	868.00	4	217
1025822	3/18/2014	Planned Outage	116.63	2	58.32
1026000	3/18/2014	Planned Outage	428.33	5	85.67
1026005	3/18/2014	Planned Outage	75.60	1	75.6
1026008	3/18/2014	Planned Outage	60.00	5	12
1026009	3/18/2014	Planned Outage	200.07	4	50.02
1026012	3/18/2014	Planned Outage	145.40	3	48.47
1026018	3/18/2014	Planned Outage	27.23	1	27.23
1026057	3/19/2014	Planned Outage	42.50	1	42.5
1026058	3/19/2014	Planned Outage	127.45	3	42.48
1026060	3/19/2014	Planned Outage	461.25	3	153.75
1026063	3/19/2014	Planned Outage	56.33	1	56.33
1026066	3/19/2014	Planned Outage	116.20	1	116.2
1026067	3/19/2014	Planned Outage	308.58	7	44.08
1026069	3/19/2014	Planned Outage	1,253.05	57	21.98
1026072	3/19/2014	Planned Outage	11,284.00	62	182
1026074	3/19/2014	Planned Outage	147.00	4	36.75
1026078	3/19/2014	Planned Outage	184.80	6	30.8
1026080	3/19/2014	Planned Outage	529.13	4	132.28
1026082	3/19/2014	Planned Outage	336.40	3	112.13
1026085	3/19/2014	Planned Outage	84.30	1	84.3
1026087	3/19/2014	Planned Outage	168.00	2	84
1026089	3/19/2014	Planned Outage	116.92	1	116.92
1026095	3/19/2014	Planned Outage	427.00	7	61
1026096	3/19/2014	Planned Outage	673.55	57	11.82
1026103	3/19/2014	Planned Outage	43.00	1	43
1026105	3/19/2014	Planned Outage	62.43	2	31.22
1026113	3/19/2014	Planned Outage	174.40	1	174.4
1026117	3/19/2014	Planned Outage	178.72	1	178.72
1026123	3/19/2014	Planned Outage	441.30	6	73.55
1026126	3/19/2014	Planned Outage	30.33	2	15.17
1026130	3/19/2014	Planned Outage	26.00	3	8.67
1026131	3/19/2014	Planned Outage	72.95	3	24.32
1026133	3/19/2014	Planned Outage	358.77	94	3.82
1026137	3/19/2014	Planned Outage	285.48	7	40.78
1026138	3/19/2014	Planned Outage	79.27	4	19.82
1026139	3/19/2014	Planned Outage	95.23	1	95.23
1026142	3/19/2014	Planned Outage	15.98	1	15.98
1026148	3/19/2014	Planned Outage	32.62	1	32.62
1026149	3/19/2014	Planned Outage	16.57	2	8.28
1026172	3/20/2014	Planned Outage	112.27	2	56.13
1026174	3/20/2014	Planned Outage	11,130.00	70	159
1026177	3/20/2014	Planned Outage	141.13	4	35.28
1026183	3/20/2014	Planned Outage	35.98	1	35.98
1026184	3/20/2014	Planned Outage	33.53	1	33.53
1026185	3/20/2014	Planned Outage	31.38	1	31.38
1026187	3/20/2014	Planned Outage	257.25	5	51.45
1026188	3/20/2014	Planned Outage	64.12	1	64.12

Appendix 1

2014 Planned Outages Table

1026189	3/20/2014	Planned Outage	7,246.17	70	103.52
1026192	3/20/2014	Planned Outage	1,186.47	4	296.62
1026193	3/20/2014	Planned Outage	513.75	25	20.55
1026195	3/20/2014	Planned Outage	5,821.83	26	223.92
1026196	3/20/2014	Planned Outage	4,923.97	22	223.82
1026197	3/20/2014	Planned Outage	10,274.87	46	223.37
1026202	3/20/2014	Planned Outage	16.50	2	8.25
1026204	3/20/2014	Planned Outage	647.10	9	71.9
1026207	3/20/2014	Planned Outage	17.05	1	17.05
1026208	3/20/2014	Planned Outage	130.08	7	18.58
1026209	3/20/2014	Planned Outage	29.07	4	7.27
1026211	3/20/2014	Planned Outage	647.00	6	107.83
1026213	3/20/2014	Planned Outage	64.57	1	64.57
1026215	3/20/2014	Planned Outage	106.92	5	21.38
1026223	3/20/2014	Planned Outage	11,844.25	59	200.75
1026226	3/20/2014	Planned Outage	434.40	8	54.3
1026233	3/20/2014	Planned Outage	66.37	1	66.37
1026236	3/20/2014	Planned Outage	2,328.80	24	97.03
1026272	3/21/2014	Planned Outage	286.77	1	286.77
1026281	3/21/2014	Planned Outage	177.45	7	25.35
1026283	3/21/2014	Planned Outage	456.03	2	228.02
1026287	3/21/2014	Planned Outage	258.03	2	129.02
1026291	3/21/2014	Planned Outage	625.25	5	125.05
1026302	3/21/2014	Planned Outage	72.33	1	72.33
1026303	3/21/2014	Planned Outage	82.68	1	82.68
1026305	3/21/2014	Planned Outage	22.00	1	22
1026307	3/21/2014	Planned Outage	207.33	5	41.47
1026313	3/21/2014	Planned Outage	86.27	1	86.27
1026314	3/21/2014	Planned Outage	26.50	1	26.5
1026321	3/21/2014	Planned Outage	4.80	1	4.8
1026322	3/21/2014	Planned Outage	170.83	1	170.83
1026377	3/22/2014	Planned Outage	36.30	1	36.3
1026385	3/22/2014	Planned Outage	83.75	3	27.92
1026414	3/22/2014	Planned Outage	38.90	2	19.45
1026427	3/23/2014	Planned Outage	3,310.18	17	194.72
1026481	3/24/2014	Planned Outage	2,041.83	10	204.18
1026487	3/24/2014	Planned Outage	71.80	1	71.8
1026489	3/24/2014	Planned Outage	92.40	2	46.2
1026491	3/24/2014	Planned Outage	53.50	1	53.5
1026492	3/24/2014	Planned Outage	487.43	2	243.72
1026493	3/24/2014	Planned Outage	371.43	11	33.77
1026495	3/24/2014	Planned Outage	99.25	3	33.08
1026499	3/24/2014	Planned Outage	76.50	2	38.25
1026500	3/24/2014	Planned Outage	50.35	3	16.78
1026501	3/24/2014	Planned Outage	155.53	2	77.77
1026504	3/24/2014	Planned Outage	66.50	2	33.25
1026508	3/24/2014	Planned Outage	703.00	37	19
1026509	3/24/2014	Planned Outage	108.93	4	27.23
1026510	3/24/2014	Planned Outage	70.40	12	5.87

Appendix 1

2014 Planned Outages Table

1026511	3/24/2014	Planned Outage	58.27	2	29.13
1026513	3/24/2014	Planned Outage	267.87	2	133.93
1026515	3/24/2014	Planned Outage	20.13	1	20.13
1026531	3/24/2014	Planned Outage	351.30	2	175.65
1026533	3/24/2014	Planned Outage	41.20	4	10.3
1026535	3/24/2014	Planned Outage	94.23	1	94.23
1026536	3/24/2014	Planned Outage	565.20	3	188.4
1026538	3/24/2014	Planned Outage	106.10	1	106.1
1026539	3/24/2014	Planned Outage	190.00	2	95
1026540	3/24/2014	Planned Outage	435.80	12	36.32
1026541	3/24/2014	Planned Outage	218.73	4	54.68
1026545	3/24/2014	Planned Outage	28.85	1	28.85
1026547	3/24/2014	Planned Outage	21.35	1	21.35
1026549	3/24/2014	Planned Outage	29.83	2	14.92
1026551	3/24/2014	Planned Outage	754.20	4	188.55
1026554	3/24/2014	Planned Outage	95.97	2	47.98
1026561	3/24/2014	Planned Outage	19.52	1	19.52
1026562	3/24/2014	Planned Outage	19.67	1	19.67
1026577	3/24/2014	Planned Outage	1,881.83	10	188.18
1026621	3/25/2014	Planned Outage	71.63	2	35.82
1026677	3/25/2014	Planned Outage	9.98	1	9.98
1026682	3/25/2014	Planned Outage	22.27	4	5.57
1026683	3/25/2014	Planned Outage	516.13	4	129.03
1026691	3/25/2014	Planned Outage	144.05	3	48.02
1026692	3/25/2014	Planned Outage	637.15	3	212.38
1026695	3/25/2014	Planned Outage	489.42	5	97.88
1026714	3/25/2014	Planned Outage	241.48	1	241.48
1026716	3/25/2014	Planned Outage	232.60	12	19.38
1026718	3/25/2014	Planned Outage	89.45	1	89.45
1026719	3/25/2014	Planned Outage	90.00	2	45
1026721	3/25/2014	Planned Outage	187.40	4	46.85
1026728	3/25/2014	Planned Outage	202.00	2	101
1026735	3/25/2014	Planned Outage	20.00	8	2.5
1026737	3/25/2014	Planned Outage	277.40	3	92.47
1026742	3/25/2014	Planned Outage	23.97	1	23.97
1026744	3/25/2014	Planned Outage	101.20	8	12.65
1026771	3/25/2014	Planned Outage	95.95	3	31.98
1026773	3/25/2014	Planned Outage	34.02	1	34.02
1026821	3/26/2014	Planned Outage	438.93	2	219.47
1026823	3/26/2014	Planned Outage	49.80	1	49.8
1026825	3/26/2014	Planned Outage	99.20	2	49.6
1026826	3/26/2014	Planned Outage	77.55	11	7.05
1026827	3/26/2014	Planned Outage	37.00	5	7.4
1026829	3/26/2014	Planned Outage	15.05	1	15.05
1026832	3/26/2014	Planned Outage	16.60	3	5.53
1026833	3/26/2014	Planned Outage	859.93	4	214.98
1026835	3/26/2014	Planned Outage	57.12	1	57.12
1026839	3/26/2014	Planned Outage	437.85	7	62.55
1026840	3/26/2014	Planned Outage	72.20	4	18.05

Appendix 1

2014 Planned Outages Table

1026844	3/26/2014	Planned Outage	126.33	1	126.33
1026846	3/26/2014	Planned Outage	228.75	5	45.75
1026848	3/26/2014	Planned Outage	310.80	4	77.7
1026852	3/26/2014	Planned Outage	132.75	1	132.75
1026856	3/26/2014	Planned Outage	321.83	5	64.37
1026857	3/26/2014	Planned Outage	1,037.50	30	34.58
1026861	3/26/2014	Planned Outage	88.00	2	44
1026866	3/26/2014	Planned Outage	142.00	2	71
1026874	3/26/2014	Planned Outage	9.40	1	9.4
1026875	3/26/2014	Planned Outage	183.70	2	91.85
1026884	3/26/2014	Planned Outage	141.95	1	141.95
1026885	3/26/2014	Planned Outage	142.28	1	142.28
1026889	3/26/2014	Planned Outage	25.58	1	25.58
1026896	3/26/2014	Planned Outage	86.90	1	86.9
1026898	3/26/2014	Planned Outage	78.05	1	78.05
1026904	3/26/2014	Planned Outage	51.42	1	51.42
1026906	3/26/2014	Planned Outage	94.82	1	94.82
1026910	3/26/2014	Planned Outage	1,071.42	5	214.28
1026933	3/27/2014	Planned Outage	48.38	1	48.38
1026936	3/27/2014	Planned Outage	349.70	3	116.57
1026946	3/27/2014	Planned Outage	166.00	3	55.33
1026947	3/27/2014	Planned Outage	29.30	1	29.3
1026949	3/27/2014	Planned Outage	51.98	1	51.98
1026950	3/27/2014	Planned Outage	578.90	7	82.7
1026951	3/27/2014	Planned Outage	196.50	6	32.75
1026953	3/27/2014	Planned Outage	83.60	3	27.87
1026954	3/27/2014	Planned Outage	144.10	2	72.05
1026955	3/27/2014	Planned Outage	25.88	1	25.88
1026957	3/27/2014	Planned Outage	31.97	2	15.98
1026958	3/27/2014	Planned Outage	106.53	8	13.32
1026962	3/27/2014	Planned Outage	166.50	5	33.3
1026968	3/27/2014	Planned Outage	45.32	1	45.32
1026970	3/27/2014	Planned Outage	167.87	2	83.93
1026971	3/27/2014	Planned Outage	68.60	4	17.15
1026977	3/27/2014	Planned Outage	50.93	4	12.73
1026988	3/27/2014	Planned Outage	5,168.00	38	136
1026991	3/27/2014	Planned Outage	68.30	6	11.38
1026996	3/27/2014	Planned Outage	81.65	3	27.22
1027000	3/27/2014	Planned Outage	12.98	1	12.98
1027093	3/28/2014	Planned Outage	134.60	6	22.43
1027833	3/28/2014	Planned Outage	89.20	4	22.3
1028059	3/28/2014	Planned Outage	443.48	1	443.48
1028089	3/28/2014	Planned Outage	284.53	44	6.47
1028168	3/28/2014	Planned Outage	153.07	8	19.13
1028194	3/28/2014	Planned Outage	398.08	1	398.08
1028284	3/28/2014	Planned Outage	206.93	1	206.93
1028305	3/28/2014	Planned Outage	22.88	1	22.88
1028314	3/29/2014	Planned Outage	565.00	12	47.08
1028476	3/29/2014	Planned Outage	11.77	1	11.77

Appendix 1

2014 Planned Outages Table

1028536	3/29/2014	Planned Outage	18.87	1	18.87
1028562	3/29/2014	Planned Outage	8.05	1	8.05
1028595	3/30/2014	Planned Outage	1,338.00	5	267.6
1028601	3/30/2014	Planned Outage	79.10	2	39.55
1028602	3/30/2014	Planned Outage	137.20	4	34.3
1028756	3/31/2014	Planned Outage	17.03	1	17.03
1028759	3/31/2014	Planned Outage	227.20	3	75.73
1028762	3/31/2014	Planned Outage	486.03	2	243.02
1028772	3/31/2014	Planned Outage	52.32	1	52.32
1028783	3/31/2014	Planned Outage	178.40	4	44.6
1028787	3/31/2014	Planned Outage	491.90	3	163.97
1028788	3/31/2014	Planned Outage	56.33	1	56.33
1028790	3/31/2014	Planned Outage	185.27	4	46.32
1028793	3/31/2014	Planned Outage	338.70	3	112.9
1028796	3/31/2014	Planned Outage	636.65	7	90.95
1028801	3/31/2014	Planned Outage	136.87	4	34.22
1028804	3/31/2014	Planned Outage	207.40	2	103.7
1028805	3/31/2014	Planned Outage	64.75	3	21.58
1028818	3/31/2014	Planned Outage	39.20	1	39.2
1028823	3/31/2014	Planned Outage	11.95	1	11.95
1028826	3/31/2014	Planned Outage	79.90	1	79.9
1028830	3/31/2014	Planned Outage	42.25	1	42.25
1028832	3/31/2014	Planned Outage	72.10	3	24.03
1028834	3/31/2014	Planned Outage	1,000.80	6	166.8
1028842	3/31/2014	Planned Outage	142.33	4	35.58
1028846	3/31/2014	Planned Outage	169.95	1	169.95
1028847	3/31/2014	Planned Outage	394.00	2	197
1028849	3/31/2014	Planned Outage	255.10	3	85.03
1028871	3/31/2014	Planned Outage	19.13	1	19.13
1028911	4/1/2014	Planned Outage	102.70	1	102.7
1028918	4/1/2014	Planned Outage	3.25	1	3.25
1028920	4/1/2014	Planned Outage	1,962.65	51	38.48
1028924	4/1/2014	Planned Outage	123.10	3	41.03
1028925	4/1/2014	Planned Outage	229.50	3	76.5
1028926	4/1/2014	Planned Outage	218.27	2	109.13
1028928	4/1/2014	Planned Outage	4,897.67	14	349.83
1028931	4/1/2014	Planned Outage	38,968.25	85	458.45
1028934	4/1/2014	Planned Outage	294.25	15	19.62
1028943	4/1/2014	Planned Outage	142.83	2	71.42
1028949	4/1/2014	Planned Outage	123.70	6	20.62
1028952	4/1/2014	Planned Outage	527.80	7	75.4
1028953	4/1/2014	Planned Outage	175.35	3	58.45
1028957	4/1/2014	Planned Outage	142.00	4	35.5
1028958	4/1/2014	Planned Outage	950.00	6	158.33
1028960	4/1/2014	Planned Outage	360.00	6	60
1028962	4/1/2014	Planned Outage	98.55	3	32.85
1028963	4/1/2014	Planned Outage	64.33	4	16.08
1028967	4/1/2014	Planned Outage	18.25	1	18.25
1028968	4/1/2014	Planned Outage	1,005.33	4	251.33

Appendix 1

2014 Planned Outages Table

1028969	4/1/2014	Planned Outage	291.55	3	97.18
1028975	4/1/2014	Planned Outage	690.47	4	172.62
1028995	4/1/2014	Planned Outage	126.10	1	126.1
1028998	4/1/2014	Planned Outage	116.37	1	116.37
1029008	4/1/2014	Planned Outage	54.40	1	54.4
1029010	4/1/2014	Planned Outage	882.00	6	147
1029018	4/1/2014	Planned Outage	201.67	1	201.67
1029256	4/2/2014	Planned Outage	54.93	1	54.93
1029258	4/2/2014	Planned Outage	13.05	1	13.05
1029259	4/2/2014	Planned Outage	792.05	7	113.15
1029260	4/2/2014	Planned Outage	11.15	1	11.15
1029261	4/2/2014	Planned Outage	271.20	18	15.07
1029262	4/2/2014	Planned Outage	11.77	1	11.77
1029266	4/2/2014	Planned Outage	147.58	5	29.52
1029269	4/2/2014	Planned Outage	866.60	21	41.27
1029273	4/2/2014	Planned Outage	1,031.60	8	128.95
1029275	4/2/2014	Planned Outage	405.50	5	81.1
1029277	4/2/2014	Planned Outage	98.73	4	24.68
1029282	4/2/2014	Planned Outage	243.50	6	40.58
1029286	4/2/2014	Planned Outage	957.73	4	239.43
1029287	4/2/2014	Planned Outage	682.00	3	227.33
1029288	4/2/2014	Planned Outage	13,235.83	50	264.72
1029292	4/2/2014	Planned Outage	107.23	2	53.62
1029293	4/2/2014	Planned Outage	56.40	1	56.4
1029294	4/2/2014	Planned Outage	84.67	2	42.33
1029296	4/2/2014	Planned Outage	112.15	1	112.15
1029298	4/2/2014	Planned Outage	89.82	1	89.82
1029300	4/2/2014	Planned Outage	344.70	6	57.45
1029302	4/2/2014	Planned Outage	62.98	1	62.98
1029305	4/2/2014	Planned Outage	91.87	2	45.93
1029307	4/2/2014	Planned Outage	36.65	3	12.22
1029308	4/2/2014	Planned Outage	398.50	5	79.7
1029313	4/2/2014	Planned Outage	69.12	1	69.12
1029317	4/2/2014	Planned Outage	25.48	1	25.48
1029325	4/2/2014	Planned Outage	83.45	3	27.82
1029326	4/2/2014	Planned Outage	53.67	2	26.83
1029329	4/2/2014	Planned Outage	627.30	51	12.3
1029333	4/2/2014	Planned Outage	134.67	5	26.93
1029339	4/2/2014	Planned Outage	354.75	3	118.25
1029340	4/2/2014	Planned Outage	102.20	1	102.2
1029343	4/2/2014	Planned Outage	78.52	1	78.52
1029345	4/2/2014	Planned Outage	141.43	1	141.43
1029355	4/2/2014	Planned Outage	95.03	1	95.03
1029364	4/2/2014	Planned Outage	176.00	2	88
1029369	4/2/2014	Planned Outage	430.47	4	107.62
1029399	4/3/2014	Planned Outage	139.05	1	139.05
1029403	4/3/2014	Planned Outage	109.17	2	54.58
1029404	4/3/2014	Planned Outage	231.83	1	231.83
1029406	4/3/2014	Planned Outage	10.08	1	10.08

Appendix 1

2014 Planned Outages Table

1029407	4/3/2014	Planned Outage	49.83	5	9.97
1029408	4/3/2014	Planned Outage	7.48	1	7.48
1029409	4/3/2014	Planned Outage	620.33	4	155.08
1029411	4/3/2014	Planned Outage	77.97	1	77.97
1029414	4/3/2014	Planned Outage	85.07	1	85.07
1029416	4/3/2014	Planned Outage	384.67	2	192.33
1029420	4/3/2014	Planned Outage	24.82	1	24.82
1029421	4/3/2014	Planned Outage	643.87	4	160.97
1029426	4/3/2014	Planned Outage	862.00	5	172.4
1029432	4/3/2014	Planned Outage	572.33	4	143.08
1029441	4/3/2014	Planned Outage	70.60	4	17.65
1029444	4/3/2014	Planned Outage	84.27	1	84.27
1029452	4/3/2014	Planned Outage	68.48	1	68.48
1029453	4/3/2014	Planned Outage	13.92	1	13.92
1029459	4/3/2014	Planned Outage	154.47	7	22.07
1029473	4/3/2014	Planned Outage	75.48	1	75.48
1029477	4/3/2014	Planned Outage	7.17	1	7.17
1029483	4/3/2014	Planned Outage	64.20	3	21.4
1029486	4/3/2014	Planned Outage	67.07	1	67.07
1029490	4/3/2014	Planned Outage	117.50	1	117.5
1029491	4/3/2014	Planned Outage	106.73	2	53.37
1029496	4/3/2014	Planned Outage	17.90	1	17.9
1029521	4/3/2014	Planned Outage	5.47	1	5.47
1029563	4/4/2014	Planned Outage	183.33	4	45.83
1029575	4/4/2014	Planned Outage	4,730.00	25	189.2
1029579	4/4/2014	Planned Outage	5.15	1	5.15
1029581	4/4/2014	Planned Outage	1,642.08	25	65.68
1029587	4/4/2014	Planned Outage	67.92	5	13.58
1029590	4/4/2014	Planned Outage	130.07	1	130.07
1029591	4/4/2014	Planned Outage	144.95	1	144.95
1029592	4/4/2014	Planned Outage	39.73	1	39.73
1029603	4/4/2014	Planned Outage	138.20	1	138.2
1029604	4/4/2014	Planned Outage	109.33	1	109.33
1029605	4/4/2014	Planned Outage	432.33	4	108.08
1029606	4/4/2014	Planned Outage	73.35	3	24.45
1029611	4/4/2014	Planned Outage	15.92	1	15.92
1029774	4/4/2014	Planned Outage	145.03	1	145.03
1029780	4/4/2014	Planned Outage	62.30	6	10.38
1030224	4/7/2014	Planned Outage	80.00	5	16
1030339	4/7/2014	Planned Outage	399.00	7	57
1030341	4/7/2014	Planned Outage	333.47	4	83.37
1030354	4/7/2014	Planned Outage	77.97	1	77.97
1030389	4/7/2014	Planned Outage	131.13	4	32.78
1030436	4/7/2014	Planned Outage	24.70	2	12.35
1030635	4/7/2014	Planned Outage	35.27	1	35.27
1030658	4/7/2014	Planned Outage	30.83	1	30.83
1030664	4/7/2014	Planned Outage	43.40	4	10.85
1030666	4/7/2014	Planned Outage	71.05	1	71.05
1030675	4/7/2014	Planned Outage	252.93	1	252.93

Appendix 1

2014 Planned Outages Table

1030683	4/7/2014	Planned Outage	49.45	3	16.48
1030687	4/7/2014	Planned Outage	41.67	4	10.42
1030695	4/7/2014	Planned Outage	130.75	5	26.15
1030698	4/7/2014	Planned Outage	936.07	4	234.02
1030701	4/7/2014	Planned Outage	65.70	2	32.85
1030731	4/8/2014	Planned Outage	127.57	1	127.57
1030740	4/8/2014	Planned Outage	981.70	6	163.62
1030747	4/8/2014	Planned Outage	68.85	1	68.85
1030748	4/8/2014	Planned Outage	194.05	1	194.05
1030751	4/8/2014	Planned Outage	1,369.20	9	152.13
1030754	4/8/2014	Planned Outage	782.63	2	391.32
1030757	4/8/2014	Planned Outage	1,558.27	4	389.57
1030758	4/8/2014	Planned Outage	1,169.60	3	389.87
1030759	4/8/2014	Planned Outage	772.97	2	386.48
1030760	4/8/2014	Planned Outage	3,743.30	41	91.3
1030763	4/8/2014	Planned Outage	1,963.87	22	89.27
1030769	4/8/2014	Planned Outage	129.58	1	129.58
1030770	4/8/2014	Planned Outage	87.15	1	87.15
1030773	4/8/2014	Planned Outage	18.03	1	18.03
1030776	4/8/2014	Planned Outage	5,114.17	34	150.42
1030780	4/8/2014	Planned Outage	6.80	1	6.8
1030783	4/8/2014	Planned Outage	12.78	1	12.78
1030786	4/8/2014	Planned Outage	539.55	3	179.85
1030788	4/8/2014	Planned Outage	177.98	1	177.98
1030796	4/8/2014	Planned Outage	132.58	43	3.08
1030801	4/8/2014	Planned Outage	10.80	2	5.4
1030802	4/8/2014	Planned Outage	642.93	4	160.73
1030803	4/8/2014	Planned Outage	159.77	1	159.77
1030806	4/8/2014	Planned Outage	382.90	7	54.7
1030807	4/8/2014	Planned Outage	105.67	4	26.42
1030816	4/8/2014	Planned Outage	294.75	3	98.25
1030820	4/8/2014	Planned Outage	28.20	3	9.4
1030823	4/8/2014	Planned Outage	284.93	4	71.23
1030825	4/8/2014	Planned Outage	839.42	7	119.92
1030830	4/8/2014	Planned Outage	322.40	4	80.6
1030853	4/8/2014	Planned Outage	79.65	3	26.55
1030865	4/8/2014	Planned Outage	7,009.67	85	82.47
1030866	4/8/2014	Planned Outage	72.00	2	36
1030899	4/9/2014	Planned Outage	352.00	32	11
1031250	4/9/2014	Planned Outage	451.87	4	112.97
1031254	4/9/2014	Planned Outage	121.00	2	60.5
1031259	4/9/2014	Planned Outage	1,821.87	14	130.13
1031261	4/9/2014	Planned Outage	203.33	2	101.67
1031263	4/9/2014	Planned Outage	405.47	2	202.73
1031264	4/9/2014	Planned Outage	1,662.67	4	415.67
1031265	4/9/2014	Planned Outage	1,241.85	3	413.95
1031266	4/9/2014	Planned Outage	184.30	1	184.3
1031267	4/9/2014	Planned Outage	130.10	3	43.37
1031269	4/9/2014	Planned Outage	85.73	1	85.73

Appendix 1

2014 Planned Outages Table

1031270	4/9/2014	Planned Outage	1,369.68	11	124.52
1031271	4/9/2014	Planned Outage	812.00	5	162.4
1031272	4/9/2014	Planned Outage	325.80	2	162.9
1031274	4/9/2014	Planned Outage	71.05	7	10.15
1031275	4/9/2014	Planned Outage	195.83	5	39.17
1031276	4/9/2014	Planned Outage	3,654.37	74	49.38
1031293	4/9/2014	Planned Outage	64.95	3	21.65
1031294	4/9/2014	Planned Outage	112.13	4	28.03
1031298	4/9/2014	Planned Outage	486.60	4	121.65
1031301	4/9/2014	Planned Outage	34.32	1	34.32
1031304	4/9/2014	Planned Outage	12.03	1	12.03
1031311	4/9/2014	Planned Outage	265.92	5	53.18
1031315	4/9/2014	Planned Outage	120.37	2	60.18
1031320	4/9/2014	Planned Outage	84.20	4	21.05
1031323	4/9/2014	Planned Outage	48.57	1	48.57
1031331	4/9/2014	Planned Outage	1,388.10	7	198.3
1031342	4/9/2014	Planned Outage	130.00	3	43.33
1031355	4/10/2014	Planned Outage	235.23	1	235.23
1031356	4/10/2014	Planned Outage	233.13	1	233.13
1031365	4/10/2014	Planned Outage	9,770.00	1954	5
1031369	4/10/2014	Planned Outage	429.35	3	143.12
1031370	4/10/2014	Planned Outage	74.73	1	74.73
1031374	4/10/2014	Planned Outage	144.05	1	144.05
1031380	4/10/2014	Planned Outage	34.05	1	34.05
1031382	4/10/2014	Planned Outage	351.50	2	175.75
1031383	4/10/2014	Planned Outage	174.12	1	174.12
1031384	4/10/2014	Planned Outage	222.40	4	55.6
1031385	4/10/2014	Planned Outage	23.52	1	23.52
1031388	4/10/2014	Planned Outage	3,021.75	17	177.75
1031389	4/10/2014	Planned Outage	120.27	2	60.13
1031390	4/10/2014	Planned Outage	109.35	3	36.45
1031391	4/10/2014	Planned Outage	8.30	1	8.3
1031393	4/10/2014	Planned Outage	187.30	2	93.65
1031400	4/10/2014	Planned Outage	28.85	1	28.85
1031414	4/10/2014	Planned Outage	53.85	1	53.85
1031418	4/10/2014	Planned Outage	70.70	3	23.57
1031431	4/10/2014	Planned Outage	544.00	16	34
1031432	4/10/2014	Planned Outage	91.67	4	22.92
1031586	4/11/2014	Planned Outage	21.77	2	10.88
1031592	4/11/2014	Planned Outage	38.93	1	38.93
1031600	4/11/2014	Planned Outage	242.33	10	24.23
1031608	4/11/2014	Planned Outage	44.70	3	14.9
1031611	4/11/2014	Planned Outage	115.13	1	115.13
1031627	4/11/2014	Planned Outage	150.50	2	75.25
1031653	4/11/2014	Planned Outage	114.30	3	38.1
1031659	4/11/2014	Planned Outage	83.35	1	83.35
1031677	4/11/2014	Planned Outage	14.95	1	14.95
1031678	4/11/2014	Planned Outage	12.97	1	12.97
1032150	4/13/2014	Planned Outage	974.67	430	2.27

Appendix 1

2014 Planned Outages Table

1032168	4/13/2014	Planned Outage	60.50	1	60.5
1032215	4/13/2014	Planned Outage	41.50	1	41.5
1032249	4/14/2014	Planned Outage	294.80	4	73.7
1032262	4/14/2014	Planned Outage	115.27	4	28.82
1032263	4/14/2014	Planned Outage	379.07	2	189.53
1032268	4/14/2014	Planned Outage	964.00	6	160.67
1032270	4/14/2014	Planned Outage	3.47	1	3.47
1032271	4/14/2014	Planned Outage	143.20	3	47.73
1032275	4/14/2014	Planned Outage	122.53	1	122.53
1032276	4/14/2014	Planned Outage	122.62	1	122.62
1032277	4/14/2014	Planned Outage	708.40	8	88.55
1032278	4/14/2014	Planned Outage	350.13	4	87.53
1032281	4/14/2014	Planned Outage	20.33	1	20.33
1032282	4/14/2014	Planned Outage	750.87	4	187.72
1032284	4/14/2014	Planned Outage	134.98	7	19.28
1032291	4/14/2014	Planned Outage	38.03	2	19.02
1032292	4/14/2014	Planned Outage	594.73	2	297.37
1032302	4/14/2014	Planned Outage	165.05	1	165.05
1032332	4/14/2014	Planned Outage	1,170.22	11	106.38
1032358	4/14/2014	Planned Outage	91.67	4	22.92
1032362	4/14/2014	Planned Outage	87.20	2	43.6
1032942	4/15/2014	Planned Outage	253.10	1	253.1
1033213	4/15/2014	Planned Outage	172.58	5	34.52
1033271	4/15/2014	Planned Outage	1,591.10	21	75.77
1033273	4/15/2014	Planned Outage	74.15	1	74.15
1033398	4/15/2014	Planned Outage	27.30	1	27.3
1033403	4/15/2014	Planned Outage	233.13	1	233.13
1033404	4/15/2014	Planned Outage	378.25	3	126.08
1033409	4/15/2014	Planned Outage	53.75	1	53.75
1033411	4/15/2014	Planned Outage	446.60	12	37.22
1033428	4/15/2014	Planned Outage	70.72	1	70.72
1033437	4/15/2014	Planned Outage	2,936.13	61	48.13
1033439	4/15/2014	Planned Outage	106.60	3	35.53
1033440	4/15/2014	Planned Outage	155.40	3	51.8
1033443	4/15/2014	Planned Outage	68.17	5	13.63
1033445	4/15/2014	Planned Outage	54.00	4	13.5
1033447	4/15/2014	Planned Outage	867.07	4	216.77
1033697	4/15/2014	Planned Outage	334.13	7	47.73
1033709	4/15/2014	Planned Outage	156.90	2	78.45
1033754	4/15/2014	Planned Outage	29.83	1	29.83
1033771	4/16/2014	Planned Outage	517.20	12	43.1
1033773	4/16/2014	Planned Outage	171.53	4	42.88
1033774	4/16/2014	Planned Outage	615.00	15	41
1033777	4/16/2014	Planned Outage	593.93	4	148.48
1033778	4/16/2014	Planned Outage	82.82	1	82.82
1033779	4/16/2014	Planned Outage	177.93	4	44.48
1033780	4/16/2014	Planned Outage	204.70	1	204.7
1033784	4/16/2014	Planned Outage	22.53	1	22.53
1033787	4/16/2014	Planned Outage	1,291.10	6	215.18

Appendix 1

2014 Planned Outages Table

1033791	4/16/2014	Planned Outage	477.60	4	119.4
1033793	4/16/2014	Planned Outage	260.00	3	86.67
1033796	4/16/2014	Planned Outage	106.15	1	106.15
1033800	4/16/2014	Planned Outage	9.63	1	9.63
1033803	4/16/2014	Planned Outage	9.15	1	9.15
1033804	4/16/2014	Planned Outage	66.37	1	66.37
1033805	4/16/2014	Planned Outage	533.83	5	106.77
1033813	4/16/2014	Planned Outage	20.93	1	20.93
1033814	4/16/2014	Planned Outage	52.00	4	13
1033819	4/16/2014	Planned Outage	325.33	8	40.67
1033821	4/16/2014	Planned Outage	34.62	1	34.62
1033822	4/16/2014	Planned Outage	20.80	2	10.4
1033826	4/16/2014	Planned Outage	29.35	3	9.78
1033868	4/16/2014	Planned Outage	51.05	3	17.02
1033871	4/16/2014	Planned Outage	591.83	10	59.18
1033874	4/16/2014	Planned Outage	574.00	8	71.75
1033878	4/16/2014	Planned Outage	17.62	1	17.62
1033879	4/16/2014	Planned Outage	1,539.65	7	219.95
1033881	4/16/2014	Planned Outage	353.93	4	88.48
1033883	4/16/2014	Planned Outage	349.07	4	87.27
1033890	4/16/2014	Planned Outage	14.97	2	7.48
1033891	4/16/2014	Planned Outage	182.65	3	60.88
1033903	4/16/2014	Planned Outage	180.00	9	20
1033912	4/16/2014	Planned Outage	210.73	4	52.68
1033913	4/16/2014	Planned Outage	52.73	1	52.73
1033918	4/16/2014	Planned Outage	27.20	2	13.6
1033920	4/16/2014	Planned Outage	37.25	1	37.25
1033933	4/16/2014	Planned Outage	272.35	3	90.78
1034005	4/17/2014	Planned Outage	205.95	3	68.65
1034126	4/17/2014	Planned Outage	256.53	4	64.13
1034128	4/17/2014	Planned Outage	2,094.43	19	110.23
1034129	4/17/2014	Planned Outage	1,436.75	15	95.78
1034130	4/17/2014	Planned Outage	96.73	1	96.73
1034131	4/17/2014	Planned Outage	109.72	1	109.72
1034132	4/17/2014	Planned Outage	523.17	10	52.32
1034135	4/17/2014	Planned Outage	251.07	2	125.53
1034136	4/17/2014	Planned Outage	124.47	1	124.47
1034138	4/17/2014	Planned Outage	21,193.20	87	243.6
1034141	4/17/2014	Planned Outage	442.20	4	110.55
1034142	4/17/2014	Planned Outage	442.00	4	110.5
1034144	4/17/2014	Planned Outage	72.65	3	24.22
1034146	4/17/2014	Planned Outage	1,199.40	12	99.95
1034148	4/17/2014	Planned Outage	8.40	1	8.4
1034149	4/17/2014	Planned Outage	100.75	1	100.75
1034154	4/17/2014	Planned Outage	46.55	1	46.55
1034174	4/17/2014	Planned Outage	34.85	3	11.62
1034182	4/17/2014	Planned Outage	27.63	1	27.63
1034185	4/17/2014	Planned Outage	29.80	2	14.9
1034318	4/18/2014	Planned Outage	19.88	1	19.88

Appendix 1

2014 Planned Outages Table

1034372	4/18/2014	Planned Outage	251.43	19	13.23
1034390	4/18/2014	Planned Outage	62.13	2	31.07
1034445	4/18/2014	Planned Outage	41.30	6	6.88
1034488	4/18/2014	Planned Outage	88.87	2	44.43
1034609	4/20/2014	Planned Outage	111.30	3	37.1
1034646	4/21/2014	Planned Outage	69.97	2	34.98
1034651	4/21/2014	Planned Outage	103.87	1	103.87
1034665	4/21/2014	Planned Outage	68.58	1	68.58
1034666	4/21/2014	Planned Outage	1,279.67	5	255.93
1034667	4/21/2014	Planned Outage	871.50	5	174.3
1034670	4/21/2014	Planned Outage	1,358.00	7	194
1034677	4/21/2014	Planned Outage	46.00	1	46
1034693	4/21/2014	Planned Outage	40.53	8	5.07
1034698	4/21/2014	Planned Outage	47.47	2	23.73
1034702	4/21/2014	Planned Outage	602.87	4	150.72
1034704	4/21/2014	Planned Outage	91.50	2	45.75
1034710	4/21/2014	Planned Outage	74.03	2	37.02
1034711	4/21/2014	Planned Outage	982.40	6	163.73
1034713	4/21/2014	Planned Outage	36.27	2	18.13
1034737	4/21/2014	Planned Outage	440.25	3	146.75
1034781	4/22/2014	Planned Outage	63.70	1	63.7
1034782	4/22/2014	Planned Outage	1,016.52	7	145.22
1034786	4/22/2014	Planned Outage	2,243.70	54	41.55
1034794	4/22/2014	Planned Outage	36.17	2	18.08
1034799	4/22/2014	Planned Outage	107.47	1	107.47
1034800	4/22/2014	Planned Outage	195.43	2	97.72
1034803	4/22/2014	Planned Outage	710.80	8	88.85
1034804	4/22/2014	Planned Outage	5,469.45	63	86.82
1034806	4/22/2014	Planned Outage	88.72	1	88.72
1034810	4/22/2014	Planned Outage	823.00	4	205.75
1034814	4/22/2014	Planned Outage	185.00	185	1
1034826	4/22/2014	Planned Outage	436.17	10	43.62
1034828	4/22/2014	Planned Outage	58.77	2	29.38
1034833	4/22/2014	Planned Outage	91.92	5	18.38
1034842	4/22/2014	Planned Outage	213.33	4	53.33
1034848	4/22/2014	Planned Outage	324.02	1	324.02
1034850	4/22/2014	Planned Outage	413.23	7	59.03
1034861	4/22/2014	Planned Outage	109.30	3	36.43
1034862	4/22/2014	Planned Outage	221.32	7	31.62
1034900	4/23/2014	Planned Outage	301.65	1	301.65
1034906	4/23/2014	Planned Outage	67.70	1	67.7
1034921	4/23/2014	Planned Outage	63.77	1	63.77
1034922	4/23/2014	Planned Outage	182.00	1	182
1034923	4/23/2014	Planned Outage	115.20	12	9.6
1034927	4/23/2014	Planned Outage	25.05	3	8.35
1034928	4/23/2014	Planned Outage	23.45	3	7.82
1034930	4/23/2014	Planned Outage	63.75	5	12.75
1034933	4/23/2014	Planned Outage	66.47	4	16.62
1034935	4/23/2014	Planned Outage	12.92	5	2.58

Appendix 1

2014 Planned Outages Table

1034939	4/23/2014	Planned Outage	9.58	5	1.92
1034943	4/23/2014	Planned Outage	55.00	4	13.75
1034944	4/23/2014	Planned Outage	5,296.67	20	264.83
1034945	4/23/2014	Planned Outage	2,075.75	23	90.25
1034947	4/23/2014	Planned Outage	39.67	2	19.83
1034950	4/23/2014	Planned Outage	39.65	1	39.65
1034955	4/23/2014	Planned Outage	253.60	4	63.4
1034956	4/23/2014	Planned Outage	86.07	1	86.07
1034957	4/23/2014	Planned Outage	59.05	1	59.05
1034962	4/23/2014	Planned Outage	41.43	1	41.43
1034967	4/23/2014	Planned Outage	27.97	2	13.98
1034971	4/23/2014	Planned Outage	31.50	3	10.5
1034981	4/23/2014	Planned Outage	213.17	1	213.17
1034985	4/23/2014	Planned Outage	1,056.25	5	211.25
1034986	4/23/2014	Planned Outage	201.00	5	40.2
1034988	4/23/2014	Planned Outage	252.87	2	126.43
1034992	4/23/2014	Planned Outage	827.20	12	68.93
1034993	4/23/2014	Planned Outage	1,374.00	20	68.7
1034997	4/23/2014	Planned Outage	88.00	2	44
1035000	4/23/2014	Planned Outage	26.00	1	26
1035001	4/23/2014	Planned Outage	45.40	1	45.4
1035015	4/23/2014	Planned Outage	78.17	2	39.08
1035020	4/23/2014	Planned Outage	16.98	1	16.98
1035024	4/23/2014	Planned Outage	184.10	3	61.37
1035029	4/23/2014	Planned Outage	258.13	4	64.53
1035046	4/23/2014	Planned Outage	73.10	6	12.18
1035047	4/23/2014	Planned Outage	115.50	22	5.25
1035054	4/23/2014	Planned Outage	451.07	34	13.27
1035064	4/24/2014	Planned Outage	39.93	1	39.93
1035083	4/24/2014	Planned Outage	46.97	1	46.97
1035084	4/24/2014	Planned Outage	46.63	1	46.63
1035085	4/24/2014	Planned Outage	312.75	9	34.75
1035088	4/24/2014	Planned Outage	592.00	4	148
1035089	4/24/2014	Planned Outage	157.20	3	52.4
1035091	4/24/2014	Planned Outage	254.67	16	15.92
1035092	4/24/2014	Planned Outage	131.85	1	131.85
1035093	4/24/2014	Planned Outage	411.25	3	137.08
1035096	4/24/2014	Planned Outage	124.22	1	124.22
1035116	4/24/2014	Planned Outage	313.30	3	104.43
1035133	4/24/2014	Planned Outage	63.60	4	15.9
1035157	4/24/2014	Planned Outage	785.60	16	49.1
1035161	4/24/2014	Planned Outage	81.80	4	20.45
1035164	4/25/2014	Planned Outage	15,014.40	51	294.4
1035170	4/25/2014	Planned Outage	34.83	19	1.83
1035171	4/25/2014	Planned Outage	32.08	25	1.28
1035173	4/25/2014	Planned Outage	84.70	3	28.23
1035181	4/25/2014	Planned Outage	271.40	3	90.47
1035182	4/25/2014	Planned Outage	89.68	1	89.68
1035192	4/25/2014	Planned Outage	112.48	1	112.48

Appendix 1

2014 Planned Outages Table

1035194	4/25/2014	Planned Outage	116.45	1	116.45
1035195	4/25/2014	Planned Outage	1,245.00	10	124.5
1035202	4/25/2014	Planned Outage	65.13	2	32.57
1035203	4/25/2014	Planned Outage	50.08	5	10.02
1035204	4/25/2014	Planned Outage	113.03	2	56.52
1035205	4/25/2014	Planned Outage	224.47	4	56.12
1035206	4/25/2014	Planned Outage	45.32	1	45.32
1035209	4/25/2014	Planned Outage	376.00	5	75.2
1035210	4/25/2014	Planned Outage	751.33	10	75.13
1035214	4/25/2014	Planned Outage	27.13	1	27.13
1035215	4/25/2014	Planned Outage	30.80	2	15.4
1035216	4/25/2014	Planned Outage	11.82	1	11.82
1035217	4/25/2014	Planned Outage	18.55	7	2.65
1035219	4/25/2014	Planned Outage	813.15	9	90.35
1035230	4/25/2014	Planned Outage	13.48	1	13.48
1035234	4/25/2014	Planned Outage	645.60	8	80.7
1035236	4/25/2014	Planned Outage	26.72	7	3.82
1035238	4/25/2014	Planned Outage	38.25	1	38.25
1035239	4/25/2014	Planned Outage	57.07	16	3.57
1035241	4/25/2014	Planned Outage	18.02	1	18.02
1035243	4/25/2014	Planned Outage	21.98	1	21.98
1035285	4/25/2014	Planned Outage	6,992.95	51	137.12
1035343	4/26/2014	Planned Outage	889.73	4	222.43
1035494	4/27/2014	Planned Outage	108.43	2	54.22
1035511	4/28/2014	Planned Outage	143.58	1	143.58
1035515	4/28/2014	Planned Outage	387.00	3	129
1035524	4/28/2014	Planned Outage	508.27	4	127.07
1035525	4/28/2014	Planned Outage	380.40	3	126.8
1035526	4/28/2014	Planned Outage	270.93	8	33.87
1035531	4/28/2014	Planned Outage	362.50	3	120.83
1035533	4/28/2014	Planned Outage	1,800.90	23	78.3
1035538	4/28/2014	Planned Outage	50.87	1	50.87
1035541	4/28/2014	Planned Outage	237.45	3	79.15
1035543	4/28/2014	Planned Outage	133.80	1	133.8
1035545	4/28/2014	Planned Outage	130.47	1	130.47
1035549	4/28/2014	Planned Outage	748.00	4	187
1035551	4/28/2014	Planned Outage	216.17	1	216.17
1035552	4/28/2014	Planned Outage	784.53	4	196.13
1035554	4/28/2014	Planned Outage	5.60	1	5.6
1035558	4/28/2014	Planned Outage	158.57	1	158.57
1035566	4/28/2014	Planned Outage	7.50	6	1.25
1035570	4/28/2014	Planned Outage	99.70	1	99.7
1035578	4/28/2014	Planned Outage	30.62	1	30.62
1035589	4/28/2014	Planned Outage	43.53	1	43.53
1035608	4/28/2014	Planned Outage	1.45	1	1.45
1036318	4/29/2014	Planned Outage	672.25	3	224.08
1036882	4/29/2014	Planned Outage	25.22	1	25.22
1036980	4/29/2014	Planned Outage	90.60	1	90.6
1040839	4/30/2014	Planned Outage	32.00	20	1.6

Appendix 1

2014 Planned Outages Table

1040923	4/30/2014	Planned Outage	574.40	8	71.8
1040961	4/30/2014	Planned Outage	66.60	2	33.3
1040980	5/1/2014	Planned Outage	635.25	5	127.05
1041101	5/1/2014	Planned Outage	1,348.53	8	168.57
1041136	5/1/2014	Planned Outage	37.15	3	12.38
1041147	5/1/2014	Planned Outage	592.75	5	118.55
1041190	5/1/2014	Planned Outage	37.67	1	37.67
1041210	5/1/2014	Planned Outage	2,410.20	52	46.35
1041221	5/1/2014	Planned Outage	324.27	4	81.07
1041222	5/1/2014	Planned Outage	921.53	92	10.02
1041233	5/1/2014	Planned Outage	153.97	1	153.97
1041245	5/1/2014	Planned Outage	4,387.20	48	91.4
1041247	5/1/2014	Planned Outage	840.08	5	168.02
1041263	5/1/2014	Planned Outage	12,015.98	53	226.72
1041269	5/1/2014	Planned Outage	188.40	3	62.8
1041275	5/1/2014	Planned Outage	1,260.40	92	13.7
1041300	5/1/2014	Planned Outage	108.00	1	108
1041320	5/1/2014	Planned Outage	170.00	2	85
1041321	5/1/2014	Planned Outage	31.80	1	31.8
1041330	5/1/2014	Planned Outage	10.53	1	10.53
1041343	5/1/2014	Planned Outage	69.17	1	69.17
1041356	5/1/2014	Planned Outage	33.38	1	33.38
1041485	5/2/2014	Planned Outage	91.40	3	30.47
1041488	5/2/2014	Planned Outage	45.80	4	11.45
1041498	5/2/2014	Planned Outage	241.45	3	80.48
1041501	5/2/2014	Planned Outage	94.45	3	31.48
1041506	5/2/2014	Planned Outage	122.20	1	122.2
1041507	5/2/2014	Planned Outage	491.87	7	70.27
1041521	5/2/2014	Planned Outage	15.12	1	15.12
1041524	5/2/2014	Planned Outage	28.57	1	28.57
1041530	5/2/2014	Planned Outage	31.33	4	7.83
1041540	5/2/2014	Planned Outage	27.20	2	13.6
1041542	5/2/2014	Planned Outage	32.37	1	32.37
1041547	5/2/2014	Planned Outage	24.90	1	24.9
1041548	5/2/2014	Planned Outage	16.43	1	16.43
1041549	5/2/2014	Planned Outage	6,191.60	46	134.6
1041559	5/2/2014	Planned Outage	117.53	4	29.38
1041578	5/2/2014	Planned Outage	13.27	1	13.27
1041600	5/2/2014	Planned Outage	880.00	6	146.67
1041601	5/2/2014	Planned Outage	25.23	1	25.23
1041605	5/2/2014	Planned Outage	14.98	1	14.98
1041679	5/2/2014	Planned Outage	860.93	4	215.23
1041698	5/2/2014	Planned Outage	108.13	4	27.03
1041707	5/2/2014	Planned Outage	130.90	3	43.63
1041717	5/3/2014	Planned Outage	30,990.67	176	176.08
1041728	5/3/2014	Planned Outage	192.83	1	192.83
1041733	5/3/2014	Planned Outage	64,109.60	631	101.6
1041734	5/3/2014	Planned Outage	122.95	3	40.98
1041736	5/3/2014	Planned Outage	2,568.00	24	107

Appendix 1

2014 Planned Outages Table

1041739	5/3/2014	Planned Outage	309.00	3	103
1041759	5/3/2014	Planned Outage	936.00	468	2
1041760	5/3/2014	Planned Outage	4,405.55	51	86.38
1041761	5/3/2014	Planned Outage	2,000.23	23	86.97
1041783	5/3/2014	Planned Outage	1,527.97	23	66.43
1041800	5/3/2014	Planned Outage	1,579.83	10	157.98
1041803	5/3/2014	Planned Outage	139.93	2	69.97
1041828	5/3/2014	Planned Outage	67.90	1	67.9
1041829	5/3/2014	Planned Outage	201.20	3	67.07
1041834	5/3/2014	Planned Outage	4.40	1	4.4
1041874	5/4/2014	Planned Outage	28.32	1	28.32
1041875	5/4/2014	Planned Outage	2,668.53	8	333.57
1042007	5/4/2014	Planned Outage	736.33	5	147.27
1042020	5/4/2014	Planned Outage	73.35	3	24.45
1042025	5/4/2014	Planned Outage	360.00	5	72
1042043	5/4/2014	Planned Outage	3,372.00	24	140.5
1042062	5/4/2014	Planned Outage	64.00	1	64
1042072	5/4/2014	Planned Outage	6.00	2	3
1042077	5/4/2014	Planned Outage	61.00	1	61
1042109	5/5/2014	Planned Outage	6,415.20	81	79.2
1042110	5/5/2014	Planned Outage	144.00	2	72
1042111	5/5/2014	Planned Outage	1,379.73	16	86.23
1042112	5/5/2014	Planned Outage	468.00	3	156
1042113	5/5/2014	Planned Outage	13.18	1	13.18
1042116	5/5/2014	Planned Outage	221.40	6	36.9
1042122	5/5/2014	Planned Outage	375.53	4	93.88
1042125	5/5/2014	Planned Outage	119.92	5	23.98
1042127	5/5/2014	Planned Outage	258.67	5	51.73
1042129	5/5/2014	Planned Outage	198.57	14	14.18
1042133	5/5/2014	Planned Outage	61.85	1	61.85
1042135	5/5/2014	Planned Outage	31.47	1	31.47
1042137	5/5/2014	Planned Outage	172.05	9	19.12
1042141	5/5/2014	Planned Outage	79.00	1	79
1042142	5/5/2014	Planned Outage	15.77	1	15.77
1042144	5/5/2014	Planned Outage	97.10	1	97.1
1042145	5/5/2014	Planned Outage	341.70	3	113.9
1042147	5/5/2014	Planned Outage	5.30	1	5.3
1042157	5/5/2014	Planned Outage	54.58	5	10.92
1042176	5/5/2014	Planned Outage	98.70	1	98.7
1042179	5/5/2014	Planned Outage	252.73	2	126.37
1042180	5/5/2014	Planned Outage	124.63	1	124.63
1042181	5/5/2014	Planned Outage	27.02	1	27.02
1042186	5/5/2014	Planned Outage	208.13	8	26.02
1042198	5/5/2014	Planned Outage	16.08	1	16.08
1042199	5/5/2014	Planned Outage	315.45	3	105.15
1042207	5/5/2014	Planned Outage	691.35	11	62.85
1042211	5/5/2014	Planned Outage	80.05	1	80.05
1042215	5/5/2014	Planned Outage	255.23	2	127.62
1042216	5/5/2014	Planned Outage	252.17	2	126.08

Appendix 1

2014 Planned Outages Table

1042221	5/5/2014	Planned Outage	14.10	3	4.7
1042223	5/5/2014	Planned Outage	52.23	1	52.23
1042225	5/5/2014	Planned Outage	155.97	2	77.98
1042243	5/5/2014	Planned Outage	134.75	5	26.95
1042298	5/6/2014	Planned Outage	59.75	1	59.75
1042344	5/6/2014	Planned Outage	432.00	12	36
1042345	5/6/2014	Planned Outage	138.25	1	138.25
1042350	5/6/2014	Planned Outage	266.67	5	53.33
1042351	5/6/2014	Planned Outage	13.13	1	13.13
1042355	5/6/2014	Planned Outage	3,418.13	17	201.07
1042357	5/6/2014	Planned Outage	377.58	5	75.52
1042358	5/6/2014	Planned Outage	2,471.50	10	247.15
1042366	5/6/2014	Planned Outage	981.00	6	163.5
1042381	5/6/2014	Planned Outage	525.58	7	75.08
1042382	5/6/2014	Planned Outage	2,312.00	289	8
1042394	5/6/2014	Planned Outage	117.63	1	117.63
1042400	5/6/2014	Planned Outage	113.32	1	113.32
1042405	5/6/2014	Planned Outage	305.80	6	50.97
1042427	5/6/2014	Planned Outage	346.33	5	69.27
1042428	5/6/2014	Planned Outage	989.70	9	109.97
1042448	5/6/2014	Planned Outage	37.20	4	9.3
1042457	5/6/2014	Planned Outage	530.33	10	53.03
1042473	5/7/2014	Planned Outage	6,352.50	45	141.17
1042488	5/7/2014	Planned Outage	5,850.90	22	265.95
1042499	5/7/2014	Planned Outage	239.20	6	39.87
1042504	5/7/2014	Planned Outage	1,310.20	6	218.37
1042509	5/7/2014	Planned Outage	2,709.02	23	117.78
1042511	5/7/2014	Planned Outage	179.22	1	179.22
1042512	5/7/2014	Planned Outage	377.83	5	75.57
1042513	5/7/2014	Planned Outage	187.17	1	187.17
1042514	5/7/2014	Planned Outage	365.10	3	121.7
1042517	5/7/2014	Planned Outage	561.90	3	187.3
1042518	5/7/2014	Planned Outage	371.17	2	185.58
1042529	5/7/2014	Planned Outage	170.85	1	170.85
1042531	5/7/2014	Planned Outage	170.80	4	42.7
1042532	5/7/2014	Planned Outage	166.87	4	41.72
1042533	5/7/2014	Planned Outage	4,320.00	16	270
1042534	5/7/2014	Planned Outage	34.22	1	34.22
1042535	5/7/2014	Planned Outage	226.77	2	113.38
1042539	5/7/2014	Planned Outage	2,302.00	8	287.75
1042553	5/7/2014	Planned Outage	120.13	2	60.07
1042559	5/7/2014	Planned Outage	877.60	4	219.4
1042561	5/7/2014	Planned Outage	12,836.08	95	135.12
1042562	5/7/2014	Planned Outage	147.83	1	147.83
1042564	5/7/2014	Planned Outage	75.40	4	18.85
1042565	5/7/2014	Planned Outage	388.03	7	55.43
1042575	5/7/2014	Planned Outage	430.27	7	61.47
1042579	5/7/2014	Planned Outage	140.58	7	20.08
1042581	5/7/2014	Planned Outage	648.30	6	108.05

Appendix 1

2014 Planned Outages Table

1042590	5/7/2014	Planned Outage	24.17	2	12.08
1042591	5/7/2014	Planned Outage	98.60	2	49.3
1042603	5/7/2014	Planned Outage	75.53	4	18.88
1042605	5/7/2014	Planned Outage	18.43	1	18.43
1042630	5/8/2014	Planned Outage	6.67	1	6.67
1042631	5/8/2014	Planned Outage	27.97	1	27.97
1042633	5/8/2014	Planned Outage	32.20	6	5.37
1042635	5/8/2014	Planned Outage	5.63	1	5.63
1042638	5/8/2014	Planned Outage	6.20	4	1.55
1042641	5/8/2014	Planned Outage	21.95	3	7.32
1042643	5/8/2014	Planned Outage	6.83	1	6.83
1042645	5/8/2014	Planned Outage	272.08	5	54.42
1042646	5/8/2014	Planned Outage	775.40	6	129.23
1042647	5/8/2014	Planned Outage	69.93	2	34.97
1042648	5/8/2014	Planned Outage	68.97	2	34.48
1042651	5/8/2014	Planned Outage	260.92	1	260.92
1042653	5/8/2014	Planned Outage	215.55	3	71.85
1042656	5/8/2014	Planned Outage	482.10	6	80.35
1042657	5/8/2014	Planned Outage	179.10	3	59.7
1042659	5/8/2014	Planned Outage	867.87	4	216.97
1042660	5/8/2014	Planned Outage	76.57	1	76.57
1042669	5/8/2014	Planned Outage	635.47	4	158.87
1042674	5/8/2014	Planned Outage	252.12	7	36.02
1042675	5/8/2014	Planned Outage	153.47	2	76.73
1042676	5/8/2014	Planned Outage	293.08	5	58.62
1042701	5/8/2014	Planned Outage	27.17	1	27.17
1042709	5/8/2014	Planned Outage	20.73	1	20.73
1042713	5/8/2014	Planned Outage	430.85	3	143.62
1042773	5/9/2014	Planned Outage	370.00	5	74
1042778	5/9/2014	Planned Outage	128.90	3	42.97
1042780	5/9/2014	Planned Outage	82.75	3	27.58
1042781	5/9/2014	Planned Outage	401.07	4	100.27
1042785	5/9/2014	Planned Outage	26.63	1	26.63
1042786	5/9/2014	Planned Outage	53.55	7	7.65
1043212	5/9/2014	Planned Outage	86.88	1	86.88
1043214	5/9/2014	Planned Outage	292.12	1	292.12
1043220	5/9/2014	Planned Outage	31.75	3	10.58
1043223	5/9/2014	Planned Outage	25.53	1	25.53
1043226	5/9/2014	Planned Outage	1,206.92	35	34.48
1043228	5/9/2014	Planned Outage	30.20	1	30.2
1043233	5/9/2014	Planned Outage	28.13	2	14.07
1043240	5/9/2014	Planned Outage	89.80	4	22.45
1043241	5/9/2014	Planned Outage	61.08	1	61.08
1043247	5/9/2014	Planned Outage	132.93	8	16.62
1043249	5/9/2014	Planned Outage	114.80	4	28.7
1043258	5/9/2014	Planned Outage	3.38	1	3.38
1043365	5/10/2014	Planned Outage	140.43	1	140.43
1043596	5/12/2014	Planned Outage	120.65	3	40.22
1043597	5/12/2014	Planned Outage	91.92	1	91.92

Appendix 1

2014 Planned Outages Table

1043604	5/12/2014	Planned Outage	270.00	4	67.5
1043607	5/12/2014	Planned Outage	130.28	1	130.28
1043608	5/12/2014	Planned Outage	40.05	1	40.05
1043609	5/12/2014	Planned Outage	1,027.13	7	146.73
1043610	5/12/2014	Planned Outage	1,135.57	22	51.62
1043618	5/12/2014	Planned Outage	165.00	4	41.25
1043620	5/12/2014	Planned Outage	37.60	1	37.6
1043621	5/12/2014	Planned Outage	20.37	1	20.37
1043622	5/12/2014	Planned Outage	40.83	1	40.83
1043623	5/12/2014	Planned Outage	158.17	1	158.17
1043624	5/12/2014	Planned Outage	33.78	1	33.78
1043627	5/12/2014	Planned Outage	145.75	1	145.75
1043628	5/12/2014	Planned Outage	126.95	3	42.32
1043632	5/12/2014	Planned Outage	78.93	4	19.73
1043635	5/12/2014	Planned Outage	58.77	2	29.38
1043642	5/12/2014	Planned Outage	192.67	8	24.08
1043675	5/12/2014	Planned Outage	31.70	3	10.57
1043704	5/12/2014	Planned Outage	516.47	2	258.23
1043726	5/12/2014	Planned Outage	50.00	1	50
1044259	5/13/2014	Planned Outage	358.08	5	71.62
1044298	5/13/2014	Planned Outage	5.77	1	5.77
1044299	5/13/2014	Planned Outage	224.80	8	28.1
1044305	5/13/2014	Planned Outage	139.10	6	23.18
1044308	5/13/2014	Planned Outage	371.53	2	185.77
1044314	5/13/2014	Planned Outage	3.05	1	3.05
1044315	5/13/2014	Planned Outage	933.00	3	311
1044316	5/13/2014	Planned Outage	18.37	1	18.37
1044327	5/13/2014	Planned Outage	1,124.20	7	160.6
1044331	5/13/2014	Planned Outage	332.97	2	166.48
1044332	5/13/2014	Planned Outage	177.60	4	44.4
1044335	5/13/2014	Planned Outage	875.93	4	218.98
1044341	5/13/2014	Planned Outage	170.37	2	85.18
1044345	5/13/2014	Planned Outage	44.50	1	44.5
1044346	5/13/2014	Planned Outage	354.77	2	177.38
1044347	5/13/2014	Planned Outage	6,015.00	1203	5
1044348	5/13/2014	Planned Outage	153.33	1	153.33
1044349	5/13/2014	Planned Outage	304.30	2	152.15
1044394	5/13/2014	Planned Outage	57.65	3	19.22
1044399	5/13/2014	Planned Outage	411.30	6	68.55
1044404	5/13/2014	Planned Outage	160.65	7	22.95
1044405	5/13/2014	Planned Outage	242.08	7	34.58
1044407	5/13/2014	Planned Outage	440.10	6	73.35
1044408	5/13/2014	Planned Outage	848.30	6	141.38
1044409	5/13/2014	Planned Outage	284.23	2	142.12
1044419	5/13/2014	Planned Outage	158.87	4	39.72
1044427	5/13/2014	Planned Outage	419.00	2	209.5
1044429	5/13/2014	Planned Outage	18.15	3	6.05
1044452	5/13/2014	Planned Outage	245.00	3	81.67
1044501	5/14/2014	Planned Outage	17.67	1	17.67

Appendix 1

2014 Planned Outages Table

1044519	5/14/2014	Planned Outage	40.60	1	40.6
1044521	5/14/2014	Planned Outage	868.40	3	289.47
1044525	5/14/2014	Planned Outage	181.13	4	45.28
1044526	5/14/2014	Planned Outage	433.07	29	14.93
1044532	5/14/2014	Planned Outage	357.00	5	71.4
1044538	5/14/2014	Planned Outage	26.33	1	26.33
1044541	5/14/2014	Planned Outage	61.65	1	61.65
1044544	5/14/2014	Planned Outage	68.00	34	2
1044549	5/14/2014	Planned Outage	26.88	1	26.88
1044551	5/14/2014	Planned Outage	416.67	5	83.33
1044557	5/14/2014	Planned Outage	57.30	6	9.55
1044586	5/14/2014	Planned Outage	548.10	7	78.3
1044593	5/14/2014	Planned Outage	247.80	3	82.6
1044596	5/14/2014	Planned Outage	128.00	4	32
1044604	5/14/2014	Planned Outage	6.48	1	6.48
1044606	5/14/2014	Planned Outage	91.73	1	91.73
1044607	5/14/2014	Planned Outage	60.73	2	30.37
1044619	5/14/2014	Planned Outage	35.20	2	17.6
1044620	5/14/2014	Planned Outage	26.45	1	26.45
1044623	5/14/2014	Planned Outage	15.13	4	3.78
1044630	5/14/2014	Planned Outage	50.47	4	12.62
1044638	5/14/2014	Planned Outage	25.90	3	8.63
1044642	5/14/2014	Planned Outage	28.00	2	14
1044655	5/14/2014	Planned Outage	108.60	3	36.2
1044659	5/14/2014	Planned Outage	140.12	7	20.02
1044663	5/14/2014	Planned Outage	11.15	1	11.15
1044664	5/14/2014	Planned Outage	4.97	1	4.97
1044736	5/15/2014	Planned Outage	428.40	4	107.1
1044741	5/15/2014	Planned Outage	32.92	1	32.92
1044779	5/15/2014	Planned Outage	71.07	4	17.77
1044801	5/15/2014	Planned Outage	6.00	1	6
1044807	5/15/2014	Planned Outage	44.53	2	22.27
1044808	5/15/2014	Planned Outage	88.00	2	44
1044813	5/15/2014	Planned Outage	453.00	1	453
1044815	5/15/2014	Planned Outage	253.80	12	21.15
1044818	5/15/2014	Planned Outage	360.13	4	90.03
1044820	5/15/2014	Planned Outage	39.43	1	39.43
1044821	5/15/2014	Planned Outage	625.45	7	89.35
1044822	5/15/2014	Planned Outage	698.40	8	87.3
1044825	5/15/2014	Planned Outage	520.00	4	130
1044828	5/15/2014	Planned Outage	252.00	4	63
1044831	5/15/2014	Planned Outage	122.65	11	11.15
1044836	5/15/2014	Planned Outage	137.00	3	45.67
1044838	5/15/2014	Planned Outage	83.17	10	8.32
1044840	5/15/2014	Planned Outage	87.50	2	43.75
1044854	5/15/2014	Planned Outage	139.40	4	34.85
1044866	5/15/2014	Planned Outage	922.50	6	153.75
1044867	5/15/2014	Planned Outage	307.40	2	153.7
1044881	5/15/2014	Planned Outage	92.30	6	15.38

Appendix 1

2014 Planned Outages Table

1044882	5/15/2014	Planned Outage	31.40	1	31.4
1044902	5/15/2014	Planned Outage	62.25	1	62.25
1045001	5/16/2014	Planned Outage	66.50	3	22.17
1045002	5/16/2014	Planned Outage	51.75	3	17.25
1045005	5/16/2014	Planned Outage	365.47	4	91.37
1045006	5/16/2014	Planned Outage	197.80	3	65.93
1045008	5/16/2014	Planned Outage	127.48	1	127.48
1045012	5/16/2014	Planned Outage	17.12	1	17.12
1045013	5/16/2014	Planned Outage	100.90	6	16.82
1045015	5/16/2014	Planned Outage	56.67	5	11.33
1045019	5/16/2014	Planned Outage	251.25	3	83.75
1045020	5/16/2014	Planned Outage	35.63	2	17.82
1045022	5/16/2014	Planned Outage	159.40	2	79.7
1045027	5/16/2014	Planned Outage	32.42	1	32.42
1045042	5/16/2014	Planned Outage	298.20	7	42.6
1045043	5/16/2014	Planned Outage	29.38	1	29.38
1045044	5/16/2014	Planned Outage	112.13	4	28.03
1045048	5/16/2014	Planned Outage	60.57	2	30.28
1045052	5/16/2014	Planned Outage	98.52	1	98.52
1045053	5/16/2014	Planned Outage	78.75	3	26.25
1045054	5/16/2014	Planned Outage	27.68	1	27.68
1045080	5/16/2014	Planned Outage	149.73	4	37.43
1045082	5/16/2014	Planned Outage	24.95	1	24.95
1045098	5/16/2014	Planned Outage	19.50	6	3.25
1045201	5/17/2014	Planned Outage	304.97	7	43.57
1045202	5/17/2014	Planned Outage	1,601.60	12	133.47
1045250	5/18/2014	Planned Outage	10.80	3	3.6
1045273	5/18/2014	Planned Outage	165.75	9	18.42
1045322	5/19/2014	Planned Outage	87.85	1	87.85
1045326	5/19/2014	Planned Outage	31.70	2	15.85
1045327	5/19/2014	Planned Outage	84.63	2	42.32
1045332	5/19/2014	Planned Outage	105.97	1	105.97
1045334	5/19/2014	Planned Outage	137.40	3	45.8
1045336	5/19/2014	Planned Outage	13.50	1	13.5
1045338	5/19/2014	Planned Outage	205.15	1	205.15
1045342	5/19/2014	Planned Outage	133.87	1	133.87
1045343	5/19/2014	Planned Outage	68.20	3	22.73
1045344	5/19/2014	Planned Outage	351.53	4	87.88
1045346	5/19/2014	Planned Outage	503.10	43	11.7
1045349	5/19/2014	Planned Outage	29.65	3	9.88
1045352	5/19/2014	Planned Outage	196.90	3	65.63
1045355	5/19/2014	Planned Outage	53.20	6	8.87
1045357	5/19/2014	Planned Outage	371.25	5	74.25
1045359	5/19/2014	Planned Outage	188.37	2	94.18
1045363	5/19/2014	Planned Outage	236.20	2	118.1
1045409	5/19/2014	Planned Outage	393.60	8	49.2
1045412	5/19/2014	Planned Outage	289.85	3	96.62
1045413	5/19/2014	Planned Outage	322.53	2	161.27
1045418	5/19/2014	Planned Outage	215.20	2	107.6

Appendix 1

2014 Planned Outages Table

1045419	5/19/2014	Planned Outage	168.83	2	84.42
1045422	5/19/2014	Planned Outage	93.50	3	31.17
1045425	5/19/2014	Planned Outage	53.70	3	17.9
1045429	5/19/2014	Planned Outage	271.07	2	135.53
1045456	5/20/2014	Planned Outage	245.80	2	122.9
1045457	5/20/2014	Planned Outage	113.85	1	113.85
1045459	5/20/2014	Planned Outage	26.30	2	13.15
1045470	5/20/2014	Planned Outage	4,349.35	37	117.55
1045472	5/20/2014	Planned Outage	390.95	7	55.85
1045475	5/20/2014	Planned Outage	147.42	5	29.48
1045477	5/20/2014	Planned Outage	1,734.02	7	247.72
1045479	5/20/2014	Planned Outage	13.75	1	13.75
1045480	5/20/2014	Planned Outage	1,108.10	7	158.3
1045481	5/20/2014	Planned Outage	144.35	1	144.35
1045482	5/20/2014	Planned Outage	726.50	5	145.3
1045486	5/20/2014	Planned Outage	87.15	3	29.05
1045487	5/20/2014	Planned Outage	20.30	1	20.3
1045488	5/20/2014	Planned Outage	88.87	1	88.87
1045490	5/20/2014	Planned Outage	4.62	1	4.62
1045491	5/20/2014	Planned Outage	262.33	2	131.17
1045493	5/20/2014	Planned Outage	130.75	1	130.75
1045498	5/20/2014	Planned Outage	182.17	2	91.08
1045519	5/20/2014	Planned Outage	35.60	4	8.9
1045520	5/20/2014	Planned Outage	449.93	2	224.97
1045527	5/20/2014	Planned Outage	13.48	1	13.48
1045537	5/20/2014	Planned Outage	1,209.00	1209	1
1045550	5/20/2014	Planned Outage	4.13	1	4.13
1045555	5/20/2014	Planned Outage	349.27	2	174.63
1045557	5/20/2014	Planned Outage	9.62	1	9.62
1045561	5/20/2014	Planned Outage	57.00	1	57
1045577	5/20/2014	Planned Outage	34.70	1	34.7
1045578	5/20/2014	Planned Outage	410.00	5	82
1045591	5/20/2014	Planned Outage	7.18	1	7.18
1045593	5/20/2014	Planned Outage	174.32	1	174.32
1045644	5/21/2014	Planned Outage	697.67	4	174.42
1045648	5/21/2014	Planned Outage	41.70	2	20.85
1045649	5/21/2014	Planned Outage	25.85	3	8.62
1045652	5/21/2014	Planned Outage	32.02	1	32.02
1045662	5/21/2014	Planned Outage	1,823.07	8	227.88
1045665	5/21/2014	Planned Outage	14,241.60	72	197.8
1045673	5/21/2014	Planned Outage	1,782.80	8	222.85
1045675	5/21/2014	Planned Outage	28.73	1	28.73
1045676	5/21/2014	Planned Outage	132.92	5	26.58
1045677	5/21/2014	Planned Outage	72.90	3	24.3
1045685	5/21/2014	Planned Outage	576.80	6	96.13
1045686	5/21/2014	Planned Outage	851.77	11	77.43
1045692	5/21/2014	Planned Outage	63.55	3	21.18
1045693	5/21/2014	Planned Outage	6,520.80	66	98.8
1045697	5/21/2014	Planned Outage	219.00	4	54.75

Appendix 1

2014 Planned Outages Table

1045701	5/21/2014	Planned Outage	1,637.72	11	148.88
1045703	5/21/2014	Planned Outage	109.27	4	27.32
1045706	5/21/2014	Planned Outage	23.47	1	23.47
1045708	5/21/2014	Planned Outage	1,404.53	46	30.53
1045711	5/21/2014	Planned Outage	161.47	2	80.73
1045717	5/21/2014	Planned Outage	27.00	10	2.7
1045719	5/21/2014	Planned Outage	110.43	1	110.43
1045725	5/21/2014	Planned Outage	520.40	6	86.73
1045727	5/21/2014	Planned Outage	9.32	1	9.32
1045728	5/21/2014	Planned Outage	120.87	4	30.22
1045731	5/21/2014	Planned Outage	22.10	3	7.37
1045732	5/21/2014	Planned Outage	545.60	2	272.8
1045733	5/21/2014	Planned Outage	21.55	3	7.18
1045735	5/21/2014	Planned Outage	19.92	1	19.92
1045736	5/21/2014	Planned Outage	200.57	2	100.28
1045739	5/21/2014	Planned Outage	101.20	2	50.6
1045743	5/21/2014	Planned Outage	35.07	1	35.07
1045745	5/21/2014	Planned Outage	506.40	6	84.4
1045753	5/21/2014	Planned Outage	924.40	8	115.55
1045759	5/21/2014	Planned Outage	37.75	1	37.75
1045808	5/22/2014	Planned Outage	204.25	3	68.08
1045829	5/22/2014	Planned Outage	18,861.60	58	325.2
1045835	5/22/2014	Planned Outage	545.70	6	90.95
1045836	5/22/2014	Planned Outage	194.70	3	64.9
1045838	5/22/2014	Planned Outage	82.42	1	82.42
1045839	5/22/2014	Planned Outage	326.47	4	81.62
1045840	5/22/2014	Planned Outage	245.00	3	81.67
1045841	5/22/2014	Planned Outage	289.33	5	57.87
1045844	5/22/2014	Planned Outage	302.50	6	50.42
1045852	5/22/2014	Planned Outage	375.20	21	17.87
1045855	5/22/2014	Planned Outage	203.87	4	50.97
1045859	5/22/2014	Planned Outage	714.58	7	102.08
1045861	5/22/2014	Planned Outage	22.68	1	22.68
1045879	5/22/2014	Planned Outage	465.87	8	58.23
1045880	5/22/2014	Planned Outage	73.10	6	12.18
1045882	5/22/2014	Planned Outage	25.25	1	25.25
1045890	5/22/2014	Planned Outage	181.05	3	60.35
1045893	5/22/2014	Planned Outage	41.40	4	10.35
1045895	5/22/2014	Planned Outage	208.75	5	41.75
1045967	5/23/2014	Planned Outage	37.87	4	9.47
1045968	5/23/2014	Planned Outage	526.00	5	105.2
1045971	5/23/2014	Planned Outage	647.13	4	161.78
1045976	5/23/2014	Planned Outage	33.85	3	11.28
1045977	5/23/2014	Planned Outage	1,454.53	8	181.82
1045978	5/23/2014	Planned Outage	1,273.53	7	181.93
1045983	5/23/2014	Planned Outage	178.02	1	178.02
1045985	5/23/2014	Planned Outage	21.63	1	21.63
1045990	5/23/2014	Planned Outage	103.55	1	103.55
1045992	5/23/2014	Planned Outage	72.00	2	36

Appendix 1

2014 Planned Outages Table

1045994	5/23/2014	Planned Outage	13,513.75	95	142.25
1045997	5/23/2014	Planned Outage	77.95	3	25.98
1046005	5/23/2014	Planned Outage	93.67	2	46.83
1046006	5/23/2014	Planned Outage	18.75	1	18.75
1046008	5/23/2014	Planned Outage	82.00	4	20.5
1046020	5/23/2014	Planned Outage	15.30	1	15.3
1046022	5/23/2014	Planned Outage	48.43	2	24.22
1046036	5/23/2014	Planned Outage	59.40	2	29.7
1046052	5/23/2014	Planned Outage	7.90	1	7.9
1046091	5/24/2014	Planned Outage	60.07	4	15.02
1046185	5/25/2014	Planned Outage	8.60	6	1.43
1046194	5/25/2014	Planned Outage	67.00	6	11.17
1046214	5/25/2014	Planned Outage	258.10	6	43.02
1047051	5/26/2014	Planned Outage	352.90	1	352.9
1047084	5/26/2014	Planned Outage	169.88	1	169.88
1047117	5/26/2014	Planned Outage	238.85	3	79.62
1047119	5/26/2014	Planned Outage	78.95	1	78.95
1047143	5/26/2014	Planned Outage	33.73	1	33.73
1047144	5/26/2014	Planned Outage	271.73	8	33.97
1047148	5/26/2014	Planned Outage	26.63	1	26.63
1047177	5/27/2014	Planned Outage	371.82	7	53.12
1047184	5/27/2014	Planned Outage	104.85	1	104.85
1047192	5/27/2014	Planned Outage	52.55	3	17.52
1047193	5/27/2014	Planned Outage	190.80	4	47.7
1047195	5/27/2014	Planned Outage	54.75	3	18.25
1047197	5/27/2014	Planned Outage	17,838.00	45	396.4
1047200	5/27/2014	Planned Outage	617.60	8	77.2
1047203	5/27/2014	Planned Outage	740.40	4	185.1
1047205	5/27/2014	Planned Outage	24.40	4	6.1
1047206	5/27/2014	Planned Outage	946.20	6	157.7
1047223	5/27/2014	Planned Outage	134.27	4	33.57
1047225	5/27/2014	Planned Outage	757.83	5	151.57
1047226	5/27/2014	Planned Outage	596.50	10	59.65
1047227	5/27/2014	Planned Outage	60.62	1	60.62
1047240	5/27/2014	Planned Outage	61.27	4	15.32
1047248	5/27/2014	Planned Outage	182.78	1	182.78
1047252	5/27/2014	Planned Outage	44.32	1	44.32
1047253	5/27/2014	Planned Outage	213.28	1	213.28
1047255	5/27/2014	Planned Outage	267.82	1	267.82
1047262	5/27/2014	Planned Outage	6.63	1	6.63
1047278	5/27/2014	Planned Outage	59.55	3	19.85
1047280	5/27/2014	Planned Outage	117.00	13	9
1047282	5/27/2014	Planned Outage	57.43	1	57.43
1047289	5/27/2014	Planned Outage	490.95	3	163.65
1047294	5/27/2014	Planned Outage	16.63	2	8.32
1047295	5/27/2014	Planned Outage	62.47	1	62.47
1047297	5/27/2014	Planned Outage	15,486.57	217	71.37
1047301	5/27/2014	Planned Outage	12,765.00	185	69
1047344	5/27/2014	Planned Outage	63.50	1	63.5

Appendix 1

2014 Planned Outages Table

1047362	5/27/2014	Planned Outage	163.00	1	163
1047375	5/27/2014	Planned Outage	18.77	2	9.38
1047376	5/27/2014	Planned Outage	79.60	1	79.6
1047446	5/28/2014	Planned Outage	99.43	1	99.43
1047459	5/28/2014	Planned Outage	4,851.17	26	186.58
1047469	5/28/2014	Planned Outage	110.03	2	55.02
1047470	5/28/2014	Planned Outage	14.12	1	14.12
1047471	5/28/2014	Planned Outage	139.17	5	27.83
1047474	5/28/2014	Planned Outage	368.45	3	122.82
1047475	5/28/2014	Planned Outage	4.42	1	4.42
1047477	5/28/2014	Planned Outage	146.73	4	36.68
1047487	5/28/2014	Planned Outage	854.67	8	106.83
1047492	5/28/2014	Planned Outage	71.73	1	71.73
1047495	5/28/2014	Planned Outage	121.22	7	17.32
1047501	5/28/2014	Planned Outage	11,211.20	176	63.7
1047502	5/28/2014	Planned Outage	422.25	9	46.92
1047503	5/28/2014	Planned Outage	1.70	1	1.7
1047504	5/28/2014	Planned Outage	117.63	2	58.82
1047524	5/28/2014	Planned Outage	357.60	3	119.2
1047535	5/28/2014	Planned Outage	118.23	2	59.12
1047541	5/28/2014	Planned Outage	18.07	1	18.07
1047552	5/28/2014	Planned Outage	373.60	4	93.4
1047554	5/28/2014	Planned Outage	23.80	1	23.8
1047559	5/28/2014	Planned Outage	39.00	3	13
1047561	5/28/2014	Planned Outage	55.07	4	13.77
1047608	5/29/2014	Planned Outage	21.55	1	21.55
1047669	5/29/2014	Planned Outage	33.45	1	33.45
1047705	5/29/2014	Planned Outage	763.93	7	109.13
1047706	5/29/2014	Planned Outage	173.07	2	86.53
1047711	5/29/2014	Planned Outage	906.25	3	302.08
1047733	5/29/2014	Planned Outage	238.83	10	23.88
1047743	5/29/2014	Planned Outage	38.82	1	38.82
1047745	5/29/2014	Planned Outage	97.55	3	32.52
1047828	5/29/2014	Planned Outage	1,105.13	22	50.23
1047896	5/30/2014	Planned Outage	869.67	10	86.97
1047903	5/30/2014	Planned Outage	111.32	1	111.32
1047909	5/30/2014	Planned Outage	52.17	1	52.17
1047914	5/30/2014	Planned Outage	19.47	1	19.47
1047915	5/30/2014	Planned Outage	61.12	1	61.12
1047922	5/30/2014	Planned Outage	173.07	4	43.27
1047928	5/30/2014	Planned Outage	11.35	1	11.35
1047930	5/30/2014	Planned Outage	200.00	5	40
1047931	5/30/2014	Planned Outage	50.82	1	50.82
1047932	5/30/2014	Planned Outage	52.60	1	52.6
1047936	5/30/2014	Planned Outage	56.68	1	56.68
1047947	5/30/2014	Planned Outage	84.53	4	21.13
1047949	5/30/2014	Planned Outage	31.15	1	31.15
1047952	5/30/2014	Planned Outage	112.07	4	28.02
1047953	5/30/2014	Planned Outage	42.87	2	21.43

Appendix 1

2014 Planned Outages Table

1047957	5/30/2014	Planned Outage	74.33	2	37.17
1047968	5/30/2014	Planned Outage	192.60	4	48.15
1047972	5/30/2014	Planned Outage	46.85	1	46.85
1047976	5/30/2014	Planned Outage	93.42	5	18.68
1047979	5/30/2014	Planned Outage	184.10	6	30.68
1047987	5/30/2014	Planned Outage	197.07	2	98.53
1047994	5/30/2014	Planned Outage	21.70	7	3.1
1048000	5/30/2014	Planned Outage	314.37	2	157.18
1048022	5/30/2014	Planned Outage	19.03	1	19.03
1048028	5/30/2014	Planned Outage	12.05	1	12.05
1048049	5/30/2014	Planned Outage	659.83	5	131.97
1048257	6/1/2014	Planned Outage	1,376.17	5	275.23
1048314	6/1/2014	Planned Outage	9.10	1	9.1
1048315	6/1/2014	Planned Outage	8.93	1	8.93
1048373	6/2/2014	Planned Outage	25.87	2	12.93
1048386	6/2/2014	Planned Outage	804.88	7	114.98
1048390	6/2/2014	Planned Outage	129.87	4	32.47
1048393	6/2/2014	Planned Outage	88.00	2	44
1048395	6/2/2014	Planned Outage	236.65	3	78.88
1048407	6/2/2014	Planned Outage	349.07	4	87.27
1048409	6/2/2014	Planned Outage	271.88	11	24.72
1048412	6/2/2014	Planned Outage	136.20	4	34.05
1048419	6/2/2014	Planned Outage	7,266.30	53	137.1
1048423	6/2/2014	Planned Outage	115.83	2	57.92
1048426	6/2/2014	Planned Outage	155.25	3	51.75
1048428	6/2/2014	Planned Outage	124.75	5	24.95
1048429	6/2/2014	Planned Outage	51.33	1	51.33
1048430	6/2/2014	Planned Outage	144.35	1	144.35
1048433	6/2/2014	Planned Outage	197.27	2	98.63
1048434	6/2/2014	Planned Outage	7.62	1	7.62
1048435	6/2/2014	Planned Outage	192.07	2	96.03
1048437	6/2/2014	Planned Outage	36.37	1	36.37
1048447	6/2/2014	Planned Outage	273.95	3	91.32
1048448	6/2/2014	Planned Outage	29.90	6	4.98
1048453	6/2/2014	Planned Outage	7.45	1	7.45
1048456	6/2/2014	Planned Outage	99.13	1	99.13
1048470	6/2/2014	Planned Outage	75.05	1	75.05
1048474	6/2/2014	Planned Outage	4.63	1	4.63
1048479	6/2/2014	Planned Outage	172.93	4	43.23
1048766	6/3/2014	Planned Outage	104.25	1	104.25
1048789	6/3/2014	Planned Outage	1,021.65	7	145.95
1048794	6/3/2014	Planned Outage	79.43	1	79.43
1048797	6/3/2014	Planned Outage	566.60	6	94.43
1048800	6/3/2014	Planned Outage	224.43	2	112.22
1048808	6/3/2014	Planned Outage	15.97	1	15.97
1048810	6/3/2014	Planned Outage	6,119.10	54	113.32
1048812	6/3/2014	Planned Outage	19.88	1	19.88
1048815	6/3/2014	Planned Outage	97.37	1	97.37
1048818	6/3/2014	Planned Outage	85.30	1	85.3

Appendix 1

2014 Planned Outages Table

1048819	6/3/2014	Planned Outage	29.02	1	29.02
1048821	6/3/2014	Planned Outage	10,949.58	55	199.08
1048824	6/3/2014	Planned Outage	107.72	1	107.72
1048826	6/3/2014	Planned Outage	11.85	1	11.85
1048829	6/3/2014	Planned Outage	365.90	3	121.97
1048832	6/3/2014	Planned Outage	105.53	2	52.77
1048839	6/3/2014	Planned Outage	37.15	3	12.38
1048841	6/3/2014	Planned Outage	22.40	1	22.4
1048845	6/3/2014	Planned Outage	64.53	2	32.27
1048852	6/3/2014	Planned Outage	2,892.00	30	96.4
1048866	6/3/2014	Planned Outage	81.33	4	20.33
1048867	6/3/2014	Planned Outage	52.50	2	26.25
1048875	6/3/2014	Planned Outage	116.40	3	38.8
1048881	6/3/2014	Planned Outage	354.00	6	59
1048882	6/3/2014	Planned Outage	171.00	3	57
1048884	6/3/2014	Planned Outage	180.00	5	36
1048907	6/4/2014	Planned Outage	57.52	1	57.52
1048915	6/4/2014	Planned Outage	1,040.00	6	173.33
1048924	6/4/2014	Planned Outage	1,380.50	11	125.5
1048928	6/4/2014	Planned Outage	304.93	2	152.47
1048930	6/4/2014	Planned Outage	1,157.17	5	231.43
1048938	6/4/2014	Planned Outage	19.57	1	19.57
1048940	6/4/2014	Planned Outage	132.95	3	44.32
1048943	6/4/2014	Planned Outage	216.30	9	24.03
1048944	6/4/2014	Planned Outage	92.73	2	46.37
1048945	6/4/2014	Planned Outage	30.97	2	15.48
1048948	6/4/2014	Planned Outage	9.28	1	9.28
1048951	6/4/2014	Planned Outage	929.60	16	58.1
1048955	6/4/2014	Planned Outage	73.42	5	14.68
1048956	6/4/2014	Planned Outage	602.55	13	46.35
1048957	6/4/2014	Planned Outage	293.00	6	48.83
1048958	6/4/2014	Planned Outage	148.20	4	37.05
1048959	6/4/2014	Planned Outage	8,457.75	81	104.42
1048962	6/4/2014	Planned Outage	2.10	1	2.1
1048971	6/4/2014	Planned Outage	13.35	1	13.35
1048975	6/4/2014	Planned Outage	1,152.27	8	144.03
1049006	6/4/2014	Planned Outage	25.50	2	12.75
1049008	6/4/2014	Planned Outage	65.35	3	21.78
1049009	6/4/2014	Planned Outage	354.00	1	354
1049011	6/4/2014	Planned Outage	102.00	2	51
1049017	6/4/2014	Planned Outage	567.80	6	94.63
1049029	6/4/2014	Planned Outage	95.45	3	31.82
1049031	6/4/2014	Planned Outage	337.20	2	168.6
1049032	6/4/2014	Planned Outage	53.13	1	53.13
1049035	6/4/2014	Planned Outage	360.30	3	120.1
1049055	6/5/2014	Planned Outage	176.88	1	176.88
1049056	6/5/2014	Planned Outage	707.13	4	176.78
1049061	6/5/2014	Planned Outage	2,539.03	38	66.82
1049065	6/5/2014	Planned Outage	572.67	8	71.58

Appendix 1

2014 Planned Outages Table

1049090	6/5/2014	Planned Outage	540.10	3	180.03
1049096	6/5/2014	Planned Outage	84.50	1	84.5
1049099	6/5/2014	Planned Outage	899.02	17	52.88
1049100	6/5/2014	Planned Outage	320.75	3	106.92
1049104	6/5/2014	Planned Outage	75.65	1	75.65
1049105	6/5/2014	Planned Outage	97.67	4	24.42
1049106	6/5/2014	Planned Outage	147.50	5	29.5
1049108	6/5/2014	Planned Outage	80.95	3	26.98
1049109	6/5/2014	Planned Outage	600.00	30	20
1049114	6/5/2014	Planned Outage	72.50	3	24.17
1049115	6/5/2014	Planned Outage	83.45	3	27.82
1049116	6/5/2014	Planned Outage	86.83	5	17.37
1049119	6/5/2014	Planned Outage	9.50	1	9.5
1049120	6/5/2014	Planned Outage	39.30	3	13.1
1049123	6/5/2014	Planned Outage	42.83	2	21.42
1049127	6/5/2014	Planned Outage	41.40	3	13.8
1049128	6/5/2014	Planned Outage	14.53	2	7.27
1049140	6/5/2014	Planned Outage	552.50	6	92.08
1049144	6/5/2014	Planned Outage	355.00	5	71
1049152	6/5/2014	Planned Outage	66.35	3	22.12
1049155	6/5/2014	Planned Outage	86.55	3	28.85
1049157	6/5/2014	Planned Outage	29.95	1	29.95
1049220	6/5/2014	Planned Outage	230.50	5	46.1
1049237	6/6/2014	Planned Outage	37.50	1	37.5
1049246	6/6/2014	Planned Outage	260.87	13	20.07
1049257	6/6/2014	Planned Outage	3,102.23	26	119.32
1049258	6/6/2014	Planned Outage	517.50	5	103.5
1049259	6/6/2014	Planned Outage	53.80	1	53.8
1049262	6/6/2014	Planned Outage	323.75	5	64.75
1049263	6/6/2014	Planned Outage	45.33	1	45.33
1049265	6/6/2014	Planned Outage	206.60	4	51.65
1049269	6/6/2014	Planned Outage	20.17	1	20.17
1049281	6/6/2014	Planned Outage	144.00	8	18
1049670	6/9/2014	Planned Outage	635.87	4	158.97
1049676	6/9/2014	Planned Outage	569.22	7	81.32
1049677	6/9/2014	Planned Outage	89.08	5	17.82
1049682	6/9/2014	Planned Outage	2.45	1	2.45
1049685	6/9/2014	Planned Outage	8.80	1	8.8
1049687	6/9/2014	Planned Outage	130.20	3	43.4
1049688	6/9/2014	Planned Outage	12.47	1	12.47
1049690	6/9/2014	Planned Outage	139.22	1	139.22
1049696	6/9/2014	Planned Outage	1,069.83	7	152.83
1049703	6/9/2014	Planned Outage	60.00	2	30
1049704	6/9/2014	Planned Outage	157.93	4	39.48
1049706	6/9/2014	Planned Outage	37.43	2	18.72
1049709	6/9/2014	Planned Outage	117.00	10	11.7
1049711	6/9/2014	Planned Outage	15.00	1	15
1049714	6/9/2014	Planned Outage	459.33	4	114.83
1049814	6/9/2014	Planned Outage	37.50	6	6.25

Appendix 1

2014 Planned Outages Table

1049819	6/9/2014	Planned Outage	78.75	5	15.75
1049822	6/9/2014	Planned Outage	10.47	1	10.47
1049823	6/9/2014	Planned Outage	160.80	8	20.1
1049832	6/9/2014	Planned Outage	513.53	4	128.38
1049837	6/9/2014	Planned Outage	567.90	3	189.3
1049855	6/9/2014	Planned Outage	29.00	1	29
1049863	6/9/2014	Planned Outage	75.27	4	18.82
1049864	6/9/2014	Planned Outage	18.42	1	18.42
1049894	6/10/2014	Planned Outage	62.25	45	1.38
1049899	6/10/2014	Planned Outage	612.67	4	153.17
1049923	6/10/2014	Planned Outage	14.95	1	14.95
1049925	6/10/2014	Planned Outage	539.83	10	53.98
1049926	6/10/2014	Planned Outage	455.60	4	113.9
1049928	6/10/2014	Planned Outage	305.10	3	101.7
1049931	6/10/2014	Planned Outage	2,912.67	10	291.27
1049932	6/10/2014	Planned Outage	26.80	1	26.8
1049933	6/10/2014	Planned Outage	40.77	1	40.77
1049940	6/10/2014	Planned Outage	51.20	1	51.2
1049941	6/10/2014	Planned Outage	3,493.47	7	499.07
1049943	6/10/2014	Planned Outage	589.75	5	117.95
1049947	6/10/2014	Planned Outage	109.08	7	15.58
1049949	6/10/2014	Planned Outage	19.40	1	19.4
1049950	6/10/2014	Planned Outage	18.93	4	4.73
1049952	6/10/2014	Planned Outage	64.65	1	64.65
1049954	6/10/2014	Planned Outage	81.60	2	40.8
1049957	6/10/2014	Planned Outage	205.20	4	51.3
1049959	6/10/2014	Planned Outage	132.65	3	44.22
1049961	6/10/2014	Planned Outage	199.90	3	66.63
1049967	6/10/2014	Planned Outage	99.92	1	99.92
1049969	6/10/2014	Planned Outage	130.20	7	18.6
1049971	6/10/2014	Planned Outage	26.90	6	4.48
1049972	6/10/2014	Planned Outage	48.13	1	48.13
1049973	6/10/2014	Planned Outage	19.05	1	19.05
1049988	6/10/2014	Planned Outage	45.83	2	22.92
1049989	6/10/2014	Planned Outage	104.60	3	34.87
1049990	6/10/2014	Planned Outage	415.60	4	103.9
1049998	6/10/2014	Planned Outage	165.00	1	165
1050000	6/10/2014	Planned Outage	22.58	1	22.58
1050001	6/10/2014	Planned Outage	63.95	3	21.32
1050002	6/10/2014	Planned Outage	22.80	1	22.8
1050009	6/10/2014	Planned Outage	127.20	3	42.4
1050015	6/10/2014	Planned Outage	42.62	1	42.62
1050019	6/10/2014	Planned Outage	235.92	5	47.18
1050025	6/10/2014	Planned Outage	595.67	5	119.13
1050029	6/10/2014	Planned Outage	234.13	1	234.13
1050032	6/10/2014	Planned Outage	31.63	1	31.63
1050055	6/10/2014	Planned Outage	170.08	5	34.02
1050058	6/10/2014	Planned Outage	6.02	1	6.02
1050060	6/10/2014	Planned Outage	73.23	2	36.62

Appendix 1

2014 Planned Outages Table

1050063	6/10/2014	Planned Outage	259.83	10	25.98
1050226	6/11/2014	Planned Outage	151.30	6	25.22
1050241	6/11/2014	Planned Outage	3,925.60	7	560.8
1050250	6/11/2014	Planned Outage	715.50	27	26.5
1050256	6/11/2014	Planned Outage	77.53	4	19.38
1050259	6/11/2014	Planned Outage	268.13	4	67.03
1050265	6/11/2014	Planned Outage	296.15	3	98.72
1050270	6/11/2014	Planned Outage	60.90	3	20.3
1050273	6/11/2014	Planned Outage	135.20	4	33.8
1050274	6/11/2014	Planned Outage	1,348.67	14	96.33
1050277	6/11/2014	Planned Outage	3,336.03	41	81.37
1050286	6/11/2014	Planned Outage	344.00	3	114.67
1050289	6/11/2014	Planned Outage	3.70	1	3.7
1050308	6/11/2014	Planned Outage	108.25	5	21.65
1050310	6/11/2014	Planned Outage	112.92	5	22.58
1050336	6/11/2014	Planned Outage	13.03	1	13.03
1050339	6/11/2014	Planned Outage	319.20	3	106.4
1050341	6/11/2014	Planned Outage	74.40	2	37.2
1050343	6/11/2014	Planned Outage	10.95	1	10.95
1050344	6/11/2014	Planned Outage	18.98	1	18.98
1050345	6/11/2014	Planned Outage	88.58	5	17.72
1050353	6/11/2014	Planned Outage	138.50	3	46.17
1050354	6/11/2014	Planned Outage	58.65	3	19.55
1050356	6/11/2014	Planned Outage	14.68	1	14.68
1050357	6/11/2014	Planned Outage	23.52	1	23.52
1050362	6/11/2014	Planned Outage	7.78	1	7.78
1050364	6/11/2014	Planned Outage	276.65	3	92.22
1050366	6/11/2014	Planned Outage	19.27	1	19.27
1050368	6/11/2014	Planned Outage	65.50	2	32.75
1050376	6/11/2014	Planned Outage	42.42	1	42.42
1050387	6/12/2014	Planned Outage	388.25	3	129.42
1050393	6/12/2014	Planned Outage	80.77	1	80.77
1050401	6/12/2014	Planned Outage	2,000.10	18	111.12
1050408	6/12/2014	Planned Outage	606.42	5	121.28
1050409	6/12/2014	Planned Outage	284.10	6	47.35
1050411	6/12/2014	Planned Outage	262.77	2	131.38
1050412	6/12/2014	Planned Outage	367.00	4	91.75
1050414	6/12/2014	Planned Outage	198.10	2	99.05
1050415	6/12/2014	Planned Outage	118.07	23	5.13
1050416	6/12/2014	Planned Outage	207.95	3	69.32
1050418	6/12/2014	Planned Outage	226.00	4	56.5
1050422	6/12/2014	Planned Outage	3,547.13	7	506.73
1050424	6/12/2014	Planned Outage	38.17	1	38.17
1050427	6/12/2014	Planned Outage	66.08	1	66.08
1050428	6/12/2014	Planned Outage	136.30	6	22.72
1050432	6/12/2014	Planned Outage	9,151.43	58	157.78
1050433	6/12/2014	Planned Outage	353.40	9	39.27
1050434	6/12/2014	Planned Outage	47.47	4	11.87
1050436	6/12/2014	Planned Outage	641.75	5	128.35

Appendix 1

2014 Planned Outages Table

1050437	6/12/2014	Planned Outage	22.50	1	22.5
1050440	6/12/2014	Planned Outage	652.00	4	163
1050444	6/12/2014	Planned Outage	85.82	1	85.82
1050447	6/12/2014	Planned Outage	4,341.60	54	80.4
1050453	6/12/2014	Planned Outage	952.10	2	476.05
1050455	6/12/2014	Planned Outage	13.10	1	13.1
1050456	6/12/2014	Planned Outage	15.73	1	15.73
1050458	6/12/2014	Planned Outage	138.77	1	138.77
1050459	6/12/2014	Planned Outage	23.27	2	11.63
1050464	6/12/2014	Planned Outage	24.20	2	12.1
1050472	6/12/2014	Planned Outage	129.00	3	43
1050473	6/12/2014	Planned Outage	44.73	1	44.73
1050514	6/12/2014	Planned Outage	64.60	4	16.15
1050515	6/12/2014	Planned Outage	53.07	1	53.07
1050518	6/12/2014	Planned Outage	2,140.00	8	267.5
1050521	6/12/2014	Planned Outage	17.53	1	17.53
1050523	6/12/2014	Planned Outage	16.23	1	16.23
1050535	6/12/2014	Planned Outage	111.00	3	37
1050586	6/13/2014	Planned Outage	100.25	5	20.05
1050590	6/13/2014	Planned Outage	174.77	2	87.38
1050591	6/13/2014	Planned Outage	256.45	3	85.48
1050595	6/13/2014	Planned Outage	24.43	1	24.43
1050609	6/13/2014	Planned Outage	3,546.32	7	506.62
1050613	6/13/2014	Planned Outage	57.47	2	28.73
1050622	6/13/2014	Planned Outage	558.20	6	93.03
1050625	6/13/2014	Planned Outage	1,069.57	11	97.23
1050630	6/13/2014	Planned Outage	182.78	1	182.78
1050643	6/13/2014	Planned Outage	191.33	8	23.92
1050653	6/13/2014	Planned Outage	6.15	1	6.15
1050655	6/13/2014	Planned Outage	218.50	5	43.7
1050665	6/13/2014	Planned Outage	20.87	2	10.43
1050674	6/13/2014	Planned Outage	21.33	1	21.33
1050710	6/13/2014	Planned Outage	49.93	1	49.93
1050719	6/13/2014	Planned Outage	230.82	11	20.98
1050737	6/13/2014	Planned Outage	15.40	1	15.4
1050740	6/14/2014	Planned Outage	294.25	3	98.08
1050793	6/14/2014	Planned Outage	117.60	4	29.4
1050855	6/15/2014	Planned Outage	360.15	3	120.05
1050857	6/15/2014	Planned Outage	148.10	6	24.68
1050876	6/15/2014	Planned Outage	171.07	1	171.07
1050913	6/16/2014	Planned Outage	552.00	6	92
1050915	6/16/2014	Planned Outage	1,682.80	8	210.35
1050925	6/16/2014	Planned Outage	38.37	1	38.37
1050926	6/16/2014	Planned Outage	167.50	2	83.75
1050940	6/16/2014	Planned Outage	181.07	14	12.93
1050941	6/16/2014	Planned Outage	275.95	3	91.98
1050951	6/16/2014	Planned Outage	1,632.28	17	96.02
1050955	6/16/2014	Planned Outage	123.40	6	20.57
1050958	6/16/2014	Planned Outage	107.12	1	107.12

Appendix 1

2014 Planned Outages Table

1050961	6/16/2014	Planned Outage	1,604.63	14	114.62
1050971	6/16/2014	Planned Outage	6,207.30	2299	2.7
1050982	6/16/2014	Planned Outage	16.77	2	8.38
1050984	6/16/2014	Planned Outage	113.47	8	14.18
1050986	6/16/2014	Planned Outage	184.50	6	30.75
1050991	6/16/2014	Planned Outage	143.60	4	35.9
1050997	6/16/2014	Planned Outage	11.57	1	11.57
1051008	6/16/2014	Planned Outage	61.00	2	30.5
1051009	6/16/2014	Planned Outage	621.80	3	207.27
1051011	6/16/2014	Planned Outage	13.92	1	13.92
1051019	6/16/2014	Planned Outage	13.75	1	13.75
1051024	6/16/2014	Planned Outage	28.67	2	14.33
1051025	6/16/2014	Planned Outage	413.50	10	41.35
1051034	6/16/2014	Planned Outage	148.35	3	49.45
1051036	6/16/2014	Planned Outage	130.50	6	21.75
1051056	6/16/2014	Planned Outage	44.05	3	14.68
1051107	6/17/2014	Planned Outage	150.00	2	75
1051113	6/17/2014	Planned Outage	45.97	2	22.98
1051114	6/17/2014	Planned Outage	44.83	2	22.42
1051116	6/17/2014	Planned Outage	365.50	1	365.5
1051121	6/17/2014	Planned Outage	66.20	2	33.1
1051122	6/17/2014	Planned Outage	71.85	3	23.95
1051123	6/17/2014	Planned Outage	2,769.07	22	125.87
1051129	6/17/2014	Planned Outage	20.30	3	6.77
1051131	6/17/2014	Planned Outage	129.00	1	129
1051135	6/17/2014	Planned Outage	156.70	2	78.35
1051136	6/17/2014	Planned Outage	119.80	2	59.9
1051137	6/17/2014	Planned Outage	59.73	1	59.73
1051138	6/17/2014	Planned Outage	178.20	3	59.4
1051139	6/17/2014	Planned Outage	59.40	1	59.4
1051144	6/17/2014	Planned Outage	202.40	3	67.47
1051145	6/17/2014	Planned Outage	262.73	4	65.68
1051146	6/17/2014	Planned Outage	28.10	2	14.05
1051148	6/17/2014	Planned Outage	37.47	2	18.73
1051149	6/17/2014	Planned Outage	59.47	2	29.73
1051150	6/17/2014	Planned Outage	810.13	14	57.87
1051153	6/17/2014	Planned Outage	82.40	4	20.6
1051154	6/17/2014	Planned Outage	128.90	3	42.97
1051155	6/17/2014	Planned Outage	469.40	6	78.23
1051156	6/17/2014	Planned Outage	230.20	2	115.1
1051157	6/17/2014	Planned Outage	115.22	1	115.22
1051160	6/17/2014	Planned Outage	6.67	1	6.67
1051161	6/17/2014	Planned Outage	311.60	3	103.87
1051164	6/17/2014	Planned Outage	54.68	1	54.68
1051171	6/17/2014	Planned Outage	35.08	5	7.02
1051173	6/17/2014	Planned Outage	138.10	3	46.03
1051175	6/17/2014	Planned Outage	40.65	3	13.55
1051176	6/17/2014	Planned Outage	251.83	2	125.92
1051179	6/17/2014	Planned Outage	195.67	4	48.92

Appendix 1

2014 Planned Outages Table

1051183	6/17/2014	Planned Outage	6.73	1	6.73
1051185	6/17/2014	Planned Outage	10.30	2	5.15
1051187	6/17/2014	Planned Outage	73.35	3	24.45
1051189	6/17/2014	Planned Outage	146.25	5	29.25
1051190	6/17/2014	Planned Outage	10.80	1	10.8
1051196	6/17/2014	Planned Outage	40.70	3	13.57
1051197	6/17/2014	Planned Outage	28.10	2	14.05
1051204	6/17/2014	Planned Outage	24.27	2	12.13
1051220	6/17/2014	Planned Outage	132.10	2	66.05
1051229	6/17/2014	Planned Outage	72.93	4	18.23
1051254	6/17/2014	Planned Outage	86.42	1	86.42
1051269	6/17/2014	Planned Outage	365.50	6	60.92
1051286	6/18/2014	Planned Outage	401.45	7	57.35
1051309	6/18/2014	Planned Outage	49.00	7	7
1051314	6/18/2014	Planned Outage	59.83	5	11.97
1051321	6/18/2014	Planned Outage	10.08	1	10.08
1051322	6/18/2014	Planned Outage	53.42	1	53.42
1051323	6/18/2014	Planned Outage	17.87	1	17.87
1051325	6/18/2014	Planned Outage	9.07	1	9.07
1051326	6/18/2014	Planned Outage	321.05	1	321.05
1051334	6/18/2014	Planned Outage	245.10	6	40.85
1051335	6/18/2014	Planned Outage	699.30	3	233.1
1051339	6/18/2014	Planned Outage	126.63	1	126.63
1051341	6/18/2014	Planned Outage	139.70	6	23.28
1051343	6/18/2014	Planned Outage	31.93	2	15.97
1051345	6/18/2014	Planned Outage	9.20	1	9.2
1051348	6/18/2014	Planned Outage	52.55	1	52.55
1051349	6/18/2014	Planned Outage	108.17	2	54.08
1051352	6/18/2014	Planned Outage	10.27	1	10.27
1051355	6/18/2014	Planned Outage	222.37	7	31.77
1051356	6/18/2014	Planned Outage	85.00	3	28.33
1051360	6/18/2014	Planned Outage	33.00	1	33
1051373	6/18/2014	Planned Outage	123.20	4	30.8
1051399	6/18/2014	Planned Outage	77.13	2	38.57
1051400	6/18/2014	Planned Outage	99.27	2	49.63
1051402	6/18/2014	Planned Outage	1,396.67	8	174.58
1051411	6/18/2014	Planned Outage	837.80	6	139.63
1051413	6/18/2014	Planned Outage	45.27	4	11.32
1051416	6/18/2014	Planned Outage	14.52	1	14.52
1051417	6/18/2014	Planned Outage	14.35	1	14.35
1051456	6/18/2014	Planned Outage	706.27	8	88.28
1051464	6/18/2014	Planned Outage	326.27	4	81.57
1051479	6/19/2014	Planned Outage	32.30	1	32.3
1051504	6/19/2014	Planned Outage	99.90	3	33.3
1051510	6/19/2014	Planned Outage	79.25	5	15.85
1051514	6/19/2014	Planned Outage	57.80	6	9.63
1051515	6/19/2014	Planned Outage	93.70	6	15.62
1051517	6/19/2014	Planned Outage	13.45	1	13.45
1051523	6/19/2014	Planned Outage	7,852.00	130	60.4

Appendix 1

2014 Planned Outages Table

1051526	6/19/2014	Planned Outage	20.30	2	10.15
1051527	6/19/2014	Planned Outage	252.27	2	126.13
1051530	6/19/2014	Planned Outage	190.28	7	27.18
1051534	6/19/2014	Planned Outage	5.63	1	5.63
1051539	6/19/2014	Planned Outage	41.87	1	41.87
1051542	6/19/2014	Planned Outage	14.97	1	14.97
1051551	6/19/2014	Planned Outage	56.53	1	56.53
1051557	6/19/2014	Planned Outage	103.77	2	51.88
1051561	6/19/2014	Planned Outage	26.90	6	4.48
1051567	6/19/2014	Planned Outage	139.70	3	46.57
1051568	6/19/2014	Planned Outage	124.20	4	31.05
1051572	6/19/2014	Planned Outage	86.45	3	28.82
1051597	6/19/2014	Planned Outage	113.48	1	113.48
1051604	6/19/2014	Planned Outage	165.40	4	41.35
1051608	6/19/2014	Planned Outage	184.80	6	30.8
1051610	6/19/2014	Planned Outage	155.70	6	25.95
1051611	6/19/2014	Planned Outage	219.80	6	36.63
1051655	6/19/2014	Planned Outage	276.10	6	46.02
1051665	6/19/2014	Planned Outage	12.18	1	12.18
1051718	6/20/2014	Planned Outage	41.57	1	41.57
1051719	6/20/2014	Planned Outage	36.90	1	36.9
1051723	6/20/2014	Planned Outage	175.20	6	29.2
1051728	6/20/2014	Planned Outage	368.67	5	73.73
1051731	6/20/2014	Planned Outage	50.33	1	50.33
1051739	6/20/2014	Planned Outage	1,673.93	7	239.13
1051742	6/20/2014	Planned Outage	35.80	4	8.95
1051748	6/20/2014	Planned Outage	19.72	1	19.72
1051749	6/20/2014	Planned Outage	144.25	3	48.08
1051756	6/20/2014	Planned Outage	42.93	4	10.73
1051764	6/20/2014	Planned Outage	10.55	1	10.55
1051767	6/20/2014	Planned Outage	10.73	1	10.73
1051849	6/20/2014	Planned Outage	44.85	3	14.95
1051922	6/20/2014	Planned Outage	29.70	3	9.9
1051933	6/21/2014	Planned Outage	10.37	2	5.18
1051947	6/21/2014	Planned Outage	517.90	3	172.63
1051951	6/21/2014	Planned Outage	44.10	3	14.7
1051974	6/21/2014	Planned Outage	64.05	3	21.35
1051995	6/21/2014	Planned Outage	325.60	11	29.6
1051998	6/22/2014	Planned Outage	42.08	1	42.08
1052297	6/22/2014	Planned Outage	298.40	8	37.3
1052328	6/23/2014	Planned Outage	44.07	2	22.03
1052339	6/23/2014	Planned Outage	78.10	1	78.1
1052351	6/23/2014	Planned Outage	383.40	4	95.85
1052352	6/23/2014	Planned Outage	140.20	2	70.1
1052362	6/23/2014	Planned Outage	806.47	4	201.62
1052363	6/23/2014	Planned Outage	146.57	2	73.28
1052368	6/23/2014	Planned Outage	148.83	5	29.77
1052369	6/23/2014	Planned Outage	228.15	3	76.05
1052373	6/23/2014	Planned Outage	317.15	3	105.72

Appendix 1

2014 Planned Outages Table

1052378	6/23/2014	Planned Outage	198.83	2	99.42
1052379	6/23/2014	Planned Outage	37.90	6	6.32
1052385	6/23/2014	Planned Outage	88.45	1	88.45
1052390	6/23/2014	Planned Outage	184.35	3	61.45
1052392	6/23/2014	Planned Outage	110.50	3	36.83
1052410	6/23/2014	Planned Outage	302.80	24	12.62
1052426	6/23/2014	Planned Outage	74.00	2	37
1052428	6/23/2014	Planned Outage	158.20	1	158.2
1052462	6/23/2014	Planned Outage	2,984.50	127	23.5
1052540	6/23/2014	Planned Outage	495.00	3	165
1052542	6/23/2014	Planned Outage	1,072.17	7	153.17
1052561	6/23/2014	Planned Outage	56.60	2	28.3
1052635	6/24/2014	Planned Outage	122.80	1	122.8
1052649	6/24/2014	Planned Outage	108.40	3	36.13
1052655	6/24/2014	Planned Outage	11.52	1	11.52
1052657	6/24/2014	Planned Outage	2,106.03	41	51.37
1052660	6/24/2014	Planned Outage	44.40	1	44.4
1052661	6/24/2014	Planned Outage	4,097.50	55	74.5
1052662	6/24/2014	Planned Outage	70.78	1	70.78
1052663	6/24/2014	Planned Outage	7,076.15	97	72.95
1052667	6/24/2014	Planned Outage	107.73	2	53.87
1052668	6/24/2014	Planned Outage	15.43	1	15.43
1052674	6/24/2014	Planned Outage	127.20	3	42.4
1052681	6/24/2014	Planned Outage	34.18	1	34.18
1052692	6/24/2014	Planned Outage	1,265.90	6	210.98
1052696	6/24/2014	Planned Outage	571.90	7	81.7
1052699	6/24/2014	Planned Outage	12.17	2	6.08
1052728	6/24/2014	Planned Outage	21.78	1	21.78
1052732	6/24/2014	Planned Outage	116.97	2	58.48
1052734	6/24/2014	Planned Outage	186.33	5	37.27
1052736	6/24/2014	Planned Outage	237.80	4	59.45
1052743	6/24/2014	Planned Outage	51.00	1	51
1052746	6/24/2014	Planned Outage	30.75	9	3.42
1052787	6/24/2014	Planned Outage	240.73	4	60.18
1052796	6/24/2014	Planned Outage	140.33	1	140.33
1052824	6/24/2014	Planned Outage	15.15	1	15.15
1052825	6/24/2014	Planned Outage	1,094.70	41	26.7
1052838	6/24/2014	Planned Outage	39.70	2	19.85
1052839	6/24/2014	Planned Outage	13.40	1	13.4
1052942	6/25/2014	Planned Outage	362.73	2	181.37
1052944	6/25/2014	Planned Outage	176.97	2	88.48
1052946	6/25/2014	Planned Outage	177.47	4	44.37
1052951	6/25/2014	Planned Outage	1,653.40	7	236.2
1052954	6/25/2014	Planned Outage	699.20	3	233.07
1052957	6/25/2014	Planned Outage	192.15	3	64.05
1052958	6/25/2014	Planned Outage	8.08	1	8.08
1052959	6/25/2014	Planned Outage	84.75	9	9.42
1052972	6/25/2014	Planned Outage	428.50	3	142.83
1052974	6/25/2014	Planned Outage	1,369.20	12	114.1

Appendix 1

2014 Planned Outages Table

1052982	6/25/2014	Planned Outage	204.23	11	18.57
1052987	6/25/2014	Planned Outage	13.90	6	2.32
1052992	6/25/2014	Planned Outage	828.00	9	92
1053020	6/25/2014	Planned Outage	30.00	2	15
1053033	6/25/2014	Planned Outage	240.83	2	120.42
1053034	6/25/2014	Planned Outage	22.58	1	22.58
1053035	6/25/2014	Planned Outage	71.55	3	23.85
1053039	6/25/2014	Planned Outage	25.95	1	25.95
1053051	6/25/2014	Planned Outage	257.47	4	64.37
1053063	6/25/2014	Planned Outage	11.70	1	11.7
1053066	6/25/2014	Planned Outage	196.03	2	98.02
1053074	6/25/2014	Planned Outage	207.80	6	34.63
1053105	6/25/2014	Planned Outage	681.22	7	97.32
1053197	6/26/2014	Planned Outage	5,301.20	1828	2.9
1053200	6/26/2014	Planned Outage	3.30	1	3.3
1053202	6/26/2014	Planned Outage	59.55	9	6.62
1053206	6/26/2014	Planned Outage	2,964.95	19	156.05
1053207	6/26/2014	Planned Outage	624.13	4	156.03
1053208	6/26/2014	Planned Outage	47.43	2	23.72
1053214	6/26/2014	Planned Outage	905.25	17	53.25
1053216	6/26/2014	Planned Outage	168.80	4	42.2
1053218	6/26/2014	Planned Outage	27.50	1	27.5
1053222	6/26/2014	Planned Outage	16.80	1	16.8
1053226	6/26/2014	Planned Outage	168.17	2	84.08
1053227	6/26/2014	Planned Outage	228.20	2	114.1
1053228	6/26/2014	Planned Outage	114.37	1	114.37
1053229	6/26/2014	Planned Outage	64.00	2	32
1053233	6/26/2014	Planned Outage	610.30	6	101.72
1053237	6/26/2014	Planned Outage	30.17	5	6.03
1053238	6/26/2014	Planned Outage	129.28	1	129.28
1053239	6/26/2014	Planned Outage	568.95	9	63.22
1053246	6/26/2014	Planned Outage	231.30	9	25.7
1053249	6/26/2014	Planned Outage	103.08	5	20.62
1053270	6/26/2014	Planned Outage	74.45	1	74.45
1053275	6/26/2014	Planned Outage	1,758.67	16	109.92
1053278	6/26/2014	Planned Outage	15.63	1	15.63
1053282	6/26/2014	Planned Outage	6.72	1	6.72
1053283	6/26/2014	Planned Outage	70.93	4	17.73
1053287	6/26/2014	Planned Outage	254.92	95	2.68
1053349	6/27/2014	Planned Outage	266.43	2	133.22
1053359	6/27/2014	Planned Outage	135.07	1	135.07
1053361	6/27/2014	Planned Outage	3,441.60	32	107.55
1053363	6/27/2014	Planned Outage	108.30	1	108.3
1053367	6/27/2014	Planned Outage	230.87	4	57.72
1053371	6/27/2014	Planned Outage	194.30	2	97.15
1053374	6/27/2014	Planned Outage	20.27	1	20.27
1053375	6/27/2014	Planned Outage	86.87	2	43.43
1053377	6/27/2014	Planned Outage	1,221.57	26	46.98
1053378	6/27/2014	Planned Outage	418.33	5	83.67

Appendix 1

2014 Planned Outages Table

1053382	6/27/2014	Planned Outage	155.75	3	51.92
1053383	6/27/2014	Planned Outage	168.40	4	42.1
1053386	6/27/2014	Planned Outage	30.85	1	30.85
1053388	6/27/2014	Planned Outage	36.58	1	36.58
1053393	6/27/2014	Planned Outage	20.65	1	20.65
1053396	6/27/2014	Planned Outage	315.00	9	35
1053399	6/27/2014	Planned Outage	116.85	1	116.85
1053403	6/27/2014	Planned Outage	4.63	2	2.32
1053420	6/27/2014	Planned Outage	53.95	1	53.95
1053421	6/27/2014	Planned Outage	54.10	1	54.1
1053477	6/28/2014	Planned Outage	46.90	6	7.82
1053482	6/28/2014	Planned Outage	13.50	6	2.25
1053665	6/30/2014	Planned Outage	92.92	1	92.92
1053667	6/30/2014	Planned Outage	152.00	2	76
1053670	6/30/2014	Planned Outage	436.00	4	109
1053684	6/30/2014	Planned Outage	109.70	2	54.85
1053685	6/30/2014	Planned Outage	180.00	2	90
1053691	6/30/2014	Planned Outage	766.17	5	153.23
1053700	6/30/2014	Planned Outage	41.03	1	41.03
1053704	6/30/2014	Planned Outage	991.60	6	165.27
1053705	6/30/2014	Planned Outage	106.93	1	106.93
1053710	6/30/2014	Planned Outage	53.50	3	17.83
1053717	6/30/2014	Planned Outage	70.77	1	70.77
1053729	6/30/2014	Planned Outage	5.40	1	5.4
1053733	6/30/2014	Planned Outage	22.13	1	22.13
1053735	6/30/2014	Planned Outage	109.60	8	13.7
1053736	6/30/2014	Planned Outage	158.00	1	158
1053739	6/30/2014	Planned Outage	204.40	6	34.07
1053740	6/30/2014	Planned Outage	115.00	1	115
1053742	6/30/2014	Planned Outage	21.77	1	21.77
1053748	6/30/2014	Planned Outage	25.40	1	25.4
1053750	6/30/2014	Planned Outage	1,204.00	7	172
1053752	6/30/2014	Planned Outage	61.32	1	61.32
1053753	6/30/2014	Planned Outage	1,032.00	6	172
1053754	6/30/2014	Planned Outage	106.00	1	106
1053755	6/30/2014	Planned Outage	18.03	1	18.03
1053760	6/30/2014	Planned Outage	420.58	5	84.12
1053762	6/30/2014	Planned Outage	38.75	1	38.75
1053767	6/30/2014	Planned Outage	305.00	61	5
1053769	6/30/2014	Planned Outage	34.57	1	34.57
1053775	6/30/2014	Planned Outage	10.12	1	10.12
1053777	6/30/2014	Planned Outage	22.75	1	22.75
1053780	6/30/2014	Planned Outage	10.08	1	10.08
1053786	6/30/2014	Planned Outage	37.47	1	37.47
1053790	6/30/2014	Planned Outage	114.00	3	38
1053818	7/1/2014	Planned Outage	2,676.00	3	892
1053819	7/1/2014	Planned Outage	99.88	1	99.88
1053824	7/1/2014	Planned Outage	24.00	2	12
1053829	7/1/2014	Planned Outage	22.00	1	22

Appendix 1

2014 Planned Outages Table

1053831	7/1/2014	Planned Outage	17.92	1	17.92
1053837	7/1/2014	Planned Outage	520.00	2	260
1053839	7/1/2014	Planned Outage	343.80	12	28.65
1053840	7/1/2014	Planned Outage	502.37	7	71.77
1053847	7/1/2014	Planned Outage	96.00	6	16
1053848	7/1/2014	Planned Outage	237.00	3	79
1053850	7/1/2014	Planned Outage	90.00	2	45
1053853	7/1/2014	Planned Outage	50.35	1	50.35
1053854	7/1/2014	Planned Outage	730.00	1	730
1053856	7/1/2014	Planned Outage	146.13	1	146.13
1053861	7/1/2014	Planned Outage	37.87	2	18.93
1053865	7/1/2014	Planned Outage	47.43	1	47.43
1053869	7/1/2014	Planned Outage	267.50	1	267.5
1053881	7/1/2014	Planned Outage	656.67	8	82.08
1053887	7/1/2014	Planned Outage	29.00	1	29
1053895	7/1/2014	Planned Outage	105.20	6	17.53
1053897	7/1/2014	Planned Outage	355.83	7	50.83
1053900	7/1/2014	Planned Outage	86.23	2	43.12
1053902	7/1/2014	Planned Outage	42.35	1	42.35
1053903	7/1/2014	Planned Outage	276.00	4	69
1053907	7/1/2014	Planned Outage	1,083.00	3	361
1053909	7/1/2014	Planned Outage	69.03	2	34.52
1053915	7/1/2014	Planned Outage	133.95	3	44.65
1053920	7/1/2014	Planned Outage	53.52	1	53.52
1053921	7/1/2014	Planned Outage	52.00	1	52
1053922	7/1/2014	Planned Outage	1,691.80	11	153.8
1053924	7/1/2014	Planned Outage	308.00	2	154
1053926	7/1/2014	Planned Outage	56.05	3	18.68
1053927	7/1/2014	Planned Outage	243.57	2	121.78
1053941	7/1/2014	Planned Outage	56.15	1	56.15
1053950	7/1/2014	Planned Outage	38.00	1	38
1053956	7/1/2014	Planned Outage	21.65	1	21.65
1053958	7/1/2014	Planned Outage	1,176.00	6	196
1053959	7/1/2014	Planned Outage	196.00	4	49
1053960	7/1/2014	Planned Outage	156.00	3	52
1054020	7/2/2014	Planned Outage	63.83	2	31.92
1054022	7/2/2014	Planned Outage	443.50	1	443.5
1054025	7/2/2014	Planned Outage	6.13	1	6.13
1054026	7/2/2014	Planned Outage	169.65	1	169.65
1054032	7/2/2014	Planned Outage	159.75	1	159.75
1054033	7/2/2014	Planned Outage	490.20	4	122.55
1054035	7/2/2014	Planned Outage	899.73	8	112.47
1054036	7/2/2014	Planned Outage	99.00	3	33
1054039	7/2/2014	Planned Outage	87.27	4	21.82
1054040	7/2/2014	Planned Outage	38.80	4	9.7
1054041	7/2/2014	Planned Outage	6,349.80	36	176.38
1054046	7/2/2014	Planned Outage	268.00	2	134
1054049	7/2/2014	Planned Outage	2,161.60	24	90.07
1054054	7/2/2014	Planned Outage	56.00	2	28

Appendix 1

2014 Planned Outages Table

1054062	7/2/2014	Planned Outage	31.90	2	15.95
1054069	7/2/2014	Planned Outage	50.78	1	50.78
1054071	7/2/2014	Planned Outage	296.17	10	29.62
1054073	7/2/2014	Planned Outage	215.55	3	71.85
1054074	7/2/2014	Planned Outage	47.77	1	47.77
1054076	7/2/2014	Planned Outage	282.00	3	94
1054077	7/2/2014	Planned Outage	360.27	8	45.03
1054091	7/2/2014	Planned Outage	32.00	1	32
1054100	7/2/2014	Planned Outage	9.97	1	9.97
1054109	7/2/2014	Planned Outage	43.58	1	43.58
1054110	7/2/2014	Planned Outage	50.02	1	50.02
1054121	7/2/2014	Planned Outage	112.93	4	28.23
1054127	7/2/2014	Planned Outage	60.97	1	60.97
1054147	7/2/2014	Planned Outage	584.25	19	30.75
1054149	7/2/2014	Planned Outage	32.35	1	32.35
1054150	7/2/2014	Planned Outage	37.23	2	18.62
1054152	7/2/2014	Planned Outage	239.40	2	119.7
1054153	7/2/2014	Planned Outage	262.73	4	65.68
1054154	7/2/2014	Planned Outage	11.33	1	11.33
1054155	7/2/2014	Planned Outage	62.98	1	62.98
1054160	7/2/2014	Planned Outage	117.00	3	39
1054164	7/2/2014	Planned Outage	51.32	1	51.32
1054181	7/2/2014	Planned Outage	305.43	7	43.63
1054194	7/2/2014	Planned Outage	58.08	5	11.62
1054215	7/3/2014	Planned Outage	65.47	2	32.73
1054224	7/3/2014	Planned Outage	17.20	2	8.6
1054225	7/3/2014	Planned Outage	570.00	5	114
1054231	7/3/2014	Planned Outage	238.87	1	238.87
1054234	7/3/2014	Planned Outage	532.40	12	44.37
1054236	7/3/2014	Planned Outage	176.27	8	22.03
1054243	7/3/2014	Planned Outage	55.73	2	27.87
1054244	7/3/2014	Planned Outage	1,635.55	7	233.65
1054249	7/3/2014	Planned Outage	83.32	1	83.32
1054250	7/3/2014	Planned Outage	240.40	4	60.1
1054256	7/3/2014	Planned Outage	591.00	3	197
1054259	7/3/2014	Planned Outage	11.18	1	11.18
1054278	7/3/2014	Planned Outage	124.00	2	62
1054439	7/5/2014	Planned Outage	31.60	1	31.6
1054505	7/6/2014	Planned Outage	583.15	3	194.38
1054507	7/6/2014	Planned Outage	108.80	6	18.13
1054540	7/7/2014	Planned Outage	37.17	1	37.17
1054542	7/7/2014	Planned Outage	243.67	5	48.73
1054543	7/7/2014	Planned Outage	302.92	5	60.58
1054545	7/7/2014	Planned Outage	18.52	1	18.52
1054548	7/7/2014	Planned Outage	20.25	1	20.25
1054550	7/7/2014	Planned Outage	82.80	4	20.7
1054551	7/7/2014	Planned Outage	66.30	2	33.15
1054553	7/7/2014	Planned Outage	408.65	3	136.22
1054554	7/7/2014	Planned Outage	107.72	1	107.72

Appendix 1

2014 Planned Outages Table

1054558	7/7/2014	Planned Outage	2,096.10	27	77.63
1054561	7/7/2014	Planned Outage	28.03	1	28.03
1054564	7/7/2014	Planned Outage	4,792.20	42	114.1
1054572	7/7/2014	Planned Outage	12.97	1	12.97
1054575	7/7/2014	Planned Outage	77.45	3	25.82
1054578	7/7/2014	Planned Outage	311.30	6	51.88
1054581	7/7/2014	Planned Outage	384.53	4	96.13
1054582	7/7/2014	Planned Outage	55.45	3	18.48
1054605	7/7/2014	Planned Outage	39.43	1	39.43
1054606	7/7/2014	Planned Outage	61.30	2	30.65
1054609	7/7/2014	Planned Outage	13.37	1	13.37
1054611	7/7/2014	Planned Outage	216.33	4	54.08
1054612	7/7/2014	Planned Outage	149.52	1	149.52
1054613	7/7/2014	Planned Outage	56.30	3	18.77
1054615	7/7/2014	Planned Outage	41.90	3	13.97
1054617	7/7/2014	Planned Outage	27.75	1	27.75
1054620	7/7/2014	Planned Outage	110.20	6	18.37
1054622	7/7/2014	Planned Outage	229.47	4	57.37
1054623	7/7/2014	Planned Outage	17.33	1	17.33
1054625	7/7/2014	Planned Outage	93.50	5	18.7
1054627	7/7/2014	Planned Outage	14.77	1	14.77
1054629	7/7/2014	Planned Outage	141.20	4	35.3
1054652	7/7/2014	Planned Outage	39.77	2	19.88
1054656	7/7/2014	Planned Outage	23.13	1	23.13
1054662	7/7/2014	Planned Outage	37.00	4	9.25
1054669	7/7/2014	Planned Outage	76.47	2	38.23
1054670	7/7/2014	Planned Outage	31.23	2	15.62
1054672	7/7/2014	Planned Outage	48.70	2	24.35
1054673	7/7/2014	Planned Outage	48.10	2	24.05
1054685	7/7/2014	Planned Outage	29.98	1	29.98
1054688	7/7/2014	Planned Outage	338.80	8	42.35
1054704	7/8/2014	Planned Outage	229.40	1	229.4
1054706	7/8/2014	Planned Outage	667.35	27	24.72
1054707	7/8/2014	Planned Outage	176.00	5	35.2
1054708	7/8/2014	Planned Outage	326.58	5	65.32
1054712	7/8/2014	Planned Outage	37.00	3	12.33
1054718	7/8/2014	Planned Outage	369.13	2	184.57
1054720	7/8/2014	Planned Outage	326.25	5	65.25
1054722	7/8/2014	Planned Outage	48.98	1	48.98
1054724	7/8/2014	Planned Outage	483.87	4	120.97
1054725	7/8/2014	Planned Outage	58.50	2	29.25
1054729	7/8/2014	Planned Outage	77.33	2	38.67
1054730	7/8/2014	Planned Outage	345.83	25	13.83
1054737	7/8/2014	Planned Outage	677.33	2	338.67
1054738	7/8/2014	Planned Outage	184.50	6	30.75
1054739	7/8/2014	Planned Outage	1,011.60	3	337.2
1054745	7/8/2014	Planned Outage	440.00	4	110
1054746	7/8/2014	Planned Outage	58.20	4	14.55
1054747	7/8/2014	Planned Outage	782.40	6	130.4

Appendix 1

2014 Planned Outages Table

1054748	7/8/2014	Planned Outage	35.53	2	17.77
1054749	7/8/2014	Planned Outage	16.92	1	16.92
1054751	7/8/2014	Planned Outage	13.82	1	13.82
1054752	7/8/2014	Planned Outage	128.50	3	42.83
1054753	7/8/2014	Planned Outage	57.13	2	28.57
1054755	7/8/2014	Planned Outage	20.90	1	20.9
1054756	7/8/2014	Planned Outage	19.97	2	9.98
1054757	7/8/2014	Planned Outage	25.20	2	12.6
1054758	7/8/2014	Planned Outage	56.52	1	56.52
1054760	7/8/2014	Planned Outage	57.80	4	14.45
1054761	7/8/2014	Planned Outage	56.60	2	28.3
1054762	7/8/2014	Planned Outage	32.30	1	32.3
1054764	7/8/2014	Planned Outage	63.03	2	31.52
1054765	7/8/2014	Planned Outage	98.75	3	32.92
1054766	7/8/2014	Planned Outage	3,910.00	17	230
1054767	7/8/2014	Planned Outage	27.10	3	9.03
1054768	7/8/2014	Planned Outage	25.63	1	25.63
1054769	7/8/2014	Planned Outage	466.73	4	116.68
1054783	7/8/2014	Planned Outage	30.60	1	30.6
1054792	7/8/2014	Planned Outage	36.57	2	18.28
1054808	7/8/2014	Planned Outage	18.92	1	18.92
1054820	7/8/2014	Planned Outage	24.10	2	12.05
1054823	7/8/2014	Planned Outage	15.13	1	15.13
1054824	7/8/2014	Planned Outage	25.00	1	25
1054827	7/8/2014	Planned Outage	51.70	3	17.23
1054831	7/8/2014	Planned Outage	345.57	7	49.37
1054832	7/8/2014	Planned Outage	13.62	1	13.62
1054833	7/8/2014	Planned Outage	11.42	1	11.42
1054838	7/8/2014	Planned Outage	21.60	2	10.8
1054859	7/9/2014	Planned Outage	11.75	1	11.75
1054864	7/9/2014	Planned Outage	695.27	4	173.82
1054865	7/9/2014	Planned Outage	199.60	3	66.53
1054866	7/9/2014	Planned Outage	1,312.00	8	164
1054867	7/9/2014	Planned Outage	13.88	1	13.88
1054868	7/9/2014	Planned Outage	25.75	1	25.75
1054870	7/9/2014	Planned Outage	20,017.83	65	307.97
1054875	7/9/2014	Planned Outage	2,268.00	9	252
1054877	7/9/2014	Planned Outage	601.75	3	200.58
1054879	7/9/2014	Planned Outage	263.27	11	23.93
1054881	7/9/2014	Planned Outage	19.45	1	19.45
1054883	7/9/2014	Planned Outage	3,997.00	42	95.17
1054889	7/9/2014	Planned Outage	562.05	27	20.82
1054890	7/9/2014	Planned Outage	81.00	3	27
1054894	7/9/2014	Planned Outage	74.93	2	37.47
1054895	7/9/2014	Planned Outage	28.75	1	28.75
1054900	7/9/2014	Planned Outage	605.33	10	60.53
1054902	7/9/2014	Planned Outage	540.10	11	49.1
1054905	7/9/2014	Planned Outage	40.78	1	40.78
1054907	7/9/2014	Planned Outage	87.90	3	29.3

Appendix 1

2014 Planned Outages Table

1054909	7/9/2014	Planned Outage	17.53	1	17.53
1054923	7/9/2014	Planned Outage	15.25	1	15.25
1054925	7/9/2014	Planned Outage	16.42	1	16.42
1054928	7/9/2014	Planned Outage	73.67	2	36.83
1054936	7/9/2014	Planned Outage	18.40	1	18.4
1054992	7/9/2014	Planned Outage	251.17	2	125.58
1055046	7/9/2014	Planned Outage	320.40	27	11.87
1055055	7/9/2014	Planned Outage	4.33	2	2.17
1055112	7/10/2014	Planned Outage	115.60	17	6.8
1055113	7/10/2014	Planned Outage	478.27	17	28.13
1055115	7/10/2014	Planned Outage	42.83	1	42.83
1055116	7/10/2014	Planned Outage	478.40	6	79.73
1055117	7/10/2014	Planned Outage	40.03	1	40.03
1055118	7/10/2014	Planned Outage	75.50	2	37.75
1055120	7/10/2014	Planned Outage	90.30	2	45.15
1055121	7/10/2014	Planned Outage	99.62	1	99.62
1055123	7/10/2014	Planned Outage	196.87	2	98.43
1055126	7/10/2014	Planned Outage	160.23	11	14.57
1055129	7/10/2014	Planned Outage	31.17	1	31.17
1055130	7/10/2014	Planned Outage	50.82	1	50.82
1055131	7/10/2014	Planned Outage	1,843.37	17	108.43
1055137	7/10/2014	Planned Outage	36.13	2	18.07
1055317	7/11/2014	Planned Outage	2,697.00	3	899
1055323	7/11/2014	Planned Outage	29.88	1	29.88
1055324	7/11/2014	Planned Outage	6,445.27	34	189.57
1055326	7/11/2014	Planned Outage	143.08	1	143.08
1055327	7/11/2014	Planned Outage	28.98	1	28.98
1055328	7/11/2014	Planned Outage	10.18	1	10.18
1055333	7/11/2014	Planned Outage	18.70	1	18.7
1055334	7/11/2014	Planned Outage	205.50	6	34.25
1055337	7/11/2014	Planned Outage	33.30	3	11.1
1055338	7/11/2014	Planned Outage	5,316.90	37	143.7
1055343	7/11/2014	Planned Outage	64.13	1	64.13
1055344	7/11/2014	Planned Outage	93.33	40	2.33
1055347	7/11/2014	Planned Outage	46.93	2	23.47
1055348	7/11/2014	Planned Outage	125.40	1	125.4
1055350	7/11/2014	Planned Outage	24.47	2	12.23
1055353	7/11/2014	Planned Outage	7.17	1	7.17
1055355	7/11/2014	Planned Outage	6.00	1	6
1055358	7/11/2014	Planned Outage	84.45	3	28.15
1055360	7/11/2014	Planned Outage	575.37	41	14.03
1055363	7/11/2014	Planned Outage	123.03	1	123.03
1055376	7/11/2014	Planned Outage	24.30	2	12.15
1055390	7/11/2014	Planned Outage	168.77	1	168.77
1055410	7/11/2014	Planned Outage	13.60	1	13.6
1055417	7/11/2014	Planned Outage	235.10	3	78.37
1055523	7/12/2014	Planned Outage	16.08	1	16.08
1055525	7/12/2014	Planned Outage	5.35	1	5.35
1055526	7/12/2014	Planned Outage	18.93	1	18.93

Appendix 1

2014 Planned Outages Table

1055661	7/13/2014	Planned Outage	88.42	5	17.68
1055670	7/13/2014	Planned Outage	405.40	4	101.35
1055742	7/14/2014	Planned Outage	513.10	14	36.65
1055743	7/14/2014	Planned Outage	141.37	1	141.37
1055744	7/14/2014	Planned Outage	675.00	5	135
1055745	7/14/2014	Planned Outage	570.00	10	57
1055746	7/14/2014	Planned Outage	1,228.13	4	307.03
1055747	7/14/2014	Planned Outage	164.90	3	54.97
1055748	7/14/2014	Planned Outage	340.32	7	48.62
1055751	7/14/2014	Planned Outage	195.53	1	195.53
1055759	7/14/2014	Planned Outage	6.92	1	6.92
1055761	7/14/2014	Planned Outage	25.83	1	25.83
1055763	7/14/2014	Planned Outage	25.80	1	25.8
1055771	7/14/2014	Planned Outage	66.20	6	11.03
1055773	7/14/2014	Planned Outage	48.05	3	16.02
1055775	7/14/2014	Planned Outage	129.80	44	2.95
1055782	7/14/2014	Planned Outage	928.08	43	21.58
1055785	7/14/2014	Planned Outage	31.87	2	15.93
1055806	7/14/2014	Planned Outage	9,399.20	93	101.07
1055809	7/14/2014	Planned Outage	124.00	2	62
1055818	7/14/2014	Planned Outage	53.78	1	53.78
1055820	7/14/2014	Planned Outage	154.45	3	51.48
1055837	7/14/2014	Planned Outage	123.08	1	123.08
1055841	7/14/2014	Planned Outage	390.00	5	78
1055842	7/14/2014	Planned Outage	78.00	2	39
1055854	7/14/2014	Planned Outage	116.52	1	116.52
1055855	7/14/2014	Planned Outage	20.88	1	20.88
1055859	7/14/2014	Planned Outage	104.10	2	52.05
1055921	7/15/2014	Planned Outage	30.95	3	10.32
1055925	7/15/2014	Planned Outage	774.60	6	129.1
1055927	7/15/2014	Planned Outage	59.30	2	29.65
1055929	7/15/2014	Planned Outage	780.85	7	111.55
1055935	7/15/2014	Planned Outage	129.33	5	25.87
1055937	7/15/2014	Planned Outage	865.60	6	144.27
1055938	7/15/2014	Planned Outage	865.10	6	144.18
1055939	7/15/2014	Planned Outage	288.53	2	144.27
1055941	7/15/2014	Planned Outage	15.27	1	15.27
1055943	7/15/2014	Planned Outage	124.37	2	62.18
1055946	7/15/2014	Planned Outage	57.00	6	9.5
1055952	7/15/2014	Planned Outage	586.42	5	117.28
1055953	7/15/2014	Planned Outage	349.42	7	49.92
1055955	7/15/2014	Planned Outage	138.90	6	23.15
1055969	7/15/2014	Planned Outage	46.65	1	46.65
1055973	7/15/2014	Planned Outage	497.00	42	11.83
1055991	7/15/2014	Planned Outage	45.10	2	22.55
1056065	7/15/2014	Planned Outage	38.80	6	6.47
1056105	7/15/2014	Planned Outage	31.53	1	31.53
1056137	7/15/2014	Planned Outage	13.02	1	13.02
1056138	7/15/2014	Planned Outage	18.55	1	18.55

Appendix 1

2014 Planned Outages Table

1056139	7/15/2014	Planned Outage	88.55	3	29.52
1056164	7/15/2014	Planned Outage	24.00	4	6
1056171	7/15/2014	Planned Outage	112.20	6	18.7
1056203	7/16/2014	Planned Outage	300.30	6	50.05
1056217	7/16/2014	Planned Outage	7,571.20	42	180.27
1056220	7/16/2014	Planned Outage	44.82	1	44.82
1056223	7/16/2014	Planned Outage	155.97	2	77.98
1056224	7/16/2014	Planned Outage	1,183.70	19	62.3
1056229	7/16/2014	Planned Outage	979.18	7	139.88
1056232	7/16/2014	Planned Outage	4,547.20	7	649.6
1056239	7/16/2014	Planned Outage	313.05	9	34.78
1056240	7/16/2014	Planned Outage	54.80	2	27.4
1056243	7/16/2014	Planned Outage	430.30	3	143.43
1056244	7/16/2014	Planned Outage	8,346.20	12	695.52
1056247	7/16/2014	Planned Outage	3,283.33	100	32.83
1056249	7/16/2014	Planned Outage	18,579.00	132	140.75
1056251	7/16/2014	Planned Outage	39.00	13	3
1056255	7/16/2014	Planned Outage	370.80	3	123.6
1056256	7/16/2014	Planned Outage	51.40	1	51.4
1056257	7/16/2014	Planned Outage	39.27	1	39.27
1056275	7/16/2014	Planned Outage	37.67	2	18.83
1056276	7/16/2014	Planned Outage	25.73	1	25.73
1056277	7/16/2014	Planned Outage	21.28	1	21.28
1056281	7/16/2014	Planned Outage	440.42	7	62.92
1056283	7/16/2014	Planned Outage	14.93	1	14.93
1056286	7/16/2014	Planned Outage	12.63	1	12.63
1056291	7/16/2014	Planned Outage	18.42	1	18.42
1056297	7/16/2014	Planned Outage	35.75	1	35.75
1056301	7/16/2014	Planned Outage	444.75	5	88.95
1056333	7/16/2014	Planned Outage	314.00	40	7.85
1056336	7/16/2014	Planned Outage	14.78	1	14.78
1056341	7/16/2014	Planned Outage	44.78	1	44.78
1056346	7/16/2014	Planned Outage	48.80	3	16.27
1056350	7/16/2014	Planned Outage	13.62	1	13.62
1056356	7/16/2014	Planned Outage	76.70	2	38.35
1056361	7/16/2014	Planned Outage	22.02	1	22.02
1056362	7/16/2014	Planned Outage	65.42	1	65.42
1056364	7/16/2014	Planned Outage	3.83	1	3.83
1056366	7/16/2014	Planned Outage	548.00	5	109.6
1056367	7/16/2014	Planned Outage	110.05	1	110.05
1056386	7/17/2014	Planned Outage	17.65	3	5.88
1056389	7/17/2014	Planned Outage	336.73	2	168.37
1056392	7/17/2014	Planned Outage	25.72	1	25.72
1056394	7/17/2014	Planned Outage	219.00	1	219
1056398	7/17/2014	Planned Outage	1,944.83	7	277.83
1056404	7/17/2014	Planned Outage	166.60	4	41.65
1056406	7/17/2014	Planned Outage	196.00	2	98
1056407	7/17/2014	Planned Outage	107.33	4	26.83
1056412	7/17/2014	Planned Outage	6.50	1	6.5

Appendix 1

2014 Planned Outages Table

1056415	7/17/2014	Planned Outage	416.00	8	52
1056416	7/17/2014	Planned Outage	566.42	5	113.28
1056420	7/17/2014	Planned Outage	318.13	8	39.77
1056421	7/17/2014	Planned Outage	1,102.20	6	183.7
1056422	7/17/2014	Planned Outage	7,123.00	68	104.75
1056428	7/17/2014	Planned Outage	195.33	4	48.83
1056429	7/17/2014	Planned Outage	492.00	3	164
1056430	7/17/2014	Planned Outage	440.00	4	110
1056431	7/17/2014	Planned Outage	738.40	4	184.6
1056434	7/17/2014	Planned Outage	97.15	3	32.38
1056439	7/17/2014	Planned Outage	307.70	2	153.85
1056440	7/17/2014	Planned Outage	309.93	4	77.48
1056454	7/17/2014	Planned Outage	65.35	3	21.78
1056459	7/17/2014	Planned Outage	248.97	11	22.63
1056467	7/17/2014	Planned Outage	218.75	5	43.75
1056473	7/17/2014	Planned Outage	28.70	3	9.57
1056474	7/17/2014	Planned Outage	81.73	1	81.73
1056498	7/17/2014	Planned Outage	53.23	2	26.62
1056504	7/17/2014	Planned Outage	263.53	4	65.88
1056524	7/18/2014	Planned Outage	92.77	1	92.77
1056526	7/18/2014	Planned Outage	62.07	1	62.07
1056536	7/18/2014	Planned Outage	62.37	2	31.18
1056538	7/18/2014	Planned Outage	62.30	2	31.15
1056539	7/18/2014	Planned Outage	387.40	4	96.85
1056542	7/18/2014	Planned Outage	193.50	5	38.7
1056544	7/18/2014	Planned Outage	415.27	4	103.82
1056546	7/18/2014	Planned Outage	20.65	1	20.65
1056547	7/18/2014	Planned Outage	377.50	5	75.5
1056548	7/18/2014	Planned Outage	377.67	5	75.53
1056550	7/18/2014	Planned Outage	27.60	1	27.6
1056553	7/18/2014	Planned Outage	34.80	1	34.8
1056555	7/18/2014	Planned Outage	168.00	28	6
1056557	7/18/2014	Planned Outage	133.63	2	66.82
1056559	7/18/2014	Planned Outage	56.23	2	28.12
1056561	7/18/2014	Planned Outage	88.67	7	12.67
1056562	7/18/2014	Planned Outage	137.73	1	137.73
1056570	7/18/2014	Planned Outage	88.42	5	17.68
1056574	7/18/2014	Planned Outage	23.38	1	23.38
1056583	7/18/2014	Planned Outage	38.20	3	12.73
1056588	7/18/2014	Planned Outage	834.70	17	49.1
1056595	7/18/2014	Planned Outage	31.43	1	31.43
1056598	7/18/2014	Planned Outage	240.27	4	60.07
1056928	7/18/2014	Planned Outage	327.93	2	163.97
1056930	7/19/2014	Planned Outage	348.67	5	69.73
1057004	7/19/2014	Planned Outage	42.58	1	42.58
1057150	7/19/2014	Planned Outage	1,358.17	58	23.42
1057176	7/19/2014	Planned Outage	29.68	1	29.68
1057370	7/21/2014	Planned Outage	21.12	1	21.12
1057374	7/21/2014	Planned Outage	779.65	31	25.15

Appendix 1

2014 Planned Outages Table

1057403	7/21/2014	Planned Outage	2,018.15	3	672.72
1057412	7/21/2014	Planned Outage	25.03	2	12.52
1057416	7/21/2014	Planned Outage	54.90	2	27.45
1057419	7/21/2014	Planned Outage	5.53	1	5.53
1057421	7/21/2014	Planned Outage	48.58	5	9.72
1057422	7/21/2014	Planned Outage	12.17	2	6.08
1057424	7/21/2014	Planned Outage	274.07	2	137.03
1057425	7/21/2014	Planned Outage	18.45	1	18.45
1057427	7/21/2014	Planned Outage	34.53	2	17.27
1057429	7/21/2014	Planned Outage	219.62	1	219.62
1057432	7/21/2014	Planned Outage	246.83	2	123.42
1057435	7/21/2014	Planned Outage	316.10	2	158.05
1057436	7/21/2014	Planned Outage	286.50	5	57.3
1057439	7/21/2014	Planned Outage	25.03	2	12.52
1057442	7/21/2014	Planned Outage	729.42	5	145.88
1057444	7/21/2014	Planned Outage	51.17	5	10.23
1057446	7/21/2014	Planned Outage	125.07	4	31.27
1057447	7/21/2014	Planned Outage	490.13	4	122.53
1057448	7/21/2014	Planned Outage	49.27	2	24.63
1057450	7/21/2014	Planned Outage	19.57	1	19.57
1057452	7/21/2014	Planned Outage	58.67	4	14.67
1057454	7/21/2014	Planned Outage	548.10	162	3.38
1057458	7/21/2014	Planned Outage	16.80	1	16.8
1057462	7/21/2014	Planned Outage	24.77	2	12.38
1057464	7/21/2014	Planned Outage	79.33	10	7.93
1057466	7/21/2014	Planned Outage	101.47	4	25.37
1057468	7/21/2014	Planned Outage	239.60	4	59.9
1057474	7/21/2014	Planned Outage	57.73	2	28.87
1057476	7/21/2014	Planned Outage	14.80	1	14.8
1057477	7/21/2014	Planned Outage	20.58	1	20.58
1057484	7/21/2014	Planned Outage	77.78	1	77.78
1057492	7/21/2014	Planned Outage	53.50	1	53.5
1057493	7/21/2014	Planned Outage	52.83	1	52.83
1057495	7/21/2014	Planned Outage	23.63	1	23.63
1057499	7/21/2014	Planned Outage	566.00	4	141.5
1057502	7/21/2014	Planned Outage	251.20	4	62.8
1057505	7/21/2014	Planned Outage	6.13	2	3.07
1057510	7/21/2014	Planned Outage	36.13	2	18.07
1057515	7/21/2014	Planned Outage	122.35	3	40.78
1057565	7/22/2014	Planned Outage	2,449.85	3	816.62
1057571	7/22/2014	Planned Outage	6,886.65	279	24.68
1057579	7/22/2014	Planned Outage	28.15	3	9.38
1057584	7/22/2014	Planned Outage	723.83	10	72.38
1057585	7/22/2014	Planned Outage	1,188.00	6	198
1057586	7/22/2014	Planned Outage	16.87	4	4.22
1057589	7/22/2014	Planned Outage	893.93	4	223.48
1057590	7/22/2014	Planned Outage	104.72	1	104.72
1057592	7/22/2014	Planned Outage	8.48	1	8.48
1057593	7/22/2014	Planned Outage	81.43	2	40.72

Appendix 1

2014 Planned Outages Table

1057594	7/22/2014	Planned Outage	40.43	1	40.43
1057596	7/22/2014	Planned Outage	68.60	6	11.43
1057599	7/22/2014	Planned Outage	175.82	7	25.12
1057600	7/22/2014	Planned Outage	666.00	27	24.67
1057602	7/22/2014	Planned Outage	732.63	31	23.63
1057605	7/22/2014	Planned Outage	22.73	1	22.73
1057608	7/22/2014	Planned Outage	44.67	4	11.17
1057610	7/22/2014	Planned Outage	83.70	6	13.95
1057611	7/22/2014	Planned Outage	8.00	1	8
1057612	7/22/2014	Planned Outage	171.95	1	171.95
1057614	7/22/2014	Planned Outage	5.93	1	5.93
1057617	7/22/2014	Planned Outage	28.80	2	14.4
1057632	7/22/2014	Planned Outage	72.78	1	72.78
1057633	7/22/2014	Planned Outage	16.67	5	3.33
1057635	7/22/2014	Planned Outage	31.93	4	7.98
1057636	7/22/2014	Planned Outage	94.58	5	18.92
1057637	7/22/2014	Planned Outage	80.33	4	20.08
1057643	7/22/2014	Planned Outage	168.75	5	33.75
1057650	7/22/2014	Planned Outage	80.27	4	20.07
1057657	7/22/2014	Planned Outage	125.65	3	41.88
1057658	7/22/2014	Planned Outage	104.73	4	26.18
1057664	7/22/2014	Planned Outage	39.47	4	9.87
1057666	7/22/2014	Planned Outage	430.27	4	107.57
1057667	7/22/2014	Planned Outage	38.67	4	9.67
1057668	7/22/2014	Planned Outage	24.20	1	24.2
1057674	7/22/2014	Planned Outage	362.83	5	72.57
1057676	7/22/2014	Planned Outage	102.97	2	51.48
1057677	7/22/2014	Planned Outage	34.50	1	34.5
1057678	7/22/2014	Planned Outage	40.33	4	10.08
1057680	7/22/2014	Planned Outage	27.00	3	9
1057697	7/22/2014	Planned Outage	37.87	2	18.93
1057698	7/22/2014	Planned Outage	60.65	3	20.22
1057701	7/22/2014	Planned Outage	335.05	3	111.68
1057704	7/22/2014	Planned Outage	46.10	2	23.05
1057707	7/22/2014	Planned Outage	78.20	3	26.07
1057708	7/22/2014	Planned Outage	68.23	2	34.12
1057716	7/22/2014	Planned Outage	121.35	3	40.45
1057729	7/22/2014	Planned Outage	100.50	2	50.25
1057730	7/22/2014	Planned Outage	45.10	3	15.03
1057732	7/22/2014	Planned Outage	28.40	1	28.4
1057733	7/22/2014	Planned Outage	74.50	3	24.83
1057736	7/22/2014	Planned Outage	69.20	2	34.6
1057738	7/22/2014	Planned Outage	10.87	1	10.87
1057751	7/22/2014	Planned Outage	61.60	2	30.8
1057792	7/23/2014	Planned Outage	6.63	1	6.63
1057794	7/23/2014	Planned Outage	385.20	9	42.8
1057795	7/23/2014	Planned Outage	280.13	1	280.13
1057798	7/23/2014	Planned Outage	725.60	3	241.87
1057801	7/23/2014	Planned Outage	158.07	2	79.03

Appendix 1

2014 Planned Outages Table

1057803	7/23/2014	Planned Outage	457.73	4	114.43
1057805	7/23/2014	Planned Outage	454.93	8	56.87
1057807	7/23/2014	Planned Outage	862.40	3	287.47
1057808	7/23/2014	Planned Outage	109.53	4	27.38
1057821	7/23/2014	Planned Outage	192.37	1	192.37
1057823	7/23/2014	Planned Outage	540.83	5	108.17
1057827	7/23/2014	Planned Outage	121.97	2	60.98
1057828	7/23/2014	Planned Outage	2,311.25	43	53.75
1057830	7/23/2014	Planned Outage	242.77	2	121.38
1057831	7/23/2014	Planned Outage	115.97	1	115.97
1057832	7/23/2014	Planned Outage	127.67	4	31.92
1057833	7/23/2014	Planned Outage	370.50	6	61.75
1057834	7/23/2014	Planned Outage	2,400.05	23	104.35
1057845	7/23/2014	Planned Outage	49.47	1	49.47
1057847	7/23/2014	Planned Outage	121.80	4	30.45
1057848	7/23/2014	Planned Outage	34.77	2	17.38
1057854	7/23/2014	Planned Outage	137.58	5	27.52
1057860	7/23/2014	Planned Outage	8.43	1	8.43
1057869	7/23/2014	Planned Outage	15.30	1	15.3
1057870	7/23/2014	Planned Outage	77.87	4	19.47
1057875	7/23/2014	Planned Outage	34.20	1	34.2
1057877	7/23/2014	Planned Outage	13.12	1	13.12
1057880	7/23/2014	Planned Outage	129.33	8	16.17
1057881	7/23/2014	Planned Outage	15.53	4	3.88
1057882	7/23/2014	Planned Outage	836.85	7	119.55
1057883	7/23/2014	Planned Outage	932.90	6	155.48
1057885	7/23/2014	Planned Outage	41.93	2	20.97
1057887	7/23/2014	Planned Outage	581.50	5	116.3
1057891	7/23/2014	Planned Outage	13.77	1	13.77
1057895	7/23/2014	Planned Outage	48.50	2	24.25
1057896	7/23/2014	Planned Outage	213.73	4	53.43
1057898	7/23/2014	Planned Outage	24.18	1	24.18
1057899	7/23/2014	Planned Outage	48.57	2	24.28
1057904	7/23/2014	Planned Outage	734.08	23	31.92
1057906	7/23/2014	Planned Outage	561.77	38	14.78
1057927	7/24/2014	Planned Outage	85.10	3	28.37
1057930	7/24/2014	Planned Outage	36.05	1	36.05
1057931	7/24/2014	Planned Outage	720.90	18	40.05
1057932	7/24/2014	Planned Outage	158.00	4	39.5
1057933	7/24/2014	Planned Outage	335.50	6	55.92
1057934	7/24/2014	Planned Outage	77.58	1	77.58
1057935	7/24/2014	Planned Outage	520.50	5	104.1
1057938	7/24/2014	Planned Outage	10.72	1	10.72
1057943	7/24/2014	Planned Outage	1,238.50	15	82.57
1057947	7/24/2014	Planned Outage	154.67	2	77.33
1057948	7/24/2014	Planned Outage	51.45	7	7.35
1057951	7/24/2014	Planned Outage	29.20	2	14.6
1057957	7/24/2014	Planned Outage	26.28	1	26.28
1057959	7/24/2014	Planned Outage	22.78	1	22.78

Appendix 1

2014 Planned Outages Table

1057963	7/24/2014	Planned Outage	26.95	3	8.98
1057964	7/24/2014	Planned Outage	79.50	2	39.75
1057965	7/24/2014	Planned Outage	54.93	2	27.47
1057967	7/24/2014	Planned Outage	227.70	9	25.3
1057968	7/24/2014	Planned Outage	222.00	6	37
1057971	7/24/2014	Planned Outage	37.58	1	37.58
1057978	7/24/2014	Planned Outage	25.65	3	8.55
1057990	7/24/2014	Planned Outage	11.95	1	11.95
1057991	7/24/2014	Planned Outage	102.87	4	25.72
1058002	7/24/2014	Planned Outage	357.47	7	51.07
1058022	7/24/2014	Planned Outage	149.35	3	49.78
1058043	7/25/2014	Planned Outage	67.27	2	33.63
1058044	7/25/2014	Planned Outage	247.13	11	22.47
1058045	7/25/2014	Planned Outage	47.83	2	23.92
1058055	7/25/2014	Planned Outage	144.25	5	28.85
1058058	7/25/2014	Planned Outage	67.20	12	5.6
1058059	7/25/2014	Planned Outage	396.50	5	79.3
1058061	7/25/2014	Planned Outage	21.80	2	10.9
1058065	7/25/2014	Planned Outage	28.20	1	28.2
1058085	7/25/2014	Planned Outage	134.07	4	33.52
1058090	7/25/2014	Planned Outage	47.33	8	5.92
1058122	7/25/2014	Planned Outage	33.80	1	33.8
1058170	7/26/2014	Planned Outage	224.13	1	224.13
1058171	7/26/2014	Planned Outage	290.88	1	290.88
1058193	7/26/2014	Planned Outage	37.32	1	37.32
1058461	7/26/2014	Planned Outage	168.20	6	28.03
1058463	7/26/2014	Planned Outage	138.42	5	27.68
1058515	7/27/2014	Planned Outage	6.23	2	3.12
1058524	7/27/2014	Planned Outage	1,222.00	156	7.83
1058544	7/27/2014	Planned Outage	5.20	1	5.2
1058628	7/27/2014	Planned Outage	396.00	4	99
1059448	7/28/2014	Planned Outage	152.53	4	38.13
1059449	7/28/2014	Planned Outage	23.77	1	23.77
1059450	7/28/2014	Planned Outage	69.00	3	23
1059451	7/28/2014	Planned Outage	1,050.00	14	75
1059454	7/28/2014	Planned Outage	180.00	2	90
1059456	7/28/2014	Planned Outage	38.03	2	19.02
1059460	7/28/2014	Planned Outage	148.67	2	74.33
1059463	7/28/2014	Planned Outage	5,388.60	84	64.15
1059465	7/28/2014	Planned Outage	2,070.35	3	690.12
1059472	7/28/2014	Planned Outage	28.00	1	28
1059473	7/28/2014	Planned Outage	22.17	1	22.17
1059474	7/28/2014	Planned Outage	50.65	1	50.65
1059475	7/28/2014	Planned Outage	23.70	2	11.85
1059476	7/28/2014	Planned Outage	362.58	5	72.52
1059479	7/28/2014	Planned Outage	86.00	2	43
1059489	7/28/2014	Planned Outage	1,425.00	45	31.67
1059492	7/28/2014	Planned Outage	66.00	3	22
1059493	7/28/2014	Planned Outage	151.72	1	151.72

Appendix 1

2014 Planned Outages Table

1059494	7/28/2014	Planned Outage	1,768.20	12	147.35
1059500	7/28/2014	Planned Outage	31.80	2	15.9
1059502	7/28/2014	Planned Outage	206.00	1	206
1059506	7/28/2014	Planned Outage	18.78	1	18.78
1059508	7/28/2014	Planned Outage	63.00	1	63
1059511	7/28/2014	Planned Outage	29.00	1	29
1059514	7/28/2014	Planned Outage	60.00	1	60
1059516	7/28/2014	Planned Outage	118.00	2	59
1059519	7/28/2014	Planned Outage	226.45	21	10.78
1059537	7/28/2014	Planned Outage	53.00	1	53
1059538	7/28/2014	Planned Outage	96.00	4	24
1059551	7/28/2014	Planned Outage	88.00	4	22
1059553	7/28/2014	Planned Outage	96.00	3	32
1059560	7/28/2014	Planned Outage	137.17	5	27.43
1059565	7/28/2014	Planned Outage	41.53	2	20.77
1059571	7/28/2014	Planned Outage	69.27	2	34.63
1059572	7/28/2014	Planned Outage	17.18	1	17.18
1059573	7/28/2014	Planned Outage	86.33	2	43.17
1059602	7/28/2014	Planned Outage	65.55	3	21.85
1059648	7/28/2014	Planned Outage	18.27	1	18.27
1059744	7/29/2014	Planned Outage	170.30	6	28.38
1059750	7/29/2014	Planned Outage	86.98	1	86.98
1059752	7/29/2014	Planned Outage	150.87	4	37.72
1059755	7/29/2014	Planned Outage	342.93	2	171.47
1059757	7/29/2014	Planned Outage	6,251.00	70	89.3
1059759	7/29/2014	Planned Outage	87.88	1	87.88
1059766	7/29/2014	Planned Outage	126.25	5	25.25
1059768	7/29/2014	Planned Outage	102.30	6	17.05
1059769	7/29/2014	Planned Outage	98.48	1	98.48
1059775	7/29/2014	Planned Outage	1,453.70	6	242.28
1059776	7/29/2014	Planned Outage	3,646.63	31	117.63
1059779	7/29/2014	Planned Outage	121.93	1	121.93
1059780	7/29/2014	Planned Outage	1,398.80	13	107.6
1059784	7/29/2014	Planned Outage	21.00	1	21
1059785	7/29/2014	Planned Outage	5.20	1	5.2
1059791	7/29/2014	Planned Outage	57.00	3	19
1059792	7/29/2014	Planned Outage	525.60	8	65.7
1059797	7/29/2014	Planned Outage	18.60	1	18.6
1059808	7/29/2014	Planned Outage	194.30	3	64.77
1059811	7/29/2014	Planned Outage	138.13	4	34.53
1059820	7/29/2014	Planned Outage	98.62	1	98.62
1059825	7/29/2014	Planned Outage	76.00	4	19
1059828	7/29/2014	Planned Outage	88.00	4	22
1059831	7/29/2014	Planned Outage	18.35	1	18.35
1059832	7/29/2014	Planned Outage	162.00	3	54
1059836	7/29/2014	Planned Outage	93.23	2	46.62
1059837	7/29/2014	Planned Outage	925.10	66	14.02
1059839	7/29/2014	Planned Outage	203.27	4	50.82
1059842	7/29/2014	Planned Outage	381.20	4	95.3

Appendix 1

2014 Planned Outages Table

1059844	7/29/2014	Planned Outage	6.73	1	6.73
1059845	7/29/2014	Planned Outage	12.70	1	12.7
1059846	7/29/2014	Planned Outage	116.20	4	29.05
1059848	7/29/2014	Planned Outage	100.87	2	50.43
1059849	7/29/2014	Planned Outage	51.73	2	25.87
1059850	7/29/2014	Planned Outage	82.30	2	41.15
1059851	7/29/2014	Planned Outage	936.13	8	117.02
1059853	7/29/2014	Planned Outage	54.73	2	27.37
1059858	7/29/2014	Planned Outage	198.73	4	49.68
1059859	7/29/2014	Planned Outage	77.75	1	77.75
1059862	7/29/2014	Planned Outage	175.98	1	175.98
1059871	7/29/2014	Planned Outage	33.20	2	16.6
1059873	7/29/2014	Planned Outage	41.53	2	20.77
1059877	7/29/2014	Planned Outage	136.40	4	34.1
1059884	7/29/2014	Planned Outage	31.70	1	31.7
1059887	7/29/2014	Planned Outage	46.27	4	11.57
1059888	7/29/2014	Planned Outage	37.07	2	18.53
1059893	7/29/2014	Planned Outage	11.53	1	11.53
1059905	7/30/2014	Planned Outage	34.22	1	34.22
1059912	7/30/2014	Planned Outage	15.55	3	5.18
1059915	7/30/2014	Planned Outage	1,491.47	8	186.43
1059916	7/30/2014	Planned Outage	665.80	3	221.93
1059920	7/30/2014	Planned Outage	223.10	6	37.18
1059925	7/30/2014	Planned Outage	271.40	4	67.85
1059926	7/30/2014	Planned Outage	19.62	1	19.62
1059929	7/30/2014	Planned Outage	39.37	1	39.37
1059930	7/30/2014	Planned Outage	226.70	6	37.78
1059932	7/30/2014	Planned Outage	811.65	7	115.95
1059934	7/30/2014	Planned Outage	136.10	3	45.37
1059935	7/30/2014	Planned Outage	75.10	2	37.55
1059938	7/30/2014	Planned Outage	36.07	4	9.02
1059941	7/30/2014	Planned Outage	506.70	6	84.45
1059942	7/30/2014	Planned Outage	506.10	6	84.35
1059944	7/30/2014	Planned Outage	9.18	1	9.18
1059948	7/30/2014	Planned Outage	91.07	2	45.53
1059950	7/30/2014	Planned Outage	14.17	1	14.17
1059951	7/30/2014	Planned Outage	418.95	7	59.85
1059955	7/30/2014	Planned Outage	315.55	3	105.18
1059960	7/30/2014	Planned Outage	115.75	3	38.58
1059961	7/30/2014	Planned Outage	62.30	6	10.38
1059964	7/30/2014	Planned Outage	140.13	4	35.03
1059969	7/30/2014	Planned Outage	54.55	3	18.18
1059972	7/30/2014	Planned Outage	98.53	4	24.63
1059975	7/30/2014	Planned Outage	15.30	2	7.65
1059976	7/30/2014	Planned Outage	35.00	3	11.67
1059978	7/30/2014	Planned Outage	25.35	3	8.45
1059979	7/30/2014	Planned Outage	15.08	1	15.08
1059980	7/30/2014	Planned Outage	65.30	6	10.88
1059981	7/30/2014	Planned Outage	99.27	2	49.63

Appendix 1

2014 Planned Outages Table

1059982	7/30/2014	Planned Outage	104.10	9	11.57
1059983	7/30/2014	Planned Outage	18.68	1	18.68
1059985	7/30/2014	Planned Outage	45.60	2	22.8
1059987	7/30/2014	Planned Outage	19.55	3	6.52
1059993	7/30/2014	Planned Outage	58.27	4	14.57
1059994	7/30/2014	Planned Outage	65.40	4	16.35
1059998	7/30/2014	Planned Outage	170.57	7	24.37
1060001	7/30/2014	Planned Outage	142.20	4	35.55
1060002	7/30/2014	Planned Outage	71.20	3	23.73
1060006	7/30/2014	Planned Outage	536.70	6	89.45
1060013	7/30/2014	Planned Outage	33.43	1	33.43
1060014	7/30/2014	Planned Outage	45.07	4	11.27
1060015	7/30/2014	Planned Outage	361.55	7	51.65
1060019	7/30/2014	Planned Outage	569.40	6	94.9
1060045	7/30/2014	Planned Outage	39.40	1	39.4
1060060	7/31/2014	Planned Outage	25.35	3	8.45
1060062	7/31/2014	Planned Outage	111.25	1	111.25
1060065	7/31/2014	Planned Outage	109.08	1	109.08
1060067	7/31/2014	Planned Outage	325.30	2	162.65
1060071	7/31/2014	Planned Outage	726.60	9	80.73
1060072	7/31/2014	Planned Outage	32.35	3	10.78
1060074	7/31/2014	Planned Outage	619.20	6	103.2
1060077	7/31/2014	Planned Outage	214.33	4	53.58
1060078	7/31/2014	Planned Outage	936.00	72	13
1060085	7/31/2014	Planned Outage	124.05	1	124.05
1060287	7/31/2014	Planned Outage	75.00	1	75
1060349	7/31/2014	Planned Outage	127.00	1	127
1060351	7/31/2014	Planned Outage	346.60	3	115.53
1060441	7/31/2014	Planned Outage	926.40	18	51.47
1060443	7/31/2014	Planned Outage	49.00	1	49
1060444	7/31/2014	Planned Outage	24.10	1	24.1
1060449	7/31/2014	Planned Outage	190.05	3	63.35
1060457	7/31/2014	Planned Outage	121.10	7	17.3
1060458	7/31/2014	Planned Outage	1.15	1	1.15
1060463	7/31/2014	Planned Outage	198.90	54	3.68
1060500	8/1/2014	Planned Outage	658.93	8	82.37
1060504	8/1/2014	Planned Outage	63.25	5	12.65
1060507	8/1/2014	Planned Outage	259.87	2	129.93
1060509	8/1/2014	Planned Outage	55.33	1	55.33
1060511	8/1/2014	Planned Outage	123.13	4	30.78
1060512	8/1/2014	Planned Outage	138.65	3	46.22
1060517	8/1/2014	Planned Outage	920.47	4	230.12
1060519	8/1/2014	Planned Outage	53.97	1	53.97
1060521	8/1/2014	Planned Outage	149.50	5	29.9
1060522	8/1/2014	Planned Outage	6,883.07	104	66.18
1060524	8/1/2014	Planned Outage	237.47	4	59.37
1060588	8/1/2014	Planned Outage	31.98	1	31.98
1060589	8/1/2014	Planned Outage	58.27	4	14.57
1060590	8/1/2014	Planned Outage	154.58	1	154.58

Appendix 1

2014 Planned Outages Table

1060650	8/2/2014	Planned Outage	167.02	1	167.02
1060652	8/2/2014	Planned Outage	15.00	1	15
1060657	8/2/2014	Planned Outage	1,461.00	18	81.17
1060662	8/2/2014	Planned Outage	8.77	1	8.77
1060664	8/2/2014	Planned Outage	157.70	6	26.28
1060675	8/2/2014	Planned Outage	23.18	1	23.18
1060703	8/2/2014	Planned Outage	9.57	1	9.57
1060777	8/4/2014	Planned Outage	54.00	3	18
1060818	8/4/2014	Planned Outage	45.83	2	22.92
1060820	8/4/2014	Planned Outage	175.13	2	87.57
1060822	8/4/2014	Planned Outage	188.07	4	47.02
1060824	8/4/2014	Planned Outage	19.23	1	19.23
1060826	8/4/2014	Planned Outage	526.73	4	131.68
1060831	8/4/2014	Planned Outage	1,540.00	6	256.67
1060835	8/4/2014	Planned Outage	46.10	1	46.1
1060836	8/4/2014	Planned Outage	34.63	2	17.32
1060837	8/4/2014	Planned Outage	16.83	2	8.42
1060838	8/4/2014	Planned Outage	227.23	2	113.62
1060842	8/4/2014	Planned Outage	205.20	6	34.2
1060844	8/4/2014	Planned Outage	412.87	4	103.22
1060852	8/4/2014	Planned Outage	54.87	1	54.87
1060853	8/4/2014	Planned Outage	62.40	2	31.2
1060858	8/4/2014	Planned Outage	17.92	1	17.92
1060861	8/4/2014	Planned Outage	35.47	1	35.47
1060863	8/4/2014	Planned Outage	545.75	15	36.38
1060866	8/4/2014	Planned Outage	68.57	2	34.28
1060868	8/4/2014	Planned Outage	6,619.73	58	114.13
1060874	8/4/2014	Planned Outage	666.33	10	66.63
1060876	8/4/2014	Planned Outage	375.78	7	53.68
1060883	8/4/2014	Planned Outage	31.08	1	31.08
1060886	8/4/2014	Planned Outage	37.13	2	18.57
1060892	8/4/2014	Planned Outage	376.27	4	94.07
1060894	8/4/2014	Planned Outage	58.20	4	14.55
1060909	8/4/2014	Planned Outage	29.02	1	29.02
1060926	8/4/2014	Planned Outage	126.60	4	31.65
1060928	8/4/2014	Planned Outage	6.00	1	6
1060929	8/4/2014	Planned Outage	75.62	1	75.62
1060930	8/4/2014	Planned Outage	72.67	2	36.33
1060933	8/4/2014	Planned Outage	250.27	4	62.57
1060934	8/4/2014	Planned Outage	53.57	1	53.57
1060938	8/4/2014	Planned Outage	34.17	1	34.17
1060939	8/4/2014	Planned Outage	350.53	11	31.87
1060941	8/4/2014	Planned Outage	5.03	2	2.52
1061024	8/5/2014	Planned Outage	27.65	1	27.65
1061026	8/5/2014	Planned Outage	47.90	3	15.97
1061030	8/5/2014	Planned Outage	57.32	1	57.32
1061035	8/5/2014	Planned Outage	1,585.33	10	158.53
1061041	8/5/2014	Planned Outage	23.15	1	23.15
1061042	8/5/2014	Planned Outage	497.00	7	71

Appendix 1

2014 Planned Outages Table

1061045	8/5/2014	Planned Outage	1,988.13	8	248.52
1061046	8/5/2014	Planned Outage	61.38	1	61.38
1061048	8/5/2014	Planned Outage	1,335.80	6	222.63
1061051	8/5/2014	Planned Outage	101.15	3	33.72
1061052	8/5/2014	Planned Outage	178.20	1	178.2
1061056	8/5/2014	Planned Outage	42.28	1	42.28
1061059	8/5/2014	Planned Outage	396.33	4	99.08
1061060	8/5/2014	Planned Outage	97.93	1	97.93
1061062	8/5/2014	Planned Outage	54.22	1	54.22
1061064	8/5/2014	Planned Outage	45.83	1	45.83
1061065	8/5/2014	Planned Outage	135.30	3	45.1
1061066	8/5/2014	Planned Outage	45.25	1	45.25
1061067	8/5/2014	Planned Outage	69.23	2	34.62
1061068	8/5/2014	Planned Outage	31.43	2	15.72
1061073	8/5/2014	Planned Outage	40.02	1	40.02
1061079	8/5/2014	Planned Outage	184.87	4	46.22
1061081	8/5/2014	Planned Outage	13.10	2	6.55
1061082	8/5/2014	Planned Outage	10.03	1	10.03
1061084	8/5/2014	Planned Outage	153.40	3	51.13
1061096	8/5/2014	Planned Outage	18.67	2	9.33
1061099	8/5/2014	Planned Outage	26.25	3	8.75
1061100	8/5/2014	Planned Outage	7.83	1	7.83
1061108	8/5/2014	Planned Outage	61.45	1	61.45
1061109	8/5/2014	Planned Outage	46.98	1	46.98
1061117	8/5/2014	Planned Outage	35.67	5	7.13
1061128	8/5/2014	Planned Outage	28.20	1	28.2
1061142	8/5/2014	Planned Outage	31.87	4	7.97
1061143	8/5/2014	Planned Outage	6.93	1	6.93
1061147	8/5/2014	Planned Outage	157.60	3	52.53
1061148	8/5/2014	Planned Outage	209.07	4	52.27
1061155	8/5/2014	Planned Outage	187.50	9	20.83
1061157	8/5/2014	Planned Outage	657.07	7	93.87
1061163	8/5/2014	Planned Outage	43.87	1	43.87
1061176	8/5/2014	Planned Outage	184.00	8	23
1061220	8/6/2014	Planned Outage	120.93	1	120.93
1061237	8/6/2014	Planned Outage	176.07	2	88.03
1061245	8/6/2014	Planned Outage	84.30	3	28.1
1061250	8/6/2014	Planned Outage	737.85	3	245.95
1061254	8/6/2014	Planned Outage	524.13	4	131.03
1061255	8/6/2014	Planned Outage	4,134.00	90	45.93
1061258	8/6/2014	Planned Outage	43.72	1	43.72
1061262	8/6/2014	Planned Outage	231.83	5	46.37
1061263	8/6/2014	Planned Outage	15.00	1	15
1061264	8/6/2014	Planned Outage	443.00	1	443
1061265	8/6/2014	Planned Outage	279.58	5	55.92
1061270	8/6/2014	Planned Outage	22,798.77	199	114.57
1061272	8/6/2014	Planned Outage	22.17	1	22.17
1061273	8/6/2014	Planned Outage	347.25	5	69.45
1061274	8/6/2014	Planned Outage	64.55	3	21.52

Appendix 1

2014 Planned Outages Table

1061275	8/6/2014	Planned Outage	956.25	5	191.25
1061281	8/6/2014	Planned Outage	29.57	1	29.57
1061286	8/6/2014	Planned Outage	130.02	1	130.02
1061289	8/6/2014	Planned Outage	253.43	2	126.72
1061291	8/6/2014	Planned Outage	92.60	2	46.3
1061294	8/6/2014	Planned Outage	17.23	1	17.23
1061295	8/6/2014	Planned Outage	160.93	4	40.23
1061297	8/6/2014	Planned Outage	113.33	5	22.67
1061312	8/6/2014	Planned Outage	49.02	1	49.02
1061313	8/6/2014	Planned Outage	98.57	2	49.28
1061316	8/6/2014	Planned Outage	149.60	2	74.8
1061318	8/6/2014	Planned Outage	251.30	6	41.88
1061321	8/6/2014	Planned Outage	217.35	3	72.45
1061323	8/6/2014	Planned Outage	342.83	22	15.58
1061324	8/6/2014	Planned Outage	304.70	22	13.85
1061325	8/6/2014	Planned Outage	586.93	4	146.73
1061328	8/6/2014	Planned Outage	41.07	4	10.27
1061331	8/6/2014	Planned Outage	128.03	1	128.03
1061332	8/6/2014	Planned Outage	744.73	2	372.37
1061335	8/6/2014	Planned Outage	39.00	2	19.5
1061338	8/6/2014	Planned Outage	165.13	2	82.57
1061345	8/6/2014	Planned Outage	178.07	4	44.52
1061348	8/6/2014	Planned Outage	66.70	2	33.35
1061350	8/6/2014	Planned Outage	360.20	6	60.03
1061353	8/6/2014	Planned Outage	47.17	2	23.58
1061356	8/6/2014	Planned Outage	7.65	1	7.65
1061357	8/6/2014	Planned Outage	916.53	4	229.13
1061391	8/7/2014	Planned Outage	21.00	2	10.5
1061393	8/7/2014	Planned Outage	34.97	1	34.97
1061395	8/7/2014	Planned Outage	71.07	4	17.77
1061411	8/7/2014	Planned Outage	21.43	2	10.72
1061413	8/7/2014	Planned Outage	10.27	1	10.27
1061416	8/7/2014	Planned Outage	111.98	1	111.98
1061417	8/7/2014	Planned Outage	561.97	2	280.98
1061418	8/7/2014	Planned Outage	43.18	1	43.18
1061419	8/7/2014	Planned Outage	31.68	1	31.68
1061422	8/7/2014	Planned Outage	41.12	1	41.12
1061425	8/7/2014	Planned Outage	60.40	2	30.2
1061428	8/7/2014	Planned Outage	19.85	1	19.85
1061430	8/7/2014	Planned Outage	1,185.50	5	237.1
1061432	8/7/2014	Planned Outage	236.80	1	236.8
1061433	8/7/2014	Planned Outage	872.32	7	124.62
1061435	8/7/2014	Planned Outage	175.25	3	58.42
1061438	8/7/2014	Planned Outage	2,277.50	15	151.83
1061439	8/7/2014	Planned Outage	37.60	2	18.8
1061444	8/7/2014	Planned Outage	114.80	6	19.13
1061449	8/7/2014	Planned Outage	14.27	1	14.27
1061450	8/7/2014	Planned Outage	7.68	1	7.68
1061453	8/7/2014	Planned Outage	15.87	1	15.87

Appendix 1

2014 Planned Outages Table

1061486	8/7/2014	Planned Outage	285.42	5	57.08
1061489	8/7/2014	Planned Outage	75.00	4	18.75
1061495	8/7/2014	Planned Outage	23.88	1	23.88
1061497	8/7/2014	Planned Outage	146.80	2	73.4
1061588	8/8/2014	Planned Outage	149.65	1	149.65
1061589	8/8/2014	Planned Outage	1,238.33	25	49.53
1061598	8/8/2014	Planned Outage	119.13	1	119.13
1061609	8/8/2014	Planned Outage	17.38	1	17.38
1061610	8/8/2014	Planned Outage	295.87	28	10.57
1061612	8/8/2014	Planned Outage	286.65	27	10.62
1061616	8/8/2014	Planned Outage	88.73	1	88.73
1061678	8/8/2014	Planned Outage	11.57	1	11.57
1061722	8/8/2014	Planned Outage	730.95	33	22.15
1061784	8/9/2014	Planned Outage	112.53	1	112.53
1061805	8/9/2014	Planned Outage	44.07	1	44.07
1061824	8/9/2014	Planned Outage	32.78	1	32.78
1061840	8/9/2014	Planned Outage	62.80	1	62.8
1062011	8/10/2014	Planned Outage	11.00	1	11
1062063	8/11/2014	Planned Outage	254.68	7	36.38
1062066	8/11/2014	Planned Outage	36.10	2	18.05
1062067	8/11/2014	Planned Outage	61.53	1	61.53
1062073	8/11/2014	Planned Outage	204.40	4	51.1
1062075	8/11/2014	Planned Outage	29.87	1	29.87
1062076	8/11/2014	Planned Outage	156.33	4	39.08
1062077	8/11/2014	Planned Outage	790.08	5	158.02
1062078	8/11/2014	Planned Outage	25.77	2	12.88
1062080	8/11/2014	Planned Outage	132.13	4	33.03
1062085	8/11/2014	Planned Outage	88.40	2	44.2
1062086	8/11/2014	Planned Outage	536.20	4	134.05
1062087	8/11/2014	Planned Outage	77.43	2	38.72
1062088	8/11/2014	Planned Outage	192.33	2	96.17
1062089	8/11/2014	Planned Outage	29.27	2	14.63
1062093	8/11/2014	Planned Outage	1,980.53	56	35.37
1062095	8/11/2014	Planned Outage	292.95	9	32.55
1062096	8/11/2014	Planned Outage	222.20	3	74.07
1062101	8/11/2014	Planned Outage	13.33	1	13.33
1062103	8/11/2014	Planned Outage	91.33	2	45.67
1062106	8/11/2014	Planned Outage	14.42	1	14.42
1062109	8/11/2014	Planned Outage	48.85	1	48.85
1062111	8/11/2014	Planned Outage	45.43	1	45.43
1062112	8/11/2014	Planned Outage	359.50	5	71.9
1062113	8/11/2014	Planned Outage	61.90	3	20.63
1062115	8/11/2014	Planned Outage	429.92	11	39.08
1062119	8/11/2014	Planned Outage	73.65	3	24.55
1062121	8/11/2014	Planned Outage	73.80	3	24.6
1062125	8/11/2014	Planned Outage	1,121.13	4	280.28
1062126	8/11/2014	Planned Outage	4.73	4	1.18
1062128	8/11/2014	Planned Outage	145.53	4	36.38
1062129	8/11/2014	Planned Outage	945.33	4	236.33

Appendix 1

2014 Planned Outages Table

1062130	8/11/2014	Planned Outage	87.50	5	17.5
1062133	8/11/2014	Planned Outage	84.95	3	28.32
1062144	8/11/2014	Planned Outage	353.30	2	176.65
1062175	8/12/2014	Planned Outage	7.13	1	7.13
1062176	8/12/2014	Planned Outage	65.83	2	32.92
1062177	8/12/2014	Planned Outage	34.60	4	8.65
1062179	8/12/2014	Planned Outage	387.85	3	129.28
1062181	8/12/2014	Planned Outage	152.13	1	152.13
1062182	8/12/2014	Planned Outage	175.83	5	35.17
1062184	8/12/2014	Planned Outage	388.65	3	129.55
1062185	8/12/2014	Planned Outage	333.45	3	111.15
1062187	8/12/2014	Planned Outage	144.97	1	144.97
1062188	8/12/2014	Planned Outage	13,532.77	181	74.77
1062199	8/12/2014	Planned Outage	52.70	3	17.57
1062202	8/12/2014	Planned Outage	146.07	7	20.87
1062204	8/12/2014	Planned Outage	880.02	7	125.72
1062205	8/12/2014	Planned Outage	826.70	6	137.78
1062208	8/12/2014	Planned Outage	1,351.73	8	168.97
1062212	8/12/2014	Planned Outage	94.40	3	31.47
1062213	8/12/2014	Planned Outage	58.15	3	19.38
1062217	8/12/2014	Planned Outage	55.27	1	55.27
1062220	8/12/2014	Planned Outage	1,973.88	49	40.28
1062225	8/12/2014	Planned Outage	132.60	4	33.15
1062226	8/12/2014	Planned Outage	87.93	4	21.98
1062228	8/12/2014	Planned Outage	48.05	3	16.02
1062231	8/12/2014	Planned Outage	434.37	2	217.18
1062235	8/12/2014	Planned Outage	206.50	5	41.3
1062242	8/12/2014	Planned Outage	39.80	3	13.27
1062248	8/12/2014	Planned Outage	10.33	2	5.17
1062250	8/12/2014	Planned Outage	80.40	4	20.1
1062254	8/12/2014	Planned Outage	245.80	3	81.93
1062257	8/12/2014	Planned Outage	110.60	7	15.8
1062258	8/12/2014	Planned Outage	39.38	1	39.38
1062259	8/12/2014	Planned Outage	74.20	1	74.2
1062261	8/12/2014	Planned Outage	86.20	1	86.2
1062391	8/13/2014	Planned Outage	24.98	1	24.98
1062393	8/13/2014	Planned Outage	132.07	1	132.07
1062402	8/13/2014	Planned Outage	191.10	7	27.3
1062404	8/13/2014	Planned Outage	280.80	6	46.8
1062407	8/13/2014	Planned Outage	136.95	1	136.95
1062408	8/13/2014	Planned Outage	72.20	4	18.05
1062411	8/13/2014	Planned Outage	8.00	1	8
1062412	8/13/2014	Planned Outage	1,067.00	6	177.83
1062413	8/13/2014	Planned Outage	21.50	3	7.17
1062419	8/13/2014	Planned Outage	78.43	2	39.22
1062420	8/13/2014	Planned Outage	1,160.17	5	232.03
1062427	8/13/2014	Planned Outage	138.03	2	69.02
1062429	8/13/2014	Planned Outage	68.47	2	34.23
1062436	8/13/2014	Planned Outage	76.88	1	76.88

Appendix 1

2014 Planned Outages Table

1062441	8/13/2014	Planned Outage	103.67	5	20.73
1062446	8/13/2014	Planned Outage	80.05	3	26.68
1062454	8/13/2014	Planned Outage	495.60	4	123.9
1062455	8/13/2014	Planned Outage	155.73	4	38.93
1062459	8/13/2014	Planned Outage	582.73	4	145.68
1062460	8/13/2014	Planned Outage	1,054.60	6	175.77
1062461	8/13/2014	Planned Outage	876.67	5	175.33
1062473	8/13/2014	Planned Outage	1,177.92	25	47.12
1062477	8/13/2014	Planned Outage	9.30	1	9.3
1062485	8/13/2014	Planned Outage	74.30	3	24.77
1062491	8/13/2014	Planned Outage	121.00	2	60.5
1062492	8/13/2014	Planned Outage	46.80	6	7.8
1062495	8/13/2014	Planned Outage	72.00	5	14.4
1062499	8/13/2014	Planned Outage	280.87	2	140.43
1062501	8/13/2014	Planned Outage	277.97	2	138.98
1062524	8/14/2014	Planned Outage	321.47	4	80.37
1062527	8/14/2014	Planned Outage	3.67	1	3.67
1062530	8/14/2014	Planned Outage	300.40	4	75.1
1062532	8/14/2014	Planned Outage	625.20	9	69.47
1062534	8/14/2014	Planned Outage	16.15	1	16.15
1062536	8/14/2014	Planned Outage	7.12	1	7.12
1062540	8/14/2014	Planned Outage	20.10	1	20.1
1062541	8/14/2014	Planned Outage	546.67	8	68.33
1062544	8/14/2014	Planned Outage	309.45	3	103.15
1062548	8/14/2014	Planned Outage	202.70	2	101.35
1062550	8/14/2014	Planned Outage	4,224.98	53	79.72
1062551	8/14/2014	Planned Outage	106.60	3	35.53
1062554	8/14/2014	Planned Outage	1,474.20	7	210.6
1062556	8/14/2014	Planned Outage	23.07	2	11.53
1062557	8/14/2014	Planned Outage	116.87	4	29.22
1062560	8/14/2014	Planned Outage	1,606.00	8	200.75
1062563	8/14/2014	Planned Outage	34.10	3	11.37
1062569	8/14/2014	Planned Outage	86.35	3	28.78
1062571	8/14/2014	Planned Outage	35.45	3	11.82
1062572	8/14/2014	Planned Outage	71.10	6	11.85
1062576	8/14/2014	Planned Outage	14.13	2	7.07
1062578	8/14/2014	Planned Outage	17.23	2	8.62
1062580	8/14/2014	Planned Outage	22.53	2	11.27
1062581	8/14/2014	Planned Outage	24.67	2	12.33
1062592	8/14/2014	Planned Outage	60.95	1	60.95
1062637	8/15/2014	Planned Outage	64.93	4	16.23
1062639	8/15/2014	Planned Outage	214.03	2	107.02
1062643	8/15/2014	Planned Outage	63.90	1	63.9
1062648	8/15/2014	Planned Outage	146.10	3	48.7
1062652	8/15/2014	Planned Outage	1,111.13	7	158.73
1062661	8/15/2014	Planned Outage	10.75	3	3.58
1062662	8/15/2014	Planned Outage	3.57	1	3.57
1062663	8/15/2014	Planned Outage	3,405.38	7	486.48
1062664	8/15/2014	Planned Outage	224.25	9	24.92

Appendix 1

2014 Planned Outages Table

1062665	8/15/2014	Planned Outage	28.47	2	14.23
1062666	8/15/2014	Planned Outage	8.05	1	8.05
1062673	8/15/2014	Planned Outage	273.35	11	24.85
1062674	8/15/2014	Planned Outage	4,947.83	35	141.37
1062708	8/15/2014	Planned Outage	21.43	2	10.72
1063081	8/17/2014	Planned Outage	1,689.10	7	241.3
1063107	8/17/2014	Planned Outage	12.22	1	12.22
1063191	8/18/2014	Planned Outage	499.70	6	83.28
1063196	8/18/2014	Planned Outage	36.37	1	36.37
1063199	8/18/2014	Planned Outage	131.50	3	43.83
1063208	8/18/2014	Planned Outage	234.67	2	117.33
1063210	8/18/2014	Planned Outage	155.30	1	155.3
1063212	8/18/2014	Planned Outage	12.33	2	6.17
1063215	8/18/2014	Planned Outage	1,082.92	5	216.58
1063217	8/18/2014	Planned Outage	147.70	3	49.23
1063218	8/18/2014	Planned Outage	130.30	1	130.3
1063223	8/18/2014	Planned Outage	101.13	2	50.57
1063225	8/18/2014	Planned Outage	74.13	2	37.07
1063226	8/18/2014	Planned Outage	208.72	1	208.72
1063233	8/18/2014	Planned Outage	116.60	3	38.87
1063234	8/18/2014	Planned Outage	57.07	4	14.27
1063236	8/18/2014	Planned Outage	11.85	1	11.85
1063237	8/18/2014	Planned Outage	74.03	2	37.02
1063267	8/18/2014	Planned Outage	139.23	2	69.62
1063302	8/18/2014	Planned Outage	27.57	2	13.78
1063317	8/18/2014	Planned Outage	64.67	2	32.33
1063334	8/18/2014	Planned Outage	108.00	4	27
1063341	8/18/2014	Planned Outage	115.43	2	57.72
1063344	8/18/2014	Planned Outage	115.87	1	115.87
1063345	8/18/2014	Planned Outage	536.60	4	134.15
1063350	8/18/2014	Planned Outage	126.00	3	42
1063391	8/18/2014	Planned Outage	4,334.10	9	481.57
1063511	8/19/2014	Planned Outage	161.80	1	161.8
1063513	8/19/2014	Planned Outage	30.87	2	15.43
1063515	8/19/2014	Planned Outage	20.22	1	20.22
1063518	8/19/2014	Planned Outage	94.33	4	23.58
1063521	8/19/2014	Planned Outage	353.67	4	88.42
1063522	8/19/2014	Planned Outage	943.50	6	157.25
1063523	8/19/2014	Planned Outage	170.53	1	170.53
1063525	8/19/2014	Planned Outage	124.90	1	124.9
1063527	8/19/2014	Planned Outage	16.33	4	4.08
1063529	8/19/2014	Planned Outage	14.03	2	7.02
1063530	8/19/2014	Planned Outage	127.35	3	42.45
1063531	8/19/2014	Planned Outage	281.15	3	93.72
1063532	8/19/2014	Planned Outage	4.00	2	2
1063535	8/19/2014	Planned Outage	1,646.02	13	126.62
1063536	8/19/2014	Planned Outage	43.67	1	43.67
1063548	8/19/2014	Planned Outage	375.00	5	75
1063549	8/19/2014	Planned Outage	102.60	6	17.1

Appendix 1

2014 Planned Outages Table

1063554	8/19/2014	Planned Outage	761.33	4	190.33
1063556	8/19/2014	Planned Outage	372.10	3	124.03
1063558	8/19/2014	Planned Outage	37.25	1	37.25
1063566	8/19/2014	Planned Outage	18.17	1	18.17
1063569	8/19/2014	Planned Outage	36.15	3	12.05
1063580	8/19/2014	Planned Outage	19.80	3	6.6
1063779	8/20/2014	Planned Outage	8.48	1	8.48
1063782	8/20/2014	Planned Outage	25.27	1	25.27
1063787	8/20/2014	Planned Outage	5.80	1	5.8
1063790	8/20/2014	Planned Outage	99.40	2	49.7
1063793	8/20/2014	Planned Outage	1,553.30	14	110.95
1063795	8/20/2014	Planned Outage	47.90	2	23.95
1063796	8/20/2014	Planned Outage	301.55	3	100.52
1063798	8/20/2014	Planned Outage	123.47	1	123.47
1063799	8/20/2014	Planned Outage	166.32	1	166.32
1063802	8/20/2014	Planned Outage	521.50	7	74.5
1063808	8/20/2014	Planned Outage	99.07	1	99.07
1063811	8/20/2014	Planned Outage	5,592.80	48	116.52
1063821	8/20/2014	Planned Outage	93.00	3	31
1063828	8/20/2014	Planned Outage	72.87	1	72.87
1063831	8/20/2014	Planned Outage	162.67	10	16.27
1063832	8/20/2014	Planned Outage	41.43	2	20.72
1063836	8/20/2014	Planned Outage	53.53	4	13.38
1063840	8/20/2014	Planned Outage	59.40	4	14.85
1063843	8/20/2014	Planned Outage	491.00	4	122.75
1063848	8/20/2014	Planned Outage	501.87	4	125.47
1063856	8/20/2014	Planned Outage	119.07	2	59.53
1063862	8/20/2014	Planned Outage	51.50	6	8.58
1063866	8/20/2014	Planned Outage	22.92	5	4.58
1063870	8/20/2014	Planned Outage	60.20	2	30.1
1063910	8/21/2014	Planned Outage	102.00	2	51
1063912	8/21/2014	Planned Outage	55.48	1	55.48
1063928	8/21/2014	Planned Outage	79.88	1	79.88
1063929	8/21/2014	Planned Outage	53.45	1	53.45
1063934	8/21/2014	Planned Outage	13,720.45	59	232.55
1063935	8/21/2014	Planned Outage	83.78	1	83.78
1063936	8/21/2014	Planned Outage	120.17	1	120.17
1063937	8/21/2014	Planned Outage	2,677.50	63	42.5
1063943	8/21/2014	Planned Outage	35.25	3	11.75
1063946	8/21/2014	Planned Outage	996.10	7	142.3
1063948	8/21/2014	Planned Outage	33.47	2	16.73
1063952	8/21/2014	Planned Outage	168.00	3	56
1063956	8/21/2014	Planned Outage	18.10	1	18.1
1063958	8/21/2014	Planned Outage	247.45	7	35.35
1064053	8/22/2014	Planned Outage	25.63	1	25.63
1064058	8/22/2014	Planned Outage	62.08	5	12.42
1064059	8/22/2014	Planned Outage	36.40	1	36.4
1064060	8/22/2014	Planned Outage	563.13	4	140.78
1064061	8/22/2014	Planned Outage	38.40	1	38.4

Appendix 1

2014 Planned Outages Table

1064063	8/22/2014	Planned Outage	135.40	4	33.85
1064065	8/22/2014	Planned Outage	68.13	2	34.07
1064066	8/22/2014	Planned Outage	14.08	1	14.08
1064067	8/22/2014	Planned Outage	8,034.95	21	382.62
1064070	8/22/2014	Planned Outage	92.57	1	92.57
1064071	8/22/2014	Planned Outage	403.00	6	67.17
1064072	8/22/2014	Planned Outage	651.58	5	130.32
1064073	8/22/2014	Planned Outage	30.55	3	10.18
1064076	8/22/2014	Planned Outage	19.40	2	9.7
1064081	8/22/2014	Planned Outage	43.53	2	21.77
1064095	8/22/2014	Planned Outage	6,249.53	52	120.18
1064098	8/22/2014	Planned Outage	225.00	1	225
1064100	8/22/2014	Planned Outage	14.63	1	14.63
1064106	8/22/2014	Planned Outage	41.17	2	20.58
1064107	8/22/2014	Planned Outage	29.73	4	7.43
1064121	8/22/2014	Planned Outage	248.27	4	62.07
1064287	8/23/2014	Planned Outage	111.87	4	27.97
1064288	8/23/2014	Planned Outage	69.40	4	17.35
1064319	8/24/2014	Planned Outage	5,158.08	17	303.42
1064323	8/24/2014	Planned Outage	238.90	6	39.82
1064466	8/24/2014	Planned Outage	266.20	2	133.1
1064673	8/25/2014	Planned Outage	92.47	1	92.47
1064676	8/25/2014	Planned Outage	119.77	1	119.77
1064679	8/25/2014	Planned Outage	65.78	1	65.78
1064685	8/25/2014	Planned Outage	12.50	1	12.5
1064686	8/25/2014	Planned Outage	102.00	2	51
1064690	8/25/2014	Planned Outage	727.20	24	30.3
1064692	8/25/2014	Planned Outage	49.85	1	49.85
1064695	8/25/2014	Planned Outage	73.43	1	73.43
1064705	8/25/2014	Planned Outage	80.52	1	80.52
1064707	8/25/2014	Planned Outage	158.50	6	26.42
1064712	8/25/2014	Planned Outage	116.00	2	58
1064716	8/25/2014	Planned Outage	83.53	2	41.77
1064718	8/25/2014	Planned Outage	71.40	4	17.85
1064720	8/25/2014	Planned Outage	198.33	7	28.33
1064723	8/25/2014	Planned Outage	61.67	1	61.67
1064724	8/25/2014	Planned Outage	17.50	1	17.5
1064725	8/25/2014	Planned Outage	147.53	4	36.88
1064727	8/25/2014	Planned Outage	107.93	4	26.98
1064728	8/25/2014	Planned Outage	55.10	1	55.1
1064735	8/25/2014	Planned Outage	357.50	6	59.58
1064736	8/25/2014	Planned Outage	63.97	1	63.97
1064737	8/25/2014	Planned Outage	327.35	3	109.12
1064743	8/25/2014	Planned Outage	411.83	1	411.83
1064787	8/25/2014	Planned Outage	39.58	1	39.58
1064788	8/25/2014	Planned Outage	146.20	6	24.37
1064803	8/25/2014	Planned Outage	9.87	1	9.87
1064808	8/25/2014	Planned Outage	443.17	2	221.58
1064809	8/25/2014	Planned Outage	50.55	3	16.85

Appendix 1

2014 Planned Outages Table

1064816	8/25/2014	Planned Outage	184.13	4	46.03
1064824	8/25/2014	Planned Outage	2,331.12	13	179.32
1064859	8/26/2014	Planned Outage	803.07	4	200.77
1064890	8/26/2014	Planned Outage	72.20	3	24.07
1064904	8/26/2014	Planned Outage	21.88	1	21.88
1064908	8/26/2014	Planned Outage	518.05	3	172.68
1064912	8/26/2014	Planned Outage	275.67	4	68.92
1064913	8/26/2014	Planned Outage	51.10	3	17.03
1064915	8/26/2014	Planned Outage	281.43	2	140.72
1064916	8/26/2014	Planned Outage	491.70	3	163.9
1064918	8/26/2014	Planned Outage	900.40	4	225.1
1064930	8/26/2014	Planned Outage	801.60	6	133.6
1064933	8/26/2014	Planned Outage	153.38	1	153.38
1064936	8/26/2014	Planned Outage	269.33	8	33.67
1064939	8/26/2014	Planned Outage	515.10	2	257.55
1064940	8/26/2014	Planned Outage	326.07	4	81.52
1064941	8/26/2014	Planned Outage	6.82	1	6.82
1064947	8/26/2014	Planned Outage	100.92	1	100.92
1064951	8/26/2014	Planned Outage	6.83	1	6.83
1064952	8/26/2014	Planned Outage	15.63	1	15.63
1064953	8/26/2014	Planned Outage	90.00	1	90
1064957	8/26/2014	Planned Outage	252.40	3	84.13
1064958	8/26/2014	Planned Outage	615.20	4	153.8
1064959	8/26/2014	Planned Outage	51.87	4	12.97
1064974	8/26/2014	Planned Outage	46.30	2	23.15
1064978	8/26/2014	Planned Outage	14.48	1	14.48
1065002	8/26/2014	Planned Outage	221.90	6	36.98
1065020	8/26/2014	Planned Outage	110.27	2	55.13
1065035	8/26/2014	Planned Outage	637.80	9	70.87
1065054	8/27/2014	Planned Outage	84.28	1	84.28
1065055	8/27/2014	Planned Outage	24.30	1	24.3
1065059	8/27/2014	Planned Outage	35,661.33	172	207.33
1065063	8/27/2014	Planned Outage	235.00	2	117.5
1065064	8/27/2014	Planned Outage	198.65	1	198.65
1065065	8/27/2014	Planned Outage	83.68	1	83.68
1065068	8/27/2014	Planned Outage	93.78	1	93.78
1065069	8/27/2014	Planned Outage	32.92	1	32.92
1065073	8/27/2014	Planned Outage	84.45	3	28.15
1065074	8/27/2014	Planned Outage	26.67	1	26.67
1065077	8/27/2014	Planned Outage	390.00	65	6
1065078	8/27/2014	Planned Outage	59.33	10	5.93
1065081	8/27/2014	Planned Outage	266.83	2	133.42
1065083	8/27/2014	Planned Outage	83.00	1	83
1065086	8/27/2014	Planned Outage	71.52	1	71.52
1065088	8/27/2014	Planned Outage	67.85	1	67.85
1065089	8/27/2014	Planned Outage	222.43	1	222.43
1065090	8/27/2014	Planned Outage	49.23	2	24.62
1065092	8/27/2014	Planned Outage	9.00	2	4.5
1065094	8/27/2014	Planned Outage	2,992.50	30	99.75

Appendix 1

2014 Planned Outages Table

1065095	8/27/2014	Planned Outage	2,502.08	25	100.08
1065096	8/27/2014	Planned Outage	58.08	1	58.08
1065097	8/27/2014	Planned Outage	147.70	6	24.62
1065099	8/27/2014	Planned Outage	537.35	1	537.35
1065100	8/27/2014	Planned Outage	165.60	6	27.6
1065104	8/27/2014	Planned Outage	65.00	65	1
1065105	8/27/2014	Planned Outage	1.87	1	1.87
1065106	8/27/2014	Planned Outage	28.03	2	14.02
1065108	8/27/2014	Planned Outage	183.47	2	91.73
1065110	8/27/2014	Planned Outage	22.03	1	22.03
1065117	8/27/2014	Planned Outage	474.07	13	36.47
1065127	8/27/2014	Planned Outage	154.00	11	14
1065132	8/27/2014	Planned Outage	68.45	3	22.82
1065133	8/27/2014	Planned Outage	35.85	3	11.95
1065239	8/27/2014	Planned Outage	122.07	4	30.52
1065279	8/28/2014	Planned Outage	8.67	2	4.33
1065282	8/28/2014	Planned Outage	6.83	2	3.42
1065286	8/28/2014	Planned Outage	129.63	1	129.63
1065288	8/28/2014	Planned Outage	859.00	5	171.8
1065290	8/28/2014	Planned Outage	102.20	3	34.07
1065295	8/28/2014	Planned Outage	82.88	1	82.88
1065296	8/28/2014	Planned Outage	155.00	4	38.75
1065299	8/28/2014	Planned Outage	4,962.47	22	225.57
1065300	8/28/2014	Planned Outage	5,865.17	26	225.58
1065303	8/28/2014	Planned Outage	533.05	21	25.38
1065307	8/28/2014	Planned Outage	405.60	4	101.4
1065310	8/28/2014	Planned Outage	283.30	3	94.43
1065311	8/28/2014	Planned Outage	94.28	1	94.28
1065313	8/28/2014	Planned Outage	84.80	1	84.8
1065316	8/28/2014	Planned Outage	1,659.17	10	165.92
1065327	8/28/2014	Planned Outage	19.23	2	9.62
1065331	8/28/2014	Planned Outage	124.67	2	62.33
1065332	8/28/2014	Planned Outage	4.43	1	4.43
1065337	8/28/2014	Planned Outage	564.20	28	20.15
1065344	8/28/2014	Planned Outage	78.07	2	39.03
1065354	8/28/2014	Planned Outage	102.40	6	17.07
1065356	8/28/2014	Planned Outage	45.37	1	45.37
1065370	8/28/2014	Planned Outage	84.53	1	84.53
1065377	8/28/2014	Planned Outage	958.10	11	87.1
1065401	8/29/2014	Planned Outage	321.73	4	80.43
1065402	8/29/2014	Planned Outage	15.08	1	15.08
1065403	8/29/2014	Planned Outage	32.33	1	32.33
1065404	8/29/2014	Planned Outage	130.15	3	43.38
1065405	8/29/2014	Planned Outage	51.92	5	10.38
1065407	8/29/2014	Planned Outage	158.93	4	39.73
1065408	8/29/2014	Planned Outage	150.80	6	25.13
1065410	8/29/2014	Planned Outage	301.13	4	75.28
1065411	8/29/2014	Planned Outage	75.32	1	75.32
1065412	8/29/2014	Planned Outage	117.53	2	58.77

Appendix 1

2014 Planned Outages Table

1065414	8/29/2014	Planned Outage	123.92	1	123.92
1065415	8/29/2014	Planned Outage	585.47	8	73.18
1065417	8/29/2014	Planned Outage	85.67	2	42.83
1065419	8/29/2014	Planned Outage	6,119.80	74	82.7
1065426	8/29/2014	Planned Outage	52.00	2	26
1065432	8/29/2014	Planned Outage	27.10	1	27.1
1065433	8/29/2014	Planned Outage	83.60	3	27.87
1065437	8/29/2014	Planned Outage	62.53	4	15.63
1065441	8/29/2014	Planned Outage	230.23	2	115.12
1065458	8/29/2014	Planned Outage	198.07	4	49.52
1065473	8/29/2014	Planned Outage	29.40	1	29.4
1065511	8/30/2014	Planned Outage	100.50	1	100.5
1065562	8/30/2014	Planned Outage	479.60	22	21.8
1065763	9/1/2014	Planned Outage	100.25	3	33.42
1065785	9/1/2014	Planned Outage	115.08	5	23.02
1065838	9/2/2014	Planned Outage	1,719.00	9	191
1065841	9/2/2014	Planned Outage	7,062.27	8	882.78
1065845	9/2/2014	Planned Outage	97.43	2	48.72
1065846	9/2/2014	Planned Outage	103.18	1	103.18
1065848	9/2/2014	Planned Outage	930.93	8	116.37
1065855	9/2/2014	Planned Outage	108.35	1	108.35
1065861	9/2/2014	Planned Outage	129.25	1	129.25
1065866	9/2/2014	Planned Outage	160.50	9	17.83
1065868	9/2/2014	Planned Outage	381.33	4	95.33
1065869	9/2/2014	Planned Outage	114.75	1	114.75
1065873	9/2/2014	Planned Outage	1,270.20	36	35.28
1065874	9/2/2014	Planned Outage	144.93	4	36.23
1065877	9/2/2014	Planned Outage	368.53	4	92.13
1065906	9/2/2014	Planned Outage	124.28	1	124.28
1066156	9/2/2014	Planned Outage	320.42	5	64.08
1066185	9/2/2014	Planned Outage	346.43	2	173.22
1066203	9/2/2014	Planned Outage	162.20	2	81.1
1066239	9/3/2014	Planned Outage	27.82	1	27.82
1066240	9/3/2014	Planned Outage	147.00	4	36.75
1066242	9/3/2014	Planned Outage	94.40	6	15.73
1066243	9/3/2014	Planned Outage	59.63	1	59.63
1066244	9/3/2014	Planned Outage	200.95	3	66.98
1066245	9/3/2014	Planned Outage	66.57	1	66.57
1066246	9/3/2014	Planned Outage	140.20	2	70.1
1066247	9/3/2014	Planned Outage	375.97	2	187.98
1066252	9/3/2014	Planned Outage	215.55	1	215.55
1066253	9/3/2014	Planned Outage	321.55	3	107.18
1066257	9/3/2014	Planned Outage	79.60	4	19.9
1066259	9/3/2014	Planned Outage	1,018.73	59	17.27
1066266	9/3/2014	Planned Outage	205.63	2	102.82
1066269	9/3/2014	Planned Outage	975.50	6	162.58
1066273	9/3/2014	Planned Outage	608.07	4	152.02
1066274	9/3/2014	Planned Outage	64.18	1	64.18
1066275	9/3/2014	Planned Outage	28.37	2	14.18

Appendix 1

2014 Planned Outages Table

1066277	9/3/2014	Planned Outage	847.80	6	141.3
1066278	9/3/2014	Planned Outage	68.20	4	17.05
1066279	9/3/2014	Planned Outage	104.10	2	52.05
1066280	9/3/2014	Planned Outage	113.83	5	22.77
1066282	9/3/2014	Planned Outage	49.35	1	49.35
1066284	9/3/2014	Planned Outage	184.70	1	184.7
1066285	9/3/2014	Planned Outage	739.67	4	184.92
1066301	9/3/2014	Planned Outage	38.03	1	38.03
1066303	9/3/2014	Planned Outage	289.80	6	48.3
1066304	9/3/2014	Planned Outage	46.58	5	9.32
1066305	9/3/2014	Planned Outage	68.42	1	68.42
1066306	9/3/2014	Planned Outage	51.20	3	17.07
1066314	9/3/2014	Planned Outage	486.25	25	19.45
1066318	9/3/2014	Planned Outage	220.20	4	55.05
1066329	9/3/2014	Planned Outage	73.78	1	73.78
1066338	9/3/2014	Planned Outage	19.00	1	19
1066339	9/3/2014	Planned Outage	75.37	2	37.68
1066340	9/3/2014	Planned Outage	219.73	4	54.93
1066453	9/3/2014	Planned Outage	185.60	8	23.2
1066464	9/3/2014	Planned Outage	20.38	1	20.38
1066465	9/3/2014	Planned Outage	19.55	1	19.55
1066468	9/3/2014	Planned Outage	13.23	1	13.23
1066475	9/3/2014	Planned Outage	259.33	4	64.83
1066478	9/3/2014	Planned Outage	148.85	3	49.62
1066480	9/3/2014	Planned Outage	81.83	2	40.92
1066506	9/4/2014	Planned Outage	22.92	1	22.92
1066509	9/4/2014	Planned Outage	119.25	1	119.25
1066510	9/4/2014	Planned Outage	120.08	5	24.02
1066511	9/4/2014	Planned Outage	185.33	5	37.07
1066512	9/4/2014	Planned Outage	48.47	1	48.47
1066513	9/4/2014	Planned Outage	242.60	2	121.3
1066520	9/4/2014	Planned Outage	88.25	3	29.42
1066521	9/4/2014	Planned Outage	133.73	8	16.72
1066522	9/4/2014	Planned Outage	116.28	1	116.28
1066523	9/4/2014	Planned Outage	116.32	1	116.32
1066525	9/4/2014	Planned Outage	360.67	8	45.08
1066527	9/4/2014	Planned Outage	65.87	4	16.47
1066530	9/4/2014	Planned Outage	55.07	4	13.77
1066536	9/4/2014	Planned Outage	497.33	4	124.33
1066542	9/4/2014	Planned Outage	126.08	5	25.22
1066559	9/4/2014	Planned Outage	170.40	4	42.6
1066564	9/4/2014	Planned Outage	97.25	3	32.42
1066588	9/4/2014	Planned Outage	47.30	1	47.3
1066597	9/4/2014	Planned Outage	336.67	5	67.33
1066600	9/4/2014	Planned Outage	737.13	4	184.28
1066607	9/4/2014	Planned Outage	213.00	4	53.25
1066654	9/5/2014	Planned Outage	81.00	6	13.5
1066663	9/5/2014	Planned Outage	58.40	2	29.2
1066665	9/5/2014	Planned Outage	175.10	6	29.18

Appendix 1

2014 Planned Outages Table

1066667	9/5/2014	Planned Outage	177.87	4	44.47
1066670	9/5/2014	Planned Outage	1,432.00	8	179
1066674	9/5/2014	Planned Outage	80.38	1	80.38
1066675	9/5/2014	Planned Outage	60.00	1	60
1066676	9/5/2014	Planned Outage	42.05	1	42.05
1066677	9/5/2014	Planned Outage	293.88	7	41.98
1066678	9/5/2014	Planned Outage	166.93	4	41.73
1066679	9/5/2014	Planned Outage	406.27	2	203.13
1066681	9/5/2014	Planned Outage	90.87	2	45.43
1066682	9/5/2014	Planned Outage	262.00	2	131
1066687	9/5/2014	Planned Outage	94.20	2	47.1
1066689	9/5/2014	Planned Outage	16.05	1	16.05
1066691	9/5/2014	Planned Outage	2,123.87	68	31.23
1066693	9/5/2014	Planned Outage	33.67	5	6.73
1066697	9/5/2014	Planned Outage	28.33	5	5.67
1066699	9/5/2014	Planned Outage	422.43	2	211.22
1066700	9/5/2014	Planned Outage	4.02	1	4.02
1066703	9/5/2014	Planned Outage	66.00	2	33
1066713	9/5/2014	Planned Outage	20.47	1	20.47
1066730	9/5/2014	Planned Outage	44.90	1	44.9
1066737	9/5/2014	Planned Outage	12.08	1	12.08
1066798	9/6/2014	Planned Outage	471.77	2	235.88
1067081	9/7/2014	Planned Outage	8,169.00	45	181.53
1067522	9/8/2014	Planned Outage	147.80	2	73.9
1067523	9/8/2014	Planned Outage	620.40	18	34.47
1067526	9/8/2014	Planned Outage	98.00	2	49
1067527	9/8/2014	Planned Outage	44.85	1	44.85
1067528	9/8/2014	Planned Outage	46.22	1	46.22
1067529	9/8/2014	Planned Outage	16.07	2	8.03
1067530	9/8/2014	Planned Outage	399.08	5	79.82
1067537	9/8/2014	Planned Outage	491.60	4	122.9
1067543	9/8/2014	Planned Outage	386.25	3	128.75
1067546	9/8/2014	Planned Outage	273.30	2	136.65
1067559	9/8/2014	Planned Outage	247.67	4	61.92
1067560	9/8/2014	Planned Outage	247.93	4	61.98
1067566	9/8/2014	Planned Outage	42.57	1	42.57
1067567	9/8/2014	Planned Outage	51.53	2	25.77
1067568	9/8/2014	Planned Outage	81.70	2	40.85
1067589	9/8/2014	Planned Outage	5,416.75	141	38.42
1067591	9/8/2014	Planned Outage	4,112.93	109	37.73
1067626	9/8/2014	Planned Outage	4,114.50	15	274.3
1067838	9/8/2014	Planned Outage	19.20	6	3.2
1067841	9/8/2014	Planned Outage	3.20	1	3.2
1067988	9/8/2014	Planned Outage	1,083.35	141	7.68
1067989	9/8/2014	Planned Outage	237.05	33	7.18
1068000	9/8/2014	Planned Outage	60.00	4	15
1068007	9/8/2014	Planned Outage	26.67	8	3.33
1068008	9/8/2014	Planned Outage	1.95	1	1.95
1068010	9/8/2014	Planned Outage	936.17	274	3.42

Appendix 1

2014 Planned Outages Table

1068044	9/9/2014	Planned Outage	54.00	3	18
1068055	9/9/2014	Planned Outage	131.10	9	14.57
1068258	9/9/2014	Planned Outage	266.17	2	133.08
1068260	9/9/2014	Planned Outage	212.40	3	70.8
1068261	9/9/2014	Planned Outage	178.07	2	89.03
1068263	9/9/2014	Planned Outage	1,062.15	9	118.02
1068268	9/9/2014	Planned Outage	26.00	6	4.33
1068269	9/9/2014	Planned Outage	54.52	1	54.52
1068271	9/9/2014	Planned Outage	770.20	6	128.37
1068272	9/9/2014	Planned Outage	64.50	10	6.45
1068278	9/9/2014	Planned Outage	27.77	2	13.88
1068282	9/9/2014	Planned Outage	484.50	3	161.5
1068290	9/9/2014	Planned Outage	22.82	1	22.82
1068291	9/9/2014	Planned Outage	1,110.60	108	10.28
1068295	9/9/2014	Planned Outage	10,475.67	22	476.17
1068296	9/9/2014	Planned Outage	95.37	2	47.68
1068297	9/9/2014	Planned Outage	892.33	4	223.08
1068302	9/9/2014	Planned Outage	138.42	1	138.42
1068304	9/9/2014	Planned Outage	691.10	6	115.18
1068314	9/9/2014	Planned Outage	50.00	2	25
1068315	9/9/2014	Planned Outage	395.30	6	65.88
1068317	9/9/2014	Planned Outage	54.87	4	13.72
1068319	9/9/2014	Planned Outage	163.82	1	163.82
1068323	9/9/2014	Planned Outage	82.48	1	82.48
1068324	9/9/2014	Planned Outage	82.57	1	82.57
1068326	9/9/2014	Planned Outage	37.73	2	18.87
1068327	9/9/2014	Planned Outage	199.17	5	39.83
1068328	9/9/2014	Planned Outage	344.05	21	16.38
1068331	9/9/2014	Planned Outage	557.30	6	92.88
1068332	9/9/2014	Planned Outage	10,630.40	66	161.07
1068335	9/9/2014	Planned Outage	191.17	5	38.23
1068337	9/9/2014	Planned Outage	481.37	14	34.38
1068339	9/9/2014	Planned Outage	15.65	1	15.65
1068340	9/9/2014	Planned Outage	99.40	3	33.13
1068341	9/9/2014	Planned Outage	134.90	2	67.45
1068344	9/9/2014	Planned Outage	392.00	4	98
1068345	9/9/2014	Planned Outage	97.93	1	97.93
1068356	9/9/2014	Planned Outage	399.93	7	57.13
1068370	9/9/2014	Planned Outage	83.05	3	27.68
1068371	9/9/2014	Planned Outage	78.07	1	78.07
1068372	9/9/2014	Planned Outage	234.50	3	78.17
1068374	9/9/2014	Planned Outage	837.43	7	119.63
1068380	9/9/2014	Planned Outage	112.17	2	56.08
1068387	9/9/2014	Planned Outage	37.00	1	37
1068389	9/9/2014	Planned Outage	669.00	5	133.8
1068390	9/9/2014	Planned Outage	65.67	5	13.13
1068391	9/9/2014	Planned Outage	45.53	2	22.77
1068396	9/9/2014	Planned Outage	21.70	2	10.85
1068399	9/9/2014	Planned Outage	292.13	4	73.03

Appendix 1

2014 Planned Outages Table

1068400	9/9/2014	Planned Outage	48.10	2	24.05
1068407	9/9/2014	Planned Outage	213.67	5	42.73
1068460	9/10/2014	Planned Outage	15.17	1	15.17
1068464	9/10/2014	Planned Outage	39.55	3	13.18
1068476	9/10/2014	Planned Outage	126.00	5	25.2
1068477	9/10/2014	Planned Outage	121.00	5	24.2
1068481	9/10/2014	Planned Outage	334.10	2	167.05
1068484	9/10/2014	Planned Outage	462.80	3	154.27
1068485	9/10/2014	Planned Outage	615.80	4	153.95
1068487	9/10/2014	Planned Outage	262.93	4	65.73
1068489	9/10/2014	Planned Outage	400.27	4	100.07
1068490	9/10/2014	Planned Outage	151.20	3	50.4
1068494	9/10/2014	Planned Outage	586.67	5	117.33
1068495	9/10/2014	Planned Outage	22.68	1	22.68
1068499	9/10/2014	Planned Outage	283.70	2	141.85
1068500	9/10/2014	Planned Outage	10.37	1	10.37
1068503	9/10/2014	Planned Outage	644.40	2	322.2
1068504	9/10/2014	Planned Outage	1,936.20	6	322.7
1068506	9/10/2014	Planned Outage	24.25	1	24.25
1068514	9/10/2014	Planned Outage	42.80	1	42.8
1068518	9/10/2014	Planned Outage	35.62	1	35.62
1068520	9/10/2014	Planned Outage	72.00	3	24
1068522	9/10/2014	Planned Outage	253.40	4	63.35
1068524	9/10/2014	Planned Outage	26.17	1	26.17
1068528	9/10/2014	Planned Outage	114.53	4	28.63
1068530	9/10/2014	Planned Outage	345.13	4	86.28
1068554	9/10/2014	Planned Outage	127.13	2	63.57
1068555	9/10/2014	Planned Outage	120.67	2	60.33
1068557	9/10/2014	Planned Outage	8.97	1	8.97
1068558	9/10/2014	Planned Outage	73.73	8	9.22
1068559	9/10/2014	Planned Outage	157.17	5	31.43
1068568	9/10/2014	Planned Outage	47.93	2	23.97
1068569	9/10/2014	Planned Outage	65.00	3	21.67
1068574	9/10/2014	Planned Outage	359.33	8	44.92
1068601	9/11/2014	Planned Outage	198.30	1	198.3
1068603	9/11/2014	Planned Outage	9,784.05	19	514.95
1068613	9/11/2014	Planned Outage	121.35	1	121.35
1068614	9/11/2014	Planned Outage	12,803.00	60	213.38
1068618	9/11/2014	Planned Outage	179.50	3	59.83
1068619	9/11/2014	Planned Outage	231.67	4	57.92
1068620	9/11/2014	Planned Outage	686.40	6	114.4
1068621	9/11/2014	Planned Outage	228.93	2	114.47
1068623	9/11/2014	Planned Outage	1,091.70	6	181.95
1068624	9/11/2014	Planned Outage	177.00	4	44.25
1068625	9/11/2014	Planned Outage	78.23	1	78.23
1068626	9/11/2014	Planned Outage	127.68	1	127.68
1068628	9/11/2014	Planned Outage	55.95	1	55.95
1068629	9/11/2014	Planned Outage	330.20	3	110.07
1068632	9/11/2014	Planned Outage	8,304.80	48	173.02

Appendix 1

2014 Planned Outages Table

1068634	9/11/2014	Planned Outage	216.07	7	30.87
1068635	9/11/2014	Planned Outage	296.25	5	59.25
1068636	9/11/2014	Planned Outage	692.83	5	138.57
1068637	9/11/2014	Planned Outage	687.50	5	137.5
1068638	9/11/2014	Planned Outage	166.95	3	55.65
1068640	9/11/2014	Planned Outage	23.50	1	23.5
1068642	9/11/2014	Planned Outage	10,396.07	68	152.88
1068653	9/11/2014	Planned Outage	101.77	1	101.77
1068689	9/11/2014	Planned Outage	149.25	5	29.85
1068690	9/11/2014	Planned Outage	20.70	1	20.7
1068754	9/11/2014	Planned Outage	53.62	1	53.62
1068758	9/11/2014	Planned Outage	80.50	2	40.25
1068761	9/11/2014	Planned Outage	85.10	3	28.37
1068768	9/11/2014	Planned Outage	579.02	7	82.72
1068772	9/11/2014	Planned Outage	1,048.80	18	58.27
1068773	9/11/2014	Planned Outage	54.00	1	54
1068774	9/11/2014	Planned Outage	66.92	5	13.38
1068842	9/12/2014	Planned Outage	470.50	3	156.83
1068846	9/12/2014	Planned Outage	3.98	1	3.98
1068848	9/12/2014	Planned Outage	12.90	1	12.9
1068849	9/12/2014	Planned Outage	130.33	2	65.17
1068850	9/12/2014	Planned Outage	42.10	2	21.05
1068855	9/12/2014	Planned Outage	131.47	4	32.87
1068863	9/12/2014	Planned Outage	3,879.75	63	61.58
1068866	9/12/2014	Planned Outage	7.43	1	7.43
1068868	9/12/2014	Planned Outage	15.67	1	15.67
1068869	9/12/2014	Planned Outage	83.80	4	20.95
1068871	9/12/2014	Planned Outage	4,442.28	107	41.52
1068873	9/12/2014	Planned Outage	260.42	5	52.08
1068874	9/12/2014	Planned Outage	2,075.05	47	44.15
1068876	9/12/2014	Planned Outage	478.83	17	28.17
1068877	9/12/2014	Planned Outage	87.80	3	29.27
1068878	9/12/2014	Planned Outage	55.85	1	55.85
1068880	9/12/2014	Planned Outage	128.93	4	32.23
1068881	9/12/2014	Planned Outage	62.20	2	31.1
1068883	9/12/2014	Planned Outage	1,379.83	17	81.17
1068888	9/12/2014	Planned Outage	2.18	1	2.18
1068892	9/12/2014	Planned Outage	9.70	1	9.7
1068894	9/12/2014	Planned Outage	24.85	21	1.18
1068908	9/12/2014	Planned Outage	71.33	1	71.33
1068913	9/12/2014	Planned Outage	94.63	17	5.57
1068940	9/12/2014	Planned Outage	1,901.50	15	126.77
1068977	9/13/2014	Planned Outage	584.90	6	97.48
1069299	9/14/2014	Planned Outage	187.90	3	62.63
1069458	9/15/2014	Planned Outage	680.55	13	52.35
1069465	9/15/2014	Planned Outage	53.13	4	13.28
1069468	9/15/2014	Planned Outage	16.60	2	8.3
1069469	9/15/2014	Planned Outage	1,496.93	8	187.12
1069470	9/15/2014	Planned Outage	1,742.80	8	217.85

Appendix 1

2014 Planned Outages Table

1069474	9/15/2014	Planned Outage	36.33	1	36.33
1069475	9/15/2014	Planned Outage	647.73	7	92.53
1069477	9/15/2014	Planned Outage	308.65	3	102.88
1069484	9/15/2014	Planned Outage	79.00	3	26.33
1069489	9/15/2014	Planned Outage	43.37	2	21.68
1069493	9/15/2014	Planned Outage	388.25	3	129.42
1069495	9/15/2014	Planned Outage	40.13	2	20.07
1069502	9/15/2014	Planned Outage	84.32	1	84.32
1069503	9/15/2014	Planned Outage	84.03	1	84.03
1069508	9/15/2014	Planned Outage	320.60	7	45.8
1069509	9/15/2014	Planned Outage	245.43	2	122.72
1069522	9/15/2014	Planned Outage	117.75	9	13.08
1069527	9/15/2014	Planned Outage	64.20	3	21.4
1069528	9/15/2014	Planned Outage	41.50	5	8.3
1069532	9/15/2014	Planned Outage	200.47	4	50.12
1069544	9/15/2014	Planned Outage	5.77	1	5.77
1069545	9/15/2014	Planned Outage	15.05	3	5.02
1069551	9/15/2014	Planned Outage	596.40	4	149.1
1069568	9/15/2014	Planned Outage	170.83	5	34.17
1069590	9/15/2014	Planned Outage	168.58	7	24.08
1069691	9/16/2014	Planned Outage	223.48	1	223.48
1069694	9/16/2014	Planned Outage	138.53	4	34.63
1069695	9/16/2014	Planned Outage	235.32	7	33.62
1069697	9/16/2014	Planned Outage	24.65	1	24.65
1069704	9/16/2014	Planned Outage	13.95	1	13.95
1069707	9/16/2014	Planned Outage	518.80	4	129.7
1069716	9/16/2014	Planned Outage	301.90	3	100.63
1069717	9/16/2014	Planned Outage	367.85	3	122.62
1069721	9/16/2014	Planned Outage	34.27	1	34.27
1069725	9/16/2014	Planned Outage	684.47	4	171.12
1069726	9/16/2014	Planned Outage	373.47	8	46.68
1069730	9/16/2014	Planned Outage	68.80	2	34.4
1069731	9/16/2014	Planned Outage	664.00	4	166
1069748	9/16/2014	Planned Outage	484.50	3	161.5
1069749	9/16/2014	Planned Outage	167.47	4	41.87
1069750	9/16/2014	Planned Outage	75.05	1	75.05
1069758	9/16/2014	Planned Outage	141.80	3	47.27
1069761	9/16/2014	Planned Outage	99.85	3	33.28
1069762	9/16/2014	Planned Outage	70.00	1	70
1069763	9/16/2014	Planned Outage	69.97	1	69.97
1069772	9/16/2014	Planned Outage	42.40	8	5.3
1069773	9/16/2014	Planned Outage	25.32	1	25.32
1069774	9/16/2014	Planned Outage	68.75	5	13.75
1069778	9/16/2014	Planned Outage	31.25	1	31.25
1069800	9/16/2014	Planned Outage	47.37	1	47.37
1069957	9/16/2014	Planned Outage	63.83	1	63.83
1069986	9/16/2014	Planned Outage	12.90	2	6.45
1070094	9/17/2014	Planned Outage	20.42	1	20.42
1070097	9/17/2014	Planned Outage	65.88	1	65.88

Appendix 1

2014 Planned Outages Table

1070098	9/17/2014	Planned Outage	78.10	1	78.1
1070099	9/17/2014	Planned Outage	332.27	4	83.07
1070101	9/17/2014	Planned Outage	208.93	4	52.23
1070102	9/17/2014	Planned Outage	204.87	4	51.22
1070104	9/17/2014	Planned Outage	584.53	4	146.13
1070115	9/17/2014	Planned Outage	168.87	1	168.87
1070117	9/17/2014	Planned Outage	151.30	17	8.9
1070125	9/17/2014	Planned Outage	21.75	1	21.75
1070127	9/17/2014	Planned Outage	51.93	1	51.93
1070131	9/17/2014	Planned Outage	59.30	3	19.77
1070137	9/17/2014	Planned Outage	398.30	2	199.15
1070156	9/17/2014	Planned Outage	4,723.40	57	82.87
1070165	9/17/2014	Planned Outage	155.87	2	77.93
1070173	9/17/2014	Planned Outage	52.25	5	10.45
1070175	9/17/2014	Planned Outage	125.53	4	31.38
1070176	9/17/2014	Planned Outage	59.48	1	59.48
1070178	9/17/2014	Planned Outage	60.33	4	15.08
1070479	9/17/2014	Planned Outage	83.25	1	83.25
1070499	9/17/2014	Planned Outage	575.53	4	143.88
1070505	9/17/2014	Planned Outage	119.17	2	59.58
1070506	9/17/2014	Planned Outage	254.45	3	84.82
1070508	9/17/2014	Planned Outage	1,323.70	14	94.55
1070509	9/17/2014	Planned Outage	99.53	1	99.53
1070510	9/17/2014	Planned Outage	1,594.50	9	177.17
1070515	9/17/2014	Planned Outage	265.60	3	88.53
1070524	9/18/2014	Planned Outage	22.93	1	22.93
1070539	9/18/2014	Planned Outage	311.85	3	103.95
1070540	9/18/2014	Planned Outage	86.13	1	86.13
1070541	9/18/2014	Planned Outage	48.60	12	4.05
1070544	9/18/2014	Planned Outage	942.50	6	157.08
1070547	9/18/2014	Planned Outage	4.95	1	4.95
1070548	9/18/2014	Planned Outage	5.47	1	5.47
1070549	9/18/2014	Planned Outage	205.98	1	205.98
1070552	9/18/2014	Planned Outage	1,259.88	7	179.98
1070555	9/18/2014	Planned Outage	277.30	6	46.22
1070557	9/18/2014	Planned Outage	185.83	5	37.17
1070559	9/18/2014	Planned Outage	13.42	1	13.42
1070564	9/18/2014	Planned Outage	738.77	37	19.97
1070566	9/18/2014	Planned Outage	34.53	2	17.27
1070569	9/18/2014	Planned Outage	83.83	5	16.77
1070572	9/18/2014	Planned Outage	23.10	1	23.1
1070625	9/18/2014	Planned Outage	183.00	10	18.3
1070639	9/19/2014	Planned Outage	17.05	1	17.05
1070646	9/19/2014	Planned Outage	36.20	2	18.1
1070674	9/19/2014	Planned Outage	24.32	1	24.32
1070680	9/19/2014	Planned Outage	16.65	1	16.65
1070694	9/19/2014	Planned Outage	178.20	4	44.55
1070695	9/19/2014	Planned Outage	34.60	6	5.77
1070703	9/19/2014	Planned Outage	55.18	11	5.02

Appendix 1

2014 Planned Outages Table

1070704	9/19/2014	Planned Outage	30.10	7	4.3
1070708	9/19/2014	Planned Outage	3,694.20	47	78.6
1070710	9/19/2014	Planned Outage	32.62	1	32.62
1070713	9/19/2014	Planned Outage	91.13	1	91.13
1070714	9/19/2014	Planned Outage	311.67	10	31.17
1070717	9/19/2014	Planned Outage	87.33	4	21.83
1070720	9/19/2014	Planned Outage	96.10	1	96.1
1070721	9/19/2014	Planned Outage	94.50	1	94.5
1070729	9/19/2014	Planned Outage	131.00	5	26.2
1070745	9/19/2014	Planned Outage	22.13	4	5.53
1070760	9/19/2014	Planned Outage	52.25	3	17.42
1070764	9/19/2014	Planned Outage	345.25	3	115.08
1070912	9/21/2014	Planned Outage	206.27	34	6.07
1070948	9/21/2014	Planned Outage	76.50	3	25.5
1071019	9/22/2014	Planned Outage	3.17	1	3.17
1071022	9/22/2014	Planned Outage	53.32	1	53.32
1071028	9/22/2014	Planned Outage	375.67	5	75.13
1071029	9/22/2014	Planned Outage	1,900.98	11	172.82
1071031	9/22/2014	Planned Outage	36.72	1	36.72
1071034	9/22/2014	Planned Outage	47.70	1	47.7
1071038	9/22/2014	Planned Outage	199.47	1	199.47
1071039	9/22/2014	Planned Outage	290.08	5	58.02
1071041	9/22/2014	Planned Outage	3,387.20	58	58.4
1071043	9/22/2014	Planned Outage	119.20	2	59.6
1071045	9/22/2014	Planned Outage	2,110.27	19	111.07
1071050	9/22/2014	Planned Outage	2,128.10	13	163.7
1071051	9/22/2014	Planned Outage	72.60	4	18.15
1071053	9/22/2014	Planned Outage	51.42	1	51.42
1071054	9/22/2014	Planned Outage	14.80	1	14.8
1071056	9/22/2014	Planned Outage	61.83	1	61.83
1071057	9/22/2014	Planned Outage	96.30	3	32.1
1071058	9/22/2014	Planned Outage	664.87	4	166.22
1071064	9/22/2014	Planned Outage	282.73	4	70.68
1071070	9/22/2014	Planned Outage	78.20	4	19.55
1071085	9/22/2014	Planned Outage	5.38	1	5.38
1071094	9/22/2014	Planned Outage	150.55	3	50.18
1071108	9/22/2014	Planned Outage	123.43	1	123.43
1071124	9/22/2014	Planned Outage	61.05	1	61.05
1071152	9/23/2014	Planned Outage	91.82	1	91.82
1071165	9/23/2014	Planned Outage	132.00	18	7.33
1071166	9/23/2014	Planned Outage	155.20	1	155.2
1071170	9/23/2014	Planned Outage	44.05	3	14.68
1071171	9/23/2014	Planned Outage	33.70	1	33.7
1071178	9/23/2014	Planned Outage	1,146.00	24	47.75
1071182	9/23/2014	Planned Outage	423.87	4	105.97
1071183	9/23/2014	Planned Outage	731.87	8	91.48
1071188	9/23/2014	Planned Outage	156.17	2	78.08
1071191	9/23/2014	Planned Outage	123.20	2	61.6
1071193	9/23/2014	Planned Outage	60.67	5	12.13

Appendix 1

2014 Planned Outages Table

1071195	9/23/2014	Planned Outage	255.80	3	85.27
1071197	9/23/2014	Planned Outage	680.00	40	17
1071203	9/23/2014	Planned Outage	332.00	4	83
1071205	9/23/2014	Planned Outage	54.45	3	18.15
1071206	9/23/2014	Planned Outage	252.80	6	42.13
1071214	9/23/2014	Planned Outage	880.00	40	22
1071223	9/23/2014	Planned Outage	90.00	6	15
1071226	9/23/2014	Planned Outage	144.00	4	36
1071228	9/23/2014	Planned Outage	100.87	2	50.43
1071229	9/23/2014	Planned Outage	6.00	6	1
1071231	9/23/2014	Planned Outage	63.03	1	63.03
1071238	9/23/2014	Planned Outage	53.47	1	53.47
1071241	9/23/2014	Planned Outage	130.80	2	65.4
1071245	9/23/2014	Planned Outage	53.50	2	26.75
1071248	9/23/2014	Planned Outage	119.00	1	119
1071249	9/23/2014	Planned Outage	663.07	4	165.77
1071251	9/23/2014	Planned Outage	124.47	2	62.23
1071252	9/23/2014	Planned Outage	21.40	1	21.4
1071262	9/23/2014	Planned Outage	1.15	1	1.15
1071266	9/23/2014	Planned Outage	133.50	3	44.5
1071267	9/23/2014	Planned Outage	38.93	4	9.73
1071270	9/23/2014	Planned Outage	1,078.30	6	179.72
1071273	9/23/2014	Planned Outage	859.50	10	85.95
1071276	9/23/2014	Planned Outage	160.70	6	26.78
1071510	9/24/2014	Planned Outage	28.40	2	14.2
1071512	9/24/2014	Planned Outage	1,605.33	40	40.13
1071513	9/24/2014	Planned Outage	156.00	6	26
1071518	9/24/2014	Planned Outage	45.23	2	22.62
1071520	9/24/2014	Planned Outage	73.95	17	4.35
1071522	9/24/2014	Planned Outage	130.20	1	130.2
1071523	9/24/2014	Planned Outage	693.65	3	231.22
1071525	9/24/2014	Planned Outage	686.90	3	228.97
1071527	9/24/2014	Planned Outage	412.77	7	58.97
1071529	9/24/2014	Planned Outage	123.30	1	123.3
1071530	9/24/2014	Planned Outage	71.67	4	17.92
1071531	9/24/2014	Planned Outage	30.00	3	10
1071532	9/24/2014	Planned Outage	501.60	4	125.4
1071533	9/24/2014	Planned Outage	262.45	3	87.48
1071534	9/24/2014	Planned Outage	1,435.00	41	35
1071537	9/24/2014	Planned Outage	12.00	3	4
1071538	9/24/2014	Planned Outage	223.00	6	37.17
1071539	9/24/2014	Planned Outage	73.17	2	36.58
1071540	9/24/2014	Planned Outage	336.00	14	24
1071541	9/24/2014	Planned Outage	317.80	6	52.97
1071544	9/24/2014	Planned Outage	215.00	5	43
1071552	9/24/2014	Planned Outage	42.00	14	3
1071554	9/24/2014	Planned Outage	119.50	3	39.83
1071562	9/24/2014	Planned Outage	724.17	25	28.97
1071563	9/24/2014	Planned Outage	29.42	1	29.42

Appendix 1

2014 Planned Outages Table

1071569	9/24/2014	Planned Outage	17.58	1	17.58
1071574	9/24/2014	Planned Outage	40.83	2	20.42
1071577	9/24/2014	Planned Outage	294.67	2	147.33
1071580	9/24/2014	Planned Outage	266.00	3	88.67
1071581	9/24/2014	Planned Outage	86.85	1	86.85
1071589	9/24/2014	Planned Outage	322.65	3	107.55
1071599	9/24/2014	Planned Outage	320.25	5	64.05
1071600	9/24/2014	Planned Outage	290.67	5	58.13
1071604	9/24/2014	Planned Outage	23.03	1	23.03
1071621	9/25/2014	Planned Outage	470.13	4	117.53
1071624	9/25/2014	Planned Outage	418.33	10	41.83
1071627	9/25/2014	Planned Outage	63.43	1	63.43
1071629	9/25/2014	Planned Outage	85.62	1	85.62
1071631	9/25/2014	Planned Outage	61.07	1	61.07
1071632	9/25/2014	Planned Outage	196.07	2	98.03
1071633	9/25/2014	Planned Outage	70.93	2	35.47
1071635	9/25/2014	Planned Outage	60.97	2	30.48
1071636	9/25/2014	Planned Outage	8,169.20	39	209.47
1071640	9/25/2014	Planned Outage	342.42	7	48.92
1071641	9/25/2014	Planned Outage	122.55	1	122.55
1071642	9/25/2014	Planned Outage	361.35	3	120.45
1071645	9/25/2014	Planned Outage	63.18	1	63.18
1071650	9/25/2014	Planned Outage	6,568.80	48	136.85
1071654	9/25/2014	Planned Outage	6,293.00	60	104.88
1071658	9/25/2014	Planned Outage	112.23	26	4.32
1071663	9/25/2014	Planned Outage	184.80	28	6.6
1071670	9/25/2014	Planned Outage	399.00	19	21
1071680	9/25/2014	Planned Outage	758.33	26	29.17
1071683	9/25/2014	Planned Outage	24.00	3	8
1071712	9/25/2014	Planned Outage	812.27	16	50.77
1071713	9/25/2014	Planned Outage	253.17	5	50.63
1071714	9/25/2014	Planned Outage	1,455.80	29	50.2
1071749	9/26/2014	Planned Outage	53.40	2	26.7
1071754	9/26/2014	Planned Outage	605.20	4	151.3
1071761	9/26/2014	Planned Outage	850.50	14	60.75
1071762	9/26/2014	Planned Outage	52.78	1	52.78
1071767	9/26/2014	Planned Outage	867.00	85	10.2
1071775	9/26/2014	Planned Outage	75.33	8	9.42
1071776	9/26/2014	Planned Outage	40.47	2	20.23
1071778	9/26/2014	Planned Outage	4,401.00	60	73.35
1071790	9/26/2014	Planned Outage	115.90	3	38.63
1071794	9/26/2014	Planned Outage	3,810.27	68	56.03
1071796	9/26/2014	Planned Outage	37.42	1	37.42
1071797	9/26/2014	Planned Outage	1,714.65	207	8.28
1071810	9/26/2014	Planned Outage	901.67	25	36.07
1071812	9/26/2014	Planned Outage	48.37	1	48.37
1071820	9/26/2014	Planned Outage	155.17	1	155.17
1071821	9/26/2014	Planned Outage	97.92	1	97.92
1071824	9/26/2014	Planned Outage	29.42	1	29.42

Appendix 1

2014 Planned Outages Table

1071847	9/26/2014	Planned Outage	52.42	1	52.42
1071848	9/26/2014	Planned Outage	209.67	4	52.42
1071858	9/26/2014	Planned Outage	162.30	6	27.05
1071865	9/27/2014	Planned Outage	122.40	1	122.4
1071884	9/27/2014	Planned Outage	88.20	4	22.05
1071970	9/28/2014	Planned Outage	24.03	7	3.43
1071971	9/28/2014	Planned Outage	10.15	3	3.38
1072017	9/29/2014	Planned Outage	105.42	1	105.42
1072027	9/29/2014	Planned Outage	193.50	5	38.7
1072028	9/29/2014	Planned Outage	25,165.80	124	202.95
1072041	9/29/2014	Planned Outage	108.58	1	108.58
1072050	9/29/2014	Planned Outage	155.90	3	51.97
1072052	9/29/2014	Planned Outage	201.15	3	67.05
1072054	9/29/2014	Planned Outage	60.67	4	15.17
1072061	9/29/2014	Planned Outage	182.45	3	60.82
1072062	9/29/2014	Planned Outage	37.92	1	37.92
1072069	9/29/2014	Planned Outage	144.00	2	72
1072073	9/29/2014	Planned Outage	129.68	1	129.68
1072076	9/29/2014	Planned Outage	1,367.10	49	27.9
1072080	9/29/2014	Planned Outage	245.80	6	40.97
1072082	9/29/2014	Planned Outage	118.87	4	29.72
1072092	9/29/2014	Planned Outage	98.20	1	98.2
1072137	9/29/2014	Planned Outage	61.07	2	30.53
1072143	9/29/2014	Planned Outage	38.90	2	19.45
1072167	9/30/2014	Planned Outage	119.43	1	119.43
1072173	9/30/2014	Planned Outage	278.80	8	34.85
1072174	9/30/2014	Planned Outage	37.10	1	37.1
1072183	9/30/2014	Planned Outage	67.55	3	22.52
1072187	9/30/2014	Planned Outage	47.00	4	11.75
1072191	9/30/2014	Planned Outage	220.00	22	10
1072192	9/30/2014	Planned Outage	49.33	4	12.33
1072194	9/30/2014	Planned Outage	73.07	8	9.13
1072195	9/30/2014	Planned Outage	58.67	5	11.73
1072196	9/30/2014	Planned Outage	276.00	12	23
1072198	9/30/2014	Planned Outage	651.30	3	217.1
1072200	9/30/2014	Planned Outage	73.85	3	24.62
1072201	9/30/2014	Planned Outage	51.47	2	25.73
1072202	9/30/2014	Planned Outage	4,648.87	137	33.93
1072205	9/30/2014	Planned Outage	108.70	2	54.35
1072207	9/30/2014	Planned Outage	54.30	3	18.1
1072209	9/30/2014	Planned Outage	142.50	6	23.75
1072210	9/30/2014	Planned Outage	83.10	3	27.7
1072214	9/30/2014	Planned Outage	331.73	4	82.93
1072216	9/30/2014	Planned Outage	105.00	4	26.25
1072220	9/30/2014	Planned Outage	43.60	3	14.53
1072221	9/30/2014	Planned Outage	17.53	1	17.53
1072225	9/30/2014	Planned Outage	77.40	3	25.8
1072229	9/30/2014	Planned Outage	15.93	1	15.93
1072230	9/30/2014	Planned Outage	216.75	3	72.25

Appendix 1

2014 Planned Outages Table

1072233	9/30/2014	Planned Outage	499.27	4	124.82
1072242	9/30/2014	Planned Outage	29.78	1	29.78
1072250	9/30/2014	Planned Outage	22.00	22	1
1072251	9/30/2014	Planned Outage	359.87	4	89.97
1072257	9/30/2014	Planned Outage	60.00	12	5
1072258	9/30/2014	Planned Outage	12.00	12	1
1072261	9/30/2014	Planned Outage	154.00	6	25.67
1072263	9/30/2014	Planned Outage	70.23	1	70.23
1072330	10/1/2014	Planned Outage	3,809.87	16	238.12
1072333	10/1/2014	Planned Outage	95,226.00	180	529.03
1072335	10/1/2014	Planned Outage	210,774.17	398	529.58
1072340	10/1/2014	Planned Outage	85.47	4	21.37
1072341	10/1/2014	Planned Outage	82.03	1	82.03
1072343	10/1/2014	Planned Outage	16.95	1	16.95
1072356	10/1/2014	Planned Outage	132.02	1	132.02
1072357	10/1/2014	Planned Outage	23.60	1	23.6
1072361	10/1/2014	Planned Outage	112.70	6	18.78
1072367	10/1/2014	Planned Outage	33.00	4	8.25
1072368	10/1/2014	Planned Outage	58.20	2	29.1
1072381	10/1/2014	Planned Outage	322.47	4	80.62
1072382	10/1/2014	Planned Outage	482.70	6	80.45
1072392	10/1/2014	Planned Outage	367.67	4	91.92
1072393	10/1/2014	Planned Outage	72.42	5	14.48
1072394	10/1/2014	Planned Outage	302.25	3	100.75
1072395	10/1/2014	Planned Outage	129.00	4	32.25
1072398	10/1/2014	Planned Outage	11.05	3	3.68
1072411	10/1/2014	Planned Outage	26.05	3	8.68
1072414	10/1/2014	Planned Outage	293.85	9	32.65
1072415	10/1/2014	Planned Outage	84.95	3	28.32
1072418	10/1/2014	Planned Outage	75.07	4	18.77
1072419	10/1/2014	Planned Outage	20.65	1	20.65
1072423	10/1/2014	Planned Outage	35.15	1	35.15
1072437	10/1/2014	Planned Outage	356.73	4	89.18
1072438	10/1/2014	Planned Outage	83.17	5	16.63
1072441	10/1/2014	Planned Outage	325.80	4	81.45
1072444	10/1/2014	Planned Outage	21.93	2	10.97
1072446	10/1/2014	Planned Outage	263.80	4	65.95
1072477	10/2/2014	Planned Outage	71.55	3	23.85
1072482	10/2/2014	Planned Outage	145.05	3	48.35
1072489	10/2/2014	Planned Outage	1,043.12	7	149.02
1072490	10/2/2014	Planned Outage	339.50	5	67.9
1072492	10/2/2014	Planned Outage	28.70	1	28.7
1072493	10/2/2014	Planned Outage	602.83	5	120.57
1072495	10/2/2014	Planned Outage	59.52	1	59.52
1072496	10/2/2014	Planned Outage	452.72	23	19.68
1072500	10/2/2014	Planned Outage	14.87	1	14.87
1072501	10/2/2014	Planned Outage	1,374.92	7	196.42
1072502	10/2/2014	Planned Outage	160.55	1	160.55
1072503	10/2/2014	Planned Outage	172.03	2	86.02

Appendix 1

2014 Planned Outages Table

1072504	10/2/2014	Planned Outage	425.20	6	70.87
1072505	10/2/2014	Planned Outage	41.07	1	41.07
1072506	10/2/2014	Planned Outage	40.28	1	40.28
1072507	10/2/2014	Planned Outage	93.12	1	93.12
1072509	10/2/2014	Planned Outage	49.07	1	49.07
1072510	10/2/2014	Planned Outage	40.62	1	40.62
1072511	10/2/2014	Planned Outage	2,904.00	88	33
1072514	10/2/2014	Planned Outage	97.67	4	24.42
1072516	10/2/2014	Planned Outage	181.42	5	36.28
1072517	10/2/2014	Planned Outage	48.67	2	24.33
1072518	10/2/2014	Planned Outage	170.68	7	24.38
1072524	10/2/2014	Planned Outage	5,282.23	107	49.37
1072529	10/2/2014	Planned Outage	58.25	3	19.42
1072541	10/2/2014	Planned Outage	279.40	3	93.13
1072551	10/2/2014	Planned Outage	83.57	2	41.78
1072600	10/3/2014	Planned Outage	51.42	5	10.28
1072605	10/3/2014	Planned Outage	129.28	1	129.28
1072630	10/3/2014	Planned Outage	65.22	7	9.32
1072635	10/3/2014	Planned Outage	43.72	1	43.72
1072658	10/3/2014	Planned Outage	160.33	4	40.08
1072665	10/3/2014	Planned Outage	772.80	16	48.3
1072708	10/3/2014	Planned Outage	111.02	1	111.02
1072710	10/3/2014	Planned Outage	257.50	3	85.83
1072711	10/3/2014	Planned Outage	20.70	18	1.15
1072730	10/3/2014	Planned Outage	76.40	4	19.1
1072731	10/3/2014	Planned Outage	2,234.08	85	26.28
1072732	10/3/2014	Planned Outage	916.42	7	130.92
1072749	10/3/2014	Planned Outage	8.35	1	8.35
1072751	10/3/2014	Planned Outage	7.18	1	7.18
1072760	10/3/2014	Planned Outage	168.20	6	28.03
1072763	10/3/2014	Planned Outage	108.17	5	21.63
1072764	10/3/2014	Planned Outage	21.45	1	21.45
1072817	10/4/2014	Planned Outage	30.00	1	30
1072818	10/4/2014	Planned Outage	43.40	1	43.4
1072820	10/4/2014	Planned Outage	24.00	1	24
1072821	10/4/2014	Planned Outage	49.72	1	49.72
1072860	10/4/2014	Planned Outage	462.00	22	21
1072976	10/6/2014	Planned Outage	367.37	2	183.68
1072981	10/6/2014	Planned Outage	20.52	1	20.52
1072998	10/6/2014	Planned Outage	73.45	1	73.45
1072999	10/6/2014	Planned Outage	239.33	2	119.67
1073001	10/6/2014	Planned Outage	102.67	4	25.67
1073007	10/6/2014	Planned Outage	9,154.00	92	99.5
1073013	10/6/2014	Planned Outage	180.22	11	16.38
1073014	10/6/2014	Planned Outage	152.90	6	25.48
1073021	10/6/2014	Planned Outage	74.15	3	24.72
1073025	10/6/2014	Planned Outage	175.40	2	87.7
1073027	10/6/2014	Planned Outage	345.17	2	172.58
1073029	10/6/2014	Planned Outage	37.65	3	12.55

Appendix 1

2014 Planned Outages Table

1073031	10/6/2014	Planned Outage	70.40	6	11.73
1073033	10/6/2014	Planned Outage	102.75	3	34.25
1073034	10/6/2014	Planned Outage	182.27	8	22.78
1073036	10/6/2014	Planned Outage	53.10	3	17.7
1073043	10/6/2014	Planned Outage	759.08	5	151.82
1073056	10/6/2014	Planned Outage	81.43	1	81.43
1073057	10/6/2014	Planned Outage	2.58	1	2.58
1073062	10/6/2014	Planned Outage	155.60	1	155.6
1073065	10/6/2014	Planned Outage	903.47	7	129.07
1073111	10/7/2014	Planned Outage	42.20	1	42.2
1073112	10/7/2014	Planned Outage	41.93	1	41.93
1073116	10/7/2014	Planned Outage	136.40	4	34.1
1073117	10/7/2014	Planned Outage	191.00	2	95.5
1073119	10/7/2014	Planned Outage	81.42	1	81.42
1073121	10/7/2014	Planned Outage	131.82	1	131.82
1073122	10/7/2014	Planned Outage	9,977.40	69	144.6
1073127	10/7/2014	Planned Outage	50.47	1	50.47
1073130	10/7/2014	Planned Outage	50.90	1	50.9
1073131	10/7/2014	Planned Outage	1,951.73	8	243.97
1073138	10/7/2014	Planned Outage	161.57	1	161.57
1073144	10/7/2014	Planned Outage	11.88	1	11.88
1073145	10/7/2014	Planned Outage	54.32	1	54.32
1073147	10/7/2014	Planned Outage	1,186.90	11	107.9
1073150	10/7/2014	Planned Outage	261.50	2	130.75
1073154	10/7/2014	Planned Outage	46.50	2	23.25
1073169	10/7/2014	Planned Outage	226.02	71	3.18
1073173	10/7/2014	Planned Outage	22.98	1	22.98
1073174	10/7/2014	Planned Outage	235.50	1	235.5
1073175	10/7/2014	Planned Outage	234.40	1	234.4
1073177	10/7/2014	Planned Outage	223.30	3	74.43
1073180	10/7/2014	Planned Outage	511.50	3	170.5
1073181	10/7/2014	Planned Outage	128.73	4	32.18
1073188	10/7/2014	Planned Outage	533.27	4	133.32
1073267	10/8/2014	Planned Outage	21.17	2	10.58
1073268	10/8/2014	Planned Outage	134.85	3	44.95
1073269	10/8/2014	Planned Outage	17.87	1	17.87
1073270	10/8/2014	Planned Outage	50.90	6	8.48
1073273	10/8/2014	Planned Outage	34.20	1	34.2
1073275	10/8/2014	Planned Outage	349.40	3	116.47
1073277	10/8/2014	Planned Outage	188.58	1	188.58
1073278	10/8/2014	Planned Outage	939.17	10	93.92
1073279	10/8/2014	Planned Outage	16.95	1	16.95
1073280	10/8/2014	Planned Outage	26.03	2	13.02
1073283	10/8/2014	Planned Outage	108.10	1	108.1
1073286	10/8/2014	Planned Outage	46.98	1	46.98
1073288	10/8/2014	Planned Outage	9.45	1	9.45
1073291	10/8/2014	Planned Outage	29.97	2	14.98
1073292	10/8/2014	Planned Outage	292.22	1	292.22
1073293	10/8/2014	Planned Outage	292.53	1	292.53

Appendix 1

2014 Planned Outages Table

1073294	10/8/2014	Planned Outage	29,661.33	196	151.33
1073299	10/8/2014	Planned Outage	8.37	1	8.37
1073300	10/8/2014	Planned Outage	17.40	2	8.7
1073302	10/8/2014	Planned Outage	103.33	4	25.83
1073305	10/8/2014	Planned Outage	67.67	5	13.53
1073331	10/8/2014	Planned Outage	140.50	2	70.25
1073332	10/8/2014	Planned Outage	134.30	1	134.3
1073345	10/8/2014	Planned Outage	237.53	4	59.38
1073346	10/8/2014	Planned Outage	321.75	9	35.75
1073349	10/8/2014	Planned Outage	30.32	1	30.32
1073360	10/8/2014	Planned Outage	96.13	2	48.07
1073367	10/8/2014	Planned Outage	299.08	5	59.82
1073368	10/8/2014	Planned Outage	60.08	1	60.08
1073377	10/8/2014	Planned Outage	190.43	2	95.22
1073378	10/8/2014	Planned Outage	95.30	1	95.3
1073379	10/8/2014	Planned Outage	95.92	1	95.92
1073386	10/8/2014	Planned Outage	69.80	3	23.27
1073388	10/8/2014	Planned Outage	676.85	3	225.62
1073431	10/9/2014	Planned Outage	14.58	1	14.58
1073432	10/9/2014	Planned Outage	44.05	1	44.05
1073433	10/9/2014	Planned Outage	271.78	1	271.78
1073435	10/9/2014	Planned Outage	18.53	1	18.53
1073439	10/9/2014	Planned Outage	325.20	2	162.6
1073440	10/9/2014	Planned Outage	162.88	1	162.88
1073448	10/9/2014	Planned Outage	327.15	3	109.05
1073454	10/9/2014	Planned Outage	47.00	1	47
1073462	10/9/2014	Planned Outage	56.47	4	14.12
1073465	10/9/2014	Planned Outage	253.15	3	84.38
1073466	10/9/2014	Planned Outage	28.07	2	14.03
1073468	10/9/2014	Planned Outage	88.23	1	88.23
1073470	10/9/2014	Planned Outage	104.93	2	52.47
1073477	10/9/2014	Planned Outage	663.75	5	132.75
1073478	10/9/2014	Planned Outage	52.23	2	26.12
1073479	10/9/2014	Planned Outage	226.73	4	56.68
1073480	10/9/2014	Planned Outage	170.00	3	56.67
1073481	10/9/2014	Planned Outage	102.93	4	25.73
1073483	10/9/2014	Planned Outage	21.32	1	21.32
1073486	10/9/2014	Planned Outage	40.03	2	20.02
1073487	10/9/2014	Planned Outage	27.12	1	27.12
1073488	10/9/2014	Planned Outage	212.50	5	42.5
1073491	10/9/2014	Planned Outage	111.93	4	27.98
1073493	10/9/2014	Planned Outage	181.30	1	181.3
1073495	10/9/2014	Planned Outage	100.88	1	100.88
1073507	10/9/2014	Planned Outage	61.93	4	15.48
1073531	10/10/2014	Planned Outage	77.50	3	25.83
1073534	10/10/2014	Planned Outage	49.90	3	16.63
1073540	10/10/2014	Planned Outage	688.75	5	137.75
1073542	10/10/2014	Planned Outage	150.90	2	75.45
1073553	10/10/2014	Planned Outage	142.08	5	28.42

Appendix 1

2014 Planned Outages Table

1073556	10/10/2014	Planned Outage	46.75	1	46.75
1073557	10/10/2014	Planned Outage	85.58	1	85.58
1073559	10/10/2014	Planned Outage	5,589.45	27	207.02
1073562	10/10/2014	Planned Outage	117.70	3	39.23
1073567	10/10/2014	Planned Outage	1,215.58	5	243.12
1073568	10/10/2014	Planned Outage	64.45	3	21.48
1073569	10/10/2014	Planned Outage	3,838.00	101	38
1073572	10/10/2014	Planned Outage	2,353.40	84	28.02
1073575	10/10/2014	Planned Outage	28.20	1	28.2
1073583	10/10/2014	Planned Outage	9,267.93	106	87.43
1073587	10/10/2014	Planned Outage	33.40	1	33.4
1073591	10/10/2014	Planned Outage	22.70	1	22.7
1073631	10/11/2014	Planned Outage	1,619.10	7	231.3
1073753	10/13/2014	Planned Outage	12.03	1	12.03
1073813	10/13/2014	Planned Outage	120.85	1	120.85
1073818	10/13/2014	Planned Outage	91.53	2	45.77
1073819	10/13/2014	Planned Outage	16.63	1	16.63
1073822	10/13/2014	Planned Outage	502.60	6	83.77
1073823	10/13/2014	Planned Outage	30.37	2	15.18
1073826	10/13/2014	Planned Outage	36.43	2	18.22
1073827	10/13/2014	Planned Outage	130.60	4	32.65
1073828	10/13/2014	Planned Outage	318.83	10	31.88
1073834	10/13/2014	Planned Outage	174.13	8	21.77
1073836	10/13/2014	Planned Outage	46.00	2	23
1073838	10/13/2014	Planned Outage	216.00	1	216
1073839	10/13/2014	Planned Outage	363.97	2	181.98
1073840	10/13/2014	Planned Outage	162.33	4	40.58
1073841	10/13/2014	Planned Outage	201.67	5	40.33
1073843	10/13/2014	Planned Outage	45.70	1	45.7
1073846	10/13/2014	Planned Outage	75.53	4	18.88
1073847	10/13/2014	Planned Outage	52.37	2	26.18
1073848	10/13/2014	Planned Outage	239.87	4	59.97
1073849	10/13/2014	Planned Outage	28.00	2	14
1073850	10/13/2014	Planned Outage	52.00	2	26
1073852	10/13/2014	Planned Outage	82.58	5	16.52
1073856	10/13/2014	Planned Outage	69.33	1	69.33
1073857	10/13/2014	Planned Outage	13.02	1	13.02
1073860	10/13/2014	Planned Outage	67.20	3	22.4
1073876	10/13/2014	Planned Outage	44.55	3	14.85
1073912	10/13/2014	Planned Outage	161.00	7	23
1073921	10/13/2014	Planned Outage	2.72	1	2.72
1073940	10/13/2014	Planned Outage	157.45	1	157.45
1073943	10/13/2014	Planned Outage	73.57	2	36.78
1075286	10/14/2014	Planned Outage	9.77	2	4.88
1075369	10/14/2014	Planned Outage	41.20	2	20.6
1075390	10/14/2014	Planned Outage	176.10	6	29.35
1075418	10/14/2014	Planned Outage	549.58	5	109.92
1075425	10/14/2014	Planned Outage	16.07	1	16.07
1075434	10/14/2014	Planned Outage	25.00	1	25

Appendix 1

2014 Planned Outages Table

1075447	10/14/2014	Planned Outage	48.88	1	48.88
1075450	10/14/2014	Planned Outage	610.13	4	152.53
1075497	10/15/2014	Planned Outage	59.98	1	59.98
1075498	10/15/2014	Planned Outage	280.27	2	140.13
1075500	10/15/2014	Planned Outage	47.60	4	11.9
1075503	10/15/2014	Planned Outage	366.53	4	91.63
1075508	10/15/2014	Planned Outage	1,052.20	4	263.05
1075513	10/15/2014	Planned Outage	10.65	1	10.65
1075517	10/15/2014	Planned Outage	913.33	5	182.67
1075524	10/15/2014	Planned Outage	1,733.20	6	288.87
1075526	10/15/2014	Planned Outage	241.67	2	120.83
1075528	10/15/2014	Planned Outage	235.50	2	117.75
1075530	10/15/2014	Planned Outage	88.13	2	44.07
1075531	10/15/2014	Planned Outage	117.17	5	23.43
1075534	10/15/2014	Planned Outage	37.17	5	7.43
1075536	10/15/2014	Planned Outage	12.37	2	6.18
1075537	10/15/2014	Planned Outage	94.72	1	94.72
1075542	10/15/2014	Planned Outage	37.17	2	18.58
1075543	10/15/2014	Planned Outage	276.47	52	5.32
1075546	10/15/2014	Planned Outage	360.80	6	60.13
1075547	10/15/2014	Planned Outage	4,189.00	59	71
1075550	10/15/2014	Planned Outage	872.25	15	58.15
1075554	10/15/2014	Planned Outage	172.80	6	28.8
1075557	10/15/2014	Planned Outage	40.97	1	40.97
1075559	10/15/2014	Planned Outage	722.00	6	120.33
1075563	10/15/2014	Planned Outage	324.33	7	46.33
1075565	10/15/2014	Planned Outage	208.00	52	4
1075566	10/15/2014	Planned Outage	34.20	9	3.8
1075577	10/15/2014	Planned Outage	113.73	4	28.43
1075579	10/15/2014	Planned Outage	126.45	9	14.05
1075583	10/15/2014	Planned Outage	680.05	3	226.68
1075589	10/15/2014	Planned Outage	51.88	1	51.88
1075591	10/15/2014	Planned Outage	272.27	4	68.07
1075604	10/15/2014	Planned Outage	52.60	3	17.53
1075625	10/16/2014	Planned Outage	30.78	1	30.78
1075635	10/16/2014	Planned Outage	114.20	3	38.07
1075645	10/16/2014	Planned Outage	104.28	1	104.28
1075679	10/16/2014	Planned Outage	198.73	4	49.68
1075680	10/16/2014	Planned Outage	41.48	1	41.48
1075681	10/16/2014	Planned Outage	192.93	2	96.47
1075687	10/16/2014	Planned Outage	713.33	25	28.53
1075693	10/16/2014	Planned Outage	189.00	2	94.5
1075697	10/16/2014	Planned Outage	400.33	4	100.08
1075698	10/16/2014	Planned Outage	361.25	17	21.25
1075701	10/16/2014	Planned Outage	71.95	1	71.95
1075702	10/16/2014	Planned Outage	23.50	10	2.35
1075703	10/16/2014	Planned Outage	1,091.83	10	109.18
1075704	10/16/2014	Planned Outage	904.05	41	22.05
1075706	10/16/2014	Planned Outage	98.83	2	49.42

Appendix 1

2014 Planned Outages Table

1075707	10/16/2014	Planned Outage	122.67	4	30.67
1075709	10/16/2014	Planned Outage	1,253.20	8	156.65
1075712	10/16/2014	Planned Outage	311.17	2	155.58
1075713	10/16/2014	Planned Outage	7.28	1	7.28
1075715	10/16/2014	Planned Outage	35.88	1	35.88
1075718	10/16/2014	Planned Outage	182.40	8	22.8
1075722	10/16/2014	Planned Outage	225.03	2	112.52
1075737	10/16/2014	Planned Outage	29.38	1	29.38
1075744	10/16/2014	Planned Outage	460.42	5	92.08
1075752	10/16/2014	Planned Outage	25.97	2	12.98
1075753	10/16/2014	Planned Outage	258.90	3	86.3
1075759	10/16/2014	Planned Outage	83.53	2	41.77
1075760	10/16/2014	Planned Outage	82.60	1	82.6
1075762	10/16/2014	Planned Outage	16.97	1	16.97
1075777	10/16/2014	Planned Outage	40.85	1	40.85
1075807	10/17/2014	Planned Outage	97.42	1	97.42
1075810	10/17/2014	Planned Outage	140.67	4	35.17
1075811	10/17/2014	Planned Outage	101.98	1	101.98
1075812	10/17/2014	Planned Outage	1,325.50	22	60.25
1075814	10/17/2014	Planned Outage	163.40	6	27.23
1075816	10/17/2014	Planned Outage	50.15	1	50.15
1075818	10/17/2014	Planned Outage	317.85	3	105.95
1075820	10/17/2014	Planned Outage	54.25	1	54.25
1075822	10/17/2014	Planned Outage	268.92	5	53.78
1075823	10/17/2014	Planned Outage	72.67	2	36.33
1075826	10/17/2014	Planned Outage	29.48	1	29.48
1075832	10/17/2014	Planned Outage	151.05	9	16.78
1075843	10/17/2014	Planned Outage	7.33	1	7.33
1075851	10/17/2014	Planned Outage	52.22	1	52.22
1075856	10/17/2014	Planned Outage	100.75	5	20.15
1075860	10/17/2014	Planned Outage	77.00	1	77
1075862	10/17/2014	Planned Outage	84.20	1	84.2
1076078	10/20/2014	Planned Outage	529.13	4	132.28
1076081	10/20/2014	Planned Outage	39.32	1	39.32
1076086	10/20/2014	Planned Outage	29.10	2	14.55
1076093	10/20/2014	Planned Outage	190.13	8	23.77
1076099	10/20/2014	Planned Outage	28.40	8	3.55
1076103	10/20/2014	Planned Outage	35.07	4	8.77
1076107	10/20/2014	Planned Outage	51.33	2	25.67
1076112	10/20/2014	Planned Outage	8,988.80	64	140.45
1076114	10/20/2014	Planned Outage	91.63	2	45.82
1076115	10/20/2014	Planned Outage	225.03	2	112.52
1076120	10/20/2014	Planned Outage	47.97	2	23.98
1076121	10/20/2014	Planned Outage	1,097.25	57	19.25
1076124	10/20/2014	Planned Outage	510.80	4	127.7
1076127	10/20/2014	Planned Outage	81.50	3	27.17
1076128	10/20/2014	Planned Outage	18.55	3	6.18
1076133	10/20/2014	Planned Outage	4,332.18	71	61.02
1076137	10/20/2014	Planned Outage	1,268.57	19	66.77

Appendix 1

2014 Planned Outages Table

1076140	10/20/2014	Planned Outage	111.00	4	27.75
1076151	10/20/2014	Planned Outage	108.03	2	54.02
1076159	10/20/2014	Planned Outage	37.57	1	37.57
1076160	10/20/2014	Planned Outage	62.43	2	31.22
1076161	10/20/2014	Planned Outage	69.97	1	69.97
1076165	10/20/2014	Planned Outage	463.50	18	25.75
1076166	10/20/2014	Planned Outage	101.93	1	101.93
1076183	10/20/2014	Planned Outage	36.12	1	36.12
1076188	10/20/2014	Planned Outage	130.33	5	26.07
1076190	10/20/2014	Planned Outage	495.80	3	165.27
1076192	10/20/2014	Planned Outage	129.00	5	25.8
1076196	10/20/2014	Planned Outage	164.67	4	41.17
1076200	10/20/2014	Planned Outage	833.12	7	119.02
1076202	10/20/2014	Planned Outage	113.52	1	113.52
1076245	10/21/2014	Planned Outage	863.00	5	172.6
1076255	10/21/2014	Planned Outage	70.65	1	70.65
1076261	10/21/2014	Planned Outage	19.48	1	19.48
1076265	10/21/2014	Planned Outage	236.90	2	118.45
1076269	10/21/2014	Planned Outage	116.60	1	116.6
1076272	10/21/2014	Planned Outage	85.10	2	42.55
1076275	10/21/2014	Planned Outage	932.07	4	233.02
1076277	10/21/2014	Planned Outage	330.08	5	66.02
1076278	10/21/2014	Planned Outage	130.20	2	65.1
1076279	10/21/2014	Planned Outage	196.70	3	65.57
1076280	10/21/2014	Planned Outage	17.50	2	8.75
1076283	10/21/2014	Planned Outage	93.42	1	93.42
1076285	10/21/2014	Planned Outage	39.15	3	13.05
1076291	10/21/2014	Planned Outage	55.83	2	27.92
1076292	10/21/2014	Planned Outage	10.60	1	10.6
1076293	10/21/2014	Planned Outage	14.48	1	14.48
1076295	10/21/2014	Planned Outage	8.00	1	8
1076318	10/21/2014	Planned Outage	29.17	1	29.17
1076320	10/21/2014	Planned Outage	442.67	5	88.53
1076323	10/21/2014	Planned Outage	268.50	3	89.5
1076324	10/21/2014	Planned Outage	491.33	4	122.83
1076325	10/21/2014	Planned Outage	299.60	4	74.9
1076345	10/21/2014	Planned Outage	260.25	5	52.05
1076362	10/21/2014	Planned Outage	67.13	4	16.78
1076369	10/21/2014	Planned Outage	516.00	3	172
1076518	10/22/2014	Planned Outage	238.53	2	119.27
1076519	10/22/2014	Planned Outage	80.32	1	80.32
1076521	10/22/2014	Planned Outage	287.97	2	143.98
1076526	10/22/2014	Planned Outage	256.80	4	64.2
1076530	10/22/2014	Planned Outage	44.42	1	44.42
1076532	10/22/2014	Planned Outage	96.52	1	96.52
1076536	10/22/2014	Planned Outage	247.25	3	82.42
1076543	10/22/2014	Planned Outage	152.33	4	38.08
1076544	10/22/2014	Planned Outage	29.17	1	29.17
1076549	10/22/2014	Planned Outage	326.73	4	81.68

Appendix 1

2014 Planned Outages Table

1076550	10/22/2014	Planned Outage	10.58	1	10.58
1076551	10/22/2014	Planned Outage	477.27	4	119.32
1076553	10/22/2014	Planned Outage	33.20	1	33.2
1076562	10/22/2014	Planned Outage	287.50	6	47.92
1076563	10/22/2014	Planned Outage	47.75	1	47.75
1076565	10/22/2014	Planned Outage	218.67	4	54.67
1076569	10/22/2014	Planned Outage	3,814.55	321	11.88
1076580	10/22/2014	Planned Outage	142.83	2	71.42
1076583	10/22/2014	Planned Outage	2,368.92	35	67.68
1076593	10/22/2014	Planned Outage	390.33	4	97.58
1076599	10/22/2014	Planned Outage	76.43	2	38.22
1076602	10/22/2014	Planned Outage	334.03	2	167.02
1076603	10/22/2014	Planned Outage	306.70	2	153.35
1076609	10/22/2014	Planned Outage	400.80	4	100.2
1076610	10/22/2014	Planned Outage	929.80	6	154.97
1076612	10/22/2014	Planned Outage	590.17	5	118.03
1076617	10/22/2014	Planned Outage	1,599.70	17	94.1
1076618	10/22/2014	Planned Outage	6.57	1	6.57
1076620	10/22/2014	Planned Outage	18.83	1	18.83
1076665	10/23/2014	Planned Outage	523.58	5	104.72
1076666	10/23/2014	Planned Outage	647.25	3	215.75
1076673	10/23/2014	Planned Outage	152.60	4	38.15
1076676	10/23/2014	Planned Outage	500.00	5	100
1076690	10/23/2014	Planned Outage	128.33	2	64.17
1076691	10/23/2014	Planned Outage	182.25	1	182.25
1076703	10/23/2014	Planned Outage	4,760.00	28	170
1076705	10/23/2014	Planned Outage	20.50	5	4.1
1076708	10/23/2014	Planned Outage	129.53	4	32.38
1076709	10/23/2014	Planned Outage	457.67	4	114.42
1076713	10/23/2014	Planned Outage	20.48	1	20.48
1076716	10/23/2014	Planned Outage	268.00	3	89.33
1076717	10/23/2014	Planned Outage	147.60	3	49.2
1076724	10/23/2014	Planned Outage	504.00	3	168
1076726	10/23/2014	Planned Outage	17.05	1	17.05
1076727	10/23/2014	Planned Outage	86.47	2	43.23
1076733	10/23/2014	Planned Outage	380.00	5	76
1076734	10/23/2014	Planned Outage	51.33	4	12.83
1076742	10/23/2014	Planned Outage	87.85	3	29.28
1076745	10/23/2014	Planned Outage	85.95	1	85.95
1076763	10/23/2014	Planned Outage	64.20	6	10.7
1076798	10/24/2014	Planned Outage	329.73	4	82.43
1076828	10/24/2014	Planned Outage	144.03	1	144.03
1076832	10/24/2014	Planned Outage	1,584.00	6	264
1076845	10/24/2014	Planned Outage	217.50	2	108.75
1076846	10/24/2014	Planned Outage	216.43	2	108.22
1076847	10/24/2014	Planned Outage	354.25	39	9.08
1076849	10/24/2014	Planned Outage	868.83	5	173.77
1076853	10/24/2014	Planned Outage	2,396.60	69	34.73
1076858	10/24/2014	Planned Outage	28.62	1	28.62

Appendix 1

2014 Planned Outages Table

1076859	10/24/2014	Planned Outage	37.37	1	37.37
1076860	10/24/2014	Planned Outage	39.58	1	39.58
1076862	10/24/2014	Planned Outage	34.98	1	34.98
1076865	10/24/2014	Planned Outage	57.10	2	28.55
1076866	10/24/2014	Planned Outage	27.95	1	27.95
1076878	10/24/2014	Planned Outage	104.27	2	52.13
1076880	10/24/2014	Planned Outage	75.87	1	75.87
1076889	10/24/2014	Planned Outage	127.23	1	127.23
1076890	10/24/2014	Planned Outage	18.82	1	18.82
1076897	10/24/2014	Planned Outage	26.53	2	13.27
1076903	10/24/2014	Planned Outage	14.70	1	14.7
1077094	10/26/2014	Planned Outage	544.80	6	90.8
1077095	10/26/2014	Planned Outage	90.77	1	90.77
1077128	10/26/2014	Planned Outage	252.40	3	84.13
1077194	10/27/2014	Planned Outage	58.07	4	14.52
1077195	10/27/2014	Planned Outage	42.35	3	14.12
1077196	10/27/2014	Planned Outage	488.00	4	122
1077197	10/27/2014	Planned Outage	267.75	3	89.25
1077202	10/27/2014	Planned Outage	7,582.93	16	473.93
1077204	10/27/2014	Planned Outage	311.67	4	77.92
1077206	10/27/2014	Planned Outage	167.35	1	167.35
1077207	10/27/2014	Planned Outage	98.23	1	98.23
1077209	10/27/2014	Planned Outage	258.00	3	86
1077213	10/27/2014	Planned Outage	189.67	5	37.93
1077214	10/27/2014	Planned Outage	1,711.03	7	244.43
1077216	10/27/2014	Planned Outage	6,726.00	3363	2
1077299	10/27/2014	Planned Outage	716.00	4	179
1077301	10/27/2014	Planned Outage	183.82	1	183.82
1077304	10/27/2014	Planned Outage	832.08	5	166.42
1077307	10/27/2014	Planned Outage	316.80	4	79.2
1077309	10/27/2014	Planned Outage	245.12	7	35.02
1077326	10/27/2014	Planned Outage	117.00	4	29.25
1077329	10/27/2014	Planned Outage	846.67	8	105.83
1077331	10/27/2014	Planned Outage	247.00	1	247
1077333	10/27/2014	Planned Outage	122.00	2	61
1077334	10/27/2014	Planned Outage	34.23	1	34.23
1077338	10/27/2014	Planned Outage	399.00	3	133
1077339	10/27/2014	Planned Outage	50.18	1	50.18
1077344	10/27/2014	Planned Outage	528.95	3	176.32
1077346	10/27/2014	Planned Outage	373.15	3	124.38
1077351	10/27/2014	Planned Outage	1,282.83	10	128.28
1077367	10/27/2014	Planned Outage	41.27	2	20.63
1077693	10/28/2014	Planned Outage	495.70	6	82.62
1077700	10/28/2014	Planned Outage	528.55	3	176.18
1077707	10/28/2014	Planned Outage	290.30	3	96.77
1077708	10/28/2014	Planned Outage	96.78	1	96.78
1077711	10/28/2014	Planned Outage	519.90	3	173.3
1077712	10/28/2014	Planned Outage	517.20	3	172.4
1077714	10/28/2014	Planned Outage	315.10	3	105.03

Appendix 1

2014 Planned Outages Table

1077718	10/28/2014	Planned Outage	56.67	2	28.33
1077720	10/28/2014	Planned Outage	159.25	3	53.08
1077721	10/28/2014	Planned Outage	400.98	1	400.98
1077722	10/28/2014	Planned Outage	1,282.65	9	142.52
1077724	10/28/2014	Planned Outage	58.48	1	58.48
1077729	10/28/2014	Planned Outage	112.58	1	112.58
1077732	10/28/2014	Planned Outage	70.15	3	23.38
1077738	10/28/2014	Planned Outage	191.40	3	63.8
1077752	10/28/2014	Planned Outage	63.43	1	63.43
1077755	10/28/2014	Planned Outage	544.00	6	90.67
1077762	10/28/2014	Planned Outage	148.72	1	148.72
1077781	10/28/2014	Planned Outage	73.35	1	73.35
1077796	10/28/2014	Planned Outage	37.58	1	37.58
1077799	10/28/2014	Planned Outage	60.37	1	60.37
1077801	10/28/2014	Planned Outage	139.80	4	34.95
1077808	10/28/2014	Planned Outage	189.05	3	63.02
1077834	10/29/2014	Planned Outage	1,253.20	3	417.73
1077840	10/29/2014	Planned Outage	164.85	1	164.85
1077844	10/29/2014	Planned Outage	487.60	4	121.9
1077845	10/29/2014	Planned Outage	207.55	3	69.18
1077848	10/29/2014	Planned Outage	330.20	3	110.07
1077850	10/29/2014	Planned Outage	17.90	1	17.9
1077851	10/29/2014	Planned Outage	90.57	2	45.28
1077861	10/29/2014	Planned Outage	97.07	16	6.07
1077864	10/29/2014	Planned Outage	57.35	1	57.35
1077868	10/29/2014	Planned Outage	624.00	3	208
1077869	10/29/2014	Planned Outage	19.85	1	19.85
1077871	10/29/2014	Planned Outage	54.83	1	54.83
1077872	10/29/2014	Planned Outage	1,329.90	11	120.9
1077874	10/29/2014	Planned Outage	103.00	1	103
1077875	10/29/2014	Planned Outage	211.70	3	70.57
1077910	10/29/2014	Planned Outage	132.30	1	132.3
1077923	10/29/2014	Planned Outage	75.30	1	75.3
1077941	10/29/2014	Planned Outage	181.90	3	60.63
1077942	10/29/2014	Planned Outage	275.53	4	68.88
1078027	10/30/2014	Planned Outage	105.60	11	9.6
1078030	10/30/2014	Planned Outage	721.53	4	180.38
1078043	10/30/2014	Planned Outage	27.52	1	27.52
1078048	10/30/2014	Planned Outage	58.52	1	58.52
1078051	10/30/2014	Planned Outage	426.55	3	142.18
1078057	10/30/2014	Planned Outage	115.88	1	115.88
1078060	10/30/2014	Planned Outage	72.17	1	72.17
1078061	10/30/2014	Planned Outage	136.00	2	68
1078062	10/30/2014	Planned Outage	39.87	4	9.97
1078063	10/30/2014	Planned Outage	80.00	1	80
1078068	10/30/2014	Planned Outage	729.17	5	145.83
1078069	10/30/2014	Planned Outage	145.22	1	145.22
1078071	10/30/2014	Planned Outage	241.55	3	80.52
1078072	10/30/2014	Planned Outage	85.02	1	85.02

Appendix 1

2014 Planned Outages Table

1078074	10/30/2014	Planned Outage	15.35	1	15.35
1078081	10/30/2014	Planned Outage	364.80	6	60.8
1078088	10/30/2014	Planned Outage	3,907.50	50	78.15
1078105	10/30/2014	Planned Outage	90.92	1	90.92
1078124	10/30/2014	Planned Outage	291.00	3	97
1078126	10/30/2014	Planned Outage	55.20	1	55.2
1078131	10/30/2014	Planned Outage	14.07	1	14.07
1078170	10/31/2014	Planned Outage	249.55	3	83.18
1078181	10/31/2014	Planned Outage	74.43	1	74.43
1078182	10/31/2014	Planned Outage	18.82	1	18.82
1078186	10/31/2014	Planned Outage	39.45	3	13.15
1078188	10/31/2014	Planned Outage	495.60	8	61.95
1078192	10/31/2014	Planned Outage	31.67	1	31.67
1078193	10/31/2014	Planned Outage	256.67	20	12.83
1078194	10/31/2014	Planned Outage	169.92	5	33.98
1078195	10/31/2014	Planned Outage	17.02	1	17.02
1078211	10/31/2014	Planned Outage	163.20	4	40.8
1078213	10/31/2014	Planned Outage	620.33	4	155.08
1078349	11/1/2014	Planned Outage	194.62	1	194.62
1078422	11/1/2014	Planned Outage	25.18	1	25.18
1078436	11/1/2014	Planned Outage	18.72	1	18.72
1078466	11/2/2014	Planned Outage	3,464.15	79	43.85
1078470	11/2/2014	Planned Outage	169.07	4	42.27
1078577	11/3/2014	Planned Outage	2,121.33	40	53.03
1078578	11/3/2014	Planned Outage	226.28	1	226.28
1078586	11/3/2014	Planned Outage	35.62	1	35.62
1078589	11/3/2014	Planned Outage	264.17	5	52.83
1078601	11/3/2014	Planned Outage	8.33	1	8.33
1078602	11/3/2014	Planned Outage	40.67	2	20.33
1078608	11/3/2014	Planned Outage	33.50	1	33.5
1078610	11/3/2014	Planned Outage	97.75	1	97.75
1078615	11/3/2014	Planned Outage	124.10	1	124.1
1078617	11/3/2014	Planned Outage	463.87	4	115.97
1078618	11/3/2014	Planned Outage	23.53	2	11.77
1078621	11/3/2014	Planned Outage	29.83	1	29.83
1078625	11/3/2014	Planned Outage	90.13	4	22.53
1078627	11/3/2014	Planned Outage	490.87	4	122.72
1078628	11/3/2014	Planned Outage	244.50	2	122.25
1078630	11/3/2014	Planned Outage	14.28	1	14.28
1078631	11/3/2014	Planned Outage	136.62	1	136.62
1078646	11/3/2014	Planned Outage	108.20	2	54.1
1078651	11/3/2014	Planned Outage	413.65	3	137.88
1078654	11/3/2014	Planned Outage	647.50	15	43.17
1078779	11/4/2014	Planned Outage	212.15	3	70.72
1078781	11/4/2014	Planned Outage	248.50	3	82.83
1078784	11/4/2014	Planned Outage	191.20	1	191.2
1078786	11/4/2014	Planned Outage	217.77	1	217.77
1078789	11/4/2014	Planned Outage	204.55	1	204.55
1078793	11/4/2014	Planned Outage	189.23	1	189.23

Appendix 1

2014 Planned Outages Table

1078797	11/4/2014	Planned Outage	909.08	5	181.82
1078798	11/4/2014	Planned Outage	4,726.00	60	78.77
1078806	11/4/2014	Planned Outage	91.65	3	30.55
1078807	11/4/2014	Planned Outage	438.03	2	219.02
1078809	11/4/2014	Planned Outage	371.50	5	74.3
1078815	11/4/2014	Planned Outage	814.45	7	116.35
1078817	11/4/2014	Planned Outage	23.47	1	23.47
1078818	11/4/2014	Planned Outage	25.33	5	5.07
1078821	11/4/2014	Planned Outage	270.20	4	67.55
1078823	11/4/2014	Planned Outage	6,321.00	60	105.35
1078824	11/4/2014	Planned Outage	172.35	3	57.45
1078825	11/4/2014	Planned Outage	17.15	1	17.15
1078826	11/4/2014	Planned Outage	17.28	1	17.28
1078832	11/4/2014	Planned Outage	72.52	1	72.52
1078833	11/4/2014	Planned Outage	356.50	5	71.3
1078835	11/4/2014	Planned Outage	160.65	7	22.95
1078841	11/4/2014	Planned Outage	402.90	9	44.77
1078845	11/4/2014	Planned Outage	13.42	1	13.42
1078857	11/4/2014	Planned Outage	43.17	1	43.17
1078861	11/4/2014	Planned Outage	140.63	2	70.32
1078863	11/4/2014	Planned Outage	25.83	2	12.92
1078864	11/4/2014	Planned Outage	64.83	5	12.97
1078865	11/4/2014	Planned Outage	234.87	4	58.72
1078867	11/4/2014	Planned Outage	8.58	1	8.58
1078880	11/4/2014	Planned Outage	49.68	1	49.68
1078882	11/4/2014	Planned Outage	174.90	3	58.3
1078889	11/4/2014	Planned Outage	211.00	4	52.75
1078932	11/5/2014	Planned Outage	1,003.38	11	91.22
1078933	11/5/2014	Planned Outage	455.25	5	91.05
1078934	11/5/2014	Planned Outage	686.35	7	98.05
1078935	11/5/2014	Planned Outage	1,410.00	15	94
1078936	11/5/2014	Planned Outage	712.00	8	89
1078937	11/5/2014	Planned Outage	528.00	6	88
1078938	11/5/2014	Planned Outage	174.67	4	43.67
1078942	11/5/2014	Planned Outage	4.58	1	4.58
1078944	11/5/2014	Planned Outage	207.20	1	207.2
1078945	11/5/2014	Planned Outage	280.80	3	93.6
1078947	11/5/2014	Planned Outage	203.57	2	101.78
1078952	11/5/2014	Planned Outage	698.60	7	99.8
1078953	11/5/2014	Planned Outage	799.07	8	99.88
1078954	11/5/2014	Planned Outage	174.63	1	174.63
1078956	11/5/2014	Planned Outage	9.63	1	9.63
1078957	11/5/2014	Planned Outage	7.38	1	7.38
1078959	11/5/2014	Planned Outage	118.60	3	39.53
1078962	11/5/2014	Planned Outage	21.90	1	21.9
1078967	11/5/2014	Planned Outage	236.58	1	236.58
1078970	11/5/2014	Planned Outage	6.43	1	6.43
1078973	11/5/2014	Planned Outage	457.67	2	228.83
1078974	11/5/2014	Planned Outage	143.67	1	143.67

Appendix 1

2014 Planned Outages Table

1078978	11/5/2014	Planned Outage	249.87	4	62.47
1078982	11/5/2014	Planned Outage	1,611.42	61	26.42
1078987	11/5/2014	Planned Outage	34.23	1	34.23
1078990	11/5/2014	Planned Outage	84.75	5	16.95
1078993	11/5/2014	Planned Outage	95.90	1	95.9
1078994	11/5/2014	Planned Outage	68.83	7	9.83
1078995	11/5/2014	Planned Outage	3,334.00	1667	2
1079004	11/5/2014	Planned Outage	206.47	4	51.62
1079007	11/5/2014	Planned Outage	313.50	5	62.7
1079010	11/5/2014	Planned Outage	55.13	2	27.57
1079017	11/5/2014	Planned Outage	13.82	1	13.82
1079019	11/5/2014	Planned Outage	39.95	3	13.32
1079037	11/5/2014	Planned Outage	3,252.08	125	26.02
1079040	11/5/2014	Planned Outage	5,917.10	237	24.97
1079097	11/6/2014	Planned Outage	12.85	1	12.85
1079106	11/6/2014	Planned Outage	269.37	2	134.68
1079107	11/6/2014	Planned Outage	77.35	1	77.35
1079108	11/6/2014	Planned Outage	159.15	1	159.15
1079109	11/6/2014	Planned Outage	324.87	4	81.22
1079111	11/6/2014	Planned Outage	15.98	1	15.98
1079112	11/6/2014	Planned Outage	6.60	1	6.6
1079113	11/6/2014	Planned Outage	96.90	18	5.38
1079115	11/6/2014	Planned Outage	205.62	1	205.62
1079117	11/6/2014	Planned Outage	2,035.57	79	25.77
1079118	11/6/2014	Planned Outage	1,552.00	60	25.87
1079130	11/6/2014	Planned Outage	187.43	2	93.72
1079132	11/6/2014	Planned Outage	761.13	7	108.73
1079133	11/6/2014	Planned Outage	36.93	1	36.93
1079135	11/6/2014	Planned Outage	65.45	1	65.45
1079136	11/6/2014	Planned Outage	33.12	1	33.12
1079137	11/6/2014	Planned Outage	50.02	1	50.02
1079139	11/6/2014	Planned Outage	35.73	2	17.87
1079142	11/6/2014	Planned Outage	50.43	1	50.43
1079144	11/6/2014	Planned Outage	213.47	4	53.37
1079145	11/6/2014	Planned Outage	52.52	1	52.52
1079151	11/6/2014	Planned Outage	183.17	1	183.17
1079159	11/6/2014	Planned Outage	102.68	1	102.68
1079162	11/6/2014	Planned Outage	18.08	1	18.08
1079168	11/6/2014	Planned Outage	388.20	9	43.13
1079189	11/7/2014	Planned Outage	8,855.93	98	90.37
1079194	11/7/2014	Planned Outage	137.02	1	137.02
1079207	11/7/2014	Planned Outage	117.50	3	39.17
1079208	11/7/2014	Planned Outage	32.48	1	32.48
1079209	11/7/2014	Planned Outage	92.43	2	46.22
1079211	11/7/2014	Planned Outage	478.40	8	59.8
1079214	11/7/2014	Planned Outage	24.58	1	24.58
1079215	11/7/2014	Planned Outage	77.53	1	77.53
1079216	11/7/2014	Planned Outage	731.47	52	14.07
1079217	11/7/2014	Planned Outage	240.33	4	60.08

Appendix 1

2014 Planned Outages Table

1079234	11/7/2014	Planned Outage	25.08	1	25.08
1079235	11/7/2014	Planned Outage	59.00	4	14.75
1079236	11/7/2014	Planned Outage	29.17	1	29.17
1079237	11/7/2014	Planned Outage	2.48	1	2.48
1079242	11/7/2014	Planned Outage	54.20	3	18.07
1079246	11/7/2014	Planned Outage	17.07	1	17.07
1079251	11/7/2014	Planned Outage	69.33	1	69.33
1079256	11/7/2014	Planned Outage	119.53	2	59.77
1079264	11/7/2014	Planned Outage	9.60	8	1.2
1079270	11/7/2014	Planned Outage	108.35	1	108.35
1079334	11/8/2014	Planned Outage	316.55	1	316.55
1079337	11/8/2014	Planned Outage	19.68	1	19.68
1079338	11/8/2014	Planned Outage	1,107.87	28	39.57
1079340	11/8/2014	Planned Outage	34.90	1	34.9
1079470	11/10/2014	Planned Outage	25.75	1	25.75
1079510	11/10/2014	Planned Outage	42.22	1	42.22
1079522	11/10/2014	Planned Outage	46.00	4	11.5
1079525	11/10/2014	Planned Outage	46.58	1	46.58
1079526	11/10/2014	Planned Outage	561.55	3	187.18
1079527	11/10/2014	Planned Outage	281.20	4	70.3
1079529	11/10/2014	Planned Outage	21.92	5	4.38
1079530	11/10/2014	Planned Outage	10.87	1	10.87
1079531	11/10/2014	Planned Outage	23.07	4	5.77
1079535	11/10/2014	Planned Outage	62.00	6	10.33
1079540	11/10/2014	Planned Outage	18.90	3	6.3
1079548	11/10/2014	Planned Outage	390.13	4	97.53
1079550	11/10/2014	Planned Outage	135.55	3	45.18
1079552	11/10/2014	Planned Outage	643.20	6	107.2
1079554	11/10/2014	Planned Outage	96.70	3	32.23
1079557	11/10/2014	Planned Outage	173.40	3	57.8
1079567	11/10/2014	Planned Outage	63.00	21	3
1079572	11/10/2014	Planned Outage	94.00	1	94
1079581	11/10/2014	Planned Outage	115.38	1	115.38
1079587	11/10/2014	Planned Outage	24.42	5	4.88
1079589	11/10/2014	Planned Outage	71.60	4	17.9
1079592	11/10/2014	Planned Outage	14.23	1	14.23
1079598	11/10/2014	Planned Outage	33.02	1	33.02
1079603	11/10/2014	Planned Outage	230.75	5	46.15
1079605	11/10/2014	Planned Outage	256.80	4	64.2
1079606	11/10/2014	Planned Outage	200.83	2	100.42
1079614	11/10/2014	Planned Outage	20.87	1	20.87
1079624	11/10/2014	Planned Outage	9.07	1	9.07
1079651	11/11/2014	Planned Outage	67.60	4	16.9
1079654	11/11/2014	Planned Outage	132.97	2	66.48
1079655	11/11/2014	Planned Outage	169.15	3	56.38
1079659	11/11/2014	Planned Outage	53.40	3	17.8
1079660	11/11/2014	Planned Outage	293.15	3	97.72
1079661	11/11/2014	Planned Outage	29.33	4	7.33
1079662	11/11/2014	Planned Outage	99.23	1	99.23

Appendix 1

2014 Planned Outages Table

1079663	11/11/2014	Planned Outage	37.80	3	12.6
1079666	11/11/2014	Planned Outage	44.53	2	22.27
1079667	11/11/2014	Planned Outage	41.17	2	20.58
1079668	11/11/2014	Planned Outage	274.40	3	91.47
1079669	11/11/2014	Planned Outage	183.70	2	91.85
1079670	11/11/2014	Planned Outage	1,745.15	19	91.85
1079676	11/11/2014	Planned Outage	83.60	4	20.9
1079685	11/11/2014	Planned Outage	350.13	8	43.77
1079688	11/11/2014	Planned Outage	9,263.87	67	138.27
1079691	11/11/2014	Planned Outage	72.37	2	36.18
1079692	11/11/2014	Planned Outage	146.27	4	36.57
1079693	11/11/2014	Planned Outage	16.42	1	16.42
1079695	11/11/2014	Planned Outage	87.67	2	43.83
1079696	11/11/2014	Planned Outage	51.90	2	25.95
1079697	11/11/2014	Planned Outage	64.10	3	21.37
1079698	11/11/2014	Planned Outage	376.13	7	53.73
1079701	11/11/2014	Planned Outage	49.40	3	16.47
1079704	11/11/2014	Planned Outage	73.62	1	73.62
1079706	11/11/2014	Planned Outage	36.12	1	36.12
1079708	11/11/2014	Planned Outage	8.68	1	8.68
1079711	11/11/2014	Planned Outage	283.60	4	70.9
1079712	11/11/2014	Planned Outage	69.30	1	69.3
1079715	11/11/2014	Planned Outage	46.35	3	15.45
1079717	11/11/2014	Planned Outage	181.00	4	45.25
1079718	11/11/2014	Planned Outage	343.10	6	57.18
1079745	11/11/2014	Planned Outage	5,354.70	13	411.9
1079769	11/12/2014	Planned Outage	47.38	1	47.38
1079777	11/12/2014	Planned Outage	943.77	23	41.03
1079779	11/12/2014	Planned Outage	596.25	15	39.75
1079783	11/12/2014	Planned Outage	280.07	4	70.02
1079784	11/12/2014	Planned Outage	944.55	9	104.95
1079785	11/12/2014	Planned Outage	78.27	4	19.57
1079786	11/12/2014	Planned Outage	22.05	1	22.05
1079789	11/12/2014	Planned Outage	76.47	4	19.12
1079792	11/12/2014	Planned Outage	464.83	2	232.42
1079795	11/12/2014	Planned Outage	10.27	4	2.57
1079797	11/12/2014	Planned Outage	130.17	1	130.17
1079800	11/12/2014	Planned Outage	445.78	7	63.68
1079801	11/12/2014	Planned Outage	439.37	7	62.77
1079807	11/12/2014	Planned Outage	767.10	6	127.85
1079808	11/12/2014	Planned Outage	509.53	4	127.38
1079809	11/12/2014	Planned Outage	559.35	9	62.15
1079810	11/12/2014	Planned Outage	15.28	1	15.28
1079817	11/12/2014	Planned Outage	625.60	4	156.4
1079820	11/12/2014	Planned Outage	33.53	1	33.53
1079823	11/12/2014	Planned Outage	53.38	1	53.38
1079824	11/12/2014	Planned Outage	479.03	7	68.43
1079826	11/12/2014	Planned Outage	39.87	2	19.93
1079827	11/12/2014	Planned Outage	226.52	1	226.52

Appendix 1

2014 Planned Outages Table

1079828	11/12/2014	Planned Outage	135.77	1	135.77
1079829	11/12/2014	Planned Outage	5.32	1	5.32
1079831	11/12/2014	Planned Outage	26.22	1	26.22
1079837	11/12/2014	Planned Outage	214.20	4	53.55
1079842	11/12/2014	Planned Outage	12,607.88	149	84.62
1079845	11/12/2014	Planned Outage	10.93	1	10.93
1079847	11/12/2014	Planned Outage	99.65	1	99.65
1079848	11/12/2014	Planned Outage	18.87	4	4.72
1079851	11/12/2014	Planned Outage	56.75	1	56.75
1079852	11/12/2014	Planned Outage	24.93	8	3.12
1079854	11/12/2014	Planned Outage	36.73	2	18.37
1079857	11/12/2014	Planned Outage	975.27	4	243.82
1079859	11/12/2014	Planned Outage	287.67	4	71.92
1079862	11/12/2014	Planned Outage	246.85	3	82.28
1079881	11/12/2014	Planned Outage	25.10	1	25.1
1079882	11/12/2014	Planned Outage	440.30	2	220.15
1079884	11/12/2014	Planned Outage	195.25	1	195.25
1079894	11/13/2014	Planned Outage	148.87	11	13.53
1079895	11/13/2014	Planned Outage	58.00	4	14.5
1079905	11/13/2014	Planned Outage	1,133.07	7	161.87
1079908	11/13/2014	Planned Outage	218.63	7	31.23
1079910	11/13/2014	Planned Outage	394.50	18	21.92
1079911	11/13/2014	Planned Outage	58.45	3	19.48
1079914	11/13/2014	Planned Outage	57.53	2	28.77
1079920	11/13/2014	Planned Outage	65.47	4	16.37
1079922	11/13/2014	Planned Outage	3,440.27	97	35.47
1079927	11/13/2014	Planned Outage	28.85	1	28.85
1079928	11/13/2014	Planned Outage	147.47	8	18.43
1079933	11/13/2014	Planned Outage	32.33	1	32.33
1079934	11/13/2014	Planned Outage	249.50	6	41.58
1079938	11/13/2014	Planned Outage	15.83	1	15.83
1079939	11/13/2014	Planned Outage	75.70	2	37.85
1079942	11/13/2014	Planned Outage	1,124.55	27	41.65
1080057	11/14/2014	Planned Outage	147.32	1	147.32
1080081	11/14/2014	Planned Outage	141.32	1	141.32
1080083	11/14/2014	Planned Outage	241.05	9	26.78
1080084	11/14/2014	Planned Outage	1,921.20	6	320.2
1080086	11/14/2014	Planned Outage	552.13	4	138.03
1080091	11/14/2014	Planned Outage	21.53	1	21.53
1080092	11/14/2014	Planned Outage	186.95	3	62.32
1080093	11/14/2014	Planned Outage	67.90	1	67.9
1080098	11/14/2014	Planned Outage	9,239.25	97	95.25
1080101	11/14/2014	Planned Outage	593.02	7	84.72
1080110	11/14/2014	Planned Outage	354.00	4	88.5
1080119	11/14/2014	Planned Outage	670.80	4	167.7
1080127	11/14/2014	Planned Outage	207.47	4	51.87
1080134	11/14/2014	Planned Outage	2,059.63	98	21.02
1080143	11/14/2014	Planned Outage	228.08	7	32.58
1080186	11/15/2014	Planned Outage	29.57	2	14.78

Appendix 1

2014 Planned Outages Table

1080188	11/15/2014	Planned Outage	43.50	5	8.7
1080227	11/15/2014	Planned Outage	999.00	9	111
1080317	11/16/2014	Planned Outage	200.58	1	200.58
1080542	11/17/2014	Planned Outage	38.02	1	38.02
1080602	11/17/2014	Planned Outage	417.08	7	59.58
1080615	11/17/2014	Planned Outage	151.32	1	151.32
1080634	11/17/2014	Planned Outage	468.00	6	78
1080671	11/17/2014	Planned Outage	4.50	1	4.5
1080675	11/17/2014	Planned Outage	29.47	2	14.73
1080676	11/17/2014	Planned Outage	492.40	4	123.1
1080678	11/17/2014	Planned Outage	80.00	4	20
1080679	11/17/2014	Planned Outage	696.53	64	10.88
1080711	11/17/2014	Planned Outage	295.80	2	147.9
1080714	11/17/2014	Planned Outage	111.30	1	111.3
1080747	11/17/2014	Planned Outage	172.50	5	34.5
1080791	11/18/2014	Planned Outage	6.60	1	6.6
1080797	11/18/2014	Planned Outage	5,019.05	37	135.65
1080800	11/18/2014	Planned Outage	128.60	3	42.87
1080802	11/18/2014	Planned Outage	76.48	1	76.48
1080804	11/18/2014	Planned Outage	59.83	2	29.92
1080807	11/18/2014	Planned Outage	21.80	1	21.8
1080808	11/18/2014	Planned Outage	65.15	1	65.15
1080830	11/18/2014	Planned Outage	275.60	3	91.87
1080831	11/18/2014	Planned Outage	242.73	2	121.37
1080837	11/18/2014	Planned Outage	229.20	9	25.47
1080838	11/18/2014	Planned Outage	117.00	13	9
1080841	11/18/2014	Planned Outage	262.90	2	131.45
1080843	11/18/2014	Planned Outage	684.08	5	136.82
1080876	11/18/2014	Planned Outage	119.20	4	29.8
1080879	11/18/2014	Planned Outage	892.33	4	223.08
1080888	11/18/2014	Planned Outage	44.90	1	44.9
1080890	11/18/2014	Planned Outage	29.42	1	29.42
1080892	11/18/2014	Planned Outage	858.00	10	85.8
1080894	11/18/2014	Planned Outage	412.67	4	103.17
1080898	11/18/2014	Planned Outage	121.77	2	60.88
1080900	11/18/2014	Planned Outage	379.20	9	42.13
1080911	11/18/2014	Planned Outage	21.95	1	21.95
1081035	11/19/2014	Planned Outage	42.77	1	42.77
1081051	11/19/2014	Planned Outage	64.67	1	64.67
1081052	11/19/2014	Planned Outage	1,139.50	5	227.9
1081054	11/19/2014	Planned Outage	279.25	3	93.08
1081055	11/19/2014	Planned Outage	280.90	2	140.45
1081060	11/19/2014	Planned Outage	174.10	3	58.03
1081078	11/19/2014	Planned Outage	331.75	5	66.35
1081088	11/19/2014	Planned Outage	11.52	1	11.52
1081092	11/19/2014	Planned Outage	113.52	1	113.52
1081093	11/19/2014	Planned Outage	27.40	2	13.7
1081098	11/19/2014	Planned Outage	28.60	2	14.3
1081121	11/19/2014	Planned Outage	4.47	2	2.23

Appendix 1

2014 Planned Outages Table

1081124	11/19/2014	Planned Outage	336.60	3	112.2
1081137	11/19/2014	Planned Outage	177.13	4	44.28
1081189	11/20/2014	Planned Outage	606.40	4	151.6
1081202	11/20/2014	Planned Outage	232.63	2	116.32
1081203	11/20/2014	Planned Outage	171.42	1	171.42
1081205	11/20/2014	Planned Outage	1,447.12	13	111.32
1081209	11/20/2014	Planned Outage	8.65	1	8.65
1081211	11/20/2014	Planned Outage	11,902.80	78	152.6
1081231	11/20/2014	Planned Outage	96.00	3	32
1081232	11/20/2014	Planned Outage	106.60	2	53.3
1081237	11/20/2014	Planned Outage	29.47	1	29.47
1081246	11/20/2014	Planned Outage	6,838.10	57	119.97
1081254	11/20/2014	Planned Outage	26.98	1	26.98
1081271	11/20/2014	Planned Outage	768.40	8	96.05
1081283	11/20/2014	Planned Outage	69.70	3	23.23
1081290	11/20/2014	Planned Outage	73.63	1	73.63
1081301	11/20/2014	Planned Outage	231.17	2	115.58
1081316	11/20/2014	Planned Outage	796.53	16	49.78
1081340	11/21/2014	Planned Outage	20,081.85	83	241.95
1081343	11/21/2014	Planned Outage	2,076.60	6	346.1
1081357	11/21/2014	Planned Outage	569.75	3	189.92
1081359	11/21/2014	Planned Outage	111.12	1	111.12
1081361	11/21/2014	Planned Outage	196.90	3	65.63
1081362	11/21/2014	Planned Outage	199.20	1	199.2
1081365	11/21/2014	Planned Outage	1.32	1	1.32
1081366	11/21/2014	Planned Outage	25,305.38	103	245.68
1081381	11/21/2014	Planned Outage	79.65	3	26.55
1081386	11/21/2014	Planned Outage	6.45	1	6.45
1081393	11/21/2014	Planned Outage	36.67	1	36.67
1081395	11/21/2014	Planned Outage	104.40	1	104.4
1081418	11/21/2014	Planned Outage	65.48	1	65.48
1081420	11/21/2014	Planned Outage	193.20	8	24.15
1081422	11/21/2014	Planned Outage	24.23	1	24.23
1081423	11/21/2014	Planned Outage	21.42	1	21.42
1081428	11/21/2014	Planned Outage	24.02	1	24.02
1081437	11/21/2014	Planned Outage	168.42	5	33.68
1082025	11/23/2014	Planned Outage	423.90	6	70.65
1082194	11/24/2014	Planned Outage	35.07	4	8.77
1082200	11/24/2014	Planned Outage	56.55	1	56.55
1082224	11/24/2014	Planned Outage	1,490.58	31	48.08
1082237	11/24/2014	Planned Outage	47.53	1	47.53
1082238	11/24/2014	Planned Outage	32.45	1	32.45
1082244	11/24/2014	Planned Outage	75.90	2	37.95
1082254	11/24/2014	Planned Outage	398.53	7	56.93
1082260	11/24/2014	Planned Outage	79.65	1	79.65
1082261	11/24/2014	Planned Outage	82.75	5	16.55
1082263	11/24/2014	Planned Outage	55.00	1	55
1082265	11/24/2014	Planned Outage	74.00	2	37
1082275	11/24/2014	Planned Outage	55.87	4	13.97

Appendix 1

2014 Planned Outages Table

1082284	11/24/2014	Planned Outage	86.20	3	28.73
1082286	11/24/2014	Planned Outage	18.40	1	18.4
1082315	11/24/2014	Planned Outage	25.40	1	25.4
1082365	11/25/2014	Planned Outage	7.03	1	7.03
1082368	11/25/2014	Planned Outage	13.70	1	13.7
1082370	11/25/2014	Planned Outage	94.93	2	47.47
1082379	11/25/2014	Planned Outage	27.05	3	9.02
1082380	11/25/2014	Planned Outage	68.33	4	17.08
1082383	11/25/2014	Planned Outage	14.07	1	14.07
1082384	11/25/2014	Planned Outage	51.33	1	51.33
1082385	11/25/2014	Planned Outage	44.82	1	44.82
1082398	11/25/2014	Planned Outage	26.72	1	26.72
1082400	11/25/2014	Planned Outage	147.58	5	29.52
1082404	11/25/2014	Planned Outage	15.63	1	15.63
1082409	11/25/2014	Planned Outage	169.80	2	84.9
1082410	11/25/2014	Planned Outage	1,091.13	13	83.93
1082419	11/25/2014	Planned Outage	141.85	1	141.85
1082424	11/25/2014	Planned Outage	56.35	3	18.78
1082426	11/25/2014	Planned Outage	390.08	5	78.02
1082430	11/25/2014	Planned Outage	23.23	1	23.23
1082440	11/25/2014	Planned Outage	57.50	3	19.17
1082441	11/25/2014	Planned Outage	29.75	1	29.75
1082453	11/25/2014	Planned Outage	793.33	5	158.67
1082463	11/25/2014	Planned Outage	151.40	3	50.47
1082515	11/25/2014	Planned Outage	500.85	371	1.35
1082556	11/26/2014	Planned Outage	70.93	1	70.93
1082557	11/26/2014	Planned Outage	325.52	1	325.52
1082559	11/26/2014	Planned Outage	42.15	3	14.05
1082561	11/26/2014	Planned Outage	84.00	1	84
1082564	11/26/2014	Planned Outage	37.30	1	37.3
1082566	11/26/2014	Planned Outage	197.80	4	49.45
1082567	11/26/2014	Planned Outage	95.17	5	19.03
1082578	11/26/2014	Planned Outage	23.90	1	23.9
1082580	11/26/2014	Planned Outage	562.70	6	93.78
1082601	11/26/2014	Planned Outage	26.23	2	13.12
1082603	11/26/2014	Planned Outage	342.20	3	114.07
1082604	11/26/2014	Planned Outage	32.90	1	32.9
1082605	11/26/2014	Planned Outage	123.55	3	41.18
1082713	11/27/2014	Planned Outage	72.20	3	24.07
1082837	11/29/2014	Planned Outage	404.43	1	404.43
1082864	11/29/2014	Planned Outage	336.95	3	112.32
1082868	11/29/2014	Planned Outage	142.95	9	15.88
1083040	12/1/2014	Planned Outage	33.95	3	11.32
1083051	12/1/2014	Planned Outage	22.73	2	11.37
1083054	12/1/2014	Planned Outage	76.72	1	76.72
1083056	12/1/2014	Planned Outage	153.55	1	153.55
1083057	12/1/2014	Planned Outage	172.00	3	57.33
1083060	12/1/2014	Planned Outage	459.43	7	65.63
1083061	12/1/2014	Planned Outage	64.48	1	64.48

Appendix 1

2014 Planned Outages Table

1083062	12/1/2014	Planned Outage	46,198.97	338	136.68
1083064	12/1/2014	Planned Outage	292.83	7	41.83
1083065	12/1/2014	Planned Outage	231.50	2	115.75
1083075	12/1/2014	Planned Outage	1,091.67	5	218.33
1083077	12/1/2014	Planned Outage	14,334.75	27	530.92
1083079	12/1/2014	Planned Outage	68.40	6	11.4
1083087	12/1/2014	Planned Outage	15.40	4	3.85
1083093	12/1/2014	Planned Outage	417.08	5	83.42
1083096	12/1/2014	Planned Outage	277.77	2	138.88
1083097	12/1/2014	Planned Outage	188.07	4	47.02
1083100	12/1/2014	Planned Outage	87.70	3	29.23
1083106	12/1/2014	Planned Outage	220.83	50	4.42
1083113	12/1/2014	Planned Outage	24.87	1	24.87
1083114	12/1/2014	Planned Outage	22.55	1	22.55
1083117	12/1/2014	Planned Outage	97.85	3	32.62
1083128	12/1/2014	Planned Outage	973.23	43	22.63
1083137	12/1/2014	Planned Outage	26.93	1	26.93
1083138	12/1/2014	Planned Outage	219.30	2	109.65
1083160	12/1/2014	Planned Outage	46.13	1	46.13
1083188	12/2/2014	Planned Outage	942.33	4	235.58
1083250	12/2/2014	Planned Outage	72.87	2	36.43
1083260	12/2/2014	Planned Outage	122.00	5	24.4
1083264	12/2/2014	Planned Outage	18.13	4	4.53
1083266	12/2/2014	Planned Outage	14.52	1	14.52
1083273	12/2/2014	Planned Outage	615.40	17	36.2
1083278	12/2/2014	Planned Outage	132.52	1	132.52
1083279	12/2/2014	Planned Outage	98.43	1	98.43
1083281	12/2/2014	Planned Outage	15.65	1	15.65
1083286	12/2/2014	Planned Outage	49.57	1	49.57
1083289	12/2/2014	Planned Outage	1,113.83	10	111.38
1083293	12/2/2014	Planned Outage	168.75	5	33.75
1083295	12/2/2014	Planned Outage	7,514.65	143	52.55
1083300	12/2/2014	Planned Outage	1,059.22	49	21.62
1083308	12/2/2014	Planned Outage	196.13	4	49.03
1083314	12/2/2014	Planned Outage	166.20	1	166.2
1083319	12/2/2014	Planned Outage	142.22	7	20.32
1083331	12/2/2014	Planned Outage	482.40	2	241.2
1083334	12/2/2014	Planned Outage	259.60	33	7.87
1083438	12/2/2014	Planned Outage	85.87	8	10.73
1083473	12/3/2014	Planned Outage	1,872.27	7	267.47
1083475	12/3/2014	Planned Outage	285.73	4	71.43
1083478	12/3/2014	Planned Outage	156.90	1	156.9
1083481	12/3/2014	Planned Outage	389.93	4	97.48
1083482	12/3/2014	Planned Outage	62.75	1	62.75
1083485	12/3/2014	Planned Outage	11.88	1	11.88
1083486	12/3/2014	Planned Outage	102.38	1	102.38
1083487	12/3/2014	Planned Outage	576.22	7	82.32
1083490	12/3/2014	Planned Outage	1,297.27	11	117.93
1083492	12/3/2014	Planned Outage	95.55	7	13.65

Appendix 1

2014 Planned Outages Table

1083493	12/3/2014	Planned Outage	5,061.00	28	180.75
1083496	12/3/2014	Planned Outage	79.67	2	39.83
1083497	12/3/2014	Planned Outage	409.45	57	7.18
1083503	12/3/2014	Planned Outage	379.10	17	22.3
1083505	12/3/2014	Planned Outage	5,064.45	19	266.55
1083506	12/3/2014	Planned Outage	26.20	3	8.73
1083507	12/3/2014	Planned Outage	25.45	3	8.48
1083509	12/3/2014	Planned Outage	375.20	12	31.27
1083511	12/3/2014	Planned Outage	155.70	2	77.85
1083514	12/3/2014	Planned Outage	1.32	1	1.32
1083515	12/3/2014	Planned Outage	1.92	1	1.92
1083517	12/3/2014	Planned Outage	13.13	1	13.13
1083518	12/3/2014	Planned Outage	99.50	1	99.5
1083519	12/3/2014	Planned Outage	190.60	2	95.3
1083521	12/3/2014	Planned Outage	48.75	3	16.25
1083522	12/3/2014	Planned Outage	270.13	2	135.07
1083524	12/3/2014	Planned Outage	103.33	2	51.67
1083525	12/3/2014	Planned Outage	90.90	2	45.45
1083526	12/3/2014	Planned Outage	1,052.00	24	43.83
1083562	12/4/2014	Planned Outage	116.33	2	58.17
1083571	12/4/2014	Planned Outage	16.97	1	16.97
1083573	12/4/2014	Planned Outage	194.67	2	97.33
1083575	12/4/2014	Planned Outage	115.70	13	8.9
1083576	12/4/2014	Planned Outage	60.18	1	60.18
1083578	12/4/2014	Planned Outage	456.98	7	65.28
1083580	12/4/2014	Planned Outage	13,338.33	151	88.33
1083582	12/4/2014	Planned Outage	286.73	1	286.73
1083584	12/4/2014	Planned Outage	371.33	4	92.83
1083585	12/4/2014	Planned Outage	79.50	3	26.5
1083589	12/4/2014	Planned Outage	19.78	1	19.78
1083595	12/4/2014	Planned Outage	55.25	1	55.25
1083596	12/4/2014	Planned Outage	4,009.00	76	52.75
1083598	12/4/2014	Planned Outage	37.97	1	37.97
1083602	12/4/2014	Planned Outage	2,121.60	51	41.6
1083605	12/4/2014	Planned Outage	114.27	2	57.13
1083608	12/4/2014	Planned Outage	12.12	1	12.12
1083609	12/4/2014	Planned Outage	1,399.20	212	6.6
1083618	12/4/2014	Planned Outage	23.90	1	23.9
1083624	12/4/2014	Planned Outage	150.50	2	75.25
1083628	12/4/2014	Planned Outage	18.75	1	18.75
1083630	12/4/2014	Planned Outage	228.80	1	228.8
1083636	12/4/2014	Planned Outage	13.13	1	13.13
1083650	12/5/2014	Planned Outage	604.20	2	302.1
1083661	12/5/2014	Planned Outage	437.37	1	437.37
1083664	12/5/2014	Planned Outage	743.30	6	123.88
1083667	12/5/2014	Planned Outage	46.25	1	46.25
1083669	12/5/2014	Planned Outage	140.53	4	35.13
1083673	12/5/2014	Planned Outage	57.00	6	9.5
1083675	12/5/2014	Planned Outage	271.95	1	271.95

Appendix 1

2014 Planned Outages Table

1083677	12/5/2014	Planned Outage	55.40	4	13.85
1083679	12/5/2014	Planned Outage	30.07	1	30.07
1083681	12/5/2014	Planned Outage	88.03	2	44.02
1083686	12/5/2014	Planned Outage	499.10	6	83.18
1083688	12/5/2014	Planned Outage	8,806.00	74	119
1083709	12/5/2014	Planned Outage	55.65	1	55.65
1083711	12/5/2014	Planned Outage	52.87	4	13.22
1083712	12/5/2014	Planned Outage	34.00	4	8.5
1083721	12/5/2014	Planned Outage	270.60	6	45.1
1083729	12/5/2014	Planned Outage	11.92	1	11.92
1083754	12/6/2014	Planned Outage	39.02	1	39.02
1083775	12/6/2014	Planned Outage	282.15	9	31.35
1083823	12/7/2014	Planned Outage	1,633.88	13	125.68
1083839	12/7/2014	Planned Outage	17.22	1	17.22
1083861	12/8/2014	Planned Outage	184.00	5	36.8
1083863	12/8/2014	Planned Outage	54.10	3	18.03
1083864	12/8/2014	Planned Outage	80.83	5	16.17
1083867	12/8/2014	Planned Outage	15.80	4	3.95
1083874	12/8/2014	Planned Outage	125.52	1	125.52
1083875	12/8/2014	Planned Outage	64.82	1	64.82
1083876	12/8/2014	Planned Outage	81.30	1	81.3
1083878	12/8/2014	Planned Outage	1,579.73	16	98.73
1083879	12/8/2014	Planned Outage	498.00	10	49.8
1083883	12/8/2014	Planned Outage	87.00	2	43.5
1083884	12/8/2014	Planned Outage	7,405.20	132	56.1
1083906	12/8/2014	Planned Outage	11.27	1	11.27
1083918	12/8/2014	Planned Outage	25.13	4	6.28
1083919	12/8/2014	Planned Outage	81.95	3	27.32
1083920	12/8/2014	Planned Outage	459.00	6	76.5
1083949	12/8/2014	Planned Outage	142.83	2	71.42
1083966	12/8/2014	Planned Outage	50.25	3	16.75
1083978	12/8/2014	Planned Outage	9.40	2	4.7
1083980	12/8/2014	Planned Outage	596.42	5	119.28
1083983	12/8/2014	Planned Outage	141.90	3	47.3
1084013	12/9/2014	Planned Outage	15.15	1	15.15
1084014	12/9/2014	Planned Outage	3.55	1	3.55
1084028	12/9/2014	Planned Outage	210.00	7	30
1084034	12/9/2014	Planned Outage	26.70	2	13.35
1084035	12/9/2014	Planned Outage	14.35	1	14.35
1084039	12/9/2014	Planned Outage	96.00	4	24
1084040	12/9/2014	Planned Outage	604.00	4	151
1084041	12/9/2014	Planned Outage	580.00	4	145
1084042	12/9/2014	Planned Outage	368.07	2	184.03
1084054	12/9/2014	Planned Outage	529.20	4	132.3
1084100	12/10/2014	Planned Outage	53.15	3	17.72
1084102	12/10/2014	Planned Outage	561.40	7	80.2
1084103	12/10/2014	Planned Outage	212.55	9	23.62
1084105	12/10/2014	Planned Outage	44.23	1	44.23
1084108	12/10/2014	Planned Outage	3,972.80	52	76.4

Appendix 1

2014 Planned Outages Table

1084109	12/10/2014	Planned Outage	112.58	7	16.08
1084114	12/10/2014	Planned Outage	1,020.93	19	53.73
1084119	12/10/2014	Planned Outage	557.20	3	185.73
1084121	12/10/2014	Planned Outage	441.33	5	88.27
1084123	12/10/2014	Planned Outage	268.30	2	134.15
1084125	12/10/2014	Planned Outage	6.40	2	3.2
1084127	12/10/2014	Planned Outage	24.15	1	24.15
1084128	12/10/2014	Planned Outage	21.57	1	21.57
1084129	12/10/2014	Planned Outage	69.05	3	23.02
1084130	12/10/2014	Planned Outage	9,427.17	95	99.23
1084131	12/10/2014	Planned Outage	1,391.85	27	51.55
1084135	12/10/2014	Planned Outage	10.32	1	10.32
1084136	12/10/2014	Planned Outage	30.42	5	6.08
1084147	12/10/2014	Planned Outage	56.27	2	28.13
1084153	12/10/2014	Planned Outage	70.43	2	35.22
1084154	12/10/2014	Planned Outage	158.20	6	26.37
1084159	12/10/2014	Planned Outage	42.87	1	42.87
1084169	12/10/2014	Planned Outage	231.47	4	57.87
1084170	12/10/2014	Planned Outage	203.27	2	101.63
1084190	12/11/2014	Planned Outage	59.35	3	19.78
1084193	12/11/2014	Planned Outage	12.83	1	12.83
1084200	12/11/2014	Planned Outage	27.97	1	27.97
1084201	12/11/2014	Planned Outage	4,394.90	71	61.9
1084205	12/11/2014	Planned Outage	11.07	1	11.07
1084212	12/11/2014	Planned Outage	598.27	4	149.57
1084215	12/11/2014	Planned Outage	15.63	1	15.63
1084216	12/11/2014	Planned Outage	247.27	2	123.63
1084217	12/11/2014	Planned Outage	291.70	6	48.62
1084219	12/11/2014	Planned Outage	5,087.62	31	164.12
1084221	12/11/2014	Planned Outage	4,730.40	27	175.2
1084224	12/11/2014	Planned Outage	11,498.32	67	171.62
1084229	12/11/2014	Planned Outage	836.42	5	167.28
1084230	12/11/2014	Planned Outage	834.33	5	166.87
1084231	12/11/2014	Planned Outage	159.20	1	159.2
1084232	12/11/2014	Planned Outage	952.70	6	158.78
1084234	12/11/2014	Planned Outage	61.72	1	61.72
1084237	12/11/2014	Planned Outage	337.07	2	168.53
1084240	12/11/2014	Planned Outage	157.67	1	157.67
1084241	12/11/2014	Planned Outage	12,167.60	57	213.47
1084246	12/11/2014	Planned Outage	21.30	1	21.3
1084247	12/11/2014	Planned Outage	2,673.00	22	121.5
1084253	12/11/2014	Planned Outage	222.15	3	74.05
1084260	12/11/2014	Planned Outage	29.32	1	29.32
1084261	12/11/2014	Planned Outage	6,730.00	50	134.6
1084263	12/11/2014	Planned Outage	18.40	1	18.4
1084264	12/11/2014	Planned Outage	1,584.67	20	79.23
1084269	12/11/2014	Planned Outage	1,204.35	9	133.82
1084276	12/11/2014	Planned Outage	52.60	2	26.3
1084277	12/11/2014	Planned Outage	65.77	2	32.88

Appendix 1

2014 Planned Outages Table

1084295	12/11/2014	Planned Outage	34.75	1	34.75
1084323	12/12/2014	Planned Outage	182.60	6	30.43
1084325	12/12/2014	Planned Outage	326.25	5	65.25
1084328	12/12/2014	Planned Outage	22.00	2	11
1084329	12/12/2014	Planned Outage	87.35	3	29.12
1084331	12/12/2014	Planned Outage	89.75	3	29.92
1084332	12/12/2014	Planned Outage	52.90	2	26.45
1084333	12/12/2014	Planned Outage	1,704.00	45	37.87
1084336	12/12/2014	Planned Outage	63.13	2	31.57
1084338	12/12/2014	Planned Outage	583.00	10	58.3
1084339	12/12/2014	Planned Outage	58.38	1	58.38
1084340	12/12/2014	Planned Outage	23.53	1	23.53
1084342	12/12/2014	Planned Outage	47.87	2	23.93
1084344	12/12/2014	Planned Outage	38.43	2	19.22
1084352	12/12/2014	Planned Outage	202.88	7	28.98
1084354	12/12/2014	Planned Outage	72.53	2	36.27
1084359	12/12/2014	Planned Outage	156.55	3	52.18
1084384	12/12/2014	Planned Outage	74.93	2	37.47
1084388	12/12/2014	Planned Outage	17.25	1	17.25
1084536	12/14/2014	Planned Outage	115.88	1	115.88
1084548	12/14/2014	Planned Outage	52.82	1	52.82
1084563	12/14/2014	Planned Outage	56.08	1	56.08
1084570	12/14/2014	Planned Outage	60.55	1	60.55
1084600	12/15/2014	Planned Outage	390.40	3	130.13
1084602	12/15/2014	Planned Outage	146.95	3	48.98
1084606	12/15/2014	Planned Outage	258.67	4	64.67
1084608	12/15/2014	Planned Outage	374.20	6	62.37
1084610	12/15/2014	Planned Outage	89.52	1	89.52
1084611	12/15/2014	Planned Outage	7.47	7	1.07
1084614	12/15/2014	Planned Outage	144.47	4	36.12
1084619	12/15/2014	Planned Outage	146.50	15	9.77
1084620	12/15/2014	Planned Outage	117.05	3	39.02
1084621	12/15/2014	Planned Outage	4,449.20	98	45.4
1084630	12/15/2014	Planned Outage	86.20	2	43.1
1084631	12/15/2014	Planned Outage	3,119.67	98	31.83
1084634	12/15/2014	Planned Outage	132.40	1	132.4
1084638	12/15/2014	Planned Outage	125.93	4	31.48
1084639	12/15/2014	Planned Outage	124.73	4	31.18
1084643	12/15/2014	Planned Outage	55.58	1	55.58
1084645	12/15/2014	Planned Outage	142.15	3	47.38
1084691	12/15/2014	Planned Outage	88.90	1	88.9
1084703	12/15/2014	Planned Outage	23.60	2	11.8
1084704	12/15/2014	Planned Outage	10.00	5	2
1084705	12/15/2014	Planned Outage	27.93	1	27.93
1084707	12/15/2014	Planned Outage	191.83	10	19.18
1084710	12/15/2014	Planned Outage	240.75	15	16.05
1084711	12/15/2014	Planned Outage	58.45	1	58.45
1084732	12/16/2014	Planned Outage	144.30	3	48.1
1084739	12/16/2014	Planned Outage	193.18	1	193.18

Appendix 1

2014 Planned Outages Table

1084741	12/16/2014	Planned Outage	327.10	2	163.55
1084743	12/16/2014	Planned Outage	64.42	1	64.42
1084745	12/16/2014	Planned Outage	78.43	1	78.43
1084749	12/16/2014	Planned Outage	27.10	2	13.55
1084752	12/16/2014	Planned Outage	58.82	1	58.82
1084754	12/16/2014	Planned Outage	46.33	2	23.17
1084757	12/16/2014	Planned Outage	1,313.10	9	145.9
1084759	12/16/2014	Planned Outage	555.30	9	61.7
1084762	12/16/2014	Planned Outage	248.90	3	82.97
1084763	12/16/2014	Planned Outage	248.80	3	82.93
1084765	12/16/2014	Planned Outage	111.83	1	111.83
1084767	12/16/2014	Planned Outage	4,632.10	66	70.18
1084771	12/16/2014	Planned Outage	334.87	4	83.72
1084772	12/16/2014	Planned Outage	99.13	2	49.57
1084782	12/16/2014	Planned Outage	3,239.60	89	36.4
1084787	12/16/2014	Planned Outage	64.75	3	21.58
1084791	12/16/2014	Planned Outage	28.07	1	28.07
1084795	12/16/2014	Planned Outage	82.20	4	20.55
1084797	12/16/2014	Planned Outage	172.52	1	172.52
1084818	12/16/2014	Planned Outage	141.65	1	141.65
1084828	12/17/2014	Planned Outage	3,044.98	11	276.82
1084831	12/17/2014	Planned Outage	3,001.00	10	300.1
1084844	12/17/2014	Planned Outage	174.07	2	87.03
1084845	12/17/2014	Planned Outage	16.27	1	16.27
1084846	12/17/2014	Planned Outage	32.30	2	16.15
1084848	12/17/2014	Planned Outage	97.35	3	32.45
1084850	12/17/2014	Planned Outage	305.17	1	305.17
1084855	12/17/2014	Planned Outage	459.90	7	65.7
1084857	12/17/2014	Planned Outage	33.00	1	33
1084862	12/17/2014	Planned Outage	23.50	2	11.75
1084867	12/17/2014	Planned Outage	209.00	11	19
1084868	12/17/2014	Planned Outage	86.25	3	28.75
1084871	12/17/2014	Planned Outage	54.47	2	27.23
1084876	12/17/2014	Planned Outage	137.67	5	27.53
1084881	12/17/2014	Planned Outage	24.33	1	24.33
1084882	12/17/2014	Planned Outage	474.00	4	118.5
1084883	12/17/2014	Planned Outage	1,425.67	7	203.67
1084888	12/17/2014	Planned Outage	281.15	3	93.72
1084892	12/17/2014	Planned Outage	399.80	4	99.95
1084903	12/17/2014	Planned Outage	21.57	1	21.57
1084907	12/17/2014	Planned Outage	42.90	9	4.77
1084908	12/17/2014	Planned Outage	70.00	14	5
1084911	12/17/2014	Planned Outage	11.55	1	11.55
1084912	12/17/2014	Planned Outage	37.60	4	9.4
1084927	12/17/2014	Planned Outage	122.55	9	13.62
1084949	12/18/2014	Planned Outage	153.52	1	153.52
1084950	12/18/2014	Planned Outage	586.00	4	146.5
1084952	12/18/2014	Planned Outage	874.25	13	67.25
1084956	12/18/2014	Planned Outage	165.47	4	41.37

Appendix 1

2014 Planned Outages Table

1084957	12/18/2014	Planned Outage	62.00	10	6.2
1084960	12/18/2014	Planned Outage	87.38	1	87.38
1084961	12/18/2014	Planned Outage	785.40	4	196.35
1084968	12/18/2014	Planned Outage	5.60	2	2.8
1084969	12/18/2014	Planned Outage	3,260.25	35	93.15
1084971	12/18/2014	Planned Outage	58.77	2	29.38
1084972	12/18/2014	Planned Outage	40.32	1	40.32
1084975	12/18/2014	Planned Outage	468.85	3	156.28
1084978	12/18/2014	Planned Outage	109.65	3	36.55
1084980	12/18/2014	Planned Outage	447.50	25	17.9
1084981	12/18/2014	Planned Outage	150.15	9	16.68
1084991	12/18/2014	Planned Outage	34.47	4	8.62
1084993	12/18/2014	Planned Outage	204.00	5	40.8
1084998	12/18/2014	Planned Outage	12.65	1	12.65
1085038	12/19/2014	Planned Outage	59.20	3	19.73
1085042	12/19/2014	Planned Outage	48.78	1	48.78
1085051	12/19/2014	Planned Outage	46.70	2	23.35
1085052	12/19/2014	Planned Outage	16.45	1	16.45
1085053	12/19/2014	Planned Outage	121.87	1	121.87
1085054	12/19/2014	Planned Outage	121.67	1	121.67
1085055	12/19/2014	Planned Outage	167.60	2	83.8
1085056	12/19/2014	Planned Outage	89.60	7	12.8
1085059	12/19/2014	Planned Outage	208.53	4	52.13
1085062	12/19/2014	Planned Outage	45.20	12	3.77
1085067	12/19/2014	Planned Outage	49.73	4	12.43
1085075	12/19/2014	Planned Outage	95.13	2	47.57
1085078	12/19/2014	Planned Outage	24.57	1	24.57
1085092	12/19/2014	Planned Outage	611.63	2	305.82
1085100	12/19/2014	Planned Outage	50.38	1	50.38
1085102	12/19/2014	Planned Outage	306.33	5	61.27
1085109	12/19/2014	Planned Outage	37.87	1	37.87
1085341	12/22/2014	Planned Outage	1,032.63	13	79.43
1085348	12/22/2014	Planned Outage	22.00	22	1
1085349	12/22/2014	Planned Outage	338.00	1	338
1085364	12/22/2014	Planned Outage	174.83	2	87.42
1085371	12/22/2014	Planned Outage	42.17	1	42.17
1085373	12/22/2014	Planned Outage	242.40	6	40.4
1085375	12/22/2014	Planned Outage	185.20	4	46.3
1085380	12/22/2014	Planned Outage	257.20	4	64.3
1085392	12/22/2014	Planned Outage	256.03	2	128.02
1085417	12/22/2014	Planned Outage	75.15	3	25.05
1085478	12/23/2014	Planned Outage	483.35	7	69.05
1085505	12/23/2014	Planned Outage	17.10	1	17.1
1085566	12/23/2014	Planned Outage	129.67	5	25.93
1085587	12/23/2014	Planned Outage	191.60	4	47.9
1085589	12/23/2014	Planned Outage	33.60	2	16.8
1085614	12/23/2014	Planned Outage	19.57	1	19.57
1085953	12/24/2014	Planned Outage	33.27	1	33.27
1085978	12/24/2014	Planned Outage	65.73	4	16.43

Appendix 1

2014 Planned Outages Table

1086080	12/25/2014	Planned Outage	886.03	19	46.63
1086082	12/25/2014	Planned Outage	36.68	1	36.68
1086110	12/26/2014	Planned Outage	1,914.70	41	46.7
1086118	12/26/2014	Planned Outage	38.20	1	38.2
1086127	12/26/2014	Planned Outage	198.60	3	66.2
1086169	12/26/2014	Planned Outage	47.03	2	23.52
1086178	12/26/2014	Planned Outage	187.70	2	93.85
1086236	12/27/2014	Planned Outage	272.13	8	34.02
1086386	12/29/2014	Planned Outage	49.30	2	24.65
1086387	12/29/2014	Planned Outage	25.38	1	25.38
1086391	12/29/2014	Planned Outage	268.53	2	134.27
1086392	12/29/2014	Planned Outage	606.87	4	151.72
1086406	12/29/2014	Planned Outage	27.23	1	27.23
1086407	12/29/2014	Planned Outage	751.27	4	187.82
1086419	12/29/2014	Planned Outage	148.05	7	21.15
1086430	12/29/2014	Planned Outage	96.87	2	48.43
1086433	12/29/2014	Planned Outage	69.40	6	11.57
1086447	12/29/2014	Planned Outage	61.00	5	12.2
1086449	12/29/2014	Planned Outage	89.93	2	44.97
1086452	12/29/2014	Planned Outage	1,157.70	18	64.32
1086455	12/29/2014	Planned Outage	1,390.50	6	231.75
1086460	12/29/2014	Planned Outage	76.90	2	38.45
1086467	12/29/2014	Planned Outage	144.82	1	144.82
1086480	12/29/2014	Planned Outage	216.10	2	108.05
1086494	12/29/2014	Planned Outage	22.88	1	22.88
1086500	12/29/2014	Planned Outage	46.18	1	46.18
1086525	12/30/2014	Planned Outage	6.67	1	6.67
1086531	12/30/2014	Planned Outage	42.12	7	6.02
1086535	12/30/2014	Planned Outage	270.47	2	135.23
1086538	12/30/2014	Planned Outage	336.60	6	56.1
1086543	12/30/2014	Planned Outage	43.50	1	43.5
1086544	12/30/2014	Planned Outage	2,006.75	23	87.25
1086551	12/30/2014	Planned Outage	274.58	1	274.58
1086552	12/30/2014	Planned Outage	607.15	3	202.38
1086553	12/30/2014	Planned Outage	402.57	2	201.28
1086558	12/30/2014	Planned Outage	200.08	5	40.02
1086560	12/30/2014	Planned Outage	15.13	1	15.13
1086561	12/30/2014	Planned Outage	156.00	3	52
1086568	12/30/2014	Planned Outage	21.05	1	21.05
1086573	12/30/2014	Planned Outage	261.77	2	130.88
1086575	12/30/2014	Planned Outage	82.93	2	41.47
1086580	12/30/2014	Planned Outage	64.78	1	64.78
1086585	12/30/2014	Planned Outage	567.87	4	141.97
1086586	12/30/2014	Planned Outage	82.33	4	20.58
1086602	12/30/2014	Planned Outage	100.00	8	12.5
1086616	12/31/2014	Planned Outage	333.00	3	111
1086617	12/31/2014	Planned Outage	643.73	2	321.87
1086631	12/31/2014	Planned Outage	59.75	5	11.95
1086632	12/31/2014	Planned Outage	304.53	4	76.13

Appendix 1

2014 Planned Outages Table

1086633	12/31/2014	Planned Outage	122.40	3	40.8
1086634	12/31/2014	Planned Outage	554.60	2	277.3
1086638	12/31/2014	Planned Outage	14.45	1	14.45
1086639	12/31/2014	Planned Outage	894.40	8	111.8
1086644	12/31/2014	Planned Outage	28.20	2	14.1
1086645	12/31/2014	Planned Outage	75.93	1	75.93
1086646	12/31/2014	Planned Outage	359.67	5	71.93
1086650	12/31/2014	Planned Outage	11.92	1	11.92
1086653	12/31/2014	Planned Outage	61.62	1	61.62
1086656	12/31/2014	Planned Outage	494.67	10	49.47
1086658	12/31/2014	Planned Outage	14.32	1	14.32

Gulf Power Company Annual Wood Pole Inspection Report (Reporting Year 2014)

[illegible]

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
18	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
514	WESTERN	0	0.00	1	0	0	0	0.00	0	0	0
804	WESTERN	0	0.29	1	0	0	4	1.08	0	0	0
2222	EASTERN	0	0.08	1	0	0	1	0.59	10	0	0
2613	CENTRAL	2	2.48	18	5980.5	36	0	0.00	0	0	0
2619	CENTRAL	14	5.24	67	18156	68	0	0.00	0	0	0
5202	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5212	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5222	WESTERN	0	0.00	0	0	0	1	0.00	0	0	0
5232	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5242	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5262	WESTERN	0	0.00	0	0	0	1	0.00	0	0	0
5332	WESTERN	89	14.08	774	52105.6	1005	52	11.39	1294	404.32	7
5342	WESTERN	27	3.88	168	46270.56	285	21	5.24	913	5792.78	30
5352	WESTERN	45	6.86	142	6303.24	59	31	2.86	88	4759	20
5362	WESTERN	0	0.00	0	0	0	0	0.00	1	0	0
5372	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5382	WESTERN	458	128.51	1805	491525.25	2579	36	6.31	146	2164.2	10
5392	WESTERN	236	61.72	930	96036.52	815	19	2.18	25	0	0
5412	WESTERN	1	0.41	3	0	0	0	0.00	0	0	0
5502	WESTERN	64	12.41	316	3595.69	46	9	9.71	506	728.8	6
5512	WESTERN	167	41.54	1004	217912.79	1727	26	10.86	487	1368.07	10
5522	WESTERN	101	23.63	597	119297.3	651	13	4.05	269	421	1
5542	WESTERN	105	32.47	1800	890876.01	5971	29	24.49	1246	21797.87	207
5562	WESTERN	87	22.80	1775	74633.62	2215	16	5.02	335	5813.85	21
5572	WESTERN	31	12.47	936	82763.93	705	14	5.26	373	3840.93	22
5582	WESTERN	98	15.61	879	7103.98	93	13	7.87	930	268.08	5
5592	WESTERN	27	4.40	262	4617.36	41	16	5.46	1123	0	0
5602	WESTERN	305	74.88	1867	36050.38	1256	33	12.25	127	98	1
5612	WESTERN	467	134.35	2242	166429.93	1735	12	4.62	174	134.17	1
5632	WESTERN	22	6.32	473	190525.51	1356	22	6.83	730	433.2	2
5642	WESTERN	104	24.57	1604	60950.36	505	14	17.59	1086	18548.96	79
5652	CENTRAL	83	16.50	1114	400571.46	1777	33	5.18	411	16451.31	80
5662	CENTRAL	95	18.68	1663	188590.5	1252	60	8.39	1301	4935.45	26
5682	CENTRAL	49	9.28	913	336029.06	2621	24	2.35	237	698.07	4
5752	WESTERN	144	26.91	1326	68224.45	538	23	20.73	1017	214.2	1
5762	WESTERN	76	22.22	973	77917.51	694	15	15.29	1057	10953.67	34
5772	WESTERN	20	3.85	129	3328.98	52	6	2.74	202	2711	24
5782	WESTERN	204	64.21	1917	41688.48	488	24	19.18	549	1165.42	9
5792	WESTERN	283	98.15	2311	320009.1	3016	47	13.52	561	612.33	7
5822	WESTERN	103	24.88	1367	146830.24	3483	29	11.06	648	5360.09	39

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
18	WESTERN	0	0	No	0.00	0.00	0.00	0	0	0	0.00	0.00
514	WESTERN	0	0	No	0.01	0.00	0.01	1	0	0	0.10	4.72
804	WESTERN	0	0	No	2.22	1.08	1.13	1	0	0	0.10	0.46
2222	EASTERN	0	0	No	0.76	0.68	0.08	11	0	0	0.10	0.03
2613	CENTRAL	0	0	No	2.49	0.00	2.49	18	5980.5	36	0.10	0.09
2619	CENTRAL	0	1	No	5.27	0.00	5.27	67	18156	68	0.10	0.32
5202	WESTERN	0	0	No	0.03	0.00	0.03	0	0	0	0	4.14
5212	WESTERN	0	0	No	0.02	0.00	0.02	0	0	0	0	3.22
5222	WESTERN	0	0	Yes	1.00	0.97	0.03	0	0	0	0	5.09
5232	WESTERN	0	0	Yes	1.08	1.06	0.02	0	0	0	0	4.60
5242	WESTERN	0	0	No	0.02	0.00	0.02	0	0	0	0	1.19
5262	WESTERN	0	0	Yes	1.03	0.96	0.07	0	0	0	0	4.20
5332	WESTERN	0	0	Yes	30.21	11.39	18.82	2068	52509.92	1012	0.75	11.38
5342	WESTERN	0	0	Yes	10.85	5.24	5.61	1081	52063.34	315	0.10	7.03
5352	WESTERN	0	0	Yes	11.84	2.86	8.98	230	11062.24	79	0.25	11.51
5362	WESTERN	0	0	No	3.17	0.03	3.15	1	0	0	0.10	0.35
5372	WESTERN	0	0	No	3.14	0.03	3.11	0	0	0	0.10	1.20
5382	WESTERN	2	0	No	142.74	6.31	136.44	1951	493689.45	2589	0.50	10.47
5392	WESTERN	0	0	No	64.92	2.18	62.75	955	96036.52	815	0.50	4.30
5412	WESTERN	0	0	No	0.93	0.00	0.93	3	0	0	0.10	6.26
5502	WESTERN	0	0	Yes	23.44	9.89	13.54	822	4324.49	52	1.50	8.03
5512	WESTERN	1	0	Yes	55.18	10.86	44.32	1491	219280.86	1737	0.50	6.75
5522	WESTERN	0	0	No	32.52	4.05	28.47	866	119718.3	652	0.10	4.05
5542	WESTERN	0	0	Yes	61.48	24.49	36.99	3046	970371.98	9628	1.00	15.86
5562	WESTERN	0	0	Yes	30.75	5.02	25.73	2110	80447.47	2236	0.10	8.78
5572	WESTERN	0	0	No	18.68	5.26	13.43	1309	87940.26	1941	0.10	6.95
5582	WESTERN	1	0	Yes	26.61	7.87	18.74	1809	7372.06	98	0.10	9.88
5592	WESTERN	0	0	Yes	14.32	6.79	7.53	1385	4617.36	41	1.50	3.97
5602	WESTERN	0	0	Yes	93.12	12.26	80.86	1994	36148.38	1257	0.50	12.12
5612	WESTERN	0	0	Yes	145.06	4.62	140.45	2416	166564.1	1736	1.00	12.59
5632	WESTERN	0	0	Yes	15.30	8.11	7.19	1203	190958.71	1358	0.50	4.60
5642	WESTERN	0	0	No	47.85	17.59	30.26	2690	79499.32	584	1.00	12.76
5652	CENTRAL	0	1	No	24.17	5.18	18.99	1525	417022.77	1857	0.10	8.88
5662	CENTRAL	1	0	No	28.30	8.46	19.84	2964	193525.95	1278	0.10	11.37
5682	CENTRAL	1	0	No	12.62	2.35	10.27	1150	336820.13	2656	0.10	9.73
5752	WESTERN	1	0	Yes	52.12	20.73	31.39	2343	68438.65	539	0.75	12.63
5762	WESTERN	0	1	Yes	39.86	15.29	24.57	2030	153203.16	2803	1.00	8.39
5772	WESTERN	0	0	Yes	8.49	2.75	5.74	331	6039.98	76	0.50	2.92
5782	WESTERN	0	0	Yes	89.02	19.18	69.84	2466	42853.9	497	1.50	11.94
5792	WESTERN	2	0	No	118.35	13.52	104.83	2872	320621.43	3023	1.00	12.40
5822	WESTERN	0	0	Yes	39.96	11.06	28.90	2015	152190.33	3522	0.25	11.53

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
5832	WESTERN	203	59.47	2346	291787.61	2111	18	2.53	150	86.5	1
5842	WESTERN	160	37.86	1606	84344.24	562	20	14.39	1061	1413.92	10
5852	WESTERN	84	25.72	805	36911.59	293	8	1.07	8	0	0
5872	WESTERN	49	11.18	661	126401.44	1357	30	15.19	954	5633.33	41
5882	CENTRAL	92	22.02	1991	84263.8	997	35	5.02	649	11745.23	43
5892	CENTRAL	106	27.48	2033	202147.14	3952	52	17.75	1426	6306.95	27
5902	WESTERN	40	7.17	584	81404.33	1018	3	2.23	141	5348.07	28
5912	WESTERN	25	2.05	270	9205.21	63	34	5.59	363	1930	10
5922	WESTERN	40	7.07	710	42292.84	391	25	25.13	1675	56393.89	326
5932	WESTERN	68	13.82	1149	112838.65	1412	26	14.17	929	24309.33	142
5942	WESTERN	17	6.55	639	890151.06	2785	40	8.82	1672	6095.97	20
5952	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
5972	WESTERN	39	8.80	658	25928.53	313	17	4.77	458	3571.32	12
5982	WESTERN	40	14.81	963	60354.56	439	49	12.61	1419	21097.16	99
5992	WESTERN	39	8.12	624	8816.39	101	22	11.12	1063	19449.07	70
6022	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
6032	WESTERN	32	6.48	336	51268.88	710	18	4.11	779	2883.25	19
6042	WESTERN	81	17.56	1697	280723.76	1908	6	0.44	47	0	0
6052	WESTERN	130	29.57	1528	87722.27	1376	23	12.41	1184	3861.45	14
6062	WESTERN	71	19.62	1595	71638.15	687	7	0.30	14	0	0
6072	WESTERN	109	25.52	1278	233911.55	4897	41	23.78	1742	9337.85	78
6082	WESTERN	109	28.27	1557	113638.82	1394	17	11.00	1018	0	0
6092	WESTERN	39	14.08	867	35997.65	382	26	8.50	1032	7192.73	100
6212	WESTERN	115	28.22	1219	199785.49	4810	24	25.90	1201	5857.88	72
6222	WESTERN	73	18.52	621	36821.01	593	24	12.16	792	6838.25	57
6338	WESTERN	0	0.00	0	0	0	0	0.90	44	0	0
6348	WESTERN	0	0.00	0	0	0	0	0.92	37	0	0
6352	WESTERN	0	0.00	0	0	0	0	0.86	56	0	0
6412	CENTRAL	86	29.34	634	186518.05	1495	6	3.85	128	23	1
6432	CENTRAL	23	7.25	201	20368.08	236	4	0.58	11	0	0
6452	CENTRAL	37	6.38	90	5653.93	54	5	0.43	4	0	0
6482	WESTERN	34	10.44	812	46974.21	328	29	9.42	1216	8144.05	31
6508	WESTERN	10	1.56	28	1042.2	11	9	0.37	8	446	2
6522	WESTERN	110	16.51	1510	387899.73	4750	36	3.49	469	2340.95	35
6532	WESTERN	106	23.05	1753	213543.61	2360	8	0.40	302	0	0
6542	WESTERN	60	13.95	1324	28068.5	298	14	1.26	238	423.07	8
6572	WESTERN	114	21.51	1624	200834.54	1670	21	0.93	244	24873.2	70
6582	WESTERN	98	17.90	1518	128105.32	1342	5	0.28	28	0	0
6592	WESTERN	21	2.21	184	6657	107	9	0.91	208	1577.75	5

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
5832	WESTERN	0	0	Yes	68.40	2.53	65.87	2496	291874.11	2112	0.50	11.46
5842	WESTERN	0	0	No	54.94	14.39	40.55	2667	85758.16	572	1.00	12.20
5852	WESTERN	1	0	Yes	29.45	1.07	28.37	813	36911.59	293	0.10	4.43
5872	WESTERN	0	0	No	27.63	15.19	12.44	1615	132034.77	1398	0.25	8.78
5882	CENTRAL	0	0	No	28.61	5.02	23.59	2640	96009.03	1040	0.25	10.40
5892	CENTRAL	0	0	No	51.76	17.75	34.00	3459	208454.09	3979	0.25	16.03
5902	WESTERN	0	0	Yes	11.27	3.06	8.21	725	86752.4	1046	0.10	7.02
5912	WESTERN	0	0	Yes	11.69	6.60	5.09	633	11135.21	73	0.10	6.97
5922	WESTERN	0	0	Yes	36.59	25.14	11.45	2385	98686.73	717	0.25	13.77
5932	WESTERN	0	0	Yes	29.63	14.17	15.46	2078	137147.98	1554	0.25	10.14
5942	WESTERN	0	0	No	21.41	10.97	10.44	2311	896247.03	2805	0.50	13.37
5952	WESTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.00	0.00
5972	WESTERN	0	0	Yes	16.25	4.85	11.39	1116	29499.85	325	0.10	4.94
5982	WESTERN	0	0	No	29.35	12.88	16.48	2382	81451.72	538	0.10	9.32
5992	WESTERN	0	0	Yes	22.07	11.21	10.85	1687	28265.46	171	0.10	8.14
6022	WESTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.00	0.00
6032	WESTERN	0	0	Yes	13.82	4.11	9.71	1115	54152.13	729	0.20	7.01
6042	WESTERN	0	0	Yes	19.62	0.44	19.18	1744	551499.26	3627	0.10	6.40
6052	WESTERN	0	0	Yes	45.74	12.41	33.32	2712	91583.72	1390	1.00	11.11
6062	WESTERN	0	0	Yes	23.34	0.30	23.03	1609	71638.15	687	0.10	6.99
6072	WESTERN	0	0	Yes	54.56	23.78	30.78	3020	243249.4	4975	0.10	14.99
6082	WESTERN	0	0	Yes	43.49	11.00	32.49	2575	113638.82	1394	0.20	10.56
6092	WESTERN	0	0	Yes	26.30	8.52	17.78	1899	43190.38	482	0.20	9.55
6212	WESTERN	0	0	Yes	59.06	26.19	32.87	2420	205643.37	4882	1.00	12.89
6222	WESTERN	0	0	Yes	32.81	12.16	20.65	1413	43659.26	650	0.50	6.51
6338	WESTERN	0	0	No	0.90	0.90	0.00	44	0	0	0.00	0.00
6348	WESTERN	0	0	No	0.92	0.92	0.00	37	0	0	0.00	0.00
6352	WESTERN	0	0	No	0.86	0.86	0.00	56	0	0	0.00	0.00
6412	CENTRAL	0	0	Yes	34.47	3.85	30.63	762	186541.05	1496	0.10	3.90
6432	CENTRAL	0	0	No	8.88	0.58	8.29	212	46341.33	663	0.10	1.11
6452	CENTRAL	0	0	Yes	10.13	0.43	9.70	94	5653.93	54	0.10	0.90
6482	WESTERN	0	0	Yes	22.96	9.47	13.49	2028	55118.26	359	0.10	7.64
6508	WESTERN	0	0	No	2.52	0.46	2.06	36	1488.2	13	0.50	9.70
6522	WESTERN	0	0	No	23.88	3.50	20.38	1979	390240.68	4785	0.10	8.52
6532	WESTERN	0	0	No	24.79	0.40	24.38	2055	371585.41	5944	0.10	7.86
6542	WESTERN	0	0	No	17.86	1.26	16.60	1562	28491.57	306	0.10	6.99
6572	WESTERN	0	0	No	24.58	0.93	23.65	1868	475372.76	6327	2.00	8.88
6582	WESTERN	0	0	Yes	21.03	0.28	20.76	1546	128105.32	1342	0.10	6.20
6592	WESTERN	0	0	No	6.45	0.91	5.54	392	24950.75	510	0.10	7.98

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
6602	WESTERN	30	6.56	545	7194.18	67	4	0.14	19	0	0
6612	WESTERN	67	12.20	1226	40104.47	935	5	0.10	4	0	0
6622	WESTERN	43	7.63	783	18032.46	149	4	0.12	11	0	0
6632	WESTERN	85	8.54	638	10590.66	98	10	0.98	15	0	0
6642	WESTERN	63	9.73	583	23534.41	206	7	0.43	52	0	0
6652	WESTERN	157	25.82	2360	150867.68	1170	11	1.04	157	4899.83	26
6662	WESTERN	86	17.71	977	56263.99	774	26	3.84	396	0	0
6678	WESTERN	56	17.29	1655	104818.65	919	25	5.46	712	6665.57	109
6682	WESTERN	35	9.73	736	20825.22	483	11	2.38	223	0	0
6692	WESTERN	60	13.62	1120	64257.12	575	12	2.93	522	0	0
6706	WESTERN	55	13.91	760	38699.95	357	4	0.11	4	0	0
6716	WESTERN	64	12.36	798	164213.58	1675	17	1.12	163	0	0
6722	WESTERN	0	0.37	1	0	0	0	0.00	2	0	0
6732	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
6742	WESTERN	29	11.35	1134	61104.24	743	11	7.38	654	14849.7	101
6774	WESTERN	65	16.44	721	56032.28	539	31	2.32	86	316	2
6782	WESTERN	99	27.02	1024	108820.5	1906	21	6.53	662	767.23	1
6792	WESTERN	162	34.15	1249	60305.4	882	47	12.85	1148	72641.1	278
6912	WESTERN	133	33.53	916	41657.19	384	21	6.87	441	230.88	2
6922	WESTERN	177	46.81	1174	47635.49	416	7	2.96	126	0	0
6932	WESTERN	103	22.39	879	217535.83	2832	23	12.23	736	11116.12	84
6942	WESTERN	274	53.34	1463	205005.68	1678	16	3.80	156	27135.08	77
6966	WESTERN	1	0.41	0	0	0	1	0.02	1	0	0
6982	WESTERN	7	9.99	14	638.23	4	0	0.00	0	0	0
6992	WESTERN	108	19.49	1013	173947.63	1415	31	19.91	1241	259	5
7012	WESTERN	132	33.56	1809	108382.17	2533	17	4.53	380	89	3
7022	WESTERN	64	11.65	580	4671.22	56	16	6.23	281	5591.23	34
7032	WESTERN	48	9.68	528	18050.68	320	14	4.24	355	0	0
7042	WESTERN	78	22.15	910	95241.23	1069	19	14.04	786	12660.54	62
7112	WESTERN	118	23.20	1105	73809.03	750	21	6.93	614	0	0
7122	WESTERN	129	23.00	721	145227.53	2794	28	14.55	886	12069.55	83
7132	WESTERN	126	19.32	943	128531.81	2753	24	9.57	671	1129.73	3
7157	WESTERN	0	0.60	0	0	0	1	0.09	1	0	0
7172	WESTERN	71	16.06	835	25158.64	355	16	6.24	348	691.67	7
7232	WESTERN	196	50.06	1855	91878.04	1287	53	8.90	421	1427	16
7246	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
7252	WESTERN	164	38.93	1396	252801.55	2018	43	17.16	1133	3730.79	40
7262	WESTERN	184	64.22	2611	145002.54	3510	25	6.64	509	847.75	7
7272	WESTERN	230	70.31	2240	291611.42	3807	33	3.11	241	590.19	11

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
6602	WESTERN	0	0	Yes	7.81	0.14	7.68	564	7194.18	67	0.10	2.01
6612	WESTERN	0	0	Yes	15.87	0.18	15.69	1230	40104.47	935	0.10	5.54
6622	WESTERN	0	0	Yes	9.37	0.25	9.12	794	18032.46	149	0.10	3.85
6632	WESTERN	0	0	Yes	11.54	0.98	10.56	653	10590.66	98	0.10	8.93
6642	WESTERN	0	0	Yes	13.00	0.43	12.56	635	23534.41	206	0.10	6.71
6652	WESTERN	0	0	Yes	29.72	1.04	28.68	2517	155767.51	1196	0.10	10.67
6662	WESTERN	0	0	Yes	25.02	3.84	21.18	1373	56263.99	774	0.10	8.48
6678	WESTERN	0	0	Yes	25.14	5.46	19.68	2367	148881.29	3327	0.10	9.55
6682	WESTERN	0	0	Yes	16.42	2.38	14.05	959	20825.22	483	0.10	5.16
6692	WESTERN	0	0	Yes	18.89	2.93	15.96	1642	64257.12	575	0.25	6.05
6706	WESTERN	0	0	No	15.41	0.11	15.30	764	38699.95	357	0.10	4.17
6716	WESTERN	0	0	Yes	18.28	1.13	17.16	961	168358.08	1765	0.10	5.62
6722	WESTERN	0	0	Yes	1.20	0.12	1.08	3	0	0	0.10	10.08
6732	WESTERN	0	0	Yes	0.67	0.12	0.55	0	0	0	0.10	4.89
6742	WESTERN	0	0	Yes	21.41	7.46	13.95	1788	253378.54	4377	0.10	6.94
6774	WESTERN	0	0	No	21.43	2.32	19.11	807	56348.28	541	0.25	6.93
6782	WESTERN	1	0	No	39.34	6.53	32.82	1686	109587.73	1907	0.25	9.39
6792	WESTERN	0	0	No	50.39	12.85	37.54	2397	132946.5	1160	1.00	11.80
6912	WESTERN	0	0	Yes	42.02	6.87	35.15	1357	41888.07	386	0.50	7.02
6922	WESTERN	1	0	Yes	51.01	2.96	48.05	1300	47635.49	416	0.10	5.40
6932	WESTERN	0	0	No	39.51	12.23	27.28	1615	437800.4	5885	0.50	7.94
6942	WESTERN	0	0	Yes	61.48	3.80	57.68	1619	232140.76	1755	0.25	6.59
6966	WESTERN	0	0	No	0.42	0.02	0.41	1	0	0	0.00	0.00
6982	WESTERN	0	0	No	10.60	0.00	10.60	14	638.23	4	0.10	0.84
6992	WESTERN	0	0	Yes	45.18	19.91	25.27	2254	194907.26	3666	0.25	12.85
7012	WESTERN	0	0	No	42.26	4.53	37.73	2189	108471.17	2536	0.10	11.15
7022	WESTERN	0	0	Yes	21.68	6.23	15.46	861	10262.45	90	0.10	6.37
7032	WESTERN	0	0	No	14.83	4.24	10.59	883	18050.68	320	0.10	4.62
7042	WESTERN	0	0	Yes	40.44	14.04	26.41	1696	107901.77	1131	0.25	7.86
7112	WESTERN	0	0	Yes	31.39	6.94	24.46	1719	73809.03	750	0.25	11.53
7122	WESTERN	0	0	Yes	40.87	14.55	26.32	1607	157297.08	2877	1.00	8.61
7132	WESTERN	0	0	Yes	33.63	9.57	24.06	1614	129661.54	2756	0.25	7.45
7157	WESTERN	0	0	No	0.70	0.09	0.61	1	0	0	0.00	1.99
7172	WESTERN	0	0	Yes	27.55	6.24	21.32	1183	25850.31	362	0.10	5.50
7232	WESTERN	0	0	Yes	63.79	8.90	54.89	2276	93305.04	1303	0.10	10.00
7246	WESTERN	0	0	No	0.00	0.00	0.00	0	0	0	0.00	0.00
7252	WESTERN	0	0	Yes	59.46	17.16	42.30	2529	256532.34	2058	0.50	12.68
7262	WESTERN	0	1	Yes	75.94	6.64	69.30	3120	153537.79	6592	0.25	11.92
7272	WESTERN	1	0	Yes	76.70	3.11	73.59	2481	292201.61	3818	0.10	12.17

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
7282	WESTERN	95	24.92	1423	177567.26	1863	27	4.13	222	1073.26	9
7292	WESTERN	123	27.44	1540	20096.83	285	19	4.59	422	270.43	7
7302	WESTERN	0	0.73	0	0	0	0	0.72	4	0	0
7332	WESTERN	72	16.93	462	29550.08	276	28	18.58	988	179011.43	561
7342	WESTERN	141	22.36	1051	225791.29	4613	70	15.25	2319	52342.29	185
7352	WESTERN	42	12.27	995	117701	923	23	7.40	1392	49109.05	299
7362	WESTERN	31	4.86	301	470977.75	1911	44	6.51	1652	24288.47	75
7372	WESTERN	63	12.38	819	324491.76	1708	29	28.26	1927	33368.22	235
7492	WESTERN	129	28.64	762	38320.43	433	10	0.97	66	0	0
7512	WESTERN	94	17.18	1242	123940.19	1644	34	5.26	477	3566.03	55
7522	WESTERN	50	9.23	825	81396.37	285	35	10.02	566	1703.42	10
7532	WESTERN	8	2.27	175	13996.35	123	6	17.57	1132	63858.05	173
7542	WESTERN	0	0.00	0	94	1	1	5.64	361	0	0
7582	WESTERN	173	34.42	2299	173601.67	2152	23	4.44	366	0	0
7592	WESTERN	20	5.40	298	188222.64	1901	12	6.18	583	3190.98	35
7602	WESTERN	29	4.70	186	33128	499	37	3.22	424	10778.3	80
7612	WESTERN	87	14.76	1118	44692.04	557	50	5.45	851	21494.48	87
7622	WESTERN	49	10.10	956	44196.93	750	19	2.54	366	1918	15
7632	WESTERN	95	13.53	1103	64686.76	740	13	4.86	459	15565.18	147
7642	WESTERN	42	10.66	942	5226.4	57	21	3.73	557	12922.15	64
7652	WESTERN	11	1.04	35	197	3	25	3.67	107	0	0
7662	WESTERN	76	16.69	1123	138838.1	762	26	7.08	805	37985.6	290
7682	WESTERN	68	10.77	1053	24562.54	139	33	8.05	1073	17375.2	119
7692	WESTERN	7	1.52	109	3956.67	68	7	0.51	10	0	0
7702	WESTERN	45	10.70	938	124412.61	851	10	6.52	495	1138.33	20
7712	WESTERN	39	9.57	674	20348.82	159	4	1.32	133	359.27	1
7722	WESTERN	43	12.26	1000	96484.38	467	1	0.75	45	12182.35	71
7732	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
7742	WESTERN	58	18.68	1814	38467.24	412	14	1.91	297	3207.49	30
7752	WESTERN	85	18.22	1345	137362.82	1008	32	5.90	746	621.9	3
7762	WESTERN	53	11.94	1246	60320.6	1003	5	0.41	67	0	0
7772	WESTERN	42	6.17	365	24579.68	538	12	1.36	268	541.73	2
7782	WESTERN	78	12.52	993	32594.69	386	11	1.21	156	173.52	1
7792	WESTERN	95	21.28	1376	45753.29	504	19	9.36	737	18687.99	69
7802	WESTERN	27	5.70	273	23012.7	308	32	5.46	866	3795.3	32
7822	WESTERN	43	6.96	428	76610.92	988	26	7.76	1474	103889.97	507
7832	WESTERN	130	28.42	1676	309481.93	5045	21	9.16	1169	25.43	1
7842	WESTERN	146	31.66	1708	177409.21	2603	42	11.71	1038	5262.18	27
7872	WESTERN	35	5.80	346	95860.6	309	21	1.66	70	0	0

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
7282	WESTERN	0	0	Yes	33.50	4.13	29.37	1645	178640.52	1872	0.10	10.07
7292	WESTERN	0	0	Yes	36.67	4.59	32.08	1962	20367.26	292	0.20	10.40
7302	WESTERN	0	0	No	1.47	0.72	0.76	4	0	0	0.10	0.48
7332	WESTERN	0	0	Yes	37.44	18.58	18.86	1450	208561.51	837	0.25	7.86
7342	WESTERN	0	0	Yes	42.02	15.54	26.48	3370	278133.58	4798	0.25	14.53
7352	WESTERN	0	0	Yes	22.17	7.40	14.78	2387	408186.05	3604	0.25	8.83
7362	WESTERN	0	0	Yes	14.85	6.70	8.14	1953	515766.22	2068	0.25	8.69
7372	WESTERN	0	0	Yes	43.64	28.26	15.37	2746	363331.98	4679	0.50	10.66
7492	WESTERN	0	0	No	32.67	0.97	31.70	828	38320.43	433	0.10	4.45
7512	WESTERN	0	0	Yes	25.14	5.26	19.89	1719	127506.22	1699	0.25	10.23
7522	WESTERN	0	0	Yes	22.77	10.02	12.75	1391	83099.79	295	0.25	11.55
7532	WESTERN	0	0	Yes	24.57	21.37	3.20	1307	77854.4	296	0.25	6.79
7542	WESTERN	0	0	Yes	10.70	9.93	0.78	361	36422.67	366	0.25	4.71
7582	WESTERN	0	0	Yes	44.49	4.44	40.05	2665	173601.67	2152	0.10	10.56
7592	WESTERN	0	0	Yes	12.72	6.18	6.55	881	233705.62	2808	0.10	4.35
7602	WESTERN	0	0	No	9.15	3.22	5.93	610	43906.3	579	0.25	5.16
7612	WESTERN	0	0	Yes	22.28	5.45	16.83	1969	66186.52	644	0.10	12.16
7622	WESTERN	0	0	Yes	14.39	2.54	11.85	1322	46114.93	765	0.10	7.08
7632	WESTERN	0	0	No	19.85	4.86	14.98	1562	80251.94	887	0.10	6.89
7642	WESTERN	0	0	No	16.03	3.73	12.30	1499	18148.55	121	0.10	6.41
7652	WESTERN	0	0	Yes	7.63	3.89	3.75	142	197	3	0.10	6.40
7662	WESTERN	0	0	No	26.85	7.08	19.77	1928	176823.7	1052	0.10	10.51
7682	WESTERN	0	0	No	23.25	8.25	15.00	2126	41937.74	258	0.10	8.74
7692	WESTERN	0	0	Yes	3.58	0.51	3.07	119	3956.67	68	0.10	1.55
7702	WESTERN	0	0	Yes	19.77	6.52	13.24	1433	125550.94	871	0.10	8.29
7712	WESTERN	0	0	Yes	12.59	1.32	11.27	807	20708.09	160	0.10	3.26
7722	WESTERN	0	0	Yes	16.19	0.75	15.44	1045	199255.03	1605	0.10	4.49
7732	WESTERN	0	0	No	0.00	0.00	0.00	0	0	0	0.00	0.00
7742	WESTERN	0	0	Yes	24.06	1.91	22.15	2111	41674.73	442	0.10	7.92
7752	WESTERN	0	0	Yes	27.80	5.90	21.90	2091	140460.32	3074	0.10	8.80
7762	WESTERN	0	0	Yes	14.73	0.41	14.31	1313	60320.6	1003	0.10	5.29
7772	WESTERN	0	0	Yes	9.85	1.36	8.49	633	73583.41	1155	0.10	5.87
7782	WESTERN	1	0	Yes	17.24	1.21	16.03	1149	37899.14	1523	0.25	9.11
7792	WESTERN	0	0	Yes	32.79	9.36	23.43	2113	64441.28	573	0.10	10.32
7802	WESTERN	0	0	No	12.84	5.46	7.38	1139	29511.08	1335	0.50	12.51
7822	WESTERN	0	0	No	17.35	7.76	9.59	1902	261728.89	3429	1.00	7.95
7832	WESTERN	0	0	No	41.61	9.16	32.45	2845	309507.36	5046	0.10	11.04
7842	WESTERN	1	0	Yes	46.04	11.71	34.33	2746	189731.36	5311	0.10	13.02
7872	WESTERN	0	0	Yes	9.91	1.66	8.24	416	100131.53	452	0.50	11.15

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
7882	WESTERN	56	11.81	620	28747.15	300	32	4.19	270	0	0
7892	WESTERN	0	0.00	12	0	0	1	1.02	89	0	0
7902	CENTRAL	177	45.29	1623	133425.03	618	34	5.21	363	10167.8	47
7912	CENTRAL	170	57.02	1484	222641.73	2693	16	1.35	113	0	0
7922	WESTERN	82	13.40	934	456172.54	1583	29	14.72	1248	1219.3	9
7932	WESTERN	66	14.14	1033	41097.97	518	54	8.60	1010	3795.64	42
7942	WESTERN	52	5.43	530	10223.36	103	26	2.35	132	189	3
7962	CENTRAL	80	27.49	465	79173.86	522	4	0.35	5	0	0
7992	EASTERN	83	35.58	1025	100648.3	762	39	10.82	737	2418.03	14
8012	EASTERN	3	1.37	16	0	0	6	0.48	4	0	0
8032	EASTERN	35	21.81	195	59752.05	326	28	11.85	46	0	0
8052	EASTERN	0	0.00	1	0	0	0	0.00	0	0	0
8062	EASTERN	63	28.53	472	161362.29	908	17	3.36	25	387.93	4
8112	EASTERN	62	10.57	1582	30194.3	423	32	2.47	1963	22589.75	182
8122	EASTERN	31	5.22	225	131677.87	745	25	12.90	1398	2667.02	43
8132	EASTERN	39	12.60	378	20036.54	232	48	34.30	2267	471701.57	2408
8142	EASTERN	0	0.00	0	0	0	0	0.00	0	0	0
8162	CENTRAL	50	13.00	477	339285.31	2149	55	26.09	1853	17928.9	65
8172	CENTRAL	3	1.18	23	84895.93	382	14	17.42	1868	214863.57	2119
8182	CENTRAL	0	0.00	0	96.08	1	9	4.57	1165	0	0
8202	EASTERN	92	23.07	1428	41970.92	576	31	5.11	564	0	0
8222	EASTERN	6	4.24	43	103.6	1	13	22.95	912	0	0
8232	EASTERN	0	0.00	0	0	0	0	0.00	0	0	0
8252	EASTERN	0	0.00	0	0	0	0	0.00	0	0	0
8262	EASTERN	0	2.36	0	0	0	0	0.02	0	0	0
8282	EASTERN	111	25.26	2006	339650.26	3658	46	5.68	794	5714.87	51
8332	EASTERN	93	37.26	1763	140040.72	1379	73	22.39	1465	25862.55	239
8342	EASTERN	97	26.44	2024	87349.24	886	40	3.16	497	553.35	3
8352	EASTERN	67	12.43	1176	83855.12	722	28	2.91	1711	162.85	1
8362	EASTERN	55	15.85	808	156951.36	1142	33	12.84	2125	42995.61	239
8372	EASTERN	12	1.49	110	2770.8	12	17	8.40	838	5696.55	31
8382	EASTERN	6	0.76	15	12811.65	113	8	1.36	92	0	0
8392	EASTERN	62	13.34	1103	142823.21	2073	17	1.98	386	14786	62
8412	EASTERN	88	15.18	1318	161689.02	1542	42	2.21	403	0	0
8422	EASTERN	0	0.00	0	0	0	0	0.00	0	0	0
8432	EASTERN	70	13.07	1337	31034.31	321	16	1.25	321	0	0
8442	EASTERN	67	10.31	1016	28188.26	309	14	0.92	129	3985	75
8452	EASTERN	39	6.37	267	2910.45	52	59	7.97	714	2377.13	14
8472	EASTERN	109	20.63	2092	95157.99	1816	26	3.03	495	0	0

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
7882	WESTERN	0	0	Yes	16.93	4.19	12.73	890	28747.15	300	0.50	12.16
7892	WESTERN	0	0	No	1.57	1.02	0.56	101	0	0	0.50	9.51
7902	CENTRAL	2	0	No	54.93	5.21	49.72	1986	290434.63	2644	0.10	12.10
7912	CENTRAL	0	2	No	63.33	1.35	61.98	1597	306773.43	4295	0.10	6.94
7922	WESTERN	0	0	No	30.75	14.72	16.03	2182	510166.04	2375	0.10	9.84
7932	WESTERN	0	0	No	24.74	8.60	16.14	2043	44893.61	560	0.10	13.67
7942	WESTERN	0	0	Yes	12.09	3.02	9.07	662	10412.36	106	0.25	9.36
7962	CENTRAL	0	0	No	31.23	0.38	30.85	470	79173.86	522	0.10	1.97
7992	EASTERN	6	0	Yes	53.55	10.82	42.73	1762	103066.33	776	0.50	8.61
8012	EASTERN	0	0	No	2.27	0.73	1.54	20	0	0	0.10	1.45
8032	EASTERN	0	0	No	36.51	11.85	24.66	241	65352.05	550	0.10	1.10
8052	EASTERN	0	0	No	0.01	0.00	0.01	1	0	0	0.00	0.00
8062	EASTERN	4	0	No	36.44	3.36	33.08	497	201651.42	1896	1.00	4.97
8112	EASTERN	0	0	Yes	15.46	3.10	12.36	3545	52784.05	605	0.25	12.99
8122	EASTERN	0	0	Yes	19.93	12.90	7.02	1623	134344.89	788	1.00	14.24
8132	EASTERN	1	0	No	48.71	34.57	14.14	2645	491738.11	2640	2.00	13.61
8142	EASTERN	0	0	No	0.00	0.00	0.00	0	0	0	0.00	0.00
8162	CENTRAL	0	0	No	40.96	26.30	14.66	2330	357214.21	2214	1.00	13.04
8172	CENTRAL	0	0	Yes	19.36	18.18	1.18	1891	299759.5	2501	1.00	12.25
8182	CENTRAL	0	0	Yes	6.86	5.61	1.25	1165	96.08	1	0.50	8.22
8202	EASTERN	0	0	Yes	30.81	5.11	25.70	1992	41970.92	576	0.10	8.37
8222	EASTERN	0	0	No	27.44	23.03	4.41	955	103.6	1	0.50	7.37
8232	EASTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.1	4.40
8252	EASTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.1	1.87
8262	EASTERN	0	0	No	3.56	0.02	3.54	0	0	0	0.1	9.59
8282	EASTERN	0	0	No	32.19	5.68	26.50	2800	345365.13	3709	0.10	10.78
8332	EASTERN	2	0	Yes	63.80	22.39	41.41	3228	165903.27	1618	0.25	12.88
8342	EASTERN	2	0	Yes	32.21	3.16	29.05	2521	87902.59	889	0.10	11.53
8352	EASTERN	1	0	No	16.66	2.91	13.75	2887	84017.97	723	0.50	11.83
8362	EASTERN	0	0	No	31.19	12.84	18.35	2933	199946.97	1381	2.00	11.21
8372	EASTERN	0	0	Yes	10.92	8.40	2.52	948	8467.35	43	1.00	12.63
8382	EASTERN	0	0	Yes	3.14	1.37	1.77	107	22024.65	224	1.00	9.50
8392	EASTERN	0	0	Yes	17.50	1.98	15.52	1489	455103.41	5770	0.10	7.73
8412	EASTERN	0	0	No	20.32	2.21	18.11	1721	161689.02	1542	0.50	12.34
8422	EASTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.00	0.00
8432	EASTERN	0	0	Yes	16.00	1.25	14.75	1658	31034.31	321	0.10	7.00
8442	EASTERN	1	0	Yes	13.49	0.92	12.57	1145	32173.26	384	0.10	6.06
8452	EASTERN	0	0	Yes	16.28	7.97	8.32	981	5287.58	66	0.10	12.19
8472	EASTERN	0	0	Yes	27.90	3.08	24.82	2587	95157.99	1816	0.10	10.85

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
8482	EASTERN	50	10.35	590	60873.96	679	30	2.26	227	137	2
8492	EASTERN	29	3.83	271	8314.09	142	13	1.32	117	1152.7	6
8512	EASTERN	7	1.25	30	47.43	1	13	9.99	924	44308.7	253
8522	EASTERN	55	12.20	653	27298.74	494	48	19.72	2047	1043.88	8
8532	EASTERN	21	3.08	148	828.57	10	27	2.95	1621	0	0
8542	EASTERN	14	0.97	131	70942.42	846	12	3.58	3172	77.48	2
8552	EASTERN	44	9.41	830	237223.73	1448	40	8.46	1493	21094.5	232
8562	EASTERN	37	4.15	464	5299.2	62	28	7.95	1711	56395.1	328
8572	EASTERN	110	24.67	1866	37071.72	381	41	5.59	715	6767.3	59
8582	EASTERN	57	11.69	1164	107044.85	630	24	8.56	1917	5706.31	31
8592	EASTERN	1	0.39	13	0	0	10	0.32	1	0	0
8602	EASTERN	104	22.13	1274	9751.27	125	43	19.62	1479	26709.73	148
8612	EASTERN	53	13.01	532	6128.5	65	18	5.70	245	542.37	4
8622	EASTERN	72	13.65	648	30470.02	239	33	9.05	573	668.41	9
8642	EASTERN	64	9.86	1261	121914.6	646	45	10.62	1378	2408.5	40
8672	EASTERN	33	6.99	312	150190.01	1191	50	25.06	1905	74008.89	319
8682	EASTERN	57	11.33	1254	158530.27	844	37	9.73	1996	1155.72	4
8702	EASTERN	76	18.02	1754	53005.55	963	18	1.01	99	1874	24
8712	EASTERN	68	15.18	1285	38372.14	521	31	3.28	148	0	0
8722	EASTERN	124	26.69	2014	172457.88	2181	23	1.62	295	419	3
8732	EASTERN	82	19.25	2105	383009.96	2950	18	1.58	244	0	0
8782	EASTERN	35	8.61	252	22955.36	178	41	2.83	225	138	2
8792	EASTERN	173	39.61	2608	480309.63	4486	35	4.30	408	0	0
8802	EASTERN	84	22.41	1397	135003.3	1409	35	14.62	1207	8855.63	55
8812	EASTERN	74	17.29	1292	28502.01	218	61	11.65	1534	13209.88	89
8822	EASTERN	96	23.23	1545	175210.88	2146	54	9.67	1771	6492.71	32
8842	CENTRAL	12	1.78	69	141435.75	1241	33	17.19	1651	14932.57	31
8852	EASTERN	79	20.32	1525	99242.04	740	12	1.34	145	204.37	1
8872	CENTRAL	24	7.33	322	111361.16	304	33	6.97	618	2313.5	6
8882	CENTRAL	20	3.15	593	11160.86	66	46	7.92	1977	19857.04	315
8892	CENTRAL	29	5.00	526	18813.69	248	44	9.12	1894	5443.68	17
8932	CENTRAL	138	39.00	1297	119738.07	2163	26	7.37	337	0	0
8942	CENTRAL	12	1.50	29	145.62	1	8	0.39	17	0	0
8952	EASTERN	11	11.42	16	2983.1	26	3	0.29	2	0	0
8962	EASTERN	59	14.28	1255	275331.42	2527	46	13.12	1676	21237.04	116
8972	EASTERN	92	25.75	2392	235917.63	1445	22	14.74	1020	191	1
8982	CENTRAL	11	1.70	191	3266.1	35	17	1.61	291	0	0
8992	CENTRAL	0	0.00	0	0	0	0	0.00	0	0	0
9042	CENTRAL	62	8.15	555	39119.59	602	56	18.05	1435	76520.62	280

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
8482	EASTERN	0	0	No	16.26	2.26	14.00	817	83850.89	1525	0.10	12.10
8492	EASTERN	0	0	Yes	6.16	1.32	4.85	388	9466.79	148	0.10	3.02
8512	EASTERN	0	0	No	13.06	11.06	2.00	954	44356.13	254	0.50	6.43
8522	EASTERN	0	0	No	34.97	19.93	15.04	2700	28342.62	502	0.50	15.18
8532	EASTERN	0	0	No	6.83	2.95	3.89	1769	828.57	10	0.50	10.83
8542	EASTERN	0	0	No	5.75	3.73	2.02	3303	95166.47	3957	1.00	13.66
8552	EASTERN	3	0	Yes	21.44	8.66	12.77	2323	258318.23	1680	0.50	9.48
8562	EASTERN	0	0	Yes	16.61	8.61	7.99	2175	61694.3	390	0.50	10.42
8572	EASTERN	2	0	Yes	33.29	5.59	27.70	2581	47994.22	3037	0.10	13.18
8582	EASTERN	0	0	Yes	22.19	8.57	13.62	3081	112751.16	661	0.50	14.53
8592	EASTERN	0	0	No	1.81	0.32	1.49	14	0	0	0.10	6.30
8602	EASTERN	3	0	No	45.15	19.62	25.53	2753	36461	273	0.25	13.58
8612	EASTERN	2	0	Yes	23.23	5.70	17.53	777	6670.87	69	0.10	5.04
8622	EASTERN	0	0	Yes	27.46	9.05	18.42	1221	31138.43	248	0.25	10.08
8642	EASTERN	0	0	No	22.46	10.62	11.84	2639	124323.1	686	0.50	9.88
8672	EASTERN	0	0	Yes	34.72	25.06	9.66	2217	575097.3	4913	0.50	12.77
8682	EASTERN	1	0	No	23.11	9.73	13.38	3250	159685.99	848	0.50	12.71
8702	EASTERN	0	0	Yes	22.01	1.01	21.01	1853	54879.55	987	0.10	7.01
8712	EASTERN	0	0	Yes	22.02	3.34	18.69	1433	201573.27	4817	0.10	12.05
8722	EASTERN	1	0	Yes	30.67	1.62	29.06	2309	172876.88	2184	0.10	10.60
8732	EASTERN	1	0	Yes	24.13	1.67	22.46	2349	383009.96	2950	0.10	9.86
8782	EASTERN	0	0	Yes	12.14	2.88	9.26	477	42124.46	654	0.50	8.99
8792	EASTERN	1	0	Yes	47.49	4.30	43.19	3016	487738.63	6671	0.10	12.55
8802	EASTERN	2	0	No	38.32	14.62	23.69	2604	143858.93	1464	0.10	12.72
8812	EASTERN	0	0	Yes	32.38	11.65	20.73	2826	41711.89	307	0.50	14.55
8822	EASTERN	0	0	No	35.86	9.67	26.19	3316	181703.59	2178	0.10	15.33
8842	CENTRAL	0	0	Yes	20.44	17.19	3.25	1720	159271.92	2980	0.50	11.87
8852	EASTERN	1	0	Yes	24.85	1.34	23.50	1670	99446.41	741	0.10	8.82
8872	CENTRAL	0	0	No	14.77	6.97	7.81	940	113674.66	310	0.50	9.25
8882	CENTRAL	0	0	Yes	13.51	9.07	4.44	2570	31017.9	381	0.50	9.01
8892	CENTRAL	1	0	Yes	17.56	10.49	7.07	2420	24257.37	265	0.50	11.78
8932	CENTRAL	0	1	No	48.90	7.37	41.53	1634	119738.07	2163	1.00	9.87
8942	CENTRAL	0	0	No	3.52	0.39	3.13	46	145.62	1	1.00	1.54
8952	EASTERN	0	0	No	11.71	0.29	11.42	18	4772.1	46	0.10	0.67
8962	EASTERN	1	0	No	29.24	13.12	16.12	2931	296568.46	2643	0.25	10.95
8972	EASTERN	0	0	No	41.94	14.82	27.12	3412	236108.63	1446	0.25	10.34
8982	CENTRAL	0	0	Yes	4.78	1.61	3.17	482	3266.1	35	0.50	2.98
8992	CENTRAL	0	0	No	0.00	0.00	0.00	0	0	0	0.00	0.00
9042	CENTRAL	0	0	Yes	28.68	18.10	10.58	1990	115640.21	882	0.50	8.94

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
9052	CENTRAL	46	10.51	1146	59858.26	672	34	4.75	733	3035	7
9062	CENTRAL	15	1.70	198	542864.57	1793	18	6.10	739	4181.63	42
9082	CENTRAL	15	1.63	245	25463.5	441	28	10.80	2388	160972.75	599
9092	EASTERN	5	3.13	10	144	1	0	0.00	0	0	0
9112	EASTERN	86	43.36	957	63549.57	665	24	2.68	148	4252.48	43
9122	EASTERN	16	7.02	211	30031.75	291	4	0.70	6	0	0
9132	CENTRAL	83	11.85	862	104642.06	1092	74	12.14	1412	24352.06	104
9142	CENTRAL	115	19.92	1635	265306.74	2545	42	4.69	487	12327.48	115
9152	CENTRAL	75	14.33	1209	505283.89	4617	44	3.65	550	240.53	1
9162	CENTRAL	60	14.01	785	464481.51	2277	11	2.58	340	493.23	5
9172	CENTRAL	49	14.93	1402	60595.29	1093	26	9.77	781	2743.67	17
9182	CENTRAL	170	67.86	794	25398.2	216	15	1.32	21	132.53	2
9192	CENTRAL	126	36.65	2108	429168.97	4304	18	3.16	272	14409.75	127
9202	EASTERN	73	34.47	661	76199.42	815	12	1.03	37	0	0
9212	EASTERN	169	83.27	1569	140969.98	1613	26	2.00	74	227.54	2
9222	EASTERN	69	23.10	904	25550.52	371	37	2.27	127	60.47	1
9232	CENTRAL	94	23.35	1610	101297.48	1644	22	2.19	217	0	0
9242	CENTRAL	61	15.07	727	367114.76	3190	46	9.18	914	36854.18	170
9252	CENTRAL	84	18.88	1343	97698.82	726	51	16.87	1047	66896.06	397
9292	CENTRAL	47	8.65	1166	102060.85	534	34	2.98	935	937.32	13
9312	CENTRAL	63	16.98	2073	291075.01	1529	9	1.11	89	0	0
9322	CENTRAL	35	7.69	1179	80995.34	718	14	0.75	241	4897.5	18
9332	CENTRAL	54	10.31	1084	21602.16	352	30	4.82	437	401	3
9342	CENTRAL	62	10.12	1167	70729.84	771	18	1.21	181	367.4	5
9352	CENTRAL	57	12.47	1407	54961.65	594	21	2.25	384	0	0
9362	CENTRAL	73	14.86	1550	358814.55	1846	20	0.81	160	11890.12	57
9372	CENTRAL	61	13.48	1421	52132.54	704	8	0.18	9	0	0
9382	CENTRAL	47	8.42	779	83852.12	1588	16	1.30	604	0	0
9402	CENTRAL	35	3.97	780	40928.55	402	39	1.68	1895	8150.77	32
9412	CENTRAL	54	8.24	845	119673.37	798	29	1.87	1283	897.65	13
9422	CENTRAL	33	4.44	568	31935.48	264	15	0.44	237	0	0
9462	CENTRAL	100	21.97	1877	49909.41	2532	52	14.20	1027	9768.38	37
9472	CENTRAL	53	14.76	1016	138883.31	941	59	25.98	1292	19163.77	109
9492	CENTRAL	44	6.36	545	73227.7	463	33	3.18	668	10515.87	41
9522	EASTERN	340	161.97	1656	685790.06	7424	24	4.42	48	6234.21	34
9532	CENTRAL	24	3.13	141	219627.53	1346	37	11.57	2367	66539.17	157
9562	CENTRAL	49	5.15	711	176686.43	2353	33	3.25	721	170.07	2
9572	CENTRAL	12	2.70	410	509743.97	3359	65	8.04	2552	4808.63	42
9582	CENTRAL	0	0.00	0	0	0	0	0.00	0	0	0

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
9052	CENTRAL	0	0	Yes	19.45	4.75	14.70	1879	62893.26	679	0.20	10.56
9062	CENTRAL	0	0	No	8.26	6.10	2.16	937	750318.5	2952	0.50	5.28
9082	CENTRAL	0	0	Yes	17.49	12.28	5.21	2633	186436.25	1040	0.50	11.01
9092	EASTERN	0	0	No	5.59	0.00	5.59	10	144	1	0.10	1.93
9112	EASTERN	2	0	No	47.26	2.68	44.57	1105	67802.05	708	0.10	5.49
9122	EASTERN	0	0	No	8.55	0.75	7.80	217	30031.75	291	0.50	7.30
9132	CENTRAL	0	0	Yes	26.82	12.57	14.25	2274	128994.12	1196	0.25	9.92
9142	CENTRAL	0	0	Yes	27.61	5.05	22.56	2122	283793.82	4784	0.25	10.22
9152	CENTRAL	0	0	No	20.95	3.65	17.30	1759	522764.51	6502	0.10	8.61
9162	CENTRAL	0	0	No	18.05	2.58	15.47	1125	662018.49	3407	0.10	5.30
9172	CENTRAL	0	0	No	26.71	9.77	16.94	2183	63338.96	1110	0.10	9.15
9182	CENTRAL	0	0	No	74.95	1.32	73.64	815	25530.73	218	0.25	6.22
9192	CENTRAL	0	0	Yes	44.63	3.16	41.47	2380	450879.22	6786	0.25	10.10
9202	EASTERN	1	0	Yes	38.69	1.03	37.66	698	76199.42	815	0.10	4.82
9212	EASTERN	4	0	No	86.88	2.00	84.88	1643	141197.52	1615	0.10	6.58
9222	EASTERN	1	0	Yes	29.59	2.27	27.32	1031	25610.99	372	0.10	8.62
9232	CENTRAL	1	0	No	26.99	2.19	24.80	1827	101297.48	1644	0.10	7.60
9242	CENTRAL	0	0	Yes	27.93	9.18	18.75	1641	403968.94	3360	1.00	11.40
9252	CENTRAL	0	0	Yes	39.29	16.87	22.41	2390	1271630.96	5976	0.50	9.88
9292	CENTRAL	1	0	No	13.35	2.98	10.37	2101	102998.17	547	0.10	8.38
9312	CENTRAL	0	0	No	19.63	1.11	18.52	2162	291075.01	1529	0.10	9.44
9322	CENTRAL	0	0	Yes	10.16	0.75	9.42	1420	85892.84	736	0.10	5.19
9332	CENTRAL	0	0	Yes	17.53	4.82	12.71	1521	27154.16	1870	0.10	7.99
9342	CENTRAL	0	0	No	13.68	1.21	12.46	1348	71097.24	776	0.10	7.02
9352	CENTRAL	0	0	Yes	17.27	2.25	15.02	1791	54961.65	594	0.10	7.91
9362	CENTRAL	0	0	Yes	17.66	1.00	16.66	1710	519334.47	4955	0.10	9.47
9372	CENTRAL	0	0	Yes	15.67	0.18	15.48	1430	55416.94	2132	0.10	7.07
9382	CENTRAL	0	0	Yes	11.27	1.30	9.97	1383	83852.12	1588	0.10	6.74
9402	CENTRAL	0	0	Yes	9.48	2.04	7.44	2675	49079.32	434	0.25	8.59
9412	CENTRAL	0	0	Yes	12.86	2.16	10.70	2128	120571.02	811	0.10	8.30
9422	CENTRAL	0	0	Yes	7.01	0.44	6.57	805	31935.48	264	0.10	4.39
9462	CENTRAL	0	0	No	37.65	14.20	23.45	2904	63255.39	5321	0.25	12.94
9472	CENTRAL	0	0	No	43.64	25.98	17.67	2308	223312.08	3340	0.25	11.72
9492	CENTRAL	0	0	Yes	12.21	3.36	8.85	1213	83743.57	504	0.50	10.41
9522	EASTERN	14	1	No	176.33	4.64	171.69	1704	692024.27	7458	0.10	6.62
9532	CENTRAL	0	0	Yes	17.08	11.57	5.51	2508	286166.7	1503	0.25	14.84
9562	CENTRAL	0	0	Yes	10.66	3.65	7.02	1432	177210.5	2532	0.50	10.43
9572	CENTRAL	0	0	Yes	13.05	8.44	4.61	2962	528889.6	4994	0.25	12.60
9582	CENTRAL	0	0	No	0.01	0.00	0.01	0	0	0	0.00	0.00

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(c) Number of Overhead Lateral Lines	(d) Number of Overhead Lateral Miles	(e) Number of Customers Served on Overhead Lateral Lines	(f) CMI for Overhead Lateral Lines	(g) CI for Overhead Lateral Lines	(h) Number of Underground Lateral Lines	(i) Number of Underground Lateral Miles	(j) Number of Customers Served on Underground Lateral Lines	(k) CMI for Underground Lateral Lines	(l) CI for Underground Lateral Lines
9592	EASTERN	124	112.56	750	139644.26	1582	33	15.13	322	11419.28	60
9602	CENTRAL	54	9.09	621	7053.06	63	27	8.38	946	2951.47	51
9612	CENTRAL	81	16.82	1561	115054.89	1314	34	3.46	700	11673.94	62
9622	CENTRAL	87	10.54	923	128603.53	916	27	2.14	420	114.6	1
9632	CENTRAL	36	4.35	217	34791.68	382	14	0.50	26	0	0
9672	CENTRAL	181	45.54	1919	83985.41	971	22	8.37	791	1997.1	25
9682	CENTRAL	46	10.38	409	74352.58	674	38	12.38	1015	13745.81	53
9692	CENTRAL	107	32.09	1758	157354.97	1629	22	2.89	540	0	0
9702	EASTERN	1	0.39	1	107.2	1	0	0.00	0	0	0
9792	CENTRAL	121	35.00	2492	78526.94	1208	25	7.69	834	2128.5	32
9802	EASTERN	25	15.16	185	41942.94	352	0	0.00	0	0	0
9812	CENTRAL	81	36.07	970	787080.12	2805	52	18.43	1689	4459.83	27
9828	CENTRAL	24	9.01	198	23787.47	184	4	0.24	7	0	0
9832	EASTERN	214	99.41	2104	162057.66	2447	25	1.42	86	0	0
9854	EASTERN	0	0.00	1	0	0	0	0.00	0	0	0
9912	EASTERN	0	1.48	5	0	0	2	0.08	6	0	0
15002	CENTRAL	0	0.00	2	0	0	0	0.00	0	0	0
15034	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
15044	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
15062	EASTERN	9	2.94	113	5530.53	39	3	10.80	73	912.3	9
15242	CENTRAL	3	0.16	7	0	0	15	8.30	444	652.67	2
15252	CENTRAL	4	0.32	10	18562.83	245	19	12.48	1139	60295.31	365
15262	CENTRAL	10	1.51	83	7347.9	39	15	3.96	868	0	0
15472	EASTERN	20	1.68	107	2316.84	26	8	1.62	236	0	0
15482	EASTERN	33	9.87	775	54011.2	543	29	5.63	808	16420.28	73
15492	EASTERN	0	0.00	0	0	0	0	0.00	0	0	0
15702	WESTERN	131	18.11	1985	134015.54	781	13	0.73	178	6268.17	110
15712	WESTERN	76	9.14	758	12257.16	160	23	1.81	50	0	0
15722	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
15752	WESTERN	0	0.00	0	0	0	0	0.00	0	0	0
15762	WESTERN	40	4.75	585	31979.55	311	27	1.77	61	1824	3
15772	WESTERN	35	5.30	652	15508.36	73	7	0.41	17	0	0

APPENDIX 3 FEEDER SPECIFIC DATA

(a) Feeder ID	(b) Sub Region	(m) Number of Automatic Line Sectionalizing Devices on the Lateral Lines	(n) Number of Automatic Line Sectionalizing Devices on the Feeder	(o) Whether the Feeder Circuit is Loop	(p) Total Length of the Feeder Circuit	(q) Length of Underground Portion of the Feeder Circuit	(r) Length of Overhead Portion of the Feeder Circuit	(s) Number of Customers Served by Overhead Feeders	(t) CMI for Overhead Feeders	(u) CI for Overhead Feeders	(v) Load Growth %	(w) Peak Load MVA
9592	EASTERN	8	2	No	135.54	15.13	120.41	1072	161363.54	1848	0.10	3.34
9602	CENTRAL	0	1	Yes	19.72	8.38	11.34	1567	10004.53	114	0.10	9.00
9612	CENTRAL	0	0	Yes	23.17	3.46	19.71	2261	126728.83	1376	0.10	10.60
9622	CENTRAL	0	0	Yes	15.99	2.14	13.86	1343	182286.13	1754	0.10	9.78
9632	CENTRAL	0	0	Yes	6.23	0.50	5.73	243	64375.68	554	0.10	6.47
9672	CENTRAL	0	0	No	57.17	8.37	48.80	2710	85982.51	996	0.50	13.24
9682	CENTRAL	0	0	No	25.20	12.38	12.82	1424	88098.39	727	0.50	12.17
9692	CENTRAL	0	0	Yes	35.86	2.89	32.97	2298	432491.37	5942	0.50	8.76
9702	EASTERN	0	0	No	3.41	0.00	3.41	1	303.2	2	0.10	2.96
9792	CENTRAL	1	0	No	47.11	7.69	39.42	3326	80655.44	1240	1.50	15.06
9802	EASTERN	3	0	No	15.29	0.00	15.29	185	41942.94	352	0.10	0.76
9812	CENTRAL	1	0	No	61.23	18.43	42.80	2659	791539.95	2832	1.00	13.51
9828	CENTRAL	0	0	No	11.30	0.24	11.06	205	23787.47	184	0.50	1.08
9832	EASTERN	6	0	No	103.37	1.42	101.95	2190	162057.66	2447	0.10	11.92
9854	EASTERN	0	0	No	0.05	0.00	0.05	1	0	0	0.00	0.00
9912	EASTERN	0	0	No	1.56	0.08	1.48	11	0	0	0.10	3.00
15002	CENTRAL	0	0	No	0.02	0.00	0.02	2	0	0	0.10	3.95
15034	WESTERN	0	0	No	0.28	0.28	0.00	0	0	0	0.00	3.65
15044	WESTERN	0	0	No	0.28	0.27	0.00	0	0	0	0.00	3.65
15062	EASTERN	0	0	No	19.99	10.86	9.12	186	15782.25	233	0.50	1.79
15242	CENTRAL	0	0	Yes	10.06	8.31	1.75	451	652.67	2	0.50	8.86
15252	CENTRAL	0	0	Yes	14.29	12.48	1.81	1149	78858.14	610	0.50	7.58
15262	CENTRAL	0	0	Yes	6.97	3.96	3.01	951	7347.9	39	0.50	7.73
15472	EASTERN	0	0	Yes	5.02	1.62	3.40	343	2316.84	26	1.00	1.64
15482	EASTERN	0	0	Yes	19.46	5.63	13.83	1583	70431.48	616	1.00	6.86
15492	EASTERN	0	0	No	0.02	0.00	0.02	0	0	0	0.00	0.00
15702	WESTERN	0	0	Yes	22.85	1.14	21.70	2163	140283.71	891	0.10	9.36
15712	WESTERN	0	0	Yes	14.18	1.96	12.22	808	12257.16	160	0.10	12.23
15722	WESTERN	0	0	No	0.05	0.00	0.05	0	0	0	0.00	0.00
15752	WESTERN	0	0	No	0.01	0.00	0.01	0	0	0	0.00	0.00
15762	WESTERN	0	0	Yes	10.38	2.50	7.87	646	33803.55	314	0.10	9.58
15772	WESTERN	0	0	Yes	8.68	0.41	8.27	669	15508.36	73	0.10	4.45

Report on Collaborative Research for Hurricane Hardening

Provided by

The Public Utility Research Center
University of Florida

To the

Utility Sponsor Steering Committee

February 2015

I. Introduction

The Florida Public Service Commission (FPSC) issued Order No. PSC-06-00351-PAA-EI on April 25, 2006 (Order 06-0351) directing each investor-owned electric utility (IOU) to establish a plan that increases collaborative research to further the development of storm resilient electric utility infrastructure and technologies that reduce storm restoration costs and outages to customers. This order directed IOUs to solicit participation from municipal electric utilities and rural electric cooperatives in addition to available educational and research organizations. As a means of accomplishing this task, the IOUs joined with the municipal electric utilities and rural electric cooperatives in the state (collectively referred to as the Project Sponsors) to form a Steering Committee of representatives from each utility and entered into a Memorandum of Understanding (MOU) with the University of Florida's Public Utility Research Center (PURC). This MOU was recently extended by the Research Collaboration Partners through December 31, 2015.

PURC manages the work flow and communications, develops work plans, serves as a subject matter expert, conducts research, facilitates the hiring of experts, coordinates with research vendors, advises the Project Sponsors, and provides reports for Project activities. The collaborative research has focused on undergrounding, vegetation management, hurricane-wind speeds at granular levels, and improved materials for distribution facilities.

This report provides an update on the activities of the Steering Committee since the previous report dated February 2014.

II. Undergrounding

The collaborative research on undergrounding has been focused on understanding the existing research on the economics and effects of hardening strategies, including undergrounding, so that informed decisions can be made about undergrounding policies and specific undergrounding projects.

The collaborative has refined the computer model developed by Quanta Technologies and there has been a collective effort to learn more about the function and functionality of the computer code. PURC and the Project Sponsors have worked to fill information gaps for model inputs and significant efforts have been invested in the area of forensics data collection. Since the state has not been affected by any hurricanes since the database software was completed, there is currently no data. Therefore, future efforts to refine the undergrounding model will occur when such data becomes available.

In addition, PURC has worked with doctoral and master's candidates in the University of Florida Department of Civil and Coastal Engineering to assess some of the inter-relationships between wind speed and other environmental factors on utility equipment damage. PURC has also been contacted by engineering researchers at the University of Wisconsin and North Carolina State University with an interest in the model, though no additional relationships have been established. In addition to universities, PURC was contacted by researchers at the Argonne National Laboratory who expressed interest in modeling the effects of storm damage. The researchers continue to develop a deterministic model, but did use many of the factors that the Collaborative have attempted to quantify. Every researcher that contacts PURC cites the model as the only non-proprietary model of its kind.

The research discussed in last year's report on the relationship between wind speed and rainfall is still under review by the engineering press. Further results of this and related research can likely be used to further refine the model.

III. Wind Data Collection

The Project Sponsors entered into a wind monitoring agreement with WeatherFlow, Inc., in 2007. Under the agreement, Florida Sponsors agreed to provide WeatherFlow with access to their properties and to allow WeatherFlow to install, maintain and operate portions of their wind monitoring network facilities on utility-owned properties under certain conditions in exchange for access to wind monitoring data generated by WeatherFlow's wind monitoring network in Florida. WeatherFlow's Florida wind monitoring network includes 50 permanent wind monitoring stations around the coast of Florida, including one or more stations located on utility-owned property. The wind monitoring agreement expired in early 2012; however, the wind, temperature, and barometric pressure data being collected at these stations is being made available to the Project Sponsors on a complimentary basis.

IV. Public Outreach

In last year's report we discussed the impact of Hurricane Sandy on greater interest in storm preparedness. PURC researchers discussed the collaborative effort in Florida with the engineering departments of the state regulators in Connecticut, New York, and New Jersey, and regulators in Jamaica, Grenada, and Curacao. While all of the regulators and policymakers showed great interest in the genesis of the collaborative effort, and the results of that effort, they have not, at this point, shown further interest in participating in the research effort.

PURC researchers continue to utilize the insight gained through the hurricane hardening research to contribute to the debate on undergrounding in the popular press, and reinforce the state of Florida as a thought leader in this area. On February 13, 2014 PURC Director of Energy Studies Ted Kury was asked to contribute an essay on CNN.com entitled "Burying power lines is not always the answer" where he discussed the economic trade-offs of undergrounding power lines. The essay also provided a link to an *Electricity Journal* article by Kury and Lynne Holt, another PURC researcher, which discusses Florida's cooperative approach and holds it up as a "best practice" in regulation. In addition, the October 2014 issue of *Costco Connection* featured a debate on whether utilities should be required to bury power lines, where Kury provided the "No" position.

V. Conclusion

In response to the FPSC's Order 06-0351, IOUs, municipal electric utilities, and rural electric cooperatives joined together and retained PURC to coordinate research on electric infrastructure hardening. The steering committee has taken steps to extend the research collaboration MOU so that the industry will be in a position to focus its research efforts on undergrounding research, granular wind research and vegetation management when significant storm activity affects the state.

Appendix 5

Cross Reference Index

Eight-Year Wooden Pole Inspection Programs

- ◆ Summary of the Inspection Program..... (Section 2.1)

Year of Review Wooden Pole Inspection Summary

- ◆ Total poles..... (Appendix 2, Column a)
- ◆ Poles Planned for inspection for the year of review..... (Appendix 2, Column b)
- ◆ Poles Inspected for the year of review..... (Appendix 2, Column c)
- ◆ Poles Failed Inspection for the year of review..... (Appendix 2, Column d)
 - Corrective action and how many poles were corrected..... (Appendix 2, Column g)
- ◆ The number of years completed in the 8-year cycle..... (Section 2.1)

Projected Next Year of Review Wooden Pole Inspection Summary

- ◆ Total Poles (should be the same as above)..... (Appendix 2, Column a)
- ◆ Total Number of Wooden Poles Inspected for 2006 (beginning of 8 year cycle) to the year of review..... (Appendix 2, Column l)
- ◆ Number of Wooden Poles Inspections planned for the next year of review..... (Appendix 2, Column k)
- ◆ Years Remaining in the 8-year cycle after the next year of review..... (Section 2.3)

Ten Initiatives

(1) Three-Year Vegetation Management Cycle for Distribution Circuits

- ◆ Summary of the vegetation management plans for the companies' feeder and lateral circuits..... (Section 3.1)

Vegetation Clearing From Feeder Circuits

- ◆ 1st Year of 3-year Cycle..... (Section 3.4)
- ◆ Total Feeder Miles..... (Section 3.4)
- ◆ Miles Trimmed for each year of the cycle..... (Section 3.4)
- ◆ Total Feeder Miles Trimmed..... (Section 3.4)

Vegetation Clearing From Lateral Circuits

- ◆ Number of years in cycle..... (Section 3.4)
- ◆ 1st year of cycle..... (Section 3.4)
- ◆ Total Lateral miles..... (Section 3.4)
- ◆ Miles Trimmed for each year of the cycle..... (Section 3.4)
- ◆ Total Lateral Miles Trimmed..... (Section 3.4)

(2) Audit of Joint Use Agreements

- ◆ Summary of the Joint Use Agreements for poles and a summary of the monitoring of the strength and loading requirements for those poles..... (Section 2.2, DCN 03686-10 in Docket No. 100265-EI)

(3) Six-Year Transmission Inspections

- ◆ Summary of the six-year transmission structures, substations, and all hardware associated with these facilities inspections..... (Section 5.0)

(4) Hardening of Existing Transmission Structures

- ◆ Summary of the Hardening of Existing Transmission Structures..... (Section 6.0)

Appendix 5

Cross Reference Index

(5) Transmission and Distribution Geographic Information System

- ◆ Summary of the company's transmission and distribution geographic information system..... (Section 8.0)

(6) Post-Storm Data Collection and Forensic Analysis

- ◆ Summary of the company's post-storm data collection and forensic analysis..... (Section 9.1)

(7) Collection of Detailed Outage Data Differentiating Between the Reliability Performance of Overhead and Underground Systems

- ◆ Summary of the collection of detailed outage data differentiating between the reliability performance of overhead and underground systems..... (Section 10.0)

(8) Increased Utility Coordination with Local Governments

- ◆ Summary of the utilities increased coordination with the Local Governments..... (Section 11.0)

(9) Collaborative Research on Effects of Hurricane Winds and Storm Surge

- ◆ Summary of the continuing collaborative research with PURC on the effects of hurricane winds and storm surge..... (Appendix 4)

(10) A Natural Disaster Preparedness and Recovery Program

- ◆ Summary of the company's Natural Disaster Preparedness and Recovery Program..... (Section 13.0)

Reliability Performance

- ◆ Summary of the company's overall reliability performance..... (Section 15.1)

Actual Distribution Service Reliability

- ◆ Provide Form PSC/ECR 102-1(a) (8/06) entitled "Causes of Outages Events – Actual"..... (Appendix 1)
- ◆ Provide Form PSC/ECR 102-2(a) (8/06) entitled "Three Percent Feeder list – Actual"..... (Appendix 1)
- ◆ Provide Form PSC/ECR 102-3(a) (8/06) entitled "System Reliability Indices – Actual"..... (Appendix 1)
- ◆ Provide Actual Customer Minutes of Interruption (CMI) and Customer Interruptions (CI)..... (Appendix 1)
- ◆ Provide Documented Exclusion (CMI and CI) for the follow:
 - Planned Outages..... (Appendix 1)
 - Named Storm Outages..... (Section 15.7)
 - Tornados..... (Section 15.7)
 - Ice on Lines..... (Not Applicable)
 - Planned Load Management Event..... (Not Applicable)
 - Customer Request..... (Not Available)
 - Fires..... (Not Applicable)
 - Extreme Weather Event..... (Section 15.7)
 - Other Distribution..... (Section 15.7)
 - Other Transmission and Generation..... (Appendix)
- ◆ Summary of the Documented Exclusion (CMI and CI) with dates of what happened..... (Section 15.7)

Appendix 5

Cross Reference Index

Adjusted Distribution Service Reliability

- ◆ PSC Chart entitled “Actual Data: Customer Minutes of Interruption (CMI), Customer Interruptions (CI) and Documented Exclusions..... (Appendix 1)
- ◆ Provide Form PSC/ECR 102-1(b) (8/06) entitled “Causes of Outages Events – Adjusted”..... (Appendix 1)
- ◆ Provide Form PSC/ECR 102-2(b) (8/06) entitled “Three Percent Feeder list – Adjusted”..... (Appendix 1)
- ◆ Provide Form PSC/ECR 102-3(b) (8/06) entitled “System Reliability Indices – Adjusted”..... (Appendix 1)
- ◆ Summary of SAIDI explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem..... (Section 15.1 and 15.3)
- ◆ Summary of SAIFI explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem..... (Section 15.1 and 15.3)
- ◆ Summary of CAIDI explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem..... (Section 15.1 and 15.3)
- ◆ Summary of MAIFIe explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem... (Section 15.1 and 15.3)
- ◆ Summary of CEMI5 explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem... (Section 15.1 and 15.3)
- ◆ Summary of L-Bar explaining any improvements or declines, plus if a region has a pattern of declining, explain what is being implementing to correct the problem..... (Section 15.1 and 15.3)
- ◆ Summary of the Companies Three Percent Feeder Report, plus if a feeder has a pattern of being on the list, explain what is being implementing to correct the problem..... (Section 15.3)
- ◆ Summary of the Top Ten Outage Cause, plus a cause has a pattern of being on the list, explain what is being implementing to correct the problem..... (Section 15.1, 15.3, 15.9 and Appendix 1)
- ◆ Summary of the Company’s Reliability Related Complaints, plus the number complaints are raising, explain what is being implementing to correct the problem..... (Section 15.1 and 15.11)