



Christopher T. Wright
Senior Attorney – Regulatory
Florida Power & Light Company
700 Universe Blvd
Juno Beach, FL 33408-0420
Phone: (561) 691-7144
E-mail: Christopher.Wright@fpl.com
Florida Authorized House Counsel;
Admitted in Pennsylvania

March 1, 2022

VIA ELECTRONIC FILING

Mr. Adam J. Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

**Re: Docket No. 20220000-OT
2021 Annual Reliability Reports for
Florida Power & Light Company and Gulf Power Company**

Dear Mr. Teitzman:


Pursuant to Rule 25-6.0455, F.A.C., enclosed for filing in the above referenced docket, please find the following:

- Florida Power & Light Company 2021 Annual Distribution Reliability Report
- Gulf Power Company 2021 Annual Distribution Reliability Report

On January 1, 2021, Florida Power & Light Company (FPL) and Gulf Power Company (Gulf) were legally merged, with FPL as the surviving entity. Although legally merged, FPL and Gulf operated as separate ratemaking entities during 2021. Effective January 1, 2022, the rates and tariffs of Gulf and FPL were consolidated and unified, all former Gulf customers became FPL customers, and Gulf ceased to exist as a separate regulated entity. However, because the information included in the attached reports pertains to 2021 when FPL and Gulf existed as separate ratemaking entities, FPL is herein providing separate annual reliability reports for FPL and the former Gulf.

If you or your staff have any question regarding this filing, please contact me at (561) 691-7144.

Respectfully submitted,



Christopher T. Wright
Authorized House Counsel No. 1007055

Enclosures

cc: Tom Ballinger
Penelope Buys

Florida Power & Light Company
700 Universe Boulevard, Juno Beach, FL 33408



Florida Power & Light Company

2021 Annual Reliability Report

March 1, 2022

Table of Contents

	<u>Page</u>
<u>Executive Summary</u>	3
<u>Reliability</u>	4
<u>Appendix</u>	32
Reconciliation of Adjusted to Actual Reliability Indices	
Distribution Excluded Extreme Weather Events	
Distribution Excluded Outage Events	
Feeder Specific Data and Attached Laterals	
Transmission and Substation Outage Events	

EXECUTIVE SUMMARY – FPL’s MARCH 1, 2022 FILING

Florida Power & Light Company (“FPL” or the “Company”) herein submits its Annual Reliability Report for the preceding calendar year (2021) pursuant to Rule 25-6.0455(1), F.A.C. In 2021, FPL achieved its best-ever Transmission and Distribution (“T&D”) System performance results for multiple reliability indices, including the System Average Interruption Duration Index (“SAIDI”), the System Average Interruption Frequency Index (“SAIFI”), and the Momentary Average Interruption Frequency Index events (“MAIFIE”). Additionally, FPL continued to invest in and take significant steps to strengthen and modernize its electric infrastructure to reduce day-to-day outages and restoration times. In 2022, FPL plans to continue these efforts as part of its proven reliability programs.

RELIABILITY

Summary – Reliability

Total FPL System (Distribution and Transmission) – Overall reliability is best gauged by SAIDI, the most relevant and best overall reliability indicator because it encompasses two other standard industry performance metrics for reliability: System Average Interruption Frequency Index (“SAIFI”) and Customer Average Interruption Duration Index (“CAIDI”). In 2021, FPL continued to provide excellent overall reliability for its customers, achieving a best-ever total FPL T&D system adjusted SAIDI of 45.6 minutes (2020 – 48.5 minutes). Additionally, FPL achieved a best-ever FPL T&D system adjusted Momentary Average Interruption Frequency Index events (“MAIFle”) of 3.0 momentary events (2020 – 3.2 momentary events).

Distribution – FPL’s 2021 overall adjusted distribution reliability results were: SAIDI, a best-ever 43.8 minutes (2020 – 47.3 minutes); SAIFI, a best-ever 0.70 interruptions per customer (2020 – 0.76 interruptions); CAIDI, 62.5 minutes (2020 – 62.4 minutes) and a best-ever adjusted MAIFle, 2.3 momentary events (2020 – 2.6 momentary events).

Transmission – In 2021, FPL’s Transmission/Substation adjusted reliability results were: SAIDI, 1.8 minutes (2020 – 1.2 minutes); SAIFI, 0.12 interruptions per customer (2020 – 0.11 interruptions); and MAIFle, 0.7 momentary events (2020 – 0.6 momentary events).

Distribution Reliability

GENERAL

1. Discuss overall performance absent adjustments (Form 102).

FPL's overall unadjusted distribution reliability in 2021, as measured by SAIDI, was 56.69 minutes. This unadjusted performance includes approximately 12.85 minutes associated with allowed exclusions (e.g., tornados, named storms/hurricanes, and planned interruptions).

2. Describe the level of detailed reliability data the Company tracks.

FPL tracks the following reliability data associated with each individual interruption: customers affected, minutes interrupted, cause of outage, percentage of customers partially restored, device affected by interruption, and location of the device. All of the interruption data is compiled to calculate reliability indices which are tracked throughout the year. The reliability indices that FPL tracks include the following: SAIDI, SAIFI, CAIDI, MAIFI, MAIFle, L-Bar, CEMI-3, CEMI-5, CEMI-8, CEMM-15, CEMM-25, and Customer Momentary Experience ("CME").

3. Describe Company efforts to increase critical review of detailed reliability data.

The Company generates and reviews daily reports that provide detailed reliability information, such as the previous day's interruptions by device, month-to-date reliability indices, and year-to-date reliability indices. FPL's management utilizes the information in conducting daily in-depth reviews of key reliability data to identify lessons learned and areas for improvement. This review also includes an assessment of upcoming weather and potential impacts, operational risks, and a final review of the daily operations plan. FPL's management team also conducts monthly reliability reviews of the programs, objectives, and actual performance vs. the plan. On an

annual basis, FPL reviews its reliability performance and outage causes to implement lessons learned and further improve its reliability programs. With the aid of advanced statistical applications, such as Minitab and Six Sigma analysis, FPL performs statistical analyses to identify reliability trends, root causes, and measure program benefits.

4. Describe the process used by your company to identify and select the level of detailed reliability data.

FPL's reliability data detail has been developed over the years based on industry practices, internal needs, as well as external requirements (e.g., requirements of regulators).

5. Discuss adjustments:

Generation Events – None.

Transmission Events - See Appendix.

Distribution Events - See response to Distribution Reliability Item Nos. 11 & 13.

Extreme Weather - See response to Distribution Reliability Item Nos. 7 & 10.

6. Discuss adjusted performance.

Distribution - See summary at the beginning of this reliability section as well as the response to Item No. 1 above.

EXTREME WEATHER

7. Include in the discussion, the type of weather event, strength (wind speeds/surge-flood levels), locations affected and source of meteorological information.

Extreme Weather Events	**Strength (wind speeds/surge-flood levels)	Landfall Location	Management Regions Affected
Tornado	EF0	North Florida was impacted Feb 15	Affected: North Florida Supported: Central Florida
Tornado	EF1	Manasota and Panama City were impacted April 10	Affected: Manasota and Panama City Supported: Boca Raton, West Palm, Brevard, North Florida, Central Florida, Treasure Coast, Naples and Toledo Blade.
Tornado	EF2	Manasota and Panama City were impacted April 11	Affected: Mansota and Panama City Supported: Boca Raton, West Palm, Brevard, North Florida and Treasure Coast.
Claudette	TS	Central Florida and North Florida were impacted June 19	Affected: Central Florida and North Florida
Claudette	TD	All FPL management areas except Manasota, Toledo Blade and Naples were impacted June 20	Affected: Boca Raton, West Palm, Brevard, Central Florida, North Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Central Broward, North Broward, and South Broward
Elsa	TS	All FPL management areas except North Florida were impacted July 5	Affected: Boca Raton, West Palm, Brevard, Central Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Naples, Toledo Blade, Central Broward, North Broward and South Broward. Supported: North Florida
Elsa	H	All FPL management areas except Central Broward were impacted July 6	Affected: Boca Raton, West Palm, Brevard, Central Florida, North Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Naples, Toledo Blade, North Broward and South Broward.
Elsa	H	Broward, Brevard, Central Florida, Manasota, Naples, North Florida, Toledo Blade, Tresure Coast, Boca Raton and West Palm were impacted July 7	Affected: Broward, Brevard, Central Florida, Manasota, Naples, North Florida, Toledo Blade, Tresure Coast, Boca Raton and West Palm. Supported: Central Dade, South Dade, West Dade, North Dade, South Broward, North Broward, and Central Broward.
Elsa	TS	North Florida was impacted July 8	Impacted: North Florida Supported: Central Florida
Tornado	EF0	Boca Raton August 7	Affected: Boca Raton
Fred	TD	All FPL management areas except North Florida were impacted August 13	Affected: Boca Raton, West Palm, Brevard, Central Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Naples, Toledo Blade, Central Broward, North Broward and South Broward.
Fred	TS	All FPL management areas were impacted August 14 -16	Affected: Boca Raton, West Palm, Brevard, Central Florida, Treasure Coast, Central Dade, North Dade, North Florida, South Dade, West Dade, Manasota, Naples, Toledo Blade, Central Broward, North Broward and South Broward.
Fred	TS	Central Florida and North Florida were impacted August 17	Affected: Central Florida, and North Florida. Supported: Boca Raton, Brevard, Treasure Coast and West Broward.

Extreme Weather Events	**Strength (wind speeds/surge-flood levels)	Landfall Location	Management Regions Affected
Ida	H	Central Dade, Manasota, Naples, South Dade, Toledo Blade and West Dade were impacted August 28	Affected: Central Dade, Manasota, Naples, South Dade, Toledo Blade and West Dade.
Ida	H	Manasota, Naples, and Toledo Blade were impacted August 29	Affected: Manasota, Naples, and Toledo Blade.
Ida	TD	North Florida August 31	Affected: North Florida
Ida	TD	All FPL management areas were impacted September 1	Affected: Boca Raton, West Palm, Brevard, Central Florida, North Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Naples, Toledo Blade, Central Broward, North Broward and South Broward.
Ida	TD	All FPL management areas were impacted September 2	Affected: Boca Raton, West Palm, Brevard, Central Florida, North Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Naples, Toledo Blade, Central Broward, North Broward, and South Broward.
Mindy	TS	Brevard, Central Florida, Manasota, North Florida, Toledo Blade and Treasure Coast were impacted September 8	Affected: Brevard, Central Florida, Manasota, North Florida, Toledo Blade and Treasure Coast.
Mindy	TS	Boca Raton, Brevard, Central Florida, Manasota, North Florida, Treasure Coast, Toledo Blade and West Palm were impacted September 9	Affected: Boca Raton, Brevard, Central Florida, Manasota, North Florida, Treasure Coast, Toledo Blade and West Palm.
Tornado	EF0	Manasota October 28	Affected: Manasota Supported: Toledo Blade
Tornado	EF1	North Florida December 8	Affected: North Florida
Tornado	EF1	Naples December 21	Affected: Naples Supported: Boca Raton, West Palm, Brevard, Central Florida, North Florida, Treasure Coast, Central Dade, North Dade, South Dade, West Dade, Manasota, Toledo Blade, Central Broward, North Broward and South Broward.

Data Source: <http://www.spc.noaa.gov/climo/reports>
<http://www.nhc.noaa.gov>

** Utilizing the Saffir-Simpson Hurricane Wind Scale from the National Hurricane Center for a tropical cyclone, we have broken down the strength / wind speeds into the following categories:

- Tropical Depression ("TD") with sustained wind speed of 38 mph or less.
- Tropical Storm ("TS") with sustained wind speed of 39-73 mph
- Hurricane ("H") with sustained wind speed of 74-110 mph
- Major Hurricane ("M") with sustained wind speed of 111-157 mph or higher

8. Describe the Company's efforts to avoid or minimize, in terms of costs incurred and outage duration, any similar events in the future.

FPL maintains a philosophy of continuous improvement. As a part of that philosophy, we gather information and lessons learned from each extreme weather event, maintain awareness of challenges that may be on the horizon, and seek opportunities to leverage relationships and technology to continue to minimize the cost and duration of restoration events that may affect the Company's system. Some examples of this include:

- Reviewing and updating pandemic processes and guidelines based on Centers for Disease Control and Prevention ("CDC") guidance to ensure the safety of employees responding to events and maintain efficiency in on-boarding external resources.
- Continued technology improvements including implementing a new application to streamline resource management and billing processes, as well as improve communications during an event.
- Expanding the use of drones and investigating opportunities such as satellite technology to assist with patrols and infrastructure assessments immediately after the weather has cleared.
- Yearly review of contracts and rates to ensure the most cost-effective resources are available prior to storm season.
- Implementing FPL's Storm Protection Plan ("SPP") as a systematic approach to achieve the legislative objectives of Section 366.96, F.S., to protect and strengthen T&D infrastructure from extreme weather conditions, reduce outage times and restoration costs, and improve overall service reliability to customers.

9. If the method of deriving the weather exclusion is different from the method used for 2020, please explain the changes and provide the CMI and CI for 2021 using the prior method.

No changes were made to FPL's exclusion methodology.

10. Provide the 2021 service reliability data for each extreme weather outage event that is excluded from your Company’s 2021 Annual Distribution Reliability Report pursuant to Rule 25-6.0455.

The following data is provided in the Appendix:

- A) Causation
- B) Date
- C) CI
- D) CMI
- E) L-Bar

OTHER DISTRIBUTION ADJUSTMENTS

11. Discuss the causation of each type of distribution event that resulted in customer outages.

Causation	# of Outages	CI	CMI	LBAR
Planned Interruptions	42,798	320,626	23,604,747	74

12. Describe the Company’s efforts to avoid or minimize any similar events in the future in terms of the level of costs incurred and outage duration.

FPL continually evaluates the need for planned crew and customer-requested outages by determining if there are alternative work methods that could minimize or prevent such an outage. If an outage is not preventable, FPL works with customers to schedule necessary outages during times that are more convenient for them (e.g., nights and weekends).

13. Provide the 2021 service reliability data for each distribution outage event that is excluded from your Company’s 2021 Annual Distribution Reliability Report pursuant to Rule 25-6.0455.

The following data is provided in the Appendix:

- A) Causation
- B) Date
- C) CMI
- D) CI
- E) L-Bar

2021 ADJUSTED RELIABILITY CAUSES OF OUTAGE EVENTS

14. Five-year patterns/trends in outage causation for each of the top causes of outage events, including the frequency, duration, restoration time, cost incurred to restore service, remediation programs, and remediation program costs.

Rank	PSC Cause Group	System Avg. Interruption (SAIDI)					Frequency (SAIFI)					Duration (CAIDI)				
		2017	2018	2019	2020	2021	2017	2018	2019	2020	2021	2017	2018	2019	2020	2021
1	Defective Equipment	23.8	23.5	21.3	22.0	19.4	0.39	0.36	0.30	0.32	0.27	61.7	64.7	71.3	69.8	72.6
2	Vegetation	9.9	8.2	8.9	9.4	8.6	0.10	0.08	0.08	0.08	0.07	99.4	105.9	106.1	117.9	124.5
3	Other Weather	4.5	5.2	4.1	3.3	3.2	0.06	0.07	0.05	0.04	0.04	70.2	71.7	78.4	90.2	83.3
4	All Other Causes	3.2	3.4	3.4	2.8	2.8	0.10	0.12	0.11	0.10	0.10	30.4	28.6	30.1	28.5	29.2
5	Unknown	3.4	3.1	2.4	2.3	2.2	0.10	0.10	0.10	0.08	0.07	32.1	30.3	23.8	28.0	31.7
6	Animals	2.6	2.3	2.6	1.9	2.2	0.04	0.04	0.05	0.03	0.04	59.8	56.7	57.4	62.3	62.0
7	Vehicle	2.9	2.7	2.3	2.2	2.2	0.04	0.03	0.03	0.03	0.03	71.6	79.9	72.8	76.5	67.9
8	Other	2.5	2.5	2.3	1.9	1.8	0.04	0.05	0.06	0.07	0.08	64.5	51.4	36.0	28.3	23.4
9	Lightning	1.6	2.3	2.0	1.5	1.3	0.02	0.03	0.03	0.02	0.01	62.8	81.5	77.2	73.8	101.8
	System Total	54.3	53.2	49.4	47.3	43.8	0.90	0.89	0.82	0.76	0.70	60.0	60.0	60.3	62.4	62.5

See remediation programs/budget levels in FPL’s response to Distribution Reliability Item No. 16. Costs incurred to restore service by cause are not specifically tracked.

15. The process used to identify and select the actions to improve the performance in each of the top causes of outages.

Annually, FPL evaluates its current reliability remediation programs and verifies the programs’ needs. In addition, if necessary, FPL proposes new reliability remediation programs to improve its reliability performance, concentrating on the highest cause codes and those cause codes that have shown trends needing attention.

16. 2022 activities and budget levels addressing each of the top causes of service outages (programs > \$1.0 Million).

Program*	Program Description	Impact on which Cause Codes	2022 Budget**
Distribution Automation/ Smart Grid	Install and maintain Distribution Automation Devices. This Program includes Automated Feeder Switches, Automated Lateral Switches and Fault Current Indicators. These devices will help mitigate the effects of feeder and lateral interruption by clearing temporary faults, decreasing voltage sags, decreasing field visits for replacing blown fuses, isolating problematic areas and decreasing restoration time; making it a more reliable system.	All	\$ 187.1
System Expansion	Provide the necessary feeder capacity to serve all customers during normal and emergency periods, and install the infrastructure necessary to support system contingency.	All	\$ 118.9
Cable Lateral	Reduce the number of direct buried lateral cable failures and reduce customer interruptions.	Equipment Failure	\$ 31.4
Auto TX Switch (ATS)	Reduce the number of permanent outages caused by temporary faults on overhead transformer equipment	Animal, Unknown, Vegetation, Weather	\$ 27.8
Handhole Inspections / Pad-mounted Transformers	Inspection/Remediation of non-compliant conditions. The purpose of this program is to maintain pad-mount transformer security.	Equipment Failure	\$ 21.4
Cable Feeder	Reduce the number of direct buried feeder cable failures and reduce customer interruptions.	Equipment Failure	\$ 19.2
Customer Impact	Projects targeted to improve reliability for specific customers or geographic areas	Equipment Failure	\$ 16.9
Switch Cabinet Replacements and Auto Tx	Inspection/Remediation/Replacement of deteriorating Switch Cabinet conditions (rust, etc.)	Animal, Unknown, Vegetation, Weather	\$ 10.0
Frequency Feeder Repairs	Target overhead/hybrid feeders with the highest customer interruptions, and conduct thermo and visual assessment to identify what equipment and other findings need to be repaired.	All	\$ 9.5
Submarine Cable	Reduce the number of Submarine feeder cable failures and reduce customer interruptions.	Equipment Failure	\$ 7.3
RA Switch Replacement	This program will proactively replace RA switches in order to enhance system operations and reliability.	Equipment Failure	\$ 7.2
CEMI Program	Conducts trigger based post outage investigations on feeders meeting the program criteria and conducts thermo and visual assessments to identify what equipment and other findings need to be repaired.	All	\$ 6.9
Open Wire Secondary	Identification and removal of overhead open wire secondary lines.	Vegetation, Unknown	\$ 6.0
Vault Inspections and repairs (not including RA Switches)	Inspect vaults and Powell-Esco Switches. Program will mitigate vault interruptions and will help to identify any issues that need to be addressed before an interruption occurs.	Equipment Failure	\$ 4.5
Feeder Ownership Immediate Response Repairs	Assess overhead/hybrid feeders visually and make repairs to findings that could cause immediate outages	All	\$ 3.8
OCR Replacement	Replace Oil Circuit Reclosers with Electronic Reclosers	Equipment Failures	\$ 3.0
Reliability -Capital Projects	Capital intensive projects to increase overall reliability	All	\$ 2.7
VAR Management (installations and maintenance)	Install, relocate, maintain, and control distribution capacitor banks. This program will help maintain or improve power factor performance, improve system efficiency, reliability, and quality of service voltage to our customers.	Remaining Causes	\$ 2.3
Outlier Devices	Identifying and correcting laterals experiencing the highest number of customers interrupted and/or laterals with difficult restoration conditions.	All	\$ 1.7
OH Equipment Upgrade	Upgrade specific feeder equipment to newest standard to improve reliability	Equipment Failures	\$ 1.1

* Programs ≥ \$1 million

** Effective January 1, 2022, the operations, rates, and tariffs of the former Gulf Power Company (“Gulf”) and FPL were consolidated and unified, all former Gulf customers became FPL customers, and Gulf ceased to exist as a separate regulated entity. As a result, this column includes the consolidated 2022 budget for the FPL and former Gulf Service areas. This column also includes costs associated with the SPP.

THREE-PERCENT FEEDER LIST

17. Identify whether any feeders appearing on the three-percent list more than once within a consecutive five-year period and any actions implemented to improve feeder performance.

See FPL's three-percent list in the Appendix.

See FPL's responses to Distribution Reliability Question numbers 16 and 18 for actions that FPL has taken to address these feeders.

18. Process used to identify and select the actions to improve the performance of feeders on the three-percent feeder list, if any.

FPL evaluates feeder performance on a daily basis and has addressed feeders on this list through its "Frequency Feeder" program and one or more of its other reliability programs.

The objective of FPL's Frequency Feeder program is to reduce the number of customers experiencing multiple interruptions and multiple momentary interruptions by identifying and correcting feeders experiencing the highest number of events and/or customers interrupted. The initiative may strengthen feeders up to and including extreme wind loading standards for additional overall reliability improvement.

19. 2022 activities and budget levels directed at improving feeder performance.

See response to Distribution Reliability Item No. 16.

REGIONAL RELIABILITY INDICES

20. Five-Year patterns/trends in each region’s reliability for each index and on any overall basis.

Annual SAIDI performance for the Distribution unit and its regions

Data	Region	2017	2018	2019	2020	2021
SAIDI	Boca Raton (BR)	45.1	49.5	42.0	41.2	35.5
	Brevard (BV)	56.1	43.7	44.3	49.2	46.0
	Central Broward (CB)	60.7	59.5	64.6	53.8	52.9
	Central Dade (CD)	41.8	41.7	53.8	41.2	46.4
	Central Florida (CF)	46.2	47.2	40.2	41.0	42.8
	Manasota (MS)	50.2	52.4	34.1	36.8	36.5
	Naples (NA)	63.9	55.1	50.1	45.1	38.7
	North Broward (NB)	37.6	38.9	37.3	31.1	31.4
	North Dade (ND)	69.1	69.5	64.4	58.4	59.6
	North Florida (NF)	64.5	73.0	59.9	61.7	54.5
	South Broward (SB)	42.3	50.9	50.7	45.9	35.1
	South Dade (SD)	63.2	58.7	55.7	54.7	58.0
	Toledo Blade (TB)	77.2	69.7	56.3	50.3	53.0
	Treasure Coast (TC)	65.6	47.2	53.7	52.1	44.6
	West Palm (WB)	45.8	46.1	40.8	59.3	35.6
	West Dade (WD)	53.8	67.2	60.6	48.4	49.5
	All FPL	54.3	53.2	49.4	47.3	43.8

Annual SAIFI performance for the Distribution unit and its regions

Data	Region	2017	2018	2019	2020	2021
SAIFI	BR	0.89	1.00	0.80	0.73	0.66
	BV	1.04	0.87	0.81	0.88	0.82
	CB	1.11	0.90	0.88	0.75	0.80
	CD	0.79	0.77	0.78	0.57	0.67
	CF	0.85	0.84	0.77	0.76	0.71
	MS	0.77	0.73	0.58	0.64	0.54
	NA	0.92	0.89	0.82	0.69	0.72
	NB	0.65	0.66	0.61	0.53	0.57
	ND	0.96	0.94	1.00	0.78	0.81
	NF	1.04	1.25	1.04	1.07	0.87
	SB	0.79	0.90	0.85	0.73	0.55
	SD	0.79	0.83	0.74	0.79	0.80
	TB	1.12	1.01	0.88	0.79	0.86
	TC	1.11	0.81	0.97	0.85	0.65
	WB	0.96	0.97	0.83	0.96	0.58
	WD	0.85	1.03	0.96	0.77	0.72
	All FPL	0.90	0.89	0.82	0.76	0.70

Annual CAIDI performance for the Distribution unit and its regions

Data	Region	2017	2018	2019	2020	2021
CAIDI	BR	50.4	49.4	52.4	56.3	53.4
	BV	53.9	50.2	54.6	55.8	56.1
	CB	54.6	66.1	73.7	71.8	66.1
	CD	53.2	54.5	68.8	72.2	69.4
	CF	54.4	56.1	52.5	53.7	60.4
	MS	65.0	71.9	59.1	57.4	67.3
	NA	69.2	61.8	61.3	65.8	53.6
	NB	58.0	59.2	61.1	58.3	54.8
	ND	71.8	74.2	64.4	74.5	73.3
	NF	62.2	58.2	57.6	57.7	62.5
	SB	53.8	56.3	59.6	63.2	63.4
	SD	80.0	70.7	75.2	69.3	72.7
	TB	69.0	68.8	64.3	63.5	61.5
	TC	59.0	58.7	55.2	61.2	60.3
	WB	47.5	47.7	48.9	61.5	61.9
	WD	63.4	65.2	63.0	62.9	68.5
	AI FPL	60.0	60.0	60.3	62.4	62.5

Annual MAIFe performance for the Distribution unit and its regions

Data	Region	2017	2018	2019	2020	2021
MAIFe	BR	4.5	4.2	3.7	3.2	2.7
	BV	4.0	3.6	3.1	2.3	2.5
	CB	6.1	4.3	3.3	2.6	2.0
	CD	3.5	3.0	2.8	2.3	2.1
	CF	3.4	3.8	2.8	2.3	2.3
	MS	3.8	3.7	2.4	1.8	1.7
	NA	6.2	4.9	3.4	2.5	2.3
	NB	3.2	3.5	2.5	2.0	1.6
	ND	3.5	3.2	2.8	2.4	1.9
	NF	4.2	3.2	2.8	2.3	2.2
	SB	4.1	4.6	3.5	2.9	2.5
	SD	4.3	3.9	3.4	2.8	2.8
	TB	4.5	5.2	3.4	2.9	2.7
	TC	4.0	3.6	3.2	3.1	2.1
	WB	4.5	4.8	4.2	3.1	2.4
	WD	4.2	4.3	3.7	2.8	3.2
	AI FPL	4.3	4.0	3.2	2.6	2.3

Annual Cust >5 performance for the Distribution unit and its regions

Data	Region	2017	2018	2019	2020	2021
# Cust >5	BR	0.4%	0.9%	1.0%	0.2%	0.1%
	BV	0.9%	0.3%	0.2%	0.4%	0.8%
	CB	0.7%	0.2%	0.5%	0.2%	0.2%
	CD	0.8%	0.7%	0.1%	0.2%	0.2%
	CF	0.2%	0.8%	0.4%	0.4%	0.2%
	MS	0.3%	0.3%	0.3%	0.2%	0.1%
	NA	0.3%	0.3%	1.0%	0.4%	0.2%
	NB	0.1%	0.5%	0.2%	0.1%	0.4%
	ND	1.2%	0.7%	1.0%	0.4%	0.5%
	NF	0.7%	1.4%	0.7%	0.7%	0.4%
	SB	0.6%	0.2%	0.3%	0.2%	0.2%
	SD	0.7%	0.3%	0.7%	0.1%	0.4%
	TB	1.5%	1.9%	0.7%	0.5%	0.5%
	TC	1.7%	0.5%	1.2%	0.6%	0.3%
	WB	2.0%	0.6%	0.3%	0.5%	0.3%
	WD	0.7%	0.5%	0.6%	0.6%	0.3%
	All FPL	0.8%	0.6%	0.6%	0.3%	0.3%

21. The process used to identify and select actions to improve the regional reliability trends.

See FPL’s response to Distribution Reliability Item No. 3.

22. Discuss any 2022 projected activities and budget levels directed at improving regional reliability performance.

See FPL’s response to Distribution Reliability Item No. 16. Each program listed addresses equipment and devices at the management area level.

OVERHEAD – UNDERGROUND RELIABILITY

23. Describe the five-year patterns/trends in reliability performance of underground systems vs. overhead systems.

The majority of FPL's customers are fed from circuits that are a hybrid of both overhead ("OH") and underground ("UG") systems. The methodology used to classify a customer as OH is defined as those customers served by a feeder with combined feeder and lateral OH miles greater than or equal to 95% of the total primary miles. Then, to classify a customer as UG, customers must be served by a feeder with combined feeder and lateral UG miles greater than or equal to 95% of the total primary miles. The balance of customers is classified as Hybrid. According to this methodology, FPL has 104 OH feeders, 587 UG feeders, with the remaining 2,826 feeders classified as hybrid. This methodology was applied for FPL's responses to Distribution Reliability Question Nos. 23 and 26.

Five years' reliability performance of UG, hybrid and OH systems

Data	Year	Hybrid	OH	UG	ALL
SAIDI	2017	55.5	89.6	17.7	54.3
	2018	54.2	89.0	21.2	53.2
	2019	49.4	87.4	31.3	49.4
	2020	48.4	82.7	20.8	47.3
	2021	44.7	77.0	23.8	43.8
SAIFI	2017	0.94	1.31	0.26	0.90
	2018	0.92	1.18	0.36	0.89
	2019	0.84	1.07	0.40	0.82
	2020	0.78	1.09	0.33	0.76
	2021	0.72	1.16	0.37	0.70
CAIDI	2017	59.2	68.2	68.3	60.0
	2018	59.2	75.6	59.0	60.0
	2019	58.5	81.8	78.8	60.3
	2020	61.7	75.8	63.7	62.4
	2021	62.1	66.6	65.0	62.5
L BAR	2017	194	177	220	193
	2018	200	182	260	199
	2019	178	165	231	178
	2020	178	170	218	178
	2021	183	171	213	183

FPL's UG system's SAIDI performance has been better than its OH system, primarily driven by a better SAIFI. Also, the CAIDI associated with UG has generally performed better than OH due to FPL's looped UG system, which generally provides more opportunities for sectionalizing.

24. Describe Company efforts to separately track the reliability of overhead and underground systems.

FPL continually monitors each feeder interruption with a designation of either OH, UG, or hybrid system. FPL analyzes the types of equipment that fail to in order to determine the performance of its OH and UG systems. For example, FPL has equipment codes that relate specifically to its OH system (disconnect switches,

insulators, jumpers, wire) and UG system (cable, switch cabinets, elbow, and terminators).

After storm events, if feasible, FPL performs the forensic analyses/activities to compare OH vs. UG infrastructure performance. These analyses/activities are consistent with FPL's approved plan for Storm Preparedness Initiatives No. 7.

25. Describe the process used by your company to identify and select the actions to promote underground distribution systems.

URD Tariff - FPL supports all customer requests to convert OH facilities to UG or install new facilities UG. FPL's staff works to ensure timely and helpful responses to all inquiries for costs and requirements. In 2021, ten municipalities signed undergrounding agreements and moved forward with thirteen projects. FPL's Commission approved URD tariff provides incentives for new UG construction and OH to UG conversions for qualified projects.

Local Community Presentations – FPL conducts numerous presentations with local community groups who are interested in exploring OH to UG conversions.

Local Ordinances – There currently are local ordinances in multiple counties within FPL's service area that require new facilities to be installed as UG facilities. In addition, several municipalities require the customer to convert existing OH lines on or adjacent to their property when a major renovation is performed.

Distribution Lateral Hardening Program - FPL's commission approved Distribution Lateral Hardening Program as part of the SPP targets certain overhead laterals that were impacted by recent storms and have a history of vegetation-related outages and other reliability issues for conversion from OH to UG.

26. Provide Overhead and Underground Metrics

See FPL's response to Distribution Reliability Item No. 23 for classification criteria. CEMI-5 is not available by OH and UG. The miles below include only primary circuits (Feeders and Laterals).

2021 OH:

Number of miles = 4,483
Number of customers = 147,128
Number of Customer Minutes Interrupted (CMI) = 11,324,594
Number of Customers Interruptions (CI) = 170,006
L-Bar = $\frac{\text{Minutes of Interruption}}{\text{Total Number of Outages}} = \frac{906,807}{5,294} = 171$

2021 HYBRID:

Number of miles = 60,454
Number of customers = 4,653,912
Number of Customer Minutes Interrupted (CMI) = 207,958,026
Number of Customers Interruptions (CI) = 3,346,695
L-Bar = $\frac{\text{Minutes of Interruption}}{\text{Total Number of Outages}} = \frac{13,947,761}{76,172} = 183$

2021 UG:

Number of miles = 4,661
Number of customers = 440,268
Number of Customer Minutes Interrupted (CMI) = 10,478,549
Number of Customers Interruptions (CI) = 161,318
L-Bar = $\frac{\text{Minutes of Interruption}}{\text{Total Number of Outages}} = \frac{299,996}{1,407} = 213$

Data	Year	Hybrid	OH	UG	ALL
Number of Customers	2017	4,341,527	215,252	356,088	4,912,867
	2018	4,416,606	198,599	363,096	4,978,301
	2019	4,506,458	187,831	392,255	5,086,544
	2020	4,577,392	165,807	414,845	5,158,044
	2021	4,653,912	147,128	440,268	5,241,308
CMI	2017	240,963,708	19,282,826	6,315,376	266,561,910
	2018	239,453,615	17,681,763	7,707,127	264,842,505
	2019	222,398,170	16,409,477	12,291,925	251,099,572
	2020	221,755,358	13,718,150	8,610,736	244,084,244
	2021	207,958,026	11,324,594	10,478,549	229,761,169
CI	2017	4,071,005	282,621	92,463	4,446,089
	2018	4,047,356	233,873	130,673	4,411,902
	2019	3,804,882	200,692	155,915	4,161,489
	2020	3,592,732	180,951	135,245	3,908,928
	2021	3,346,695	170,006	161,318	3,678,019
MAIFle	2017	4.6	5.1	0.9	4.3
	2018	4.2	5.0	1.0	4.0
	2019	3.4	3.4	0.9	3.2
	2020	2.7	3.6	1.0	2.6
	2021	2.4	2.7	0.7	2.3

RELIABILITY RELATED CUSTOMER COMPLAINTS

27. Provide the five-year history for reliability-related* customer complaints.

- 2017 40
- 2018 30
- 2019 27
- 2020 29
- 2021 23

* As defined by the FPSC.

28. Describe Company efforts to correlate reliability-related complaints with reliability indices for applicable feeder, lateral, and sub region.

FPL addresses reliability complaints on a case-by-case basis. Lessons learned from issues and resolutions identified may be incorporated into our practices, if deemed appropriate. FPL also utilizes certain reliability programs, e.g., Customer Impact and Frequency Feeders, to address customer complaints.

29. Describe the process used by your company to identify and select systemic actions to improve reliability due to customer complaints. If no such program exists explain why.

See response to Distribution Reliability Item No. 28.

Transmission Reliability

1. Reliability Adjustments Events (Transmission).

See Appendix.

2. Localized Versus System-Wide Events.

None.

3. Description of Reliability Programs.

The transmission and substation reliability initiative is a two-fold program. The first part consists of on-going assessments and inspections of the transmission and substation system conditions and the associated mitigation work as required. The second part consists of the following targeted reliability areas:

Animals – Program to prevent and mitigate the effects of animal-related events to the transmission and substation system. Animals include (but are not limited to) birds, squirrels, monk parrots, and raccoons.

Equipment – Proactive replacement of both transmission and substation equipment reaching end of life. Items include, but are not limited to, insulators, overhead ground wires (“OHGW”), distribution breakers, transmission breakers, switches, and substation regulators.

Lightning – Items include bonding, grounding, and arrester installations.

Foreign Interference – Outreach and awareness safety program to minimize the impact of foreign interference (e.g., cranes, balloons, diggers, sailboats, etc.) into electrical lines.

4. Five-Year Reliability Performance

Transmission/Substation
12 months ending December 31

Transmission/Substation	2017	2018	2019	2020	2021
SAIDI	2.1	1.6	2.0	1.2	1.8
SAIFI	0.16	0.13	0.13	0.11	0.12
MAIFI	0.6	0.7	0.7	0.8	0.8
MAIFle	0.6	0.6	0.6	0.6	0.7

5. Description of Company’s Tracking

FPL’s Transmission/Substation group investigates all transmission and substation outages to identify the root cause(s) and develop solutions. Reliability performance is tracked using SAIDI, SAIFI, MAIFI, and MAIFle.

6. Method of Program Selections

For program selection, FPL's Transmission/Substation group utilizes historical reliability performance, trends, condition assessments, and risk ranking.



ANNUAL DISTRIBUTION RELIABILITY REPORT FOR 2021

SAIDI	= System Average Interruption Duration Index		
	= $\frac{\text{Sum of All Customer Minutes Interrupted (CMI)}}{\text{Total number of Customers Served (C)}}$	$\frac{229,761,169}{5,241,308}$	43.84
CAIDI	= Customer Average Interruption Duration Index		
	= $\frac{\text{Sum of All Customer Minutes Interrupted (CMI)}}{\text{Total number of Customer Interruptions (CI)}}$	$\frac{229,761,169}{3,678,019}$	62.5
SAIFI	= System Average Interruption Frequency Index		
	= $\frac{\text{Total number of Customer Interruptions (CI)}}{\text{Total number of Customers Served (C)}}$	$\frac{3,678,019}{5,241,308}$	0.70
MAIFle	= Momentary Average Interruption Event		
	= $\frac{\text{Sum of All Customer Momentary Interruption Events (CME)}}{\text{Total number of Customers Served (C)}}$	$\frac{12,090,486}{5,239,787}$	2.31
L BAR	= $\frac{\text{Minutes of Interruption (AO)}}{\text{Total Number of Outages (\# of Outages)}}$	$\frac{15,154,564}{82,873}$	183
%CEMI-5	= $\frac{\text{Sum of CEMI-5 Customers (\# Cust>5)}}{\text{Total number of Customers Served (C)}}$	$\frac{15,870}{5,241,308}$	0.3%

Service Reliability Indices Data								
Utility Name: FPL								Year: 2021
District or Service Area	Customer Served (C)	# of Outages	CMI	CI	AO	CME	# Cust >5	MAIFle Customer Served
Boca Raton	390,005	4,526	13,842,207	259,275	829,200	1,063,285	431	403,792
Brevard	327,339	6,425	15,066,103	268,327	1,060,178	790,664	2,742	325,156
Central Broward	289,450	4,803	15,303,618	231,581	889,166	618,191	571	303,901
Central Dade	331,087	3,842	15,358,900	221,466	804,908	664,347	627	329,242
Central Florida	312,544	5,766	13,380,326	221,636	868,138	721,515	634	314,733
Manasota	423,344	5,922	15,455,771	229,773	1,049,756	732,678	395	431,698
Naples	428,887	4,702	16,603,018	309,530	933,105	933,284	722	411,930
North Broward	326,654	3,606	10,243,971	186,957	620,682	496,626	1,230	319,454
North Dade	255,885	5,848	15,260,345	208,307	1,067,596	462,921	1,340	250,648
North Florida	183,858	4,601	10,028,463	160,451	715,328	387,392	647	183,877
South Broward	348,897	4,269	12,235,296	192,849	783,082	841,565	817	336,818
South Dade	310,243	6,088	17,984,995	247,401	1,465,168	846,259	1,103	305,901
Toledo Blade	299,091	5,879	15,844,482	257,758	1,009,234	787,877	1,587	307,433
Treasure Coast	354,410	6,655	15,802,901	262,424	1,190,218	922,788	1,274	353,952
West Dade	278,531	4,125	13,777,307	201,046	835,360	936,306	741	291,681
West Palm	381,083	5,816	13,573,466	219,238	1,033,445	884,788	1,009	369,571
All FPL	5,241,308	82,873	229,761,169	3,678,019	15,154,564	12,090,486	15,870	5,239,787

* For MAIFle only, FPL utilizes a slightly different customer served count for the Management Areas. Specifically, customer counts are determined by counting the customers on all feeders out of the substations located in each Management Area, regardless of where that feeder runs geographically (i.e., a customer served could be located in another Management Area). This is different than the customer served count used for SAIDI and SAIFI, which uses the actual count of customers with meters located in each Management Area.

PSC/ECR 102-1(a)

Incorporated by reference in Rule 25-6.0455

Causes of Outage Events – Actual			
Utility Name: FPL		Year: 2021	
Cause (a)	Number of Outage Events (N) (b)	Average Duration (L-Bar) (c)	Average Restoration Time (CAIDI) (d)
Defective Equipment	33,030	207	73.9
Request	43,638	74	73.5
Vegetation	19,366	211	125.9
Unknown	8,289	133	34.2
Other Weather	6,666	206	101.9
Animals	9,851	110	62.0
Other	7,702	180	35.4
All Other Causes	3,312	155	29.4
Lightning	1,430	269	107.4
Vehicle	980	263	67.9
System Total	134,264	151	67.9

PSC/ECR 102-1(b)

Incorporated by reference in Rule 25-6.0455

Causes of Outage Events – Adjusted			
Utility Name: FPL		Year: 2021	
Cause (a)	Number of Outage Events (N) (b)	Average Duration (L-Bar) (c)	Average Restoration Time (CAIDI) (d)
Defective Equipment	31,216	205	72.6
Vegetation	17,090	207	124.5
Unknown	7,740	131	31.7
Other Weather	5,275	187	83.3
Animals	9,436	110	62.0
Other	6,728	166	23.4
All Other Causes	3,172	155	29.2
Lightning	1,270	265	101.8
Vehicle	946	261	67.9
System Total	82,873	183	62.5

THREE PERCENT FEEDER LIST - ACTUAL													
FPL Primary Circuit Id. No. or Name (a)	Substation Origin (b)	Location (c)	Year 2021 Number of Customers					Total (h)	Number of Outage Events (N)	Average Duration (L-Bar) (L)	Average Restoration Time (CAIDI) (n)	Listed Last Year?	No. of Years in the Last 5
			Residential (d)	Commercial (e)	Industrial (f)	Other (g)							
400934	BELLE GLADE	Palm Beach	1395	299	8	55	1702	9	421	92.0	Y	3	
500766	ENGLEWOOD	Sarasota	2256	157	3	19	2416	9	229	58.0	Y	2	
810366	NEWTON	Miami-Dade	843	172	0	8	1015	9	151	147.0	Y	2	
202234	MIMS	Brevard	1463	167	4	32	1634	8	44	18.0	N	1	
705468	PHOENIX	Broward	2956	177	2	5	3135	8	34	16.0	N	1	
202533	AURORA	Brevard	1440	321	1	21	1762	7	11	7.0	N	1	
400832	PAHOKEE	Palm Beach	268	88	19	6	375	7	166	64.0	N	2	
407662	LOXAHATCHEE	Palm Beach	2505	59	10	2	2574	7	54	19.0	N	1	
507262	SAN CARLOS	Lee	2538	602	1	23	3141	7	35	31.0	N	1	
704766	STONEBRIDGE	Broward	1729	127	1	13	1857	7	79	12.0	N	1	
802235	GLADEVIEW	Miami-Dade	1902	140	2	13	2044	7	24	12.0	N	2	
808533	SEMINOLA	Miami-Dade	1020	196	1	8	1217	7	141	94.0	N	2	
102535	MATANZAS	St Johns	2104	182	13	13	2299	6	119	50.0	N	1	
105061	SCOTTSMOOR	Volusia	2086	258	2	47	2346	6	30	21.0	N	2	
408463	ADAMS	St Lucie	172	266	3	9	441	6	115	74.0	Y	4	
409436	SKYPASS	Palm Beach	489	34	7	0	530	6	31	14.0	N	1	
412261	OTTER	St Lucie	444	77	1	10	522	6	133	34.0	N	2	
500931	OSPREY	Sarasota	1246	235	5	12	1486	6	92	45.0	Y	2	
502461	LABELLE	Hendry	2974	247	30	95	3251	6	80	40.0	Y	3	
502463	LABELLE	Hendry	1165	228	8	44	1401	6	47	20.0	Y	5	
505261	RUBONIA	Manatee	1554	451	19	21	2024	6	50	26.0	N	1	
507266	SAN CARLOS	Lee	3457	382	3	27	3842	6	199	57.0	N	1	
706262	VALENCIA	Broward	2946	255	9	26	3210	6	46	11.0	N	1	
807733	LEMON CITY	Miami-Dade	989	313	1	8	1303	6	162	53.0	N	1	
808263	LINDGREN	Miami-Dade	3279	189	0	3	3468	6	24	16.0	N	1	
100832	PORT ORANGE	Volusia	2188	186	7	14	2381	5	73	27.0	N	1	
102364	ST JOE	Flagler	2649	157	9	26	2815	5	37	8.0	N	1	
106363	REGIS	Flagler	918	229	7	43	1154	5	40	36.0	Y	2	
205361	GENEVA	Seminole	878	113	7	43	998	5	29	13.0	N	2	
207362	WYOMING	Brevard	3323	74	1	46	3398	5	12	8.0	N	1	
400133	WEST PALM BEACH	Palm Beach	772	367	2	4	1141	5	156	72.0	Y	2	
400332	NORTHWOOD	Palm Beach	498	47	8	2	553	5	134	74.0	Y	2	
403435	JENSEN	Martin	1797	353	1	14	2151	5	29	16.0	N	1	
404836	GERMANTOWN	Palm Beach	1178	282	4	4	1464	5	69	18.0	N	1	
407463	INDRIO	St Lucie	1315	182	0	7	1497	5	112	23.0	N	1	
408664	HOMELAND	Palm Beach	1283	337	13	9	1633	5	108	52.0	Y	3	
502462	LABELLE	Hendry	1448	363	7	61	1818	5	34	29.0	Y	2	
503039	PHILLIPPI	Sarasota	2193	384	7	10	2584	5	62	16.0	N	1	
503131	SOLANA	Collier	1915	128	13	4	2056	5	5	4.0	N	1	
505664	ROTONDA	Charlotte	3427	281	19	13	3727	5	353	78.0	Y	4	
507361	ORANGE TREE	Collier	2269	113	25	195	2407	5	35	13.0	N	2	
508462	GATEWAY	Lee	2150	438	7	74	2595	5	137	41.0	Y	2	
700636	VERENA	Broward	1665	126	4	6	1795	5	167	45.0	N	1	
701432	PORT	Broward	193	30	9	1	232	5	164	63.0	N	1	
704032	MOTOROLA	Broward	3112	171	7	6	3290	5	41	29.0	N	1	
704570	MALLARD	Broward	4252	247	2	7	4501	5	52	13.0	N	1	
706663	NOBHILL	Broward	2647	262	3	3	2912	5	30	21.0	N	1	
800448	COCONUT GROVE	Miami-Dade	953	122	5	10	1080	5	181	73.0	N	1	
801036	NORMANDY BEACH	Miami-Dade	1016	148	11	4	1175	5	34	28.0	N	1	
801134	FRONTON	Miami-Dade	1938	348	1	16	1997	5	248	51.0	N	1	
801436	FULFORD	Miami-Dade	2844	196	3	20	2843	5	5	41.0	N	1	
802834	ARCH CREEK	Miami-Dade	1274	208	0	8	1482	5	25	20.0	N	1	
803031	TROPICAL	Miami-Dade	1381	136	0	7	1517	5	98	20.0	N	1	
804531	GRATIGNY	Miami-Dade	1406	73	0	15	1479	5	125	44.0	N	1	
804632	INDUSTRIAL	Miami-Dade	549	276	1	13	826	5	167	50.0	N	2	
806237	INDIAN CREEK	Miami-Dade	367	22	9	4	398	5	119	67.0	N	1	
806333	ULETA	Miami-Dade	2433	96	0	9	2529	5	151	40.0	N	2	
806842	RED ROAD	Miami-Dade	265	367	0	6	632	5	88	47.0	N	1	
810932	LATIN QUARTER	Miami-Dade	2083	417	4	8	2504	5	51	19.0	N	1	
100331	HASTINGS	St Johns	683	262	7	52	952	4	4	3.0	Y	2	
101463	FLAGLER BEACH	Flagler	2389	200	47	16	2636	4	204	39.0	N	2	
105762	RIVERTON	St Johns	1312	122	6	11	1440	4	173	34.0	N	3	
106365	REGIS	Flagler	2842	160	5	52	3007	4	42	35.0	N	1	
107633	TOLOMATO	St Johns	1536	115	15	7	1666	4	7	6.0	Y	2	
200732	COCOA BEACH	Brevard	1328	186	1	6	1515	4	7	7.0	N	1	
201432	GRANDVIEW	Seminole	1391	261	3	28	1655	4	44	11.0	N	1	
202134	INDIAN RIVER	Brevard	1313	265	1	23	1579	4	64	26.0	N	1	
202232	MIMS	Brevard	1407	108	6	23	1521	4	41	20.0	N	1	
202233	MIMS	Brevard	1097	63	1	19	1161	4	7	7.0	N	1	
202537	AURORA	Brevard	1973	73	1	1	2047	4	4	3.0	N	1	
203133	ROCKLEDGE	Brevard	1509	70	8	8	1587	4	26	15.0	N	1	
203233	INDIALANTIC	Brevard	1279	163	2	7	1444	4	68	29.0	N	1	
203637	HARRIS	Brevard	1432	217	3	21	1652	4	4	3.0	N	2	
204261	BABCOCK	Brevard	2488	101	1	50	2590	4	5	6.0	N	1	
206934	BARNA	Brevard	1574	77	3	13	1654	4	11	10.0	N	1	
209861	YORKE	Brevard	614	254	1	12	869	4	83	19.0	N	1	
301139	COLUMBIA	Columbia	678	136	7	27	821	4	175	71.0	N	2	
308065	MILLS	Nassau	1742	115	7	67	1864	4	69	31.0	N	1	
400539	BOYNTON	Palm Beach	1035	259	2	3	1296	4	58	57.0	N	1	
400662	WABASSO	Indian River	1338	297	14	27	1649	4	111	44.0	N	1	
401762	OLYMPIA	Martin	2159	280	2	15	2441	4	101	22.0	N	1	
401833	JUPITER	Palm Beach	1245	78	2	8	1325	4	48	28.0	N	1	
402131	TERMINAL	Palm Beach	1651	169	2	8	1822	4	60	35.0	Y	2	
402133	TERMINAL	Palm Beach	1287	267	1	24	1555	4	41	40.0	Y	2	
402533	BELVEDERE	Palm Beach	691	190	5	6	886	4	61	10.0	N	1	
402833	LANTANA	Palm Beach	1755	218	6	9	1979	4	20	13.0	N	1	
402838	LANTANA	Palm Beach	2979	192	9	17	3180	4	111	11.0	N	1	
403634	SOUTH BAY	Palm Beach	0	164	5	3	169	4	522	127.0	N	3	
404135	GOLF	Palm Beach	1997	269	8	17	2274	4	58	33.0	N	1	
404136	GOLF	Palm Beach	4278	332	9	17	4619	4	274	64.0	Y	2	
404631	PLATT	Martin	2048	331	2	28	2381	4	2	2.0	N	2	
405862	DELTRAIL	Palm Beach	3579	137	5	2	3721	4	81	26.0	N	1	
406064	SHERMAN	Okeechobee	551	238	2	28	791	4	120	12.0	N	1	
406533	OSBORNE	Palm Beach	2008	97	20	23	2125	4	44	24.0	N	1	
406862	KIMBERLY	Palm Beach	1434	58	2	1	1494	4	115	41.0	N	1	
407161	CRANE	Martin	2778	155	7	7	2940	4	474	23.0	N	1	
407234	JOG	Palm Beach	1200	147	4	17	1351	4	67	31.0	N	1	
407931	QUANTUM	Palm Beach	2257	183	7	16	2447	4	136	52.0	N	1	
408667	HOMELAND	Palm Beach	1117	443	6	13	1566	4	13	12.0	N	1	
410361	SARAL	St Lucie	855	77	1	2	933	4	97	82.0	N	1	
410365	MARLIN	Palm Beach	150	1	1	11	2429	4	68	14.0	N	1	
412161	ALLAPATTAH	St Lucie	1505	100	0	7	1605	4	108	19.0	N	1	
500131	SARASOTA	Sarasota	1441	268	3	32	1712	4	65	31.0	N	1	
501432	ARCADIA	De Soto	2280	275	10	46	2565	4	43	29.0	N	1	
501766	IONA	Lee	3750	250	1	25	4001	4	70	18.0	N	2	
502636	COLONIAL	Lee	1702	179	1	21	1882	4	46	20.0	N	1	

PSC/ECR 102-3 (a)

System Reliability Indices - Actual											
FPL											Year: 2021
District or Service Area (a)	CMI	CI	CME	AO	N	Cust Served	SAIDI (b)	CAIDI (c)	SAIFI (d)	MAIFle (e)	CEMIS (f)
Boca Raton	17,620,646	311,683	1,173,623	1,076,885	6,565	390,005	45.2	56.5	0.80	2.9	544
Brevard	18,053,532	314,998	853,490	1,398,330	11,661	327,339	55.2	57.3	0.96	2.6	2,999
Central Broward	17,946,942	259,213	645,793	1,108,562	6,589	289,450	62.0	69.2	0.90	2.1	700
Central Dade	19,338,131	261,709	689,984	999,789	4,989	331,087	58.4	73.9	0.79	2.1	727
Central Florida	15,472,007	265,513	757,540	1,153,543	11,664	312,544	49.5	58.3	0.85	2.4	827
Manasota	21,623,250	295,146	812,911	1,581,218	9,929	423,344	51.1	73.3	0.70	1.9	480
Naples	22,792,405	365,789	1,063,080	1,312,978	8,495	428,887	53.1	62.3	0.85	2.6	868
North Broward	12,149,807	205,622	525,676	776,901	4,863	326,654	37.2	59.1	0.63	1.6	1,253
North Dade	17,110,903	233,519	485,059	1,256,777	7,276	255,885	66.9	73.3	0.91	1.9	1,547
North Florida	12,816,985	196,806	426,925	940,790	6,797	183,858	69.7	65.1	1.07	2.3	732
South Broward	14,020,322	218,432	892,528	951,695	5,821	348,897	40.2	64.2	0.63	2.6	885
South Dade	20,340,370	268,729	926,262	1,739,522	8,351	310,243	65.6	75.7	0.87	3.0	1,367
Toledo Blade	30,512,152	372,962	957,175	1,767,657	15,384	299,091	102.0	81.8	1.25	3.1	1,787
Treasure Coast	20,974,599	306,736	1,061,956	1,711,786	10,952	354,410	53.3	131.3	0.77	9.1	1,388
West Dade	15,342,921	213,659	1,025,943	1,019,778	5,306	278,531	55.1	71.8	0.77	3.5	959
West Palm	21,014,851	283,177	1,017,380	1,471,281	9,622	381,083	55.1	74.2	0.74	2.8	1,047
All FPL	297,129,823	4,373,693	13,315,325	20,267,492	134,264	5,241,308	56.7	67.9	0.83	2.5	18,110

PSC/ECR 102-3 (b)

System Reliability Indices - Adjusted											
FPL											Year: 2021
District or Service Area (a)	CMI	CI	CME	AO	N	Cust Served	SAIDI (b)	CAIDI (c)	SAIFI (d)	MAIFle (e)	CEMIS (f)
Boca Raton	13,842,207	259,275	1,063,285	829,200	4,526	390,005	35.5	53.4	0.66	2.6	431
Brevard	15,066,103	268,327	790,664	1,060,178	6,425	327,339	46.0	56.1	0.82	2.4	2,742
Central Broward	15,303,618	231,581	618,191	889,166	4,803	289,450	52.9	66.1	0.80	2.0	571
Central Dade	15,358,900	221,466	664,347	804,908	3,842	331,087	46.4	69.4	0.67	2.0	627
Central Florida	13,380,326	221,636	721,515	868,138	5,766	312,544	42.8	60.4	0.71	2.3	634
Manasota	15,455,771	229,773	732,678	1,049,756	5,922	423,344	36.5	67.3	0.54	1.7	395
Naples	16,603,018	309,530	933,284	933,105	4,702	428,887	38.7	53.6	0.72	2.3	722
North Broward	10,243,971	186,957	496,626	620,682	3,606	326,654	31.4	54.8	0.57	1.6	1,230
North Dade	15,260,345	208,307	462,921	1,067,596	5,848	255,885	59.6	73.3	0.81	1.8	1,340
North Florida	10,028,463	160,451	387,392	715,328	4,601	183,858	54.5	62.5	0.87	2.1	647
South Broward	12,235,296	192,849	841,565	783,082	4,269	348,897	35.1	63.4	0.55	2.5	817
South Dade	17,984,995	247,401	846,259	1,465,168	6,088	310,243	58.0	72.7	0.80	2.8	1,103
Toledo Blade	15,844,482	257,758	787,877	1,009,234	5,879	299,091	53.0	61.5	0.86	2.6	1,587
Treasure Coast	15,802,901	262,424	922,788	1,190,218	6,655	354,410	39.5	119.8	0.65	8.4	1,274
West Dade	13,777,307	201,046	936,306	835,360	4,125	278,531	49.5	68.5	0.72	3.2	741
West Palm	13,573,466	219,238	884,788	1,033,445	5,816	381,083	35.6	61.9	0.58	2.4	1,009
All FPL	229,761,169	3,678,019	12,090,486	15,154,564	82,873	5,241,308	43.8	62.5	0.70	2.3	15,870

APPENDIX

Actual Data: Customer Minutes of Interruption (CMI), Customer Interruptions (CI) and Documented Exclusions

2021	Customer minutes of Interruption (CMI)		Customer Interruptions (CI)	
	Value	% of Actual	Value	% of Actual
Reported Actual Data (1)	297,129,823	100%	4,373,693	100%
Documented Exclusions				
Planned Service Interruptions	23,604,747	8%	320,626	7%
Tropical Storm	6,200,550	2%	83,533	2%
Tornado	26,293,495	9%	170,156	4%
Hurricane	11,269,862	4%	121,359	3%
Ice on Lines	-	0%	-	0%
Subtropical Storm	-	0%	-	0%
Generation/Transmission Events (2)	9,301,177	N/A	645,399	N/A
Extreme Weather (EOC Activation)	-	0%	-	0%
Fire (EOC Activation)	-	0%	-	0%
Reported Adjusted Data	229,761,169	77%	3,678,019	84%

Notes:

(1) Excludes Generation/Transmission Events per 25-6.0455(2)

(2) Informational Only, as reported actual data already excludes Generation/Transmission Events

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	2/15/2021	2	228	114
Tornado	2/15/2021	1	69	69
Tornado	2/15/2021	50	11,850	237
Tornado	2/15/2021	2	548	274
Tornado	2/15/2021	1	247	247
Tornado	2/15/2021	2	60	30
Tornado	2/15/2021	15	840	56
Tornado	2/15/2021	72	3,112	81
Tornado	2/15/2021	3	318	106
Tornado	2/15/2021	1	160	160
Tornado	2/15/2021	1	112	112
Tornado	2/15/2021	1	170	170
Tornado	2/15/2021	2	228	114
Tornado	2/15/2021	3	555	185
Tornado	2/15/2021	1	201	201
Tornado	2/15/2021	1	35	35
Tornado	2/15/2021	4	60	15
Tornado	2/15/2021	5	20	4
Tornado	2/15/2021	1	239	239
Tornado	2/15/2021	5	265	53
Tornado	2/15/2021	1	107	108
Tornado	2/15/2021	3	57	19
Tornado	2/15/2021	1	21	21
Tornado	2/15/2021	8	88	11
Tornado	2/15/2021	1	23	23
Tornado	2/15/2021	3	24	8
Tornado	2/15/2021	1	13	13
Tornado	2/15/2021	1	58	58
Tornado	2/15/2021	1	30	30
Tornado	2/15/2021	8	224	28
Tornado	2/15/2021	1	171	171
Tornado	2/15/2021	1	306	306
Tornado	2/15/2021	10	170	17
Tornado	2/15/2021	1	101	101
Tornado	2/15/2021	2	130	65
Tornado	2/15/2021	411	82,383	803
Tornado	2/15/2021	31	17,887	577
Tornado	2/15/2021	1	122	122
Tornado	2/15/2021	3	687	229
Tornado	2/15/2021	65	8,547	686
Tornado	2/15/2021	1	297	297
Tornado	2/15/2021	1	214	214
Tornado	2/15/2021	1	55	55

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	2/15/2021	4	116	29
Tornado	2/15/2021	9	1,224	262
Tornado	2/15/2021	2	72	36
Tornado	2/15/2021	3	81	27
Tornado	2/15/2021	396	7,164	39
Tornado	2/15/2021	9	162	18
Tornado	2/15/2021	2	130	65
Tornado	2/15/2021	5	475	95
Tornado	2/15/2021	4	476	119
Tornado	2/15/2021	1	121	121
Tornado	2/15/2021	40	11,880	297
Tornado	2/15/2021	10	950	95
Tornado	2/15/2021	2	36	18
Tornado	2/15/2021	25	11,726	532
Tornado	2/15/2021	1	172	172
Tornado	2/15/2021	11	1,562	142
Tornado	2/15/2021	5	120	24
Tornado	2/15/2021	19	1,311	69
Tornado	2/15/2021	1	70	70
Tornado	2/15/2021	10	630	63
Tornado	2/15/2021	4	892	223
Tornado	2/15/2021	47	7,791	393
Tornado	2/15/2021	1	471	471
Tornado	2/15/2021	1	241	241
Tornado	2/15/2021	1	146	146
Tornado	2/15/2021	3	300	100
Tornado	2/15/2021	2	134	67
Tornado	2/15/2021	2	304	152
Tornado	2/15/2021	1	333	333
Tornado	2/15/2021	4	1,088	272
Tornado	2/15/2021	1	182	182
Tornado	2/15/2021	1	189	189
Tornado	2/15/2021	1	303	303
Tornado	2/15/2021	21	1,155	55
Tornado	2/15/2021	85	8,670	102
Tornado	4/10/2021	1	215	215
Tornado	4/10/2021	41	1,312	32
Tornado	4/10/2021	21	11,487	547
Tornado	4/10/2021	2	1,012	506
Tornado	4/10/2021	1	49	49
Tornado	4/10/2021	198	10,759	180
Tornado	4/10/2021	6	708	118
Tornado	4/10/2021	6	408	68

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	4	360	90
Tornado	4/10/2021	1	120	120
Tornado	4/10/2021	2	90	45
Tornado	4/10/2021	1	199	199
Tornado	4/10/2021	2	390	195
Tornado	4/10/2021	6	1,722	287
Tornado	4/10/2021	5	860	172
Tornado	4/10/2021	1	204	204
Tornado	4/10/2021	2	160	80
Tornado	4/10/2021	1	17	17
Tornado	4/10/2021	6	18	3
Tornado	4/10/2021	4	136	34
Tornado	4/10/2021	2	448	224
Tornado	4/10/2021	1	75	75
Tornado	4/10/2021	4	156	39
Tornado	4/10/2021	3	2,079	693
Tornado	4/10/2021	3	180	60
Tornado	4/10/2021	43	2,021	47
Tornado	4/10/2021	2	286	143
Tornado	4/10/2021	9	18	2
Tornado	4/10/2021	3	363	121
Tornado	4/10/2021	1	52	52
Tornado	4/10/2021	99	5,742	58
Tornado	4/10/2021	1	71	71
Tornado	4/10/2021	1	49	49
Tornado	4/10/2021	2	4	2
Tornado	4/10/2021	2	444	222
Tornado	4/10/2021	4	352	88
Tornado	4/10/2021	1	71	71
Tornado	4/10/2021	50	3,150	63
Tornado	4/10/2021	13	2,519	301
Tornado	4/10/2021	2	108	54
Tornado	4/10/2021	1	539	539
Tornado	4/10/2021	8	2,144	268
Tornado	4/10/2021	2	806	403
Tornado	4/10/2021	1	94	94
Tornado	4/10/2021	2	232	116
Tornado	4/10/2021	162	35,117	268
Tornado	4/10/2021	105	11,340	108
Tornado	4/10/2021	1	101	101
Tornado	4/10/2021	51	5,849	219
Tornado	4/10/2021	1	204	204
Tornado	4/10/2021	916	48,116	71

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	1	404	404
Tornado	4/10/2021	19	2,679	141
Tornado	4/10/2021	34	13,532	398
Tornado	4/10/2021	1	187	187
Tornado	4/10/2021	2	168	84
Tornado	4/10/2021	1	40	40
Tornado	4/10/2021	25	3,875	155
Tornado	4/10/2021	19	2,489	131
Tornado	4/10/2021	9	765	85
Tornado	4/10/2021	1	158	158
Tornado	4/10/2021	3	468	156
Tornado	4/10/2021	1	126	126
Tornado	4/10/2021	8	1,456	182
Tornado	4/10/2021	1	141	141
Tornado	4/10/2021	1	111	111
Tornado	4/10/2021	1	569	569
Tornado	4/10/2021	5	485	97
Tornado	4/10/2021	10	220	22
Tornado	4/10/2021	1	91	91
Tornado	4/10/2021	10	2,890	289
Tornado	4/10/2021	1	15	15
Tornado	4/10/2021	1	153	153
Tornado	4/10/2021	4	164	41
Tornado	4/10/2021	2	66	33
Tornado	4/10/2021	1	131	131
Tornado	4/10/2021	1	121	121
Tornado	4/10/2021	21	8,610	410
Tornado	4/10/2021	5	645	129
Tornado	4/10/2021	3	258	86
Tornado	4/10/2021	16	960	60
Tornado	4/10/2021	43	6,106	142
Tornado	4/10/2021	131	19,519	149
Tornado	4/10/2021	2	36	18
Tornado	4/10/2021	55	4,268	88
Tornado	4/10/2021	267	12,015	45
Tornado	4/10/2021	393	103,048	426
Tornado	4/10/2021	18	1,980	110
Tornado	4/10/2021	706	26,880	48
Tornado	4/10/2021	6	138	23
Tornado	4/10/2021	5	385	77
Tornado	4/10/2021	33	1,419	43
Tornado	4/10/2021	22	7,304	332
Tornado	4/10/2021	5	260	52

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	23	11,132	484
Tornado	4/10/2021	19	1,045	55
Tornado	4/10/2021	9	4,068	452
Tornado	4/10/2021	5	1,515	303
Tornado	4/10/2021	62	5,084	82
Tornado	4/10/2021	155	6,820	44
Tornado	4/10/2021	22	88	4
Tornado	4/10/2021	89	7,476	84
Tornado	4/10/2021	1	272	272
Tornado	4/10/2021	7	3,465	495
Tornado	4/10/2021	337	22,733	160
Tornado	4/10/2021	4	1,048	262
Tornado	4/10/2021	153	9,792	64
Tornado	4/10/2021	17	1,258	74
Tornado	4/10/2021	37	2,459	260
Tornado	4/10/2021	6	4,434	739
Tornado	4/10/2021	2	812	406
Tornado	4/10/2021	1	72	72
Tornado	4/10/2021	2	690	345
Tornado	4/10/2021	4	1,268	317
Tornado	4/10/2021	6	3,120	520
Tornado	4/10/2021	95	3,135	33
Tornado	4/10/2021	10	2,690	269
Tornado	4/10/2021	7	2,821	403
Tornado	4/10/2021	21	8,946	426
Tornado	4/10/2021	2	1,412	706
Tornado	4/10/2021	14	2,674	191
Tornado	4/10/2021	39	13,455	345
Tornado	4/10/2021	8	4,544	568
Tornado	4/10/2021	47	9,212	196
Tornado	4/10/2021	4	2,060	515
Tornado	4/10/2021	80	23,120	289
Tornado	4/10/2021	3	996	332
Tornado	4/10/2021	4	376	94
Tornado	4/10/2021	4	804	201
Tornado	4/10/2021	18	2,034	113
Tornado	4/10/2021	656	21,164	123
Tornado	4/10/2021	11	3,706	371
Tornado	4/10/2021	50	9,400	188
Tornado	4/10/2021	68	8,500	133
Tornado	4/10/2021	1,735	138,459	204
Tornado	4/10/2021	3	996	332
Tornado	4/10/2021	1	52	52

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	9	10,971	1,219
Tornado	4/10/2021	51	18,411	361
Tornado	4/10/2021	2	884	442
Tornado	4/10/2021	53	87,079	1,643
Tornado	4/10/2021	18	828	46
Tornado	4/10/2021	11	6,182	562
Tornado	4/10/2021	14	8,752	626
Tornado	4/10/2021	18	1,890	105
Tornado	4/10/2021	6	3,036	506
Tornado	4/10/2021	8	821	548
Tornado	4/10/2021	87	10,527	121
Tornado	4/10/2021	40	7,840	196
Tornado	4/10/2021	1	586	586
Tornado	4/10/2021	1	557	557
Tornado	4/10/2021	1,518	48,957	39
Tornado	4/10/2021	70	3,360	48
Tornado	4/10/2021	8	5,016	627
Tornado	4/10/2021	11	5,203	473
Tornado	4/10/2021	1	472	472
Tornado	4/10/2021	6	630	105
Tornado	4/10/2021	1	313	313
Tornado	4/10/2021	14	7,340	526
Tornado	4/10/2021	19	32,984	1,736
Tornado	4/10/2021	19	3,344	176
Tornado	4/10/2021	2	1,014	507
Tornado	4/10/2021	101	9,090	90
Tornado	4/10/2021	33	3,861	117
Tornado	4/10/2021	10	2,700	270
Tornado	4/10/2021	20	6,614	575
Tornado	4/10/2021	1	329	329
Tornado	4/10/2021	2	944	472
Tornado	4/10/2021	46	19,877	482
Tornado	4/10/2021	32	4,032	126
Tornado	4/10/2021	38	3,078	81
Tornado	4/10/2021	13	4,043	311
Tornado	4/10/2021	29	4,756	164
Tornado	4/10/2021	21	1,281	61
Tornado	4/10/2021	20	4,960	248
Tornado	4/10/2021	4	456	114
Tornado	4/10/2021	1,247	62,350	50
Tornado	4/10/2021	500	20,500	41
Tornado	4/10/2021	58	16,820	290
Tornado	4/10/2021	1	92	92

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	6	2,052	342
Tornado	4/10/2021	4	648	162
Tornado	4/10/2021	22	5,060	230
Tornado	4/10/2021	27	6,399	237
Tornado	4/10/2021	39	1,911	49
Tornado	4/10/2021	2	666	333
Tornado	4/10/2021	8	1,352	169
Tornado	4/10/2021	8	2,248	281
Tornado	4/10/2021	7	1,379	197
Tornado	4/10/2021	36	3,096	86
Tornado	4/10/2021	1	314	314
Tornado	4/10/2021	26	2,548	98
Tornado	4/10/2021	10	4,340	434
Tornado	4/10/2021	23	3,404	148
Tornado	4/10/2021	4	908	227
Tornado	4/10/2021	413	17,346	42
Tornado	4/10/2021	1	139	139
Tornado	4/10/2021	5	1,330	266
Tornado	4/10/2021	55	5,940	108
Tornado	4/10/2021	8	2,056	257
Tornado	4/10/2021	92	9,660	105
Tornado	4/10/2021	10	2,890	289
Tornado	4/10/2021	622	55,358	89
Tornado	4/10/2021	12	4,860	405
Tornado	4/10/2021	32	15,456	483
Tornado	4/10/2021	10	1,620	162
Tornado	4/10/2021	25	1,575	63
Tornado	4/10/2021	2	1,216	608
Tornado	4/10/2021	530	104,940	198
Tornado	4/10/2021	3	684	228
Tornado	4/10/2021	26	14,768	568
Tornado	4/10/2021	10	590	59
Tornado	4/10/2021	50	4,800	96
Tornado	4/10/2021	57	34,428	604
Tornado	4/10/2021	1	337	337
Tornado	4/10/2021	6	1,062	177
Tornado	4/10/2021	133	5,453	41
Tornado	4/10/2021	7	2,646	378
Tornado	4/10/2021	1	531	531
Tornado	4/10/2021	5	755	151
Tornado	4/10/2021	118	9,440	80
Tornado	4/10/2021	218	17,876	82
Tornado	4/10/2021	1	346	346

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	14	5,376	384
Tornado	4/10/2021	16	13,372	867
Tornado	4/10/2021	4	2,392	598
Tornado	4/10/2021	5	1,330	266
Tornado	4/10/2021	3	630	210
Tornado	4/10/2021	165	27,599	173
Tornado	4/10/2021	99	41,184	416
Tornado	4/10/2021	1	105	105
Tornado	4/10/2021	2	214	107
Tornado	4/10/2021	2	326	163
Tornado	4/10/2021	603	27,644	93
Tornado	4/10/2021	1	489	489
Tornado	4/10/2021	82	4,838	59
Tornado	4/10/2021	75	6,825	91
Tornado	4/10/2021	2	688	344
Tornado	4/10/2021	1	380	380
Tornado	4/10/2021	4	652	163
Tornado	4/10/2021	1	280	280
Tornado	4/10/2021	38	24,168	636
Tornado	4/10/2021	50	21,100	422
Tornado	4/10/2021	20	2,760	138
Tornado	4/10/2021	39	14,313	367
Tornado	4/10/2021	2	594	297
Tornado	4/10/2021	1	518	518
Tornado	4/10/2021	1	89	89
Tornado	4/10/2021	2	642	321
Tornado	4/10/2021	9	1,413	157
Tornado	4/10/2021	5	3,735	747
Tornado	4/10/2021	3	1,251	417
Tornado	4/10/2021	9	4,509	501
Tornado	4/10/2021	4	536	134
Tornado	4/10/2021	70	6,090	87
Tornado	4/10/2021	1	176	176
Tornado	4/10/2021	13	2,847	219
Tornado	4/10/2021	806	36,276	345
Tornado	4/10/2021	6	924	154
Tornado	4/10/2021	8	3,848	481
Tornado	4/10/2021	2	588	294
Tornado	4/10/2021	3	1,251	417
Tornado	4/10/2021	2	268	134
Tornado	4/10/2021	57	30,096	528
Tornado	4/10/2021	22	6,622	301
Tornado	4/10/2021	1	60	60

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	4	1,160	290
Tornado	4/10/2021	1	554	554
Tornado	4/10/2021	6	2,376	396
Tornado	4/10/2021	1	379	379
Tornado	4/10/2021	2	84	42
Tornado	4/10/2021	2	488	244
Tornado	4/10/2021	100	17,100	171
Tornado	4/10/2021	1	936	936
Tornado	4/10/2021	87	48,459	557
Tornado	4/10/2021	4	1,932	483
Tornado	4/10/2021	116	44,428	383
Tornado	4/10/2021	6	3,618	603
Tornado	4/10/2021	9	1,107	123
Tornado	4/10/2021	1	145	145
Tornado	4/10/2021	16	6,496	406
Tornado	4/10/2021	3	657	219
Tornado	4/10/2021	1	328	328
Tornado	4/10/2021	14	3,864	276
Tornado	4/10/2021	1	45	45
Tornado	4/10/2021	40	6,080	152
Tornado	4/10/2021	3	66	22
Tornado	4/10/2021	585	42,688	190
Tornado	4/10/2021	7	1,267	181
Tornado	4/10/2021	5	1,140	228
Tornado	4/10/2021	9	4,194	466
Tornado	4/10/2021	1	467	467
Tornado	4/10/2021	3	528	176
Tornado	4/10/2021	1	605	605
Tornado	4/10/2021	4	2,072	518
Tornado	4/10/2021	1	142	142
Tornado	4/10/2021	22	6,900	428
Tornado	4/10/2021	2	438	219
Tornado	4/10/2021	8	1,368	171
Tornado	4/10/2021	2	196	98
Tornado	4/10/2021	3	738	246
Tornado	4/10/2021	17	2,550	150
Tornado	4/10/2021	1	129	129
Tornado	4/10/2021	1	378	378
Tornado	4/10/2021	17	1,020	60
Tornado	4/10/2021	16	10,640	665
Tornado	4/10/2021	978	119,316	122
Tornado	4/10/2021	1	105	105
Tornado	4/10/2021	1	79	79

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	3	996	332
Tornado	4/10/2021	57	12,996	292
Tornado	4/10/2021	4	960	240
Tornado	4/10/2021	6	1,074	179
Tornado	4/10/2021	5	255	51
Tornado	4/10/2021	2	106	53
Tornado	4/10/2021	79	28,993	367
Tornado	4/10/2021	2	248	124
Tornado	4/10/2021	1	371	371
Tornado	4/10/2021	1	190	190
Tornado	4/10/2021	13	5,471	479
Tornado	4/10/2021	17	2,516	148
Tornado	4/10/2021	3	663	221
Tornado	4/10/2021	24	4,504	204
Tornado	4/10/2021	1,978	195,370	185
Tornado	4/10/2021	55	10,206	438
Tornado	4/10/2021	4	400	100
Tornado	4/10/2021	25	900	36
Tornado	4/10/2021	17	2,856	168
Tornado	4/10/2021	15	1,320	88
Tornado	4/10/2021	2	436	218
Tornado	4/10/2021	2	248	124
Tornado	4/10/2021	2	278	139
Tornado	4/10/2021	1	75	75
Tornado	4/10/2021	1,583	34,826	22
Tornado	4/10/2021	61	16,592	272
Tornado	4/10/2021	13	2,457	189
Tornado	4/10/2021	9	4,266	474
Tornado	4/10/2021	2	288	144
Tornado	4/10/2021	19	1,349	71
Tornado	4/10/2021	4	1,224	306
Tornado	4/10/2021	6	798	133
Tornado	4/10/2021	7	3,339	477
Tornado	4/10/2021	1,038	20,738	51
Tornado	4/10/2021	3	1,419	473
Tornado	4/10/2021	2	322	161
Tornado	4/10/2021	10	1,560	156
Tornado	4/10/2021	180	13,680	76
Tornado	4/10/2021	24	6,936	289
Tornado	4/10/2021	1	233	233
Tornado	4/10/2021	4	200	50
Tornado	4/10/2021	4	1,880	470
Tornado	4/10/2021	5	950	190

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	1	81	81
Tornado	4/10/2021	1,881	1,881	1
Tornado	4/10/2021	3,296	213,586	208
Tornado	4/10/2021	6	2,784	464
Tornado	4/10/2021	35	15,978	892
Tornado	4/10/2021	93	22,261	242
Tornado	4/10/2021	47	27,025	575
Tornado	4/10/2021	30	12,540	418
Tornado	4/10/2021	1	343	343
Tornado	4/10/2021	16	7,680	480
Tornado	4/10/2021	1	841	841
Tornado	4/10/2021	10	4,884	534
Tornado	4/10/2021	2	218	109
Tornado	4/10/2021	1	161	161
Tornado	4/10/2021	13	4,888	376
Tornado	4/10/2021	13	5,031	387
Tornado	4/10/2021	6	2,526	421
Tornado	4/10/2021	12	5,124	427
Tornado	4/10/2021	55	11,995	530
Tornado	4/10/2021	8	536	67
Tornado	4/10/2021	5	830	166
Tornado	4/10/2021	2	94	47
Tornado	4/10/2021	5	2,300	460
Tornado	4/10/2021	52	16,588	319
Tornado	4/10/2021	24	1,728	72
Tornado	4/10/2021	25	3,000	120
Tornado	4/10/2021	6	1,800	300
Tornado	4/10/2021	27	1,647	61
Tornado	4/10/2021	11	5,071	461
Tornado	4/10/2021	1	62	62
Tornado	4/10/2021	7	2,702	386
Tornado	4/10/2021	8	1,656	207
Tornado	4/10/2021	1	120	120
Tornado	4/10/2021	15	420	28
Tornado	4/10/2021	103	8,240	80
Tornado	4/10/2021	6	1,068	178
Tornado	4/10/2021	1	247	247
Tornado	4/10/2021	2	172	86
Tornado	4/10/2021	26	3,822	147
Tornado	4/10/2021	1	113	113
Tornado	4/10/2021	6	2,658	443
Tornado	4/10/2021	2	314	157
Tornado	4/10/2021	1	223	223

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/10/2021	1	7	7
Tornado	4/10/2021	1,445	17,340	12
Tornado	4/10/2021	1	166	166
Tornado	4/10/2021	3	879	293
Tornado	4/10/2021	13	1,781	137
Tornado	4/10/2021	16	6,992	437
Tornado	4/10/2021	1	6	6
Tornado	4/11/2021	2	388	194
Tornado	4/11/2021	1	20	20
Tornado	4/11/2021	4	1,980	495
Tornado	4/11/2021	1	93	93
Tornado	4/11/2021	51	357	7
Tornado	4/11/2021	4	180	45
Tornado	4/11/2021	49	7,590	161
Tornado	4/11/2021	1	71	71
Tornado	4/11/2021	5	125	25
Tornado	4/11/2021	1	77	77
Tornado	4/11/2021	1	318	318
Tornado	4/11/2021	2	236	118
Tornado	4/11/2021	2	556	278
Tornado	4/11/2021	8	824	103
Tornado	4/11/2021	4	1,324	331
Tornado	4/11/2021	44	2,596	59
Tornado	4/11/2021	1	140	140
Tornado	4/11/2021	1	92	92
Tornado	4/11/2021	1	78	78
Tornado	4/11/2021	1	99	99
Tornado	4/11/2021	45	1,800	40
Tornado	4/11/2021	40	1,840	46
Tornado	4/11/2021	31	1,922	62
Tornado	4/11/2021	4	240	60
Tornado	4/11/2021	11	1,188	108
Tornado	4/11/2021	3	300	100
Tornado	4/11/2021	3	414	138
Tornado	4/11/2021	16	464	29
Tornado	4/11/2021	4	288	72
Tornado	4/11/2021	4	140	35
Tornado	4/11/2021	2	80	40
Tornado	4/11/2021	1	145	145
Tornado	4/11/2021	107	7,597	71
Tornado	4/11/2021	380	15,200	40
Tornado	4/11/2021	2	440	220
Tornado	4/11/2021	1	118	118

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	25	2,825	113
Tornado	4/11/2021	2	348	174
Tornado	4/11/2021	1	84	84
Tornado	4/11/2021	3	168	56
Tornado	4/11/2021	1	82	82
Tornado	4/11/2021	50	1,900	38
Tornado	4/11/2021	5	200	40
Tornado	4/11/2021	4	1,244	311
Tornado	4/11/2021	1	317	317
Tornado	4/11/2021	1	153	153
Tornado	4/11/2021	2	432	216
Tornado	4/11/2021	1	134	134
Tornado	4/11/2021	2	52	26
Tornado	4/11/2021	1	73	73
Tornado	4/11/2021	1	64	64
Tornado	4/11/2021	9	495	55
Tornado	4/11/2021	12	1,500	125
Tornado	4/11/2021	1	143	143
Tornado	4/11/2021	1	40	40
Tornado	4/11/2021	1	206	206
Tornado	4/11/2021	9	351	39
Tornado	4/11/2021	284	27,264	96
Tornado	4/11/2021	1	276	276
Tornado	4/11/2021	12	1,242	231
Tornado	4/11/2021	2	114	57
Tornado	4/11/2021	3	2,511	837
Tornado	4/11/2021	8	1,112	139
Tornado	4/11/2021	1	173	173
Tornado	4/11/2021	513	28,728	56
Tornado	4/11/2021	86	9,288	108
Tornado	4/11/2021	985	31,520	32
Tornado	4/11/2021	1	152	152
Tornado	4/11/2021	2	386	193
Tornado	4/11/2021	5	220	44
Tornado	4/11/2021	5	1,335	267
Tornado	4/11/2021	48	3,264	68
Tornado	4/11/2021	3	3,312	1,104
Tornado	4/11/2021	42	2,520	60
Tornado	4/11/2021	5	1,780	356
Tornado	4/11/2021	1	71	71
Tornado	4/11/2021	4	1,116	279
Tornado	4/11/2021	5	980	196
Tornado	4/11/2021	2	164	82

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	9	3,861	429
Tornado	4/11/2021	2	86	43
Tornado	4/11/2021	10	1,590	159
Tornado	4/11/2021	8	1,608	201
Tornado	4/11/2021	1	156	156
Tornado	4/11/2021	1	160	160
Tornado	4/11/2021	6	300	50
Tornado	4/11/2021	4	352	88
Tornado	4/11/2021	10	4,000	400
Tornado	4/11/2021	8	616	77
Tornado	4/11/2021	1	254	254
Tornado	4/11/2021	19	1,748	92
Tornado	4/11/2021	7	1,694	242
Tornado	4/11/2021	1	224	224
Tornado	4/11/2021	67	4,087	61
Tornado	4/11/2021	1	498	498
Tornado	4/11/2021	26	7,670	295
Tornado	4/11/2021	2	466	233
Tornado	4/11/2021	1	62	62
Tornado	4/11/2021	26	3,614	139
Tornado	4/11/2021	11	2,838	258
Tornado	4/11/2021	4	908	227
Tornado	4/11/2021	1	201	201
Tornado	4/11/2021	31	36,487	1,177
Tornado	4/11/2021	5	2,035	407
Tornado	4/11/2021	13	2,015	155
Tornado	4/11/2021	8	2,392	299
Tornado	4/11/2021	67	8,442	126
Tornado	4/11/2021	36	12,960	360
Tornado	4/11/2021	40	11,880	297
Tornado	4/11/2021	75	9,600	128
Tornado	4/11/2021	172	28,552	166
Tornado	4/11/2021	2	268	134
Tornado	4/11/2021	50	7,300	146
Tornado	4/11/2021	12	936	78
Tornado	4/11/2021	851	2,553	3
Tornado	4/11/2021	1	807	807
Tornado	4/11/2021	12	1,860	155
Tornado	4/11/2021	6	2,496	416
Tornado	4/11/2021	14	10,934	781
Tornado	4/11/2021	118	13,098	111
Tornado	4/11/2021	5	305	61
Tornado	4/11/2021	84	5,376	64

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	1	1,324	1,324
Tornado	4/11/2021	23	9,545	415
Tornado	4/11/2021	5	955	191
Tornado	4/11/2021	1,514	28,403	310
Tornado	4/11/2021	98	8,134	83
Tornado	4/11/2021	19	3,154	166
Tornado	4/11/2021	4	1,792	448
Tornado	4/11/2021	6	1,134	189
Tornado	4/11/2021	3	636	212
Tornado	4/11/2021	5	2,080	416
Tornado	4/11/2021	22	4,252	290
Tornado	4/11/2021	61	10,370	170
Tornado	4/11/2021	109	48,378	1,378
Tornado	4/11/2021	14	5,600	400
Tornado	4/11/2021	18	6,786	377
Tornado	4/11/2021	38	12,426	327
Tornado	4/11/2021	2	3,658	1,829
Tornado	4/11/2021	2	46	23
Tornado	4/11/2021	2	1,578	789
Tornado	4/11/2021	29	14,790	510
Tornado	4/11/2021	3	1,026	342
Tornado	4/11/2021	72	5,472	76
Tornado	4/11/2021	7	462	66
Tornado	4/11/2021	1	550	550
Tornado	4/11/2021	128	21,120	165
Tornado	4/11/2021	14	2,240	160
Tornado	4/11/2021	3	1,791	597
Tornado	4/11/2021	273	110,520	814
Tornado	4/11/2021	3	1,038	346
Tornado	4/11/2021	8	2,788	659
Tornado	4/11/2021	20	1,220	61
Tornado	4/11/2021	103	20,687	829
Tornado	4/11/2021	4	1,356	339
Tornado	4/11/2021	47	14,581	1,202
Tornado	4/11/2021	28	17,920	844
Tornado	4/11/2021	3	5,691	1,897
Tornado	4/11/2021	3	324	108
Tornado	4/11/2021	4	1,324	331
Tornado	4/11/2021	16	1,024	64
Tornado	4/11/2021	3	1,950	650
Tornado	4/11/2021	1	663	663
Tornado	4/11/2021	5	2,595	519
Tornado	4/11/2021	156	29,296	522

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	2	104	52
Tornado	4/11/2021	97	24,347	251
Tornado	4/11/2021	25	1,700	68
Tornado	4/11/2021	2	1,554	777
Tornado	4/11/2021	90	22,910	636
Tornado	4/11/2021	2	586	293
Tornado	4/11/2021	1	150	150
Tornado	4/11/2021	43	9,073	211
Tornado	4/11/2021	59	24,668	752
Tornado	4/11/2021	827	5,789	7
Tornado	4/11/2021	66	14,652	222
Tornado	4/11/2021	4	884	221
Tornado	4/11/2021	1	1,288	1,288
Tornado	4/11/2021	2	94	47
Tornado	4/11/2021	3	1,011	337
Tornado	4/11/2021	4	5,536	1,384
Tornado	4/11/2021	38	16,098	651
Tornado	4/11/2021	9	4,761	529
Tornado	4/11/2021	1	197	197
Tornado	4/11/2021	26	1,170	45
Tornado	4/11/2021	33	10,065	305
Tornado	4/11/2021	13	11,011	847
Tornado	4/11/2021	10	1,280	128
Tornado	4/11/2021	1,612	100,681	106
Tornado	4/11/2021	36	14,465	715
Tornado	4/11/2021	59	1,592	548
Tornado	4/11/2021	71	2,690	302
Tornado	4/11/2021	50	26,550	531
Tornado	4/11/2021	9	4,608	512
Tornado	4/11/2021	395	23,366	108
Tornado	4/11/2021	5	95	19
Tornado	4/11/2021	1	747	747
Tornado	4/11/2021	3	78	26
Tornado	4/11/2021	1	204	204
Tornado	4/11/2021	66	26,706	895
Tornado	4/11/2021	48	22,254	493
Tornado	4/11/2021	6	4,806	801
Tornado	4/11/2021	2	1,054	527
Tornado	4/11/2021	10	6,770	677
Tornado	4/11/2021	1	1,186	1,186
Tornado	4/11/2021	30	43,320	1,444
Tornado	4/11/2021	1	1,485	1,485
Tornado	4/11/2021	2	432	216

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	3	4,083	1,361
Tornado	4/11/2021	227	211,791	933
Tornado	4/11/2021	32	12,064	377
Tornado	4/11/2021	31	8,835	285
Tornado	4/11/2021	154	48,786	775
Tornado	4/11/2021	77	37,782	1,446
Tornado	4/11/2021	1	754	754
Tornado	4/11/2021	525	92,925	177
Tornado	4/11/2021	32	21,664	677
Tornado	4/11/2021	19	3,762	198
Tornado	4/11/2021	6	7,224	1,204
Tornado	4/11/2021	8	11,576	1,447
Tornado	4/11/2021	854	431,296	1,339
Tornado	4/11/2021	40	33,160	829
Tornado	4/11/2021	5	7,780	1,556
Tornado	4/11/2021	35	22,855	653
Tornado	4/11/2021	37	64,343	1,739
Tornado	4/11/2021	27	18,522	686
Tornado	4/11/2021	4	1,432	358
Tornado	4/11/2021	76	40,888	538
Tornado	4/11/2021	7	6,881	983
Tornado	4/11/2021	80	20,240	253
Tornado	4/11/2021	36	24,807	697
Tornado	4/11/2021	1	1,193	1,193
Tornado	4/11/2021	14	7,322	523
Tornado	4/11/2021	7	2,443	349
Tornado	4/11/2021	1,916	287,400	150
Tornado	4/11/2021	2	1,196	598
Tornado	4/11/2021	7	4,809	687
Tornado	4/11/2021	1	101	101
Tornado	4/11/2021	1	520	520
Tornado	4/11/2021	15	2,328	163
Tornado	4/11/2021	1	685	685
Tornado	4/11/2021	30	10,710	357
Tornado	4/11/2021	103	28,056	372
Tornado	4/11/2021	17	15,147	891
Tornado	4/11/2021	81	57,996	716
Tornado	4/11/2021	9	2,331	259
Tornado	4/11/2021	1	911	911
Tornado	4/11/2021	16	7,856	491
Tornado	4/11/2021	22	12,716	578
Tornado	4/11/2021	92	53,236	827
Tornado	4/11/2021	11	902	82

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	166	46,480	280
Tornado	4/11/2021	35	30,765	879
Tornado	4/11/2021	32	1,216	38
Tornado	4/11/2021	11	6,974	634
Tornado	4/11/2021	7	6,370	910
Tornado	4/11/2021	8	2,608	326
Tornado	4/11/2021	4	3,840	960
Tornado	4/11/2021	1	1,132	1,132
Tornado	4/11/2021	28	14,056	502
Tornado	4/11/2021	31	16,492	532
Tornado	4/11/2021	55	27,115	493
Tornado	4/11/2021	24	13,344	556
Tornado	4/11/2021	36	7,992	222
Tornado	4/11/2021	1	1,228	1,228
Tornado	4/11/2021	151	65,987	437
Tornado	4/11/2021	38	8,982	825
Tornado	4/11/2021	98	10,978	347
Tornado	4/11/2021	17	23,417	1,486
Tornado	4/11/2021	9	7,821	869
Tornado	4/11/2021	61	26,535	435
Tornado	4/11/2021	43	18,662	434
Tornado	4/11/2021	1,955	204,224	167
Tornado	4/11/2021	5	4,175	835
Tornado	4/11/2021	9	6,624	736
Tornado	4/11/2021	34	26,690	785
Tornado	4/11/2021	12	5,124	427
Tornado	4/11/2021	559	85,527	153
Tornado	4/11/2021	3	4,041	1,347
Tornado	4/11/2021	5	150	30
Tornado	4/11/2021	5	2,845	569
Tornado	4/11/2021	1	560	560
Tornado	4/11/2021	32	4,016	391
Tornado	4/11/2021	30	13,950	465
Tornado	4/11/2021	10	3,170	317
Tornado	4/11/2021	5	3,940	788
Tornado	4/11/2021	1	312	312
Tornado	4/11/2021	1,170	136,402	728
Tornado	4/11/2021	121	35,411	731
Tornado	4/11/2021	30	12,720	424
Tornado	4/11/2021	733	171,522	234
Tornado	4/11/2021	12	2,004	167
Tornado	4/11/2021	3	2,199	733
Tornado	4/11/2021	4	1,840	460

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	8	6,216	777
Tornado	4/11/2021	3	2,313	771
Tornado	4/11/2021	2,133	178,020	86
Tornado	4/11/2021	68	5,984	88
Tornado	4/11/2021	78	6,240	80
Tornado	4/11/2021	191	163,346	934
Tornado	4/11/2021	55	5,280	96
Tornado	4/11/2021	12	1,992	166
Tornado	4/11/2021	76	53,884	709
Tornado	4/11/2021	13	11,869	913
Tornado	4/11/2021	1,232	146,608	119
Tornado	4/11/2021	2,165	134,240	216
Tornado	4/11/2021	39	13,221	339
Tornado	4/11/2021	667	32,683	49
Tornado	4/11/2021	33	20,097	609
Tornado	4/11/2021	66	42,502	1,357
Tornado	4/11/2021	1,246	382,522	307
Tornado	4/11/2021	961	21,142	22
Tornado	4/11/2021	12	8,748	729
Tornado	4/11/2021	91	57,876	636
Tornado	4/11/2021	2	1,996	998
Tornado	4/11/2021	8	808	101
Tornado	4/11/2021	82	5,904	72
Tornado	4/11/2021	1,684	113,046	185
Tornado	4/11/2021	34	10,268	302
Tornado	4/11/2021	10	2,030	203
Tornado	4/11/2021	6	54	9
Tornado	4/11/2021	3	501	167
Tornado	4/11/2021	4	1,676	419
Tornado	4/11/2021	29	6,090	210
Tornado	4/11/2021	29	4,031	139
Tornado	4/11/2021	15	3,675	245
Tornado	4/11/2021	1	1,087	1,087
Tornado	4/11/2021	7	3,955	565
Tornado	4/11/2021	514	107,940	210
Tornado	4/11/2021	36	2,484	69
Tornado	4/11/2021	36	8,640	240
Tornado	4/11/2021	1,527	229,390	780
Tornado	4/11/2021	25	20,075	803
Tornado	4/11/2021	1,099	117,701	215
Tornado	4/11/2021	27	18,846	698
Tornado	4/11/2021	9	11,673	1,297
Tornado	4/11/2021	36	21,276	591

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	23	17,089	743
Tornado	4/11/2021	55	33,583	1,097
Tornado	4/11/2021	20	20,000	1,000
Tornado	4/11/2021	2	380	190
Tornado	4/11/2021	864	126,144	146
Tornado	4/11/2021	12	7,920	660
Tornado	4/11/2021	1	576	576
Tornado	4/11/2021	1	25	25
Tornado	4/11/2021	74	35,076	474
Tornado	4/11/2021	16	9,392	587
Tornado	4/11/2021	4	768	192
Tornado	4/11/2021	9	5,454	606
Tornado	4/11/2021	18	3,474	193
Tornado	4/11/2021	14	5,292	378
Tornado	4/11/2021	40	9,720	243
Tornado	4/11/2021	15	5,145	343
Tornado	4/11/2021	1	757	757
Tornado	4/11/2021	11	4,202	382
Tornado	4/11/2021	21	9,954	474
Tornado	4/11/2021	18	6,336	352
Tornado	4/11/2021	14	6,188	442
Tornado	4/11/2021	43	9,460	220
Tornado	4/11/2021	22	15,752	716
Tornado	4/11/2021	50	7,100	142
Tornado	4/11/2021	56	20,053	365
Tornado	4/11/2021	10	6,180	618
Tornado	4/11/2021	3	4,239	1,413
Tornado	4/11/2021	9	7,416	824
Tornado	4/11/2021	12	2,568	214
Tornado	4/11/2021	17	4,573	269
Tornado	4/11/2021	33	9,933	301
Tornado	4/11/2021	8	3,488	436
Tornado	4/11/2021	1	298	298
Tornado	4/11/2021	6	1,488	248
Tornado	4/11/2021	6	6,744	1,124
Tornado	4/11/2021	1	822	822
Tornado	4/11/2021	4	3,164	791
Tornado	4/11/2021	83	19,994	598
Tornado	4/11/2021	4	3,460	865
Tornado	4/11/2021	4	1,544	386
Tornado	4/11/2021	3	1,854	618
Tornado	4/11/2021	13	5,148	396
Tornado	4/11/2021	6	5,376	896

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	3	2,424	808
Tornado	4/11/2021	1	315	315
Tornado	4/11/2021	12	5,340	445
Tornado	4/11/2021	7	6,272	896
Tornado	4/11/2021	20	12,820	641
Tornado	4/11/2021	33	24,321	737
Tornado	4/11/2021	190	83,030	437
Tornado	4/11/2021	10	2,640	264
Tornado	4/11/2021	34	12,104	356
Tornado	4/11/2021	1	1,270	1,270
Tornado	4/11/2021	149	23,675	199
Tornado	4/11/2021	34	1,428	42
Tornado	4/11/2021	48	2,400	50
Tornado	4/11/2021	2,134	72,395	48
Tornado	4/11/2021	1	153	153
Tornado	4/11/2021	56	36,456	651
Tornado	4/11/2021	121	57,273	513
Tornado	4/11/2021	1	391	391
Tornado	4/11/2021	2	1,286	643
Tornado	4/11/2021	18	16,884	938
Tornado	4/11/2021	12	11,100	925
Tornado	4/11/2021	1	858	858
Tornado	4/11/2021	10	9,310	931
Tornado	4/11/2021	4	1,312	328
Tornado	4/11/2021	8	1,832	229
Tornado	4/11/2021	7	2,464	352
Tornado	4/11/2021	3	993	331
Tornado	4/11/2021	1	186	186
Tornado	4/11/2021	1	186	186
Tornado	4/11/2021	12	2,988	249
Tornado	4/11/2021	7	1,288	184
Tornado	4/11/2021	8	10,416	1,302
Tornado	4/11/2021	10	5,380	538
Tornado	4/11/2021	25	13,725	549
Tornado	4/11/2021	1	477	477
Tornado	4/11/2021	1	544	544
Tornado	4/11/2021	1	36	36
Tornado	4/11/2021	7	4,025	575
Tornado	4/11/2021	14	15,764	1,126
Tornado	4/11/2021	10	3,660	366
Tornado	4/11/2021	6	2,184	364
Tornado	4/11/2021	3	1,089	363
Tornado	4/11/2021	11	3,982	362

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	12	4,320	360
Tornado	4/11/2021	10	3,530	353
Tornado	4/11/2021	7	2,387	341
Tornado	4/11/2021	9	4,455	495
Tornado	4/11/2021	4	1,636	409
Tornado	4/11/2021	29	7,598	262
Tornado	4/11/2021	1	1,006	1,006
Tornado	4/11/2021	1	1,239	1,239
Tornado	4/11/2021	593	26,685	45
Tornado	4/11/2021	1	934	934
Tornado	4/11/2021	56	9,520	170
Tornado	4/11/2021	16	5,744	359
Tornado	4/11/2021	2	1,662	831
Tornado	4/11/2021	9	3,834	426
Tornado	4/11/2021	1	78	78
Tornado	4/11/2021	18	14,472	822
Tornado	4/11/2021	69	21,528	312
Tornado	4/11/2021	1	1,355	1,355
Tornado	4/11/2021	8	2,344	293
Tornado	4/11/2021	43	20,726	482
Tornado	4/11/2021	13	2,925	225
Tornado	4/11/2021	6	912	152
Tornado	4/11/2021	25	11,900	476
Tornado	4/11/2021	54	5,562	103
Tornado	4/11/2021	4	1,484	371
Tornado	4/11/2021	1	101	101
Tornado	4/11/2021	43	688	16
Tornado	4/11/2021	7	21	3
Tornado	4/11/2021	1	285	285
Tornado	4/11/2021	12	3,696	308
Tornado	4/11/2021	101	15,968	280
Tornado	4/11/2021	1	788	788
Tornado	4/11/2021	6	3,666	611
Tornado	4/11/2021	1	498	498
Tornado	4/11/2021	1	299	299
Tornado	4/11/2021	5	870	174
Tornado	4/11/2021	1	323	323
Tornado	4/11/2021	4	772	193
Tornado	4/11/2021	391	16,031	41
Tornado	4/11/2021	1	566	566
Tornado	4/11/2021	1	1	1
Tornado	4/11/2021	1	116	116
Tornado	4/11/2021	146	40,880	280

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	1	220	220
Tornado	4/11/2021	2	992	496
Tornado	4/11/2021	27	10,422	386
Tornado	4/11/2021	2	234	117
Tornado	4/11/2021	32	15,840	495
Tornado	4/11/2021	23	10,948	476
Tornado	4/11/2021	1	567	567
Tornado	4/11/2021	2	100	50
Tornado	4/11/2021	10	2,370	237
Tornado	4/11/2021	2	2,178	1,089
Tornado	4/11/2021	23	2,323	101
Tornado	4/11/2021	7	770	110
Tornado	4/11/2021	5	7,825	1,565
Tornado	4/11/2021	1	1,285	1,285
Tornado	4/11/2021	64	24,850	426
Tornado	4/11/2021	76	5,320	70
Tornado	4/11/2021	16	1,264	79
Tornado	4/11/2021	5	155	31
Tornado	4/11/2021	2	816	408
Tornado	4/11/2021	1	96	96
Tornado	4/11/2021	18	954	53
Tornado	4/11/2021	1	298	298
Tornado	4/11/2021	1	632	632
Tornado	4/11/2021	16	5,072	317
Tornado	4/11/2021	8	576	72
Tornado	4/11/2021	1	205	205
Tornado	4/11/2021	34	8,126	239
Tornado	4/11/2021	1	960	960
Tornado	4/11/2021	392	128,534	1,306
Tornado	4/11/2021	4	540	135
Tornado	4/11/2021	4	4,804	1,201
Tornado	4/11/2021	2	1,436	718
Tornado	4/11/2021	47	21,385	455
Tornado	4/11/2021	11	8,064	849
Tornado	4/11/2021	15	15,330	1,022
Tornado	4/11/2021	50	36,650	733
Tornado	4/11/2021	6	36	6
Tornado	4/11/2021	66	26,730	405
Tornado	4/11/2021	4	992	248
Tornado	4/11/2021	4	4,324	1,081
Tornado	4/11/2021	21	336	16
Tornado	4/11/2021	25	14,475	579
Tornado	4/11/2021	1	1,098	1,098

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	1	1,005	1,005
Tornado	4/11/2021	15	1,350	90
Tornado	4/11/2021	5	330	66
Tornado	4/11/2021	11	9,009	819
Tornado	4/11/2021	1	71	71
Tornado	4/11/2021	3	963	321
Tornado	4/11/2021	2,728	123,359	174
Tornado	4/11/2021	1	1,246	1,246
Tornado	4/11/2021	68	13,035	850
Tornado	4/11/2021	1	191	191
Tornado	4/11/2021	1,443	85,407	232
Tornado	4/11/2021	95	3,895	41
Tornado	4/11/2021	2	2,504	1,252
Tornado	4/11/2021	73	5,256	72
Tornado	4/11/2021	10	2,060	206
Tornado	4/11/2021	5	730	146
Tornado	4/11/2021	1	277	277
Tornado	4/11/2021	1	376	376
Tornado	4/11/2021	185	23,125	125
Tornado	4/11/2021	1	275	275
Tornado	4/11/2021	1	326	326
Tornado	4/11/2021	15	6,315	421
Tornado	4/11/2021	2	1,158	579
Tornado	4/11/2021	1	982	982
Tornado	4/11/2021	1	56	56
Tornado	4/11/2021	2	2,776	1,388
Tornado	4/11/2021	35	22,120	632
Tornado	4/11/2021	1	53	53
Tornado	4/11/2021	13	17,395	1,771
Tornado	4/11/2021	10	10,840	1,084
Tornado	4/11/2021	1	21	21
Tornado	4/11/2021	2	874	437
Tornado	4/11/2021	1	18	18
Tornado	4/11/2021	1	46	46
Tornado	4/11/2021	4	672	168
Tornado	4/11/2021	12	648	54
Tornado	4/11/2021	19	3,382	178
Tornado	4/11/2021	1	592	592
Tornado	4/11/2021	1	1,194	1,194
Tornado	4/11/2021	14	6,720	480
Tornado	4/11/2021	1	839	839
Tornado	4/11/2021	1	591	591
Tornado	4/11/2021	1	1,100	1,100

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	4	1,008	252
Tornado	4/11/2021	625	203,804	332
Tornado	4/11/2021	2	1,264	632
Tornado	4/11/2021	2	554	277
Tornado	4/11/2021	1	207	207
Tornado	4/11/2021	28	41,888	1,496
Tornado	4/11/2021	1	881	881
Tornado	4/11/2021	5	1,145	229
Tornado	4/11/2021	68	8,908	131
Tornado	4/11/2021	1	44	44
Tornado	4/11/2021	1	256	256
Tornado	4/11/2021	4	668	167
Tornado	4/11/2021	4	660	165
Tornado	4/11/2021	3	498	166
Tornado	4/11/2021	4	664	166
Tornado	4/11/2021	1	163	163
Tornado	4/11/2021	1	164	164
Tornado	4/11/2021	2	326	163
Tornado	4/11/2021	3	483	161
Tornado	4/11/2021	1	160	160
Tornado	4/11/2021	1	158	158
Tornado	4/11/2021	5	780	156
Tornado	4/11/2021	4	620	155
Tornado	4/11/2021	3	453	151
Tornado	4/11/2021	1	819	819
Tornado	4/11/2021	1	34	34
Tornado	4/11/2021	16	281	41
Tornado	4/11/2021	7	1,155	165
Tornado	4/11/2021	1	813	813
Tornado	4/11/2021	18	2,952	164
Tornado	4/11/2021	1	343	343
Tornado	4/11/2021	4	3,420	855
Tornado	4/11/2021	17	3,400	200
Tornado	4/11/2021	7	1,589	227
Tornado	4/11/2021	4	504	126
Tornado	4/11/2021	1	328	328
Tornado	4/11/2021	3	267	89
Tornado	4/11/2021	1	1,026	1,026
Tornado	4/11/2021	5	135	27
Tornado	4/11/2021	1	45	45
Tornado	4/11/2021	4	3,888	972
Tornado	4/11/2021	2	542	271
Tornado	4/11/2021	2	204	102

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	4/11/2021	4	3,160	790
Tornado	4/11/2021	1	83	83
Tornado	4/11/2021	6	726	121
Tornado	4/11/2021	19	6,281	755
Tornado	4/11/2021	16	9,968	623
Tornado	4/11/2021	25	16,100	644
Tornado	4/11/2021	7	518	74
Tornado	4/11/2021	2	1,678	839
Tornado	4/11/2021	15	10,320	688
Tornado	4/11/2021	1	208	208
Tornado	4/11/2021	1	4	4
Tornado	4/11/2021	1	365	365
Tornado	4/11/2021	1	243	243
Tornado	4/11/2021	1	332	332
Tornado	4/11/2021	1	32	32
Tornado	4/11/2021	9	1,188	132
Tornado	4/11/2021	4	352	88
Tornado	4/11/2021	34	15,300	450
Tornado	4/11/2021	1	102	102
Tornado	4/11/2021	3	1,590	530
Tornado	4/11/2021	34	26,180	770
Tornado	4/11/2021	58	23,548	406
Tornado	4/11/2021	1	171	171
Tornado	4/11/2021	1	894	894
Tornado	4/11/2021	27	6,210	230
Tornado	4/11/2021	7	10,150	1,450
Tornado	4/11/2021	2	2,016	1,008
Tornado	4/11/2021	1	369	369
Tornado	4/11/2021	3	969	323
Tornado	4/11/2021	10	1,610	161
Tornado	4/11/2021	1	948	948
Tornado	4/11/2021	1	273	273
Tropical Storm Claud	6/19/2021	1	81	81
Tropical Storm Claud	6/19/2021	2	152	76
Tropical Storm Claud	6/19/2021	1	174	174
Tropical Storm Claud	6/19/2021	4	356	89
Tropical Storm Claud	6/19/2021	209	19,437	93
Tropical Storm Claud	6/19/2021	6	630	105
Tropical Storm Claud	6/19/2021	3	189	63
Tropical Storm Claud	6/19/2021	1	138	138
Tropical Storm Claud	6/19/2021	2	84	42
Tropical Storm Claud	6/19/2021	86	11,104	266
Tropical Storm Claud	6/19/2021	1	137	137

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/19/2021	2	58	29
Tropical Storm Claud	6/19/2021	1	42	42
Tropical Storm Claud	6/19/2021	7	91	13
Tropical Storm Claud	6/19/2021	5	170	34
Tropical Storm Claud	6/19/2021	1	16	16
Tropical Storm Claud	6/19/2021	1	161	161
Tropical Storm Claud	6/19/2021	1	181	181
Tropical Storm Claud	6/19/2021	2	38	19
Tropical Storm Claud	6/19/2021	1	266	266
Tropical Storm Claud	6/19/2021	3	777	259
Tropical Storm Claud	6/19/2021	1	556	556
Tropical Storm Claud	6/19/2021	1	164	164
Tropical Storm Claud	6/19/2021	57	10,716	188
Tropical Storm Claud	6/19/2021	1	23	23
Tropical Storm Claud	6/19/2021	1	57	57
Tropical Storm Claud	6/19/2021	77	6,930	90
Tropical Storm Claud	6/19/2021	8	728	91
Tropical Storm Claud	6/19/2021	14	1,848	132
Tropical Storm Claud	6/19/2021	1	219	219
Tropical Storm Claud	6/19/2021	1	76	76
Tropical Storm Claud	6/19/2021	2	250	125
Tropical Storm Claud	6/19/2021	9	1,305	145
Tropical Storm Claud	6/19/2021	21	1,974	94
Tropical Storm Claud	6/19/2021	1	212	212
Tropical Storm Claud	6/19/2021	1	771	771
Tropical Storm Claud	6/19/2021	1	290	290
Tropical Storm Claud	6/19/2021	34	5,338	157
Tropical Storm Claud	6/19/2021	2	88	44
Tropical Storm Claud	6/19/2021	19	2,337	123
Tropical Storm Claud	6/19/2021	4	548	137
Tropical Storm Claud	6/19/2021	4	2,916	729
Tropical Storm Claud	6/19/2021	3	207	69
Tropical Storm Claud	6/19/2021	1	69	69
Tropical Storm Claud	6/19/2021	1	32	32
Tropical Storm Claud	6/19/2021	1	19	19
Tropical Storm Claud	6/20/2021	2	494	247
Tropical Storm Claud	6/20/2021	26	1,846	71
Tropical Storm Claud	6/20/2021	15	3,075	205
Tropical Storm Claud	6/20/2021	8	5,752	719
Tropical Storm Claud	6/20/2021	8	520	65
Tropical Storm Claud	6/20/2021	14	3,010	215
Tropical Storm Claud	6/20/2021	8	3,112	389
Tropical Storm Claud	6/20/2021	3	1,617	539

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	1,014	26,934	45
Tropical Storm Claud	6/20/2021	18	2,232	124
Tropical Storm Claud	6/20/2021	5	925	185
Tropical Storm Claud	6/20/2021	5	915	183
Tropical Storm Claud	6/20/2021	27	2,943	109
Tropical Storm Claud	6/20/2021	16	1,296	81
Tropical Storm Claud	6/20/2021	52	13,572	261
Tropical Storm Claud	6/20/2021	5	385	77
Tropical Storm Claud	6/20/2021	37	9,472	256
Tropical Storm Claud	6/20/2021	1	90	90
Tropical Storm Claud	6/20/2021	5	405	81
Tropical Storm Claud	6/20/2021	27	2,997	111
Tropical Storm Claud	6/20/2021	1	90	90
Tropical Storm Claud	6/20/2021	10	4,260	426
Tropical Storm Claud	6/20/2021	3	876	292
Tropical Storm Claud	6/20/2021	625	33,935	539
Tropical Storm Claud	6/20/2021	30	22,980	766
Tropical Storm Claud	6/20/2021	1	60	60
Tropical Storm Claud	6/20/2021	1	85	85
Tropical Storm Claud	6/20/2021	4	300	75
Tropical Storm Claud	6/20/2021	36	1,620	45
Tropical Storm Claud	6/20/2021	1	163	163
Tropical Storm Claud	6/20/2021	8	320	40
Tropical Storm Claud	6/20/2021	23	1,702	74
Tropical Storm Claud	6/20/2021	1	152	152
Tropical Storm Claud	6/20/2021	1	147	147
Tropical Storm Claud	6/20/2021	1	15	15
Tropical Storm Claud	6/20/2021	1	249	249
Tropical Storm Claud	6/20/2021	20	1,740	87
Tropical Storm Claud	6/20/2021	21	1,827	87
Tropical Storm Claud	6/20/2021	1	118	118
Tropical Storm Claud	6/20/2021	4	1,692	423
Tropical Storm Claud	6/20/2021	1	112	112
Tropical Storm Claud	6/20/2021	8	504	63
Tropical Storm Claud	6/20/2021	8	440	55
Tropical Storm Claud	6/20/2021	8	1,472	184
Tropical Storm Claud	6/20/2021	1	528	528
Tropical Storm Claud	6/20/2021	1	1,387	1,387
Tropical Storm Claud	6/20/2021	3	564	188
Tropical Storm Claud	6/20/2021	3	474	158
Tropical Storm Claud	6/20/2021	4	428	107
Tropical Storm Claud	6/20/2021	31	2,945	95
Tropical Storm Claud	6/20/2021	8	1,800	225

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	15	1,920	128
Tropical Storm Claud	6/20/2021	109	8,611	79
Tropical Storm Claud	6/20/2021	80	1,200	15
Tropical Storm Claud	6/20/2021	1	480	480
Tropical Storm Claud	6/20/2021	6	276	46
Tropical Storm Claud	6/20/2021	2	460	368
Tropical Storm Claud	6/20/2021	1	302	302
Tropical Storm Claud	6/20/2021	1	9	9
Tropical Storm Claud	6/20/2021	23	3,220	140
Tropical Storm Claud	6/20/2021	6	390	65
Tropical Storm Claud	6/20/2021	3	90	30
Tropical Storm Claud	6/20/2021	5	1,130	226
Tropical Storm Claud	6/20/2021	1	155	155
Tropical Storm Claud	6/20/2021	3	141	47
Tropical Storm Claud	6/20/2021	1	10	10
Tropical Storm Claud	6/20/2021	1	165	165
Tropical Storm Claud	6/20/2021	5	2,230	446
Tropical Storm Claud	6/20/2021	4	216	54
Tropical Storm Claud	6/20/2021	1	21	21
Tropical Storm Claud	6/20/2021	7	2,667	381
Tropical Storm Claud	6/20/2021	1	220	220
Tropical Storm Claud	6/20/2021	1	65	65
Tropical Storm Claud	6/20/2021	1	618	618
Tropical Storm Claud	6/20/2021	42	15,330	365
Tropical Storm Claud	6/20/2021	20	2,320	116
Tropical Storm Claud	6/20/2021	1	485	485
Tropical Storm Claud	6/20/2021	6	474	79
Tropical Storm Claud	6/20/2021	9	810	90
Tropical Storm Claud	6/20/2021	16	880	55
Tropical Storm Claud	6/20/2021	4	796	199
Tropical Storm Claud	6/20/2021	1	119	119
Tropical Storm Claud	6/20/2021	6	2,826	471
Tropical Storm Claud	6/20/2021	7	2,471	353
Tropical Storm Claud	6/20/2021	1	433	433
Tropical Storm Claud	6/20/2021	21	882	42
Tropical Storm Claud	6/20/2021	3	333	111
Tropical Storm Claud	6/20/2021	212	63,600	300
Tropical Storm Claud	6/20/2021	1	44	44
Tropical Storm Claud	6/20/2021	12	2,820	235
Tropical Storm Claud	6/20/2021	4	192	48
Tropical Storm Claud	6/20/2021	1	46	46
Tropical Storm Claud	6/20/2021	2	606	303
Tropical Storm Claud	6/20/2021	1	97	97

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	10	390	39
Tropical Storm Claud	6/20/2021	63	9,400	160
Tropical Storm Claud	6/20/2021	2	282	141
Tropical Storm Claud	6/20/2021	6	72	12
Tropical Storm Claud	6/20/2021	9	450	50
Tropical Storm Claud	6/20/2021	8	448	56
Tropical Storm Claud	6/20/2021	285	1,140	4
Tropical Storm Claud	6/20/2021	8	3,824	478
Tropical Storm Claud	6/20/2021	9	945	105
Tropical Storm Claud	6/20/2021	9	666	74
Tropical Storm Claud	6/20/2021	19	2,926	154
Tropical Storm Claud	6/20/2021	1	73	73
Tropical Storm Claud	6/20/2021	19	1,197	63
Tropical Storm Claud	6/20/2021	1	22	22
Tropical Storm Claud	6/20/2021	4	452	113
Tropical Storm Claud	6/20/2021	185	25,715	139
Tropical Storm Claud	6/20/2021	2	544	272
Tropical Storm Claud	6/20/2021	53	3,180	60
Tropical Storm Claud	6/20/2021	330	19,470	59
Tropical Storm Claud	6/20/2021	6	1,890	315
Tropical Storm Claud	6/20/2021	43	2,365	55
Tropical Storm Claud	6/20/2021	1	233	233
Tropical Storm Claud	6/20/2021	9	2,232	248
Tropical Storm Claud	6/20/2021	57	57	1
Tropical Storm Claud	6/20/2021	12	1,728	144
Tropical Storm Claud	6/20/2021	19	4,712	248
Tropical Storm Claud	6/20/2021	2	680	340
Tropical Storm Claud	6/20/2021	6	366	61
Tropical Storm Claud	6/20/2021	1	219	219
Tropical Storm Claud	6/20/2021	1	193	193
Tropical Storm Claud	6/20/2021	10	1,320	132
Tropical Storm Claud	6/20/2021	9	3,663	407
Tropical Storm Claud	6/20/2021	1	97	97
Tropical Storm Claud	6/20/2021	1	816	816
Tropical Storm Claud	6/20/2021	9	1,602	178
Tropical Storm Claud	6/20/2021	1,460	8,906	8
Tropical Storm Claud	6/20/2021	10	1,520	152
Tropical Storm Claud	6/20/2021	8	2,312	289
Tropical Storm Claud	6/20/2021	9	4,284	476
Tropical Storm Claud	6/20/2021	10	1,890	189
Tropical Storm Claud	6/20/2021	7	1,379	197
Tropical Storm Claud	6/20/2021	20	2,107	198
Tropical Storm Claud	6/20/2021	8	1,952	244

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	1	361	361
Tropical Storm Claud	6/20/2021	1	28	28
Tropical Storm Claud	6/20/2021	8	1,440	180
Tropical Storm Claud	6/20/2021	6	474	79
Tropical Storm Claud	6/20/2021	57	13,509	237
Tropical Storm Claud	6/20/2021	39	4,563	117
Tropical Storm Claud	6/20/2021	19	2,584	136
Tropical Storm Claud	6/20/2021	3	513	171
Tropical Storm Claud	6/20/2021	53	3,922	74
Tropical Storm Claud	6/20/2021	4	312	78
Tropical Storm Claud	6/20/2021	6	1,896	316
Tropical Storm Claud	6/20/2021	28	2,548	91
Tropical Storm Claud	6/20/2021	138	12,282	89
Tropical Storm Claud	6/20/2021	16	416	26
Tropical Storm Claud	6/20/2021	13	2,210	170
Tropical Storm Claud	6/20/2021	3	480	160
Tropical Storm Claud	6/20/2021	22	2,178	99
Tropical Storm Claud	6/20/2021	3	519	173
Tropical Storm Claud	6/20/2021	1	172	172
Tropical Storm Claud	6/20/2021	22	6,226	283
Tropical Storm Claud	6/20/2021	5	655	272
Tropical Storm Claud	6/20/2021	17	2,065	253
Tropical Storm Claud	6/20/2021	14	1,531	218
Tropical Storm Claud	6/20/2021	36	2,916	81
Tropical Storm Claud	6/20/2021	8	1,928	241
Tropical Storm Claud	6/20/2021	38	14,668	386
Tropical Storm Claud	6/20/2021	1	121	121
Tropical Storm Claud	6/20/2021	4	1,292	323
Tropical Storm Claud	6/20/2021	38	5,545	267
Tropical Storm Claud	6/20/2021	6	978	163
Tropical Storm Claud	6/20/2021	18	3,420	342
Tropical Storm Claud	6/20/2021	244	27,399	397
Tropical Storm Claud	6/20/2021	74	6,808	92
Tropical Storm Claud	6/20/2021	4	632	158
Tropical Storm Claud	6/20/2021	2	610	305
Tropical Storm Claud	6/20/2021	4	972	243
Tropical Storm Claud	6/20/2021	65	14,560	224
Tropical Storm Claud	6/20/2021	5	1,410	282
Tropical Storm Claud	6/20/2021	53	3,392	64
Tropical Storm Claud	6/20/2021	3	387	129
Tropical Storm Claud	6/20/2021	1	121	121
Tropical Storm Claud	6/20/2021	2	472	236
Tropical Storm Claud	6/20/2021	42	20,259	1,191

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	41	2,624	64
Tropical Storm Claud	6/20/2021	3	123	41
Tropical Storm Claud	6/20/2021	4	396	99
Tropical Storm Claud	6/20/2021	1	72	72
Tropical Storm Claud	6/20/2021	3	1,104	368
Tropical Storm Claud	6/20/2021	610	610	1
Tropical Storm Claud	6/20/2021	11	957	87
Tropical Storm Claud	6/20/2021	8	1,080	135
Tropical Storm Claud	6/20/2021	12	4,056	338
Tropical Storm Claud	6/20/2021	12	2,400	200
Tropical Storm Claud	6/20/2021	132	21,516	163
Tropical Storm Claud	6/20/2021	14	3,052	218
Tropical Storm Claud	6/20/2021	3	984	328
Tropical Storm Claud	6/20/2021	17	1,474	173
Tropical Storm Claud	6/20/2021	4	480	120
Tropical Storm Claud	6/20/2021	6	1,074	179
Tropical Storm Claud	6/20/2021	2	536	268
Tropical Storm Claud	6/20/2021	4	196	49
Tropical Storm Claud	6/20/2021	8	2,376	297
Tropical Storm Claud	6/20/2021	23	1,886	82
Tropical Storm Claud	6/20/2021	9	1,737	193
Tropical Storm Claud	6/20/2021	80	40,880	511
Tropical Storm Claud	6/20/2021	4	704	176
Tropical Storm Claud	6/20/2021	12	3,396	283
Tropical Storm Claud	6/20/2021	9	711	79
Tropical Storm Claud	6/20/2021	12	444	37
Tropical Storm Claud	6/20/2021	63	12,915	205
Tropical Storm Claud	6/20/2021	192	1,344	7
Tropical Storm Claud	6/20/2021	15	5,220	348
Tropical Storm Claud	6/20/2021	1	126	126
Tropical Storm Claud	6/20/2021	8	1,728	216
Tropical Storm Claud	6/20/2021	4	516	129
Tropical Storm Claud	6/20/2021	56	8,008	143
Tropical Storm Claud	6/20/2021	49	4,214	86
Tropical Storm Claud	6/20/2021	26	6,756	419
Tropical Storm Claud	6/20/2021	36	8,832	524
Tropical Storm Claud	6/20/2021	7	3,164	452
Tropical Storm Claud	6/20/2021	7	735	105
Tropical Storm Claud	6/20/2021	2	256	128
Tropical Storm Claud	6/20/2021	10	3,420	342
Tropical Storm Claud	6/20/2021	13	1,846	142
Tropical Storm Claud	6/20/2021	23	2,392	104
Tropical Storm Claud	6/20/2021	33	5,916	410

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	10	80	8
Tropical Storm Claud	6/20/2021	24	8,040	335
Tropical Storm Claud	6/20/2021	2	126	63
Tropical Storm Claud	6/20/2021	1	205	205
Tropical Storm Claud	6/20/2021	25	1,850	74
Tropical Storm Claud	6/20/2021	22	5,179	485
Tropical Storm Claud	6/20/2021	26	4,991	428
Tropical Storm Claud	6/20/2021	17	1,513	89
Tropical Storm Claud	6/20/2021	9	2,979	331
Tropical Storm Claud	6/20/2021	1	122	122
Tropical Storm Claud	6/20/2021	1	35	35
Tropical Storm Claud	6/20/2021	11	1,485	135
Tropical Storm Claud	6/20/2021	43	1,763	41
Tropical Storm Claud	6/20/2021	23	5,980	260
Tropical Storm Claud	6/20/2021	52	12,500	304
Tropical Storm Claud	6/20/2021	1	154	154
Tropical Storm Claud	6/20/2021	10	2,730	273
Tropical Storm Claud	6/20/2021	9	1,602	178
Tropical Storm Claud	6/20/2021	2	1,092	546
Tropical Storm Claud	6/20/2021	8	1,336	167
Tropical Storm Claud	6/20/2021	1	60	60
Tropical Storm Claud	6/20/2021	6	1,788	298
Tropical Storm Claud	6/20/2021	41	3,544	407
Tropical Storm Claud	6/20/2021	10	1,310	131
Tropical Storm Claud	6/20/2021	17	3,349	197
Tropical Storm Claud	6/20/2021	7	1,078	154
Tropical Storm Claud	6/20/2021	31	5,395	397
Tropical Storm Claud	6/20/2021	1	131	131
Tropical Storm Claud	6/20/2021	4	6,444	1,611
Tropical Storm Claud	6/20/2021	8	2,848	356
Tropical Storm Claud	6/20/2021	1	210	210
Tropical Storm Claud	6/20/2021	10	1,890	189
Tropical Storm Claud	6/20/2021	128	11,950	275
Tropical Storm Claud	6/20/2021	4	1,188	297
Tropical Storm Claud	6/20/2021	6	12	2
Tropical Storm Claud	6/20/2021	8	2,856	357
Tropical Storm Claud	6/20/2021	16	352	22
Tropical Storm Claud	6/20/2021	1	99	99
Tropical Storm Claud	6/20/2021	117	16,508	268
Tropical Storm Claud	6/20/2021	7	1,316	188
Tropical Storm Claud	6/20/2021	1	10	10
Tropical Storm Claud	6/20/2021	1	48	48
Tropical Storm Claud	6/20/2021	1	564	564

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	10	2,790	279
Tropical Storm Claud	6/20/2021	43	13,158	306
Tropical Storm Claud	6/20/2021	13	3,167	506
Tropical Storm Claud	6/20/2021	1	130	130
Tropical Storm Claud	6/20/2021	13	741	57
Tropical Storm Claud	6/20/2021	8	2,568	322
Tropical Storm Claud	6/20/2021	9	477	53
Tropical Storm Claud	6/20/2021	3,399	13,596	4
Tropical Storm Claud	6/20/2021	763	104,364	232
Tropical Storm Claud	6/20/2021	31	1,178	38
Tropical Storm Claud	6/20/2021	3	501	167
Tropical Storm Claud	6/20/2021	72	6,984	97
Tropical Storm Claud	6/20/2021	1	396	396
Tropical Storm Claud	6/20/2021	60	58,906	1,062
Tropical Storm Claud	6/20/2021	4	304	76
Tropical Storm Claud	6/20/2021	23	13,018	566
Tropical Storm Claud	6/20/2021	2	402	201
Tropical Storm Claud	6/20/2021	1	76	76
Tropical Storm Claud	6/20/2021	8	7,912	989
Tropical Storm Claud	6/20/2021	1	156	156
Tropical Storm Claud	6/20/2021	77	9,823	131
Tropical Storm Claud	6/20/2021	1	85	85
Tropical Storm Claud	6/20/2021	2	172	86
Tropical Storm Claud	6/20/2021	11	2,431	221
Tropical Storm Claud	6/20/2021	4	104	26
Tropical Storm Claud	6/20/2021	1	60	60
Tropical Storm Claud	6/20/2021	18	792	44
Tropical Storm Claud	6/20/2021	6	342	57
Tropical Storm Claud	6/20/2021	17	9,435	555
Tropical Storm Claud	6/20/2021	1	327	327
Tropical Storm Claud	6/20/2021	11	121	11
Tropical Storm Claud	6/20/2021	36	2,412	67
Tropical Storm Claud	6/20/2021	1	121	121
Tropical Storm Claud	6/20/2021	1	195	195
Tropical Storm Claud	6/20/2021	1	82	82
Tropical Storm Claud	6/20/2021	1	46	46
Tropical Storm Claud	6/20/2021	2	1,466	733
Tropical Storm Claud	6/20/2021	1	392	392
Tropical Storm Claud	6/20/2021	5	7,670	1,534
Tropical Storm Claud	6/20/2021	1	48	48
Tropical Storm Claud	6/20/2021	1	15	15
Tropical Storm Claud	6/20/2021	3	1,302	434
Tropical Storm Claud	6/20/2021	1	57	57

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm Claud	6/20/2021	1	157	157
Tropical Storm Claud	6/20/2021	1	45	45
Tropical Storm Claud	6/20/2021	53	14,460	276
Tropical Storm Claud	6/20/2021	26	1,274	49
Tropical Storm Claud	6/20/2021	1	27	27
Tropical Storm Claud	6/20/2021	34	21,114	621
Hurricane Elsa	7/5/2021	1	566	566
Hurricane Elsa	7/5/2021	1	102	102
Hurricane Elsa	7/5/2021	1	61	61
Hurricane Elsa	7/5/2021	5	1,055	211
Hurricane Elsa	7/5/2021	1	202	202
Hurricane Elsa	7/5/2021	1	892	892
Hurricane Elsa	7/5/2021	3	1,746	582
Hurricane Elsa	7/5/2021	12	12,528	1,044
Hurricane Elsa	7/5/2021	4	204	51
Hurricane Elsa	7/5/2021	4	352	88
Hurricane Elsa	7/5/2021	160	16,320	102
Hurricane Elsa	7/5/2021	4	292	73
Hurricane Elsa	7/5/2021	2	86	43
Hurricane Elsa	7/5/2021	11	3,872	352
Hurricane Elsa	7/5/2021	9	4,068	452
Hurricane Elsa	7/5/2021	8	992	124
Hurricane Elsa	7/5/2021	1	753	753
Hurricane Elsa	7/5/2021	9	765	85
Hurricane Elsa	7/5/2021	3	393	131
Hurricane Elsa	7/5/2021	30	5,460	182
Hurricane Elsa	7/5/2021	256	2,304	9
Hurricane Elsa	7/5/2021	69	23,514	544
Hurricane Elsa	7/5/2021	6	3,282	547
Hurricane Elsa	7/5/2021	1	387	387
Hurricane Elsa	7/5/2021	12	816	68
Hurricane Elsa	7/5/2021	4	276	69
Hurricane Elsa	7/5/2021	2	462	231
Hurricane Elsa	7/5/2021	5	1,331	325
Hurricane Elsa	7/5/2021	8	3,144	393
Hurricane Elsa	7/5/2021	18	6,966	387
Hurricane Elsa	7/5/2021	11	1,331	121
Hurricane Elsa	7/5/2021	1	283	283
Hurricane Elsa	7/5/2021	6	630	105
Hurricane Elsa	7/5/2021	3	804	268
Hurricane Elsa	7/5/2021	1	121	121
Hurricane Elsa	7/5/2021	4	292	73
Hurricane Elsa	7/5/2021	3	945	315

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	4	216	54
Hurricane Elsa	7/5/2021	1	144	144
Hurricane Elsa	7/5/2021	7	609	87
Hurricane Elsa	7/5/2021	5	270	54
Hurricane Elsa	7/5/2021	1	349	349
Hurricane Elsa	7/5/2021	2	178	89
Hurricane Elsa	7/5/2021	8	248	31
Hurricane Elsa	7/5/2021	2	78	39
Hurricane Elsa	7/5/2021	25	1,850	74
Hurricane Elsa	7/5/2021	1	341	341
Hurricane Elsa	7/5/2021	4	424	106
Hurricane Elsa	7/5/2021	2	158	79
Hurricane Elsa	7/5/2021	1	119	119
Hurricane Elsa	7/5/2021	10	2,620	262
Hurricane Elsa	7/5/2021	1	171	171
Hurricane Elsa	7/5/2021	4	960	240
Hurricane Elsa	7/5/2021	1	492	492
Hurricane Elsa	7/5/2021	116	12,822	134
Hurricane Elsa	7/5/2021	8	877	268
Hurricane Elsa	7/5/2021	1	153	153
Hurricane Elsa	7/5/2021	1	430	430
Hurricane Elsa	7/5/2021	13	6,032	464
Hurricane Elsa	7/5/2021	2	900	450
Hurricane Elsa	7/5/2021	23	4,163	181
Hurricane Elsa	7/5/2021	1	223	223
Hurricane Elsa	7/5/2021	1	103	103
Hurricane Elsa	7/5/2021	1	229	229
Hurricane Elsa	7/5/2021	113	13,560	120
Hurricane Elsa	7/5/2021	1	323	323
Hurricane Elsa	7/5/2021	1	75	75
Hurricane Elsa	7/5/2021	1	167	167
Hurricane Elsa	7/5/2021	2	398	199
Hurricane Elsa	7/5/2021	5	545	109
Hurricane Elsa	7/5/2021	1	386	386
Hurricane Elsa	7/5/2021	36	5,364	149
Hurricane Elsa	7/5/2021	1	256	256
Hurricane Elsa	7/5/2021	1	57	57
Hurricane Elsa	7/5/2021	6	264	44
Hurricane Elsa	7/5/2021	5	1,460	292
Hurricane Elsa	7/5/2021	2	128	64
Hurricane Elsa	7/5/2021	1	260	260
Hurricane Elsa	7/5/2021	1	230	230
Hurricane Elsa	7/5/2021	2	1,232	616

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	1	129	129
Hurricane Elsa	7/5/2021	22	2,420	110
Hurricane Elsa	7/5/2021	8	1,344	168
Hurricane Elsa	7/5/2021	5	395	79
Hurricane Elsa	7/5/2021	1	109	109
Hurricane Elsa	7/5/2021	1	607	607
Hurricane Elsa	7/5/2021	1	354	354
Hurricane Elsa	7/5/2021	1	280	280
Hurricane Elsa	7/5/2021	1	68	68
Hurricane Elsa	7/5/2021	3	360	120
Hurricane Elsa	7/5/2021	13	1,716	132
Hurricane Elsa	7/5/2021	1	187	187
Hurricane Elsa	7/5/2021	39	17,433	447
Hurricane Elsa	7/5/2021	2	278	139
Hurricane Elsa	7/5/2021	1	68	68
Hurricane Elsa	7/5/2021	11	341	31
Hurricane Elsa	7/5/2021	1	28	28
Hurricane Elsa	7/5/2021	1	559	559
Hurricane Elsa	7/5/2021	101	7,272	72
Hurricane Elsa	7/5/2021	5	360	72
Hurricane Elsa	7/5/2021	1	111	111
Hurricane Elsa	7/5/2021	6	1,824	304
Hurricane Elsa	7/5/2021	3	177	59
Hurricane Elsa	7/5/2021	27	513	19
Hurricane Elsa	7/5/2021	1	112	112
Hurricane Elsa	7/5/2021	6	1,056	176
Hurricane Elsa	7/5/2021	5	435	87
Hurricane Elsa	7/5/2021	5	2,680	536
Hurricane Elsa	7/5/2021	1	260	260
Hurricane Elsa	7/5/2021	1	116	116
Hurricane Elsa	7/5/2021	8	488	61
Hurricane Elsa	7/5/2021	37	925	25
Hurricane Elsa	7/5/2021	1	254	254
Hurricane Elsa	7/5/2021	1	170	170
Hurricane Elsa	7/5/2021	19	1,311	69
Hurricane Elsa	7/5/2021	7	511	73
Hurricane Elsa	7/5/2021	1	49	49
Hurricane Elsa	7/5/2021	1	334	334
Hurricane Elsa	7/5/2021	1	366	366
Hurricane Elsa	7/5/2021	1	529	529
Hurricane Elsa	7/5/2021	1	197	197
Hurricane Elsa	7/5/2021	1	156	156
Hurricane Elsa	7/5/2021	1	116	116

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	11	1,936	176
Hurricane Elsa	7/5/2021	93	14,601	157
Hurricane Elsa	7/5/2021	2	574	287
Hurricane Elsa	7/5/2021	2	92	46
Hurricane Elsa	7/5/2021	1	280	280
Hurricane Elsa	7/5/2021	1	49	49
Hurricane Elsa	7/5/2021	5	690	138
Hurricane Elsa	7/5/2021	1	88	88
Hurricane Elsa	7/5/2021	14	1,960	140
Hurricane Elsa	7/5/2021	1	142	142
Hurricane Elsa	7/5/2021	7	217	31
Hurricane Elsa	7/5/2021	23	9,821	427
Hurricane Elsa	7/5/2021	51	8,092	472
Hurricane Elsa	7/5/2021	29	1,914	66
Hurricane Elsa	7/5/2021	1	251	251
Hurricane Elsa	7/5/2021	16	1,488	93
Hurricane Elsa	7/5/2021	2,970	86,064	251
Hurricane Elsa	7/5/2021	2	118	59
Hurricane Elsa	7/5/2021	1	278	278
Hurricane Elsa	7/5/2021	11	2,321	211
Hurricane Elsa	7/5/2021	7	1,813	259
Hurricane Elsa	7/5/2021	13	2,977	229
Hurricane Elsa	7/5/2021	1	70	70
Hurricane Elsa	7/5/2021	6	282	47
Hurricane Elsa	7/5/2021	1	398	398
Hurricane Elsa	7/5/2021	1	42	42
Hurricane Elsa	7/5/2021	1	80	80
Hurricane Elsa	7/5/2021	13	2,795	215
Hurricane Elsa	7/5/2021	1	476	476
Hurricane Elsa	7/5/2021	1	356	356
Hurricane Elsa	7/5/2021	120	35,880	299
Hurricane Elsa	7/5/2021	1	546	546
Hurricane Elsa	7/5/2021	1	212	212
Hurricane Elsa	7/5/2021	1	70	70
Hurricane Elsa	7/5/2021	1,115	4,181	114
Hurricane Elsa	7/5/2021	1	315	315
Hurricane Elsa	7/5/2021	11	77	7
Hurricane Elsa	7/5/2021	17	3,096	744
Hurricane Elsa	7/5/2021	6	2,496	416
Hurricane Elsa	7/5/2021	1	176	176
Hurricane Elsa	7/5/2021	14	2,240	160
Hurricane Elsa	7/5/2021	4	144	36
Hurricane Elsa	7/5/2021	1	371	371

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	8	616	77
Hurricane Elsa	7/5/2021	1	495	495
Hurricane Elsa	7/5/2021	4	800	200
Hurricane Elsa	7/5/2021	1	146	146
Hurricane Elsa	7/5/2021	7	413	59
Hurricane Elsa	7/5/2021	14	2,072	148
Hurricane Elsa	7/5/2021	60	5,580	93
Hurricane Elsa	7/5/2021	74	6,068	82
Hurricane Elsa	7/5/2021	1	135	135
Hurricane Elsa	7/5/2021	1	247	247
Hurricane Elsa	7/5/2021	52	4,732	91
Hurricane Elsa	7/5/2021	4	20	5
Hurricane Elsa	7/5/2021	5	2,605	521
Hurricane Elsa	7/5/2021	1	162	162
Hurricane Elsa	7/5/2021	1	235	235
Hurricane Elsa	7/5/2021	1	213	213
Hurricane Elsa	7/5/2021	19	1,102	58
Hurricane Elsa	7/5/2021	100	11,762	184
Hurricane Elsa	7/5/2021	191	29,414	154
Hurricane Elsa	7/5/2021	12	2,052	171
Hurricane Elsa	7/5/2021	1	178	178
Hurricane Elsa	7/5/2021	1	327	327
Hurricane Elsa	7/5/2021	1	110	110
Hurricane Elsa	7/5/2021	23	2,384	173
Hurricane Elsa	7/5/2021	21	798	38
Hurricane Elsa	7/5/2021	98	18,816	192
Hurricane Elsa	7/5/2021	12	3,109	260
Hurricane Elsa	7/5/2021	1	243	243
Hurricane Elsa	7/5/2021	2	406	203
Hurricane Elsa	7/5/2021	1	169	169
Hurricane Elsa	7/5/2021	12	3,012	251
Hurricane Elsa	7/5/2021	20	8,500	425
Hurricane Elsa	7/5/2021	3	372	124
Hurricane Elsa	7/5/2021	1	190	190
Hurricane Elsa	7/5/2021	7	329	47
Hurricane Elsa	7/5/2021	14	938	67
Hurricane Elsa	7/5/2021	1	135	135
Hurricane Elsa	7/5/2021	15	930	62
Hurricane Elsa	7/5/2021	6	1,812	302
Hurricane Elsa	7/5/2021	1	165	165
Hurricane Elsa	7/5/2021	3	288	96
Hurricane Elsa	7/5/2021	797	50,343	92
Hurricane Elsa	7/5/2021	18	3,330	185

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	47	8,507	181
Hurricane Elsa	7/5/2021	15	4,800	320
Hurricane Elsa	7/5/2021	1	319	319
Hurricane Elsa	7/5/2021	13	3,575	275
Hurricane Elsa	7/5/2021	1	540	540
Hurricane Elsa	7/5/2021	3	843	281
Hurricane Elsa	7/5/2021	8	1,048	131
Hurricane Elsa	7/5/2021	10	1,560	156
Hurricane Elsa	7/5/2021	1	280	280
Hurricane Elsa	7/5/2021	350	26,328	156
Hurricane Elsa	7/5/2021	1	67	67
Hurricane Elsa	7/5/2021	5	1,160	232
Hurricane Elsa	7/5/2021	6	1,176	196
Hurricane Elsa	7/5/2021	1	98	98
Hurricane Elsa	7/5/2021	4	704	176
Hurricane Elsa	7/5/2021	1	196	196
Hurricane Elsa	7/5/2021	8	944	118
Hurricane Elsa	7/5/2021	21	8,127	387
Hurricane Elsa	7/5/2021	4	1,128	282
Hurricane Elsa	7/5/2021	105	19,215	183
Hurricane Elsa	7/5/2021	8	2,392	299
Hurricane Elsa	7/5/2021	7	2,093	299
Hurricane Elsa	7/5/2021	9	1,314	146
Hurricane Elsa	7/5/2021	97	21,243	219
Hurricane Elsa	7/5/2021	2	94	47
Hurricane Elsa	7/5/2021	32	9,760	305
Hurricane Elsa	7/5/2021	448	896	2
Hurricane Elsa	7/5/2021	1	53	53
Hurricane Elsa	7/5/2021	10	2,940	294
Hurricane Elsa	7/5/2021	11	2,299	209
Hurricane Elsa	7/5/2021	8	1,304	163
Hurricane Elsa	7/5/2021	77	42,658	554
Hurricane Elsa	7/5/2021	6	1,344	224
Hurricane Elsa	7/5/2021	1	204	204
Hurricane Elsa	7/5/2021	12	3,132	261
Hurricane Elsa	7/5/2021	1	133	133
Hurricane Elsa	7/5/2021	2	2,036	1,018
Hurricane Elsa	7/5/2021	117	9,828	84
Hurricane Elsa	7/5/2021	25	3,825	153
Hurricane Elsa	7/5/2021	9	1,332	148
Hurricane Elsa	7/5/2021	1	565	565
Hurricane Elsa	7/5/2021	25	8,725	349
Hurricane Elsa	7/5/2021	7	1,568	224

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	105	38,430	366
Hurricane Elsa	7/5/2021	82	19,106	233
Hurricane Elsa	7/5/2021	234	30,558	197
Hurricane Elsa	7/5/2021	22	1,540	70
Hurricane Elsa	7/5/2021	1,741	3,482	2
Hurricane Elsa	7/5/2021	20	1,080	54
Hurricane Elsa	7/5/2021	128	16,896	132
Hurricane Elsa	7/5/2021	8	1,824	228
Hurricane Elsa	7/5/2021	6	696	116
Hurricane Elsa	7/5/2021	4	488	122
Hurricane Elsa	7/5/2021	52	3,952	76
Hurricane Elsa	7/5/2021	7	1,540	220
Hurricane Elsa	7/5/2021	14	3,348	282
Hurricane Elsa	7/5/2021	21	3,171	151
Hurricane Elsa	7/5/2021	22	7,062	321
Hurricane Elsa	7/5/2021	2	160	80
Hurricane Elsa	7/5/2021	2	482	241
Hurricane Elsa	7/5/2021	3	438	146
Hurricane Elsa	7/5/2021	4	640	160
Hurricane Elsa	7/5/2021	18	10,008	556
Hurricane Elsa	7/5/2021	2	498	249
Hurricane Elsa	7/5/2021	58	29,000	500
Hurricane Elsa	7/5/2021	2	444	222
Hurricane Elsa	7/5/2021	9	1,899	211
Hurricane Elsa	7/5/2021	12	3,288	274
Hurricane Elsa	7/5/2021	63	5,355	85
Hurricane Elsa	7/5/2021	2	508	254
Hurricane Elsa	7/5/2021	6	1,500	250
Hurricane Elsa	7/5/2021	10	520	52
Hurricane Elsa	7/5/2021	32	2,656	83
Hurricane Elsa	7/5/2021	1	49	49
Hurricane Elsa	7/5/2021	4	132	33
Hurricane Elsa	7/5/2021	20	4,360	218
Hurricane Elsa	7/5/2021	40	3,840	96
Hurricane Elsa	7/5/2021	1	77	77
Hurricane Elsa	7/5/2021	7	1,407	201
Hurricane Elsa	7/5/2021	21	3,675	175
Hurricane Elsa	7/5/2021	1	232	232
Hurricane Elsa	7/5/2021	1	228	228
Hurricane Elsa	7/5/2021	39	28,860	740
Hurricane Elsa	7/5/2021	23	2,829	123
Hurricane Elsa	7/5/2021	1	227	227
Hurricane Elsa	7/5/2021	10	1,690	169

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	27	6,237	231
Hurricane Elsa	7/5/2021	12	552	46
Hurricane Elsa	7/5/2021	2	194	97
Hurricane Elsa	7/5/2021	11	2,431	221
Hurricane Elsa	7/5/2021	8	864	108
Hurricane Elsa	7/5/2021	708	30,648	53
Hurricane Elsa	7/5/2021	283	41,884	148
Hurricane Elsa	7/5/2021	21	2,835	135
Hurricane Elsa	7/5/2021	1	308	308
Hurricane Elsa	7/5/2021	7	3,284	752
Hurricane Elsa	7/5/2021	1,071	54,621	51
Hurricane Elsa	7/5/2021	7	2,191	313
Hurricane Elsa	7/5/2021	1	78	78
Hurricane Elsa	7/5/2021	4	216	54
Hurricane Elsa	7/5/2021	1	437	437
Hurricane Elsa	7/5/2021	81	4,309	152
Hurricane Elsa	7/5/2021	1	424	424
Hurricane Elsa	7/5/2021	29	9,773	337
Hurricane Elsa	7/5/2021	4	168	42
Hurricane Elsa	7/5/2021	4	456	114
Hurricane Elsa	7/5/2021	9	2,608	440
Hurricane Elsa	7/5/2021	116	21,400	238
Hurricane Elsa	7/5/2021	106	32,542	307
Hurricane Elsa	7/5/2021	7	602	86
Hurricane Elsa	7/5/2021	1	304	304
Hurricane Elsa	7/5/2021	52	2,548	49
Hurricane Elsa	7/5/2021	1,370	32,500	37
Hurricane Elsa	7/5/2021	35	8,015	229
Hurricane Elsa	7/5/2021	14	4,046	289
Hurricane Elsa	7/5/2021	48	6,816	142
Hurricane Elsa	7/5/2021	3	228	76
Hurricane Elsa	7/5/2021	8	3,040	380
Hurricane Elsa	7/5/2021	434	8,428	52
Hurricane Elsa	7/5/2021	1	104	104
Hurricane Elsa	7/5/2021	800	23,200	30
Hurricane Elsa	7/5/2021	1	217	217
Hurricane Elsa	7/5/2021	33	4,224	128
Hurricane Elsa	7/5/2021	42	2,982	71
Hurricane Elsa	7/5/2021	4	784	196
Hurricane Elsa	7/5/2021	1	86	86
Hurricane Elsa	7/5/2021	3	315	105
Hurricane Elsa	7/5/2021	1	125	125
Hurricane Elsa	7/5/2021	1	114	114

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	893	42,400	50
Hurricane Elsa	7/5/2021	35	8,645	247
Hurricane Elsa	7/5/2021	3	414	138
Hurricane Elsa	7/5/2021	12	3,228	269
Hurricane Elsa	7/5/2021	4	692	173
Hurricane Elsa	7/5/2021	12	1,428	119
Hurricane Elsa	7/5/2021	7	3,003	429
Hurricane Elsa	7/5/2021	2	64	32
Hurricane Elsa	7/5/2021	1	24	24
Hurricane Elsa	7/5/2021	10	2,160	216
Hurricane Elsa	7/5/2021	1	205	205
Hurricane Elsa	7/5/2021	3	162	54
Hurricane Elsa	7/5/2021	22	4,119	545
Hurricane Elsa	7/5/2021	33	17,886	542
Hurricane Elsa	7/5/2021	141	34,827	247
Hurricane Elsa	7/5/2021	6	1,758	293
Hurricane Elsa	7/5/2021	10	1,030	103
Hurricane Elsa	7/5/2021	60	7,800	130
Hurricane Elsa	7/5/2021	12	2,796	233
Hurricane Elsa	7/5/2021	1	245	245
Hurricane Elsa	7/5/2021	1	178	178
Hurricane Elsa	7/5/2021	21	840	40
Hurricane Elsa	7/5/2021	27	11,895	1,365
Hurricane Elsa	7/5/2021	11	1,562	142
Hurricane Elsa	7/5/2021	1	66	66
Hurricane Elsa	7/5/2021	1	234	234
Hurricane Elsa	7/5/2021	43	2,150	50
Hurricane Elsa	7/5/2021	4	828	207
Hurricane Elsa	7/5/2021	176	40,304	229
Hurricane Elsa	7/5/2021	2	1,270	635
Hurricane Elsa	7/5/2021	114	54,492	478
Hurricane Elsa	7/5/2021	815	26,300	47
Hurricane Elsa	7/5/2021	17	374	22
Hurricane Elsa	7/5/2021	7	616	88
Hurricane Elsa	7/5/2021	10	550	55
Hurricane Elsa	7/5/2021	42	4,782	150
Hurricane Elsa	7/5/2021	1	238	238
Hurricane Elsa	7/5/2021	16	2,352	147
Hurricane Elsa	7/5/2021	4	456	114
Hurricane Elsa	7/5/2021	1	151	151
Hurricane Elsa	7/5/2021	1	305	305
Hurricane Elsa	7/5/2021	5	1,085	217
Hurricane Elsa	7/5/2021	1	111	111

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	23	736	32
Hurricane Elsa	7/5/2021	5	370	74
Hurricane Elsa	7/5/2021	1	126	126
Hurricane Elsa	7/5/2021	1	102	102
Hurricane Elsa	7/5/2021	2	84	42
Hurricane Elsa	7/5/2021	4	276	69
Hurricane Elsa	7/5/2021	28	2,856	102
Hurricane Elsa	7/5/2021	637	11,466	18
Hurricane Elsa	7/5/2021	1	145	145
Hurricane Elsa	7/5/2021	4	544	136
Hurricane Elsa	7/5/2021	2	324	162
Hurricane Elsa	7/5/2021	14	8,400	600
Hurricane Elsa	7/5/2021	32	11,232	351
Hurricane Elsa	7/5/2021	1	388	388
Hurricane Elsa	7/5/2021	12	756	63
Hurricane Elsa	7/5/2021	1	205	205
Hurricane Elsa	7/5/2021	9	2,529	281
Hurricane Elsa	7/5/2021	1	526	526
Hurricane Elsa	7/5/2021	1	194	194
Hurricane Elsa	7/5/2021	4	256	64
Hurricane Elsa	7/5/2021	56	12,208	218
Hurricane Elsa	7/5/2021	3	1,680	560
Hurricane Elsa	7/5/2021	4	260	65
Hurricane Elsa	7/5/2021	6	2,196	366
Hurricane Elsa	7/5/2021	6	5,580	930
Hurricane Elsa	7/5/2021	100	23,680	394
Hurricane Elsa	7/5/2021	2	88	44
Hurricane Elsa	7/5/2021	11	671	61
Hurricane Elsa	7/5/2021	17	3,043	179
Hurricane Elsa	7/5/2021	4	568	142
Hurricane Elsa	7/5/2021	82	18,040	220
Hurricane Elsa	7/5/2021	1	441	441
Hurricane Elsa	7/5/2021	6	276	46
Hurricane Elsa	7/5/2021	3	516	172
Hurricane Elsa	7/5/2021	1	87	87
Hurricane Elsa	7/5/2021	1	492	492
Hurricane Elsa	7/5/2021	9	927	103
Hurricane Elsa	7/5/2021	1	147	147
Hurricane Elsa	7/5/2021	1	305	305
Hurricane Elsa	7/5/2021	1	170	170
Hurricane Elsa	7/5/2021	1	152	152
Hurricane Elsa	7/5/2021	22	3,542	161
Hurricane Elsa	7/5/2021	20	2,380	119

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	1	66	66
Hurricane Elsa	7/5/2021	2	214	107
Hurricane Elsa	7/5/2021	22	6,798	309
Hurricane Elsa	7/5/2021	1	126	126
Hurricane Elsa	7/5/2021	1	107	107
Hurricane Elsa	7/5/2021	1	781	781
Hurricane Elsa	7/5/2021	1	168	168
Hurricane Elsa	7/5/2021	1	377	377
Hurricane Elsa	7/5/2021	12	504	42
Hurricane Elsa	7/5/2021	66	4,092	62
Hurricane Elsa	7/5/2021	15	3,435	229
Hurricane Elsa	7/5/2021	1	146	146
Hurricane Elsa	7/5/2021	2	212	106
Hurricane Elsa	7/5/2021	8	2,344	293
Hurricane Elsa	7/5/2021	1	31	31
Hurricane Elsa	7/5/2021	9	648	72
Hurricane Elsa	7/5/2021	12	2,544	212
Hurricane Elsa	7/5/2021	74	5,032	68
Hurricane Elsa	7/5/2021	7	2,912	416
Hurricane Elsa	7/5/2021	38	2,622	69
Hurricane Elsa	7/5/2021	1	160	160
Hurricane Elsa	7/5/2021	12	2,808	234
Hurricane Elsa	7/5/2021	9	405	45
Hurricane Elsa	7/5/2021	134	58,558	437
Hurricane Elsa	7/5/2021	41	9,160	416
Hurricane Elsa	7/5/2021	7	1,946	278
Hurricane Elsa	7/5/2021	1	104	104
Hurricane Elsa	7/5/2021	9	1,584	176
Hurricane Elsa	7/5/2021	1	242	242
Hurricane Elsa	7/5/2021	13	2,704	208
Hurricane Elsa	7/5/2021	13	1,404	108
Hurricane Elsa	7/5/2021	1	307	307
Hurricane Elsa	7/5/2021	1	97	97
Hurricane Elsa	7/5/2021	1	215	215
Hurricane Elsa	7/5/2021	59	20,886	354
Hurricane Elsa	7/5/2021	1	173	173
Hurricane Elsa	7/5/2021	1	191	191
Hurricane Elsa	7/5/2021	78	18,698	267
Hurricane Elsa	7/5/2021	22	2,772	126
Hurricane Elsa	7/5/2021	31	11,873	383
Hurricane Elsa	7/5/2021	6	1,248	208
Hurricane Elsa	7/5/2021	12	816	68
Hurricane Elsa	7/5/2021	1	63	63

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	1	225	225
Hurricane Elsa	7/5/2021	1	82	82
Hurricane Elsa	7/5/2021	1	118	118
Hurricane Elsa	7/5/2021	4	668	167
Hurricane Elsa	7/5/2021	1	55	55
Hurricane Elsa	7/5/2021	11	3,311	301
Hurricane Elsa	7/5/2021	26	858	33
Hurricane Elsa	7/5/2021	6	582	97
Hurricane Elsa	7/5/2021	1	184	184
Hurricane Elsa	7/5/2021	1	40	40
Hurricane Elsa	7/5/2021	5	1,410	282
Hurricane Elsa	7/5/2021	1	66	66
Hurricane Elsa	7/5/2021	169	12,944	366
Hurricane Elsa	7/5/2021	93	12,555	135
Hurricane Elsa	7/5/2021	1	74	74
Hurricane Elsa	7/5/2021	1	208	208
Hurricane Elsa	7/5/2021	1	197	197
Hurricane Elsa	7/5/2021	16	1,200	75
Hurricane Elsa	7/5/2021	1	230	230
Hurricane Elsa	7/5/2021	1	172	172
Hurricane Elsa	7/5/2021	1	45	45
Hurricane Elsa	7/5/2021	3	108	36
Hurricane Elsa	7/5/2021	6	888	148
Hurricane Elsa	7/5/2021	4	972	243
Hurricane Elsa	7/5/2021	1	74	74
Hurricane Elsa	7/5/2021	1	125	125
Hurricane Elsa	7/5/2021	10	400	40
Hurricane Elsa	7/5/2021	14	910	65
Hurricane Elsa	7/5/2021	1	200	200
Hurricane Elsa	7/5/2021	1	49	49
Hurricane Elsa	7/5/2021	4	128	32
Hurricane Elsa	7/5/2021	1	115	115
Hurricane Elsa	7/5/2021	12	648	319
Hurricane Elsa	7/5/2021	37	6,179	167
Hurricane Elsa	7/5/2021	1	206	206
Hurricane Elsa	7/5/2021	1	58	58
Hurricane Elsa	7/5/2021	2	68	34
Hurricane Elsa	7/5/2021	11	2,794	254
Hurricane Elsa	7/5/2021	17	4,471	263
Hurricane Elsa	7/5/2021	97	12,028	124
Hurricane Elsa	7/5/2021	998	121,756	122
Hurricane Elsa	7/5/2021	46	9,798	213
Hurricane Elsa	7/5/2021	2	160	80

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/5/2021	1	113	113
Hurricane Elsa	7/5/2021	13	767	59
Hurricane Elsa	7/5/2021	2	364	182
Hurricane Elsa	7/6/2021	3	906	302
Hurricane Elsa	7/6/2021	31	4,867	157
Hurricane Elsa	7/6/2021	226	49,494	219
Hurricane Elsa	7/6/2021	1	219	219
Hurricane Elsa	7/6/2021	20	4,800	264
Hurricane Elsa	7/6/2021	122	9,638	79
Hurricane Elsa	7/6/2021	62	7,680	306
Hurricane Elsa	7/6/2021	1	130	130
Hurricane Elsa	7/6/2021	78	4,758	61
Hurricane Elsa	7/6/2021	37	8,288	224
Hurricane Elsa	7/6/2021	5	690	138
Hurricane Elsa	7/6/2021	9	2,561	591
Hurricane Elsa	7/6/2021	5	320	64
Hurricane Elsa	7/6/2021	8	504	63
Hurricane Elsa	7/6/2021	1	191	191
Hurricane Elsa	7/6/2021	1	51	51
Hurricane Elsa	7/6/2021	51	5,049	99
Hurricane Elsa	7/6/2021	1	65	65
Hurricane Elsa	7/6/2021	4	220	55
Hurricane Elsa	7/6/2021	1	39	39
Hurricane Elsa	7/6/2021	732	84,302	125
Hurricane Elsa	7/6/2021	60	15,000	426
Hurricane Elsa	7/6/2021	11	8,811	801
Hurricane Elsa	7/6/2021	1	158	158
Hurricane Elsa	7/6/2021	2	524	262
Hurricane Elsa	7/6/2021	1	58	58
Hurricane Elsa	7/6/2021	10	2,020	202
Hurricane Elsa	7/6/2021	13	2,028	156
Hurricane Elsa	7/6/2021	25	3,850	154
Hurricane Elsa	7/6/2021	1	38	38
Hurricane Elsa	7/6/2021	16	1,968	123
Hurricane Elsa	7/6/2021	1	363	363
Hurricane Elsa	7/6/2021	13	4,238	326
Hurricane Elsa	7/6/2021	65	11,974	185
Hurricane Elsa	7/6/2021	19	3,952	208
Hurricane Elsa	7/6/2021	3,064	61,534	60
Hurricane Elsa	7/6/2021	11	902	82
Hurricane Elsa	7/6/2021	9	954	106
Hurricane Elsa	7/6/2021	1	337	337
Hurricane Elsa	7/6/2021	1	333	333

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	52	52
Hurricane Elsa	7/6/2021	7	2,821	403
Hurricane Elsa	7/6/2021	1	484	484
Hurricane Elsa	7/6/2021	1	224	224
Hurricane Elsa	7/6/2021	4	244	61
Hurricane Elsa	7/6/2021	31	1,178	38
Hurricane Elsa	7/6/2021	32	3,232	101
Hurricane Elsa	7/6/2021	37	2,331	63
Hurricane Elsa	7/6/2021	1	105	105
Hurricane Elsa	7/6/2021	1	315	315
Hurricane Elsa	7/6/2021	2	382	191
Hurricane Elsa	7/6/2021	4	164	41
Hurricane Elsa	7/6/2021	42	18,060	430
Hurricane Elsa	7/6/2021	1	174	174
Hurricane Elsa	7/6/2021	1	46	46
Hurricane Elsa	7/6/2021	1	15	15
Hurricane Elsa	7/6/2021	1	113	113
Hurricane Elsa	7/6/2021	2	922	461
Hurricane Elsa	7/6/2021	1	277	277
Hurricane Elsa	7/6/2021	1	265	265
Hurricane Elsa	7/6/2021	4	1,412	353
Hurricane Elsa	7/6/2021	1	85	85
Hurricane Elsa	7/6/2021	1	102	102
Hurricane Elsa	7/6/2021	1	176	176
Hurricane Elsa	7/6/2021	47	13,207	281
Hurricane Elsa	7/6/2021	1	112	112
Hurricane Elsa	7/6/2021	1	337	337
Hurricane Elsa	7/6/2021	121	27,625	766
Hurricane Elsa	7/6/2021	2	422	211
Hurricane Elsa	7/6/2021	1	212	212
Hurricane Elsa	7/6/2021	10	290	29
Hurricane Elsa	7/6/2021	1	221	221
Hurricane Elsa	7/6/2021	1	112	112
Hurricane Elsa	7/6/2021	14	868	62
Hurricane Elsa	7/6/2021	10	970	97
Hurricane Elsa	7/6/2021	8	1,144	143
Hurricane Elsa	7/6/2021	1	290	290
Hurricane Elsa	7/6/2021	4	876	219
Hurricane Elsa	7/6/2021	1	642	642
Hurricane Elsa	7/6/2021	2	254	127
Hurricane Elsa	7/6/2021	3	333	111
Hurricane Elsa	7/6/2021	1	393	393
Hurricane Elsa	7/6/2021	1	184	184

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	151	151
Hurricane Elsa	7/6/2021	2	142	71
Hurricane Elsa	7/6/2021	1	138	138
Hurricane Elsa	7/6/2021	1	125	125
Hurricane Elsa	7/6/2021	1	46	46
Hurricane Elsa	7/6/2021	5	615	123
Hurricane Elsa	7/6/2021	1	95	95
Hurricane Elsa	7/6/2021	2	52	26
Hurricane Elsa	7/6/2021	1	440	440
Hurricane Elsa	7/6/2021	1	214	214
Hurricane Elsa	7/6/2021	1	408	408
Hurricane Elsa	7/6/2021	1	119	119
Hurricane Elsa	7/6/2021	1	104	104
Hurricane Elsa	7/6/2021	1	284	284
Hurricane Elsa	7/6/2021	4	1,136	284
Hurricane Elsa	7/6/2021	1	219	219
Hurricane Elsa	7/6/2021	1	343	343
Hurricane Elsa	7/6/2021	1	61	61
Hurricane Elsa	7/6/2021	1	170	170
Hurricane Elsa	7/6/2021	11	792	72
Hurricane Elsa	7/6/2021	3	165	55
Hurricane Elsa	7/6/2021	41	3,280	80
Hurricane Elsa	7/6/2021	1	144	144
Hurricane Elsa	7/6/2021	1	89	89
Hurricane Elsa	7/6/2021	1	51	51
Hurricane Elsa	7/6/2021	1	453	453
Hurricane Elsa	7/6/2021	1	74	74
Hurricane Elsa	7/6/2021	5	475	95
Hurricane Elsa	7/6/2021	1	102	102
Hurricane Elsa	7/6/2021	1	401	401
Hurricane Elsa	7/6/2021	5	30	6
Hurricane Elsa	7/6/2021	1	93	93
Hurricane Elsa	7/6/2021	21	7,287	347
Hurricane Elsa	7/6/2021	1	124	124
Hurricane Elsa	7/6/2021	1	261	261
Hurricane Elsa	7/6/2021	1	103	103
Hurricane Elsa	7/6/2021	1	97	97
Hurricane Elsa	7/6/2021	42	4,998	119
Hurricane Elsa	7/6/2021	4	24	6
Hurricane Elsa	7/6/2021	3	675	225
Hurricane Elsa	7/6/2021	3	15	5
Hurricane Elsa	7/6/2021	1	240	240
Hurricane Elsa	7/6/2021	13	182	14

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	3	192	64
Hurricane Elsa	7/6/2021	1	85	85
Hurricane Elsa	7/6/2021	4	32	8
Hurricane Elsa	7/6/2021	46	7,912	172
Hurricane Elsa	7/6/2021	13	572	44
Hurricane Elsa	7/6/2021	6	120	20
Hurricane Elsa	7/6/2021	11	2,387	217
Hurricane Elsa	7/6/2021	1	137	137
Hurricane Elsa	7/6/2021	1	46	46
Hurricane Elsa	7/6/2021	1	66	66
Hurricane Elsa	7/6/2021	3	165	55
Hurricane Elsa	7/6/2021	4	84	21
Hurricane Elsa	7/6/2021	16	9,616	601
Hurricane Elsa	7/6/2021	1	261	261
Hurricane Elsa	7/6/2021	7	1,365	195
Hurricane Elsa	7/6/2021	4	184	46
Hurricane Elsa	7/6/2021	1	253	253
Hurricane Elsa	7/6/2021	1	79	79
Hurricane Elsa	7/6/2021	13	494	38
Hurricane Elsa	7/6/2021	1	183	183
Hurricane Elsa	7/6/2021	1	15	15
Hurricane Elsa	7/6/2021	3	72	24
Hurricane Elsa	7/6/2021	80	9,440	118
Hurricane Elsa	7/6/2021	4	284	71
Hurricane Elsa	7/6/2021	1	119	119
Hurricane Elsa	7/6/2021	1	116	116
Hurricane Elsa	7/6/2021	5	80	16
Hurricane Elsa	7/6/2021	1	574	574
Hurricane Elsa	7/6/2021	1	107	107
Hurricane Elsa	7/6/2021	5	80	16
Hurricane Elsa	7/6/2021	11	2,959	269
Hurricane Elsa	7/6/2021	109	26,051	239
Hurricane Elsa	7/6/2021	32	2,656	83
Hurricane Elsa	7/6/2021	1	163	163
Hurricane Elsa	7/6/2021	1	178	178
Hurricane Elsa	7/6/2021	1	131	131
Hurricane Elsa	7/6/2021	1	70	70
Hurricane Elsa	7/6/2021	5	75	15
Hurricane Elsa	7/6/2021	1	263	263
Hurricane Elsa	7/6/2021	24	6,480	270
Hurricane Elsa	7/6/2021	1	151	151
Hurricane Elsa	7/6/2021	1	360	360
Hurricane Elsa	7/6/2021	1	285	285

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	2	62	31
Hurricane Elsa	7/6/2021	1	25	25
Hurricane Elsa	7/6/2021	2	20	10
Hurricane Elsa	7/6/2021	1	134	134
Hurricane Elsa	7/6/2021	9	711	79
Hurricane Elsa	7/6/2021	4	120	30
Hurricane Elsa	7/6/2021	1	73	73
Hurricane Elsa	7/6/2021	88	10,384	118
Hurricane Elsa	7/6/2021	4	1,212	303
Hurricane Elsa	7/6/2021	15	405	27
Hurricane Elsa	7/6/2021	1	249	249
Hurricane Elsa	7/6/2021	1	79	79
Hurricane Elsa	7/6/2021	1	87	87
Hurricane Elsa	7/6/2021	2	452	226
Hurricane Elsa	7/6/2021	1	334	334
Hurricane Elsa	7/6/2021	1	470	470
Hurricane Elsa	7/6/2021	1	234	234
Hurricane Elsa	7/6/2021	1	64	64
Hurricane Elsa	7/6/2021	6	348	58
Hurricane Elsa	7/6/2021	1	738	738
Hurricane Elsa	7/6/2021	1	111	111
Hurricane Elsa	7/6/2021	1	346	346
Hurricane Elsa	7/6/2021	12	624	52
Hurricane Elsa	7/6/2021	1	209	209
Hurricane Elsa	7/6/2021	8	392	49
Hurricane Elsa	7/6/2021	1	85	85
Hurricane Elsa	7/6/2021	14	910	65
Hurricane Elsa	7/6/2021	1	6	6
Hurricane Elsa	7/6/2021	3	123	41
Hurricane Elsa	7/6/2021	1	133	133
Hurricane Elsa	7/6/2021	1	96	96
Hurricane Elsa	7/6/2021	1	400	400
Hurricane Elsa	7/6/2021	1	72	72
Hurricane Elsa	7/6/2021	55	14,293	340
Hurricane Elsa	7/6/2021	7	77	11
Hurricane Elsa	7/6/2021	3	171	57
Hurricane Elsa	7/6/2021	1	176	176
Hurricane Elsa	7/6/2021	4	452	113
Hurricane Elsa	7/6/2021	1	6	6
Hurricane Elsa	7/6/2021	1,266	1,266	1
Hurricane Elsa	7/6/2021	8	1,568	196
Hurricane Elsa	7/6/2021	11	352	32
Hurricane Elsa	7/6/2021	1	92	92

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	194	194
Hurricane Elsa	7/6/2021	1	95	95
Hurricane Elsa	7/6/2021	1	5	5
Hurricane Elsa	7/6/2021	7	1,160	230
Hurricane Elsa	7/6/2021	1	37	37
Hurricane Elsa	7/6/2021	3	216	72
Hurricane Elsa	7/6/2021	3	768	256
Hurricane Elsa	7/6/2021	1	241	241
Hurricane Elsa	7/6/2021	30	90	3
Hurricane Elsa	7/6/2021	1	213	213
Hurricane Elsa	7/6/2021	1	614	614
Hurricane Elsa	7/6/2021	1	11	11
Hurricane Elsa	7/6/2021	8	2,312	289
Hurricane Elsa	7/6/2021	4	60	15
Hurricane Elsa	7/6/2021	1	117	117
Hurricane Elsa	7/6/2021	4	1,368	342
Hurricane Elsa	7/6/2021	6	36	6
Hurricane Elsa	7/6/2021	1	94	94
Hurricane Elsa	7/6/2021	66	5,874	89
Hurricane Elsa	7/6/2021	5	1,965	393
Hurricane Elsa	7/6/2021	1	19	19
Hurricane Elsa	7/6/2021	24	6,408	267
Hurricane Elsa	7/6/2021	1	208	208
Hurricane Elsa	7/6/2021	6	294	49
Hurricane Elsa	7/6/2021	6	156	26
Hurricane Elsa	7/6/2021	19	4,180	220
Hurricane Elsa	7/6/2021	1	46	46
Hurricane Elsa	7/6/2021	1	153	153
Hurricane Elsa	7/6/2021	1	241	241
Hurricane Elsa	7/6/2021	1	353	353
Hurricane Elsa	7/6/2021	1	84	84
Hurricane Elsa	7/6/2021	1	61	61
Hurricane Elsa	7/6/2021	1	480	480
Hurricane Elsa	7/6/2021	12	1,416	118
Hurricane Elsa	7/6/2021	84	14,532	173
Hurricane Elsa	7/6/2021	4	204	51
Hurricane Elsa	7/6/2021	4	60	15
Hurricane Elsa	7/6/2021	1	78	78
Hurricane Elsa	7/6/2021	5	260	52
Hurricane Elsa	7/6/2021	4	68	17
Hurricane Elsa	7/6/2021	1	240	240
Hurricane Elsa	7/6/2021	5	1,320	264
Hurricane Elsa	7/6/2021	1	547	547

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	486	486
Hurricane Elsa	7/6/2021	1	20	20
Hurricane Elsa	7/6/2021	114	8,208	72
Hurricane Elsa	7/6/2021	1	65	65
Hurricane Elsa	7/6/2021	2	286	143
Hurricane Elsa	7/6/2021	1	153	153
Hurricane Elsa	7/6/2021	2	150	75
Hurricane Elsa	7/6/2021	1	440	440
Hurricane Elsa	7/6/2021	45	2,500	168
Hurricane Elsa	7/6/2021	2	14	7
Hurricane Elsa	7/6/2021	1	61	61
Hurricane Elsa	7/6/2021	1	84	84
Hurricane Elsa	7/6/2021	1	221	221
Hurricane Elsa	7/6/2021	6	486	81
Hurricane Elsa	7/6/2021	1	262	262
Hurricane Elsa	7/6/2021	1	79	79
Hurricane Elsa	7/6/2021	1	67	67
Hurricane Elsa	7/6/2021	1	140	140
Hurricane Elsa	7/6/2021	75	13,238	339
Hurricane Elsa	7/6/2021	1	84	84
Hurricane Elsa	7/6/2021	1	176	176
Hurricane Elsa	7/6/2021	3	21	7
Hurricane Elsa	7/6/2021	1	227	227
Hurricane Elsa	7/6/2021	1	149	149
Hurricane Elsa	7/6/2021	24	1,104	46
Hurricane Elsa	7/6/2021	2	32	16
Hurricane Elsa	7/6/2021	1	233	233
Hurricane Elsa	7/6/2021	1	41	41
Hurricane Elsa	7/6/2021	1	139	139
Hurricane Elsa	7/6/2021	1	170	170
Hurricane Elsa	7/6/2021	1	184	184
Hurricane Elsa	7/6/2021	1	174	174
Hurricane Elsa	7/6/2021	1	35	35
Hurricane Elsa	7/6/2021	1	282	282
Hurricane Elsa	7/6/2021	1	240	240
Hurricane Elsa	7/6/2021	13	234	18
Hurricane Elsa	7/6/2021	76	14,212	187
Hurricane Elsa	7/6/2021	14	2,240	160
Hurricane Elsa	7/6/2021	114	19,218	233
Hurricane Elsa	7/6/2021	34	10,268	302
Hurricane Elsa	7/6/2021	3	267	89
Hurricane Elsa	7/6/2021	33	7,788	236
Hurricane Elsa	7/6/2021	255	336	28

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	3	240	80
Hurricane Elsa	7/6/2021	4	408	102
Hurricane Elsa	7/6/2021	2	438	219
Hurricane Elsa	7/6/2021	36	3,372	279
Hurricane Elsa	7/6/2021	1	99	99
Hurricane Elsa	7/6/2021	1	103	103
Hurricane Elsa	7/6/2021	63	15,183	241
Hurricane Elsa	7/6/2021	1	296	296
Hurricane Elsa	7/6/2021	84	2,166	348
Hurricane Elsa	7/6/2021	1	438	438
Hurricane Elsa	7/6/2021	1	433	433
Hurricane Elsa	7/6/2021	1	75	75
Hurricane Elsa	7/6/2021	1	69	69
Hurricane Elsa	7/6/2021	3	147	49
Hurricane Elsa	7/6/2021	1	130	130
Hurricane Elsa	7/6/2021	7	553	79
Hurricane Elsa	7/6/2021	10	660	66
Hurricane Elsa	7/6/2021	2	118	59
Hurricane Elsa	7/6/2021	3	1,278	426
Hurricane Elsa	7/6/2021	49	5,096	104
Hurricane Elsa	7/6/2021	120	2,360	71
Hurricane Elsa	7/6/2021	1	184	184
Hurricane Elsa	7/6/2021	1	361	361
Hurricane Elsa	7/6/2021	10	390	39
Hurricane Elsa	7/6/2021	1	82	82
Hurricane Elsa	7/6/2021	1	193	193
Hurricane Elsa	7/6/2021	4	1,172	293
Hurricane Elsa	7/6/2021	124	13,020	105
Hurricane Elsa	7/6/2021	50	19,000	380
Hurricane Elsa	7/6/2021	1	229	229
Hurricane Elsa	7/6/2021	3	120	40
Hurricane Elsa	7/6/2021	5	290	58
Hurricane Elsa	7/6/2021	1	266	266
Hurricane Elsa	7/6/2021	3	783	261
Hurricane Elsa	7/6/2021	1	194	194
Hurricane Elsa	7/6/2021	1	177	177
Hurricane Elsa	7/6/2021	51	5,967	117
Hurricane Elsa	7/6/2021	83	7,221	87
Hurricane Elsa	7/6/2021	85	11,033	385
Hurricane Elsa	7/6/2021	19	4,541	239
Hurricane Elsa	7/6/2021	3	219	73
Hurricane Elsa	7/6/2021	7	329	47
Hurricane Elsa	7/6/2021	1	197	197

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	19	1,824	104
Hurricane Elsa	7/6/2021	6	4,464	744
Hurricane Elsa	7/6/2021	1	172	172
Hurricane Elsa	7/6/2021	9	522	58
Hurricane Elsa	7/6/2021	8	312	39
Hurricane Elsa	7/6/2021	1	48	48
Hurricane Elsa	7/6/2021	1	118	118
Hurricane Elsa	7/6/2021	38	3,116	82
Hurricane Elsa	7/6/2021	1	334	334
Hurricane Elsa	7/6/2021	1	303	303
Hurricane Elsa	7/6/2021	1	68	68
Hurricane Elsa	7/6/2021	31	2,650	292
Hurricane Elsa	7/6/2021	747	33,657	681
Hurricane Elsa	7/6/2021	29	1,392	48
Hurricane Elsa	7/6/2021	3	363	121
Hurricane Elsa	7/6/2021	29	5,162	178
Hurricane Elsa	7/6/2021	1	102	102
Hurricane Elsa	7/6/2021	9	1,593	177
Hurricane Elsa	7/6/2021	39	6,396	164
Hurricane Elsa	7/6/2021	1	377	377
Hurricane Elsa	7/6/2021	1	359	359
Hurricane Elsa	7/6/2021	113	12,543	111
Hurricane Elsa	7/6/2021	1	386	386
Hurricane Elsa	7/6/2021	1	141	141
Hurricane Elsa	7/6/2021	31	8,370	270
Hurricane Elsa	7/6/2021	2	186	93
Hurricane Elsa	7/6/2021	14	3,108	222
Hurricane Elsa	7/6/2021	2	270	135
Hurricane Elsa	7/6/2021	1	16	16
Hurricane Elsa	7/6/2021	30	11,370	379
Hurricane Elsa	7/6/2021	3	987	329
Hurricane Elsa	7/6/2021	1	49	49
Hurricane Elsa	7/6/2021	54	4,212	78
Hurricane Elsa	7/6/2021	1	186	186
Hurricane Elsa	7/6/2021	46	5,796	126
Hurricane Elsa	7/6/2021	1	325	325
Hurricane Elsa	7/6/2021	5	255	51
Hurricane Elsa	7/6/2021	195	14,430	74
Hurricane Elsa	7/6/2021	7	357	51
Hurricane Elsa	7/6/2021	1	30	30
Hurricane Elsa	7/6/2021	1	42	42
Hurricane Elsa	7/6/2021	1	26	26
Hurricane Elsa	7/6/2021	1	26	26

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	7	385	55
Hurricane Elsa	7/6/2021	1	35	35
Hurricane Elsa	7/6/2021	5	335	67
Hurricane Elsa	7/6/2021	1	19	19
Hurricane Elsa	7/6/2021	48	20,880	435
Hurricane Elsa	7/6/2021	21	2,310	110
Hurricane Elsa	7/6/2021	72	6,768	94
Hurricane Elsa	7/6/2021	2,255	3,879	3
Hurricane Elsa	7/6/2021	145	11,165	77
Hurricane Elsa	7/6/2021	6	594	99
Hurricane Elsa	7/6/2021	2	98	49
Hurricane Elsa	7/6/2021	1	86	86
Hurricane Elsa	7/6/2021	155	35,925	444
Hurricane Elsa	7/6/2021	1	268	268
Hurricane Elsa	7/6/2021	3	66	22
Hurricane Elsa	7/6/2021	1	38	38
Hurricane Elsa	7/6/2021	3	828	276
Hurricane Elsa	7/6/2021	59	811	189
Hurricane Elsa	7/6/2021	7	1,337	191
Hurricane Elsa	7/6/2021	1	119	119
Hurricane Elsa	7/6/2021	6	966	161
Hurricane Elsa	7/6/2021	12	2,616	218
Hurricane Elsa	7/6/2021	6	402	67
Hurricane Elsa	7/6/2021	2	364	182
Hurricane Elsa	7/6/2021	2,544	87,407	74
Hurricane Elsa	7/6/2021	1	86	86
Hurricane Elsa	7/6/2021	4	144	36
Hurricane Elsa	7/6/2021	1	85	85
Hurricane Elsa	7/6/2021	1	84	84
Hurricane Elsa	7/6/2021	1	84	84
Hurricane Elsa	7/6/2021	1	83	83
Hurricane Elsa	7/6/2021	1	83	83
Hurricane Elsa	7/6/2021	1	83	83
Hurricane Elsa	7/6/2021	1	83	83
Hurricane Elsa	7/6/2021	1	83	83
Hurricane Elsa	7/6/2021	1	82	82
Hurricane Elsa	7/6/2021	7	301	43
Hurricane Elsa	7/6/2021	1	82	82
Hurricane Elsa	7/6/2021	3	315	105
Hurricane Elsa	7/6/2021	1	81	81
Hurricane Elsa	7/6/2021	1	80	80
Hurricane Elsa	7/6/2021	7	567	81
Hurricane Elsa	7/6/2021	4	272	68
Hurricane Elsa	7/6/2021	1	79	79

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	78	78
Hurricane Elsa	7/6/2021	1	77	77
Hurricane Elsa	7/6/2021	8	520	65
Hurricane Elsa	7/6/2021	1	77	77
Hurricane Elsa	7/6/2021	1	77	77
Hurricane Elsa	7/6/2021	39	3,354	86
Hurricane Elsa	7/6/2021	1	61	61
Hurricane Elsa	7/6/2021	1	75	75
Hurricane Elsa	7/6/2021	1	75	75
Hurricane Elsa	7/6/2021	19	5,415	285
Hurricane Elsa	7/6/2021	1	74	74
Hurricane Elsa	7/6/2021	20	1,540	77
Hurricane Elsa	7/6/2021	1	72	72
Hurricane Elsa	7/6/2021	1	71	71
Hurricane Elsa	7/6/2021	1	71	71
Hurricane Elsa	7/6/2021	1	71	71
Hurricane Elsa	7/6/2021	1	68	68
Hurricane Elsa	7/6/2021	10	610	61
Hurricane Elsa	7/6/2021	1	66	66
Hurricane Elsa	7/6/2021	1	66	66
Hurricane Elsa	7/6/2021	8	1,688	211
Hurricane Elsa	7/6/2021	2	136	68
Hurricane Elsa	7/6/2021	8	712	89
Hurricane Elsa	7/6/2021	1	62	62
Hurricane Elsa	7/6/2021	1	267	267
Hurricane Elsa	7/6/2021	1	122	122
Hurricane Elsa	7/6/2021	1	60	60
Hurricane Elsa	7/6/2021	104	6,864	66
Hurricane Elsa	7/6/2021	2	586	293
Hurricane Elsa	7/6/2021	1	140	140
Hurricane Elsa	7/6/2021	1	58	58
Hurricane Elsa	7/6/2021	206	21,836	106
Hurricane Elsa	7/6/2021	1	1,254	1,254
Hurricane Elsa	7/6/2021	1	55	55
Hurricane Elsa	7/6/2021	1	55	55
Hurricane Elsa	7/6/2021	1	54	54
Hurricane Elsa	7/6/2021	1	54	54
Hurricane Elsa	7/6/2021	1	54	54
Hurricane Elsa	7/6/2021	3	807	269
Hurricane Elsa	7/6/2021	1	50	50
Hurricane Elsa	7/6/2021	1	48	48
Hurricane Elsa	7/6/2021	1	49	49
Hurricane Elsa	7/6/2021	1	46	46

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	1	44	44
Hurricane Elsa	7/6/2021	289	42,194	146
Hurricane Elsa	7/6/2021	4	1,316	329
Hurricane Elsa	7/6/2021	1	57	57
Hurricane Elsa	7/6/2021	1	39	39
Hurricane Elsa	7/6/2021	1	64	64
Hurricane Elsa	7/6/2021	1	38	38
Hurricane Elsa	7/6/2021	1	34	34
Hurricane Elsa	7/6/2021	1	136	136
Hurricane Elsa	7/6/2021	1	293	293
Hurricane Elsa	7/6/2021	13	91	7
Hurricane Elsa	7/6/2021	1	49	49
Hurricane Elsa	7/6/2021	3	195	65
Hurricane Elsa	7/6/2021	1	25	25
Hurricane Elsa	7/6/2021	1	195	195
Hurricane Elsa	7/6/2021	1	167	167
Hurricane Elsa	7/6/2021	102	32,436	318
Hurricane Elsa	7/6/2021	9	3,096	344
Hurricane Elsa	7/6/2021	1	18	18
Hurricane Elsa	7/6/2021	16	2,000	125
Hurricane Elsa	7/6/2021	1	224	224
Hurricane Elsa	7/6/2021	4	836	209
Hurricane Elsa	7/6/2021	1	14	14
Hurricane Elsa	7/6/2021	107	75,542	706
Hurricane Elsa	7/6/2021	1	13	13
Hurricane Elsa	7/6/2021	11	3,003	273
Hurricane Elsa	7/6/2021	2	138	69
Hurricane Elsa	7/6/2021	115	12,650	110
Hurricane Elsa	7/6/2021	1	234	234
Hurricane Elsa	7/6/2021	86	4,042	47
Hurricane Elsa	7/6/2021	1	222	222
Hurricane Elsa	7/6/2021	1	206	206
Hurricane Elsa	7/6/2021	1	106	106
Hurricane Elsa	7/6/2021	74	4,144	56
Hurricane Elsa	7/6/2021	176	14,256	81
Hurricane Elsa	7/6/2021	1	56	56
Hurricane Elsa	7/6/2021	1	150	150
Hurricane Elsa	7/6/2021	1	53	53
Hurricane Elsa	7/6/2021	4	340	85
Hurricane Elsa	7/6/2021	3	1,851	617
Hurricane Elsa	7/6/2021	65	4,030	62
Hurricane Elsa	7/6/2021	4	416	104
Hurricane Elsa	7/6/2021	127	30,861	243

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	3	993	331
Hurricane Elsa	7/6/2021	15	5,805	387
Hurricane Elsa	7/6/2021	3	180	60
Hurricane Elsa	7/6/2021	3	1,014	338
Hurricane Elsa	7/6/2021	1	356	356
Hurricane Elsa	7/6/2021	1	338	338
Hurricane Elsa	7/6/2021	1	56	56
Hurricane Elsa	7/6/2021	3	159	53
Hurricane Elsa	7/6/2021	13	845	65
Hurricane Elsa	7/6/2021	40	13,800	345
Hurricane Elsa	7/6/2021	1	63	63
Hurricane Elsa	7/6/2021	11	341	31
Hurricane Elsa	7/6/2021	1	1,145	1,145
Hurricane Elsa	7/6/2021	29	9,135	315
Hurricane Elsa	7/6/2021	2	280	140
Hurricane Elsa	7/6/2021	5	585	117
Hurricane Elsa	7/6/2021	651	223,293	343
Hurricane Elsa	7/6/2021	88	39,600	450
Hurricane Elsa	7/6/2021	15	6,630	442
Hurricane Elsa	7/6/2021	1	22	22
Hurricane Elsa	7/6/2021	3	153	51
Hurricane Elsa	7/6/2021	7	1,309	187
Hurricane Elsa	7/6/2021	1	52	52
Hurricane Elsa	7/6/2021	10	3,230	323
Hurricane Elsa	7/6/2021	12	5,820	485
Hurricane Elsa	7/6/2021	8	3,840	480
Hurricane Elsa	7/6/2021	3	207	69
Hurricane Elsa	7/6/2021	3	354	118
Hurricane Elsa	7/6/2021	83	49,634	598
Hurricane Elsa	7/6/2021	8	776	97
Hurricane Elsa	7/6/2021	5	1,285	257
Hurricane Elsa	7/6/2021	46	2,254	49
Hurricane Elsa	7/6/2021	115	11,270	98
Hurricane Elsa	7/6/2021	1	229	229
Hurricane Elsa	7/6/2021	5	515	103
Hurricane Elsa	7/6/2021	34	11,050	325
Hurricane Elsa	7/6/2021	39	13,455	345
Hurricane Elsa	7/6/2021	1	578	578
Hurricane Elsa	7/6/2021	31	2,108	68
Hurricane Elsa	7/6/2021	1	48	48
Hurricane Elsa	7/6/2021	1	325	325
Hurricane Elsa	7/6/2021	515	14,715	1,118
Hurricane Elsa	7/6/2021	3	186	62

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	3	813	271
Hurricane Elsa	7/6/2021	4	916	229
Hurricane Elsa	7/6/2021	1	281	281
Hurricane Elsa	7/6/2021	2	804	402
Hurricane Elsa	7/6/2021	3,388	95,092	203
Hurricane Elsa	7/6/2021	68	44,336	652
Hurricane Elsa	7/6/2021	1	45	45
Hurricane Elsa	7/6/2021	1	68	68
Hurricane Elsa	7/6/2021	1	96	96
Hurricane Elsa	7/6/2021	4	1,144	286
Hurricane Elsa	7/6/2021	5	235	47
Hurricane Elsa	7/6/2021	1	122	122
Hurricane Elsa	7/6/2021	3	555	185
Hurricane Elsa	7/6/2021	1	416	416
Hurricane Elsa	7/6/2021	6	240	40
Hurricane Elsa	7/6/2021	1	183	183
Hurricane Elsa	7/6/2021	103	21,630	210
Hurricane Elsa	7/6/2021	1	95	95
Hurricane Elsa	7/6/2021	7	406	58
Hurricane Elsa	7/6/2021	1	713	713
Hurricane Elsa	7/6/2021	9	5,445	605
Hurricane Elsa	7/6/2021	2	78	39
Hurricane Elsa	7/6/2021	12	684	57
Hurricane Elsa	7/6/2021	351	145,665	415
Hurricane Elsa	7/6/2021	5	925	185
Hurricane Elsa	7/6/2021	1	338	338
Hurricane Elsa	7/6/2021	4	532	133
Hurricane Elsa	7/6/2021	1	351	351
Hurricane Elsa	7/6/2021	7	224	32
Hurricane Elsa	7/6/2021	1	393	393
Hurricane Elsa	7/6/2021	21	2,856	136
Hurricane Elsa	7/6/2021	65	19,695	303
Hurricane Elsa	7/6/2021	1	86	86
Hurricane Elsa	7/6/2021	128	37,248	291
Hurricane Elsa	7/6/2021	1	129	129
Hurricane Elsa	7/6/2021	135	71,280	528
Hurricane Elsa	7/6/2021	1	59	59
Hurricane Elsa	7/6/2021	1	18	18
Hurricane Elsa	7/6/2021	31	3,844	124
Hurricane Elsa	7/6/2021	6	744	124
Hurricane Elsa	7/6/2021	1	154	154
Hurricane Elsa	7/6/2021	160	61,920	387
Hurricane Elsa	7/6/2021	4	824	206

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	6	216	36
Hurricane Elsa	7/6/2021	21	2,352	112
Hurricane Elsa	7/6/2021	3,750	114,657	53
Hurricane Elsa	7/6/2021	7	840	120
Hurricane Elsa	7/6/2021	46	8,786	191
Hurricane Elsa	7/6/2021	2	620	310
Hurricane Elsa	7/6/2021	1	158	158
Hurricane Elsa	7/6/2021	19	247	13
Hurricane Elsa	7/6/2021	1	114	114
Hurricane Elsa	7/6/2021	95	41,515	437
Hurricane Elsa	7/6/2021	36	5,328	148
Hurricane Elsa	7/6/2021	98	9,800	100
Hurricane Elsa	7/6/2021	10	810	81
Hurricane Elsa	7/6/2021	47	25,192	536
Hurricane Elsa	7/6/2021	244	31,232	128
Hurricane Elsa	7/6/2021	2,419	102,956	312
Hurricane Elsa	7/6/2021	16	9,360	585
Hurricane Elsa	7/6/2021	1	19	19
Hurricane Elsa	7/6/2021	4	488	122
Hurricane Elsa	7/6/2021	99	7,128	72
Hurricane Elsa	7/6/2021	50	7,104	594
Hurricane Elsa	7/6/2021	3	2,724	908
Hurricane Elsa	7/6/2021	1	887	887
Hurricane Elsa	7/6/2021	6	318	53
Hurricane Elsa	7/6/2021	17	6,154	362
Hurricane Elsa	7/6/2021	7	1,897	271
Hurricane Elsa	7/6/2021	1	105	105
Hurricane Elsa	7/6/2021	5	275	55
Hurricane Elsa	7/6/2021	6	1,800	300
Hurricane Elsa	7/6/2021	7	588	84
Hurricane Elsa	7/6/2021	1	34	34
Hurricane Elsa	7/6/2021	1,485	1,485	1
Hurricane Elsa	7/6/2021	2	522	261
Hurricane Elsa	7/6/2021	31	2,387	77
Hurricane Elsa	7/6/2021	1	90	90
Hurricane Elsa	7/6/2021	19	7,391	389
Hurricane Elsa	7/6/2021	5	365	73
Hurricane Elsa	7/6/2021	1	315	315
Hurricane Elsa	7/6/2021	9	4,617	513
Hurricane Elsa	7/6/2021	1	661	661
Hurricane Elsa	7/6/2021	63	2,205	35
Hurricane Elsa	7/6/2021	1	239	239
Hurricane Elsa	7/6/2021	14	11,970	855

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/6/2021	3	1,140	380
Hurricane Elsa	7/6/2021	8	2,248	281
Hurricane Elsa	7/6/2021	3	1,062	354
Hurricane Elsa	7/6/2021	1	259	259
Hurricane Elsa	7/6/2021	17	1,156	68
Hurricane Elsa	7/6/2021	7	4,480	640
Hurricane Elsa	7/6/2021	29	6,583	227
Hurricane Elsa	7/6/2021	6	408	68
Hurricane Elsa	7/6/2021	1	227	227
Hurricane Elsa	7/7/2021	2	504	252
Hurricane Elsa	7/7/2021	2	326	163
Hurricane Elsa	7/7/2021	7	1,134	162
Hurricane Elsa	7/7/2021	1	255	255
Hurricane Elsa	7/7/2021	6	2,892	482
Hurricane Elsa	7/7/2021	314	87,606	279
Hurricane Elsa	7/7/2021	6	504	84
Hurricane Elsa	7/7/2021	1	62	62
Hurricane Elsa	7/7/2021	1	97	97
Hurricane Elsa	7/7/2021	1	105	105
Hurricane Elsa	7/7/2021	24	9,144	381
Hurricane Elsa	7/7/2021	1	379	379
Hurricane Elsa	7/7/2021	3	318	106
Hurricane Elsa	7/7/2021	1	89	89
Hurricane Elsa	7/7/2021	3	765	255
Hurricane Elsa	7/7/2021	2	172	86
Hurricane Elsa	7/7/2021	1	346	346
Hurricane Elsa	7/7/2021	1	91	91
Hurricane Elsa	7/7/2021	1	59	59
Hurricane Elsa	7/7/2021	1	52	52
Hurricane Elsa	7/7/2021	3	180	60
Hurricane Elsa	7/7/2021	1	312	312
Hurricane Elsa	7/7/2021	86	11,696	136
Hurricane Elsa	7/7/2021	17	1,921	113
Hurricane Elsa	7/7/2021	4	336	84
Hurricane Elsa	7/7/2021	19	931	49
Hurricane Elsa	7/7/2021	2	76	38
Hurricane Elsa	7/7/2021	1	58	58
Hurricane Elsa	7/7/2021	21	5,313	253
Hurricane Elsa	7/7/2021	4	360	90
Hurricane Elsa	7/7/2021	1	103	103
Hurricane Elsa	7/7/2021	1	327	327
Hurricane Elsa	7/7/2021	71	26,199	369
Hurricane Elsa	7/7/2021	34	10,710	315

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	13	1,443	111
Hurricane Elsa	7/7/2021	73	22,849	313
Hurricane Elsa	7/7/2021	2	610	305
Hurricane Elsa	7/7/2021	63	4,662	74
Hurricane Elsa	7/7/2021	11	726	66
Hurricane Elsa	7/7/2021	1	83	83
Hurricane Elsa	7/7/2021	97	25,996	268
Hurricane Elsa	7/7/2021	1	120	120
Hurricane Elsa	7/7/2021	1	413	413
Hurricane Elsa	7/7/2021	8	752	94
Hurricane Elsa	7/7/2021	1	360	360
Hurricane Elsa	7/7/2021	77	39,963	519
Hurricane Elsa	7/7/2021	3	264	88
Hurricane Elsa	7/7/2021	12	2,364	197
Hurricane Elsa	7/7/2021	22	2,068	94
Hurricane Elsa	7/7/2021	12	7,584	632
Hurricane Elsa	7/7/2021	16	11,152	697
Hurricane Elsa	7/7/2021	3	621	207
Hurricane Elsa	7/7/2021	5	225	45
Hurricane Elsa	7/7/2021	4	908	227
Hurricane Elsa	7/7/2021	60	13,665	637
Hurricane Elsa	7/7/2021	1	291	291
Hurricane Elsa	7/7/2021	1	228	228
Hurricane Elsa	7/7/2021	1	55	55
Hurricane Elsa	7/7/2021	63	5,544	88
Hurricane Elsa	7/7/2021	36	3,492	242
Hurricane Elsa	7/7/2021	1	995	995
Hurricane Elsa	7/7/2021	1	219	219
Hurricane Elsa	7/7/2021	75	27,750	370
Hurricane Elsa	7/7/2021	6	330	55
Hurricane Elsa	7/7/2021	5	3,205	641
Hurricane Elsa	7/7/2021	1	67	67
Hurricane Elsa	7/7/2021	77	27,720	360
Hurricane Elsa	7/7/2021	1	109	109
Hurricane Elsa	7/7/2021	57	32,205	565
Hurricane Elsa	7/7/2021	1	207	207
Hurricane Elsa	7/7/2021	1	490	490
Hurricane Elsa	7/7/2021	1	398	398
Hurricane Elsa	7/7/2021	7	735	105
Hurricane Elsa	7/7/2021	1	33	33
Hurricane Elsa	7/7/2021	1	344	344
Hurricane Elsa	7/7/2021	32	7,232	226
Hurricane Elsa	7/7/2021	6	972	162

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	177	177
Hurricane Elsa	7/7/2021	18	2,538	141
Hurricane Elsa	7/7/2021	22	4,730	215
Hurricane Elsa	7/7/2021	4	1,572	393
Hurricane Elsa	7/7/2021	55	34,672	811
Hurricane Elsa	7/7/2021	32	4,700	610
Hurricane Elsa	7/7/2021	1	236	236
Hurricane Elsa	7/7/2021	53	11,365	708
Hurricane Elsa	7/7/2021	3	390	130
Hurricane Elsa	7/7/2021	173	1,013	421
Hurricane Elsa	7/7/2021	17	8,466	498
Hurricane Elsa	7/7/2021	1	100	100
Hurricane Elsa	7/7/2021	5	440	88
Hurricane Elsa	7/7/2021	1	99	99
Hurricane Elsa	7/7/2021	18	2,610	145
Hurricane Elsa	7/7/2021	1	105	105
Hurricane Elsa	7/7/2021	2	204	102
Hurricane Elsa	7/7/2021	1	31	31
Hurricane Elsa	7/7/2021	7	2,779	397
Hurricane Elsa	7/7/2021	2,419	134,145	564
Hurricane Elsa	7/7/2021	1	311	311
Hurricane Elsa	7/7/2021	447	739	74
Hurricane Elsa	7/7/2021	2	216	108
Hurricane Elsa	7/7/2021	2	138	69
Hurricane Elsa	7/7/2021	76	2,044	329
Hurricane Elsa	7/7/2021	60	8,880	148
Hurricane Elsa	7/7/2021	28	4,760	170
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	1	144	144
Hurricane Elsa	7/7/2021	1	7	7
Hurricane Elsa	7/7/2021	10	4,450	445
Hurricane Elsa	7/7/2021	11	1,155	105
Hurricane Elsa	7/7/2021	9	5,346	594
Hurricane Elsa	7/7/2021	3	207	69
Hurricane Elsa	7/7/2021	1	217	217
Hurricane Elsa	7/7/2021	39	20,631	592
Hurricane Elsa	7/7/2021	1	191	191
Hurricane Elsa	7/7/2021	136	11,606	571
Hurricane Elsa	7/7/2021	1	318	318
Hurricane Elsa	7/7/2021	7	1,316	188
Hurricane Elsa	7/7/2021	14	2,226	159
Hurricane Elsa	7/7/2021	1	259	259
Hurricane Elsa	7/7/2021	2	290	145

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	187	187
Hurricane Elsa	7/7/2021	1	92	92
Hurricane Elsa	7/7/2021	4	836	209
Hurricane Elsa	7/7/2021	18	5,994	333
Hurricane Elsa	7/7/2021	1	135	135
Hurricane Elsa	7/7/2021	2	674	337
Hurricane Elsa	7/7/2021	1	305	305
Hurricane Elsa	7/7/2021	1	165	165
Hurricane Elsa	7/7/2021	1	209	209
Hurricane Elsa	7/7/2021	1	55	55
Hurricane Elsa	7/7/2021	1	272	272
Hurricane Elsa	7/7/2021	15	2,085	139
Hurricane Elsa	7/7/2021	1,011	41,451	41
Hurricane Elsa	7/7/2021	1	82	82
Hurricane Elsa	7/7/2021	3	1,215	405
Hurricane Elsa	7/7/2021	1	473	473
Hurricane Elsa	7/7/2021	1	116	116
Hurricane Elsa	7/7/2021	46	1,243	217
Hurricane Elsa	7/7/2021	2	142	71
Hurricane Elsa	7/7/2021	8	2,304	288
Hurricane Elsa	7/7/2021	66	24,090	365
Hurricane Elsa	7/7/2021	1	96	96
Hurricane Elsa	7/7/2021	5	630	126
Hurricane Elsa	7/7/2021	1	191	191
Hurricane Elsa	7/7/2021	1	101	101
Hurricane Elsa	7/7/2021	1	190	190
Hurricane Elsa	7/7/2021	15	5,880	392
Hurricane Elsa	7/7/2021	32	15,360	480
Hurricane Elsa	7/7/2021	11	3,646	456
Hurricane Elsa	7/7/2021	12	4,092	341
Hurricane Elsa	7/7/2021	1	423	423
Hurricane Elsa	7/7/2021	2	396	198
Hurricane Elsa	7/7/2021	1	230	230
Hurricane Elsa	7/7/2021	1	268	268
Hurricane Elsa	7/7/2021	1	167	167
Hurricane Elsa	7/7/2021	1	394	394
Hurricane Elsa	7/7/2021	1	103	103
Hurricane Elsa	7/7/2021	1	63	63
Hurricane Elsa	7/7/2021	1	339	339
Hurricane Elsa	7/7/2021	1	457	457
Hurricane Elsa	7/7/2021	3	246	82
Hurricane Elsa	7/7/2021	4	264	66
Hurricane Elsa	7/7/2021	10	1,300	130

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	115	115
Hurricane Elsa	7/7/2021	1	141	141
Hurricane Elsa	7/7/2021	44	8,800	200
Hurricane Elsa	7/7/2021	10	1,500	150
Hurricane Elsa	7/7/2021	5	375	75
Hurricane Elsa	7/7/2021	1	166	166
Hurricane Elsa	7/7/2021	1	86	86
Hurricane Elsa	7/7/2021	1	294	294
Hurricane Elsa	7/7/2021	15	405	27
Hurricane Elsa	7/7/2021	2	76	38
Hurricane Elsa	7/7/2021	1	167	167
Hurricane Elsa	7/7/2021	1	155	155
Hurricane Elsa	7/7/2021	6	1,284	214
Hurricane Elsa	7/7/2021	1	321	321
Hurricane Elsa	7/7/2021	1	446	446
Hurricane Elsa	7/7/2021	1	361	361
Hurricane Elsa	7/7/2021	1	291	291
Hurricane Elsa	7/7/2021	1	140	140
Hurricane Elsa	7/7/2021	4	656	164
Hurricane Elsa	7/7/2021	1	139	139
Hurricane Elsa	7/7/2021	1	141	141
Hurricane Elsa	7/7/2021	1	228	228
Hurricane Elsa	7/7/2021	1	125	125
Hurricane Elsa	7/7/2021	1	197	197
Hurricane Elsa	7/7/2021	6	1,386	231
Hurricane Elsa	7/7/2021	1	90	90
Hurricane Elsa	7/7/2021	1	78	78
Hurricane Elsa	7/7/2021	1	163	163
Hurricane Elsa	7/7/2021	1	132	132
Hurricane Elsa	7/7/2021	2,793	89,108	51
Hurricane Elsa	7/7/2021	1	36	36
Hurricane Elsa	7/7/2021	1	234	234
Hurricane Elsa	7/7/2021	1	397	397
Hurricane Elsa	7/7/2021	6	570	95
Hurricane Elsa	7/7/2021	1	68	68
Hurricane Elsa	7/7/2021	20	10,140	507
Hurricane Elsa	7/7/2021	2	1,014	507
Hurricane Elsa	7/7/2021	1,210	4,840	4
Hurricane Elsa	7/7/2021	1	361	361
Hurricane Elsa	7/7/2021	96	10,329	264
Hurricane Elsa	7/7/2021	1	181	181
Hurricane Elsa	7/7/2021	2	366	183
Hurricane Elsa	7/7/2021	1	52	52

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	42	32,844	782
Hurricane Elsa	7/7/2021	26	988	38
Hurricane Elsa	7/7/2021	11	363	33
Hurricane Elsa	7/7/2021	1	94	94
Hurricane Elsa	7/7/2021	1	103	103
Hurricane Elsa	7/7/2021	1	223	223
Hurricane Elsa	7/7/2021	4	1,776	444
Hurricane Elsa	7/7/2021	1	164	164
Hurricane Elsa	7/7/2021	22	1,188	54
Hurricane Elsa	7/7/2021	1	172	172
Hurricane Elsa	7/7/2021	19	3,306	174
Hurricane Elsa	7/7/2021	1	145	145
Hurricane Elsa	7/7/2021	1	94	94
Hurricane Elsa	7/7/2021	1	155	155
Hurricane Elsa	7/7/2021	13	1,508	116
Hurricane Elsa	7/7/2021	1	132	132
Hurricane Elsa	7/7/2021	1	88	88
Hurricane Elsa	7/7/2021	27	270	10
Hurricane Elsa	7/7/2021	1	348	348
Hurricane Elsa	7/7/2021	1	205	205
Hurricane Elsa	7/7/2021	1	118	118
Hurricane Elsa	7/7/2021	50	8,400	168
Hurricane Elsa	7/7/2021	1	38	38
Hurricane Elsa	7/7/2021	6	552	92
Hurricane Elsa	7/7/2021	12	828	69
Hurricane Elsa	7/7/2021	1	43	43
Hurricane Elsa	7/7/2021	1	114	114
Hurricane Elsa	7/7/2021	1	60	60
Hurricane Elsa	7/7/2021	1	110	110
Hurricane Elsa	7/7/2021	1	215	215
Hurricane Elsa	7/7/2021	2	74	37
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	113	48,267	603
Hurricane Elsa	7/7/2021	6	2,328	388
Hurricane Elsa	7/7/2021	1	308	308
Hurricane Elsa	7/7/2021	1	258	258
Hurricane Elsa	7/7/2021	2	490	245
Hurricane Elsa	7/7/2021	35	4,690	134
Hurricane Elsa	7/7/2021	3	684	228
Hurricane Elsa	7/7/2021	1	176	176
Hurricane Elsa	7/7/2021	1	283	283
Hurricane Elsa	7/7/2021	1	240	240
Hurricane Elsa	7/7/2021	51	4,284	84

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	3	234	78
Hurricane Elsa	7/7/2021	1	514	514
Hurricane Elsa	7/7/2021	1	237	237
Hurricane Elsa	7/7/2021	32	12,992	406
Hurricane Elsa	7/7/2021	1	98	98
Hurricane Elsa	7/7/2021	8	1,352	169
Hurricane Elsa	7/7/2021	1	345	345
Hurricane Elsa	7/7/2021	2	433	317
Hurricane Elsa	7/7/2021	1	73	73
Hurricane Elsa	7/7/2021	12	1,176	98
Hurricane Elsa	7/7/2021	1	38	38
Hurricane Elsa	7/7/2021	1	43	43
Hurricane Elsa	7/7/2021	1	384	384
Hurricane Elsa	7/7/2021	8	48	6
Hurricane Elsa	7/7/2021	6	852	142
Hurricane Elsa	7/7/2021	1	149	149
Hurricane Elsa	7/7/2021	1	245	245
Hurricane Elsa	7/7/2021	83	9,379	113
Hurricane Elsa	7/7/2021	1	60	60
Hurricane Elsa	7/7/2021	6	1,776	296
Hurricane Elsa	7/7/2021	1	119	119
Hurricane Elsa	7/7/2021	1	149	149
Hurricane Elsa	7/7/2021	1	649	649
Hurricane Elsa	7/7/2021	1	112	112
Hurricane Elsa	7/7/2021	11	132	12
Hurricane Elsa	7/7/2021	1	53	53
Hurricane Elsa	7/7/2021	27	7,078	286
Hurricane Elsa	7/7/2021	1	285	285
Hurricane Elsa	7/7/2021	6	150	25
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	1	352	352
Hurricane Elsa	7/7/2021	2	306	153
Hurricane Elsa	7/7/2021	1	324	324
Hurricane Elsa	7/7/2021	66	2,178	33
Hurricane Elsa	7/7/2021	1	563	563
Hurricane Elsa	7/7/2021	7	231	33
Hurricane Elsa	7/7/2021	1	202	202
Hurricane Elsa	7/7/2021	1	71	71
Hurricane Elsa	7/7/2021	1	176	176
Hurricane Elsa	7/7/2021	16	3,440	215
Hurricane Elsa	7/7/2021	1	292	292
Hurricane Elsa	7/7/2021	1	154	154
Hurricane Elsa	7/7/2021	1	243	243

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	4	1,492	373
Hurricane Elsa	7/7/2021	12	441	81
Hurricane Elsa	7/7/2021	1	141	141
Hurricane Elsa	7/7/2021	2	36	18
Hurricane Elsa	7/7/2021	110	19,382	641
Hurricane Elsa	7/7/2021	5	1,435	287
Hurricane Elsa	7/7/2021	8	696	87
Hurricane Elsa	7/7/2021	248	34,184	544
Hurricane Elsa	7/7/2021	10	1,700	170
Hurricane Elsa	7/7/2021	9	4,005	445
Hurricane Elsa	7/7/2021	3	1,278	426
Hurricane Elsa	7/7/2021	6	756	126
Hurricane Elsa	7/7/2021	2	822	411
Hurricane Elsa	7/7/2021	2,785	129,382	350
Hurricane Elsa	7/7/2021	57	8,721	153
Hurricane Elsa	7/7/2021	1	180	180
Hurricane Elsa	7/7/2021	70	416	347
Hurricane Elsa	7/7/2021	1	270	270
Hurricane Elsa	7/7/2021	9	873	97
Hurricane Elsa	7/7/2021	8	928	116
Hurricane Elsa	7/7/2021	1	61	61
Hurricane Elsa	7/7/2021	4	720	180
Hurricane Elsa	7/7/2021	2	128	64
Hurricane Elsa	7/7/2021	1	141	141
Hurricane Elsa	7/7/2021	68	11,152	182
Hurricane Elsa	7/7/2021	1	58	58
Hurricane Elsa	7/7/2021	1	331	331
Hurricane Elsa	7/7/2021	1	115	115
Hurricane Elsa	7/7/2021	2	82	41
Hurricane Elsa	7/7/2021	7	1,715	245
Hurricane Elsa	7/7/2021	1	222	222
Hurricane Elsa	7/7/2021	1	183	183
Hurricane Elsa	7/7/2021	3	147	49
Hurricane Elsa	7/7/2021	2	330	165
Hurricane Elsa	7/7/2021	14	2,078	337
Hurricane Elsa	7/7/2021	12	4,740	395
Hurricane Elsa	7/7/2021	2	408	204
Hurricane Elsa	7/7/2021	1	290	290
Hurricane Elsa	7/7/2021	1	421	421
Hurricane Elsa	7/7/2021	35	7,490	214
Hurricane Elsa	7/7/2021	4	104	26
Hurricane Elsa	7/7/2021	1	142	142
Hurricane Elsa	7/7/2021	1	232	232

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	6	360	60
Hurricane Elsa	7/7/2021	1	103	103
Hurricane Elsa	7/7/2021	63	21,294	338
Hurricane Elsa	7/7/2021	1	488	488
Hurricane Elsa	7/7/2021	16	4,064	254
Hurricane Elsa	7/7/2021	2	242	121
Hurricane Elsa	7/7/2021	1	110	110
Hurricane Elsa	7/7/2021	8	160	20
Hurricane Elsa	7/7/2021	1	169	169
Hurricane Elsa	7/7/2021	1	78	78
Hurricane Elsa	7/7/2021	1	450	450
Hurricane Elsa	7/7/2021	2	104	52
Hurricane Elsa	7/7/2021	5	490	98
Hurricane Elsa	7/7/2021	3	468	156
Hurricane Elsa	7/7/2021	2	850	425
Hurricane Elsa	7/7/2021	12	3,336	278
Hurricane Elsa	7/7/2021	4	604	151
Hurricane Elsa	7/7/2021	7	3,815	545
Hurricane Elsa	7/7/2021	440	5,560	41
Hurricane Elsa	7/7/2021	54	19,278	357
Hurricane Elsa	7/7/2021	1	611	611
Hurricane Elsa	7/7/2021	8	2,360	295
Hurricane Elsa	7/7/2021	257	74,787	291
Hurricane Elsa	7/7/2021	19	3,211	169
Hurricane Elsa	7/7/2021	1	499	499
Hurricane Elsa	7/7/2021	5	1,265	253
Hurricane Elsa	7/7/2021	36	1,800	50
Hurricane Elsa	7/7/2021	1	43	43
Hurricane Elsa	7/7/2021	2	222	111
Hurricane Elsa	7/7/2021	12	612	51
Hurricane Elsa	7/7/2021	2	38	19
Hurricane Elsa	7/7/2021	19	6,859	361
Hurricane Elsa	7/7/2021	3	447	149
Hurricane Elsa	7/7/2021	1	220	220
Hurricane Elsa	7/7/2021	1	367	367
Hurricane Elsa	7/7/2021	12	4,956	413
Hurricane Elsa	7/7/2021	1	252	252
Hurricane Elsa	7/7/2021	490	48,741	681
Hurricane Elsa	7/7/2021	72	41,328	574
Hurricane Elsa	7/7/2021	1	170	170
Hurricane Elsa	7/7/2021	708	148,952	534
Hurricane Elsa	7/7/2021	1	394	394
Hurricane Elsa	7/7/2021	117	7,839	67

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	3	678	226
Hurricane Elsa	7/7/2021	28	5,152	184
Hurricane Elsa	7/7/2021	4	648	162
Hurricane Elsa	7/7/2021	1	331	331
Hurricane Elsa	7/7/2021	15	3,015	201
Hurricane Elsa	7/7/2021	19	4,541	239
Hurricane Elsa	7/7/2021	3	327	109
Hurricane Elsa	7/7/2021	9	1,206	134
Hurricane Elsa	7/7/2021	82	23,392	438
Hurricane Elsa	7/7/2021	77	2,156	28
Hurricane Elsa	7/7/2021	11	77	7
Hurricane Elsa	7/7/2021	1	418	418
Hurricane Elsa	7/7/2021	36	6,336	176
Hurricane Elsa	7/7/2021	1	155	155
Hurricane Elsa	7/7/2021	1	1,335	1,335
Hurricane Elsa	7/7/2021	28	1,456	52
Hurricane Elsa	7/7/2021	1	59	59
Hurricane Elsa	7/7/2021	4	336	84
Hurricane Elsa	7/7/2021	1	223	223
Hurricane Elsa	7/7/2021	85	24,735	291
Hurricane Elsa	7/7/2021	1	618	618
Hurricane Elsa	7/7/2021	8	2,072	259
Hurricane Elsa	7/7/2021	1	130	130
Hurricane Elsa	7/7/2021	1	325	325
Hurricane Elsa	7/7/2021	2	290	145
Hurricane Elsa	7/7/2021	1	321	321
Hurricane Elsa	7/7/2021	18	5,832	324
Hurricane Elsa	7/7/2021	370	5,360	53
Hurricane Elsa	7/7/2021	22	5,038	229
Hurricane Elsa	7/7/2021	40	1,760	44
Hurricane Elsa	7/7/2021	5	465	93
Hurricane Elsa	7/7/2021	4	544	136
Hurricane Elsa	7/7/2021	3	735	245
Hurricane Elsa	7/7/2021	1	208	208
Hurricane Elsa	7/7/2021	1	201	201
Hurricane Elsa	7/7/2021	2	448	224
Hurricane Elsa	7/7/2021	2	362	181
Hurricane Elsa	7/7/2021	1	194	194
Hurricane Elsa	7/7/2021	36	1,332	37
Hurricane Elsa	7/7/2021	1	132	132
Hurricane Elsa	7/7/2021	28	7,196	257
Hurricane Elsa	7/7/2021	1	81	81
Hurricane Elsa	7/7/2021	93	45,198	486

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	71	71
Hurricane Elsa	7/7/2021	2	356	178
Hurricane Elsa	7/7/2021	2	908	454
Hurricane Elsa	7/7/2021	538	1,614	3
Hurricane Elsa	7/7/2021	1	317	317
Hurricane Elsa	7/7/2021	4	152	38
Hurricane Elsa	7/7/2021	3	114	38
Hurricane Elsa	7/7/2021	79	11,218	142
Hurricane Elsa	7/7/2021	3	306	102
Hurricane Elsa	7/7/2021	9	3,717	413
Hurricane Elsa	7/7/2021	1	162	162
Hurricane Elsa	7/7/2021	4	4	326
Hurricane Elsa	7/7/2021	1	45	45
Hurricane Elsa	7/7/2021	67	2,211	33
Hurricane Elsa	7/7/2021	1	290	290
Hurricane Elsa	7/7/2021	6	636	106
Hurricane Elsa	7/7/2021	3	525	175
Hurricane Elsa	7/7/2021	84	30,996	369
Hurricane Elsa	7/7/2021	9	864	96
Hurricane Elsa	7/7/2021	1	54	54
Hurricane Elsa	7/7/2021	29	4,843	167
Hurricane Elsa	7/7/2021	1	278	278
Hurricane Elsa	7/7/2021	3	471	157
Hurricane Elsa	7/7/2021	1	98	98
Hurricane Elsa	7/7/2021	6	2,760	460
Hurricane Elsa	7/7/2021	1	274	274
Hurricane Elsa	7/7/2021	2	476	238
Hurricane Elsa	7/7/2021	3	648	216
Hurricane Elsa	7/7/2021	5	1,525	305
Hurricane Elsa	7/7/2021	4	1,412	353
Hurricane Elsa	7/7/2021	10	250	25
Hurricane Elsa	7/7/2021	1	106	106
Hurricane Elsa	7/7/2021	2	592	296
Hurricane Elsa	7/7/2021	17	1,156	68
Hurricane Elsa	7/7/2021	8	256	32
Hurricane Elsa	7/7/2021	8	1,384	173
Hurricane Elsa	7/7/2021	14	2,086	149
Hurricane Elsa	7/7/2021	173	19,895	115
Hurricane Elsa	7/7/2021	31	4,557	147
Hurricane Elsa	7/7/2021	1	130	130
Hurricane Elsa	7/7/2021	3,133	6,266	2
Hurricane Elsa	7/7/2021	113	10,622	94
Hurricane Elsa	7/7/2021	1	347	347

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	171	9,747	57
Hurricane Elsa	7/7/2021	55	11,990	218
Hurricane Elsa	7/7/2021	1	292	292
Hurricane Elsa	7/7/2021	20	640	32
Hurricane Elsa	7/7/2021	1	168	168
Hurricane Elsa	7/7/2021	3	711	237
Hurricane Elsa	7/7/2021	1	541	541
Hurricane Elsa	7/7/2021	2	156	78
Hurricane Elsa	7/7/2021	1	169	169
Hurricane Elsa	7/7/2021	8	4,640	580
Hurricane Elsa	7/7/2021	7	224	32
Hurricane Elsa	7/7/2021	6	18	3
Hurricane Elsa	7/7/2021	2	494	247
Hurricane Elsa	7/7/2021	1	422	422
Hurricane Elsa	7/7/2021	1	113	113
Hurricane Elsa	7/7/2021	2	54	27
Hurricane Elsa	7/7/2021	1	375	375
Hurricane Elsa	7/7/2021	12	924	77
Hurricane Elsa	7/7/2021	9	684	76
Hurricane Elsa	7/7/2021	2	152	76
Hurricane Elsa	7/7/2021	12	912	76
Hurricane Elsa	7/7/2021	11	836	76
Hurricane Elsa	7/7/2021	7	532	76
Hurricane Elsa	7/7/2021	1	76	76
Hurricane Elsa	7/7/2021	7	525	75
Hurricane Elsa	7/7/2021	18	1,350	75
Hurricane Elsa	7/7/2021	1	75	75
Hurricane Elsa	7/7/2021	10	740	74
Hurricane Elsa	7/7/2021	1	73	73
Hurricane Elsa	7/7/2021	1	71	71
Hurricane Elsa	7/7/2021	1	44	44
Hurricane Elsa	7/7/2021	1	54	54
Hurricane Elsa	7/7/2021	2	86	43
Hurricane Elsa	7/7/2021	4	284	71
Hurricane Elsa	7/7/2021	17	1,207	71
Hurricane Elsa	7/7/2021	1	71	71
Hurricane Elsa	7/7/2021	1	68	68
Hurricane Elsa	7/7/2021	7	427	61
Hurricane Elsa	7/7/2021	1	56	56
Hurricane Elsa	7/7/2021	1	52	52
Hurricane Elsa	7/7/2021	3	150	50
Hurricane Elsa	7/7/2021	3	147	49
Hurricane Elsa	7/7/2021	1	49	49

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	47	47
Hurricane Elsa	7/7/2021	1	43	43
Hurricane Elsa	7/7/2021	2	78	39
Hurricane Elsa	7/7/2021	1	18	18
Hurricane Elsa	7/7/2021	4	1,924	481
Hurricane Elsa	7/7/2021	8	1,232	154
Hurricane Elsa	7/7/2021	11	3,586	326
Hurricane Elsa	7/7/2021	15	5,325	355
Hurricane Elsa	7/7/2021	1	86	86
Hurricane Elsa	7/7/2021	298	27,881	251
Hurricane Elsa	7/7/2021	1	363	363
Hurricane Elsa	7/7/2021	24	7,392	308
Hurricane Elsa	7/7/2021	71	8,449	119
Hurricane Elsa	7/7/2021	1	317	317
Hurricane Elsa	7/7/2021	1	222	222
Hurricane Elsa	7/7/2021	56	5,354	404
Hurricane Elsa	7/7/2021	4	188	47
Hurricane Elsa	7/7/2021	117	14,040	120
Hurricane Elsa	7/7/2021	60	3,660	61
Hurricane Elsa	7/7/2021	50	12,450	249
Hurricane Elsa	7/7/2021	1	154	154
Hurricane Elsa	7/7/2021	1	1,022	1,022
Hurricane Elsa	7/7/2021	2	656	328
Hurricane Elsa	7/7/2021	5	1,075	215
Hurricane Elsa	7/7/2021	28	4,424	158
Hurricane Elsa	7/7/2021	2	1,110	642
Hurricane Elsa	7/7/2021	17	4,573	269
Hurricane Elsa	7/7/2021	13	6,201	477
Hurricane Elsa	7/7/2021	3	660	220
Hurricane Elsa	7/7/2021	1	144	144
Hurricane Elsa	7/7/2021	9	585	65
Hurricane Elsa	7/7/2021	1	24	24
Hurricane Elsa	7/7/2021	1	439	439
Hurricane Elsa	7/7/2021	8	3,416	427
Hurricane Elsa	7/7/2021	72	21,816	303
Hurricane Elsa	7/7/2021	117	33,111	283
Hurricane Elsa	7/7/2021	72	4,680	65
Hurricane Elsa	7/7/2021	23	9,108	396
Hurricane Elsa	7/7/2021	1	111	111
Hurricane Elsa	7/7/2021	53	9,381	177
Hurricane Elsa	7/7/2021	260	37,020	152
Hurricane Elsa	7/7/2021	2	354	177
Hurricane Elsa	7/7/2021	79	8,848	112

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	279	279
Hurricane Elsa	7/7/2021	26	2,548	98
Hurricane Elsa	7/7/2021	23	10,902	474
Hurricane Elsa	7/7/2021	5	1,420	284
Hurricane Elsa	7/7/2021	1	282	282
Hurricane Elsa	7/7/2021	1	123	123
Hurricane Elsa	7/7/2021	86	5,332	62
Hurricane Elsa	7/7/2021	1	198	198
Hurricane Elsa	7/7/2021	5	275	55
Hurricane Elsa	7/7/2021	49	12,446	254
Hurricane Elsa	7/7/2021	15	3,630	242
Hurricane Elsa	7/7/2021	1	162	162
Hurricane Elsa	7/7/2021	7	861	123
Hurricane Elsa	7/7/2021	1	231	231
Hurricane Elsa	7/7/2021	1	228	228
Hurricane Elsa	7/7/2021	4	228	57
Hurricane Elsa	7/7/2021	79	8,453	107
Hurricane Elsa	7/7/2021	1	161	161
Hurricane Elsa	7/7/2021	4	688	172
Hurricane Elsa	7/7/2021	10	1,880	188
Hurricane Elsa	7/7/2021	1	36	36
Hurricane Elsa	7/7/2021	2	258	129
Hurricane Elsa	7/7/2021	14	1,400	100
Hurricane Elsa	7/7/2021	1	202	202
Hurricane Elsa	7/7/2021	1	625	625
Hurricane Elsa	7/7/2021	1	188	188
Hurricane Elsa	7/7/2021	1	126	126
Hurricane Elsa	7/7/2021	1	73	73
Hurricane Elsa	7/7/2021	2	478	239
Hurricane Elsa	7/7/2021	1	38	38
Hurricane Elsa	7/7/2021	1	181	181
Hurricane Elsa	7/7/2021	1	69	69
Hurricane Elsa	7/7/2021	1	132	132
Hurricane Elsa	7/7/2021	39	2,613	67
Hurricane Elsa	7/7/2021	1	206	206
Hurricane Elsa	7/7/2021	3	345	115
Hurricane Elsa	7/7/2021	2	672	336
Hurricane Elsa	7/7/2021	17	1,547	91
Hurricane Elsa	7/7/2021	10	2,970	297
Hurricane Elsa	7/7/2021	1	268	268
Hurricane Elsa	7/7/2021	1	185	185
Hurricane Elsa	7/7/2021	1	163	163
Hurricane Elsa	7/7/2021	1	305	305

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1,727	22,041	29
Hurricane Elsa	7/7/2021	14	1,176	84
Hurricane Elsa	7/7/2021	1	88	88
Hurricane Elsa	7/7/2021	1	112	112
Hurricane Elsa	7/7/2021	1	134	134
Hurricane Elsa	7/7/2021	53	3,604	68
Hurricane Elsa	7/7/2021	38	4,902	129
Hurricane Elsa	7/7/2021	1	364	364
Hurricane Elsa	7/7/2021	1	80	80
Hurricane Elsa	7/7/2021	1	306	306
Hurricane Elsa	7/7/2021	1	227	227
Hurricane Elsa	7/7/2021	1	584	584
Hurricane Elsa	7/7/2021	1	39	39
Hurricane Elsa	7/7/2021	1	147	147
Hurricane Elsa	7/7/2021	1	98	98
Hurricane Elsa	7/7/2021	1,091	31,639	29
Hurricane Elsa	7/7/2021	3	903	301
Hurricane Elsa	7/7/2021	45	3,780	84
Hurricane Elsa	7/7/2021	1	277	277
Hurricane Elsa	7/7/2021	1	196	196
Hurricane Elsa	7/7/2021	1	152	152
Hurricane Elsa	7/7/2021	1	33	33
Hurricane Elsa	7/7/2021	1	95	95
Hurricane Elsa	7/7/2021	1	92	92
Hurricane Elsa	7/7/2021	1	345	345
Hurricane Elsa	7/7/2021	9	594	66
Hurricane Elsa	7/7/2021	20	1,600	80
Hurricane Elsa	7/7/2021	1	329	329
Hurricane Elsa	7/7/2021	61	3,721	61
Hurricane Elsa	7/7/2021	6	876	146
Hurricane Elsa	7/7/2021	1	263	263
Hurricane Elsa	7/7/2021	18	3,078	171
Hurricane Elsa	7/7/2021	1	125	125
Hurricane Elsa	7/7/2021	1	278	278
Hurricane Elsa	7/7/2021	125	9,375	75
Hurricane Elsa	7/7/2021	3	228	76
Hurricane Elsa	7/7/2021	42	6,300	150
Hurricane Elsa	7/7/2021	1	236	236
Hurricane Elsa	7/7/2021	1	199	199
Hurricane Elsa	7/7/2021	1	94	94
Hurricane Elsa	7/7/2021	9	10,854	1,206
Hurricane Elsa	7/7/2021	1,393	44,843	85
Hurricane Elsa	7/7/2021	1	612	612

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	8	2,424	303
Hurricane Elsa	7/7/2021	1	256	256
Hurricane Elsa	7/7/2021	55	34,110	672
Hurricane Elsa	7/7/2021	3	342	114
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	1	1,240	1,240
Hurricane Elsa	7/7/2021	2	270	135
Hurricane Elsa	7/7/2021	2	434	217
Hurricane Elsa	7/7/2021	8	512	64
Hurricane Elsa	7/7/2021	7	378	54
Hurricane Elsa	7/7/2021	1	63	63
Hurricane Elsa	7/7/2021	12	612	51
Hurricane Elsa	7/7/2021	19	3,268	172
Hurricane Elsa	7/7/2021	1	337	337
Hurricane Elsa	7/7/2021	1	227	227
Hurricane Elsa	7/7/2021	24	264	11
Hurricane Elsa	7/7/2021	12	708	59
Hurricane Elsa	7/7/2021	1	140	140
Hurricane Elsa	7/7/2021	4	504	126
Hurricane Elsa	7/7/2021	5	555	111
Hurricane Elsa	7/7/2021	6	2,082	347
Hurricane Elsa	7/7/2021	1	80	80
Hurricane Elsa	7/7/2021	10	650	65
Hurricane Elsa	7/7/2021	68	3,536	52
Hurricane Elsa	7/7/2021	1	84	84
Hurricane Elsa	7/7/2021	3	153	51
Hurricane Elsa	7/7/2021	1	38	38
Hurricane Elsa	7/7/2021	1	275	275
Hurricane Elsa	7/7/2021	102	16,728	164
Hurricane Elsa	7/7/2021	1	184	184
Hurricane Elsa	7/7/2021	1	368	368
Hurricane Elsa	7/7/2021	4	1,712	428
Hurricane Elsa	7/7/2021	5	210	42
Hurricane Elsa	7/7/2021	15	855	57
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	21	1,491	71
Hurricane Elsa	7/7/2021	1	221	221
Hurricane Elsa	7/7/2021	1	100	100
Hurricane Elsa	7/7/2021	8	736	92
Hurricane Elsa	7/7/2021	16	720	45
Hurricane Elsa	7/7/2021	1	32	32
Hurricane Elsa	7/7/2021	6	864	144
Hurricane Elsa	7/7/2021	4	300	75

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	455	455
Hurricane Elsa	7/7/2021	5	225	45
Hurricane Elsa	7/7/2021	3	675	225
Hurricane Elsa	7/7/2021	1	174	174
Hurricane Elsa	7/7/2021	12	780	65
Hurricane Elsa	7/7/2021	3	234	78
Hurricane Elsa	7/7/2021	247	11,856	48
Hurricane Elsa	7/7/2021	189	15,309	81
Hurricane Elsa	7/7/2021	1	90	90
Hurricane Elsa	7/7/2021	6	876	146
Hurricane Elsa	7/7/2021	1	97	97
Hurricane Elsa	7/7/2021	1	336	336
Hurricane Elsa	7/7/2021	1	333	333
Hurricane Elsa	7/7/2021	1	421	421
Hurricane Elsa	7/7/2021	11	4,345	395
Hurricane Elsa	7/7/2021	8	3,432	429
Hurricane Elsa	7/7/2021	1	192	192
Hurricane Elsa	7/7/2021	11	1,518	138
Hurricane Elsa	7/7/2021	1	162	162
Hurricane Elsa	7/7/2021	1	237	237
Hurricane Elsa	7/7/2021	1	120	120
Hurricane Elsa	7/7/2021	1	171	171
Hurricane Elsa	7/7/2021	5	1,995	399
Hurricane Elsa	7/7/2021	21	8,841	421
Hurricane Elsa	7/7/2021	4	3,152	788
Hurricane Elsa	7/7/2021	1	148	148
Hurricane Elsa	7/7/2021	2	142	71
Hurricane Elsa	7/7/2021	1	316	316
Hurricane Elsa	7/7/2021	1	188	188
Hurricane Elsa	7/7/2021	29	16,084	1,881
Hurricane Elsa	7/7/2021	1	140	140
Hurricane Elsa	7/7/2021	1	192	192
Hurricane Elsa	7/7/2021	1	131	131
Hurricane Elsa	7/7/2021	14	4,396	314
Hurricane Elsa	7/7/2021	1	373	373
Hurricane Elsa	7/7/2021	1	74	74
Hurricane Elsa	7/7/2021	35	4,900	140
Hurricane Elsa	7/7/2021	1	994	994
Hurricane Elsa	7/7/2021	10	3,690	369
Hurricane Elsa	7/7/2021	14	336	24
Hurricane Elsa	7/7/2021	1	554	554
Hurricane Elsa	7/7/2021	5	5,635	1,127
Hurricane Elsa	7/7/2021	21	3,087	147

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/7/2021	1	79	79
Hurricane Elsa	7/7/2021	16	4,352	272
Hurricane Elsa	7/7/2021	10	1,180	118
Hurricane Elsa	7/7/2021	4	76	19
Hurricane Elsa	7/7/2021	43	14,620	340
Hurricane Elsa	7/7/2021	12	3,192	266
Hurricane Elsa	7/7/2021	1	2	2
Hurricane Elsa	7/7/2021	1	536	536
Hurricane Elsa	7/7/2021	1	102	102
Hurricane Elsa	7/7/2021	1	219	219
Hurricane Elsa	7/7/2021	1	118	118
Hurricane Elsa	7/7/2021	2	96	48
Hurricane Elsa	7/7/2021	1	238	238
Hurricane Elsa	7/7/2021	97	9,021	93
Hurricane Elsa	7/7/2021	3	354	118
Hurricane Elsa	7/7/2021	4	1,176	294
Hurricane Elsa	7/7/2021	3	2,667	1,341
Hurricane Elsa	7/7/2021	1	58	58
Hurricane Elsa	7/7/2021	4	188	47
Hurricane Elsa	7/7/2021	7	2,261	323
Hurricane Elsa	7/7/2021	1	59	59
Hurricane Elsa	7/7/2021	46	6,289	374
Hurricane Elsa	7/7/2021	3	168	56
Hurricane Elsa	7/7/2021	6	558	93
Hurricane Elsa	7/7/2021	14	8,484	606
Hurricane Elsa	7/8/2021	3	513	171
Hurricane Elsa	7/8/2021	3	738	246
Hurricane Elsa	7/8/2021	39	2,691	69
Hurricane Elsa	7/8/2021	18	7,182	399
Hurricane Elsa	7/8/2021	14	644	46
Hurricane Elsa	7/8/2021	1	67	67
Hurricane Elsa	7/8/2021	66	9,504	144
Hurricane Elsa	7/8/2021	10	990	99
Hurricane Elsa	7/8/2021	1	114	114
Hurricane Elsa	7/8/2021	3	1,326	442
Hurricane Elsa	7/8/2021	4	444	111
Hurricane Elsa	7/8/2021	1	53	53
Hurricane Elsa	7/8/2021	18	2,394	133
Hurricane Elsa	7/8/2021	1	638	638
Hurricane Elsa	7/8/2021	6	78	13
Hurricane Elsa	7/8/2021	2	92	46
Hurricane Elsa	7/8/2021	25	1,175	47
Hurricane Elsa	7/8/2021	1	141	141

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane Elsa	7/8/2021	1	107	107
Hurricane Elsa	7/8/2021	27	405	15
Hurricane Elsa	7/8/2021	2	368	184
Hurricane Elsa	7/8/2021	1	430	430
Hurricane Elsa	7/8/2021	79	8,352	224
Hurricane Elsa	7/8/2021	1	133	133
Hurricane Elsa	7/8/2021	1	492	492
Hurricane Elsa	7/8/2021	27	2,201	82
Hurricane Elsa	7/8/2021	1	36	36
Hurricane Elsa	7/8/2021	1	294	294
Hurricane Elsa	7/8/2021	1	425	425
Hurricane Elsa	7/8/2021	6	336	56
Hurricane Elsa	7/8/2021	30	2,130	71
Hurricane Elsa	7/8/2021	54	6,534	121
Hurricane Elsa	7/8/2021	1	48	48
Hurricane Elsa	7/8/2021	1	86	86
Hurricane Elsa	7/8/2021	2	178	89
Hurricane Elsa	7/8/2021	2	76	38
Hurricane Elsa	7/8/2021	1	180	180
Hurricane Elsa	7/8/2021	1	161	161
Hurricane Elsa	7/8/2021	1	114	114
Hurricane Elsa	7/8/2021	3	93	31
Hurricane Elsa	7/8/2021	110	9,130	83
Hurricane Elsa	7/8/2021	14	308	22
Hurricane Elsa	7/8/2021	1	145	145
Hurricane Elsa	7/8/2021	1	9	9
Hurricane Elsa	7/8/2021	2	160	80
Hurricane Elsa	7/8/2021	1	687	687
Hurricane Elsa	7/8/2021	62	5,022	81
Hurricane Elsa	7/8/2021	1	171	171
Hurricane Elsa	7/8/2021	62	3,534	57
Hurricane Elsa	7/8/2021	1	39	39
Hurricane Elsa	7/8/2021	1	134	134
Tornado	8/7/2021	8	552	69
Tornado	8/7/2021	1	31	31
Tornado	8/7/2021	3	360	120
Tornado	8/7/2021	51	3,876	76
Tornado	8/7/2021	2	36	18
Tornado	8/7/2021	1	44	44
Tornado	8/7/2021	2,397	4,794	2
Tornado	8/7/2021	1	109	109
Tornado	8/7/2021	2	196	98
Tornado	8/7/2021	19	2,318	122

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	8/7/2021	1	220	220
Tropical Storm	8/13/2021	6	1,476	246
Tropical Storm	8/13/2021	38	5,586	147
Tropical Storm	8/13/2021	20	2,880	144
Tropical Storm	8/13/2021	4	1,412	353
Tropical Storm	8/13/2021	1	139	139
Tropical Storm	8/13/2021	2	136	68
Tropical Storm	8/13/2021	1	515	515
Tropical Storm	8/13/2021	41	3,772	92
Tropical Storm	8/13/2021	4	908	227
Tropical Storm	8/13/2021	17	6,477	381
Tropical Storm	8/13/2021	1	815	815
Tropical Storm	8/13/2021	6	1,290	215
Tropical Storm	8/13/2021	12	1,700	149
Tropical Storm	8/13/2021	5	2,835	567
Tropical Storm	8/13/2021	1,097	3,291	3
Tropical Storm	8/13/2021	3	534	178
Tropical Storm	8/13/2021	31	5,146	166
Tropical Storm	8/13/2021	42	6,904	212
Tropical Storm	8/13/2021	10	6,480	648
Tropical Storm	8/13/2021	2	484	242
Tropical Storm	8/13/2021	8	1,040	130
Tropical Storm	8/13/2021	1	66	66
Tropical Storm	8/13/2021	1	262	262
Tropical Storm	8/13/2021	75	40,875	545
Tropical Storm	8/13/2021	10	3,010	301
Tropical Storm	8/13/2021	1	64	64
Tropical Storm	8/13/2021	4	2,140	535
Tropical Storm	8/13/2021	1	249	249
Tropical Storm	8/13/2021	15	3,450	230
Tropical Storm	8/13/2021	14	2,492	178
Tropical Storm	8/13/2021	3	3,000	1,000
Tropical Storm	8/13/2021	5	535	107
Tropical Storm	8/13/2021	1,623	44,599	87
Tropical Storm	8/13/2021	6	750	125
Tropical Storm	8/13/2021	1	25	25
Tropical Storm	8/13/2021	10	6,260	626
Tropical Storm	8/13/2021	38	2,774	73
Tropical Storm	8/13/2021	17	3,536	208
Tropical Storm	8/13/2021	1	521	521
Tropical Storm	8/13/2021	18	2,970	165
Tropical Storm	8/13/2021	16	8,624	539
Tropical Storm	8/13/2021	1	549	549

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	1	348	348
Tropical Storm	8/13/2021	2	194	97
Tropical Storm	8/13/2021	26	17,394	669
Tropical Storm	8/13/2021	5	895	179
Tropical Storm	8/13/2021	5	850	170
Tropical Storm	8/13/2021	37	3,367	91
Tropical Storm	8/13/2021	10	4,130	413
Tropical Storm	8/13/2021	4	832	208
Tropical Storm	8/13/2021	2	448	224
Tropical Storm	8/13/2021	6	3,426	571
Tropical Storm	8/13/2021	10	440	44
Tropical Storm	8/13/2021	26	21,918	843
Tropical Storm	8/13/2021	38	13,908	366
Tropical Storm	8/13/2021	89	16,101	523
Tropical Storm	8/13/2021	21	7,203	343
Tropical Storm	8/13/2021	1,562	214,619	582
Tropical Storm	8/13/2021	17	4,420	260
Tropical Storm	8/13/2021	27	26,487	981
Tropical Storm	8/13/2021	888	5,328	6
Tropical Storm	8/13/2021	22	5,414	248
Tropical Storm	8/13/2021	1,462	45,492	878
Tropical Storm	8/13/2021	24	5,616	234
Tropical Storm	8/13/2021	2	960	480
Tropical Storm	8/13/2021	1	341	341
Tropical Storm	8/13/2021	100	24,800	248
Tropical Storm	8/13/2021	2,145	98,670	46
Tropical Storm	8/13/2021	4	1,504	376
Tropical Storm	8/13/2021	13	6,370	490
Tropical Storm	8/13/2021	1	228	228
Tropical Storm	8/13/2021	5	370	74
Tropical Storm	8/13/2021	21	1,932	92
Tropical Storm	8/13/2021	541	1,623	3
Tropical Storm	8/13/2021	33	1,353	41
Tropical Storm	8/13/2021	3	1,701	567
Tropical Storm	8/13/2021	11	1,375	125
Tropical Storm	8/13/2021	16	5,613	433
Tropical Storm	8/13/2021	1	117	117
Tropical Storm	8/13/2021	1	46	46
Tropical Storm	8/13/2021	1	835	835
Tropical Storm	8/13/2021	3	888	296
Tropical Storm	8/13/2021	1	233	233
Tropical Storm	8/13/2021	18	1,908	106
Tropical Storm	8/13/2021	2	904	452

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	1	110	110
Tropical Storm	8/13/2021	53	33,765	769
Tropical Storm	8/13/2021	2	114	57
Tropical Storm	8/13/2021	1	67	67
Tropical Storm	8/13/2021	19	7,410	390
Tropical Storm	8/13/2021	1	201	201
Tropical Storm	8/13/2021	4	1,336	334
Tropical Storm	8/13/2021	12	1,428	119
Tropical Storm	8/13/2021	1	649	649
Tropical Storm	8/13/2021	5	430	86
Tropical Storm	8/13/2021	2	168	84
Tropical Storm	8/13/2021	11	5,016	456
Tropical Storm	8/13/2021	10	2,900	290
Tropical Storm	8/13/2021	2	90	45
Tropical Storm	8/13/2021	8	941	297
Tropical Storm	8/13/2021	12	2,832	236
Tropical Storm	8/13/2021	31	3,410	110
Tropical Storm	8/13/2021	7	399	57
Tropical Storm	8/13/2021	6	2,988	498
Tropical Storm	8/13/2021	1	185	185
Tropical Storm	8/13/2021	117	10,530	90
Tropical Storm	8/13/2021	1	513	513
Tropical Storm	8/13/2021	43	5,375	125
Tropical Storm	8/13/2021	2	266	133
Tropical Storm	8/13/2021	1	774	774
Tropical Storm	8/13/2021	4	196	49
Tropical Storm	8/13/2021	5	420	84
Tropical Storm	8/13/2021	1	242	242
Tropical Storm	8/13/2021	1	548	548
Tropical Storm	8/13/2021	9	1,062	118
Tropical Storm	8/13/2021	22	5,628	439
Tropical Storm	8/13/2021	1	417	417
Tropical Storm	8/13/2021	1	90	90
Tropical Storm	8/13/2021	1	77	77
Tropical Storm	8/13/2021	13	1,989	153
Tropical Storm	8/13/2021	8	2,264	283
Tropical Storm	8/13/2021	1	80	80
Tropical Storm	8/13/2021	1	608	608
Tropical Storm	8/13/2021	1	366	366
Tropical Storm	8/13/2021	1	149	149
Tropical Storm	8/13/2021	1	666	666
Tropical Storm	8/13/2021	109	47,746	439
Tropical Storm	8/13/2021	2	674	337

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	1	414	414
Tropical Storm	8/13/2021	24	4,152	173
Tropical Storm	8/13/2021	2	844	422
Tropical Storm	8/13/2021	5	2,205	441
Tropical Storm	8/13/2021	12	612	51
Tropical Storm	8/13/2021	1	470	470
Tropical Storm	8/13/2021	3	294	98
Tropical Storm	8/13/2021	1	364	364
Tropical Storm	8/13/2021	11	1,441	131
Tropical Storm	8/13/2021	45	4,050	90
Tropical Storm	8/13/2021	1	362	362
Tropical Storm	8/13/2021	6	1,320	220
Tropical Storm	8/13/2021	2	764	382
Tropical Storm	8/13/2021	19	9,766	514
Tropical Storm	8/13/2021	1	373	373
Tropical Storm	8/13/2021	4	832	208
Tropical Storm	8/13/2021	2	198	99
Tropical Storm	8/13/2021	1	221	221
Tropical Storm	8/13/2021	62	24,118	389
Tropical Storm	8/13/2021	1	352	352
Tropical Storm	8/13/2021	1	23	23
Tropical Storm	8/13/2021	1	474	474
Tropical Storm	8/13/2021	4	20	5
Tropical Storm	8/13/2021	6	666	111
Tropical Storm	8/13/2021	56	4,368	78
Tropical Storm	8/13/2021	1	290	290
Tropical Storm	8/13/2021	2	92	46
Tropical Storm	8/13/2021	1	633	633
Tropical Storm	8/13/2021	1	535	535
Tropical Storm	8/13/2021	1	570	570
Tropical Storm	8/13/2021	1	377	377
Tropical Storm	8/13/2021	3	303	101
Tropical Storm	8/13/2021	4	884	221
Tropical Storm	8/13/2021	7	1,764	252
Tropical Storm	8/13/2021	106	29,256	276
Tropical Storm	8/13/2021	1	264	264
Tropical Storm	8/13/2021	1	412	412
Tropical Storm	8/13/2021	7	2,352	336
Tropical Storm	8/13/2021	1	16	16
Tropical Storm	8/13/2021	6	18	3
Tropical Storm	8/13/2021	14	5,033	467
Tropical Storm	8/13/2021	8	449	143
Tropical Storm	8/13/2021	1	3	3

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	3	768	256
Tropical Storm	8/13/2021	1	465	465
Tropical Storm	8/13/2021	1	50	50
Tropical Storm	8/13/2021	8	488	61
Tropical Storm	8/13/2021	4	2,392	598
Tropical Storm	8/13/2021	13	1,066	82
Tropical Storm	8/13/2021	4	8	2
Tropical Storm	8/13/2021	9	2,457	273
Tropical Storm	8/13/2021	1	310	310
Tropical Storm	8/13/2021	4	96	24
Tropical Storm	8/13/2021	3	258	86
Tropical Storm	8/13/2021	1	277	277
Tropical Storm	8/13/2021	5	130	26
Tropical Storm	8/13/2021	28	3,444	123
Tropical Storm	8/13/2021	1	73	73
Tropical Storm	8/13/2021	5	780	156
Tropical Storm	8/13/2021	17	68	4
Tropical Storm	8/13/2021	1	54	54
Tropical Storm	8/13/2021	1	118	118
Tropical Storm	8/13/2021	2	568	284
Tropical Storm	8/13/2021	4	16	4
Tropical Storm	8/13/2021	1	332	332
Tropical Storm	8/13/2021	4	148	37
Tropical Storm	8/13/2021	1	5	5
Tropical Storm	8/13/2021	1	80	80
Tropical Storm	8/13/2021	7	1,582	226
Tropical Storm	8/13/2021	8	48	6
Tropical Storm	8/13/2021	1	344	344
Tropical Storm	8/13/2021	10	2,055	357
Tropical Storm	8/13/2021	1	562	562
Tropical Storm	8/13/2021	2	6	3
Tropical Storm	8/13/2021	138	12,972	94
Tropical Storm	8/13/2021	33	5,544	168
Tropical Storm	8/13/2021	10	390	39
Tropical Storm	8/13/2021	12	3,888	324
Tropical Storm	8/13/2021	4	32	8
Tropical Storm	8/13/2021	2	901	530
Tropical Storm	8/13/2021	1	10	10
Tropical Storm	8/13/2021	2	10	5
Tropical Storm	8/13/2021	4	1,288	322
Tropical Storm	8/13/2021	1	86	86
Tropical Storm	8/13/2021	3	21	7
Tropical Storm	8/13/2021	4	856	214

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	10	2,710	271
Tropical Storm	8/13/2021	1	377	377
Tropical Storm	8/13/2021	1	24	24
Tropical Storm	8/13/2021	16	4,352	272
Tropical Storm	8/13/2021	6	3,342	557
Tropical Storm	8/13/2021	2	70	35
Tropical Storm	8/13/2021	1	166	166
Tropical Storm	8/13/2021	3	21	7
Tropical Storm	8/13/2021	2	224	112
Tropical Storm	8/13/2021	44	176	4
Tropical Storm	8/13/2021	3	30	10
Tropical Storm	8/13/2021	3	129	43
Tropical Storm	8/13/2021	10	140	14
Tropical Storm	8/13/2021	3	279	93
Tropical Storm	8/13/2021	1	334	334
Tropical Storm	8/13/2021	4	32	8
Tropical Storm	8/13/2021	4	108	27
Tropical Storm	8/13/2021	1	120	120
Tropical Storm	8/13/2021	1	460	460
Tropical Storm	8/13/2021	2	6	3
Tropical Storm	8/13/2021	2	1,148	574
Tropical Storm	8/13/2021	31	2,945	95
Tropical Storm	8/13/2021	1	422	422
Tropical Storm	8/13/2021	2	404	202
Tropical Storm	8/13/2021	1	630	630
Tropical Storm	8/13/2021	1	55	55
Tropical Storm	8/13/2021	10	3,740	374
Tropical Storm	8/13/2021	5	1,085	217
Tropical Storm	8/13/2021	1	81	81
Tropical Storm	8/13/2021	1	7	7
Tropical Storm	8/13/2021	8	208	26
Tropical Storm	8/13/2021	11	759	69
Tropical Storm	8/13/2021	1	9	9
Tropical Storm	8/13/2021	8	56	7
Tropical Storm	8/13/2021	7	378	54
Tropical Storm	8/13/2021	1	112	112
Tropical Storm	8/13/2021	3	18	6
Tropical Storm	8/13/2021	1	245	245
Tropical Storm	8/13/2021	1	125	125
Tropical Storm	8/13/2021	1	289	289
Tropical Storm	8/13/2021	2	82	41
Tropical Storm	8/13/2021	3	30	10
Tropical Storm	8/13/2021	3	564	188

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	3	57	19
Tropical Storm	8/13/2021	2	14	7
Tropical Storm	8/13/2021	1	447	447
Tropical Storm	8/13/2021	4	1,056	264
Tropical Storm	8/13/2021	8	104	13
Tropical Storm	8/13/2021	10	70	7
Tropical Storm	8/13/2021	1	261	261
Tropical Storm	8/13/2021	3	141	47
Tropical Storm	8/13/2021	4	436	109
Tropical Storm	8/13/2021	1	534	534
Tropical Storm	8/13/2021	2	26	13
Tropical Storm	8/13/2021	3	201	67
Tropical Storm	8/13/2021	1	255	255
Tropical Storm	8/13/2021	1	68	68
Tropical Storm	8/13/2021	4	108	27
Tropical Storm	8/13/2021	1	293	293
Tropical Storm	8/13/2021	4	40	10
Tropical Storm	8/13/2021	1	466	466
Tropical Storm	8/13/2021	3	1,353	451
Tropical Storm	8/13/2021	3	51	17
Tropical Storm	8/13/2021	2	464	232
Tropical Storm	8/13/2021	2	486	243
Tropical Storm	8/13/2021	10	80	8
Tropical Storm	8/13/2021	5	400	80
Tropical Storm	8/13/2021	8	224	28
Tropical Storm	8/13/2021	2	380	190
Tropical Storm	8/13/2021	3	600	200
Tropical Storm	8/13/2021	12	5,832	486
Tropical Storm	8/13/2021	1	231	231
Tropical Storm	8/13/2021	5	880	176
Tropical Storm	8/13/2021	1	354	354
Tropical Storm	8/13/2021	8	2,960	370
Tropical Storm	8/13/2021	3	18	6
Tropical Storm	8/13/2021	2	50	25
Tropical Storm	8/13/2021	3	45	15
Tropical Storm	8/13/2021	12	1,188	99
Tropical Storm	8/13/2021	1	406	406
Tropical Storm	8/13/2021	12	96	8
Tropical Storm	8/13/2021	4	172	43
Tropical Storm	8/13/2021	1	34	34
Tropical Storm	8/13/2021	1	263	263
Tropical Storm	8/13/2021	1	57	57
Tropical Storm	8/13/2021	10	290	29

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	11	3,174	407
Tropical Storm	8/13/2021	1	422	422
Tropical Storm	8/13/2021	1	155	155
Tropical Storm	8/13/2021	1	266	266
Tropical Storm	8/13/2021	6	36	6
Tropical Storm	8/13/2021	7	119	17
Tropical Storm	8/13/2021	1	247	247
Tropical Storm	8/13/2021	4	376	94
Tropical Storm	8/13/2021	5	160	32
Tropical Storm	8/13/2021	1	259	259
Tropical Storm	8/13/2021	5	35	7
Tropical Storm	8/13/2021	3	150	50
Tropical Storm	8/13/2021	12	696	58
Tropical Storm	8/13/2021	64	6,272	157
Tropical Storm	8/13/2021	6	1,500	250
Tropical Storm	8/13/2021	10	60	6
Tropical Storm	8/13/2021	30	3,510	117
Tropical Storm	8/13/2021	1	291	291
Tropical Storm	8/13/2021	4	120	30
Tropical Storm	8/13/2021	1	423	423
Tropical Storm	8/13/2021	14	1,260	90
Tropical Storm	8/13/2021	57	5,643	99
Tropical Storm	8/13/2021	7	959	137
Tropical Storm	8/13/2021	172	22,188	129
Tropical Storm	8/13/2021	5	45	9
Tropical Storm	8/13/2021	1	265	265
Tropical Storm	8/13/2021	2	848	424
Tropical Storm	8/13/2021	1	356	356
Tropical Storm	8/13/2021	1	575	575
Tropical Storm	8/13/2021	2	128	64
Tropical Storm	8/13/2021	6	3,198	533
Tropical Storm	8/13/2021	3	63	21
Tropical Storm	8/13/2021	1	232	232
Tropical Storm	8/13/2021	642	21,186	33
Tropical Storm	8/13/2021	10	2,830	283
Tropical Storm	8/13/2021	5	505	101
Tropical Storm	8/13/2021	4	900	225
Tropical Storm	8/13/2021	1	48	48
Tropical Storm	8/13/2021	1	310	310
Tropical Storm	8/13/2021	34	2,652	78
Tropical Storm	8/13/2021	4	116	29
Tropical Storm	8/13/2021	1	212	212
Tropical Storm	8/13/2021	35	3,920	112

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	24	2,112	88
Tropical Storm	8/13/2021	12	1,572	131
Tropical Storm	8/13/2021	1	93	93
Tropical Storm	8/13/2021	1	36	36
Tropical Storm	8/13/2021	3	558	186
Tropical Storm	8/13/2021	11	1,353	123
Tropical Storm	8/13/2021	12	708	59
Tropical Storm	8/13/2021	9	1,629	181
Tropical Storm	8/13/2021	1	102	102
Tropical Storm	8/13/2021	41	2,911	71
Tropical Storm	8/13/2021	1	313	313
Tropical Storm	8/13/2021	3	903	301
Tropical Storm	8/13/2021	1	392	392
Tropical Storm	8/13/2021	1	206	206
Tropical Storm	8/13/2021	11	154	14
Tropical Storm	8/13/2021	5	140	28
Tropical Storm	8/13/2021	8	296	37
Tropical Storm	8/13/2021	1	188	229
Tropical Storm	8/13/2021	1	288	288
Tropical Storm	8/13/2021	1	164	164
Tropical Storm	8/13/2021	11	913	83
Tropical Storm	8/13/2021	3	9	3
Tropical Storm	8/13/2021	8	264	33
Tropical Storm	8/13/2021	10	1,080	108
Tropical Storm	8/13/2021	1	435	435
Tropical Storm	8/13/2021	1	4	4
Tropical Storm	8/13/2021	1	269	269
Tropical Storm	8/13/2021	3	132	44
Tropical Storm	8/13/2021	8	760	95
Tropical Storm	8/13/2021	84	2,492	345
Tropical Storm	8/13/2021	4	3,176	794
Tropical Storm	8/13/2021	14	518	37
Tropical Storm	8/13/2021	1	227	227
Tropical Storm	8/13/2021	1	278	278
Tropical Storm	8/13/2021	16	928	58
Tropical Storm	8/13/2021	3	72	24
Tropical Storm	8/13/2021	1	51	51
Tropical Storm	8/13/2021	1	105	105
Tropical Storm	8/13/2021	1	281	281
Tropical Storm	8/13/2021	1	191	191
Tropical Storm	8/13/2021	8	656	82
Tropical Storm	8/13/2021	69	1,587	23
Tropical Storm	8/13/2021	1	108	108

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	1	147	147
Tropical Storm	8/13/2021	4	688	172
Tropical Storm	8/13/2021	5	295	59
Tropical Storm	8/13/2021	12	1,044	87
Tropical Storm	8/13/2021	1	224	224
Tropical Storm	8/13/2021	6	840	140
Tropical Storm	8/13/2021	4	32	8
Tropical Storm	8/13/2021	2	48	24
Tropical Storm	8/13/2021	64	3,123	65
Tropical Storm	8/13/2021	3	5,001	1,667
Tropical Storm	8/13/2021	1	325	325
Tropical Storm	8/13/2021	1	348	348
Tropical Storm	8/13/2021	1	255	255
Tropical Storm	8/13/2021	17	4,471	263
Tropical Storm	8/13/2021	2	24	12
Tropical Storm	8/13/2021	1	27	27
Tropical Storm	8/13/2021	113	11,413	101
Tropical Storm	8/13/2021	4	112	28
Tropical Storm	8/13/2021	1	114	114
Tropical Storm	8/13/2021	1	200	200
Tropical Storm	8/13/2021	36	3,096	86
Tropical Storm	8/13/2021	21	6,489	309
Tropical Storm	8/13/2021	1	82	82
Tropical Storm	8/13/2021	6	96	16
Tropical Storm	8/13/2021	9	1,332	148
Tropical Storm	8/13/2021	6	522	87
Tropical Storm	8/13/2021	2	318	159
Tropical Storm	8/13/2021	219	41,969	465
Tropical Storm	8/13/2021	1	134	134
Tropical Storm	8/13/2021	70	15,610	223
Tropical Storm	8/13/2021	6	1,416	236
Tropical Storm	8/13/2021	89	12,282	138
Tropical Storm	8/13/2021	1	215	215
Tropical Storm	8/13/2021	1	265	265
Tropical Storm	8/13/2021	4	248	62
Tropical Storm	8/13/2021	5	2,440	488
Tropical Storm	8/13/2021	8	2,474	505
Tropical Storm	8/13/2021	105	39,228	796
Tropical Storm	8/13/2021	2	184	92
Tropical Storm	8/13/2021	83	9,462	114
Tropical Storm	8/13/2021	11	2,257	302
Tropical Storm	8/13/2021	1	295	295
Tropical Storm	8/13/2021	170	15,300	90

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	2,077	4,154	2
Tropical Storm	8/13/2021	6	1,098	183
Tropical Storm	8/13/2021	10	3,360	336
Tropical Storm	8/13/2021	7	1,526	218
Tropical Storm	8/13/2021	2	384	192
Tropical Storm	8/13/2021	7	1,701	243
Tropical Storm	8/13/2021	15	6,630	442
Tropical Storm	8/13/2021	2	396	198
Tropical Storm	8/13/2021	1	234	234
Tropical Storm	8/13/2021	1	148	148
Tropical Storm	8/13/2021	1	76	76
Tropical Storm	8/13/2021	14	952	68
Tropical Storm	8/13/2021	91	14,241	165
Tropical Storm	8/13/2021	1	621	621
Tropical Storm	8/13/2021	9	36	4
Tropical Storm	8/13/2021	1	246	246
Tropical Storm	8/13/2021	1	386	386
Tropical Storm	8/13/2021	63	5,796	92
Tropical Storm	8/13/2021	2	342	171
Tropical Storm	8/13/2021	99	8,415	85
Tropical Storm	8/13/2021	6	2,058	343
Tropical Storm	8/13/2021	2	350	175
Tropical Storm	8/13/2021	3	297	99
Tropical Storm	8/13/2021	1	151	151
Tropical Storm	8/13/2021	9	1,071	119
Tropical Storm	8/13/2021	113	11,074	98
Tropical Storm	8/13/2021	5	380	76
Tropical Storm	8/13/2021	1	150	150
Tropical Storm	8/13/2021	2,127	77,493	83
Tropical Storm	8/13/2021	68	1,532	67
Tropical Storm	8/13/2021	1	145	145
Tropical Storm	8/13/2021	4	1,056	264
Tropical Storm	8/13/2021	1	262	262
Tropical Storm	8/13/2021	1,965	3,930	2
Tropical Storm	8/13/2021	3	438	146
Tropical Storm	8/13/2021	55	8,305	151
Tropical Storm	8/13/2021	1	178	178
Tropical Storm	8/13/2021	8	1,120	140
Tropical Storm	8/13/2021	1	100	100
Tropical Storm	8/13/2021	1	133	133
Tropical Storm	8/13/2021	3	297	99
Tropical Storm	8/13/2021	1	88	88
Tropical Storm	8/13/2021	3	273	91

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	3	507	169
Tropical Storm	8/13/2021	32	4,736	148
Tropical Storm	8/13/2021	3	618	206
Tropical Storm	8/13/2021	3	570	190
Tropical Storm	8/13/2021	1	284	284
Tropical Storm	8/13/2021	49	8,668	302
Tropical Storm	8/13/2021	3	132	44
Tropical Storm	8/13/2021	8	3,064	383
Tropical Storm	8/13/2021	3	525	175
Tropical Storm	8/13/2021	5	455	91
Tropical Storm	8/13/2021	13	338	26
Tropical Storm	8/13/2021	10	2,600	260
Tropical Storm	8/13/2021	1	210	210
Tropical Storm	8/13/2021	1	140	140
Tropical Storm	8/13/2021	1	116	116
Tropical Storm	8/13/2021	4	500	125
Tropical Storm	8/13/2021	1	201	201
Tropical Storm	8/13/2021	1	116	116
Tropical Storm	8/13/2021	8	288	36
Tropical Storm	8/13/2021	2	76	38
Tropical Storm	8/13/2021	3	27	9
Tropical Storm	8/13/2021	1	115	115
Tropical Storm	8/13/2021	6	2,046	341
Tropical Storm	8/13/2021	23	2,622	114
Tropical Storm	8/13/2021	43	2,279	53
Tropical Storm	8/13/2021	1	115	115
Tropical Storm	8/13/2021	1	158	158
Tropical Storm	8/13/2021	12	2,988	249
Tropical Storm	8/13/2021	17	4,606	338
Tropical Storm	8/13/2021	2	314	157
Tropical Storm	8/13/2021	2	916	458
Tropical Storm	8/13/2021	21	7,825	533
Tropical Storm	8/13/2021	15	945	63
Tropical Storm	8/13/2021	1	84	84
Tropical Storm	8/13/2021	16	3,248	203
Tropical Storm	8/13/2021	4	188	47
Tropical Storm	8/13/2021	5	860	172
Tropical Storm	8/13/2021	1	257	257
Tropical Storm	8/13/2021	1	60	60
Tropical Storm	8/13/2021	1	30	30
Tropical Storm	8/13/2021	12	2,040	170
Tropical Storm	8/13/2021	1	252	252
Tropical Storm	8/13/2021	1	129	129

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	2	94	47
Tropical Storm	8/13/2021	54	7,992	148
Tropical Storm	8/13/2021	9	3,681	409
Tropical Storm	8/13/2021	65	6,110	94
Tropical Storm	8/13/2021	1	177	177
Tropical Storm	8/13/2021	1	55	55
Tropical Storm	8/13/2021	20	6,580	329
Tropical Storm	8/13/2021	28	2,212	79
Tropical Storm	8/13/2021	14	2,030	145
Tropical Storm	8/13/2021	4	452	113
Tropical Storm	8/13/2021	9	603	67
Tropical Storm	8/13/2021	12	2,256	188
Tropical Storm	8/13/2021	4	592	148
Tropical Storm	8/13/2021	50	9,150	183
Tropical Storm	8/13/2021	1	294	294
Tropical Storm	8/13/2021	2	176	88
Tropical Storm	8/13/2021	1	248	248
Tropical Storm	8/13/2021	1	278	278
Tropical Storm	8/13/2021	56	168	3
Tropical Storm	8/13/2021	1	337	337
Tropical Storm	8/13/2021	19	1,330	70
Tropical Storm	8/13/2021	1	752	752
Tropical Storm	8/13/2021	10	320	32
Tropical Storm	8/13/2021	4	112	28
Tropical Storm	8/13/2021	1	47	47
Tropical Storm	8/13/2021	1	144	144
Tropical Storm	8/13/2021	6	804	134
Tropical Storm	8/13/2021	12	5,088	424
Tropical Storm	8/13/2021	42	6,846	173
Tropical Storm	8/13/2021	4	740	185
Tropical Storm	8/13/2021	1	1,033	1,033
Tropical Storm	8/13/2021	12	2,004	167
Tropical Storm	8/13/2021	17	595	35
Tropical Storm	8/13/2021	5	1,115	223
Tropical Storm	8/13/2021	2	76	38
Tropical Storm	8/13/2021	1	247	247
Tropical Storm	8/13/2021	1	349	349
Tropical Storm	8/13/2021	2	36	18
Tropical Storm	8/13/2021	1	166	166
Tropical Storm	8/13/2021	1	369	369
Tropical Storm	8/13/2021	2	64	32
Tropical Storm	8/13/2021	1	388	388
Tropical Storm	8/13/2021	1	495	495

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	33	8,250	250
Tropical Storm	8/13/2021	4	1,940	485
Tropical Storm	8/13/2021	2	434	217
Tropical Storm	8/13/2021	26	3,570	358
Tropical Storm	8/13/2021	7	1,498	214
Tropical Storm	8/13/2021	33	4,785	145
Tropical Storm	8/13/2021	12	2,436	203
Tropical Storm	8/13/2021	14	1,050	75
Tropical Storm	8/13/2021	1	49	49
Tropical Storm	8/13/2021	6	4,908	818
Tropical Storm	8/13/2021	1	69	69
Tropical Storm	8/13/2021	9	3,960	440
Tropical Storm	8/13/2021	1	96	96
Tropical Storm	8/13/2021	1	80	80
Tropical Storm	8/13/2021	8	3,168	396
Tropical Storm	8/13/2021	34	4,964	146
Tropical Storm	8/13/2021	15	13,485	899
Tropical Storm	8/13/2021	4	1,944	486
Tropical Storm	8/13/2021	43	5,670	135
Tropical Storm	8/13/2021	1	72	72
Tropical Storm	8/13/2021	29	4,582	158
Tropical Storm	8/13/2021	22	5,038	229
Tropical Storm	8/13/2021	12	12,192	1,016
Tropical Storm	8/13/2021	8	784	98
Tropical Storm	8/13/2021	3	189	63
Tropical Storm	8/13/2021	22	2,841	681
Tropical Storm	8/13/2021	1	267	267
Tropical Storm	8/13/2021	6	270	45
Tropical Storm	8/13/2021	7	952	136
Tropical Storm	8/13/2021	2	402	201
Tropical Storm	8/13/2021	1	274	274
Tropical Storm	8/13/2021	5	25	5
Tropical Storm	8/13/2021	38	418	11
Tropical Storm	8/13/2021	1	43	43
Tropical Storm	8/13/2021	5	1,305	261
Tropical Storm	8/13/2021	1	56	56
Tropical Storm	8/13/2021	1	195	195
Tropical Storm	8/13/2021	9	948	140
Tropical Storm	8/13/2021	90	6,390	71
Tropical Storm	8/13/2021	5	1,125	225
Tropical Storm	8/13/2021	11	7,172	652
Tropical Storm	8/13/2021	33	10,854	534
Tropical Storm	8/13/2021	3	543	181

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	59	25,301	709
Tropical Storm	8/13/2021	99	11,781	135
Tropical Storm	8/13/2021	40	8,272	466
Tropical Storm	8/13/2021	1	537	537
Tropical Storm	8/13/2021	1	27	27
Tropical Storm	8/13/2021	27	5,858	414
Tropical Storm	8/13/2021	18	3,294	183
Tropical Storm	8/13/2021	1	16	16
Tropical Storm	8/13/2021	8	104	13
Tropical Storm	8/13/2021	25	17,000	680
Tropical Storm	8/13/2021	1	252	252
Tropical Storm	8/13/2021	4	1,536	384
Tropical Storm	8/13/2021	1	258	258
Tropical Storm	8/13/2021	8	976	122
Tropical Storm	8/13/2021	15	1,559	699
Tropical Storm	8/13/2021	419	1,257	3
Tropical Storm	8/13/2021	4	1,268	317
Tropical Storm	8/13/2021	4	2,024	506
Tropical Storm	8/13/2021	3	1,482	494
Tropical Storm	8/13/2021	8	488	61
Tropical Storm	8/13/2021	33	10,230	310
Tropical Storm	8/13/2021	11	1,353	123
Tropical Storm	8/13/2021	2	718	359
Tropical Storm	8/13/2021	3	1,251	417
Tropical Storm	8/13/2021	3	222	74
Tropical Storm	8/13/2021	1	286	286
Tropical Storm	8/13/2021	23	6,291	613
Tropical Storm	8/13/2021	3	1,782	594
Tropical Storm	8/13/2021	3	645	215
Tropical Storm	8/13/2021	3	435	145
Tropical Storm	8/13/2021	4	3,756	939
Tropical Storm	8/13/2021	1	271	271
Tropical Storm	8/13/2021	9	2,790	310
Tropical Storm	8/13/2021	28	10,016	575
Tropical Storm	8/13/2021	1	608	608
Tropical Storm	8/13/2021	31	9,858	318
Tropical Storm	8/13/2021	8	2,584	323
Tropical Storm	8/13/2021	18	1,476	82
Tropical Storm	8/13/2021	6	4,776	796
Tropical Storm	8/13/2021	6	2,364	394
Tropical Storm	8/13/2021	45	450	10
Tropical Storm	8/13/2021	17	6,694	872
Tropical Storm	8/13/2021	40	3,960	99

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	133	17,314	374
Tropical Storm	8/13/2021	1	293	293
Tropical Storm	8/13/2021	2	68	34
Tropical Storm	8/13/2021	113	4,746	42
Tropical Storm	8/13/2021	41	16,099	449
Tropical Storm	8/13/2021	3	231	77
Tropical Storm	8/13/2021	3	2,535	845
Tropical Storm	8/13/2021	4	1,904	476
Tropical Storm	8/13/2021	2	340	170
Tropical Storm	8/13/2021	11	3,003	273
Tropical Storm	8/13/2021	1	753	753
Tropical Storm	8/13/2021	20	5,591	289
Tropical Storm	8/13/2021	13	2,288	176
Tropical Storm	8/13/2021	3	147	49
Tropical Storm	8/13/2021	18	2,952	164
Tropical Storm	8/13/2021	1	382	382
Tropical Storm	8/13/2021	1	650	650
Tropical Storm	8/13/2021	1	197	197
Tropical Storm	8/13/2021	37	1,961	53
Tropical Storm	8/13/2021	1	19	19
Tropical Storm	8/13/2021	4	1,216	304
Tropical Storm	8/13/2021	1	484	484
Tropical Storm	8/13/2021	1	153	153
Tropical Storm	8/13/2021	5	2,145	429
Tropical Storm	8/13/2021	8	3,443	826
Tropical Storm	8/13/2021	5	255	51
Tropical Storm	8/13/2021	23	1,610	70
Tropical Storm	8/13/2021	11	7,975	725
Tropical Storm	8/13/2021	2	502	251
Tropical Storm	8/13/2021	3	486	162
Tropical Storm	8/13/2021	4	192	48
Tropical Storm	8/13/2021	4	1,224	306
Tropical Storm	8/13/2021	1	214	214
Tropical Storm	8/13/2021	2	78	39
Tropical Storm	8/13/2021	7	189	27
Tropical Storm	8/13/2021	5	1,510	302
Tropical Storm	8/13/2021	1	597	597
Tropical Storm	8/13/2021	7	1,512	216
Tropical Storm	8/13/2021	52	7,920	400
Tropical Storm	8/13/2021	24	10,236	758
Tropical Storm	8/13/2021	5	220	44
Tropical Storm	8/13/2021	1	183	183
Tropical Storm	8/13/2021	5	2,150	430

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/13/2021	1	333	333
Tropical Storm	8/14/2021	1	638	638
Tropical Storm	8/14/2021	67	4,690	70
Tropical Storm	8/14/2021	4	728	182
Tropical Storm	8/14/2021	5	1,415	283
Tropical Storm	8/14/2021	3	2,178	726
Tropical Storm	8/14/2021	116	13,804	119
Tropical Storm	8/14/2021	3	1,293	431
Tropical Storm	8/14/2021	1	113	113
Tropical Storm	8/14/2021	3	138	46
Tropical Storm	8/14/2021	24	6,264	261
Tropical Storm	8/14/2021	13	1,625	125
Tropical Storm	8/14/2021	20	1,200	60
Tropical Storm	8/14/2021	1	147	147
Tropical Storm	8/14/2021	3	81	27
Tropical Storm	8/14/2021	18	1,638	91
Tropical Storm	8/14/2021	1	221	221
Tropical Storm	8/14/2021	6	1,164	194
Tropical Storm	8/14/2021	2	1,376	688
Tropical Storm	8/14/2021	3	502	342
Tropical Storm	8/14/2021	1	185	185
Tropical Storm	8/14/2021	1	347	347
Tropical Storm	8/14/2021	1	323	323
Tropical Storm	8/14/2021	8	1,664	208
Tropical Storm	8/14/2021	5	780	156
Tropical Storm	8/14/2021	1	120	120
Tropical Storm	8/14/2021	20	960	48
Tropical Storm	8/14/2021	4	268	67
Tropical Storm	8/14/2021	9	3,555	395
Tropical Storm	8/14/2021	10	3,650	365
Tropical Storm	8/14/2021	24	20,223	883
Tropical Storm	8/14/2021	22	1,518	69
Tropical Storm	8/14/2021	1	55	55
Tropical Storm	8/14/2021	1	357	357
Tropical Storm	8/14/2021	2	1,066	533
Tropical Storm	8/14/2021	2	160	80
Tropical Storm	8/14/2021	3	300	100
Tropical Storm	8/14/2021	8	504	63
Tropical Storm	8/14/2021	4	284	71
Tropical Storm	8/14/2021	1	58	58
Tropical Storm	8/14/2021	1	274	274
Tropical Storm	8/14/2021	1	323	323
Tropical Storm	8/14/2021	737	1,474	2

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	5	185	37
Tropical Storm	8/14/2021	6	558	93
Tropical Storm	8/14/2021	19	6,935	365
Tropical Storm	8/14/2021	473	2,838	6
Tropical Storm	8/14/2021	16	576	36
Tropical Storm	8/14/2021	6	2,700	450
Tropical Storm	8/14/2021	6	564	94
Tropical Storm	8/14/2021	7	3,171	453
Tropical Storm	8/14/2021	660	29,700	45
Tropical Storm	8/14/2021	4	288	72
Tropical Storm	8/14/2021	1	169	169
Tropical Storm	8/14/2021	1	106	106
Tropical Storm	8/14/2021	2	64	32
Tropical Storm	8/14/2021	3	180	60
Tropical Storm	8/14/2021	1	160	160
Tropical Storm	8/14/2021	37	4,753	301
Tropical Storm	8/14/2021	39	5,850	150
Tropical Storm	8/14/2021	1	227	227
Tropical Storm	8/14/2021	94	9,682	103
Tropical Storm	8/14/2021	2	140	70
Tropical Storm	8/14/2021	3	423	141
Tropical Storm	8/14/2021	4	340	85
Tropical Storm	8/14/2021	4	124	31
Tropical Storm	8/14/2021	8	1,352	169
Tropical Storm	8/14/2021	1	351	351
Tropical Storm	8/14/2021	12	852	71
Tropical Storm	8/14/2021	48	4,368	91
Tropical Storm	8/14/2021	3	495	165
Tropical Storm	8/14/2021	7	791	113
Tropical Storm	8/14/2021	1	87	87
Tropical Storm	8/14/2021	2	446	223
Tropical Storm	8/14/2021	1	222	222
Tropical Storm	8/14/2021	1	57	57
Tropical Storm	8/14/2021	3	375	125
Tropical Storm	8/14/2021	5	630	126
Tropical Storm	8/14/2021	1	95	95
Tropical Storm	8/14/2021	3	159	53
Tropical Storm	8/14/2021	4	1,192	442
Tropical Storm	8/14/2021	8	2,144	268
Tropical Storm	8/14/2021	1	37	37
Tropical Storm	8/14/2021	1	494	494
Tropical Storm	8/14/2021	3	129	43
Tropical Storm	8/14/2021	1	387	387

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	4	740	185
Tropical Storm	8/14/2021	1	111	111
Tropical Storm	8/14/2021	1	44	44
Tropical Storm	8/14/2021	16	624	39
Tropical Storm	8/14/2021	1	239	239
Tropical Storm	8/14/2021	1	94	94
Tropical Storm	8/14/2021	1	69	69
Tropical Storm	8/14/2021	4	828	207
Tropical Storm	8/14/2021	4	144	36
Tropical Storm	8/14/2021	1	224	224
Tropical Storm	8/14/2021	1	56	56
Tropical Storm	8/14/2021	10	2,380	238
Tropical Storm	8/14/2021	2	214	107
Tropical Storm	8/14/2021	5	375	75
Tropical Storm	8/14/2021	1	219	219
Tropical Storm	8/14/2021	2	102	51
Tropical Storm	8/14/2021	85	7,565	89
Tropical Storm	8/14/2021	1	467	467
Tropical Storm	8/14/2021	1	147	147
Tropical Storm	8/14/2021	1	229	229
Tropical Storm	8/14/2021	5	830	166
Tropical Storm	8/14/2021	2	522	261
Tropical Storm	8/14/2021	1	159	159
Tropical Storm	8/14/2021	3	12	4
Tropical Storm	8/14/2021	2	436	218
Tropical Storm	8/14/2021	1	303	303
Tropical Storm	8/14/2021	1,691	20,225	205
Tropical Storm	8/14/2021	863	47,907	249
Tropical Storm	8/14/2021	4	272	68
Tropical Storm	8/14/2021	1	138	138
Tropical Storm	8/14/2021	40	17,840	446
Tropical Storm	8/14/2021	1	147	147
Tropical Storm	8/14/2021	1	124	124
Tropical Storm	8/14/2021	1	34	34
Tropical Storm	8/14/2021	5	345	69
Tropical Storm	8/14/2021	4	324	81
Tropical Storm	8/14/2021	1	68	68
Tropical Storm	8/14/2021	5	565	113
Tropical Storm	8/14/2021	1	145	145
Tropical Storm	8/14/2021	5	1,325	265
Tropical Storm	8/14/2021	8	1,488	186
Tropical Storm	8/14/2021	1	151	151
Tropical Storm	8/14/2021	1	405	405

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	3	246	82
Tropical Storm	8/14/2021	14	4,186	299
Tropical Storm	8/14/2021	5	1,095	219
Tropical Storm	8/14/2021	70	4,550	65
Tropical Storm	8/14/2021	25	1,475	59
Tropical Storm	8/14/2021	1	80	80
Tropical Storm	8/14/2021	1	110	110
Tropical Storm	8/14/2021	1	523	523
Tropical Storm	8/14/2021	5	845	169
Tropical Storm	8/14/2021	2	158	79
Tropical Storm	8/14/2021	1	211	211
Tropical Storm	8/14/2021	1	166	166
Tropical Storm	8/14/2021	1	286	286
Tropical Storm	8/14/2021	1	270	270
Tropical Storm	8/14/2021	10	640	64
Tropical Storm	8/14/2021	19	2,090	110
Tropical Storm	8/14/2021	1	60	60
Tropical Storm	8/14/2021	4	448	112
Tropical Storm	8/14/2021	1	59	59
Tropical Storm	8/14/2021	3	696	232
Tropical Storm	8/14/2021	1	207	207
Tropical Storm	8/14/2021	8	1,904	238
Tropical Storm	8/14/2021	8	3,248	406
Tropical Storm	8/14/2021	7	553	79
Tropical Storm	8/14/2021	1	183	183
Tropical Storm	8/14/2021	6	4,374	729
Tropical Storm	8/14/2021	1	21	21
Tropical Storm	8/14/2021	14	560	40
Tropical Storm	8/14/2021	49	3,528	72
Tropical Storm	8/14/2021	2	230	115
Tropical Storm	8/14/2021	2	102	51
Tropical Storm	8/14/2021	11	858	78
Tropical Storm	8/14/2021	1	223	223
Tropical Storm	8/14/2021	2	344	172
Tropical Storm	8/14/2021	1	116	116
Tropical Storm	8/14/2021	8	1,976	247
Tropical Storm	8/14/2021	1	67	67
Tropical Storm	8/14/2021	1	369	369
Tropical Storm	8/14/2021	3	201	67
Tropical Storm	8/14/2021	2	294	147
Tropical Storm	8/14/2021	1	334	334
Tropical Storm	8/14/2021	1	203	203
Tropical Storm	8/14/2021	4	348	87

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	1	59	59
Tropical Storm	8/14/2021	4	172	43
Tropical Storm	8/14/2021	4	560	140
Tropical Storm	8/14/2021	1	191	191
Tropical Storm	8/14/2021	1	118	118
Tropical Storm	8/14/2021	1	92	92
Tropical Storm	8/14/2021	1	74	74
Tropical Storm	8/14/2021	1	77	77
Tropical Storm	8/14/2021	14	2,982	213
Tropical Storm	8/14/2021	20	5,400	270
Tropical Storm	8/14/2021	3	306	102
Tropical Storm	8/14/2021	1	51	51
Tropical Storm	8/14/2021	14	2,870	205
Tropical Storm	8/14/2021	8	1,584	198
Tropical Storm	8/14/2021	12	276	23
Tropical Storm	8/14/2021	1	131	131
Tropical Storm	8/14/2021	1	166	166
Tropical Storm	8/14/2021	8	888	111
Tropical Storm	8/14/2021	1	225	225
Tropical Storm	8/14/2021	9	2,232	248
Tropical Storm	8/14/2021	7	2,366	338
Tropical Storm	8/14/2021	1	213	213
Tropical Storm	8/14/2021	102	38,250	375
Tropical Storm	8/14/2021	56	9,016	161
Tropical Storm	8/14/2021	1	346	346
Tropical Storm	8/14/2021	10	2,270	227
Tropical Storm	8/14/2021	1	193	194
Tropical Storm	8/14/2021	3	549	183
Tropical Storm	8/14/2021	1	375	375
Tropical Storm	8/14/2021	17	6,715	598
Tropical Storm	8/14/2021	20	1,140	57
Tropical Storm	8/14/2021	18	1,926	107
Tropical Storm	8/14/2021	18	5,904	328
Tropical Storm	8/14/2021	11	1,012	92
Tropical Storm	8/14/2021	8	528	66
Tropical Storm	8/14/2021	1	138	138
Tropical Storm	8/14/2021	2	16	8
Tropical Storm	8/14/2021	4	204	51
Tropical Storm	8/14/2021	13	2,717	209
Tropical Storm	8/14/2021	1	243	243
Tropical Storm	8/14/2021	11	847	77
Tropical Storm	8/14/2021	1	69	69
Tropical Storm	8/14/2021	3	144	48

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	1	146	146
Tropical Storm	8/14/2021	3	549	183
Tropical Storm	8/14/2021	1	234	234
Tropical Storm	8/14/2021	8	2,808	351
Tropical Storm	8/14/2021	10	170	17
Tropical Storm	8/14/2021	1	458	458
Tropical Storm	8/14/2021	12	1,296	108
Tropical Storm	8/14/2021	7	1,372	196
Tropical Storm	8/14/2021	24	672	28
Tropical Storm	8/14/2021	7	406	58
Tropical Storm	8/14/2021	9	924	236
Tropical Storm	8/14/2021	9	1,170	130
Tropical Storm	8/14/2021	2	244	122
Tropical Storm	8/14/2021	1	59	59
Tropical Storm	8/14/2021	11	473	43
Tropical Storm	8/14/2021	47	4,418	94
Tropical Storm	8/14/2021	2	356	178
Tropical Storm	8/14/2021	7	616	88
Tropical Storm	8/14/2021	70	3,010	43
Tropical Storm	8/14/2021	14	3,780	270
Tropical Storm	8/14/2021	180	60,300	335
Tropical Storm	8/14/2021	168	154,930	1,350
Tropical Storm	8/14/2021	3	210	70
Tropical Storm	8/14/2021	10	450	45
Tropical Storm	8/14/2021	15	630	42
Tropical Storm	8/14/2021	153	36,591	251
Tropical Storm	8/14/2021	2	690	345
Tropical Storm	8/14/2021	1	49	49
Tropical Storm	8/14/2021	1	167	167
Tropical Storm	8/14/2021	5	1,275	255
Tropical Storm	8/14/2021	29	4,234	146
Tropical Storm	8/14/2021	3	690	230
Tropical Storm	8/14/2021	9	675	75
Tropical Storm	8/14/2021	6	108	18
Tropical Storm	8/14/2021	1	136	136
Tropical Storm	8/14/2021	1	101	101
Tropical Storm	8/14/2021	1	22	22
Tropical Storm	8/14/2021	55	1,980	36
Tropical Storm	8/14/2021	9	234	26
Tropical Storm	8/14/2021	20	4,840	242
Tropical Storm	8/14/2021	4	492	123
Tropical Storm	8/14/2021	4	24	6
Tropical Storm	8/14/2021	12	408	34

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	1	413	413
Tropical Storm	8/14/2021	3	903	301
Tropical Storm	8/14/2021	11	781	71
Tropical Storm	8/14/2021	3	363	121
Tropical Storm	8/14/2021	14	2,898	207
Tropical Storm	8/14/2021	1	285	285
Tropical Storm	8/14/2021	1	254	254
Tropical Storm	8/14/2021	58	2,726	47
Tropical Storm	8/14/2021	11	4,389	399
Tropical Storm	8/14/2021	6	384	64
Tropical Storm	8/14/2021	54	13,878	257
Tropical Storm	8/14/2021	100	6,500	65
Tropical Storm	8/14/2021	2	186	93
Tropical Storm	8/14/2021	6	270	45
Tropical Storm	8/14/2021	15	1,200	80
Tropical Storm	8/14/2021	1	107	107
Tropical Storm	8/14/2021	1	101	101
Tropical Storm	8/14/2021	18	2,538	141
Tropical Storm	8/14/2021	1	223	223
Tropical Storm	8/14/2021	4	296	74
Tropical Storm	8/14/2021	1	115	115
Tropical Storm	8/14/2021	8	288	36
Tropical Storm	8/14/2021	1	117	117
Tropical Storm	8/14/2021	105	6,720	64
Tropical Storm	8/14/2021	7	567	81
Tropical Storm	8/14/2021	9	2,178	242
Tropical Storm	8/14/2021	32	1,216	38
Tropical Storm	8/14/2021	10	530	53
Tropical Storm	8/14/2021	1	94	94
Tropical Storm	8/14/2021	1	255	255
Tropical Storm	8/14/2021	46	3,726	81
Tropical Storm	8/14/2021	2	98	49
Tropical Storm	8/14/2021	3	177	59
Tropical Storm	8/14/2021	8	184	23
Tropical Storm	8/14/2021	4	340	85
Tropical Storm	8/14/2021	1	98	98
Tropical Storm	8/14/2021	26	1,872	72
Tropical Storm	8/14/2021	9	171	19
Tropical Storm	8/14/2021	2	150	75
Tropical Storm	8/14/2021	1	59	59
Tropical Storm	8/14/2021	4	252	63
Tropical Storm	8/14/2021	4	216	54
Tropical Storm	8/14/2021	2,079	37,646	60

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	1	131	131
Tropical Storm	8/14/2021	28	308	11
Tropical Storm	8/14/2021	68	20,185	315
Tropical Storm	8/14/2021	1	43	43
Tropical Storm	8/14/2021	2	70	35
Tropical Storm	8/14/2021	20	6,340	317
Tropical Storm	8/14/2021	18	684	38
Tropical Storm	8/14/2021	1	66	66
Tropical Storm	8/14/2021	5	255	51
Tropical Storm	8/14/2021	2	738	369
Tropical Storm	8/14/2021	1	73	73
Tropical Storm	8/14/2021	8	2,872	359
Tropical Storm	8/14/2021	11	1,254	114
Tropical Storm	8/14/2021	2	436	218
Tropical Storm	8/14/2021	1	121	121
Tropical Storm	8/14/2021	1	63	63
Tropical Storm	8/14/2021	1	52	52
Tropical Storm	8/14/2021	60	10,514	189
Tropical Storm	8/14/2021	9	468	52
Tropical Storm	8/14/2021	1	133	133
Tropical Storm	8/14/2021	5	205	41
Tropical Storm	8/14/2021	97	24,113	365
Tropical Storm	8/14/2021	1	80	80
Tropical Storm	8/14/2021	7	966	138
Tropical Storm	8/14/2021	2	966	483
Tropical Storm	8/14/2021	1	305	305
Tropical Storm	8/14/2021	1	868	868
Tropical Storm	8/14/2021	1	116	116
Tropical Storm	8/14/2021	1	129	129
Tropical Storm	8/14/2021	1	268	268
Tropical Storm	8/14/2021	8	472	59
Tropical Storm	8/14/2021	1	39	39
Tropical Storm	8/14/2021	12	576	48
Tropical Storm	8/14/2021	1	861	861
Tropical Storm	8/14/2021	257	24,172	752
Tropical Storm	8/14/2021	38	1,254	33
Tropical Storm	8/14/2021	13	1,560	120
Tropical Storm	8/14/2021	4	56	32
Tropical Storm	8/14/2021	1	171	171
Tropical Storm	8/14/2021	5	1,025	205
Tropical Storm	8/14/2021	1	77	77
Tropical Storm	8/14/2021	1	246	246
Tropical Storm	8/14/2021	1	213	213

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	24	1,296	54
Tropical Storm	8/14/2021	9	6,228	692
Tropical Storm	8/14/2021	23	1,380	60
Tropical Storm	8/14/2021	24	4,272	178
Tropical Storm	8/14/2021	2	2,734	1,367
Tropical Storm	8/14/2021	6	4,554	759
Tropical Storm	8/14/2021	19	15,176	1,166
Tropical Storm	8/14/2021	11	2,640	240
Tropical Storm	8/14/2021	363	25,410	70
Tropical Storm	8/14/2021	13	2,639	203
Tropical Storm	8/14/2021	9	630	70
Tropical Storm	8/14/2021	22	10,604	482
Tropical Storm	8/14/2021	10	4,800	480
Tropical Storm	8/14/2021	6	504	84
Tropical Storm	8/14/2021	8	304	38
Tropical Storm	8/14/2021	33	2,442	74
Tropical Storm	8/14/2021	4	28	312
Tropical Storm	8/14/2021	7	2,646	378
Tropical Storm	8/14/2021	35	4,060	116
Tropical Storm	8/14/2021	6	456	76
Tropical Storm	8/14/2021	1	43	43
Tropical Storm	8/14/2021	8	3,544	443
Tropical Storm	8/14/2021	11	2,530	230
Tropical Storm	8/14/2021	38	2,226	63
Tropical Storm	8/14/2021	2	68	34
Tropical Storm	8/14/2021	7	1,288	184
Tropical Storm	8/14/2021	3	1,008	336
Tropical Storm	8/14/2021	1	202	202
Tropical Storm	8/14/2021	9	225	25
Tropical Storm	8/14/2021	43	3,354	78
Tropical Storm	8/14/2021	2	768	384
Tropical Storm	8/14/2021	2	330	165
Tropical Storm	8/14/2021	18	1,188	66
Tropical Storm	8/14/2021	5	740	148
Tropical Storm	8/14/2021	54	9,072	168
Tropical Storm	8/14/2021	47	3,807	81
Tropical Storm	8/14/2021	8	504	63
Tropical Storm	8/14/2021	1	676	676
Tropical Storm	8/14/2021	44	20,680	470
Tropical Storm	8/14/2021	1	37	37
Tropical Storm	8/14/2021	2	206	103
Tropical Storm	8/14/2021	6	624	104
Tropical Storm	8/14/2021	5	175	35

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/14/2021	28	11,032	394
Tropical Storm	8/14/2021	4	1,964	491
Tropical Storm	8/14/2021	66	9,570	145
Tropical Storm	8/14/2021	16	5,872	367
Tropical Storm	8/14/2021	14	7,462	533
Tropical Storm	8/14/2021	2	96	48
Tropical Storm	8/14/2021	92	10,672	116
Tropical Storm	8/14/2021	4	1,252	313
Tropical Storm	8/14/2021	1	80	80
Tropical Storm	8/14/2021	2	384	192
Tropical Storm	8/14/2021	1	38	38
Tropical Storm	8/14/2021	1	117	117
Tropical Storm	8/14/2021	16	2,064	129
Tropical Storm	8/14/2021	1	48	48
Tropical Storm	8/14/2021	9	729	81
Tropical Storm	8/14/2021	1	92	92
Tropical Storm	8/14/2021	1	74	74
Tropical Storm	8/14/2021	2	188	94
Tropical Storm	8/14/2021	4	208	52
Tropical Storm	8/14/2021	22	2,970	135
Tropical Storm	8/14/2021	3	339	113
Tropical Storm	8/14/2021	1	184	184
Tropical Storm	8/14/2021	8	200	25
Tropical Storm	8/14/2021	6	474	79
Tropical Storm	8/14/2021	7	2,331	333
Tropical Storm	8/14/2021	23	6,946	302
Tropical Storm	8/15/2021	45	5,175	115
Tropical Storm	8/15/2021	1	154	154
Tropical Storm	8/15/2021	2	1,122	561
Tropical Storm	8/15/2021	6	270	45
Tropical Storm	8/15/2021	11	1,606	146
Tropical Storm	8/15/2021	10	2,300	230
Tropical Storm	8/15/2021	2	164	82
Tropical Storm	8/15/2021	18	2,186	205
Tropical Storm	8/15/2021	13	3,653	281
Tropical Storm	8/15/2021	1	748	748
Tropical Storm	8/15/2021	24	2,184	91
Tropical Storm	8/15/2021	66	29,181	557
Tropical Storm	8/15/2021	1	88	88
Tropical Storm	8/15/2021	6	3,642	607
Tropical Storm	8/15/2021	57	3,819	67
Tropical Storm	8/15/2021	1	429	429
Tropical Storm	8/15/2021	2	1,136	568

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	7	3,500	500
Tropical Storm	8/15/2021	4	688	172
Tropical Storm	8/15/2021	5	385	77
Tropical Storm	8/15/2021	137	38,908	284
Tropical Storm	8/15/2021	2	850	425
Tropical Storm	8/15/2021	1	69	69
Tropical Storm	8/15/2021	1	443	443
Tropical Storm	8/15/2021	3	189	63
Tropical Storm	8/15/2021	9	513	57
Tropical Storm	8/15/2021	14	4,472	483
Tropical Storm	8/15/2021	1	66	66
Tropical Storm	8/15/2021	3	1,032	344
Tropical Storm	8/15/2021	8	4,208	526
Tropical Storm	8/15/2021	1	43	43
Tropical Storm	8/15/2021	11	2,750	250
Tropical Storm	8/15/2021	9	1,170	130
Tropical Storm	8/15/2021	61	16,165	265
Tropical Storm	8/15/2021	2	132	66
Tropical Storm	8/15/2021	2	524	262
Tropical Storm	8/15/2021	1	291	291
Tropical Storm	8/15/2021	17	4,488	264
Tropical Storm	8/15/2021	3	102	34
Tropical Storm	8/15/2021	27	5,778	214
Tropical Storm	8/15/2021	25	11,375	455
Tropical Storm	8/15/2021	8	1,392	174
Tropical Storm	8/15/2021	7	518	74
Tropical Storm	8/15/2021	2	176	88
Tropical Storm	8/15/2021	128	4,608	36
Tropical Storm	8/15/2021	1	257	257
Tropical Storm	8/15/2021	1	10	10
Tropical Storm	8/15/2021	1	33	33
Tropical Storm	8/15/2021	1	90	90
Tropical Storm	8/15/2021	1	174	174
Tropical Storm	8/15/2021	1	178	178
Tropical Storm	8/15/2021	2	120	60
Tropical Storm	8/15/2021	21	2,415	115
Tropical Storm	8/15/2021	1	26	26
Tropical Storm	8/15/2021	39	3,081	79
Tropical Storm	8/15/2021	3	207	69
Tropical Storm	8/15/2021	30	1,770	59
Tropical Storm	8/15/2021	1	109	109
Tropical Storm	8/15/2021	12	600	50
Tropical Storm	8/15/2021	147	11,760	80

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	4	88	22
Tropical Storm	8/15/2021	1	97	97
Tropical Storm	8/15/2021	8	552	69
Tropical Storm	8/15/2021	9	486	54
Tropical Storm	8/15/2021	7	847	121
Tropical Storm	8/15/2021	4	1,992	498
Tropical Storm	8/15/2021	2	1,066	533
Tropical Storm	8/15/2021	2	60	30
Tropical Storm	8/15/2021	2	140	70
Tropical Storm	8/15/2021	1	136	136
Tropical Storm	8/15/2021	1	183	183
Tropical Storm	8/15/2021	1	227	227
Tropical Storm	8/15/2021	5	225	45
Tropical Storm	8/15/2021	5	2,740	548
Tropical Storm	8/15/2021	11	1,969	179
Tropical Storm	8/15/2021	2	120	60
Tropical Storm	8/15/2021	9	432	48
Tropical Storm	8/15/2021	4	920	230
Tropical Storm	8/15/2021	2	62	31
Tropical Storm	8/15/2021	1	389	389
Tropical Storm	8/15/2021	1	178	178
Tropical Storm	8/15/2021	1	148	148
Tropical Storm	8/15/2021	16	176	11
Tropical Storm	8/15/2021	3	192	64
Tropical Storm	8/15/2021	1	57	57
Tropical Storm	8/15/2021	7	273	39
Tropical Storm	8/15/2021	11	1,664	290
Tropical Storm	8/15/2021	74	3,182	43
Tropical Storm	8/15/2021	1	3	3
Tropical Storm	8/15/2021	12	156	13
Tropical Storm	8/15/2021	1	14	14
Tropical Storm	8/15/2021	9	225	25
Tropical Storm	8/15/2021	2	220	110
Tropical Storm	8/15/2021	1	325	325
Tropical Storm	8/15/2021	8	648	81
Tropical Storm	8/15/2021	3	150	50
Tropical Storm	8/15/2021	7	350	50
Tropical Storm	8/15/2021	12	936	78
Tropical Storm	8/15/2021	4	244	61
Tropical Storm	8/15/2021	30	2,130	71
Tropical Storm	8/15/2021	1	130	130
Tropical Storm	8/15/2021	1	108	108
Tropical Storm	8/15/2021	6	1,536	256

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	37	6,993	189
Tropical Storm	8/15/2021	32	1,536	48
Tropical Storm	8/15/2021	12	5,316	443
Tropical Storm	8/15/2021	8	632	79
Tropical Storm	8/15/2021	10	750	75
Tropical Storm	8/15/2021	1	75	75
Tropical Storm	8/15/2021	7	92	44
Tropical Storm	8/15/2021	39	2,418	62
Tropical Storm	8/15/2021	1	229	229
Tropical Storm	8/15/2021	1	16	16
Tropical Storm	8/15/2021	1	120	120
Tropical Storm	8/15/2021	2	62	31
Tropical Storm	8/15/2021	16	48	3
Tropical Storm	8/15/2021	4	208	52
Tropical Storm	8/15/2021	10	770	77
Tropical Storm	8/15/2021	12	168	14
Tropical Storm	8/15/2021	1	746	746
Tropical Storm	8/15/2021	4	220	55
Tropical Storm	8/15/2021	3	195	65
Tropical Storm	8/15/2021	57	7,182	126
Tropical Storm	8/15/2021	3	447	149
Tropical Storm	8/15/2021	1	156	156
Tropical Storm	8/15/2021	1	140	140
Tropical Storm	8/15/2021	1	590	590
Tropical Storm	8/15/2021	1	481	481
Tropical Storm	8/15/2021	1	67	67
Tropical Storm	8/15/2021	5	315	63
Tropical Storm	8/15/2021	1	164	164
Tropical Storm	8/15/2021	1	112	112
Tropical Storm	8/15/2021	1	159	159
Tropical Storm	8/15/2021	19	1,976	104
Tropical Storm	8/15/2021	1	271	271
Tropical Storm	8/15/2021	36	3,600	100
Tropical Storm	8/15/2021	2	10	5
Tropical Storm	8/15/2021	3	282	94
Tropical Storm	8/15/2021	1	251	251
Tropical Storm	8/15/2021	1	191	191
Tropical Storm	8/15/2021	1	91	91
Tropical Storm	8/15/2021	1	31	31
Tropical Storm	8/15/2021	1	298	298
Tropical Storm	8/15/2021	1	198	198
Tropical Storm	8/15/2021	7	819	117
Tropical Storm	8/15/2021	1	130	130

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	8	1,632	204
Tropical Storm	8/15/2021	8	512	64
Tropical Storm	8/15/2021	1	305	305
Tropical Storm	8/15/2021	1	379	379
Tropical Storm	8/15/2021	1	158	158
Tropical Storm	8/15/2021	15	4,860	324
Tropical Storm	8/15/2021	2	790	395
Tropical Storm	8/15/2021	1	111	111
Tropical Storm	8/15/2021	7	462	66
Tropical Storm	8/15/2021	11	1,749	159
Tropical Storm	8/15/2021	1	206	206
Tropical Storm	8/15/2021	3	540	180
Tropical Storm	8/15/2021	12	84	7
Tropical Storm	8/15/2021	1	77	77
Tropical Storm	8/15/2021	1	197	197
Tropical Storm	8/15/2021	7	1,253	179
Tropical Storm	8/15/2021	6	2,298	383
Tropical Storm	8/15/2021	1	145	145
Tropical Storm	8/15/2021	15	3,030	202
Tropical Storm	8/15/2021	1	614	614
Tropical Storm	8/15/2021	1	496	496
Tropical Storm	8/15/2021	57	10,203	179
Tropical Storm	8/15/2021	8	1,040	130
Tropical Storm	8/15/2021	11	2,827	257
Tropical Storm	8/15/2021	6	252	42
Tropical Storm	8/15/2021	2	136	68
Tropical Storm	8/15/2021	4	1,432	358
Tropical Storm	8/15/2021	2	66	33
Tropical Storm	8/15/2021	1	203	203
Tropical Storm	8/15/2021	9	189	21
Tropical Storm	8/15/2021	2	24	12
Tropical Storm	8/15/2021	1	77	77
Tropical Storm	8/15/2021	1	277	277
Tropical Storm	8/15/2021	1	78	78
Tropical Storm	8/15/2021	15	780	52
Tropical Storm	8/15/2021	18	1,044	58
Tropical Storm	8/15/2021	136	10,744	79
Tropical Storm	8/15/2021	1	182	182
Tropical Storm	8/15/2021	7	1,386	198
Tropical Storm	8/15/2021	1	170	170
Tropical Storm	8/15/2021	1	188	188
Tropical Storm	8/15/2021	1	170	170
Tropical Storm	8/15/2021	1	416	416

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	13	260	20
Tropical Storm	8/15/2021	1	213	213
Tropical Storm	8/15/2021	1	356	356
Tropical Storm	8/15/2021	1	124	124
Tropical Storm	8/15/2021	9	567	63
Tropical Storm	8/15/2021	1	109	109
Tropical Storm	8/15/2021	4	460	115
Tropical Storm	8/15/2021	2	252	126
Tropical Storm	8/15/2021	5	320	64
Tropical Storm	8/15/2021	9	639	71
Tropical Storm	8/15/2021	4	300	75
Tropical Storm	8/15/2021	1	223	223
Tropical Storm	8/15/2021	4	128	32
Tropical Storm	8/15/2021	1	190	190
Tropical Storm	8/15/2021	64	2,368	37
Tropical Storm	8/15/2021	39	7,098	182
Tropical Storm	8/15/2021	7	112	16
Tropical Storm	8/15/2021	27	3,537	131
Tropical Storm	8/15/2021	1	16	16
Tropical Storm	8/15/2021	147	15,435	105
Tropical Storm	8/15/2021	4	208	52
Tropical Storm	8/15/2021	1	57	57
Tropical Storm	8/15/2021	7	2,191	313
Tropical Storm	8/15/2021	1,408	1,408	1
Tropical Storm	8/15/2021	307	22,718	74
Tropical Storm	8/15/2021	2	38	19
Tropical Storm	8/15/2021	8	1,640	205
Tropical Storm	8/15/2021	1	117	117
Tropical Storm	8/15/2021	5	1,560	312
Tropical Storm	8/15/2021	1	208	208
Tropical Storm	8/15/2021	2	54	27
Tropical Storm	8/15/2021	230	18,630	81
Tropical Storm	8/15/2021	85	8,925	105
Tropical Storm	8/15/2021	345	12,765	37
Tropical Storm	8/15/2021	96	6,336	66
Tropical Storm	8/15/2021	155	13,640	88
Tropical Storm	8/15/2021	29	3,480	120
Tropical Storm	8/15/2021	4	480	120
Tropical Storm	8/15/2021	8	1,488	186
Tropical Storm	8/15/2021	3	63	21
Tropical Storm	8/15/2021	1	240	240
Tropical Storm	8/15/2021	2	124	62
Tropical Storm	8/15/2021	10	2,090	209

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	4	92	23
Tropical Storm	8/15/2021	113	3,390	30
Tropical Storm	8/15/2021	11	2,266	206
Tropical Storm	8/15/2021	1	250	250
Tropical Storm	8/15/2021	2	122	61
Tropical Storm	8/15/2021	68	5,712	84
Tropical Storm	8/15/2021	20	1,000	50
Tropical Storm	8/15/2021	4	276	69
Tropical Storm	8/15/2021	1	78	78
Tropical Storm	8/15/2021	1	180	180
Tropical Storm	8/15/2021	2	120	60
Tropical Storm	8/15/2021	2	46	23
Tropical Storm	8/15/2021	4	127	34
Tropical Storm	8/15/2021	32	14,944	467
Tropical Storm	8/15/2021	4	296	74
Tropical Storm	8/15/2021	1,547	4,641	3
Tropical Storm	8/15/2021	1	146	146
Tropical Storm	8/15/2021	3	258	86
Tropical Storm	8/15/2021	1	148	148
Tropical Storm	8/15/2021	1	75	75
Tropical Storm	8/15/2021	6	336	56
Tropical Storm	8/15/2021	3	180	60
Tropical Storm	8/15/2021	1	164	164
Tropical Storm	8/15/2021	1	196	196
Tropical Storm	8/15/2021	4	548	137
Tropical Storm	8/15/2021	1	186	186
Tropical Storm	8/15/2021	1	139	139
Tropical Storm	8/15/2021	2	144	72
Tropical Storm	8/15/2021	12	564	47
Tropical Storm	8/15/2021	2	546	273
Tropical Storm	8/15/2021	1	114	114
Tropical Storm	8/15/2021	11	3,542	322
Tropical Storm	8/15/2021	1	207	207
Tropical Storm	8/15/2021	3	150	50
Tropical Storm	8/15/2021	13	1,961	249
Tropical Storm	8/15/2021	1	57	57
Tropical Storm	8/15/2021	4	120	30
Tropical Storm	8/15/2021	9	864	96
Tropical Storm	8/15/2021	3	198	66
Tropical Storm	8/15/2021	1	56	56
Tropical Storm	8/15/2021	1	100	100
Tropical Storm	8/15/2021	1	109	109
Tropical Storm	8/15/2021	9	2,169	241

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/15/2021	1	147	147
Tropical Storm	8/15/2021	1	214	214
Tropical Storm	8/15/2021	8	1,088	136
Tropical Storm	8/15/2021	22	3,432	156
Tropical Storm	8/15/2021	4	944	236
Tropical Storm	8/15/2021	7	4,669	667
Tropical Storm	8/15/2021	1	82	82
Tropical Storm	8/16/2021	4	1,096	274
Tropical Storm	8/16/2021	3	144	48
Tropical Storm	8/16/2021	9	2,286	254
Tropical Storm	8/16/2021	1	456	456
Tropical Storm	8/16/2021	1	139	139
Tropical Storm	8/16/2021	3	111	37
Tropical Storm	8/16/2021	7	784	112
Tropical Storm	8/16/2021	11	1,276	116
Tropical Storm	8/16/2021	39	3,510	90
Tropical Storm	8/16/2021	4	368	92
Tropical Storm	8/16/2021	2	314	157
Tropical Storm	8/16/2021	1	99	99
Tropical Storm	8/16/2021	4	400	100
Tropical Storm	8/16/2021	11	396	36
Tropical Storm	8/16/2021	76	11,248	148
Tropical Storm	8/16/2021	34	1,530	45
Tropical Storm	8/16/2021	12	4,674	391
Tropical Storm	8/16/2021	1	211	211
Tropical Storm	8/16/2021	1	294	294
Tropical Storm	8/16/2021	2	910	455
Tropical Storm	8/16/2021	5	545	109
Tropical Storm	8/16/2021	9	5,463	607
Tropical Storm	8/16/2021	1	203	203
Tropical Storm	8/16/2021	1	201	201
Tropical Storm	8/16/2021	1	244	244
Tropical Storm	8/16/2021	1	44	44
Tropical Storm	8/16/2021	1	218	218
Tropical Storm	8/16/2021	1	134	134
Tropical Storm	8/16/2021	6	870	145
Tropical Storm	8/16/2021	2	394	197
Tropical Storm	8/16/2021	1	339	339
Tropical Storm	8/16/2021	1	173	173
Tropical Storm	8/16/2021	22	1,056	48
Tropical Storm	8/16/2021	7	3,171	453
Tropical Storm	8/16/2021	1	200	200
Tropical Storm	8/16/2021	3	186	62

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	1	541	541
Tropical Storm	8/16/2021	2	50	25
Tropical Storm	8/16/2021	3	456	152
Tropical Storm	8/16/2021	2	408	204
Tropical Storm	8/16/2021	4	160	40
Tropical Storm	8/16/2021	1	213	213
Tropical Storm	8/16/2021	8	568	71
Tropical Storm	8/16/2021	15	5,190	346
Tropical Storm	8/16/2021	5	940	188
Tropical Storm	8/16/2021	1	96	96
Tropical Storm	8/16/2021	7	560	80
Tropical Storm	8/16/2021	6	792	132
Tropical Storm	8/16/2021	1	189	189
Tropical Storm	8/16/2021	13	3,965	305
Tropical Storm	8/16/2021	36	2,520	70
Tropical Storm	8/16/2021	6	516	86
Tropical Storm	8/16/2021	3	585	195
Tropical Storm	8/16/2021	2	242	121
Tropical Storm	8/16/2021	1	163	163
Tropical Storm	8/16/2021	14	2,562	183
Tropical Storm	8/16/2021	2	676	338
Tropical Storm	8/16/2021	4	84	21
Tropical Storm	8/16/2021	19	684	36
Tropical Storm	8/16/2021	18	1,512	84
Tropical Storm	8/16/2021	1	54	54
Tropical Storm	8/16/2021	1	21	21
Tropical Storm	8/16/2021	1	47	47
Tropical Storm	8/16/2021	1	141	141
Tropical Storm	8/16/2021	1	338	338
Tropical Storm	8/16/2021	1	208	208
Tropical Storm	8/16/2021	1	976	976
Tropical Storm	8/16/2021	26	2,799	249
Tropical Storm	8/16/2021	2	74	37
Tropical Storm	8/16/2021	1	102	102
Tropical Storm	8/16/2021	1	129	129
Tropical Storm	8/16/2021	1	56	56
Tropical Storm	8/16/2021	1	135	135
Tropical Storm	8/16/2021	6	780	130
Tropical Storm	8/16/2021	9	1,341	149
Tropical Storm	8/16/2021	1	328	328
Tropical Storm	8/16/2021	1	170	170
Tropical Storm	8/16/2021	2	62	31
Tropical Storm	8/16/2021	1	235	235

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	4	184	46
Tropical Storm	8/16/2021	12	1,068	89
Tropical Storm	8/16/2021	1	31	31
Tropical Storm	8/16/2021	5	540	108
Tropical Storm	8/16/2021	1	228	228
Tropical Storm	8/16/2021	4	64	16
Tropical Storm	8/16/2021	3	264	88
Tropical Storm	8/16/2021	1	272	272
Tropical Storm	8/16/2021	2	406	203
Tropical Storm	8/16/2021	4	1,748	437
Tropical Storm	8/16/2021	2	24	12
Tropical Storm	8/16/2021	2	10	5
Tropical Storm	8/16/2021	1	885	885
Tropical Storm	8/16/2021	1	115	115
Tropical Storm	8/16/2021	1	119	119
Tropical Storm	8/16/2021	6	522	87
Tropical Storm	8/16/2021	1	136	136
Tropical Storm	8/16/2021	8	1,624	203
Tropical Storm	8/16/2021	1	29	29
Tropical Storm	8/16/2021	1	26	26
Tropical Storm	8/16/2021	8	448	56
Tropical Storm	8/16/2021	7	518	74
Tropical Storm	8/16/2021	1	324	324
Tropical Storm	8/16/2021	2	578	289
Tropical Storm	8/16/2021	1	71	71
Tropical Storm	8/16/2021	3	489	163
Tropical Storm	8/16/2021	7	119	17
Tropical Storm	8/16/2021	1	159	159
Tropical Storm	8/16/2021	5	1,470	294
Tropical Storm	8/16/2021	3	48	16
Tropical Storm	8/16/2021	8	1,008	126
Tropical Storm	8/16/2021	23	92	4
Tropical Storm	8/16/2021	1	261	261
Tropical Storm	8/16/2021	1	3	3
Tropical Storm	8/16/2021	1	1,372	1,372
Tropical Storm	8/16/2021	1	202	202
Tropical Storm	8/16/2021	15	1,635	109
Tropical Storm	8/16/2021	1	35	35
Tropical Storm	8/16/2021	2	8	4
Tropical Storm	8/16/2021	2	130	65
Tropical Storm	8/16/2021	2	536	268
Tropical Storm	8/16/2021	1	420	420
Tropical Storm	8/16/2021	27	3,051	113

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	1	153	153
Tropical Storm	8/16/2021	5	555	111
Tropical Storm	8/16/2021	4	120	30
Tropical Storm	8/16/2021	1	201	201
Tropical Storm	8/16/2021	1	218	218
Tropical Storm	8/16/2021	2	8	4
Tropical Storm	8/16/2021	2	130	65
Tropical Storm	8/16/2021	1	213	213
Tropical Storm	8/16/2021	1	524	524
Tropical Storm	8/16/2021	7	1,533	219
Tropical Storm	8/16/2021	1	90	90
Tropical Storm	8/16/2021	3	87	29
Tropical Storm	8/16/2021	10	350	35
Tropical Storm	8/16/2021	15	285	19
Tropical Storm	8/16/2021	1	78	78
Tropical Storm	8/16/2021	12	1,956	163
Tropical Storm	8/16/2021	1	16	16
Tropical Storm	8/16/2021	1	230	230
Tropical Storm	8/16/2021	1	5	5
Tropical Storm	8/16/2021	45	5,760	128
Tropical Storm	8/16/2021	1	257	257
Tropical Storm	8/16/2021	3	774	258
Tropical Storm	8/16/2021	1	5	5
Tropical Storm	8/16/2021	2	12	6
Tropical Storm	8/16/2021	1	17	17
Tropical Storm	8/16/2021	1	11	11
Tropical Storm	8/16/2021	8	144	18
Tropical Storm	8/16/2021	2	148	74
Tropical Storm	8/16/2021	4	36	9
Tropical Storm	8/16/2021	1	87	87
Tropical Storm	8/16/2021	3	969	323
Tropical Storm	8/16/2021	1	4	4
Tropical Storm	8/16/2021	7	1,876	268
Tropical Storm	8/16/2021	5	285	57
Tropical Storm	8/16/2021	2	10	5
Tropical Storm	8/16/2021	3	21	7
Tropical Storm	8/16/2021	3	18	6
Tropical Storm	8/16/2021	8	560	70
Tropical Storm	8/16/2021	1	174	174
Tropical Storm	8/16/2021	1	6	6
Tropical Storm	8/16/2021	9	189	21
Tropical Storm	8/16/2021	1	223	223
Tropical Storm	8/16/2021	14	196	14

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	2	10	5
Tropical Storm	8/16/2021	7	140	20
Tropical Storm	8/16/2021	4	72	18
Tropical Storm	8/16/2021	13	1,027	79
Tropical Storm	8/16/2021	4	1,680	420
Tropical Storm	8/16/2021	4	152	38
Tropical Storm	8/16/2021	58	4,951	292
Tropical Storm	8/16/2021	1	15	15
Tropical Storm	8/16/2021	6	198	33
Tropical Storm	8/16/2021	1	115	115
Tropical Storm	8/16/2021	4	192	48
Tropical Storm	8/16/2021	3	522	174
Tropical Storm	8/16/2021	11	3,377	307
Tropical Storm	8/16/2021	2	292	146
Tropical Storm	8/16/2021	3	21	7
Tropical Storm	8/16/2021	8	1,768	221
Tropical Storm	8/16/2021	11	693	63
Tropical Storm	8/16/2021	1	16	16
Tropical Storm	8/16/2021	9	198	22
Tropical Storm	8/16/2021	1	44	44
Tropical Storm	8/16/2021	2	42	21
Tropical Storm	8/16/2021	2	168	84
Tropical Storm	8/16/2021	1	8	8
Tropical Storm	8/16/2021	54	13,392	248
Tropical Storm	8/16/2021	4	40	10
Tropical Storm	8/16/2021	1	461	461
Tropical Storm	8/16/2021	1	2	2
Tropical Storm	8/16/2021	9	1,098	122
Tropical Storm	8/16/2021	2	14	7
Tropical Storm	8/16/2021	3	282	94
Tropical Storm	8/16/2021	4	48	12
Tropical Storm	8/16/2021	5	300	60
Tropical Storm	8/16/2021	2	14	7
Tropical Storm	8/16/2021	2	16	8
Tropical Storm	8/16/2021	1	220	220
Tropical Storm	8/16/2021	18	2,502	139
Tropical Storm	8/16/2021	1,680	30,974	33
Tropical Storm	8/16/2021	5	40	8
Tropical Storm	8/16/2021	2	20	10
Tropical Storm	8/16/2021	5	290	58
Tropical Storm	8/16/2021	3	588	196
Tropical Storm	8/16/2021	13	1,131	87
Tropical Storm	8/16/2021	3	96	32

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	4	172	43
Tropical Storm	8/16/2021	1	7	7
Tropical Storm	8/16/2021	1	40	40
Tropical Storm	8/16/2021	1	134	134
Tropical Storm	8/16/2021	6	1,368	228
Tropical Storm	8/16/2021	7	2,191	313
Tropical Storm	8/16/2021	1	16	16
Tropical Storm	8/16/2021	3	393	131
Tropical Storm	8/16/2021	2	10	5
Tropical Storm	8/16/2021	3	123	41
Tropical Storm	8/16/2021	15	1,200	80
Tropical Storm	8/16/2021	1	444	444
Tropical Storm	8/16/2021	1	138	138
Tropical Storm	8/16/2021	35	1,750	50
Tropical Storm	8/16/2021	1	70	70
Tropical Storm	8/16/2021	1	87	87
Tropical Storm	8/16/2021	2	54	27
Tropical Storm	8/16/2021	14	1,904	136
Tropical Storm	8/16/2021	2	8	4
Tropical Storm	8/16/2021	1	7	7
Tropical Storm	8/16/2021	4	20	5
Tropical Storm	8/16/2021	4	172	43
Tropical Storm	8/16/2021	13	390	30
Tropical Storm	8/16/2021	1	215	215
Tropical Storm	8/16/2021	1	17	17
Tropical Storm	8/16/2021	1	168	168
Tropical Storm	8/16/2021	2	626	313
Tropical Storm	8/16/2021	4	52	13
Tropical Storm	8/16/2021	2	8	4
Tropical Storm	8/16/2021	3	18	6
Tropical Storm	8/16/2021	12	84	7
Tropical Storm	8/16/2021	1	50	50
Tropical Storm	8/16/2021	15	195	13
Tropical Storm	8/16/2021	2	64	32
Tropical Storm	8/16/2021	11	3,377	307
Tropical Storm	8/16/2021	2	14	7
Tropical Storm	8/16/2021	4	468	117
Tropical Storm	8/16/2021	1,683	71,027	49
Tropical Storm	8/16/2021	4	28	7
Tropical Storm	8/16/2021	2	20	10
Tropical Storm	8/16/2021	43	1,548	36
Tropical Storm	8/16/2021	7	231	33
Tropical Storm	8/16/2021	15	4,152	302

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	15	150	10
Tropical Storm	8/16/2021	2	10	5
Tropical Storm	8/16/2021	7	1,813	259
Tropical Storm	8/16/2021	1	64	64
Tropical Storm	8/16/2021	1	204	204
Tropical Storm	8/16/2021	3	12	4
Tropical Storm	8/16/2021	1	178	178
Tropical Storm	8/16/2021	1	179	179
Tropical Storm	8/16/2021	2	44	22
Tropical Storm	8/16/2021	1	98	98
Tropical Storm	8/16/2021	1	752	752
Tropical Storm	8/16/2021	4	104	26
Tropical Storm	8/16/2021	4	144	36
Tropical Storm	8/16/2021	10	260	26
Tropical Storm	8/16/2021	1	19	19
Tropical Storm	8/16/2021	5	95	19
Tropical Storm	8/16/2021	4	84	21
Tropical Storm	8/16/2021	4	432	108
Tropical Storm	8/16/2021	10	80	8
Tropical Storm	8/16/2021	5	10	2
Tropical Storm	8/16/2021	1	158	158
Tropical Storm	8/16/2021	1	61	61
Tropical Storm	8/16/2021	2	70	35
Tropical Storm	8/16/2021	4	64	16
Tropical Storm	8/16/2021	4	476	119
Tropical Storm	8/16/2021	1	1	1
Tropical Storm	8/16/2021	1	63	63
Tropical Storm	8/16/2021	10	3,110	311
Tropical Storm	8/16/2021	1	429	429
Tropical Storm	8/16/2021	5	865	173
Tropical Storm	8/16/2021	1	18	18
Tropical Storm	8/16/2021	1	58	58
Tropical Storm	8/16/2021	3	527	177
Tropical Storm	8/16/2021	1	46	46
Tropical Storm	8/16/2021	12	3,072	256
Tropical Storm	8/16/2021	74	8,880	120
Tropical Storm	8/16/2021	4	588	147
Tropical Storm	8/16/2021	1	51	51
Tropical Storm	8/16/2021	39	7,098	182
Tropical Storm	8/16/2021	60	9,000	150
Tropical Storm	8/16/2021	6	1,692	282
Tropical Storm	8/16/2021	5	10	2
Tropical Storm	8/16/2021	1	44	44

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	7	63	9
Tropical Storm	8/16/2021	747	5,229	7
Tropical Storm	8/16/2021	7	2,044	292
Tropical Storm	8/16/2021	4	64	16
Tropical Storm	8/16/2021	7	84	12
Tropical Storm	8/16/2021	1	52	52
Tropical Storm	8/16/2021	12	3,143	490
Tropical Storm	8/16/2021	1	127	127
Tropical Storm	8/16/2021	1	405	405
Tropical Storm	8/16/2021	10	130	13
Tropical Storm	8/16/2021	11	671	61
Tropical Storm	8/16/2021	5	1,510	302
Tropical Storm	8/16/2021	4	796	199
Tropical Storm	8/16/2021	68	18,480	374
Tropical Storm	8/16/2021	1	54	54
Tropical Storm	8/16/2021	37	3,034	82
Tropical Storm	8/16/2021	17	1,836	108
Tropical Storm	8/16/2021	2	38	19
Tropical Storm	8/16/2021	2	376	188
Tropical Storm	8/16/2021	1	164	164
Tropical Storm	8/16/2021	1	109	109
Tropical Storm	8/16/2021	22	4,752	216
Tropical Storm	8/16/2021	14	4,683	589
Tropical Storm	8/16/2021	1	309	309
Tropical Storm	8/16/2021	1	190	190
Tropical Storm	8/16/2021	1	245	245
Tropical Storm	8/16/2021	1	158	158
Tropical Storm	8/16/2021	4	1,356	339
Tropical Storm	8/16/2021	3	288	96
Tropical Storm	8/16/2021	1	315	315
Tropical Storm	8/16/2021	7	84	12
Tropical Storm	8/16/2021	2	120	60
Tropical Storm	8/16/2021	4	196	49
Tropical Storm	8/16/2021	1	275	275
Tropical Storm	8/16/2021	7	56	8
Tropical Storm	8/16/2021	1	113	113
Tropical Storm	8/16/2021	1	315	315
Tropical Storm	8/16/2021	1	337	337
Tropical Storm	8/16/2021	29	3,538	122
Tropical Storm	8/16/2021	6	1,566	261
Tropical Storm	8/16/2021	6	1,554	259
Tropical Storm	8/16/2021	1	326	326
Tropical Storm	8/16/2021	1	230	230

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	1	116	116
Tropical Storm	8/16/2021	2	396	198
Tropical Storm	8/16/2021	1	123	123
Tropical Storm	8/16/2021	2	122	61
Tropical Storm	8/16/2021	4	224	56
Tropical Storm	8/16/2021	14	2,604	186
Tropical Storm	8/16/2021	1	183	183
Tropical Storm	8/16/2021	11	1,562	142
Tropical Storm	8/16/2021	1	58	58
Tropical Storm	8/16/2021	2	510	255
Tropical Storm	8/16/2021	1	268	268
Tropical Storm	8/16/2021	2	714	357
Tropical Storm	8/16/2021	1	86	86
Tropical Storm	8/16/2021	1	683	683
Tropical Storm	8/16/2021	8	1,312	164
Tropical Storm	8/16/2021	3	537	179
Tropical Storm	8/16/2021	1	699	699
Tropical Storm	8/16/2021	43	7,372	388
Tropical Storm	8/16/2021	13	2,093	161
Tropical Storm	8/16/2021	1	158	158
Tropical Storm	8/16/2021	39	5,913	339
Tropical Storm	8/16/2021	1	732	732
Tropical Storm	8/16/2021	2	772	386
Tropical Storm	8/16/2021	1	401	401
Tropical Storm	8/16/2021	1	235	235
Tropical Storm	8/16/2021	1	567	567
Tropical Storm	8/16/2021	1	53	53
Tropical Storm	8/16/2021	1	1,105	1,105
Tropical Storm	8/16/2021	20	600	30
Tropical Storm	8/16/2021	7	465	95
Tropical Storm	8/16/2021	17	1,156	68
Tropical Storm	8/16/2021	23	2,576	112
Tropical Storm	8/16/2021	85	9,945	117
Tropical Storm	8/16/2021	9	12,978	1,442
Tropical Storm	8/16/2021	1	151	151
Tropical Storm	8/16/2021	1	79	79
Tropical Storm	8/16/2021	10	3,520	352
Tropical Storm	8/16/2021	2	650	325
Tropical Storm	8/16/2021	1	1,002	1,002
Tropical Storm	8/16/2021	6	732	122
Tropical Storm	8/16/2021	1	183	183
Tropical Storm	8/16/2021	1	187	187
Tropical Storm	8/16/2021	5	1,215	243

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/16/2021	6	4,116	686
Tropical Storm	8/16/2021	6	942	157
Tropical Storm	8/16/2021	8	480	60
Tropical Storm	8/16/2021	1	33	33
Tropical Storm	8/16/2021	11	352	32
Tropical Storm	8/16/2021	1	308	308
Tropical Storm	8/16/2021	12	9,744	812
Tropical Storm	8/16/2021	8	16	2
Tropical Storm	8/16/2021	1	265	265
Tropical Storm	8/16/2021	1	85	85
Tropical Storm	8/16/2021	8	880	110
Tropical Storm	8/16/2021	2	682	341
Tropical Storm	8/16/2021	8	1,848	231
Tropical Storm	8/16/2021	1	27	27
Tropical Storm	8/16/2021	1	640	640
Tropical Storm	8/16/2021	15	750	50
Tropical Storm	8/16/2021	33	3,729	113
Tropical Storm	8/16/2021	3	342	114
Tropical Storm	8/16/2021	1	69	69
Tropical Storm	8/16/2021	5	205	41
Tropical Storm	8/16/2021	24	3,984	426
Tropical Storm	8/16/2021	5	1,560	312
Tropical Storm	8/16/2021	11	2,695	245
Tropical Storm	8/16/2021	4	992	248
Tropical Storm	8/16/2021	1	11	11
Tropical Storm	8/16/2021	8	928	116
Tropical Storm	8/16/2021	3	969	323
Tropical Storm	8/16/2021	3	915	305
Tropical Storm	8/16/2021	2	240	120
Tropical Storm	8/16/2021	1	49	49
Tropical Storm	8/16/2021	5	1,060	212
Tropical Storm	8/16/2021	25	23,725	949
Tropical Storm	8/16/2021	14	3,136	224
Tropical Storm	8/16/2021	7	2,338	334
Tropical Storm	8/16/2021	5	90	18
Tropical Storm	8/16/2021	1	88	88
Tropical Storm	8/17/2021	1	229	229
Tropical Storm	8/17/2021	11	506	46
Tropical Storm	8/17/2021	4	452	113
Tropical Storm	8/17/2021	7	371	53
Tropical Storm	8/17/2021	8	960	120
Tropical Storm	8/17/2021	34	4,046	119
Tropical Storm	8/17/2021	2	334	167

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/17/2021	6	3,546	591
Tropical Storm	8/17/2021	4	1,308	327
Tropical Storm	8/17/2021	5	535	107
Tropical Storm	8/17/2021	1	334	334
Tropical Storm	8/17/2021	38	1,748	46
Tropical Storm	8/17/2021	9	2,835	315
Tropical Storm	8/17/2021	1	62	62
Tropical Storm	8/17/2021	31	2,976	96
Tropical Storm	8/17/2021	4	292	73
Tropical Storm	8/17/2021	2	114	57
Tropical Storm	8/17/2021	3	231	77
Tropical Storm	8/17/2021	8	1,344	168
Tropical Storm	8/17/2021	1	224	224
Tropical Storm	8/17/2021	17	8,942	526
Tropical Storm	8/17/2021	1	63	63
Tropical Storm	8/17/2021	3	465	155
Tropical Storm	8/17/2021	12	2,160	180
Tropical Storm	8/17/2021	6	474	79
Tropical Storm	8/17/2021	1	115	115
Tropical Storm	8/17/2021	6	450	75
Tropical Storm	8/17/2021	3	465	155
Tropical Storm	8/17/2021	4	36	9
Tropical Storm	8/17/2021	1	158	158
Tropical Storm	8/17/2021	20	2,900	145
Tropical Storm	8/17/2021	1	110	110
Tropical Storm	8/17/2021	5	775	155
Tropical Storm	8/17/2021	8	4,536	567
Tropical Storm	8/17/2021	8	1,144	143
Tropical Storm	8/17/2021	5	665	133
Tropical Storm	8/17/2021	3	21	7
Tropical Storm	8/17/2021	26	364	14
Tropical Storm	8/17/2021	1	66	66
Tropical Storm	8/17/2021	6	516	286
Tropical Storm	8/17/2021	1	83	83
Tropical Storm	8/17/2021	3	822	274
Tropical Storm	8/17/2021	2	98	49
Tropical Storm	8/17/2021	4	32	8
Tropical Storm	8/17/2021	3	12	4
Tropical Storm	8/17/2021	6	576	96
Tropical Storm	8/17/2021	1	3	3
Tropical Storm	8/17/2021	2	10	5
Tropical Storm	8/17/2021	3	21	7
Tropical Storm	8/17/2021	3	15	5

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/17/2021	1	5	5
Tropical Storm	8/17/2021	2	10	5
Tropical Storm	8/17/2021	3	201	67
Tropical Storm	8/17/2021	9	1,179	131
Tropical Storm	8/17/2021	1,463	5,933	299
Tropical Storm	8/17/2021	4	96	24
Tropical Storm	8/17/2021	4	52	13
Tropical Storm	8/17/2021	2	176	88
Tropical Storm	8/17/2021	3	15	5
Tropical Storm	8/17/2021	2	10	5
Tropical Storm	8/17/2021	2	10	5
Tropical Storm	8/17/2021	3	15	5
Tropical Storm	8/17/2021	3	123	41
Tropical Storm	8/17/2021	809	1,618	2
Tropical Storm	8/17/2021	14	336	24
Tropical Storm	8/17/2021	1	164	164
Tropical Storm	8/17/2021	4	180	45
Tropical Storm	8/17/2021	3	1,545	515
Tropical Storm	8/17/2021	13	2,340	180
Tropical Storm	8/17/2021	5	3,315	663
Tropical Storm	8/17/2021	2	8	4
Tropical Storm	8/17/2021	4	40	10
Tropical Storm	8/17/2021	2	192	96
Tropical Storm	8/17/2021	2	38	19
Tropical Storm	8/17/2021	3	117	39
Tropical Storm	8/17/2021	1	105	105
Tropical Storm	8/17/2021	1	171	171
Tropical Storm	8/17/2021	1	348	348
Tropical Storm	8/17/2021	3	129	43
Tropical Storm	8/17/2021	17	6,919	407
Tropical Storm	8/17/2021	2	6	3
Tropical Storm	8/17/2021	3	12	4
Tropical Storm	8/17/2021	1	33	33
Tropical Storm	8/17/2021	55	5,500	100
Tropical Storm	8/17/2021	6	780	130
Tropical Storm	8/17/2021	6	762	127
Tropical Storm	8/17/2021	1	76	76
Tropical Storm	8/17/2021	1	419	419
Tropical Storm	8/17/2021	1	37	37
Tropical Storm	8/17/2021	10	1,150	115
Tropical Storm	8/17/2021	1	38	38
Tropical Storm	8/17/2021	1	18	18
Tropical Storm	8/17/2021	1	6	6

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/17/2021	2	746	373
Tropical Storm	8/17/2021	2	32	16
Tropical Storm	8/17/2021	41	7,035	174
Tropical Storm	8/17/2021	10	2,660	266
Tropical Storm	8/17/2021	4	152	38
Tropical Storm	8/17/2021	1	285	285
Tropical Storm	8/17/2021	3	1,203	401
Tropical Storm	8/17/2021	2	64	32
Tropical Storm	8/17/2021	1	178	178
Tropical Storm	8/17/2021	1	116	116
Tropical Storm	8/17/2021	1	95	95
Tropical Storm	8/17/2021	1	194	194
Tropical Storm	8/17/2021	30	2,610	87
Tropical Storm	8/17/2021	3	1,029	343
Tropical Storm	8/17/2021	1	13	13
Tropical Storm	8/17/2021	2	280	140
Tropical Storm	8/17/2021	1	107	107
Tropical Storm	8/17/2021	6	660	110
Tropical Storm	8/17/2021	2	518	259
Tropical Storm	8/17/2021	2	270	135
Tropical Storm	8/17/2021	797	797	1
Tropical Storm	8/17/2021	6	1,992	332
Tropical Storm	8/17/2021	1	95	95
Tropical Storm	8/17/2021	197	2,364	12
Tropical Storm	8/17/2021	3	228	76
Tropical Storm	8/17/2021	7	1,204	172
Tropical Storm	8/17/2021	81	1,929	159
Tropical Storm	8/17/2021	9	54	6
Tropical Storm	8/17/2021	50	5,050	101
Tropical Storm	8/17/2021	6	1,236	206
Tropical Storm	8/17/2021	4	276	69
Tropical Storm	8/17/2021	2	658	329
Tropical Storm	8/17/2021	9	441	49
Tropical Storm	8/17/2021	2	324	162
Tropical Storm	8/17/2021	9	342	38
Tropical Storm	8/17/2021	9	2,880	320
Tropical Storm	8/17/2021	2	80	40
Tropical Storm	8/17/2021	25	4,075	163
Tropical Storm	8/17/2021	1	43	43
Tropical Storm	8/17/2021	1	113	113
Tropical Storm	8/17/2021	20	13,780	689
Tropical Storm	8/17/2021	4	304	76
Tropical Storm	8/17/2021	1	16	16

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	8/17/2021	1	53	53
Tropical Storm	8/17/2021	3	1,002	334
Tropical Storm	8/17/2021	1	398	398
Tropical Storm	8/17/2021	9	900	100
Tropical Storm	8/17/2021	5	1,035	207
Tropical Storm	8/17/2021	8	464	58
Tropical Storm	8/17/2021	2	136	68
Tropical Storm	8/17/2021	8	104	13
Tropical Storm	8/17/2021	1	59	59
Tropical Storm	8/17/2021	23	1,058	46
Tropical Storm	8/17/2021	29	3,422	686
Tropical Storm	8/17/2021	9	2,394	266
Tropical Storm	8/17/2021	43	7,405	484
Tropical Storm	8/17/2021	2	176	88
Tropical Storm	8/17/2021	1	87	87
Tropical Storm	8/17/2021	4	260	65
Tropical Storm	8/17/2021	4	480	120
Tropical Storm	8/17/2021	11	66	6
Tropical Storm	8/17/2021	1	127	127
Tropical Storm	8/17/2021	1	566	566
Tropical Storm	8/17/2021	14	896	64
Tropical Storm	8/17/2021	3	126	42
Tropical Storm	8/17/2021	3	240	80
Tropical Storm	8/17/2021	17	4,556	268
Tropical Storm	8/17/2021	2	48	24
Tropical Storm	8/17/2021	34	8,728	844
Tropical Storm	8/17/2021	40	3,080	77
Tropical Storm	8/17/2021	2	144	72
Tropical Storm	8/17/2021	591	12,411	21
Tropical Storm	8/17/2021	22	4,356	198
Tropical Storm	8/17/2021	3	330	178
Tropical Storm	8/17/2021	1	45	45
Tropical Storm	8/17/2021	6	1,014	169
Tropical Storm	8/17/2021	3	555	185
Tropical Storm	8/17/2021	1	145	145
Hurricane	8/28/2021	171	22,059	129
Hurricane	8/28/2021	1	44	44
Hurricane	8/28/2021	57	10,317	181
Hurricane	8/28/2021	114	50,362	617
Hurricane	8/28/2021	1	53	53
Hurricane	8/28/2021	5	3,565	713
Hurricane	8/28/2021	2	106	53
Hurricane	8/28/2021	6	1,296	216

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/28/2021	10	3,510	351
Hurricane	8/28/2021	15	1,365	91
Hurricane	8/28/2021	1	228	228
Hurricane	8/28/2021	4	48	12
Hurricane	8/28/2021	6	1,620	270
Hurricane	8/28/2021	7	2,562	366
Hurricane	8/28/2021	9	702	78
Hurricane	8/28/2021	1	23	23
Hurricane	8/28/2021	1	25	25
Hurricane	8/28/2021	1	383	383
Hurricane	8/28/2021	2	96	48
Hurricane	8/28/2021	1	7	7
Hurricane	8/28/2021	1	133	133
Hurricane	8/28/2021	8	2,304	288
Hurricane	8/28/2021	1	110	110
Hurricane	8/28/2021	12	1,104	92
Hurricane	8/28/2021	2	46	23
Hurricane	8/28/2021	1	58	58
Hurricane	8/28/2021	1	237	237
Hurricane	8/28/2021	1	449	449
Hurricane	8/28/2021	1	331	331
Hurricane	8/28/2021	1	562	562
Hurricane	8/28/2021	1	319	319
Hurricane	8/28/2021	1	224	224
Hurricane	8/28/2021	14	4,158	297
Hurricane	8/28/2021	8	2,016	252
Hurricane	8/28/2021	10	510	51
Hurricane	8/28/2021	4	304	76
Hurricane	8/28/2021	13	1,963	151
Hurricane	8/28/2021	24	1,152	48
Hurricane	8/28/2021	1	96	96
Hurricane	8/28/2021	5	720	144
Hurricane	8/28/2021	1	114	114
Hurricane	8/28/2021	2	264	132
Hurricane	8/28/2021	1	3	3
Hurricane	8/28/2021	25	3,075	123
Hurricane	8/28/2021	1	77	77
Hurricane	8/28/2021	1	64	64
Hurricane	8/28/2021	43	15,398	380
Hurricane	8/28/2021	1	40	40
Hurricane	8/28/2021	8	3,720	465
Hurricane	8/28/2021	1	7	7
Hurricane	8/28/2021	6	540	90

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/28/2021	1	582	582
Hurricane	8/28/2021	39	17,472	448
Hurricane	8/28/2021	2	100	73
Hurricane	8/28/2021	19	1,235	65
Hurricane	8/28/2021	1	76	76
Hurricane	8/28/2021	12	792	66
Hurricane	8/28/2021	4	348	87
Hurricane	8/28/2021	38	2,698	71
Hurricane	8/28/2021	7	2,107	301
Hurricane	8/28/2021	7	987	141
Hurricane	8/28/2021	1,507	38,050	43
Hurricane	8/28/2021	1	74	74
Hurricane	8/28/2021	10	2,190	219
Hurricane	8/28/2021	1	492	492
Hurricane	8/28/2021	42	7,140	170
Hurricane	8/28/2021	9	1,836	204
Hurricane	8/28/2021	3	138	46
Hurricane	8/28/2021	11	1,309	119
Hurricane	8/28/2021	2	870	435
Hurricane	8/28/2021	2	570	285
Hurricane	8/28/2021	2	258	129
Hurricane	8/28/2021	18	4,932	274
Hurricane	8/28/2021	1	211	211
Hurricane	8/28/2021	2	782	391
Hurricane	8/28/2021	5	740	148
Hurricane	8/28/2021	7	259	37
Hurricane	8/28/2021	104	39,000	375
Hurricane	8/28/2021	18	1,998	111
Hurricane	8/28/2021	2	294	147
Hurricane	8/28/2021	6	786	131
Hurricane	8/28/2021	9	4,068	452
Hurricane	8/28/2021	105	23,217	519
Hurricane	8/28/2021	52	5,161	454
Hurricane	8/28/2021	6	906	151
Hurricane	8/28/2021	1	178	178
Hurricane	8/28/2021	20	9,020	451
Hurricane	8/28/2021	1,808	51,024	112
Hurricane	8/28/2021	1	224	224
Hurricane	8/28/2021	12	1,944	162
Hurricane	8/28/2021	6	3,060	510
Hurricane	8/28/2021	1	241	241
Hurricane	8/28/2021	107	22,684	212
Hurricane	8/28/2021	6	2,208	368

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/28/2021	59	15,045	255
Hurricane	8/28/2021	2	370	185
Hurricane	8/28/2021	79	5,378	218
Hurricane	8/28/2021	10	1,820	182
Hurricane	8/28/2021	3	1,356	452
Hurricane	8/28/2021	108	58,846	574
Hurricane	8/28/2021	11	3,795	345
Hurricane	8/28/2021	9	2,421	269
Hurricane	8/28/2021	131	26,264	264
Hurricane	8/28/2021	26	2,496	96
Hurricane	8/28/2021	8	3,288	411
Hurricane	8/28/2021	57	14,436	443
Hurricane	8/28/2021	239	30,831	129
Hurricane	8/28/2021	11	3,388	308
Hurricane	8/28/2021	2	422	211
Hurricane	8/28/2021	6	3,330	555
Hurricane	8/28/2021	106	40,810	385
Hurricane	8/28/2021	14	2,486	409
Hurricane	8/28/2021	4	776	194
Hurricane	8/28/2021	1	275	275
Hurricane	8/28/2021	27	3,969	147
Hurricane	8/28/2021	2	270	135
Hurricane	8/28/2021	18	4,140	230
Hurricane	8/28/2021	19	836	44
Hurricane	8/28/2021	72	18,144	252
Hurricane	8/28/2021	11	1,870	170
Hurricane	8/28/2021	3	705	235
Hurricane	8/28/2021	1	180	180
Hurricane	8/28/2021	5	355	71
Hurricane	8/28/2021	4	1,268	317
Hurricane	8/28/2021	10	3,230	323
Hurricane	8/28/2021	66	7,458	113
Hurricane	8/28/2021	25	6,025	241
Hurricane	8/28/2021	5	655	131
Hurricane	8/28/2021	1	115	115
Hurricane	8/28/2021	2	886	443
Hurricane	8/28/2021	8	2,352	294
Hurricane	8/28/2021	2	98	49
Hurricane	8/28/2021	12	227	29
Hurricane	8/28/2021	14	2,140	203
Hurricane	8/28/2021	1	50	50
Hurricane	8/28/2021	3	2,226	742
Hurricane	8/28/2021	1	290	290

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/28/2021	1	55	55
Hurricane	8/28/2021	3	735	245
Hurricane	8/28/2021	1	278	278
Hurricane	8/28/2021	3	72	24
Hurricane	8/28/2021	1	155	155
Hurricane	8/28/2021	1	136	136
Hurricane	8/28/2021	1	163	163
Hurricane	8/28/2021	3	198	66
Hurricane	8/28/2021	3	138	46
Hurricane	8/28/2021	2	606	303
Hurricane	8/28/2021	1	55	55
Hurricane	8/28/2021	8	280	35
Hurricane	8/28/2021	1	251	251
Hurricane	8/28/2021	5	845	169
Hurricane	8/28/2021	11	1,958	178
Hurricane	8/28/2021	1	109	109
Hurricane	8/28/2021	1	285	285
Hurricane	8/28/2021	5	690	138
Hurricane	8/28/2021	3	528	176
Hurricane	8/28/2021	18	5,346	297
Hurricane	8/28/2021	10	1,630	163
Hurricane	8/28/2021	1	136	136
Hurricane	8/28/2021	1	134	134
Hurricane	8/28/2021	2	674	337
Hurricane	8/28/2021	1	345	345
Hurricane	8/28/2021	1	171	171
Hurricane	8/28/2021	1	572	572
Hurricane	8/28/2021	68	44,268	651
Hurricane	8/28/2021	1	148	148
Hurricane	8/28/2021	1	189	189
Hurricane	8/28/2021	1	233	233
Hurricane	8/28/2021	1	290	290
Hurricane	8/28/2021	2	144	72
Hurricane	8/28/2021	1	257	257
Hurricane	8/28/2021	1	56	56
Hurricane	8/28/2021	7	406	58
Hurricane	8/28/2021	5	1,515	303
Hurricane	8/28/2021	1	338	338
Hurricane	8/28/2021	12	1,242	243
Hurricane	8/28/2021	1	158	158
Hurricane	8/28/2021	1	266	266
Hurricane	8/28/2021	1	1,015	1,015
Hurricane	8/28/2021	1	271	271

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/28/2021	7	882	126
Hurricane	8/28/2021	6	240	40
Hurricane	8/28/2021	1	36	36
Hurricane	8/28/2021	2	32	16
Hurricane	8/28/2021	1	713	713
Hurricane	8/28/2021	36	6,970	204
Hurricane	8/28/2021	1	136	136
Hurricane	8/28/2021	20	11,000	550
Hurricane	8/28/2021	41	11,275	275
Hurricane	8/28/2021	7	1,120	160
Hurricane	8/28/2021	8	3,992	499
Hurricane	8/28/2021	2	1,358	679
Hurricane	8/28/2021	12	3,444	287
Hurricane	8/28/2021	1	108	108
Hurricane	8/29/2021	1	982	982
Hurricane	8/29/2021	1	339	339
Hurricane	8/29/2021	1	520	520
Hurricane	8/29/2021	5	2,045	409
Hurricane	8/29/2021	3	30	10
Hurricane	8/29/2021	1	451	451
Hurricane	8/29/2021	1	56	56
Hurricane	8/29/2021	1	391	391
Hurricane	8/29/2021	3	138	46
Hurricane	8/29/2021	1	165	165
Hurricane	8/29/2021	2	130	65
Hurricane	8/29/2021	1	189	189
Hurricane	8/29/2021	2	108	54
Hurricane	8/29/2021	4	284	71
Hurricane	8/29/2021	1	55	55
Hurricane	8/29/2021	1	56	56
Hurricane	8/29/2021	1	237	237
Hurricane	8/29/2021	2	246	123
Hurricane	8/29/2021	5	725	145
Hurricane	8/29/2021	1	68	68
Hurricane	8/29/2021	2	518	259
Hurricane	8/29/2021	32	4,149	145
Hurricane	8/29/2021	1	354	354
Hurricane	8/29/2021	8	248	31
Hurricane	8/29/2021	314	13,502	43
Hurricane	8/29/2021	9	198	22
Hurricane	8/29/2021	1	123	123
Hurricane	8/29/2021	14	1,526	109
Hurricane	8/29/2021	67	5,896	88

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/29/2021	28	1,988	71
Hurricane	8/29/2021	98	14,602	149
Hurricane	8/29/2021	17	5,063	540
Hurricane	8/29/2021	69	10,606	324
Hurricane	8/29/2021	1	131	131
Hurricane	8/29/2021	5	840	168
Hurricane	8/29/2021	19	1,824	96
Hurricane	8/29/2021	1	182	182
Hurricane	8/29/2021	6	246	41
Hurricane	8/29/2021	1	223	223
Hurricane	8/29/2021	1	269	269
Hurricane	8/29/2021	23	2,467	193
Hurricane	8/29/2021	1	386	386
Hurricane	8/29/2021	296	20,424	69
Hurricane	8/29/2021	9	837	93
Hurricane	8/29/2021	12	1,488	124
Hurricane	8/29/2021	1	61	61
Hurricane	8/29/2021	42	5,054	441
Hurricane	8/29/2021	5	125	25
Hurricane	8/29/2021	50	5,400	108
Hurricane	8/29/2021	1	414	414
Hurricane	8/29/2021	28	4,144	148
Hurricane	8/29/2021	50	17,014	598
Hurricane	8/29/2021	12	960	80
Hurricane	8/29/2021	4	524	131
Hurricane	8/29/2021	3	657	219
Hurricane	8/29/2021	3	183	61
Hurricane	8/29/2021	26	8,218	733
Hurricane	8/29/2021	4	44	11
Hurricane	8/29/2021	89	9,056	1,396
Hurricane	8/29/2021	2	324	162
Hurricane	8/29/2021	1	301	301
Hurricane	8/29/2021	1	556	556
Hurricane	8/29/2021	36	10,200	638
Hurricane	8/29/2021	1	379	379
Hurricane	8/29/2021	15	2,955	197
Hurricane	8/29/2021	9	396	44
Hurricane	8/29/2021	6	30	5
Hurricane	8/29/2021	55	31,460	572
Hurricane	8/29/2021	23	5,593	644
Hurricane	8/29/2021	1	331	331
Hurricane	8/29/2021	4	692	173
Hurricane	8/29/2021	65	16,360	269

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/29/2021	250	34,336	299
Hurricane	8/29/2021	4	1,508	377
Hurricane	8/29/2021	58	6,322	109
Hurricane	8/29/2021	151	6,342	42
Hurricane	8/29/2021	5	1,120	224
Hurricane	8/29/2021	5	540	108
Hurricane	8/29/2021	7	2,842	406
Hurricane	8/29/2021	87	6,612	76
Hurricane	8/29/2021	14	1,470	105
Hurricane	8/29/2021	14	1,764	126
Hurricane	8/29/2021	1	151	151
Hurricane	8/29/2021	2	436	218
Hurricane	8/29/2021	1	147	147
Hurricane	8/29/2021	1	241	241
Hurricane	8/29/2021	1	291	291
Hurricane	8/29/2021	136	14,552	107
Hurricane	8/29/2021	6	1,716	286
Hurricane	8/29/2021	35	1,960	56
Hurricane	8/29/2021	2	308	154
Hurricane	8/29/2021	7	1,911	273
Hurricane	8/29/2021	1	304	304
Hurricane	8/29/2021	105	9,450	90
Hurricane	8/29/2021	13	936	72
Hurricane	8/29/2021	30	2,940	98
Hurricane	8/29/2021	2	192	96
Hurricane	8/29/2021	2	384	192
Hurricane	8/29/2021	127	21,920	314
Hurricane	8/29/2021	1	14	14
Hurricane	8/29/2021	1	200	200
Hurricane	8/29/2021	1	163	163
Hurricane	8/29/2021	3	1,143	381
Hurricane	8/29/2021	4	436	109
Hurricane	8/29/2021	2	316	158
Hurricane	8/29/2021	2	348	174
Hurricane	8/29/2021	1	298	298
Hurricane	8/29/2021	1	340	340
Hurricane	8/29/2021	2	406	203
Hurricane	8/29/2021	3	219	73
Hurricane	8/29/2021	1	331	331
Hurricane	8/29/2021	1	130	130
Hurricane	8/29/2021	2	506	253
Hurricane	8/29/2021	3	141	47
Hurricane	8/29/2021	1	130	130

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	8/29/2021	81	10,611	131
Hurricane	8/29/2021	2	438	219
Hurricane	8/29/2021	3	471	157
Hurricane	8/29/2021	1	99	99
Hurricane	8/29/2021	3	1,425	475
Hurricane	8/29/2021	1	179	179
Hurricane	8/29/2021	3	279	93
Hurricane	8/29/2021	1	270	270
Hurricane	8/29/2021	20	2,080	104
Hurricane	8/29/2021	1	257	257
Hurricane	8/29/2021	7	532	76
Hurricane	8/29/2021	9	486	54
Hurricane	8/29/2021	42	2,522	90
Hurricane	8/29/2021	8	616	77
Hurricane	8/29/2021	2	34	17
Hurricane	8/29/2021	1	497	497
Hurricane	8/31/2021	5	440	88
Hurricane	8/31/2021	1	108	108
Hurricane	8/31/2021	1	246	246
Hurricane	8/31/2021	50	59,410	1,931
Hurricane	8/31/2021	52	6,861	231
Hurricane	8/31/2021	2	76	38
Hurricane	8/31/2021	1	70	70
Hurricane	9/1/2021	4	100	25
Hurricane	9/1/2021	2	288	144
Hurricane	9/1/2021	4	680	170
Hurricane	9/1/2021	4	3,652	913
Hurricane	9/1/2021	16	2,976	186
Hurricane	9/1/2021	2	570	285
Hurricane	9/1/2021	41	11,644	284
Hurricane	9/1/2021	1	332	332
Hurricane	9/1/2021	5	35	7
Hurricane	9/1/2021	2	200	100
Hurricane	9/1/2021	6	3,840	640
Hurricane	9/1/2021	2	326	163
Hurricane	9/1/2021	8	3,592	449
Hurricane	9/1/2021	15	11,430	762
Hurricane	9/1/2021	2	972	486
Hurricane	9/1/2021	5	405	81
Hurricane	9/1/2021	39	1,521	39
Hurricane	9/1/2021	4	792	198
Hurricane	9/1/2021	2	254	127
Hurricane	9/1/2021	1	52	52

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	8	1,176	147
Hurricane	9/1/2021	43	6,665	155
Hurricane	9/1/2021	3	1,677	559
Hurricane	9/1/2021	1	25	25
Hurricane	9/1/2021	2	200	100
Hurricane	9/1/2021	4	1,236	309
Hurricane	9/1/2021	46	5,198	256
Hurricane	9/1/2021	1	150	150
Hurricane	9/1/2021	12	468	39
Hurricane	9/1/2021	39	23,439	601
Hurricane	9/1/2021	4	220	55
Hurricane	9/1/2021	4	1,748	437
Hurricane	9/1/2021	3	372	124
Hurricane	9/1/2021	4	100	25
Hurricane	9/1/2021	1	165	165
Hurricane	9/1/2021	4	216	54
Hurricane	9/1/2021	3	396	132
Hurricane	9/1/2021	1	82	82
Hurricane	9/1/2021	4	1,128	282
Hurricane	9/1/2021	19	266	14
Hurricane	9/1/2021	21	2,625	125
Hurricane	9/1/2021	1	346	346
Hurricane	9/1/2021	1	93	93
Hurricane	9/1/2021	1	99	99
Hurricane	9/1/2021	1	241	241
Hurricane	9/1/2021	2	40	20
Hurricane	9/1/2021	1	22	22
Hurricane	9/1/2021	3	135	45
Hurricane	9/1/2021	8	592	74
Hurricane	9/1/2021	15	435	29
Hurricane	9/1/2021	1	638	638
Hurricane	9/1/2021	1	164	164
Hurricane	9/1/2021	2	158	79
Hurricane	9/1/2021	5	2,575	515
Hurricane	9/1/2021	190	6,840	36
Hurricane	9/1/2021	34	1,530	45
Hurricane	9/1/2021	52	6,916	133
Hurricane	9/1/2021	40	6,680	167
Hurricane	9/1/2021	9	477	53
Hurricane	9/1/2021	8	736	92
Hurricane	9/1/2021	1	46	46
Hurricane	9/1/2021	2	1,352	676
Hurricane	9/1/2021	1	289	289

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	47	3,149	67
Hurricane	9/1/2021	3	63	21
Hurricane	9/1/2021	13	1,703	131
Hurricane	9/1/2021	9	603	67
Hurricane	9/1/2021	1	139	139
Hurricane	9/1/2021	4	204	51
Hurricane	9/1/2021	1	7	7
Hurricane	9/1/2021	12	2,892	241
Hurricane	9/1/2021	10	50	5
Hurricane	9/1/2021	3	372	124
Hurricane	9/1/2021	1	583	583
Hurricane	9/1/2021	1	386	386
Hurricane	9/1/2021	1	390	390
Hurricane	9/1/2021	1	402	402
Hurricane	9/1/2021	1	181	181
Hurricane	9/1/2021	2	86	51
Hurricane	9/1/2021	5	580	116
Hurricane	9/1/2021	1	192	192
Hurricane	9/1/2021	1	177	177
Hurricane	9/1/2021	1	339	339
Hurricane	9/1/2021	1	579	579
Hurricane	9/1/2021	1	173	173
Hurricane	9/1/2021	8	408	51
Hurricane	9/1/2021	1	329	329
Hurricane	9/1/2021	1	123	123
Hurricane	9/1/2021	1	268	268
Hurricane	9/1/2021	2	102	51
Hurricane	9/1/2021	30	1,260	42
Hurricane	9/1/2021	10	780	78
Hurricane	9/1/2021	3	165	55
Hurricane	9/1/2021	23	1,771	77
Hurricane	9/1/2021	1	179	179
Hurricane	9/1/2021	6	606	101
Hurricane	9/1/2021	2	244	122
Hurricane	9/1/2021	1	574	574
Hurricane	9/1/2021	4	316	79
Hurricane	9/1/2021	1	154	154
Hurricane	9/1/2021	1	356	356
Hurricane	9/1/2021	2	320	160
Hurricane	9/1/2021	4	204	51
Hurricane	9/1/2021	13	1,456	112
Hurricane	9/1/2021	7	77	11
Hurricane	9/1/2021	5	165	33

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	12	636	53
Hurricane	9/1/2021	1	131	131
Hurricane	9/1/2021	1	329	329
Hurricane	9/1/2021	1	144	144
Hurricane	9/1/2021	35	14,420	412
Hurricane	9/1/2021	13	429	33
Hurricane	9/1/2021	7	245	35
Hurricane	9/1/2021	7	63	9
Hurricane	9/1/2021	1	195	195
Hurricane	9/1/2021	1	81	81
Hurricane	9/1/2021	1	1,242	1,242
Hurricane	9/1/2021	1	401	401
Hurricane	9/1/2021	2	246	123
Hurricane	9/1/2021	112	4,816	43
Hurricane	9/1/2021	1	47	47
Hurricane	9/1/2021	14	616	44
Hurricane	9/1/2021	1	193	193
Hurricane	9/1/2021	1	233	233
Hurricane	9/1/2021	1	73	73
Hurricane	9/1/2021	1	218	218
Hurricane	9/1/2021	1	54	54
Hurricane	9/1/2021	37	185	5
Hurricane	9/1/2021	2	344	172
Hurricane	9/1/2021	5	670	134
Hurricane	9/1/2021	1	262	262
Hurricane	9/1/2021	9	81	9
Hurricane	9/1/2021	5	25	5
Hurricane	9/1/2021	50	4,500	90
Hurricane	9/1/2021	2	192	96
Hurricane	9/1/2021	50	5,600	112
Hurricane	9/1/2021	3	207	69
Hurricane	9/1/2021	3	45	15
Hurricane	9/1/2021	3	372	124
Hurricane	9/1/2021	1	26	26
Hurricane	9/1/2021	3	210	70
Hurricane	9/1/2021	2	56	28
Hurricane	9/1/2021	16	3,360	210
Hurricane	9/1/2021	1	160	160
Hurricane	9/1/2021	2	34	17
Hurricane	9/1/2021	81	7,506	221
Hurricane	9/1/2021	72	11,592	161
Hurricane	9/1/2021	14	3,010	215
Hurricane	9/1/2021	39	6,045	155

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	33	4,818	146
Hurricane	9/1/2021	2	22	11
Hurricane	9/1/2021	3	780	260
Hurricane	9/1/2021	4	660	165
Hurricane	9/1/2021	1	110	110
Hurricane	9/1/2021	24	3,072	128
Hurricane	9/1/2021	1	165	165
Hurricane	9/1/2021	109	11,573	133
Hurricane	9/1/2021	1	95	95
Hurricane	9/1/2021	4	72	18
Hurricane	9/1/2021	2	530	265
Hurricane	9/1/2021	2	826	413
Hurricane	9/1/2021	2	352	176
Hurricane	9/1/2021	2	854	427
Hurricane	9/1/2021	1	395	395
Hurricane	9/1/2021	2	78	39
Hurricane	9/1/2021	4	236	59
Hurricane	9/1/2021	8	344	43
Hurricane	9/1/2021	77	308	4
Hurricane	9/1/2021	40	2,640	66
Hurricane	9/1/2021	1	27	27
Hurricane	9/1/2021	9	3,865	445
Hurricane	9/1/2021	8	4,064	508
Hurricane	9/1/2021	2	512	256
Hurricane	9/1/2021	1	34	34
Hurricane	9/1/2021	9	1,611	179
Hurricane	9/1/2021	4	52	13
Hurricane	9/1/2021	3	159	53
Hurricane	9/1/2021	7	1,197	171
Hurricane	9/1/2021	7	770	110
Hurricane	9/1/2021	15	1,879	258
Hurricane	9/1/2021	2	582	291
Hurricane	9/1/2021	11	176	16
Hurricane	9/1/2021	8	80	10
Hurricane	9/1/2021	31	4,681	151
Hurricane	9/1/2021	1	263	263
Hurricane	9/1/2021	3	120	40
Hurricane	9/1/2021	5	40	8
Hurricane	9/1/2021	1	310	310
Hurricane	9/1/2021	1	163	163
Hurricane	9/1/2021	2	426	213
Hurricane	9/1/2021	11	484	44
Hurricane	9/1/2021	10	1,590	159

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	1	811	811
Hurricane	9/1/2021	1	112	112
Hurricane	9/1/2021	7	861	123
Hurricane	9/1/2021	1	394	394
Hurricane	9/1/2021	3	606	202
Hurricane	9/1/2021	22	308	14
Hurricane	9/1/2021	5	60	12
Hurricane	9/1/2021	4	984	246
Hurricane	9/1/2021	1	381	381
Hurricane	9/1/2021	3	138	46
Hurricane	9/1/2021	1	227	227
Hurricane	9/1/2021	1	54	54
Hurricane	9/1/2021	41	3,280	80
Hurricane	9/1/2021	3	144	48
Hurricane	9/1/2021	4	456	114
Hurricane	9/1/2021	14	154	11
Hurricane	9/1/2021	85	4,250	50
Hurricane	9/1/2021	14	2,926	209
Hurricane	9/1/2021	21	1,470	70
Hurricane	9/1/2021	1	130	130
Hurricane	9/1/2021	89	5,428	296
Hurricane	9/1/2021	1	203	203
Hurricane	9/1/2021	1	68	68
Hurricane	9/1/2021	2	1,068	534
Hurricane	9/1/2021	22	5,896	268
Hurricane	9/1/2021	74	10,138	137
Hurricane	9/1/2021	2	708	354
Hurricane	9/1/2021	2	74	37
Hurricane	9/1/2021	7	889	127
Hurricane	9/1/2021	1	69	69
Hurricane	9/1/2021	1	80	80
Hurricane	9/1/2021	1	1,442	1,442
Hurricane	9/1/2021	1	52	52
Hurricane	9/1/2021	268	67,784	275
Hurricane	9/1/2021	1	161	161
Hurricane	9/1/2021	2	34	17
Hurricane	9/1/2021	9	576	64
Hurricane	9/1/2021	8	144	18
Hurricane	9/1/2021	3	1,311	437
Hurricane	9/1/2021	2	160	80
Hurricane	9/1/2021	9	144	16
Hurricane	9/1/2021	4	144	36
Hurricane	9/1/2021	100	18,300	183

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	1	39	39
Hurricane	9/1/2021	4	52	13
Hurricane	9/1/2021	3	78	26
Hurricane	9/1/2021	1	98	98
Hurricane	9/1/2021	1	102	102
Hurricane	9/1/2021	6	1,482	247
Hurricane	9/1/2021	57	6,327	111
Hurricane	9/1/2021	19	2,812	148
Hurricane	9/1/2021	7	1,253	179
Hurricane	9/1/2021	74	17,020	230
Hurricane	9/1/2021	6	618	103
Hurricane	9/1/2021	21	2,961	141
Hurricane	9/1/2021	1	143	143
Hurricane	9/1/2021	29	10,440	360
Hurricane	9/1/2021	6	2,028	338
Hurricane	9/1/2021	4	1,784	446
Hurricane	9/1/2021	7	1,834	262
Hurricane	9/1/2021	6	888	148
Hurricane	9/1/2021	1	399	399
Hurricane	9/1/2021	1	234	234
Hurricane	9/1/2021	11	1,496	136
Hurricane	9/1/2021	1	209	209
Hurricane	9/1/2021	4	872	218
Hurricane	9/1/2021	1	204	204
Hurricane	9/1/2021	17	629	37
Hurricane	9/1/2021	4	1,212	303
Hurricane	9/1/2021	19	1,672	88
Hurricane	9/1/2021	5	35	7
Hurricane	9/1/2021	1	138	138
Hurricane	9/1/2021	1	137	137
Hurricane	9/1/2021	25	2,850	114
Hurricane	9/1/2021	6	480	80
Hurricane	9/1/2021	1	186	186
Hurricane	9/1/2021	9	1,818	202
Hurricane	9/1/2021	7	567	81
Hurricane	9/1/2021	177	13,629	77
Hurricane	9/1/2021	4	1,168	292
Hurricane	9/1/2021	2	344	172
Hurricane	9/1/2021	8	1,584	198
Hurricane	9/1/2021	1	271	271
Hurricane	9/1/2021	1	242	242
Hurricane	9/1/2021	1	77	77
Hurricane	9/1/2021	5	1,830	366

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	2	28	14
Hurricane	9/1/2021	8	1,688	211
Hurricane	9/1/2021	2	294	147
Hurricane	9/1/2021	82	3,034	37
Hurricane	9/1/2021	37	1,739	47
Hurricane	9/1/2021	1	282	282
Hurricane	9/1/2021	8	1,904	238
Hurricane	9/1/2021	23	4,416	192
Hurricane	9/1/2021	77	308	4
Hurricane	9/1/2021	3	723	241
Hurricane	9/1/2021	2	464	232
Hurricane	9/1/2021	1	207	207
Hurricane	9/1/2021	2	382	191
Hurricane	9/1/2021	1	20	20
Hurricane	9/1/2021	1	57	57
Hurricane	9/1/2021	4	272	68
Hurricane	9/1/2021	7	371	53
Hurricane	9/1/2021	16	1,696	106
Hurricane	9/1/2021	9	1,620	180
Hurricane	9/1/2021	1	125	125
Hurricane	9/1/2021	1	288	288
Hurricane	9/1/2021	2	52	45
Hurricane	9/1/2021	7	189	27
Hurricane	9/1/2021	23	2,852	124
Hurricane	9/1/2021	37	111	3
Hurricane	9/1/2021	24	4,176	174
Hurricane	9/1/2021	3	342	114
Hurricane	9/1/2021	118	9,322	79
Hurricane	9/1/2021	39	3,159	81
Hurricane	9/1/2021	9	459	51
Hurricane	9/1/2021	1	261	261
Hurricane	9/1/2021	31	2,232	72
Hurricane	9/1/2021	66	11,154	169
Hurricane	9/1/2021	1	182	182
Hurricane	9/1/2021	1	280	280
Hurricane	9/1/2021	64	10,304	161
Hurricane	9/1/2021	23	2,070	90
Hurricane	9/1/2021	1	174	174
Hurricane	9/1/2021	6	1,206	201
Hurricane	9/1/2021	8	1,712	214
Hurricane	9/1/2021	109	10,028	92
Hurricane	9/1/2021	8	2,120	265
Hurricane	9/1/2021	7	1,169	167

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	1	55	55
Hurricane	9/1/2021	3	282	94
Hurricane	9/1/2021	7	35	5
Hurricane	9/1/2021	6	1,494	249
Hurricane	9/1/2021	1,309	66,778	543
Hurricane	9/1/2021	9	1,971	219
Hurricane	9/1/2021	3	141	47
Hurricane	9/1/2021	1	133	133
Hurricane	9/1/2021	10	60	6
Hurricane	9/1/2021	2	168	84
Hurricane	9/1/2021	1	250	250
Hurricane	9/1/2021	1	204	204
Hurricane	9/1/2021	8	304	38
Hurricane	9/1/2021	2	276	138
Hurricane	9/1/2021	5	400	80
Hurricane	9/1/2021	6	666	111
Hurricane	9/1/2021	1	123	123
Hurricane	9/1/2021	1	237	237
Hurricane	9/1/2021	3	228	76
Hurricane	9/1/2021	1	235	235
Hurricane	9/1/2021	3	546	182
Hurricane	9/1/2021	18	1,296	72
Hurricane	9/1/2021	1	217	217
Hurricane	9/1/2021	1	172	172
Hurricane	9/1/2021	9	3,411	379
Hurricane	9/1/2021	37	20,017	541
Hurricane	9/1/2021	1	330	330
Hurricane	9/1/2021	2	196	98
Hurricane	9/1/2021	1	247	247
Hurricane	9/1/2021	5	1,425	285
Hurricane	9/1/2021	1	46	46
Hurricane	9/1/2021	2	534	267
Hurricane	9/1/2021	24	14,880	620
Hurricane	9/1/2021	43	3,010	70
Hurricane	9/1/2021	1	173	173
Hurricane	9/1/2021	10	350	35
Hurricane	9/1/2021	3	168	56
Hurricane	9/1/2021	41	3,936	96
Hurricane	9/1/2021	1	151	151
Hurricane	9/1/2021	1	55	55
Hurricane	9/1/2021	5	255	51
Hurricane	9/1/2021	1	140	140
Hurricane	9/1/2021	1	159	159

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	14	4,116	294
Hurricane	9/1/2021	1	255	255
Hurricane	9/1/2021	1	169	169
Hurricane	9/1/2021	13	1,716	132
Hurricane	9/1/2021	1	407	407
Hurricane	9/1/2021	11	1,540	140
Hurricane	9/1/2021	1	295	295
Hurricane	9/1/2021	3	327	109
Hurricane	9/1/2021	8	1,840	230
Hurricane	9/1/2021	6	1,890	315
Hurricane	9/1/2021	1	261	261
Hurricane	9/1/2021	1	171	171
Hurricane	9/1/2021	4	852	213
Hurricane	9/1/2021	1	77	77
Hurricane	9/1/2021	2	908	454
Hurricane	9/1/2021	9	1,827	203
Hurricane	9/1/2021	3	276	92
Hurricane	9/1/2021	3	276	92
Hurricane	9/1/2021	30	1,620	54
Hurricane	9/1/2021	5	750	150
Hurricane	9/1/2021	4	188	47
Hurricane	9/1/2021	489	26,192	56
Hurricane	9/1/2021	1	163	163
Hurricane	9/1/2021	19	2,869	151
Hurricane	9/1/2021	9	1,404	156
Hurricane	9/1/2021	4	256	64
Hurricane	9/1/2021	41	12,013	293
Hurricane	9/1/2021	7	1,533	219
Hurricane	9/1/2021	20	5,160	258
Hurricane	9/1/2021	1	197	197
Hurricane	9/1/2021	4	596	149
Hurricane	9/1/2021	49	19,306	394
Hurricane	9/1/2021	49	6,321	129
Hurricane	9/1/2021	4	896	224
Hurricane	9/1/2021	812	113,700	207
Hurricane	9/1/2021	6	1,626	271
Hurricane	9/1/2021	8	2,560	320
Hurricane	9/1/2021	10	2,860	286
Hurricane	9/1/2021	4	2,960	740
Hurricane	9/1/2021	1	192	192
Hurricane	9/1/2021	11	2,343	213
Hurricane	9/1/2021	19	6,859	361
Hurricane	9/1/2021	2	242	121

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	51	22,797	447
Hurricane	9/1/2021	2	78	39
Hurricane	9/1/2021	2	254	127
Hurricane	9/1/2021	8	104	13
Hurricane	9/1/2021	3	693	231
Hurricane	9/1/2021	4	560	140
Hurricane	9/1/2021	13	1,358	266
Hurricane	9/1/2021	47	2,961	63
Hurricane	9/1/2021	2	212	106
Hurricane	9/1/2021	4	784	196
Hurricane	9/1/2021	2	66	33
Hurricane	9/1/2021	1	33	33
Hurricane	9/1/2021	1	308	308
Hurricane	9/1/2021	1	28	28
Hurricane	9/1/2021	1	202	202
Hurricane	9/1/2021	9	1,323	147
Hurricane	9/1/2021	1	567	567
Hurricane	9/1/2021	1	15	15
Hurricane	9/1/2021	19	1,501	79
Hurricane	9/1/2021	2	340	170
Hurricane	9/1/2021	9	2,151	239
Hurricane	9/1/2021	4	892	223
Hurricane	9/1/2021	1	317	317
Hurricane	9/1/2021	15	120	8
Hurricane	9/1/2021	1	57	57
Hurricane	9/1/2021	4	1,956	489
Hurricane	9/1/2021	8	2,576	322
Hurricane	9/1/2021	2	118	59
Hurricane	9/1/2021	1	145	145
Hurricane	9/1/2021	2	126	63
Hurricane	9/1/2021	5	85	17
Hurricane	9/1/2021	1	157	157
Hurricane	9/1/2021	4	88	22
Hurricane	9/1/2021	3	54	18
Hurricane	9/1/2021	10	480	48
Hurricane	9/1/2021	2	68	34
Hurricane	9/1/2021	66	7,656	116
Hurricane	9/1/2021	6	456	76
Hurricane	9/1/2021	11	88	8
Hurricane	9/1/2021	7	210	30
Hurricane	9/1/2021	1	274	274
Hurricane	9/1/2021	1	377	377
Hurricane	9/1/2021	8	4,752	594

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/1/2021	1	51	51
Hurricane	9/1/2021	9	423	47
Hurricane	9/1/2021	1	124	124
Hurricane	9/1/2021	16	1,936	121
Hurricane	9/1/2021	3	168	56
Hurricane	9/1/2021	1	766	766
Hurricane	9/1/2021	80	37,336	572
Hurricane	9/1/2021	12	6,768	564
Hurricane	9/1/2021	87	29,841	343
Hurricane	9/1/2021	34	9,996	294
Hurricane	9/1/2021	15	1,590	106
Hurricane	9/1/2021	25	1,075	43
Hurricane	9/1/2021	2	48	24
Hurricane	9/1/2021	59	8,461	387
Hurricane	9/1/2021	48	4,446	298
Hurricane	9/1/2021	3	465	155
Hurricane	9/1/2021	4	312	78
Hurricane	9/1/2021	77	6,314	82
Hurricane	9/1/2021	3	1,248	416
Hurricane	9/1/2021	1	108	108
Hurricane	9/1/2021	5	1,430	286
Hurricane	9/1/2021	8	7,080	885
Hurricane	9/1/2021	3	576	192
Hurricane	9/1/2021	11	682	62
Hurricane	9/1/2021	1	194	194
Hurricane	9/1/2021	15	6,045	403
Hurricane	9/1/2021	1	191	191
Hurricane	9/1/2021	1,110	49,960	66
Hurricane	9/1/2021	10	300	30
Hurricane	9/1/2021	1	41	41
Hurricane	9/1/2021	26	4,828	203
Hurricane	9/1/2021	8	864	108
Hurricane	9/1/2021	3	1,893	631
Hurricane	9/2/2021	1	25	25
Hurricane	9/2/2021	4	1,176	294
Hurricane	9/2/2021	1	156	156
Hurricane	9/2/2021	1	451	451
Hurricane	9/2/2021	18	3,150	175
Hurricane	9/2/2021	1	47	47
Hurricane	9/2/2021	2	128	64
Hurricane	9/2/2021	1	27	27
Hurricane	9/2/2021	1	416	416
Hurricane	9/2/2021	3	705	235

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	2	702	351
Hurricane	9/2/2021	9	882	98
Hurricane	9/2/2021	5	2,460	492
Hurricane	9/2/2021	69	8,211	119
Hurricane	9/2/2021	1	476	476
Hurricane	9/2/2021	20	1,940	97
Hurricane	9/2/2021	50	5,467	116
Hurricane	9/2/2021	1	330	330
Hurricane	9/2/2021	38	7,494	447
Hurricane	9/2/2021	4	1,292	323
Hurricane	9/2/2021	1	208	208
Hurricane	9/2/2021	29	8,555	295
Hurricane	9/2/2021	2	700	350
Hurricane	9/2/2021	1	331	331
Hurricane	9/2/2021	4	1,228	307
Hurricane	9/2/2021	10	710	71
Hurricane	9/2/2021	3	891	297
Hurricane	9/2/2021	1	5	5
Hurricane	9/2/2021	2	472	236
Hurricane	9/2/2021	1	441	441
Hurricane	9/2/2021	1	169	169
Hurricane	9/2/2021	4	672	168
Hurricane	9/2/2021	46	7,682	167
Hurricane	9/2/2021	14	6,132	438
Hurricane	9/2/2021	5	275	55
Hurricane	9/2/2021	14	3,710	265
Hurricane	9/2/2021	16	6,832	427
Hurricane	9/2/2021	1	35	35
Hurricane	9/2/2021	42	2,310	55
Hurricane	9/2/2021	1	318	318
Hurricane	9/2/2021	1	216	216
Hurricane	9/2/2021	2	1,014	507
Hurricane	9/2/2021	35	9,240	264
Hurricane	9/2/2021	3	186	62
Hurricane	9/2/2021	1	291	291
Hurricane	9/2/2021	1	210	210
Hurricane	9/2/2021	1	359	359
Hurricane	9/2/2021	1	341	341
Hurricane	9/2/2021	1	417	417
Hurricane	9/2/2021	2	228	114
Hurricane	9/2/2021	89	25,276	284
Hurricane	9/2/2021	1	43	43
Hurricane	9/2/2021	130	6,630	51

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	1	55	55
Hurricane	9/2/2021	12	1,488	124
Hurricane	9/2/2021	1	2	2
Hurricane	9/2/2021	2	488	244
Hurricane	9/2/2021	1	183	183
Hurricane	9/2/2021	4	1,068	267
Hurricane	9/2/2021	2	288	144
Hurricane	9/2/2021	8	456	57
Hurricane	9/2/2021	1	300	300
Hurricane	9/2/2021	3	163	69
Hurricane	9/2/2021	6	486	81
Hurricane	9/2/2021	5	580	116
Hurricane	9/2/2021	1	305	305
Hurricane	9/2/2021	1	393	393
Hurricane	9/2/2021	37	34,891	943
Hurricane	9/2/2021	4	632	158
Hurricane	9/2/2021	86	15,136	176
Hurricane	9/2/2021	1	234	234
Hurricane	9/2/2021	1	213	213
Hurricane	9/2/2021	5	680	136
Hurricane	9/2/2021	2	32	16
Hurricane	9/2/2021	1	503	503
Hurricane	9/2/2021	5	140	28
Hurricane	9/2/2021	1	131	131
Hurricane	9/2/2021	1	135	135
Hurricane	9/2/2021	2	150	75
Hurricane	9/2/2021	7	1,148	164
Hurricane	9/2/2021	4	680	170
Hurricane	9/2/2021	11	880	80
Hurricane	9/2/2021	3	264	88
Hurricane	9/2/2021	3	192	64
Hurricane	9/2/2021	1	264	264
Hurricane	9/2/2021	2	196	98
Hurricane	9/2/2021	1	101	101
Hurricane	9/2/2021	3	537	179
Hurricane	9/2/2021	1	82	82
Hurricane	9/2/2021	13	689	53
Hurricane	9/2/2021	4	1,204	301
Hurricane	9/2/2021	1	10	10
Hurricane	9/2/2021	5	500	100
Hurricane	9/2/2021	1	17	17
Hurricane	9/2/2021	29	9,599	331
Hurricane	9/2/2021	10	1,250	125

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	1	26	26
Hurricane	9/2/2021	1	113	113
Hurricane	9/2/2021	6	336	56
Hurricane	9/2/2021	1	304	304
Hurricane	9/2/2021	2	496	248
Hurricane	9/2/2021	12	336	28
Hurricane	9/2/2021	3	276	92
Hurricane	9/2/2021	5	145	29
Hurricane	9/2/2021	18	3,096	172
Hurricane	9/2/2021	1	84	84
Hurricane	9/2/2021	1	149	149
Hurricane	9/2/2021	1	185	185
Hurricane	9/2/2021	1	366	366
Hurricane	9/2/2021	8	112	14
Hurricane	9/2/2021	1	354	354
Hurricane	9/2/2021	1	438	438
Hurricane	9/2/2021	1	180	180
Hurricane	9/2/2021	83	41,666	502
Hurricane	9/2/2021	10	460	46
Hurricane	9/2/2021	2	18	9
Hurricane	9/2/2021	1	93	93
Hurricane	9/2/2021	27	5,454	202
Hurricane	9/2/2021	2	284	142
Hurricane	9/2/2021	1	5	5
Hurricane	9/2/2021	2	458	229
Hurricane	9/2/2021	50	1,850	37
Hurricane	9/2/2021	4	64	16
Hurricane	9/2/2021	1	11	11
Hurricane	9/2/2021	7	623	89
Hurricane	9/2/2021	20	8,160	408
Hurricane	9/2/2021	9	3,897	433
Hurricane	9/2/2021	2	40	20
Hurricane	9/2/2021	1	18	18
Hurricane	9/2/2021	1	196	196
Hurricane	9/2/2021	4	252	63
Hurricane	9/2/2021	2	66	33
Hurricane	9/2/2021	45	5,535	123
Hurricane	9/2/2021	1	522	522
Hurricane	9/2/2021	1	112	112
Hurricane	9/2/2021	1	382	382
Hurricane	9/2/2021	7	434	62
Hurricane	9/2/2021	10	110	11
Hurricane	9/2/2021	17	3,927	231

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	13	6,032	464
Hurricane	9/2/2021	10	190	19
Hurricane	9/2/2021	1	22	22
Hurricane	9/2/2021	1	56	56
Hurricane	9/2/2021	1	330	330
Hurricane	9/2/2021	1	118	118
Hurricane	9/2/2021	1	17	17
Hurricane	9/2/2021	5	225	45
Hurricane	9/2/2021	1	31	31
Hurricane	9/2/2021	2	270	135
Hurricane	9/2/2021	1	61	61
Hurricane	9/2/2021	1	361	361
Hurricane	9/2/2021	1	209	209
Hurricane	9/2/2021	3	138	46
Hurricane	9/2/2021	5	770	154
Hurricane	9/2/2021	5	250	50
Hurricane	9/2/2021	1	439	439
Hurricane	9/2/2021	1	145	145
Hurricane	9/2/2021	1	441	441
Hurricane	9/2/2021	17	221	13
Hurricane	9/2/2021	1	199	199
Hurricane	9/2/2021	5	550	110
Hurricane	9/2/2021	7	161	23
Hurricane	9/2/2021	1	132	132
Hurricane	9/2/2021	2	92	46
Hurricane	9/2/2021	1	89	89
Hurricane	9/2/2021	5	705	141
Hurricane	9/2/2021	5	1,665	333
Hurricane	9/2/2021	4	500	125
Hurricane	9/2/2021	25	1,275	51
Hurricane	9/2/2021	2	28	14
Hurricane	9/2/2021	1	311	311
Hurricane	9/2/2021	1	165	165
Hurricane	9/2/2021	2	112	56
Hurricane	9/2/2021	9	585	65
Hurricane	9/2/2021	10	640	64
Hurricane	9/2/2021	10	780	78
Hurricane	9/2/2021	1	136	136
Hurricane	9/2/2021	1	14	14
Hurricane	9/2/2021	13	1,963	151
Hurricane	9/2/2021	1	121	121
Hurricane	9/2/2021	6	864	144
Hurricane	9/2/2021	1	85	85

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	21	1,344	64
Hurricane	9/2/2021	2	212	106
Hurricane	9/2/2021	1	12	12
Hurricane	9/2/2021	1	19	19
Hurricane	9/2/2021	2	106	53
Hurricane	9/2/2021	6	318	53
Hurricane	9/2/2021	4	1,240	310
Hurricane	9/2/2021	7	2,310	330
Hurricane	9/2/2021	1	199	199
Hurricane	9/2/2021	4	432	108
Hurricane	9/2/2021	7	469	67
Hurricane	9/2/2021	1	58	58
Hurricane	9/2/2021	5	105	21
Hurricane	9/2/2021	1	238	238
Hurricane	9/2/2021	6	312	52
Hurricane	9/2/2021	3	93	31
Hurricane	9/2/2021	1	175	175
Hurricane	9/2/2021	1	180	180
Hurricane	9/2/2021	3	1,608	536
Hurricane	9/2/2021	4	1,900	475
Hurricane	9/2/2021	1	322	322
Hurricane	9/2/2021	1	191	191
Hurricane	9/2/2021	4	128	32
Hurricane	9/2/2021	1	567	567
Hurricane	9/2/2021	7	28	4
Hurricane	9/2/2021	6	1,086	181
Hurricane	9/2/2021	4	188	47
Hurricane	9/2/2021	6	1,548	258
Hurricane	9/2/2021	21	5,376	256
Hurricane	9/2/2021	1	59	59
Hurricane	9/2/2021	85	6,205	73
Hurricane	9/2/2021	1	452	452
Hurricane	9/2/2021	1	371	371
Hurricane	9/2/2021	1	33	33
Hurricane	9/2/2021	2	650	325
Hurricane	9/2/2021	10	2,490	249
Hurricane	9/2/2021	3	222	74
Hurricane	9/2/2021	1	247	247
Hurricane	9/2/2021	4	316	79
Hurricane	9/2/2021	3	33	11
Hurricane	9/2/2021	2	46	23
Hurricane	9/2/2021	7	133	19
Hurricane	9/2/2021	10	660	66

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	4	1,476	369
Hurricane	9/2/2021	1	111	111
Hurricane	9/2/2021	4	884	221
Hurricane	9/2/2021	11	132	12
Hurricane	9/2/2021	3	753	251
Hurricane	9/2/2021	3	366	122
Hurricane	9/2/2021	41	2,747	67
Hurricane	9/2/2021	4	920	230
Hurricane	9/2/2021	1	173	173
Hurricane	9/2/2021	1	245	245
Hurricane	9/2/2021	3	564	188
Hurricane	9/2/2021	1	289	289
Hurricane	9/2/2021	449	1,347	3
Hurricane	9/2/2021	1	626	626
Hurricane	9/2/2021	1	173	173
Hurricane	9/2/2021	1	217	217
Hurricane	9/2/2021	21	5,250	250
Hurricane	9/2/2021	5	370	74
Hurricane	9/2/2021	7	182	26
Hurricane	9/2/2021	378	7,014	63
Hurricane	9/2/2021	80	6,160	77
Hurricane	9/2/2021	10	2,240	224
Hurricane	9/2/2021	23	3,588	156
Hurricane	9/2/2021	2	312	156
Hurricane	9/2/2021	1	56	56
Hurricane	9/2/2021	380	38,380	101
Hurricane	9/2/2021	24	2,904	121
Hurricane	9/2/2021	5	135	27
Hurricane	9/2/2021	4	608	152
Hurricane	9/2/2021	23	2,737	119
Hurricane	9/2/2021	1	304	304
Hurricane	9/2/2021	28	252	9
Hurricane	9/2/2021	1	245	245
Hurricane	9/2/2021	3	237	79
Hurricane	9/2/2021	6	708	118
Hurricane	9/2/2021	1	112	112
Hurricane	9/2/2021	76	28,956	381
Hurricane	9/2/2021	18	3,852	214
Hurricane	9/2/2021	6	1,908	318
Hurricane	9/2/2021	17	5,559	327
Hurricane	9/2/2021	48	9,120	190
Hurricane	9/2/2021	61	14,507	310
Hurricane	9/2/2021	7	2,758	394

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	14	2,100	150
Hurricane	9/2/2021	28	9,380	335
Hurricane	9/2/2021	54	14,310	265
Hurricane	9/2/2021	3	204	68
Hurricane	9/2/2021	26	7,134	279
Hurricane	9/2/2021	25	6,175	247
Hurricane	9/2/2021	82	7,134	87
Hurricane	9/2/2021	1	389	389
Hurricane	9/2/2021	13	5,031	387
Hurricane	9/2/2021	91	14,287	157
Hurricane	9/2/2021	1	306	306
Hurricane	9/2/2021	22	3,234	147
Hurricane	9/2/2021	48	9,408	196
Hurricane	9/2/2021	22	1,518	69
Hurricane	9/2/2021	331	18,132	75
Hurricane	9/2/2021	2	1,148	574
Hurricane	9/2/2021	1	89	89
Hurricane	9/2/2021	1	65	65
Hurricane	9/2/2021	8	1,672	209
Hurricane	9/2/2021	42	16,506	393
Hurricane	9/2/2021	3	555	185
Hurricane	9/2/2021	1	92	92
Hurricane	9/2/2021	10	620	62
Hurricane	9/2/2021	78	10,530	135
Hurricane	9/2/2021	1	106	106
Hurricane	9/2/2021	9	1,971	219
Hurricane	9/2/2021	13	3,705	285
Hurricane	9/2/2021	2	390	195
Hurricane	9/2/2021	2	188	94
Hurricane	9/2/2021	84	10,416	124
Hurricane	9/2/2021	10	2,320	232
Hurricane	9/2/2021	1	117	117
Hurricane	9/2/2021	117	13,806	118
Hurricane	9/2/2021	29	3,306	114
Hurricane	9/2/2021	26	7,722	297
Hurricane	9/2/2021	15	1,260	84
Hurricane	9/2/2021	80	12,560	157
Hurricane	9/2/2021	1	280	280
Hurricane	9/2/2021	1	153	153
Hurricane	9/2/2021	737	68,506	146
Hurricane	9/2/2021	3	402	134
Hurricane	9/2/2021	1	289	289
Hurricane	9/2/2021	2	88	44

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	1	197	197
Hurricane	9/2/2021	43	2,967	69
Hurricane	9/2/2021	3	618	206
Hurricane	9/2/2021	1	242	242
Hurricane	9/2/2021	4	380	95
Hurricane	9/2/2021	22	3,190	145
Hurricane	9/2/2021	1,917	85,401	54
Hurricane	9/2/2021	1	276	276
Hurricane	9/2/2021	1	269	269
Hurricane	9/2/2021	1	176	176
Hurricane	9/2/2021	1	230	230
Hurricane	9/2/2021	6	414	69
Hurricane	9/2/2021	55	14,520	264
Hurricane	9/2/2021	5	155	31
Hurricane	9/2/2021	1	161	161
Hurricane	9/2/2021	48	6,000	125
Hurricane	9/2/2021	90	5,490	61
Hurricane	9/2/2021	3	660	220
Hurricane	9/2/2021	26	1,586	61
Hurricane	9/2/2021	8	1,296	162
Hurricane	9/2/2021	3	168	56
Hurricane	9/2/2021	3	3,360	1,120
Hurricane	9/2/2021	1	174	174
Hurricane	9/2/2021	3	213	71
Hurricane	9/2/2021	3	672	224
Hurricane	9/2/2021	1	240	240
Hurricane	9/2/2021	8	1,960	245
Hurricane	9/2/2021	7	217	31
Hurricane	9/2/2021	1	142	142
Hurricane	9/2/2021	14	4,102	293
Hurricane	9/2/2021	7	1,281	183
Hurricane	9/2/2021	9	2,124	236
Hurricane	9/2/2021	40	15,440	386
Hurricane	9/2/2021	2	100	50
Hurricane	9/2/2021	1	303	303
Hurricane	9/2/2021	1	83	83
Hurricane	9/2/2021	10	3,020	302
Hurricane	9/2/2021	8	432	54
Hurricane	9/2/2021	1	218	218
Hurricane	9/2/2021	2	312	156
Hurricane	9/2/2021	15	2,265	151
Hurricane	9/2/2021	9	630	70
Hurricane	9/2/2021	1	432	432

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	2	180	90
Hurricane	9/2/2021	2	98	49
Hurricane	9/2/2021	4	496	124
Hurricane	9/2/2021	1	245	245
Hurricane	9/2/2021	1	81	81
Hurricane	9/2/2021	1	166	166
Hurricane	9/2/2021	4	604	151
Hurricane	9/2/2021	1	60	60
Hurricane	9/2/2021	18	4,950	275
Hurricane	9/2/2021	111	7,992	72
Hurricane	9/2/2021	43	3,053	71
Hurricane	9/2/2021	5	250	50
Hurricane	9/2/2021	4	192	48
Hurricane	9/2/2021	2	314	157
Hurricane	9/2/2021	2	186	93
Hurricane	9/2/2021	35	9,275	265
Hurricane	9/2/2021	30	4,920	164
Hurricane	9/2/2021	3	471	157
Hurricane	9/2/2021	4	520	130
Hurricane	9/2/2021	1	259	259
Hurricane	9/2/2021	24	4,224	176
Hurricane	9/2/2021	12	2,508	209
Hurricane	9/2/2021	8	2,208	276
Hurricane	9/2/2021	6	630	105
Hurricane	9/2/2021	1	169	169
Hurricane	9/2/2021	1	102	102
Hurricane	9/2/2021	8	608	76
Hurricane	9/2/2021	9	1,332	148
Hurricane	9/2/2021	1	208	208
Hurricane	9/2/2021	64	5,376	84
Hurricane	9/2/2021	2	90	45
Hurricane	9/2/2021	35	6,405	183
Hurricane	9/2/2021	2	10	5
Hurricane	9/2/2021	21	4,578	218
Hurricane	9/2/2021	8	1,248	156
Hurricane	9/2/2021	1	17	17
Hurricane	9/2/2021	162	16,200	100
Hurricane	9/2/2021	1	1,029	1,029
Hurricane	9/2/2021	8	888	111
Hurricane	9/2/2021	1	68	68
Hurricane	9/2/2021	2	364	182
Hurricane	9/2/2021	1	68	68
Hurricane	9/2/2021	9	414	46

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	1	531	531
Hurricane	9/2/2021	12	4,620	385
Hurricane	9/2/2021	1	138	138
Hurricane	9/2/2021	1	850	850
Hurricane	9/2/2021	9	117	13
Hurricane	9/2/2021	3	1,824	608
Hurricane	9/2/2021	1	7	7
Hurricane	9/2/2021	28	4,256	152
Hurricane	9/2/2021	1	113	113
Hurricane	9/2/2021	10	2,310	231
Hurricane	9/2/2021	57	13,338	234
Hurricane	9/2/2021	32	3,200	100
Hurricane	9/2/2021	2	312	156
Hurricane	9/2/2021	24	2,928	122
Hurricane	9/2/2021	2	100	50
Hurricane	9/2/2021	1	53	53
Hurricane	9/2/2021	1	144	144
Hurricane	9/2/2021	46	2,530	55
Hurricane	9/2/2021	5	2,325	465
Hurricane	9/2/2021	3	789	263
Hurricane	9/2/2021	1	144	144
Hurricane	9/2/2021	7	1,071	153
Hurricane	9/2/2021	46	18,216	396
Hurricane	9/2/2021	4	1,464	366
Hurricane	9/2/2021	2	392	196
Hurricane	9/2/2021	5	620	124
Hurricane	9/2/2021	1,475	48,624	57
Hurricane	9/2/2021	1	166	166
Hurricane	9/2/2021	4	1,900	475
Hurricane	9/2/2021	1	812	812
Hurricane	9/2/2021	41	3,116	76
Hurricane	9/2/2021	9	5,193	577
Hurricane	9/2/2021	1	125	125
Hurricane	9/2/2021	55	5,500	100
Hurricane	9/2/2021	1,001	6,006	6
Hurricane	9/2/2021	23	1,012	44
Hurricane	9/2/2021	7	315	45
Hurricane	9/2/2021	1	256	256
Hurricane	9/2/2021	1	23	23
Hurricane	9/2/2021	1	1,443	1,443
Hurricane	9/2/2021	3	27	9
Hurricane	9/2/2021	5	550	110
Hurricane	9/2/2021	1	42	42

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Hurricane	9/2/2021	163	12,062	74
Hurricane	9/2/2021	4	1,240	310
Hurricane	9/2/2021	1	127	127
Hurricane	9/2/2021	1	77	77
Hurricane	9/2/2021	7	245	35
Hurricane	9/2/2021	3	756	252
Hurricane	9/2/2021	1	90	90
Hurricane	9/2/2021	18	1,872	104
Hurricane	9/2/2021	1	757	757
Hurricane	9/2/2021	9	90	10
Hurricane	9/2/2021	1	152	152
Hurricane	9/2/2021	1,328	64,355	64
Hurricane	9/2/2021	1	83	83
Hurricane	9/2/2021	12	780	65
Hurricane	9/2/2021	3	228	76
Hurricane	9/2/2021	48	10,176	212
Hurricane	9/2/2021	1	27	27
Hurricane	9/2/2021	1	720	720
Hurricane	9/2/2021	72	16,056	223
Hurricane	9/2/2021	1	47	47
Hurricane	9/2/2021	3	516	172
Hurricane	9/2/2021	1	409	409
Hurricane	9/2/2021	2	620	310
Hurricane	9/2/2021	1	398	398
Hurricane	9/2/2021	552	1,104	2
Hurricane	9/2/2021	9	4,203	467
Hurricane	9/2/2021	4	528	132
Hurricane	9/2/2021	1	162	162
Hurricane	9/2/2021	1	78	78
Hurricane	9/2/2021	1	297	297
Hurricane	9/2/2021	14	1,932	138
Hurricane	9/2/2021	2	174	87
Hurricane	9/2/2021	14	2,338	167
Hurricane	9/2/2021	1	293	293
Hurricane	9/2/2021	55	13,345	444
Tropical Storm	9/8/2021	2	144	72
Tropical Storm	9/8/2021	3	135	45
Tropical Storm	9/8/2021	15	795	53
Tropical Storm	9/8/2021	2	36	18
Tropical Storm	9/8/2021	3	318	106
Tropical Storm	9/8/2021	8	3,584	448
Tropical Storm	9/8/2021	3	120	40
Tropical Storm	9/8/2021	5	1,655	331

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/8/2021	1	295	295
Tropical Storm	9/8/2021	1	29	29
Tropical Storm	9/8/2021	1	106	106
Tropical Storm	9/8/2021	87	9,048	104
Tropical Storm	9/8/2021	50	3,250	65
Tropical Storm	9/8/2021	1	164	164
Tropical Storm	9/8/2021	1	16	16
Tropical Storm	9/8/2021	1	104	104
Tropical Storm	9/8/2021	43	2,838	66
Tropical Storm	9/8/2021	2	214	107
Tropical Storm	9/8/2021	2	32	16
Tropical Storm	9/8/2021	1	251	251
Tropical Storm	9/8/2021	1	61	61
Tropical Storm	9/8/2021	1	60	60
Tropical Storm	9/8/2021	1	176	176
Tropical Storm	9/8/2021	2	32	16
Tropical Storm	9/8/2021	2	76	38
Tropical Storm	9/8/2021	1	26	26
Tropical Storm	9/8/2021	2	330	165
Tropical Storm	9/8/2021	2	73	46
Tropical Storm	9/8/2021	1	89	89
Tropical Storm	9/8/2021	2	480	282
Tropical Storm	9/8/2021	11	1,463	133
Tropical Storm	9/8/2021	1	115	115
Tropical Storm	9/8/2021	5	316	95
Tropical Storm	9/8/2021	1	260	260
Tropical Storm	9/8/2021	2	376	188
Tropical Storm	9/8/2021	19	9,348	492
Tropical Storm	9/8/2021	2	130	65
Tropical Storm	9/8/2021	7	707	101
Tropical Storm	9/8/2021	1	232	232
Tropical Storm	9/8/2021	16	288	18
Tropical Storm	9/8/2021	7	602	86
Tropical Storm	9/8/2021	4	964	241
Tropical Storm	9/8/2021	1	340	340
Tropical Storm	9/8/2021	3	240	80
Tropical Storm	9/8/2021	5	250	50
Tropical Storm	9/8/2021	1	84	84
Tropical Storm	9/8/2021	1	31	31
Tropical Storm	9/8/2021	11	110	10
Tropical Storm	9/8/2021	1	379	379
Tropical Storm	9/8/2021	34	4,420	130
Tropical Storm	9/8/2021	4	264	66

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/8/2021	2	112	65
Tropical Storm	9/8/2021	1	278	278
Tropical Storm	9/8/2021	10	2,360	236
Tropical Storm	9/8/2021	1	34	34
Tropical Storm	9/8/2021	2	268	134
Tropical Storm	9/8/2021	4	640	160
Tropical Storm	9/8/2021	2	30	15
Tropical Storm	9/8/2021	7	210	30
Tropical Storm	9/8/2021	9	315	35
Tropical Storm	9/8/2021	1	58	58
Tropical Storm	9/8/2021	10	1,280	128
Tropical Storm	9/8/2021	40	4,760	119
Tropical Storm	9/8/2021	5	315	63
Tropical Storm	9/8/2021	4	912	228
Tropical Storm	9/8/2021	5	1,090	218
Tropical Storm	9/8/2021	1	68	68
Tropical Storm	9/8/2021	1	204	204
Tropical Storm	9/8/2021	2	168	84
Tropical Storm	9/8/2021	1	66	66
Tropical Storm	9/8/2021	8	208	26
Tropical Storm	9/8/2021	1	36	36
Tropical Storm	9/8/2021	2	22	11
Tropical Storm	9/8/2021	1	136	136
Tropical Storm	9/8/2021	12	672	56
Tropical Storm	9/8/2021	2	170	85
Tropical Storm	9/8/2021	1	161	161
Tropical Storm	9/8/2021	3	54	18
Tropical Storm	9/8/2021	1	47	47
Tropical Storm	9/8/2021	4	148	37
Tropical Storm	9/8/2021	16	80	5
Tropical Storm	9/8/2021	5	275	55
Tropical Storm	9/8/2021	1	11	11
Tropical Storm	9/8/2021	1	90	90
Tropical Storm	9/8/2021	8	2,000	250
Tropical Storm	9/8/2021	1	46	46
Tropical Storm	9/8/2021	2	20	10
Tropical Storm	9/8/2021	2	46	23
Tropical Storm	9/8/2021	1	369	369
Tropical Storm	9/8/2021	8	208	26
Tropical Storm	9/8/2021	2	292	146
Tropical Storm	9/8/2021	7	77	11
Tropical Storm	9/8/2021	1	214	214
Tropical Storm	9/8/2021	3	6	2

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/8/2021	13	481	37
Tropical Storm	9/8/2021	1	108	108
Tropical Storm	9/8/2021	1	35	35
Tropical Storm	9/8/2021	2	36	18
Tropical Storm	9/8/2021	34	11,191	480
Tropical Storm	9/8/2021	1	163	163
Tropical Storm	9/8/2021	2	182	91
Tropical Storm	9/8/2021	1	201	201
Tropical Storm	9/8/2021	3	294	98
Tropical Storm	9/8/2021	3	21	7
Tropical Storm	9/8/2021	9	81	9
Tropical Storm	9/8/2021	1	12	12
Tropical Storm	9/8/2021	1	39	39
Tropical Storm	9/8/2021	3	267	89
Tropical Storm	9/8/2021	1	48	48
Tropical Storm	9/8/2021	3,003	43,249	33
Tropical Storm	9/8/2021	1	133	133
Tropical Storm	9/8/2021	7	70	10
Tropical Storm	9/8/2021	4	296	74
Tropical Storm	9/8/2021	42	2,898	69
Tropical Storm	9/8/2021	1	284	284
Tropical Storm	9/8/2021	1	73	73
Tropical Storm	9/8/2021	55	2,805	51
Tropical Storm	9/8/2021	3	342	114
Tropical Storm	9/8/2021	2	51	39
Tropical Storm	9/8/2021	1	68	68
Tropical Storm	9/8/2021	25	925	37
Tropical Storm	9/8/2021	2	286	143
Tropical Storm	9/8/2021	1	76	76
Tropical Storm	9/8/2021	1	215	215
Tropical Storm	9/8/2021	1	37	37
Tropical Storm	9/8/2021	54	3,942	73
Tropical Storm	9/8/2021	5	195	39
Tropical Storm	9/8/2021	1	48	48
Tropical Storm	9/8/2021	1	411	411
Tropical Storm	9/8/2021	67	8,120	140
Tropical Storm	9/8/2021	2	187	97
Tropical Storm	9/8/2021	1	128	128
Tropical Storm	9/8/2021	1	124	124
Tropical Storm	9/8/2021	1	71	71
Tropical Storm	9/8/2021	25	2,280	339
Tropical Storm	9/8/2021	3	1,920	640
Tropical Storm	9/8/2021	1	94	94

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/8/2021	26	3,326	191
Tropical Storm	9/8/2021	8	328	41
Tropical Storm	9/8/2021	33	6,402	194
Tropical Storm	9/8/2021	22	3,168	144
Tropical Storm	9/8/2021	38	7,700	356
Tropical Storm	9/8/2021	2	46	23
Tropical Storm	9/8/2021	1	278	278
Tropical Storm	9/8/2021	211	33,549	159
Tropical Storm	9/8/2021	1	134	134
Tropical Storm	9/8/2021	426	20,874	49
Tropical Storm	9/8/2021	26	3,903	390
Tropical Storm	9/8/2021	4	536	134
Tropical Storm	9/8/2021	2,377	11,885	5
Tropical Storm	9/8/2021	2	430	215
Tropical Storm	9/8/2021	2	70	35
Tropical Storm	9/8/2021	2	370	185
Tropical Storm	9/8/2021	15	1,395	93
Tropical Storm	9/8/2021	40	7,080	177
Tropical Storm	9/8/2021	2	720	360
Tropical Storm	9/8/2021	1	282	282
Tropical Storm	9/8/2021	6	1,074	179
Tropical Storm	9/8/2021	3	456	152
Tropical Storm	9/8/2021	3	117	39
Tropical Storm	9/8/2021	3	303	101
Tropical Storm	9/8/2021	2	986	493
Tropical Storm	9/8/2021	2	140	70
Tropical Storm	9/8/2021	1	148	148
Tropical Storm	9/8/2021	11	583	53
Tropical Storm	9/8/2021	8	384	48
Tropical Storm	9/8/2021	19	209	11
Tropical Storm	9/8/2021	6	750	125
Tropical Storm	9/8/2021	44	12,144	276
Tropical Storm	9/8/2021	10	300	30
Tropical Storm	9/8/2021	5	400	80
Tropical Storm	9/8/2021	5	2,180	436
Tropical Storm	9/8/2021	5	370	74
Tropical Storm	9/8/2021	33	2,593	181
Tropical Storm	9/8/2021	11	1,210	110
Tropical Storm	9/8/2021	38	9,538	251
Tropical Storm	9/8/2021	1	50	50
Tropical Storm	9/8/2021	10	170	17
Tropical Storm	9/8/2021	31	6,696	216
Tropical Storm	9/8/2021	12	1,188	99

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/8/2021	1	92	92
Tropical Storm	9/8/2021	23	2,116	92
Tropical Storm	9/8/2021	22	1,474	67
Tropical Storm	9/8/2021	3	240	80
Tropical Storm	9/8/2021	4	240	60
Tropical Storm	9/8/2021	1	342	342
Tropical Storm	9/8/2021	6	504	84
Tropical Storm	9/8/2021	12	744	62
Tropical Storm	9/8/2021	46	3,022	94
Tropical Storm	9/8/2021	5	940	188
Tropical Storm	9/8/2021	10	2,270	227
Tropical Storm	9/8/2021	1	304	304
Tropical Storm	9/8/2021	39	4,719	121
Tropical Storm	9/8/2021	1	360	360
Tropical Storm	9/8/2021	1	218	218
Tropical Storm	9/8/2021	4	144	36
Tropical Storm	9/8/2021	45	5,535	123
Tropical Storm	9/8/2021	21	1,281	61
Tropical Storm	9/8/2021	65	5,460	84
Tropical Storm	9/8/2021	1	127	127
Tropical Storm	9/8/2021	1	72	72
Tropical Storm	9/8/2021	4	496	124
Tropical Storm	9/8/2021	833	34,876	62
Tropical Storm	9/8/2021	2	186	93
Tropical Storm	9/8/2021	9	1,647	183
Tropical Storm	9/8/2021	7	616	88
Tropical Storm	9/8/2021	1	149	149
Tropical Storm	9/8/2021	1	65	65
Tropical Storm	9/8/2021	3	210	70
Tropical Storm	9/8/2021	1	276	276
Tropical Storm	9/8/2021	3	1,449	483
Tropical Storm	9/8/2021	3	1,002	335
Tropical Storm	9/8/2021	1	22	22
Tropical Storm	9/8/2021	49	10,633	217
Tropical Storm	9/8/2021	20	2,680	134
Tropical Storm	9/8/2021	37	7,268	204
Tropical Storm	9/8/2021	1	46	46
Tropical Storm	9/8/2021	1	613	613
Tropical Storm	9/8/2021	8	1,544	193
Tropical Storm	9/8/2021	2	250	125
Tropical Storm	9/9/2021	18	2,484	138
Tropical Storm	9/9/2021	15	7,464	824
Tropical Storm	9/9/2021	4	256	64

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	1	165	165
Tropical Storm	9/9/2021	18	3,762	209
Tropical Storm	9/9/2021	3	138	46
Tropical Storm	9/9/2021	5	315	63
Tropical Storm	9/9/2021	1	127	127
Tropical Storm	9/9/2021	16	3,476	224
Tropical Storm	9/9/2021	3	1,152	384
Tropical Storm	9/9/2021	4	288	72
Tropical Storm	9/9/2021	3	357	119
Tropical Storm	9/9/2021	20	2,100	105
Tropical Storm	9/9/2021	1	99	99
Tropical Storm	9/9/2021	1	114	114
Tropical Storm	9/9/2021	25	3,403	300
Tropical Storm	9/9/2021	2	358	179
Tropical Storm	9/9/2021	47	2,256	48
Tropical Storm	9/9/2021	4	620	155
Tropical Storm	9/9/2021	24	2,232	93
Tropical Storm	9/9/2021	6	858	143
Tropical Storm	9/9/2021	1	84	84
Tropical Storm	9/9/2021	1	122	122
Tropical Storm	9/9/2021	1	128	128
Tropical Storm	9/9/2021	3	180	60
Tropical Storm	9/9/2021	1	108	108
Tropical Storm	9/9/2021	8	432	54
Tropical Storm	9/9/2021	1	25	25
Tropical Storm	9/9/2021	2	180	90
Tropical Storm	9/9/2021	1	77	77
Tropical Storm	9/9/2021	1	290	290
Tropical Storm	9/9/2021	1	525	525
Tropical Storm	9/9/2021	7	1,176	168
Tropical Storm	9/9/2021	6	312	52
Tropical Storm	9/9/2021	1	231	231
Tropical Storm	9/9/2021	4	212	53
Tropical Storm	9/9/2021	1	258	258
Tropical Storm	9/9/2021	5	210	42
Tropical Storm	9/9/2021	1	100	100
Tropical Storm	9/9/2021	1	420	420
Tropical Storm	9/9/2021	1	118	118
Tropical Storm	9/9/2021	1	67	67
Tropical Storm	9/9/2021	1	101	101
Tropical Storm	9/9/2021	1	304	304
Tropical Storm	9/9/2021	2	146	73
Tropical Storm	9/9/2021	1	428	428

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	6	684	114
Tropical Storm	9/9/2021	3	144	48
Tropical Storm	9/9/2021	2	188	94
Tropical Storm	9/9/2021	1	106	106
Tropical Storm	9/9/2021	2	536	268
Tropical Storm	9/9/2021	17	1,479	87
Tropical Storm	9/9/2021	1	55	55
Tropical Storm	9/9/2021	1	201	201
Tropical Storm	9/9/2021	23	4,140	180
Tropical Storm	9/9/2021	9	45	5
Tropical Storm	9/9/2021	1	95	95
Tropical Storm	9/9/2021	2	128	64
Tropical Storm	9/9/2021	6	456	76
Tropical Storm	9/9/2021	4	136	34
Tropical Storm	9/9/2021	1	9	9
Tropical Storm	9/9/2021	4	448	112
Tropical Storm	9/9/2021	1	169	169
Tropical Storm	9/9/2021	8	96	12
Tropical Storm	9/9/2021	1	35	35
Tropical Storm	9/9/2021	1	198	198
Tropical Storm	9/9/2021	1	45	45
Tropical Storm	9/9/2021	4	52	13
Tropical Storm	9/9/2021	20	1,820	91
Tropical Storm	9/9/2021	2	179	130
Tropical Storm	9/9/2021	3	99	33
Tropical Storm	9/9/2021	10	140	14
Tropical Storm	9/9/2021	6	84	14
Tropical Storm	9/9/2021	10	1,410	141
Tropical Storm	9/9/2021	1	97	97
Tropical Storm	9/9/2021	11	88	8
Tropical Storm	9/9/2021	2	174	101
Tropical Storm	9/9/2021	3	150	50
Tropical Storm	9/9/2021	1	226	226
Tropical Storm	9/9/2021	1	236	236
Tropical Storm	9/9/2021	1	130	130
Tropical Storm	9/9/2021	10	1,180	118
Tropical Storm	9/9/2021	1	24	24
Tropical Storm	9/9/2021	7	693	99
Tropical Storm	9/9/2021	5	95	19
Tropical Storm	9/9/2021	2	176	88
Tropical Storm	9/9/2021	26	9,750	375
Tropical Storm	9/9/2021	5	355	71
Tropical Storm	9/9/2021	6	762	127

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	12	1,284	108
Tropical Storm	9/9/2021	4	308	77
Tropical Storm	9/9/2021	3	189	63
Tropical Storm	9/9/2021	8	3,648	456
Tropical Storm	9/9/2021	6	1,233	336
Tropical Storm	9/9/2021	5	255	51
Tropical Storm	9/9/2021	1,488	1,488	1
Tropical Storm	9/9/2021	9	468	52
Tropical Storm	9/9/2021	1	170	170
Tropical Storm	9/9/2021	1	313	313
Tropical Storm	9/9/2021	9	936	104
Tropical Storm	9/9/2021	2	562	281
Tropical Storm	9/9/2021	84	26,880	320
Tropical Storm	9/9/2021	6	294	49
Tropical Storm	9/9/2021	3	372	124
Tropical Storm	9/9/2021	7	532	76
Tropical Storm	9/9/2021	1	219	219
Tropical Storm	9/9/2021	1	308	308
Tropical Storm	9/9/2021	548	7,672	14
Tropical Storm	9/9/2021	1	175	175
Tropical Storm	9/9/2021	1	143	143
Tropical Storm	9/9/2021	2	616	308
Tropical Storm	9/9/2021	1	458	458
Tropical Storm	9/9/2021	6	12	2
Tropical Storm	9/9/2021	1	284	284
Tropical Storm	9/9/2021	4	556	139
Tropical Storm	9/9/2021	7	546	78
Tropical Storm	9/9/2021	1	73	73
Tropical Storm	9/9/2021	8	32	4
Tropical Storm	9/9/2021	3	306	102
Tropical Storm	9/9/2021	71	8,946	126
Tropical Storm	9/9/2021	33	2,310	70
Tropical Storm	9/9/2021	18	3,960	220
Tropical Storm	9/9/2021	1	147	147
Tropical Storm	9/9/2021	7	1,036	148
Tropical Storm	9/9/2021	11	610	62
Tropical Storm	9/9/2021	3	111	37
Tropical Storm	9/9/2021	10	1,280	128
Tropical Storm	9/9/2021	6	372	62
Tropical Storm	9/9/2021	4	128	32
Tropical Storm	9/9/2021	23	1,104	48
Tropical Storm	9/9/2021	6	24	4
Tropical Storm	9/9/2021	12	1,752	146

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	73	7,189	249
Tropical Storm	9/9/2021	6	1,050	175
Tropical Storm	9/9/2021	7	2,625	375
Tropical Storm	9/9/2021	7	2,030	290
Tropical Storm	9/9/2021	7	1,092	156
Tropical Storm	9/9/2021	1	317	317
Tropical Storm	9/9/2021	11	88	8
Tropical Storm	9/9/2021	13	2,821	217
Tropical Storm	9/9/2021	9	441	49
Tropical Storm	9/9/2021	1	160	160
Tropical Storm	9/9/2021	6	1,002	167
Tropical Storm	9/9/2021	1	347	347
Tropical Storm	9/9/2021	1	61	61
Tropical Storm	9/9/2021	6	1,860	310
Tropical Storm	9/9/2021	4	192	48
Tropical Storm	9/9/2021	5	605	121
Tropical Storm	9/9/2021	3	39	13
Tropical Storm	9/9/2021	10	3,060	306
Tropical Storm	9/9/2021	8	192	24
Tropical Storm	9/9/2021	1	52	52
Tropical Storm	9/9/2021	515	18,695	51
Tropical Storm	9/9/2021	1	240	240
Tropical Storm	9/9/2021	1	229	229
Tropical Storm	9/9/2021	2	384	192
Tropical Storm	9/9/2021	2	342	171
Tropical Storm	9/9/2021	1	107	107
Tropical Storm	9/9/2021	4	432	108
Tropical Storm	9/9/2021	1	40	40
Tropical Storm	9/9/2021	1	119	119
Tropical Storm	9/9/2021	1	68	68
Tropical Storm	9/9/2021	8	400	50
Tropical Storm	9/9/2021	1	71	71
Tropical Storm	9/9/2021	1	111	111
Tropical Storm	9/9/2021	9	1,838	310
Tropical Storm	9/9/2021	4	464	116
Tropical Storm	9/9/2021	6	1,536	256
Tropical Storm	9/9/2021	3	195	65
Tropical Storm	9/9/2021	1	451	451
Tropical Storm	9/9/2021	1	66	66
Tropical Storm	9/9/2021	1	79	79
Tropical Storm	9/9/2021	19	4,579	241
Tropical Storm	9/9/2021	8	920	115
Tropical Storm	9/9/2021	44	1,936	44

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	3	555	185
Tropical Storm	9/9/2021	8	872	109
Tropical Storm	9/9/2021	1	156	156
Tropical Storm	9/9/2021	3	702	234
Tropical Storm	9/9/2021	3	444	148
Tropical Storm	9/9/2021	12	2,964	247
Tropical Storm	9/9/2021	3	489	163
Tropical Storm	9/9/2021	2	332	166
Tropical Storm	9/9/2021	4	564	141
Tropical Storm	9/9/2021	2	248	124
Tropical Storm	9/9/2021	1	122	122
Tropical Storm	9/9/2021	8	688	86
Tropical Storm	9/9/2021	3	327	109
Tropical Storm	9/9/2021	7	1,351	193
Tropical Storm	9/9/2021	8	848	106
Tropical Storm	9/9/2021	48	11,232	234
Tropical Storm	9/9/2021	3	456	152
Tropical Storm	9/9/2021	2	252	126
Tropical Storm	9/9/2021	2	478	239
Tropical Storm	9/9/2021	1	241	241
Tropical Storm	9/9/2021	2	444	222
Tropical Storm	9/9/2021	5	1,010	202
Tropical Storm	9/9/2021	1	140	140
Tropical Storm	9/9/2021	907	4,535	5
Tropical Storm	9/9/2021	4	896	224
Tropical Storm	9/9/2021	2	256	128
Tropical Storm	9/9/2021	3	750	250
Tropical Storm	9/9/2021	1	112	112
Tropical Storm	9/9/2021	5	150	30
Tropical Storm	9/9/2021	7	1,918	274
Tropical Storm	9/9/2021	1	191	191
Tropical Storm	9/9/2021	5	970	194
Tropical Storm	9/9/2021	4	872	218
Tropical Storm	9/9/2021	4	320	80
Tropical Storm	9/9/2021	1	128	128
Tropical Storm	9/9/2021	2	210	105
Tropical Storm	9/9/2021	1	110	110
Tropical Storm	9/9/2021	1	157	157
Tropical Storm	9/9/2021	1	206	206
Tropical Storm	9/9/2021	49	5,275	179
Tropical Storm	9/9/2021	1	159	159
Tropical Storm	9/9/2021	4	204	51
Tropical Storm	9/9/2021	7	42	6

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tropical Storm	9/9/2021	1	155	155
Tropical Storm	9/9/2021	3	192	64
Tropical Storm	9/9/2021	2	194	97
Tropical Storm	9/9/2021	1	175	175
Tropical Storm	9/9/2021	7	1,449	207
Tropical Storm	9/9/2021	1	279	279
Tropical Storm	9/9/2021	1	223	223
Tropical Storm	9/9/2021	1	98	98
Tropical Storm	9/9/2021	2	248	124
Tropical Storm	9/9/2021	4	276	69
Tropical Storm	9/9/2021	22	6,424	292
Tropical Storm	9/9/2021	9	216	24
Tropical Storm	9/9/2021	8	1,008	126
Tropical Storm	9/9/2021	1	66	66
Tropical Storm	9/9/2021	1	112	112
Tropical Storm	9/9/2021	3	603	201
Tropical Storm	9/9/2021	1	420	420
Tropical Storm	9/9/2021	6	198	33
Tornado	10/28/2021	205	9,430	46
Tornado	10/28/2021	1	63	63
Tornado	10/28/2021	5	2,005	401
Tornado	10/28/2021	7	1,099	157
Tornado	10/28/2021	135	35,505	263
Tornado	10/28/2021	44	10,648	242
Tornado	10/28/2021	7	2,352	336
Tornado	10/28/2021	1	500	500
Tornado	10/28/2021	1	240	240
Tornado	10/28/2021	1	74	74
Tornado	10/28/2021	41	3,772	92
Tornado	10/28/2021	3	156	52
Tornado	10/28/2021	1	74	74
Tornado	10/28/2021	1	290	290
Tornado	10/28/2021	5	330	66
Tornado	10/28/2021	1	357	357
Tornado	10/28/2021	15	660	44
Tornado	10/28/2021	17	1,411	83
Tornado	10/28/2021	4	304	76
Tornado	10/28/2021	21	1,365	65
Tornado	10/28/2021	1	424	424
Tornado	10/28/2021	7	644	92
Tornado	10/28/2021	20	7,240	362
Tornado	10/28/2021	4	248	62
Tornado	10/28/2021	2	224	112

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	10/28/2021	4	68	17
Tornado	10/28/2021	3	393	131
Tornado	10/28/2021	1	119	119
Tornado	10/28/2021	9	2,646	294
Tornado	10/28/2021	3	201	67
Tornado	10/28/2021	6	348	58
Tornado	10/28/2021	1	193	193
Tornado	10/28/2021	1	93	93
Tornado	10/28/2021	1	98	98
Tornado	10/28/2021	1	231	231
Tornado	10/28/2021	6	720	120
Tornado	10/28/2021	43	4,386	102
Tornado	10/28/2021	1	13	13
Tornado	10/28/2021	8	3,120	390
Tornado	10/28/2021	6	450	75
Tornado	10/28/2021	9	720	80
Tornado	10/28/2021	1	257	257
Tornado	10/28/2021	1	24	24
Tornado	10/28/2021	1	22	22
Tornado	10/28/2021	10	3,830	383
Tornado	10/28/2021	1	10	10
Tornado	10/28/2021	5	175	35
Tornado	10/28/2021	1	217	217
Tornado	10/28/2021	1	102	102
Tornado	10/28/2021	5	125	25
Tornado	10/28/2021	1	10	10
Tornado	10/28/2021	3	117	39
Tornado	10/28/2021	3	162	54
Tornado	10/28/2021	129	6,966	54
Tornado	10/28/2021	1	232	232
Tornado	10/28/2021	1	33	33
Tornado	10/28/2021	2	564	282
Tornado	10/28/2021	2	16	8
Tornado	10/28/2021	1	222	222
Tornado	10/28/2021	11	616	56
Tornado	10/28/2021	1	13	13
Tornado	10/28/2021	8	992	124
Tornado	10/28/2021	14	602	43
Tornado	10/28/2021	88	3,608	41
Tornado	10/28/2021	1	91	91
Tornado	10/28/2021	8	304	38
Tornado	10/28/2021	1	13	13
Tornado	10/28/2021	7	2,093	299

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	10/28/2021	4	156	39
Tornado	10/28/2021	1	396	396
Tornado	10/28/2021	2,033	58,142	34
Tornado	10/28/2021	12	4,512	376
Tornado	10/28/2021	7	511	73
Tornado	10/28/2021	1	486	486
Tornado	10/28/2021	5	800	160
Tornado	10/28/2021	1	16	16
Tornado	10/28/2021	16	1,536	96
Tornado	10/28/2021	3	1,104	368
Tornado	10/28/2021	4	436	109
Tornado	10/28/2021	9	1,638	182
Tornado	10/28/2021	6	288	48
Tornado	10/28/2021	31	2,356	76
Tornado	10/28/2021	3	567	189
Tornado	10/28/2021	49	6,627	143
Tornado	10/28/2021	57	5,073	89
Tornado	10/28/2021	27	540	20
Tornado	10/28/2021	5	385	77
Tornado	10/28/2021	17	374	22
Tornado	10/28/2021	5	810	162
Tornado	10/28/2021	3	45	15
Tornado	10/28/2021	118	14,042	119
Tornado	10/28/2021	44	4,796	109
Tornado	10/28/2021	1	13	13
Tornado	10/28/2021	55	5,445	99
Tornado	10/28/2021	71	20,604	519
Tornado	10/28/2021	1	133	133
Tornado	10/28/2021	1	369	369
Tornado	10/28/2021	3	21	7
Tornado	10/28/2021	3	315	105
Tornado	10/28/2021	27	837	31
Tornado	10/28/2021	4	620	155
Tornado	10/28/2021	8	1,024	128
Tornado	10/28/2021	111	7,659	69
Tornado	10/28/2021	4	1,084	271
Tornado	10/28/2021	82	6,560	80
Tornado	10/28/2021	37	5,291	143
Tornado	10/28/2021	132	5,544	42
Tornado	10/28/2021	10	750	75
Tornado	10/28/2021	1	140	140
Tornado	10/28/2021	2	468	234
Tornado	10/28/2021	3	363	121

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	10/28/2021	5	1,380	276
Tornado	10/28/2021	811	22,624	104
Tornado	10/28/2021	129	13,278	142
Tornado	10/28/2021	1	62	62
Tornado	10/28/2021	2	530	265
Tornado	10/28/2021	4	48	12
Tornado	10/28/2021	65	3,055	47
Tornado	10/28/2021	4	832	208
Tornado	10/28/2021	2	304	152
Tornado	10/28/2021	1	237	237
Tornado	10/28/2021	1	169	169
Tornado	10/28/2021	3	321	107
Tornado	10/28/2021	1	139	139
Tornado	10/28/2021	1	41	41
Tornado	10/28/2021	99	15,840	160
Tornado	10/28/2021	7	1,085	155
Tornado	10/28/2021	16	2,488	232
Tornado	10/28/2021	132	12,144	92
Tornado	10/28/2021	29	3,915	135
Tornado	10/28/2021	5	555	111
Tornado	10/28/2021	1	354	354
Tornado	10/28/2021	201	31,009	319
Tornado	10/28/2021	2	132	66
Tornado	10/28/2021	7	637	91
Tornado	10/28/2021	1	115	115
Tornado	10/28/2021	6	3,156	526
Tornado	10/28/2021	1	107	107
Tornado	10/28/2021	6	168	28
Tornado	10/28/2021	2	286	143
Tornado	10/28/2021	2	110	55
Tornado	10/28/2021	5	800	160
Tornado	10/28/2021	1	353	353
Tornado	10/28/2021	2	486	243
Tornado	10/28/2021	3	492	164
Tornado	10/28/2021	1,772	90,501	274
Tornado	10/28/2021	7	1,539	517
Tornado	10/28/2021	4	572	143
Tornado	10/28/2021	43	43	1
Tornado	10/28/2021	1	431	431
Tornado	10/28/2021	3	393	131
Tornado	10/28/2021	1	320	320
Tornado	10/28/2021	1	111	111
Tornado	10/28/2021	1	133	133

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	10/28/2021	11	484	44
Tornado	10/28/2021	27	4,805	239
Tornado	10/28/2021	2	228	114
Tornado	10/28/2021	7	756	108
Tornado	10/28/2021	3	363	121
Tornado	10/28/2021	2	168	84
Tornado	10/28/2021	1	138	138
Tornado	10/28/2021	4	740	185
Tornado	10/28/2021	2	128	64
Tornado	10/28/2021	2	334	167
Tornado	10/28/2021	9	414	46
Tornado	10/28/2021	1	180	180
Tornado	10/28/2021	1	351	351
Tornado	10/28/2021	33	2,079	63
Tornado	10/28/2021	23	1,288	56
Tornado	10/28/2021	1	345	345
Tornado	10/28/2021	4	852	213
Tornado	10/28/2021	6	348	58
Tornado	10/28/2021	1	255	255
Tornado	10/28/2021	2	304	152
Tornado	10/28/2021	5	965	193
Tornado	10/28/2021	123	12,300	100
Tornado	10/28/2021	9	5,211	579
Tornado	10/28/2021	2	148	74
Tornado	10/28/2021	1	106	106
Tornado	10/28/2021	1	32	32
Tornado	12/8/2021	4	228	57
Tornado	12/8/2021	3	195	65
Tornado	12/8/2021	1	47	47
Tornado	12/8/2021	37	481	13
Tornado	12/8/2021	11	957	87
Tornado	12/8/2021	1	172	172
Tornado	12/8/2021	1	96	96
Tornado	12/8/2021	2	224	112
Tornado	12/8/2021	6	1,422	237
Tornado	12/8/2021	8	872	109
Tornado	12/8/2021	1	282	282
Tornado	12/8/2021	1	56	56
Tornado	12/8/2021	17	561	33
Tornado	12/8/2021	9	1,431	159
Tornado	12/8/2021	6	60	10
Tornado	12/8/2021	1	73	73
Tornado	12/8/2021	424	424	1

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/8/2021	39	2,847	73
Tornado	12/8/2021	28	1,288	46
Tornado	12/8/2021	4	76	19
Tornado	12/8/2021	1	12	12
Tornado	12/8/2021	1	633	633
Tornado	12/8/2021	6	2,394	399
Tornado	12/8/2021	2	86	43
Tornado	12/21/2021	7	920	192
Tornado	12/21/2021	65	4,745	73
Tornado	12/21/2021	10	2,930	293
Tornado	12/21/2021	4	956	239
Tornado	12/21/2021	4	144	36
Tornado	12/21/2021	2	520	260
Tornado	12/21/2021	15	1,185	79
Tornado	12/21/2021	4	392	98
Tornado	12/21/2021	8	544	68
Tornado	12/21/2021	1	90	90
Tornado	12/21/2021	1	3	3
Tornado	12/21/2021	6	534	89
Tornado	12/21/2021	112	21,156	374
Tornado	12/21/2021	23	4,209	183
Tornado	12/21/2021	1	111	111
Tornado	12/21/2021	2	396	198
Tornado	12/21/2021	17	1,938	114
Tornado	12/21/2021	1	369	369
Tornado	12/21/2021	276	29,834	152
Tornado	12/21/2021	34	7,378	217
Tornado	12/21/2021	4	100	25
Tornado	12/21/2021	1	76	76
Tornado	12/21/2021	3	564	188
Tornado	12/21/2021	6	1,824	304
Tornado	12/21/2021	1	336	336
Tornado	12/21/2021	6	1,596	266
Tornado	12/21/2021	3	222	74
Tornado	12/21/2021	2	64	32
Tornado	12/21/2021	4	384	96
Tornado	12/21/2021	4	1,308	327
Tornado	12/21/2021	1	343	343
Tornado	12/21/2021	7	1,239	177
Tornado	12/21/2021	58	4,698	81
Tornado	12/21/2021	1	47	47
Tornado	12/21/2021	1	1,000	1,000
Tornado	12/21/2021	3	348	116

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	106	11,978	113
Tornado	12/21/2021	114	114	1
Tornado	12/21/2021	7	6,692	956
Tornado	12/21/2021	2	172	86
Tornado	12/21/2021	13	3,166	592
Tornado	12/21/2021	114	12,988	670
Tornado	12/21/2021	467	255,916	548
Tornado	12/21/2021	30	9,090	303
Tornado	12/21/2021	46	61,640	1,340
Tornado	12/21/2021	1	316	316
Tornado	12/21/2021	14	7,378	527
Tornado	12/21/2021	4	780	195
Tornado	12/21/2021	3	591	197
Tornado	12/21/2021	127	12,192	96
Tornado	12/21/2021	1	258	258
Tornado	12/21/2021	1	135	135
Tornado	12/21/2021	5	2,295	459
Tornado	12/21/2021	4	284	71
Tornado	12/21/2021	1	261	261
Tornado	12/21/2021	1	292	292
Tornado	12/21/2021	1	365	365
Tornado	12/21/2021	1	138	138
Tornado	12/21/2021	150	18,450	123
Tornado	12/21/2021	151	4,983	33
Tornado	12/21/2021	1	102	102
Tornado	12/21/2021	26	17,290	665
Tornado	12/21/2021	103	52,736	512
Tornado	12/21/2021	2	200	100
Tornado	12/21/2021	107	48,257	451
Tornado	12/21/2021	2	418	209
Tornado	12/21/2021	14	2,604	186
Tornado	12/21/2021	2	308	154
Tornado	12/21/2021	122	36,112	296
Tornado	12/21/2021	323	39,246	201
Tornado	12/21/2021	92	34,776	378
Tornado	12/21/2021	4	1,752	438
Tornado	12/21/2021	11	4,818	438
Tornado	12/21/2021	11	4,752	432
Tornado	12/21/2021	1	431	431
Tornado	12/21/2021	4	544	136
Tornado	12/21/2021	1	197	197
Tornado	12/21/2021	153	14,382	94
Tornado	12/21/2021	8	3,120	390

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	238	39,508	166
Tornado	12/21/2021	84	31,332	373
Tornado	12/21/2021	2	258	129
Tornado	12/21/2021	1	456	456
Tornado	12/21/2021	3	369	123
Tornado	12/21/2021	40	4,120	103
Tornado	12/21/2021	148	50,764	343
Tornado	12/21/2021	1	123	123
Tornado	12/21/2021	2	272	136
Tornado	12/21/2021	1	608	608
Tornado	12/21/2021	21	1,764	84
Tornado	12/21/2021	51	28,254	554
Tornado	12/21/2021	9	1,233	137
Tornado	12/21/2021	1	97	97
Tornado	12/21/2021	35	11,900	340
Tornado	12/21/2021	6	1,116	186
Tornado	12/21/2021	45	5,736	417
Tornado	12/21/2021	3	528	176
Tornado	12/21/2021	22	8,184	372
Tornado	12/21/2021	4	384	96
Tornado	12/21/2021	3	1,818	606
Tornado	12/21/2021	1	180	180
Tornado	12/21/2021	11	20,119	1,829
Tornado	12/21/2021	128	97,664	763
Tornado	12/21/2021	9	2,331	259
Tornado	12/21/2021	498	16,570	181
Tornado	12/21/2021	1	838	838
Tornado	12/21/2021	9	3,168	352
Tornado	12/21/2021	4	504	126
Tornado	12/21/2021	151	2,869	19
Tornado	12/21/2021	135	135	1
Tornado	12/21/2021	2	380	190
Tornado	12/21/2021	2	270	135
Tornado	12/21/2021	55	5,885	107
Tornado	12/21/2021	4	460	115
Tornado	12/21/2021	17	153	9
Tornado	12/21/2021	4	784	196
Tornado	12/21/2021	60	7,620	127
Tornado	12/21/2021	2,185	91,089	76
Tornado	12/21/2021	165	78,210	474
Tornado	12/21/2021	1	80	80
Tornado	12/21/2021	2	1,040	520
Tornado	12/21/2021	4	1,008	252

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	1	736	736
Tornado	12/21/2021	144	29,232	203
Tornado	12/21/2021	159	6,360	40
Tornado	12/21/2021	8	4,976	622
Tornado	12/21/2021	3	444	148
Tornado	12/21/2021	72	25,272	351
Tornado	12/21/2021	4	596	149
Tornado	12/21/2021	4	1,064	266
Tornado	12/21/2021	30	11,370	379
Tornado	12/21/2021	4	556	139
Tornado	12/21/2021	112	85,680	765
Tornado	12/21/2021	5	350	70
Tornado	12/21/2021	52	2,107	686
Tornado	12/21/2021	54	29,970	555
Tornado	12/21/2021	139	64,496	464
Tornado	12/21/2021	3	759	253
Tornado	12/21/2021	9	2,673	297
Tornado	12/21/2021	332	31,872	96
Tornado	12/21/2021	125	13,375	107
Tornado	12/21/2021	5	1,150	230
Tornado	12/21/2021	2	254	127
Tornado	12/21/2021	2	430	215
Tornado	12/21/2021	5	2,075	415
Tornado	12/21/2021	2,511	5,022	2
Tornado	12/21/2021	4	340	85
Tornado	12/21/2021	66	924	14
Tornado	12/21/2021	6	1,224	204
Tornado	12/21/2021	6	1,050	175
Tornado	12/21/2021	6	2,796	466
Tornado	12/21/2021	11	1,243	113
Tornado	12/21/2021	12	5,904	492
Tornado	12/21/2021	1	129	129
Tornado	12/21/2021	12	2,352	196
Tornado	12/21/2021	46	4,140	90
Tornado	12/21/2021	11	1,023	93
Tornado	12/21/2021	4	896	224
Tornado	12/21/2021	5	2,705	541
Tornado	12/21/2021	1	729	729
Tornado	12/21/2021	37	19,906	538
Tornado	12/21/2021	18	4,500	250
Tornado	12/21/2021	4	120	30
Tornado	12/21/2021	28	12,180	435
Tornado	12/21/2021	2	272	136

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	2	450	225
Tornado	12/21/2021	9	1,890	210
Tornado	12/21/2021	80	23,200	290
Tornado	12/21/2021	191	45,840	240
Tornado	12/21/2021	9	1,377	153
Tornado	12/21/2021	1	513	513
Tornado	12/21/2021	1	98	98
Tornado	12/21/2021	1	97	97
Tornado	12/21/2021	117	17,433	149
Tornado	12/21/2021	8	880	110
Tornado	12/21/2021	49	30,195	663
Tornado	12/21/2021	9	9,009	1,001
Tornado	12/21/2021	918	93,546	555
Tornado	12/21/2021	7	791	113
Tornado	12/21/2021	8	5,384	673
Tornado	12/21/2021	1	88	88
Tornado	12/21/2021	82	15,764	1,492
Tornado	12/21/2021	76	64,752	852
Tornado	12/21/2021	3	429	143
Tornado	12/21/2021	7	2,800	400
Tornado	12/21/2021	1,363	247,275	311
Tornado	12/21/2021	6	2,778	463
Tornado	12/21/2021	198	83,358	421
Tornado	12/21/2021	1	104	104
Tornado	12/21/2021	1	233	233
Tornado	12/21/2021	14	728	52
Tornado	12/21/2021	2	210	105
Tornado	12/21/2021	2	314	157
Tornado	12/21/2021	58	1,102	19
Tornado	12/21/2021	49	22,442	458
Tornado	12/21/2021	1	605	605
Tornado	12/21/2021	4	1,728	432
Tornado	12/21/2021	8	392	49
Tornado	12/21/2021	7	3,374	482
Tornado	12/21/2021	3	2,292	764
Tornado	12/21/2021	1	179	179
Tornado	12/21/2021	1	181	181
Tornado	12/21/2021	189	80,325	425
Tornado	12/21/2021	78	10,374	133
Tornado	12/21/2021	1	279	279
Tornado	12/21/2021	199	90,943	457
Tornado	12/21/2021	1	143	143
Tornado	12/21/2021	33	3,960	120

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	1	195	195
Tornado	12/21/2021	160	27,520	172
Tornado	12/21/2021	716	111,375	272
Tornado	12/21/2021	15	2,145	143
Tornado	12/21/2021	8	4,152	519
Tornado	12/21/2021	59	26,904	456
Tornado	12/21/2021	1	440	440
Tornado	12/21/2021	190	14,630	77
Tornado	12/21/2021	62	35,836	578
Tornado	12/21/2021	73	13,213	181
Tornado	12/21/2021	128	30,336	237
Tornado	12/21/2021	43	7,181	167
Tornado	12/21/2021	3	648	216
Tornado	12/21/2021	1	195	195
Tornado	12/21/2021	3	1,290	430
Tornado	12/21/2021	6	1,410	235
Tornado	12/21/2021	103	88,477	859
Tornado	12/21/2021	12	8,844	737
Tornado	12/21/2021	1	364	364
Tornado	12/21/2021	1,991	255,883	129
Tornado	12/21/2021	1	310	310
Tornado	12/21/2021	1	11	11
Tornado	12/21/2021	4	512	128
Tornado	12/21/2021	9	1,836	204
Tornado	12/21/2021	3	81	27
Tornado	12/21/2021	1	299	299
Tornado	12/21/2021	1	373	373
Tornado	12/21/2021	2	400	200
Tornado	12/21/2021	96	23,808	248
Tornado	12/21/2021	131	18,471	141
Tornado	12/21/2021	5	1,885	377
Tornado	12/21/2021	88	51,656	587
Tornado	12/21/2021	54	32,670	605
Tornado	12/21/2021	12	3,876	323
Tornado	12/21/2021	2	242	121
Tornado	12/21/2021	39	23,049	591
Tornado	12/21/2021	56	32,536	581
Tornado	12/21/2021	137	8,494	62
Tornado	12/21/2021	14	910	65
Tornado	12/21/2021	8	6,640	830
Tornado	12/21/2021	379	185,331	489
Tornado	12/21/2021	62	43,400	700
Tornado	12/21/2021	5	2,060	412

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	1	338	338
Tornado	12/21/2021	4	1,332	333
Tornado	12/21/2021	2	198	99
Tornado	12/21/2021	33	2,541	77
Tornado	12/21/2021	102	61,914	607
Tornado	12/21/2021	1	190	190
Tornado	12/21/2021	9	1,602	178
Tornado	12/21/2021	39	12,870	330
Tornado	12/21/2021	6	468	78
Tornado	12/21/2021	4	1,212	303
Tornado	12/21/2021	84	41,412	493
Tornado	12/21/2021	20	11,020	551
Tornado	12/21/2021	46	25,760	560
Tornado	12/21/2021	51	3,315	65
Tornado	12/21/2021	6	3,702	617
Tornado	12/21/2021	469	29,547	63
Tornado	12/21/2021	21	9,597	457
Tornado	12/21/2021	41	24,969	609
Tornado	12/21/2021	71	44,091	621
Tornado	12/21/2021	38	20,064	528
Tornado	12/21/2021	1	500	500
Tornado	12/21/2021	48	57,024	1,188
Tornado	12/21/2021	37	5,809	157
Tornado	12/21/2021	127	29,591	233
Tornado	12/21/2021	18	12,330	685
Tornado	12/21/2021	431	128,438	298
Tornado	12/21/2021	438	21,900	50
Tornado	12/21/2021	112	19,488	174
Tornado	12/21/2021	1	270	270
Tornado	12/21/2021	1	505	505
Tornado	12/21/2021	1	682	682
Tornado	12/21/2021	2,021	113,797	74
Tornado	12/21/2021	61	104,798	1,718
Tornado	12/21/2021	1	245	245
Tornado	12/21/2021	203	74,943	1,605
Tornado	12/21/2021	57	7,524	132
Tornado	12/21/2021	2	1,180	590
Tornado	12/21/2021	40	4,400	110
Tornado	12/21/2021	114	41,610	365
Tornado	12/21/2021	15	16,140	1,076
Tornado	12/21/2021	90	39,330	437
Tornado	12/21/2021	9	2,511	279
Tornado	12/21/2021	107	91,057	851

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	1,996	276,302	195
Tornado	12/21/2021	291	76,242	262
Tornado	12/21/2021	729	5,103	7
Tornado	12/21/2021	31	21,979	709
Tornado	12/21/2021	561	221,682	760
Tornado	12/21/2021	1	644	644
Tornado	12/21/2021	3,791	261,716	192
Tornado	12/21/2021	63	29,736	472
Tornado	12/21/2021	293	115,735	395
Tornado	12/21/2021	15	9,810	654
Tornado	12/21/2021	72	33,336	463
Tornado	12/21/2021	3	1,317	439
Tornado	12/21/2021	3	1,356	452
Tornado	12/21/2021	17	1,411	83
Tornado	12/21/2021	144	24,624	171
Tornado	12/21/2021	2	470	235
Tornado	12/21/2021	140	51,660	369
Tornado	12/21/2021	55	23,815	433
Tornado	12/21/2021	1	582	582
Tornado	12/21/2021	6	2,028	338
Tornado	12/21/2021	3	1,410	470
Tornado	12/21/2021	30	14,430	481
Tornado	12/21/2021	34	14,416	424
Tornado	12/21/2021	33	14,454	438
Tornado	12/21/2021	15	14,415	961
Tornado	12/21/2021	1,736	125,438	117
Tornado	12/21/2021	52	5,824	112
Tornado	12/21/2021	3	2,874	958
Tornado	12/21/2021	95	43,700	460
Tornado	12/21/2021	64	20,160	471
Tornado	12/21/2021	2	608	304
Tornado	12/21/2021	85	84,660	996
Tornado	12/21/2021	57	11,913	209
Tornado	12/21/2021	7	126	18
Tornado	12/21/2021	13	12,701	977
Tornado	12/21/2021	4	108	27
Tornado	12/21/2021	52	25,688	494
Tornado	12/21/2021	68	64,872	954
Tornado	12/21/2021	3	609	203
Tornado	12/21/2021	99	70,884	716
Tornado	12/21/2021	1	8	8
Tornado	12/21/2021	4	3,108	777
Tornado	12/21/2021	82	50,676	618

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	118	67,732	574
Tornado	12/21/2021	1	323	323
Tornado	12/21/2021	31	2,310	110
Tornado	12/21/2021	40	29,840	746
Tornado	12/21/2021	66	40,392	612
Tornado	12/21/2021	47	28,858	614
Tornado	12/21/2021	108	34,236	317
Tornado	12/21/2021	1	726	726
Tornado	12/21/2021	1	648	648
Tornado	12/21/2021	1	563	563
Tornado	12/21/2021	12	2,580	215
Tornado	12/21/2021	18	13,140	730
Tornado	12/21/2021	4	1,568	392
Tornado	12/21/2021	5	1,135	227
Tornado	12/21/2021	5	1,415	283
Tornado	12/21/2021	37	17,945	485
Tornado	12/21/2021	7	4,858	694
Tornado	12/21/2021	8	88	11
Tornado	12/21/2021	15	6,825	455
Tornado	12/21/2021	1	154	154
Tornado	12/21/2021	3	2,421	807
Tornado	12/21/2021	1	116	116
Tornado	12/21/2021	732	1,464	2
Tornado	12/21/2021	139	58,241	419
Tornado	12/21/2021	1	382	382
Tornado	12/21/2021	3	789	263
Tornado	12/21/2021	4	2,336	584
Tornado	12/21/2021	1	700	700
Tornado	12/21/2021	262	47,160	180
Tornado	12/21/2021	1	84	84
Tornado	12/21/2021	2	406	203
Tornado	12/21/2021	44	3,080	70
Tornado	12/21/2021	230	51,782	505
Tornado	12/21/2021	4	1,692	423
Tornado	12/21/2021	1	350	350
Tornado	12/21/2021	1	1,557	1,557
Tornado	12/21/2021	19	10,298	542
Tornado	12/21/2021	232	13,224	57
Tornado	12/21/2021	9	90	10
Tornado	12/21/2021	1	342	342
Tornado	12/21/2021	1	349	349
Tornado	12/21/2021	11	319	29
Tornado	12/21/2021	16	5,936	371

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	165	64,020	388
Tornado	12/21/2021	8	896	112
Tornado	12/21/2021	75	39,150	522
Tornado	12/21/2021	46	24,334	529
Tornado	12/21/2021	396	152,856	386
Tornado	12/21/2021	1	380	380
Tornado	12/21/2021	46	18,722	407
Tornado	12/21/2021	50	15,800	316
Tornado	12/21/2021	139	89,516	644
Tornado	12/21/2021	8	1,064	133
Tornado	12/21/2021	6	258	43
Tornado	12/21/2021	16	10,720	670
Tornado	12/21/2021	67	24,455	365
Tornado	12/21/2021	1	387	387
Tornado	12/21/2021	131	50,697	387
Tornado	12/21/2021	2	18	9
Tornado	12/21/2021	1	599	599
Tornado	12/21/2021	5	1,870	374
Tornado	12/21/2021	1	349	349
Tornado	12/21/2021	2	1,382	691
Tornado	12/21/2021	28	18,116	647
Tornado	12/21/2021	1	685	685
Tornado	12/21/2021	40	17,560	439
Tornado	12/21/2021	32	8,512	266
Tornado	12/21/2021	52	35,464	682
Tornado	12/21/2021	14	5,558	397
Tornado	12/21/2021	15	9,495	633
Tornado	12/21/2021	28	17,500	625
Tornado	12/21/2021	3	2,115	705
Tornado	12/21/2021	8	184	23
Tornado	12/21/2021	1	365	365
Tornado	12/21/2021	10	1,700	170
Tornado	12/21/2021	74	13,098	177
Tornado	12/21/2021	36	20,124	559
Tornado	12/21/2021	4	692	173
Tornado	12/21/2021	77	42,812	556
Tornado	12/21/2021	124	58,652	473
Tornado	12/21/2021	51	38,199	749
Tornado	12/21/2021	7	980	140
Tornado	12/21/2021	122	12,579	237
Tornado	12/21/2021	1	354	354
Tornado	12/21/2021	5	5,065	1,013
Tornado	12/21/2021	1	7	7

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	4	28	7
Tornado	12/21/2021	1	243	243
Tornado	12/21/2021	312	139,152	446
Tornado	12/21/2021	9	1,971	219
Tornado	12/21/2021	122	29,280	240
Tornado	12/21/2021	1	152	152
Tornado	12/21/2021	24	5,496	229
Tornado	12/21/2021	23	11,270	490
Tornado	12/21/2021	7	5,537	791
Tornado	12/21/2021	1	433	433
Tornado	12/21/2021	10	470	47
Tornado	12/21/2021	13	3,601	277
Tornado	12/21/2021	140	34,720	248
Tornado	12/21/2021	2	972	486
Tornado	12/21/2021	8	4,752	594
Tornado	12/21/2021	72	42,480	590
Tornado	12/21/2021	35	9,380	268
Tornado	12/21/2021	2	14	7
Tornado	12/21/2021	26	4,160	160
Tornado	12/21/2021	21	9,555	455
Tornado	12/21/2021	32	15,872	496
Tornado	12/21/2021	3	2,298	766
Tornado	12/21/2021	2	356	178
Tornado	12/21/2021	69	2,830	45
Tornado	12/21/2021	28	4,256	152
Tornado	12/21/2021	1,001	98,098	98
Tornado	12/21/2021	8	8,904	1,113
Tornado	12/21/2021	3	789	263
Tornado	12/21/2021	1	647	647
Tornado	12/21/2021	5	3,715	743
Tornado	12/21/2021	5	2,775	555
Tornado	12/21/2021	15	2,085	139
Tornado	12/21/2021	4	1,068	267
Tornado	12/21/2021	6	3,828	638
Tornado	12/21/2021	10	6,310	631
Tornado	12/21/2021	54	1,296	24
Tornado	12/21/2021	1	177	177
Tornado	12/21/2021	1	458	458
Tornado	12/21/2021	3	1,785	595
Tornado	12/21/2021	10	6,370	637
Tornado	12/21/2021	17	13,430	790
Tornado	12/21/2021	1	174	174
Tornado	12/21/2021	1	667	667

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	178	64,436	362
Tornado	12/21/2021	5	240	48
Tornado	12/21/2021	4	1,916	479
Tornado	12/21/2021	151	23,707	157
Tornado	12/21/2021	1	697	697
Tornado	12/21/2021	11	3,498	318
Tornado	12/21/2021	9	12,465	1,385
Tornado	12/21/2021	8	4,032	504
Tornado	12/21/2021	1	4	4
Tornado	12/21/2021	32	23,904	747
Tornado	12/21/2021	18	9,216	512
Tornado	12/21/2021	1	142	142
Tornado	12/21/2021	56	33,264	594
Tornado	12/21/2021	2	34	17
Tornado	12/21/2021	36	12,960	360
Tornado	12/21/2021	38	2,850	369
Tornado	12/21/2021	69	25,323	367
Tornado	12/21/2021	205	37,720	184
Tornado	12/21/2021	31	12,338	398
Tornado	12/21/2021	87	13,326	551
Tornado	12/21/2021	27	7,884	292
Tornado	12/21/2021	147	58,123	526
Tornado	12/21/2021	41	44,854	1,094
Tornado	12/21/2021	19	9,462	498
Tornado	12/21/2021	64	47,680	745
Tornado	12/21/2021	8	536	67
Tornado	12/21/2021	10	170	17
Tornado	12/21/2021	3	513	171
Tornado	12/21/2021	5	830	166
Tornado	12/21/2021	1	490	490
Tornado	12/21/2021	14	3,430	245
Tornado	12/21/2021	12	552	46
Tornado	12/21/2021	18	7,236	402
Tornado	12/21/2021	16	9,584	599
Tornado	12/21/2021	70	26,880	384
Tornado	12/21/2021	155	68,510	442
Tornado	12/21/2021	2	228	114
Tornado	12/21/2021	4	1,592	398
Tornado	12/21/2021	36	21,744	604
Tornado	12/21/2021	2	359	271
Tornado	12/21/2021	10	4,430	443
Tornado	12/21/2021	1	29	29
Tornado	12/21/2021	20	29,900	1,495

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	212	12,623	592
Tornado	12/21/2021	1	290	290
Tornado	12/21/2021	1	511	511
Tornado	12/21/2021	1	1,528	1,528
Tornado	12/21/2021	80	36,960	462
Tornado	12/21/2021	19	21,432	1,128
Tornado	12/21/2021	332	373,832	1,126
Tornado	12/21/2021	11	1,518	138
Tornado	12/21/2021	1	250	250
Tornado	12/21/2021	1	1,352	1,352
Tornado	12/21/2021	3	822	274
Tornado	12/21/2021	6	1,572	262
Tornado	12/21/2021	10	5,670	567
Tornado	12/21/2021	18	8,154	453
Tornado	12/21/2021	11	3,509	319
Tornado	12/21/2021	12	5,196	433
Tornado	12/21/2021	3	1,563	521
Tornado	12/21/2021	3,821	246,073	65
Tornado	12/21/2021	33	20,262	614
Tornado	12/21/2021	2	190	95
Tornado	12/21/2021	1,499	15,135	15
Tornado	12/21/2021	6	1,494	249
Tornado	12/21/2021	5	55	11
Tornado	12/21/2021	146	101,324	694
Tornado	12/21/2021	22	3,102	141
Tornado	12/21/2021	44	28,204	641
Tornado	12/21/2021	24	9,936	414
Tornado	12/21/2021	17	1,632	96
Tornado	12/21/2021	1	151	151
Tornado	12/21/2021	1	15	15
Tornado	12/21/2021	1	154	154
Tornado	12/21/2021	1	270	270
Tornado	12/21/2021	8	88	11
Tornado	12/21/2021	9	3,564	396
Tornado	12/21/2021	8	288	36
Tornado	12/21/2021	104	125,736	1,209
Tornado	12/21/2021	7	1,708	244
Tornado	12/21/2021	3	708	236
Tornado	12/21/2021	8	10,480	1,310
Tornado	12/21/2021	17	6,987	411
Tornado	12/21/2021	55	23,100	420
Tornado	12/21/2021	15	4,684	324
Tornado	12/21/2021	1	315	315

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	7	378	54
Tornado	12/21/2021	1	872	872
Tornado	12/21/2021	1	396	396
Tornado	12/21/2021	3	507	169
Tornado	12/21/2021	1	110	110
Tornado	12/21/2021	1	1,314	1,314
Tornado	12/21/2021	3	1,698	566
Tornado	12/21/2021	23	9,959	433
Tornado	12/21/2021	5	965	193
Tornado	12/21/2021	58	25,172	434
Tornado	12/21/2021	33	2,442	74
Tornado	12/21/2021	2	16	8
Tornado	12/21/2021	66	24,684	374
Tornado	12/21/2021	1	81	81
Tornado	12/21/2021	6	1,536	256
Tornado	12/21/2021	109	29,539	271
Tornado	12/21/2021	2	18	9
Tornado	12/21/2021	83	16,434	198
Tornado	12/21/2021	50	27,400	548
Tornado	12/21/2021	21	2,226	106
Tornado	12/21/2021	21	11,823	563
Tornado	12/21/2021	671	50,837	226
Tornado	12/21/2021	9	2,934	326
Tornado	12/21/2021	14	2,170	155
Tornado	12/21/2021	1	226	226
Tornado	12/21/2021	20	11,020	551
Tornado	12/21/2021	7	413	59
Tornado	12/21/2021	1	74	74
Tornado	12/21/2021	1	578	578
Tornado	12/21/2021	225	63,000	280
Tornado	12/21/2021	9	2,052	228
Tornado	12/21/2021	34	16,252	478
Tornado	12/21/2021	4	1,232	308
Tornado	12/21/2021	4	572	143
Tornado	12/21/2021	9	765	85
Tornado	12/21/2021	45	3,285	73
Tornado	12/21/2021	33	14,256	433
Tornado	12/21/2021	26	2,496	96
Tornado	12/21/2021	4	256	64
Tornado	12/21/2021	1	7	7
Tornado	12/21/2021	3	21	7
Tornado	12/21/2021	1	706	706
Tornado	12/21/2021	9	963	107

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	4	2,732	683
Tornado	12/21/2021	16	8,576	536
Tornado	12/21/2021	52	27,560	530
Tornado	12/21/2021	10	1,030	103
Tornado	12/21/2021	5	3,100	620
Tornado	12/21/2021	8	2,360	295
Tornado	12/21/2021	91	36,491	401
Tornado	12/21/2021	105	15,645	149
Tornado	12/21/2021	9	4,572	508
Tornado	12/21/2021	17	2,703	159
Tornado	12/21/2021	52	9,516	183
Tornado	12/21/2021	4	96	24
Tornado	12/21/2021	2	302	151
Tornado	12/21/2021	1	23	23
Tornado	12/21/2021	101	31,310	310
Tornado	12/21/2021	4	1,108	277
Tornado	12/21/2021	1	611	611
Tornado	12/21/2021	2	36	18
Tornado	12/21/2021	6	2,748	458
Tornado	12/21/2021	1	368	368
Tornado	12/21/2021	8	1,152	144
Tornado	12/21/2021	5	2,105	421
Tornado	12/21/2021	6	1,218	203
Tornado	12/21/2021	114	66,576	584
Tornado	12/21/2021	7	434	62
Tornado	12/21/2021	4	672	168
Tornado	12/21/2021	16	6,560	410
Tornado	12/21/2021	8	1,048	131
Tornado	12/21/2021	1	44	44
Tornado	12/21/2021	7	854	122
Tornado	12/21/2021	160	26,400	165
Tornado	12/21/2021	1	84	84
Tornado	12/21/2021	21	14,133	673
Tornado	12/21/2021	48	6,336	132
Tornado	12/21/2021	147	7,497	51
Tornado	12/21/2021	32	4,896	153
Tornado	12/21/2021	1	678	678
Tornado	12/21/2021	10	2,220	222
Tornado	12/21/2021	9	1,746	194
Tornado	12/21/2021	10	2,400	240
Tornado	12/21/2021	7	665	95
Tornado	12/21/2021	5	2,005	401
Tornado	12/21/2021	10	6,800	680

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	8	2,144	268
Tornado	12/21/2021	43	12,126	282
Tornado	12/21/2021	1	6	6
Tornado	12/21/2021	1	595	595
Tornado	12/21/2021	1	722	722
Tornado	12/21/2021	3	1,332	444
Tornado	12/21/2021	27	6,948	270
Tornado	12/21/2021	1	41	41
Tornado	12/21/2021	1	477	477
Tornado	12/21/2021	1	76	76
Tornado	12/21/2021	1	427	427
Tornado	12/21/2021	1	308	308
Tornado	12/21/2021	11	2,299	209
Tornado	12/21/2021	1,316	3,948	3
Tornado	12/21/2021	1	556	556
Tornado	12/21/2021	41	22,099	539
Tornado	12/21/2021	20	1,720	86
Tornado	12/21/2021	3	1,716	572
Tornado	12/21/2021	1	106	106
Tornado	12/21/2021	27	3,672	106
Tornado	12/21/2021	40	6,800	170
Tornado	12/21/2021	1	641	641
Tornado	12/21/2021	13	702	54
Tornado	12/21/2021	8	896	112
Tornado	12/21/2021	126	81,900	650
Tornado	12/21/2021	9	927	103
Tornado	12/21/2021	11	3,300	300
Tornado	12/21/2021	1	93	93
Tornado	12/21/2021	8	240	30
Tornado	12/21/2021	6	3,174	529
Tornado	12/21/2021	4	800	200
Tornado	12/21/2021	1	44	44
Tornado	12/21/2021	49	50,666	1,034
Tornado	12/21/2021	41	18,778	458
Tornado	12/21/2021	3	1,914	638
Tornado	12/21/2021	3	279	93
Tornado	12/21/2021	1	96	96
Tornado	12/21/2021	5	1,565	313
Tornado	12/21/2021	32	2,368	74
Tornado	12/21/2021	4	2,180	545
Tornado	12/21/2021	17	6,987	411
Tornado	12/21/2021	213	59,214	278
Tornado	12/21/2021	9	3,348	372

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	6	1,668	278
Tornado	12/21/2021	10	660	66
Tornado	12/21/2021	61	25,193	413
Tornado	12/21/2021	1	299	299
Tornado	12/21/2021	40	14,520	363
Tornado	12/21/2021	1	29	29
Tornado	12/21/2021	8	3,352	419
Tornado	12/21/2021	1	13	13
Tornado	12/21/2021	79	35,076	444
Tornado	12/21/2021	1	358	358
Tornado	12/21/2021	2	578	289
Tornado	12/21/2021	7	2,156	308
Tornado	12/21/2021	79	7,584	96
Tornado	12/21/2021	1	415	415
Tornado	12/21/2021	1	10	10
Tornado	12/21/2021	5	1,490	298
Tornado	12/21/2021	53	12,879	243
Tornado	12/21/2021	55	3,905	71
Tornado	12/21/2021	4	68	17
Tornado	12/21/2021	8	3,672	459
Tornado	12/21/2021	1	256	256
Tornado	12/21/2021	56	19,600	350
Tornado	12/21/2021	1	125	125
Tornado	12/21/2021	4	324	81
Tornado	12/21/2021	6	1,452	242
Tornado	12/21/2021	2	662	331
Tornado	12/21/2021	1	373	373
Tornado	12/21/2021	2	1,014	507
Tornado	12/21/2021	6	564	94
Tornado	12/21/2021	56	12,848	403
Tornado	12/21/2021	41	14,391	351
Tornado	12/21/2021	22	4,884	222
Tornado	12/21/2021	13	5,915	455
Tornado	12/21/2021	2	898	449
Tornado	12/21/2021	983	67,827	69
Tornado	12/21/2021	1	527	527
Tornado	12/21/2021	14	434	31
Tornado	12/21/2021	3	561	187
Tornado	12/21/2021	966	1,932	2
Tornado	12/21/2021	1	223	223
Tornado	12/21/2021	1	96	96
Tornado	12/21/2021	56	11,704	209
Tornado	12/21/2021	3	2,160	720

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	19	11,457	603
Tornado	12/21/2021	103	32,857	319
Tornado	12/21/2021	148	52,540	355
Tornado	12/21/2021	74	32,634	441
Tornado	12/21/2021	9	2,538	282
Tornado	12/21/2021	33	15,114	458
Tornado	12/21/2021	55	22,779	562
Tornado	12/21/2021	98	62,524	638
Tornado	12/21/2021	55	32,560	592
Tornado	12/21/2021	67	35,443	529
Tornado	12/21/2021	38	18,126	477
Tornado	12/21/2021	63	31,563	501
Tornado	12/21/2021	130	88,400	680
Tornado	12/21/2021	8	2,616	327
Tornado	12/21/2021	84	27,300	325
Tornado	12/21/2021	72	18,720	260
Tornado	12/21/2021	94	36,754	391
Tornado	12/21/2021	102	20,604	202
Tornado	12/21/2021	1	7	7
Tornado	12/21/2021	132	39,204	297
Tornado	12/21/2021	1	300	300
Tornado	12/21/2021	2	462	231
Tornado	12/21/2021	10	3,740	374
Tornado	12/21/2021	1	694	694
Tornado	12/21/2021	1	617	617
Tornado	12/21/2021	74	12,432	168
Tornado	12/21/2021	56	23,072	412
Tornado	12/21/2021	4	452	113
Tornado	12/21/2021	1	18	18
Tornado	12/21/2021	1	413	413
Tornado	12/21/2021	24	10,032	418
Tornado	12/21/2021	9	4,536	504
Tornado	12/21/2021	3	2,046	682
Tornado	12/21/2021	73	20,440	280
Tornado	12/21/2021	14	1,148	82
Tornado	12/21/2021	2	20	10
Tornado	12/21/2021	4	1,844	461
Tornado	12/21/2021	1	1,185	1,185
Tornado	12/21/2021	103	24,823	241
Tornado	12/21/2021	9	2,142	238
Tornado	12/21/2021	10	1,860	186
Tornado	12/21/2021	25	2,153	283
Tornado	12/21/2021	466	54,988	207

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	2	816	408
Tornado	12/21/2021	1	320	320
Tornado	12/21/2021	2	508	254
Tornado	12/21/2021	1	452	452
Tornado	12/21/2021	1	500	500
Tornado	12/21/2021	1	36	36
Tornado	12/21/2021	84	16,632	198
Tornado	12/21/2021	1	528	528
Tornado	12/21/2021	4	1,212	303
Tornado	12/21/2021	1	32	32
Tornado	12/21/2021	5	1,710	342
Tornado	12/21/2021	22	3,344	152
Tornado	12/21/2021	1	189	189
Tornado	12/21/2021	41	2,460	60
Tornado	12/21/2021	1	453	453
Tornado	12/21/2021	19	2,736	144
Tornado	12/21/2021	1	63	63
Tornado	12/21/2021	1	321	321
Tornado	12/21/2021	68	22,100	325
Tornado	12/21/2021	49	5,880	120
Tornado	12/21/2021	77	16,170	210
Tornado	12/21/2021	5	2,365	473
Tornado	12/21/2021	4	1,552	388
Tornado	12/21/2021	4	132	33
Tornado	12/21/2021	1,493	2,986	2
Tornado	12/21/2021	28	8,428	301
Tornado	12/21/2021	6	240	40
Tornado	12/21/2021	7	4,284	612
Tornado	12/21/2021	24	9,216	384
Tornado	12/21/2021	3	612	204
Tornado	12/21/2021	4	1,160	290
Tornado	12/21/2021	25	23,300	932
Tornado	12/21/2021	5	55	11
Tornado	12/21/2021	13	1,170	90
Tornado	12/21/2021	1	214	214
Tornado	12/21/2021	2	488	244
Tornado	12/21/2021	8	176	22
Tornado	12/21/2021	4	436	109
Tornado	12/21/2021	3	240	80
Tornado	12/21/2021	12	4,572	381
Tornado	12/21/2021	8	1,416	177
Tornado	12/21/2021	60	16,980	283
Tornado	12/21/2021	1	277	277

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	10	540	54
Tornado	12/21/2021	15	6,660	444
Tornado	12/21/2021	1	106	106
Tornado	12/21/2021	1	292	292
Tornado	12/21/2021	5	1,405	281
Tornado	12/21/2021	4	1,864	466
Tornado	12/21/2021	6	306	51
Tornado	12/21/2021	8	1,388	380
Tornado	12/21/2021	9	1,746	194
Tornado	12/21/2021	10	2,200	220
Tornado	12/21/2021	1	416	416
Tornado	12/21/2021	3	711	237
Tornado	12/21/2021	42	4,116	98
Tornado	12/21/2021	1	387	387
Tornado	12/21/2021	1	45	45
Tornado	12/21/2021	12	3,972	331
Tornado	12/21/2021	1	315	315
Tornado	12/21/2021	5	1,035	207
Tornado	12/21/2021	4	1,168	292
Tornado	12/21/2021	8	2,480	310
Tornado	12/21/2021	5	2,290	458
Tornado	12/21/2021	2	490	245
Tornado	12/21/2021	1	272	272
Tornado	12/21/2021	2	1,090	545
Tornado	12/21/2021	1	683	683
Tornado	12/21/2021	1	344	344
Tornado	12/21/2021	112	43,232	386
Tornado	12/21/2021	1	44	44
Tornado	12/21/2021	1	408	408
Tornado	12/21/2021	10	6,870	687
Tornado	12/21/2021	1,529	100,914	66
Tornado	12/21/2021	1	207	207
Tornado	12/21/2021	22	1,606	73
Tornado	12/21/2021	4	32	8
Tornado	12/21/2021	3	804	268
Tornado	12/21/2021	73	4,810	108
Tornado	12/21/2021	10	690	69
Tornado	12/21/2021	1	95	95
Tornado	12/21/2021	1	68	68
Tornado	12/21/2021	6	2,826	471
Tornado	12/21/2021	2	102	51
Tornado	12/21/2021	1	107	107
Tornado	12/21/2021	1	180	180

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	2	290	145
Tornado	12/21/2021	1	86	86
Tornado	12/21/2021	14	5,054	361
Tornado	12/21/2021	1	284	284
Tornado	12/21/2021	5	2,360	472
Tornado	12/21/2021	1	35	35
Tornado	12/21/2021	1	57	57
Tornado	12/21/2021	38	1,596	42
Tornado	12/21/2021	1	356	356
Tornado	12/21/2021	1	37	37
Tornado	12/21/2021	25	13,825	553
Tornado	12/21/2021	11	110	10
Tornado	12/21/2021	2	252	126
Tornado	12/21/2021	12	6,732	561
Tornado	12/21/2021	195	29,523	275
Tornado	12/21/2021	1	141	141
Tornado	12/21/2021	3	558	186
Tornado	12/21/2021	2	398	199
Tornado	12/21/2021	89	8,722	98
Tornado	12/21/2021	122	5,612	46
Tornado	12/21/2021	28	3,864	138
Tornado	12/21/2021	52	3,380	65
Tornado	12/21/2021	1	121	121
Tornado	12/21/2021	27	2,508	156
Tornado	12/21/2021	10	810	81
Tornado	12/21/2021	1	402	402
Tornado	12/21/2021	730	16,976	74
Tornado	12/21/2021	2	496	248
Tornado	12/21/2021	13	2,600	200
Tornado	12/21/2021	1	368	368
Tornado	12/21/2021	1	373	373
Tornado	12/21/2021	8	2,520	315
Tornado	12/21/2021	1	146	146
Tornado	12/21/2021	1	476	476
Tornado	12/21/2021	16	12,747	817
Tornado	12/21/2021	7	2,863	409
Tornado	12/21/2021	1	141	141
Tornado	12/21/2021	5	3,805	761
Tornado	12/21/2021	51	4,590	90
Tornado	12/21/2021	12	840	70
Tornado	12/21/2021	35	16,695	477
Tornado	12/21/2021	1	187	187
Tornado	12/21/2021	106	20,988	198

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	2	120	60
Tornado	12/21/2021	1	213	213
Tornado	12/21/2021	3	441	147
Tornado	12/21/2021	1	81	81
Tornado	12/21/2021	3	36	12
Tornado	12/21/2021	1	328	328
Tornado	12/21/2021	1	200	200
Tornado	12/21/2021	8	4,312	539
Tornado	12/21/2021	3	153	51
Tornado	12/21/2021	1	175	175
Tornado	12/21/2021	8	344	43
Tornado	12/21/2021	8	1,456	182
Tornado	12/21/2021	1	313	313
Tornado	12/21/2021	79	26,939	341
Tornado	12/21/2021	445	88,522	693
Tornado	12/21/2021	33	1,023	31
Tornado	12/21/2021	2	278	139
Tornado	12/21/2021	26	7,826	301
Tornado	12/21/2021	3	1,365	455
Tornado	12/21/2021	6	144	24
Tornado	12/21/2021	1	302	302
Tornado	12/21/2021	1	362	362
Tornado	12/21/2021	1	437	437
Tornado	12/21/2021	1	355	355
Tornado	12/21/2021	8	2,464	308
Tornado	12/21/2021	5	975	195
Tornado	12/21/2021	9	1,026	114
Tornado	12/21/2021	29	3,741	129
Tornado	12/21/2021	1	358	358
Tornado	12/21/2021	13	8,554	658
Tornado	12/21/2021	1	171	171
Tornado	12/21/2021	6	1,008	168
Tornado	12/21/2021	7	1,638	234
Tornado	12/21/2021	16	784	49
Tornado	12/21/2021	11	792	72
Tornado	12/21/2021	2	520	260
Tornado	12/21/2021	1	203	203
Tornado	12/21/2021	5	850	170
Tornado	12/21/2021	1	286	286
Tornado	12/21/2021	1	142	142
Tornado	12/21/2021	1	172	172
Tornado	12/21/2021	64	8,896	139
Tornado	12/21/2021	6	702	117

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	7	1,260	180
Tornado	12/21/2021	3	735	245
Tornado	12/21/2021	23	1,886	82
Tornado	12/21/2021	11	2,024	184
Tornado	12/21/2021	1	190	190
Tornado	12/21/2021	1	415	415
Tornado	12/21/2021	4	1,196	299
Tornado	12/21/2021	5	660	132
Tornado	12/21/2021	2	206	103
Tornado	12/21/2021	3	1,065	355
Tornado	12/21/2021	3	507	169
Tornado	12/21/2021	37	20,757	561
Tornado	12/21/2021	40	9,680	242
Tornado	12/21/2021	1,962	149,500	198
Tornado	12/21/2021	1	53	53
Tornado	12/21/2021	93	40,920	440
Tornado	12/21/2021	21	3,297	157
Tornado	12/21/2021	1	622	622
Tornado	12/21/2021	2	696	348
Tornado	12/21/2021	81	9,315	115
Tornado	12/21/2021	7	1,449	207
Tornado	12/21/2021	1	186	186
Tornado	12/21/2021	12	372	31
Tornado	12/21/2021	4	80	20
Tornado	12/21/2021	11	1,408	128
Tornado	12/21/2021	2	556	278
Tornado	12/21/2021	1	229	229
Tornado	12/21/2021	1	435	435
Tornado	12/21/2021	1	195	195
Tornado	12/21/2021	1,209	9,672	8
Tornado	12/21/2021	20	2,880	144
Tornado	12/21/2021	43	13,803	321
Tornado	12/21/2021	19	6,384	336
Tornado	12/21/2021	1	220	220
Tornado	12/21/2021	1	592	592
Tornado	12/21/2021	9	1,809	201
Tornado	12/21/2021	3	1,203	401
Tornado	12/21/2021	6	3,372	562
Tornado	12/21/2021	4	1,164	291
Tornado	12/21/2021	12	684	57
Tornado	12/21/2021	1	280	280
Tornado	12/21/2021	31	12,834	414
Tornado	12/21/2021	1	466	466

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	13	2,106	162
Tornado	12/21/2021	6	1,830	305
Tornado	12/21/2021	17	5,933	349
Tornado	12/21/2021	1	201	201
Tornado	12/21/2021	1	168	168
Tornado	12/21/2021	1	162	162
Tornado	12/21/2021	1	190	190
Tornado	12/21/2021	11	12,012	1,092
Tornado	12/21/2021	1	213	213
Tornado	12/21/2021	8	1,648	206
Tornado	12/21/2021	8	2,352	294
Tornado	12/21/2021	29	3,182	258
Tornado	12/21/2021	5	1,030	206
Tornado	12/21/2021	2	932	466
Tornado	12/21/2021	2	246	123
Tornado	12/21/2021	8	2,808	351
Tornado	12/21/2021	1	1,339	1,339
Tornado	12/21/2021	1	115	115
Tornado	12/21/2021	1	328	328
Tornado	12/21/2021	1	153	153
Tornado	12/21/2021	1	95	95
Tornado	12/21/2021	1	279	279
Tornado	12/21/2021	4	616	154
Tornado	12/21/2021	1	289	289
Tornado	12/21/2021	4	444	111
Tornado	12/21/2021	1	194	194
Tornado	12/21/2021	67	27,068	404
Tornado	12/21/2021	2	568	284
Tornado	12/21/2021	1	115	115
Tornado	12/21/2021	5	670	134
Tornado	12/21/2021	1	381	381
Tornado	12/21/2021	83	34,196	412
Tornado	12/21/2021	4	620	155
Tornado	12/21/2021	1	259	259
Tornado	12/21/2021	95	18,535	268
Tornado	12/21/2021	4	536	134
Tornado	12/21/2021	8	576	72
Tornado	12/21/2021	10	580	58
Tornado	12/21/2021	1	104	104
Tornado	12/21/2021	219	40,734	186
Tornado	12/21/2021	42	9,450	225
Tornado	12/21/2021	16	4,096	256
Tornado	12/21/2021	1	126	126

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	2	486	243
Tornado	12/21/2021	9	1,854	206
Tornado	12/21/2021	17	2,125	125
Tornado	12/21/2021	8	2,368	296
Tornado	12/21/2021	3	714	238
Tornado	12/21/2021	2	582	291
Tornado	12/21/2021	8	1,016	127
Tornado	12/21/2021	111	16,539	149
Tornado	12/21/2021	2	210	105
Tornado	12/21/2021	1	166	166
Tornado	12/21/2021	16	720	45
Tornado	12/21/2021	1	113	113
Tornado	12/21/2021	1	26	26
Tornado	12/21/2021	4	1,536	384
Tornado	12/21/2021	4	1,396	349
Tornado	12/21/2021	1	199	199
Tornado	12/21/2021	2	316	158
Tornado	12/21/2021	94	5,922	63
Tornado	12/21/2021	513	124,659	243
Tornado	12/21/2021	5	15	3
Tornado	12/21/2021	1	307	307
Tornado	12/21/2021	21	20,790	990
Tornado	12/21/2021	206	194,464	944
Tornado	12/21/2021	30	22,290	743
Tornado	12/21/2021	66	36,696	556
Tornado	12/21/2021	70	58,030	829
Tornado	12/21/2021	12	12,636	1,053
Tornado	12/21/2021	3	1,626	542
Tornado	12/21/2021	1	2,252	2,252
Tornado	12/21/2021	2	688	344
Tornado	12/21/2021	4	2,260	565
Tornado	12/21/2021	3	315	105
Tornado	12/21/2021	1	87	87
Tornado	12/21/2021	1	415	415
Tornado	12/21/2021	8	1,136	142
Tornado	12/21/2021	17	221	13
Tornado	12/21/2021	1	281	281
Tornado	12/21/2021	2	114	57
Tornado	12/21/2021	46	5,566	121
Tornado	12/21/2021	3	1,809	603
Tornado	12/21/2021	1	149	149
Tornado	12/21/2021	11	1,672	152
Tornado	12/21/2021	1	115	115

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	4	1,492	373
Tornado	12/21/2021	1	96	96
Tornado	12/21/2021	1	1,153	1,153
Tornado	12/21/2021	1	333	333
Tornado	12/21/2021	1	298	298
Tornado	12/21/2021	12	900	75
Tornado	12/21/2021	6	1,560	260
Tornado	12/21/2021	112	34,496	308
Tornado	12/21/2021	1	411	411
Tornado	12/21/2021	1	934	934
Tornado	12/21/2021	51	14,943	293
Tornado	12/21/2021	11	341	31
Tornado	12/21/2021	3	114	66
Tornado	12/21/2021	11	660	60
Tornado	12/21/2021	2	174	87
Tornado	12/21/2021	1	186	186
Tornado	12/21/2021	1	59	59
Tornado	12/21/2021	4	340	85
Tornado	12/21/2021	22	10,868	494
Tornado	12/21/2021	19	14,041	739
Tornado	12/21/2021	1	124	124
Tornado	12/21/2021	1	76	76
Tornado	12/21/2021	4	1,024	256
Tornado	12/21/2021	3	768	256
Tornado	12/21/2021	1	869	869
Tornado	12/21/2021	130	34,970	269
Tornado	12/21/2021	1	54	54
Tornado	12/21/2021	5	4,375	875
Tornado	12/21/2021	5	910	182
Tornado	12/21/2021	139	34,472	248
Tornado	12/21/2021	1	153	153
Tornado	12/21/2021	1	86	86
Tornado	12/21/2021	35	31,185	891
Tornado	12/21/2021	441	115,101	261
Tornado	12/21/2021	15	1,890	126
Tornado	12/21/2021	1,298	54,516	42
Tornado	12/21/2021	1	138	138
Tornado	12/21/2021	3	156	52
Tornado	12/21/2021	1	264	264
Tornado	12/21/2021	1	182	182
Tornado	12/21/2021	4	804	201
Tornado	12/21/2021	1	254	254
Tornado	12/21/2021	1	221	221

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	1	161	161
Tornado	12/21/2021	1	340	340
Tornado	12/21/2021	1	339	339
Tornado	12/21/2021	2	394	197
Tornado	12/21/2021	1	63	63
Tornado	12/21/2021	106	35,616	336
Tornado	12/21/2021	19	7,809	411
Tornado	12/21/2021	17	1,020	60
Tornado	12/21/2021	7	2,086	298
Tornado	12/21/2021	1	228	228
Tornado	12/21/2021	1	950	950
Tornado	12/21/2021	1	131	131
Tornado	12/21/2021	1	80	80
Tornado	12/21/2021	1	239	239
Tornado	12/21/2021	3	84	28
Tornado	12/21/2021	3	222	74
Tornado	12/21/2021	3	273	91
Tornado	12/21/2021	14	2,520	180
Tornado	12/21/2021	26	598	23
Tornado	12/21/2021	1	141	141
Tornado	12/21/2021	1	111	111
Tornado	12/21/2021	132	17,864	594
Tornado	12/21/2021	9	2,097	233
Tornado	12/21/2021	1	101	101
Tornado	12/21/2021	169	13,154	372
Tornado	12/21/2021	1	186	186
Tornado	12/21/2021	1	335	335
Tornado	12/21/2021	13	1,872	144
Tornado	12/21/2021	6	372	62
Tornado	12/21/2021	1	60	60
Tornado	12/21/2021	24	5,160	215
Tornado	12/21/2021	1	347	347
Tornado	12/21/2021	1	281	281
Tornado	12/21/2021	1	244	244
Tornado	12/21/2021	13	2,496	192
Tornado	12/21/2021	10	3,100	310
Tornado	12/21/2021	10	4,200	420
Tornado	12/21/2021	1	405	405
Tornado	12/21/2021	1	128	128
Tornado	12/21/2021	681	688	2
Tornado	12/21/2021	2	502	251
Tornado	12/21/2021	40	4,360	109
Tornado	12/21/2021	1	748	748

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	72	22,032	306
Tornado	12/21/2021	9	693	77
Tornado	12/21/2021	101	17,170	170
Tornado	12/21/2021	3	552	184
Tornado	12/21/2021	1	82	82
Tornado	12/21/2021	1	100	100
Tornado	12/21/2021	1	396	396
Tornado	12/21/2021	14	17,906	1,279
Tornado	12/21/2021	212	95,188	449
Tornado	12/21/2021	1	683	683
Tornado	12/21/2021	1	141	141
Tornado	12/21/2021	21	1,302	62
Tornado	12/21/2021	1	383	383
Tornado	12/21/2021	53	16,695	315
Tornado	12/21/2021	6	1,314	219
Tornado	12/21/2021	5	175	35
Tornado	12/21/2021	1	172	172
Tornado	12/21/2021	2	108	54
Tornado	12/21/2021	1	125	125
Tornado	12/21/2021	1	95	95
Tornado	12/21/2021	5	770	154
Tornado	12/21/2021	1	185	185
Tornado	12/21/2021	26	4,784	184
Tornado	12/21/2021	5	1,095	219
Tornado	12/21/2021	6	4,854	809
Tornado	12/21/2021	1	190	190
Tornado	12/21/2021	13	1,638	126
Tornado	12/21/2021	1	89	89
Tornado	12/21/2021	1	138	138
Tornado	12/21/2021	1	70	70
Tornado	12/21/2021	1	267	267
Tornado	12/21/2021	29	2,407	83
Tornado	12/21/2021	42	18,526	746
Tornado	12/21/2021	4	416	104
Tornado	12/21/2021	4	208	52
Tornado	12/21/2021	1	138	138
Tornado	12/21/2021	1	346	346
Tornado	12/21/2021	1	914	914
Tornado	12/21/2021	2	8	4
Tornado	12/21/2021	1	58	58
Tornado	12/21/2021	45	4,230	94
Tornado	12/21/2021	17	3,893	229
Tornado	12/21/2021	7	1,610	230

Q10 - Distribution Excluded Extreme Weather Outage Events

Causation	Date	CI	CMI	L-Bar
Tornado	12/21/2021	4	96	24
Tornado	12/21/2021	1	764	764
Tornado	12/21/2021	2	1,254	627
Tornado	12/21/2021	64	51,968	812
Tornado	12/21/2021	1	945	945
Tornado	12/21/2021	1	85	85
Tornado	12/21/2021	6	3,222	537
Tornado	12/21/2021	302	20,790	88
Tornado	12/21/2021	1	409	409
Tornado	12/21/2021	42	18,716	532
Tornado	12/21/2021	43	5,203	121
Tornado	12/21/2021	1	811	811
Tornado	12/21/2021	1	24	24
Tornado	12/21/2021	1	237	237
Tornado	12/21/2021	1	89	89
Tornado	12/21/2021	105	5,985	57
Tornado	12/21/2021	2	32	16
Tornado	12/21/2021	1	841	841
Tornado	12/21/2021	1	151	151
Tornado	12/21/2021	1	865	865
Tornado	12/21/2021	1	36	36
Tornado	12/21/2021	35	4,305	123
Tornado	12/21/2021	1	25	25
Tornado	12/21/2021	17	6,494	382
Tornado	12/21/2021	1	86	86
Tornado	12/21/2021	10	540	54
Tornado	12/21/2021	1	502	502
Tornado	12/21/2021	2	1,150	575
Tornado	12/21/2021	1	53	53
Tornado	12/21/2021	3	564	188
Tornado	12/21/2021	1	84	84
Tornado	12/21/2021	2	748	374
Tornado	12/21/2021	1	588	588
Tornado	12/21/2021	1	581	581
Tornado	12/21/2021	1	34	34
Tornado	12/21/2021	36	2,628	73

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/1/2021	4	32	8
PLANNED	1/2/2021	3	276	92
PLANNED	1/2/2021	5	546	146
PLANNED	1/2/2021	3	33	11
CUSTOMER REQUEST	1/2/2021	4	1,124	281
PLANNED	1/2/2021	1	70	70
CUSTOMER REQUEST	1/3/2021	7	217	31
PLANNED	1/3/2021	1	181	181
PLANNED	1/3/2021	3	207	69
PLANNED	1/3/2021	2	80	56
PLANNED	1/3/2021	1	44	44
PLANNED	1/3/2021	2	276	138
PLANNED	1/4/2021	2	248	124
PLANNED	1/4/2021	4	180	45
PLANNED	1/4/2021	1	104	104
PLANNED	1/4/2021	3	408	136
PLANNED	1/4/2021	16	1,456	91
PLANNED	1/4/2021	1	112	112
PLANNED	1/4/2021	3	252	84
PLANNED	1/4/2021	4	536	134
PLANNED	1/4/2021	6	738	123
PLANNED	1/4/2021	9	1,233	137
PLANNED	1/4/2021	6	348	58
CUSTOMER REQUEST	1/4/2021	35	13,510	386
PLANNED	1/4/2021	2	218	109
PLANNED	1/4/2021	1	227	227
PLANNED	1/4/2021	3	609	203
CUSTOMER REQUEST	1/4/2021	29	10,730	370
PLANNED	1/4/2021	1	53	53
PLANNED	1/4/2021	8	816	102
PLANNED	1/4/2021	4	272	68
PLANNED	1/4/2021	3	219	73
CUSTOMER REQUEST	1/4/2021	24	7,176	299
CUSTOMER REQUEST	1/4/2021	22	2,034	349
PLANNED	1/4/2021	9	288	32
PLANNED	1/4/2021	1	128	128
PLANNED	1/4/2021	2	46	23
PLANNED	1/4/2021	2	186	93
PLANNED	1/4/2021	11	627	57
PLANNED	1/4/2021	4	48	12
PLANNED	1/4/2021	4	48	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/4/2021	8	2,032	254
PLANNED	1/4/2021	2	112	56
PLANNED	1/4/2021	10	450	45
PLANNED	1/4/2021	7	1,820	260
PLANNED	1/4/2021	7	1,820	260
PLANNED	1/4/2021	7	1,820	260
PLANNED	1/4/2021	7	1,820	260
PLANNED	1/4/2021	8	864	108
PLANNED	1/4/2021	7	112	16
PLANNED	1/4/2021	3	102	34
PLANNED	1/4/2021	1	156	156
PLANNED	1/4/2021	10	260	26
PLANNED	1/4/2021	1	27	27
PLANNED	1/4/2021	1	74	74
PLANNED	1/4/2021	1	104	104
PLANNED	1/4/2021	2	148	74
PLANNED	1/4/2021	1	120	120
PLANNED	1/4/2021	3	63	21
PLANNED	1/4/2021	16	800	50
PLANNED	1/4/2021	6	126	21
PLANNED	1/4/2021	8	208	26
PLANNED	1/4/2021	10	2,180	218
PLANNED	1/4/2021	4	56	14
PLANNED	1/4/2021	2	20	10
PLANNED	1/4/2021	5	135	27
PLANNED	1/4/2021	4	220	55
PLANNED	1/4/2021	1	240	240
PLANNED	1/4/2021	5	310	62
PLANNED	1/4/2021	5	85	17
PLANNED	1/4/2021	2	200	100
PLANNED	1/4/2021	7	700	100
PLANNED	1/4/2021	3	24	8
PLANNED	1/4/2021	1	30	30
PLANNED	1/4/2021	5	235	47
PLANNED	1/4/2021	1	139	139
PLANNED	1/4/2021	8	2,040	255
PLANNED	1/4/2021	5	240	48
PLANNED	1/4/2021	2	34	17
PLANNED	1/4/2021	2	50	25
PLANNED	1/4/2021	7	574	82
PLANNED	1/4/2021	2	106	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/4/2021	6	180	30
PLANNED	1/4/2021	9	90	10
PLANNED	1/4/2021	3	321	107
PLANNED	1/4/2021	5	235	47
PLANNED	1/4/2021	5	165	33
PLANNED	1/4/2021	8	1,320	279
PLANNED	1/4/2021	20	800	40
PLANNED	1/4/2021	1	48	48
PLANNED	1/4/2021	7	84	12
PLANNED	1/4/2021	19	532	28
PLANNED	1/4/2021	4	692	173
PLANNED	1/4/2021	4	52	13
PLANNED	1/4/2021	11	143	13
PLANNED	1/4/2021	1	79	79
PLANNED	1/4/2021	10	90	9
PLANNED	1/4/2021	2	254	127
PLANNED	1/4/2021	4	692	173
PLANNED	1/4/2021	3	516	172
PLANNED	1/4/2021	5	25	5
PLANNED	1/4/2021	93	1,767	19
PLANNED	1/4/2021	5	145	29
PLANNED	1/4/2021	4	164	41
PLANNED	1/4/2021	6	438	73
PLANNED	1/4/2021	2	36	18
PLANNED	1/4/2021	8	1,880	235
PLANNED	1/4/2021	10	690	69
PLANNED	1/4/2021	2	46	23
PLANNED	1/4/2021	1	43	43
PLANNED	1/4/2021	1	64	64
PLANNED	1/4/2021	7	69	17
PLANNED	1/4/2021	7	126	18
PLANNED	1/4/2021	4	136	34
PLANNED	1/4/2021	1	38	38
PLANNED	1/4/2021	2	170	85
PLANNED	1/4/2021	12	960	80
PLANNED	1/4/2021	1	81	81
PLANNED	1/4/2021	1	20	20
PLANNED	1/4/2021	4	28	7
PLANNED	1/4/2021	3	273	91
PLANNED	1/4/2021	6	1,224	204
PLANNED	1/4/2021	9	549	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/4/2021	10	20	2
PLANNED	1/4/2021	4	232	58
PLANNED	1/4/2021	23	644	28
PLANNED	1/4/2021	12	228	19
PLANNED	1/4/2021	5	370	74
PLANNED	1/4/2021	1	25	25
PLANNED	1/4/2021	3	138	46
PLANNED	1/4/2021	12	372	31
PLANNED	1/4/2021	1	53	53
PLANNED	1/4/2021	3	54	18
PLANNED	1/4/2021	8	1,656	207
PLANNED	1/4/2021	1	34	34
PLANNED	1/4/2021	2	300	150
PLANNED	1/4/2021	2	86	43
PLANNED	1/4/2021	1	118	118
PLANNED	1/4/2021	3	66	22
PLANNED	1/4/2021	15	810	54
CUSTOMER REQUEST	1/4/2021	29	1,566	54
PLANNED	1/4/2021	3	114	38
CUSTOMER REQUEST	1/4/2021	35	1,645	47
PLANNED	1/4/2021	7	196	28
PLANNED	1/4/2021	1	27	27
PLANNED	1/4/2021	1	34	34
PLANNED	1/4/2021	2	340	170
PLANNED	1/4/2021	4	152	38
PLANNED	1/4/2021	2	204	102
PLANNED	1/4/2021	3	183	61
PLANNED	1/5/2021	17	3,569	218
PLANNED	1/5/2021	2	198	99
PLANNED	1/5/2021	2	334	167
PLANNED	1/5/2021	8	672	84
PLANNED	1/5/2021	8	1,712	214
PLANNED	1/5/2021	19	2,755	145
PLANNED	1/5/2021	6	486	81
PLANNED	1/5/2021	4	44	11
PLANNED	1/5/2021	6	486	81
PLANNED	1/5/2021	7	567	81
PLANNED	1/5/2021	1	143	143
PLANNED	1/5/2021	2	264	132
PLANNED	1/5/2021	97	8,245	85
PLANNED	1/5/2021	1	57	57

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/5/2021	4	8	2
PLANNED	1/5/2021	2	442	221
PLANNED	1/5/2021	5	130	26
CUSTOMER REQUEST	1/5/2021	46	17,940	390
PLANNED	1/5/2021	3	87	29
PLANNED	1/5/2021	2	220	110
PLANNED	1/5/2021	2	110	55
PLANNED	1/5/2021	5	205	41
PLANNED	1/5/2021	1	135	135
PLANNED	1/5/2021	2	90	45
PLANNED	1/5/2021	11	1,936	176
PLANNED	1/5/2021	1	23	23
PLANNED	1/5/2021	2	228	114
PLANNED	1/5/2021	2	176	88
PLANNED	1/5/2021	8	1,400	175
PLANNED	1/5/2021	7	1,071	153
PLANNED	1/5/2021	2	106	53
PLANNED	1/5/2021	6	1,056	176
PLANNED	1/5/2021	1	230	230
PLANNED	1/5/2021	7	588	84
PLANNED	1/5/2021	16	1,056	66
PLANNED	1/5/2021	6	1,050	175
PLANNED	1/5/2021	7	616	88
PLANNED	1/5/2021	6	504	84
PLANNED	1/5/2021	5	210	42
PLANNED	1/5/2021	36	504	14
PLANNED	1/5/2021	8	296	37
PLANNED	1/5/2021	29	116	4
PLANNED	1/5/2021	3	156	52
PLANNED	1/5/2021	3	24	8
PLANNED	1/5/2021	2	218	109
PLANNED	1/5/2021	10	290	29
PLANNED	1/5/2021	7	686	98
PLANNED	1/5/2021	6	324	54
PLANNED	1/5/2021	1	25	25
PLANNED	1/5/2021	1	123	123
PLANNED	1/5/2021	6	306	51
PLANNED	1/5/2021	1	86	86
CUSTOMER REQUEST	1/5/2021	7	196	28
PLANNED	1/5/2021	3	375	125
PLANNED	1/5/2021	2	184	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/5/2021	48	2,880	60
PLANNED	1/5/2021	4	136	34
PLANNED	1/5/2021	10	180	18
PLANNED	1/5/2021	6	192	32
PLANNED	1/5/2021	3	186	62
PLANNED	1/5/2021	8	1,384	173
CUSTOMER REQUEST	1/5/2021	6	1,818	303
PLANNED	1/5/2021	1	138	138
PLANNED	1/5/2021	28	1,501	87
PLANNED	1/5/2021	2	118	59
PLANNED	1/5/2021	6	300	50
PLANNED	1/5/2021	1	76	76
PLANNED	1/5/2021	2	308	154
PLANNED	1/5/2021	8	80	10
PLANNED	1/5/2021	2	36	18
PLANNED	1/5/2021	2	84	42
PLANNED	1/5/2021	3	18	6
CUSTOMER REQUEST	1/5/2021	10	2,300	230
PLANNED	1/5/2021	8	176	22
PLANNED	1/5/2021	10	710	71
PLANNED	1/5/2021	18	216	12
PLANNED	1/5/2021	7	695	254
PLANNED	1/5/2021	2	266	133
PLANNED	1/5/2021	8	328	41
PLANNED	1/5/2021	5	25	5
PLANNED	1/5/2021	3	48	16
PLANNED	1/5/2021	3	87	29
PLANNED	1/5/2021	6	126	21
PLANNED	1/5/2021	2	36	18
PLANNED	1/5/2021	1	19	19
PLANNED	1/5/2021	11	110	10
PLANNED	1/5/2021	8	376	47
PLANNED	1/5/2021	6	684	114
PLANNED	1/5/2021	2	152	76
PLANNED	1/5/2021	2	46	23
PLANNED	1/5/2021	1	41	41
PLANNED	1/5/2021	2	48	24
PLANNED	1/5/2021	27	540	20
PLANNED	1/5/2021	4	116	29
PLANNED	1/5/2021	4	310	85
PLANNED	1/5/2021	10	230	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/5/2021	4	812	203
PLANNED	1/5/2021	1	24	24
PLANNED	1/5/2021	14	1,008	72
PLANNED	1/5/2021	12	1,008	84
PLANNED	1/5/2021	5	94	70
PLANNED	1/5/2021	3	48	16
PLANNED	1/5/2021	2	58	29
PLANNED	1/5/2021	2	284	142
PLANNED	1/5/2021	5	95	19
PLANNED	1/5/2021	1	42	42
PLANNED	1/5/2021	1	59	59
PLANNED	1/5/2021	2	184	92
PLANNED	1/5/2021	3	447	149
PLANNED	1/5/2021	12	516	43
PLANNED	1/5/2021	6	66	11
PLANNED	1/5/2021	5	280	56
PLANNED	1/5/2021	6	216	36
PLANNED	1/5/2021	4	60	15
PLANNED	1/5/2021	1	21	21
PLANNED	1/5/2021	1	129	129
PLANNED	1/5/2021	2	80	40
PLANNED	1/5/2021	3	123	41
PLANNED	1/5/2021	6	162	27
PLANNED	1/5/2021	2	24	12
PLANNED	1/5/2021	5	805	161
PLANNED	1/5/2021	8	872	109
PLANNED	1/5/2021	2	90	45
PLANNED	1/5/2021	1	31	31
PLANNED	1/5/2021	3	66	22
PLANNED	1/5/2021	2	30	15
PLANNED	1/5/2021	2	70	35
PLANNED	1/5/2021	1	19	19
PLANNED	1/5/2021	1	143	143
PLANNED	1/5/2021	1	110	110
PLANNED	1/5/2021	12	1,752	146
PLANNED	1/5/2021	2	18	9
PLANNED	1/5/2021	4	48	12
PLANNED	1/5/2021	1	54	54
PLANNED	1/5/2021	8	194	68
PLANNED	1/5/2021	4	360	90
PLANNED	1/5/2021	1	127	127

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/5/2021	1	18	18
PLANNED	1/5/2021	1	39	39
PLANNED	1/5/2021	4	280	70
PLANNED	1/5/2021	1	25	25
PLANNED	1/5/2021	6	180	30
PLANNED	1/5/2021	2	84	42
PLANNED	1/5/2021	1	57	57
PLANNED	1/5/2021	11	803	73
PLANNED	1/5/2021	2	84	42
PLANNED	1/6/2021	1	67	67
PLANNED	1/6/2021	3	660	220
PLANNED	1/6/2021	3	1,338	446
PLANNED	1/6/2021	14	1,162	83
PLANNED	1/6/2021	4	144	36
PLANNED	1/6/2021	3	222	74
PLANNED	1/6/2021	1	60	60
PLANNED	1/6/2021	3	300	100
PLANNED	1/6/2021	9	297	33
PLANNED	1/6/2021	51	6,477	127
PLANNED	1/6/2021	2	114	57
CUSTOMER REQUEST	1/6/2021	25	8,600	344
PLANNED	1/6/2021	1	321	321
PLANNED	1/6/2021	8	1,032	129
PLANNED	1/6/2021	7	364	52
PLANNED	1/6/2021	5	20	4
PLANNED	1/6/2021	1	58	58
PLANNED	1/6/2021	6	450	75
CUSTOMER REQUEST	1/6/2021	18	468	26
PLANNED	1/6/2021	5	800	160
CUSTOMER REQUEST	1/6/2021	33	363	11
PLANNED	1/6/2021	5	90	18
PLANNED	1/6/2021	9	891	99
PLANNED	1/6/2021	5	465	93
PLANNED	1/6/2021	1	32	32
PLANNED	1/6/2021	7	763	109
PLANNED	1/6/2021	1	27	27
PLANNED	1/6/2021	3	612	204
PLANNED	1/6/2021	7	763	109
PLANNED	1/6/2021	11	671	61
PLANNED	1/6/2021	13	1,183	91
PLANNED	1/6/2021	7	798	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/6/2021	11	198	18
PLANNED	1/6/2021	1	32	32
CUSTOMER REQUEST	1/6/2021	16	464	29
PLANNED	1/6/2021	1	303	303
PLANNED	1/6/2021	1	74	74
PLANNED	1/6/2021	8	352	44
PLANNED	1/6/2021	13	598	46
PLANNED	1/6/2021	4	388	97
PLANNED	1/6/2021	13	1,267	103
PLANNED	1/6/2021	2	450	225
PLANNED	1/6/2021	2	300	150
PLANNED	1/6/2021	2	94	47
PLANNED	1/6/2021	6	984	164
PLANNED	1/6/2021	2	18	9
PLANNED	1/6/2021	9	283	235
PLANNED	1/6/2021	4	24	6
PLANNED	1/6/2021	4	32	8
PLANNED	1/6/2021	7	336	48
PLANNED	1/6/2021	7	336	48
PLANNED	1/6/2021	8	48	6
PLANNED	1/6/2021	2	154	77
PLANNED	1/6/2021	56	9,744	174
PLANNED	1/6/2021	6	180	30
PLANNED	1/6/2021	60	8,580	143
PLANNED	1/6/2021	2	14	7
PLANNED	1/6/2021	6	888	148
PLANNED	1/6/2021	1	35	35
PLANNED	1/6/2021	2	72	36
PLANNED	1/6/2021	1	159	159
PLANNED	1/6/2021	4	100	25
PLANNED	1/6/2021	8	976	122
PLANNED	1/6/2021	9	450	50
PLANNED	1/6/2021	9	567	63
PLANNED	1/6/2021	2	94	47
PLANNED	1/6/2021	4	100	25
PLANNED	1/6/2021	3	612	204
PLANNED	1/6/2021	1	80	80
PLANNED	1/6/2021	4	312	78
PLANNED	1/6/2021	6	216	36
PLANNED	1/6/2021	8	504	63
PLANNED	1/6/2021	3	48	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	1/6/2021	18	468	26
PLANNED	1/6/2021	3	186	62
PLANNED	1/6/2021	8	264	33
PLANNED	1/6/2021	6	708	118
PLANNED	1/6/2021	4	80	20
PLANNED	1/6/2021	1	21	21
PLANNED	1/6/2021	2	42	21
PLANNED	1/6/2021	25	4,900	196
PLANNED	1/6/2021	3	42	14
PLANNED	1/6/2021	1	36	36
PLANNED	1/6/2021	1	53	53
PLANNED	1/6/2021	5	110	22
PLANNED	1/6/2021	8	296	37
PLANNED	1/6/2021	8	248	31
PLANNED	1/6/2021	9	126	14
PLANNED	1/6/2021	2	16	8
PLANNED	1/6/2021	7	77	11
PLANNED	1/6/2021	4	176	44
PLANNED	1/6/2021	4	40	10
PLANNED	1/6/2021	1	49	49
PLANNED	1/6/2021	2	194	97
PLANNED	1/6/2021	18	1,224	68
PLANNED	1/6/2021	12	804	67
PLANNED	1/6/2021	3	105	35
PLANNED	1/6/2021	7	182	26
PLANNED	1/6/2021	1	114	114
PLANNED	1/6/2021	5	520	104
PLANNED	1/6/2021	4	64	16
PLANNED	1/6/2021	4	312	78
PLANNED	1/6/2021	7	399	57
PLANNED	1/6/2021	10	570	57
PLANNED	1/6/2021	8	1,368	171
PLANNED	1/6/2021	1	15	15
PLANNED	1/6/2021	14	714	51
PLANNED	1/6/2021	8	88	11
PLANNED	1/6/2021	1	34	34
PLANNED	1/6/2021	11	528	48
PLANNED	1/6/2021	2	150	75
PLANNED	1/6/2021	2	162	81
PLANNED	1/6/2021	2	474	237
PLANNED	1/6/2021	4	904	226

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/6/2021	2	172	86
PLANNED	1/6/2021	1	72	72
PLANNED	1/6/2021	1	28	28
PLANNED	1/6/2021	4	84	21
PLANNED	1/6/2021	2	174	87
PLANNED	1/6/2021	1	86	86
PLANNED	1/6/2021	8	400	50
PLANNED	1/6/2021	3	195	65
PLANNED	1/6/2021	2	80	40
PLANNED	1/6/2021	9	54	6
PLANNED	1/6/2021	2	214	107
PLANNED	1/6/2021	3	78	26
PLANNED	1/6/2021	4	748	187
PLANNED	1/6/2021	8	64	8
PLANNED	1/6/2021	2	240	120
CUSTOMER REQUEST	1/6/2021	1	71	71
PLANNED	1/6/2021	6	480	80
PLANNED	1/6/2021	1	5	5
PLANNED	1/6/2021	2	68	34
PLANNED	1/6/2021	3	237	79
PLANNED	1/6/2021	11	594	54
PLANNED	1/6/2021	4	316	79
PLANNED	1/6/2021	1	39	39
PLANNED	1/6/2021	8	168	21
PLANNED	1/6/2021	6	12	2
PLANNED	1/6/2021	3	129	43
CUSTOMER REQUEST	1/6/2021	1	103	103
PLANNED	1/6/2021	4	516	129
PLANNED	1/6/2021	3	182	78
PLANNED	1/6/2021	3	120	40
PLANNED	1/6/2021	9	567	63
PLANNED	1/6/2021	7	357	51
PLANNED	1/6/2021	9	36	4
PLANNED	1/6/2021	1	9	9
PLANNED	1/6/2021	5	710	142
PLANNED	1/6/2021	8	792	99
PLANNED	1/6/2021	14	518	37
PLANNED	1/6/2021	12	72	6
CUSTOMER REQUEST	1/6/2021	51	9,078	178
PLANNED	1/7/2021	1	283	283
PLANNED	1/7/2021	2	194	97

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	1/7/2021	6	474	79
PLANNED	1/7/2021	3	129	43
PLANNED	1/7/2021	1	31	31
PLANNED	1/7/2021	1	56	56
PLANNED	1/7/2021	4	466	164
PLANNED	1/7/2021	1	71	71
PLANNED	1/7/2021	6	438	73
PLANNED	1/7/2021	5	365	73
PLANNED	1/7/2021	8	1,568	196
PLANNED	1/7/2021	7	742	106
PLANNED	1/7/2021	3	297	99
PLANNED	1/7/2021	1	141	141
PLANNED	1/7/2021	2	170	85
PLANNED	1/7/2021	1	24	24
PLANNED	1/7/2021	1	38	38
PLANNED	1/7/2021	1	113	113
PLANNED	1/7/2021	1	34	34
PLANNED	1/7/2021	5	240	48
PLANNED	1/7/2021	9	1,017	113
PLANNED	1/7/2021	27	1,188	44
PLANNED	1/7/2021	4	436	109
PLANNED	1/7/2021	7	784	112
PLANNED	1/7/2021	10	1,320	132
PLANNED	1/7/2021	1	7	7
PLANNED	1/7/2021	1	19	19
CUSTOMER REQUEST	1/7/2021	1	6	6
PLANNED	1/7/2021	1	51	51
PLANNED	1/7/2021	3	339	113
PLANNED	1/7/2021	3	261	87
PLANNED	1/7/2021	1	170	170
CUSTOMER REQUEST	1/7/2021	33	396	12
PLANNED	1/7/2021	8	1,784	223
PLANNED	1/7/2021	1	20	20
PLANNED	1/7/2021	2	34	17
PLANNED	1/7/2021	2	272	136
PLANNED	1/7/2021	3	234	78
PLANNED	1/7/2021	1	65	65
PLANNED	1/7/2021	1	353	353
PLANNED	1/7/2021	6	1,920	320
PLANNED	1/7/2021	29	1,769	61
PLANNED	1/7/2021	6	810	135

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/7/2021	1	4	4
PLANNED	1/7/2021	6	78	13
PLANNED	1/7/2021	1	13	13
PLANNED	1/7/2021	13	1,950	150
PLANNED	1/7/2021	7	217	31
PLANNED	1/7/2021	1	74	74
PLANNED	1/7/2021	13	624	48
PLANNED	1/7/2021	8	808	101
PLANNED	1/7/2021	1	107	107
PLANNED	1/7/2021	1	148	148
PLANNED	1/7/2021	24	648	27
PLANNED	1/7/2021	2	312	156
PLANNED	1/7/2021	3	87	29
PLANNED	1/7/2021	9	342	38
PLANNED	1/7/2021	4	192	48
PLANNED	1/7/2021	2	234	151
PLANNED	1/7/2021	3	537	179
PLANNED	1/7/2021	6	192	32
CUSTOMER REQUEST	1/7/2021	25	6,575	263
PLANNED	1/7/2021	2	198	99
PLANNED	1/7/2021	8	1,120	140
PLANNED	1/7/2021	4	236	59
PLANNED	1/7/2021	1	14	14
PLANNED	1/7/2021	3	141	47
PLANNED	1/7/2021	1	19	19
PLANNED	1/7/2021	1	100	100
PLANNED	1/7/2021	13	754	58
PLANNED	1/7/2021	4	120	30
PLANNED	1/7/2021	1	72	72
PLANNED	1/7/2021	1	23	23
PLANNED	1/7/2021	15	345	23
PLANNED	1/7/2021	1	85	85
PLANNED	1/7/2021	1	97	97
PLANNED	1/7/2021	2	246	123
PLANNED	1/7/2021	1	97	97
PLANNED	1/7/2021	1	97	97
PLANNED	1/7/2021	2	246	123
PLANNED	1/7/2021	5	780	156
PLANNED	1/7/2021	19	304	16
PLANNED	1/7/2021	1	176	176
PLANNED	1/7/2021	1	64	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/7/2021	4	744	193
PLANNED	1/7/2021	6	516	86
PLANNED	1/7/2021	4	308	77
PLANNED	1/7/2021	5	615	123
PLANNED	1/7/2021	8	680	85
PLANNED	1/7/2021	4	456	114
PLANNED	1/7/2021	16	224	14
PLANNED	1/7/2021	4	48	12
PLANNED	1/7/2021	2	128	64
PLANNED	1/7/2021	2	142	71
PLANNED	1/7/2021	4	56	14
PLANNED	1/7/2021	8	160	20
PLANNED	1/7/2021	5	145	29
PLANNED	1/7/2021	4	164	41
PLANNED	1/7/2021	33	1,221	37
PLANNED	1/7/2021	4	112	28
PLANNED	1/7/2021	1	44	44
PLANNED	1/7/2021	8	520	65
PLANNED	1/7/2021	8	552	69
PLANNED	1/7/2021	17	2,259	178
PLANNED	1/7/2021	1	5	5
PLANNED	1/7/2021	3	96	32
PLANNED	1/7/2021	6	264	44
PLANNED	1/7/2021	7	483	69
PLANNED	1/7/2021	1	53	53
CUSTOMER REQUEST	1/7/2021	1	42	42
PLANNED	1/7/2021	1	1	1
PLANNED	1/7/2021	2	52	26
PLANNED	1/7/2021	4	48	12
PLANNED	1/7/2021	9	333	37
PLANNED	1/7/2021	8	296	37
PLANNED	1/7/2021	4	440	110
PLANNED	1/7/2021	9	162	18
PLANNED	1/7/2021	8	536	67
PLANNED	1/7/2021	1	97	97
PLANNED	1/7/2021	2	16	8
PLANNED	1/7/2021	3	60	20
PLANNED	1/7/2021	1	87	87
PLANNED	1/7/2021	5	196	40
PLANNED	1/7/2021	3	144	48
PLANNED	1/7/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/7/2021	3	162	54
PLANNED	1/7/2021	1	16	16
PLANNED	1/7/2021	16	1,264	79
PLANNED	1/7/2021	2	496	248
PLANNED	1/7/2021	4	88	22
PLANNED	1/7/2021	2	186	93
PLANNED	1/7/2021	1	114	114
PLANNED	1/7/2021	23	1,035	45
PLANNED	1/7/2021	6	240	40
CUSTOMER REQUEST	1/7/2021	1	428	428
PLANNED	1/7/2021	1	27	27
PLANNED	1/7/2021	4	104	26
PLANNED	1/7/2021	6	528	88
PLANNED	1/7/2021	1	108	108
PLANNED	1/7/2021	9	225	25
PLANNED	1/7/2021	29	261	9
PLANNED	1/7/2021	16	128	8
PLANNED	1/7/2021	1	18	18
CUSTOMER REQUEST	1/7/2021	7	42	6
PLANNED	1/7/2021	2	52	26
PLANNED	1/7/2021	1	46	46
PLANNED	1/7/2021	16	160	10
PLANNED	1/7/2021	4	88	22
PLANNED	1/7/2021	1	61	61
PLANNED	1/7/2021	2	16	8
PLANNED	1/7/2021	2	64	32
PLANNED	1/7/2021	1	109	109
PLANNED	1/7/2021	3	330	110
PLANNED	1/7/2021	2	214	107
PLANNED	1/7/2021	1	50	50
PLANNED	1/7/2021	1	39	39
PLANNED	1/7/2021	12	192	16
PLANNED	1/7/2021	6	42	7
PLANNED	1/7/2021	1	108	108
PLANNED	1/7/2021	7	756	108
PLANNED	1/7/2021	23	3,519	153
PLANNED	1/7/2021	2	34	17
PLANNED	1/7/2021	2	775	389
PLANNED	1/7/2021	7	1,218	174
PLANNED	1/7/2021	4	904	226
PLANNED	1/7/2021	2	90	45

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/8/2021	4	264	66
PLANNED	1/8/2021	6	156	26
PLANNED	1/8/2021	2	120	60
PLANNED	1/8/2021	4	80	20
PLANNED	1/8/2021	3	291	97
PLANNED	1/8/2021	4	448	112
PLANNED	1/8/2021	6	582	97
PLANNED	1/8/2021	2	62	31
PLANNED	1/8/2021	3	15	5
PLANNED	1/8/2021	5	250	50
PLANNED	1/8/2021	3	150	50
CUSTOMER REQUEST	1/8/2021	1	327	327
PLANNED	1/8/2021	1	104	104
PLANNED	1/8/2021	4	744	186
PLANNED	1/8/2021	5	200	40
PLANNED	1/8/2021	2	96	48
PLANNED	1/8/2021	18	846	47
PLANNED	1/8/2021	2	286	143
PLANNED	1/8/2021	3	240	80
PLANNED	1/8/2021	8	1,160	145
PLANNED	1/8/2021	3	171	57
PLANNED	1/8/2021	8	1,128	141
PLANNED	1/8/2021	8	1,128	141
PLANNED	1/8/2021	9	1,260	140
CUSTOMER REQUEST	1/8/2021	12	6,264	573
PLANNED	1/8/2021	7	980	140
PLANNED	1/8/2021	8	672	84
CUSTOMER REQUEST	1/8/2021	13	3,706	410
CUSTOMER REQUEST	1/8/2021	7	49	7
PLANNED	1/8/2021	3	369	123
PLANNED	1/8/2021	2	134	67
PLANNED	1/8/2021	2	52	26
PLANNED	1/8/2021	1	91	91
PLANNED	1/8/2021	1	108	108
CUSTOMER REQUEST	1/8/2021	1	4,303	4,303
PLANNED	1/8/2021	4	228	57
PLANNED	1/8/2021	13	2,418	186
PLANNED	1/8/2021	7	70	10
PLANNED	1/8/2021	6	192	32
PLANNED	1/8/2021	5	200	40
CUSTOMER REQUEST	1/8/2021	25	6,700	268

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/8/2021	10	60	6
PLANNED	1/8/2021	11	242	22
PLANNED	1/8/2021	8	8	1
PLANNED	1/8/2021	1	99	99
PLANNED	1/8/2021	38	2,204	58
PLANNED	1/8/2021	8	480	60
PLANNED	1/8/2021	4	152	38
PLANNED	1/8/2021	4	276	69
PLANNED	1/8/2021	1	68	68
PLANNED	1/8/2021	13	273	21
PLANNED	1/8/2021	3	81	27
PLANNED	1/8/2021	3	279	93
PLANNED	1/8/2021	1	18	18
PLANNED	1/8/2021	8	1,432	179
PLANNED	1/8/2021	3	219	73
PLANNED	1/8/2021	4	100	25
PLANNED	1/8/2021	2	362	182
PLANNED	1/8/2021	3	552	184
PLANNED	1/8/2021	5	265	53
PLANNED	1/8/2021	8	328	41
PLANNED	1/8/2021	2	48	24
PLANNED	1/8/2021	3	57	19
PLANNED	1/8/2021	4	64	16
PLANNED	1/8/2021	2	162	81
PLANNED	1/8/2021	1	34	34
PLANNED	1/8/2021	18	1,836	102
PLANNED	1/8/2021	2	66	33
PLANNED	1/8/2021	4	120	30
PLANNED	1/8/2021	19	4,839	289
PLANNED	1/8/2021	1	369	369
PLANNED	1/8/2021	6	132	22
PLANNED	1/8/2021	28	2,492	89
PLANNED	1/8/2021	14	952	68
CUSTOMER REQUEST	1/8/2021	1	294	294
PLANNED	1/8/2021	4	180	45
PLANNED	1/8/2021	5	125	25
PLANNED	1/8/2021	8	2,248	281
PLANNED	1/8/2021	1	8	8
PLANNED	1/8/2021	10	1,710	171
PLANNED	1/8/2021	1	53	53
PLANNED	1/8/2021	3	51	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/8/2021	6	156	26
PLANNED	1/8/2021	7	707	101
PLANNED	1/8/2021	4	404	101
PLANNED	1/8/2021	5	305	61
PLANNED	1/8/2021	7	707	101
PLANNED	1/8/2021	8	120	15
PLANNED	1/8/2021	4	48	12
PLANNED	1/8/2021	8	1,000	125
PLANNED	1/8/2021	33	2,772	84
PLANNED	1/8/2021	4	56	14
PLANNED	1/8/2021	3	84	28
PLANNED	1/8/2021	3	381	127
PLANNED	1/8/2021	2	56	28
PLANNED	1/8/2021	8	160	20
PLANNED	1/8/2021	13	299	23
PLANNED	1/8/2021	3	57	19
PLANNED	1/8/2021	2	26	13
PLANNED	1/8/2021	3	87	29
PLANNED	1/8/2021	8	1,010	128
PLANNED	1/8/2021	10	150	15
PLANNED	1/8/2021	6	288	48
PLANNED	1/8/2021	1	63	63
PLANNED	1/8/2021	7	42	6
PLANNED	1/8/2021	2	26	13
PLANNED	1/8/2021	8	56	7
PLANNED	1/8/2021	3	303	101
PLANNED	1/8/2021	16	352	22
PLANNED	1/8/2021	1	63	63
PLANNED	1/8/2021	13	182	14
PLANNED	1/8/2021	1	84	84
PLANNED	1/9/2021	1	308	308
PLANNED	1/9/2021	4	224	56
PLANNED	1/9/2021	24	552	23
PLANNED	1/9/2021	1	46	46
PLANNED	1/9/2021	1	110	110
PLANNED	1/9/2021	10	1,270	127
PLANNED	1/9/2021	10	1,320	132
PLANNED	1/9/2021	6	780	130
PLANNED	1/9/2021	36	19,440	540
PLANNED	1/9/2021	12	564	47
PLANNED	1/9/2021	105	25,410	242

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/9/2021	3	111	37
PLANNED	1/9/2021	8	328	41
PLANNED	1/9/2021	2	168	84
PLANNED	1/9/2021	7	105	15
PLANNED	1/9/2021	25	3,125	125
PLANNED	1/9/2021	1	72	72
PLANNED	1/9/2021	9	432	48
PLANNED	1/9/2021	13	351	27
PLANNED	1/9/2021	9	2,205	245
CUSTOMER REQUEST	1/9/2021	1	92	92
PLANNED	1/10/2021	35	1,785	51
CUSTOMER REQUEST	1/10/2021	1	14	14
PLANNED	1/10/2021	1	184	184
PLANNED	1/10/2021	3	417	139
PLANNED	1/10/2021	6	264	44
PLANNED	1/10/2021	1	89	89
PLANNED	1/10/2021	4	108	27
PLANNED	1/10/2021	1	78	78
PLANNED	1/10/2021	3	126	42
PLANNED	1/10/2021	4	92	23
PLANNED	1/10/2021	5	45	9
CUSTOMER REQUEST	1/10/2021	11	440	40
PLANNED	1/10/2021	4	80	20
PLANNED	1/10/2021	2	260	130
PLANNED	1/10/2021	2	726	363
PLANNED	1/10/2021	11	275	25
PLANNED	1/10/2021	3	222	74
CUSTOMER REQUEST	1/10/2021	14	434	31
PLANNED	1/10/2021	2	178	89
PLANNED	1/10/2021	5	280	56
CUSTOMER REQUEST	1/10/2021	1	201	201
PLANNED	1/11/2021	4	212	53
PLANNED	1/11/2021	2	10	5
PLANNED	1/11/2021	4	660	165
CUSTOMER REQUEST	1/11/2021	1	156	156
PLANNED	1/11/2021	4	404	101
PLANNED	1/11/2021	4	408	102
PLANNED	1/11/2021	5	510	102
PLANNED	1/11/2021	6	798	133
PLANNED	1/11/2021	2	102	51
PLANNED	1/11/2021	4	28	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/11/2021	32	2,400	75
PLANNED	1/11/2021	5	75	15
PLANNED	1/11/2021	6	204	34
PLANNED	1/11/2021	7	686	98
PLANNED	1/11/2021	3	99	33
PLANNED	1/11/2021	12	1,320	110
PLANNED	1/11/2021	2	102	51
PLANNED	1/11/2021	1	48	48
PLANNED	1/11/2021	1	110	110
PLANNED	1/11/2021	2	56	28
PLANNED	1/11/2021	6	486	81
PLANNED	1/11/2021	2	116	58
PLANNED	1/11/2021	3	243	81
PLANNED	1/11/2021	5	145	29
PLANNED	1/11/2021	1	79	79
PLANNED	1/11/2021	3	63	21
PLANNED	1/11/2021	8	128	16
PLANNED	1/11/2021	5	115	23
PLANNED	1/11/2021	2	30	15
PLANNED	1/11/2021	8	184	23
PLANNED	1/11/2021	1	77	77
PLANNED	1/11/2021	1	68	68
PLANNED	1/11/2021	4	544	136
PLANNED	1/11/2021	10	190	19
PLANNED	1/11/2021	1	64	64
PLANNED	1/11/2021	1	42	42
PLANNED	1/11/2021	61	5,917	97
PLANNED	1/11/2021	11	88	8
PLANNED	1/11/2021	4	300	75
PLANNED	1/11/2021	3	93	31
PLANNED	1/11/2021	37	2,627	71
PLANNED	1/11/2021	9	1,017	113
PLANNED	1/11/2021	2	130	65
PLANNED	1/11/2021	4	84	21
PLANNED	1/11/2021	10	70	7
PLANNED	1/11/2021	7	1,022	146
PLANNED	1/11/2021	3	396	132
PLANNED	1/11/2021	3	165	55
PLANNED	1/11/2021	2	398	199
PLANNED	1/11/2021	3	1,197	399
PLANNED	1/11/2021	11	825	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/11/2021	2	496	248
PLANNED	1/11/2021	7	581	83
PLANNED	1/11/2021	9	351	39
CUSTOMER REQUEST	1/11/2021	9	261	29
PLANNED	1/11/2021	98	22,246	227
PLANNED	1/11/2021	1	427	427
PLANNED	1/11/2021	4	64	16
PLANNED	1/11/2021	9	828	92
PLANNED	1/11/2021	1	46	46
PLANNED	1/11/2021	10	870	87
PLANNED	1/11/2021	13	1,385	191
PLANNED	1/11/2021	5	35	7
PLANNED	1/11/2021	5	290	58
PLANNED	1/11/2021	7	525	75
PLANNED	1/11/2021	1	16	16
PLANNED	1/11/2021	9	2,043	227
PLANNED	1/11/2021	1	83	83
PLANNED	1/11/2021	4	40	10
PLANNED	1/11/2021	7	126	18
PLANNED	1/11/2021	4	88	22
PLANNED	1/11/2021	2	244	122
PLANNED	1/11/2021	5	430	86
PLANNED	1/11/2021	7	287	41
PLANNED	1/11/2021	4	340	85
PLANNED	1/11/2021	3	165	55
PLANNED	1/11/2021	4	192	48
PLANNED	1/11/2021	4	88	22
PLANNED	1/11/2021	20	620	31
PLANNED	1/11/2021	1	11	11
PLANNED	1/11/2021	4	4	1
PLANNED	1/11/2021	4	236	59
PLANNED	1/11/2021	2	342	171
PLANNED	1/11/2021	2	284	142
PLANNED	1/11/2021	45	3,105	69
PLANNED	1/11/2021	10	260	26
PLANNED	1/11/2021	8	344	43
PLANNED	1/11/2021	8	344	43
PLANNED	1/11/2021	1	18	18
PLANNED	1/11/2021	2	70	35
PLANNED	1/11/2021	1	82	82
PLANNED	1/11/2021	6	1,002	167

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/11/2021	4	60	15
PLANNED	1/11/2021	8	672	84
PLANNED	1/11/2021	6	612	102
PLANNED	1/11/2021	3	108	36
PLANNED	1/11/2021	2	264	132
PLANNED	1/11/2021	11	396	36
PLANNED	1/11/2021	8	288	36
PLANNED	1/11/2021	1	32	32
PLANNED	1/11/2021	5	150	30
PLANNED	1/11/2021	2	34	17
PLANNED	1/11/2021	1	28	28
PLANNED	1/11/2021	5	325	65
PLANNED	1/11/2021	6	234	39
PLANNED	1/11/2021	3	57	19
PLANNED	1/11/2021	1	3	3
PLANNED	1/11/2021	1	58	58
PLANNED	1/11/2021	8	368	46
PLANNED	1/11/2021	2	96	48
PLANNED	1/11/2021	1	68	68
PLANNED	1/11/2021	1	79	79
PLANNED	1/11/2021	2	110	55
PLANNED	1/11/2021	1	16	16
PLANNED	1/11/2021	2	190	95
PLANNED	1/11/2021	1	32	32
PLANNED	1/11/2021	1	29	29
PLANNED	1/11/2021	6	324	54
PLANNED	1/11/2021	1	68	68
PLANNED	1/11/2021	6	426	71
PLANNED	1/11/2021	1	112	112
PLANNED	1/11/2021	1	144	144
CUSTOMER REQUEST	1/11/2021	1	204	204
PLANNED	1/11/2021	1	32	32
CUSTOMER REQUEST	1/11/2021	1	39	39
CUSTOMER REQUEST	1/11/2021	1	204	204
PLANNED	1/11/2021	2	190	95
PLANNED	1/11/2021	1	88	88
PLANNED	1/11/2021	1	30	30
CUSTOMER REQUEST	1/12/2021	516	21,156	41
PLANNED	1/12/2021	11	2,805	255
PLANNED	1/12/2021	17	1,734	102
PLANNED	1/12/2021	7	448	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/12/2021	5	445	89
PLANNED	1/12/2021	2	72	36
PLANNED	1/12/2021	1	74	74
PLANNED	1/12/2021	4	164	41
PLANNED	1/12/2021	6	1,462	427
PLANNED	1/12/2021	1	201	201
PLANNED	1/12/2021	8	152	19
PLANNED	1/12/2021	3	132	44
PLANNED	1/12/2021	9	531	59
PLANNED	1/12/2021	1	94	94
CUSTOMER REQUEST	1/12/2021	5	355	71
PLANNED	1/12/2021	5	15	3
PLANNED	1/12/2021	1	311	311
PLANNED	1/12/2021	5	10	2
PLANNED	1/12/2021	8	880	110
PLANNED	1/12/2021	29	4,669	161
PLANNED	1/12/2021	1	64	64
PLANNED	1/12/2021	3	273	91
PLANNED	1/12/2021	8	272	34
PLANNED	1/12/2021	8	328	41
PLANNED	1/12/2021	1	81	81
PLANNED	1/12/2021	3	201	67
PLANNED	1/12/2021	9	864	96
PLANNED	1/12/2021	3	237	79
PLANNED	1/12/2021	8	840	105
PLANNED	1/12/2021	8	160	20
PLANNED	1/12/2021	5	680	136
PLANNED	1/12/2021	1	3	3
PLANNED	1/12/2021	2	18	9
PLANNED	1/12/2021	12	2,208	184
PLANNED	1/12/2021	9	1,467	163
PLANNED	1/12/2021	2	42	21
PLANNED	1/12/2021	1	24	24
PLANNED	1/12/2021	4	116	29
PLANNED	1/12/2021	7	518	74
PLANNED	1/12/2021	2	200	100
PLANNED	1/12/2021	9	387	43
PLANNED	1/12/2021	19	475	25
PLANNED	1/12/2021	2	78	39
PLANNED	1/12/2021	5	195	39
PLANNED	1/12/2021	12	1,176	98

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/12/2021	7	623	89
PLANNED	1/12/2021	8	736	92
PLANNED	1/12/2021	8	688	86
PLANNED	1/12/2021	1	10	10
PLANNED	1/12/2021	4	524	131
PLANNED	1/12/2021	4	136	34
PLANNED	1/12/2021	2	146	73
PLANNED	1/12/2021	11	946	86
PLANNED	1/12/2021	9	1,080	120
PLANNED	1/12/2021	3	96	32
PLANNED	1/12/2021	5	225	45
PLANNED	1/12/2021	6	138	23
PLANNED	1/12/2021	16	448	28
PLANNED	1/12/2021	4	420	105
PLANNED	1/12/2021	2	88	44
PLANNED	1/12/2021	10	170	17
PLANNED	1/12/2021	2	156	78
PLANNED	1/12/2021	1	68	68
PLANNED	1/12/2021	2	140	70
PLANNED	1/12/2021	7	182	26
PLANNED	1/12/2021	5	245	49
PLANNED	1/12/2021	1	14	14
PLANNED	1/12/2021	6	468	78
PLANNED	1/12/2021	4	76	19
PLANNED	1/12/2021	8	168	21
PLANNED	1/12/2021	5	210	42
PLANNED	1/12/2021	4	108	27
PLANNED	1/12/2021	5	1,390	278
PLANNED	1/12/2021	3	138	46
PLANNED	1/12/2021	7	511	73
PLANNED	1/12/2021	7	273	39
PLANNED	1/12/2021	12	780	65
PLANNED	1/12/2021	4	256	64
PLANNED	1/12/2021	7	462	66
PLANNED	1/12/2021	7	511	73
PLANNED	1/12/2021	10	650	65
PLANNED	1/12/2021	8	152	19
PLANNED	1/12/2021	4	484	121
PLANNED	1/12/2021	1	14	14
PLANNED	1/12/2021	1	29	29
PLANNED	1/12/2021	6	288	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/12/2021	1	59	59
PLANNED	1/12/2021	4	4	1
PLANNED	1/12/2021	2	232	116
CUSTOMER REQUEST	1/12/2021	1	153	153
PLANNED	1/12/2021	1	49	49
PLANNED	1/12/2021	4	60	15
PLANNED	1/12/2021	6	678	113
PLANNED	1/12/2021	2	70	35
PLANNED	1/12/2021	9	459	51
PLANNED	1/12/2021	6	324	54
PLANNED	1/12/2021	4	28	7
PLANNED	1/12/2021	1	122	122
PLANNED	1/12/2021	19	779	41
PLANNED	1/12/2021	1	31	31
PLANNED	1/12/2021	3	87	29
PLANNED	1/12/2021	1	3	3
PLANNED	1/12/2021	2	98	49
PLANNED	1/12/2021	4	144	36
PLANNED	1/12/2021	2	84	42
PLANNED	1/12/2021	4	56	14
PLANNED	1/12/2021	1	120	120
PLANNED	1/12/2021	8	1,280	160
PLANNED	1/12/2021	4	48	12
PLANNED	1/12/2021	11	1,203	111
PLANNED	1/12/2021	1	7	7
CUSTOMER REQUEST	1/12/2021	46	6,808	148
PLANNED	1/12/2021	1	91	91
PLANNED	1/13/2021	1	192	192
PLANNED	1/13/2021	3	198	66
CUSTOMER REQUEST	1/13/2021	1	127	127
PLANNED	1/13/2021	3	399	133
PLANNED	1/13/2021	7	385	55
PLANNED	1/13/2021	6	18	3
PLANNED	1/13/2021	2	356	178
PLANNED	1/13/2021	7	392	56
PLANNED	1/13/2021	8	416	52
PLANNED	1/13/2021	6	300	50
PLANNED	1/13/2021	2	228	114
PLANNED	1/13/2021	1	111	111
PLANNED	1/13/2021	6	198	33
PLANNED	1/13/2021	42	1,302	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/13/2021	1	97	97
PLANNED	1/13/2021	7	1,645	235
PLANNED	1/13/2021	4	856	214
CUSTOMER REQUEST	1/13/2021	1	290	290
PLANNED	1/13/2021	1	59	59
PLANNED	1/13/2021	8	168	21
PLANNED	1/13/2021	2	28	14
PLANNED	1/13/2021	1	182	182
PLANNED	1/13/2021	6	378	63
PLANNED	1/13/2021	8	1,056	132
PLANNED	1/13/2021	1	92	92
PLANNED	1/13/2021	4	164	41
PLANNED	1/13/2021	2	68	34
PLANNED	1/13/2021	7	693	99
PLANNED	1/13/2021	6	624	104
PLANNED	1/13/2021	5	275	55
PLANNED	1/13/2021	7	665	95
PLANNED	1/13/2021	10	530	53
PLANNED	1/13/2021	6	438	73
PLANNED	1/13/2021	1	31	31
PLANNED	1/13/2021	2	242	137
PLANNED	1/13/2021	13	494	38
PLANNED	1/13/2021	1	64	64
PLANNED	1/13/2021	1	225	225
PLANNED	1/13/2021	5	790	158
PLANNED	1/13/2021	1	27	27
PLANNED	1/13/2021	10	1,490	149
PLANNED	1/13/2021	1	153	153
PLANNED	1/13/2021	1	283	283
PLANNED	1/13/2021	8	568	71
PLANNED	1/13/2021	3	21	7
CUSTOMER REQUEST	1/13/2021	8	520	65
PLANNED	1/13/2021	3	39	13
PLANNED	1/13/2021	1	108	108
PLANNED	1/13/2021	23	713	31
PLANNED	1/13/2021	1	33	33
PLANNED	1/13/2021	11	880	80
PLANNED	1/13/2021	1	44	44
PLANNED	1/13/2021	5	510	102
PLANNED	1/13/2021	6	744	124
PLANNED	1/13/2021	7	977	163

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/13/2021	9	891	99
PLANNED	1/13/2021	15	4,447	372
PLANNED	1/13/2021	5	235	47
PLANNED	1/13/2021	2	70	35
PLANNED	1/13/2021	1	114	114
PLANNED	1/13/2021	4	136	34
PLANNED	1/13/2021	15	675	45
PLANNED	1/13/2021	41	984	24
PLANNED	1/13/2021	4	144	36
PLANNED	1/13/2021	5	125	25
PLANNED	1/13/2021	2	24	12
PLANNED	1/13/2021	6	168	28
PLANNED	1/13/2021	4	108	27
PLANNED	1/13/2021	9	378	42
PLANNED	1/13/2021	3	105	35
PLANNED	1/13/2021	5	1,110	222
PLANNED	1/13/2021	1	227	227
PLANNED	1/13/2021	1	195	195
PLANNED	1/13/2021	1	36	36
PLANNED	1/13/2021	11	385	35
PLANNED	1/13/2021	1	71	71
PLANNED	1/13/2021	4	72	18
PLANNED	1/13/2021	2	126	63
PLANNED	1/13/2021	4	260	65
PLANNED	1/13/2021	8	520	65
PLANNED	1/13/2021	1	39	39
PLANNED	1/13/2021	11	429	39
PLANNED	1/13/2021	6	54	9
PLANNED	1/13/2021	1	16	16
PLANNED	1/13/2021	14	730	70
PLANNED	1/13/2021	4	52	13
PLANNED	1/13/2021	10	250	25
CUSTOMER REQUEST	1/13/2021	1	97	97
PLANNED	1/13/2021	6	114	19
PLANNED	1/13/2021	10	310	31
PLANNED	1/13/2021	2	26	13
PLANNED	1/13/2021	56	12,656	226
PLANNED	1/13/2021	11	1,012	92
PLANNED	1/13/2021	4	80	20
PLANNED	1/13/2021	8	544	68
PLANNED	1/13/2021	2	272	136

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/13/2021	2	48	24
PLANNED	1/13/2021	7	105	15
PLANNED	1/13/2021	5	105	21
PLANNED	1/13/2021	3	165	55
PLANNED	1/13/2021	4	100	25
PLANNED	1/13/2021	2	48	24
PLANNED	1/13/2021	5	95	19
PLANNED	1/13/2021	8	416	52
PLANNED	1/13/2021	6	1,140	190
CUSTOMER REQUEST	1/13/2021	11	374	34
PLANNED	1/13/2021	1	72	72
PLANNED	1/13/2021	1	8	8
PLANNED	1/13/2021	3	165	55
PLANNED	1/13/2021	2	22	11
PLANNED	1/13/2021	8	632	79
PLANNED	1/13/2021	9	657	73
PLANNED	1/13/2021	8	584	73
PLANNED	1/13/2021	8	584	73
CUSTOMER REQUEST	1/13/2021	4	248	62
PLANNED	1/13/2021	2	194	97
PLANNED	1/13/2021	7	371	53
PLANNED	1/13/2021	22	528	24
PLANNED	1/13/2021	1	142	142
PLANNED	1/13/2021	7	189	27
PLANNED	1/13/2021	7	518	74
PLANNED	1/13/2021	8	752	94
PLANNED	1/13/2021	21	1,848	88
PLANNED	1/13/2021	12	1,104	92
PLANNED	1/13/2021	2	230	115
PLANNED	1/13/2021	3	183	61
PLANNED	1/13/2021	1	110	110
PLANNED	1/13/2021	1	62	62
PLANNED	1/13/2021	4	196	49
PLANNED	1/13/2021	4	372	93
CUSTOMER REQUEST	1/13/2021	1	63	63
PLANNED	1/13/2021	2	238	119
PLANNED	1/13/2021	7	1,099	157
PLANNED	1/13/2021	2	238	119
PLANNED	1/13/2021	86	10,664	124
PLANNED	1/14/2021	3	162	54
PLANNED	1/14/2021	2	124	62

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/14/2021	13	1,417	109
PLANNED	1/14/2021	4	120	30
PLANNED	1/14/2021	1	69	69
PLANNED	1/14/2021	1	49	49
PLANNED	1/14/2021	6	312	52
PLANNED	1/14/2021	1	101	101
PLANNED	1/14/2021	11	1,771	370
PLANNED	1/14/2021	6	654	109
PLANNED	1/14/2021	2	94	47
PLANNED	1/14/2021	1	99	99
PLANNED	1/14/2021	4	144	36
PLANNED	1/14/2021	6	108	18
PLANNED	1/14/2021	1	99	99
PLANNED	1/14/2021	2	270	135
PLANNED	1/14/2021	8	352	44
PLANNED	1/14/2021	1	81	81
PLANNED	1/14/2021	1	128	128
CUSTOMER REQUEST	1/14/2021	120	9,480	79
PLANNED	1/14/2021	3	219	73
PLANNED	1/14/2021	3	513	171
PLANNED	1/14/2021	10	1,490	149
PLANNED	1/14/2021	4	232	58
PLANNED	1/14/2021	23	2,139	93
PLANNED	1/14/2021	22	2,398	109
PLANNED	1/14/2021	4	160	40
PLANNED	1/14/2021	1	202	202
PLANNED	1/14/2021	1	3	3
PLANNED	1/14/2021	2	186	93
PLANNED	1/14/2021	2	160	80
PLANNED	1/14/2021	11	308	28
PLANNED	1/14/2021	1	74	74
PLANNED	1/14/2021	10	960	96
PLANNED	1/14/2021	2	59	35
PLANNED	1/14/2021	2	82	41
PLANNED	1/14/2021	5	450	90
PLANNED	1/14/2021	2	656	328
PLANNED	1/14/2021	1	164	164
PLANNED	1/14/2021	7	266	38
PLANNED	1/14/2021	4	44	11
CUSTOMER REQUEST	1/14/2021	4	28	7
PLANNED	1/14/2021	8	448	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/14/2021	6	228	38
PLANNED	1/14/2021	6	348	58
PLANNED	1/14/2021	4	848	212
PLANNED	1/14/2021	2	526	263
PLANNED	1/14/2021	5	50	10
PLANNED	1/14/2021	2	300	150
PLANNED	1/14/2021	6	786	131
PLANNED	1/14/2021	10	160	16
PLANNED	1/14/2021	1	21	21
PLANNED	1/14/2021	2	130	65
PLANNED	1/14/2021	7	497	71
PLANNED	1/14/2021	2	144	72
PLANNED	1/14/2021	2	92	46
PLANNED	1/14/2021	5	160	32
PLANNED	1/14/2021	14	3,514	251
PLANNED	1/14/2021	12	528	44
PLANNED	1/14/2021	9	963	107
PLANNED	1/14/2021	2	88	44
PLANNED	1/14/2021	12	1,272	106
PLANNED	1/14/2021	4	80	20
PLANNED	1/14/2021	4	68	17
PLANNED	1/14/2021	207	28,566	138
PLANNED	1/14/2021	8	1,668	282
PLANNED	1/14/2021	6	570	95
PLANNED	1/14/2021	8	128	16
PLANNED	1/14/2021	1	209	209
PLANNED	1/14/2021	3	33	11
PLANNED	1/14/2021	5	215	43
PLANNED	1/14/2021	2	16	8
PLANNED	1/14/2021	1	116	116
PLANNED	1/14/2021	1	122	122
PLANNED	1/14/2021	1	22	22
PLANNED	1/14/2021	6	900	150
PLANNED	1/14/2021	9	918	102
PLANNED	1/14/2021	3	252	84
PLANNED	1/14/2021	5	230	46
PLANNED	1/14/2021	7	357	51
PLANNED	1/14/2021	1	296	296
PLANNED	1/14/2021	5	1,040	208
PLANNED	1/14/2021	4	12	3
PLANNED	1/14/2021	9	333	37

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/14/2021	6	588	98
PLANNED	1/14/2021	4	56	14
PLANNED	1/14/2021	4	88	22
PLANNED	1/14/2021	4	148	37
PLANNED	1/14/2021	9	1,062	118
PLANNED	1/14/2021	6	1,266	211
PLANNED	1/14/2021	2	174	87
PLANNED	1/14/2021	22	1,584	72
PLANNED	1/14/2021	6	132	22
PLANNED	1/14/2021	3	60	20
PLANNED	1/14/2021	5	50	10
PLANNED	1/14/2021	8	224	28
PLANNED	1/14/2021	14	2,450	175
PLANNED	1/14/2021	2	142	71
PLANNED	1/14/2021	6	228	38
PLANNED	1/14/2021	6	696	116
PLANNED	1/14/2021	1	117	117
PLANNED	1/14/2021	4	196	49
PLANNED	1/14/2021	2	108	54
PLANNED	1/14/2021	7	217	31
PLANNED	1/14/2021	11	396	36
PLANNED	1/14/2021	4	140	35
PLANNED	1/14/2021	6	108	18
PLANNED	1/14/2021	2	92	46
PLANNED	1/14/2021	1	28	28
PLANNED	1/14/2021	3	183	61
PLANNED	1/14/2021	6	120	20
PLANNED	1/14/2021	3	45	15
PLANNED	1/14/2021	6	162	27
PLANNED	1/14/2021	4	464	116
PLANNED	1/14/2021	14	1,974	141
PLANNED	1/14/2021	5	55	11
PLANNED	1/14/2021	9	342	38
CUSTOMER REQUEST	1/14/2021	134	2,680	20
PLANNED	1/14/2021	2	50	25
PLANNED	1/14/2021	3	141	47
PLANNED	1/14/2021	3	192	64
PLANNED	1/14/2021	3	369	123
PLANNED	1/14/2021	12	300	25
PLANNED	1/14/2021	1	91	91
PLANNED	1/14/2021	16	208	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/14/2021	1	91	91
PLANNED	1/14/2021	1	152	152
PLANNED	1/14/2021	8	304	38
PLANNED	1/14/2021	4	96	24
PLANNED	1/14/2021	5	260	52
PLANNED	1/14/2021	3	282	94
PLANNED	1/14/2021	5	430	86
PLANNED	1/14/2021	2	68	34
PLANNED	1/14/2021	4	132	33
PLANNED	1/14/2021	4	156	39
PLANNED	1/14/2021	7	910	130
PLANNED	1/14/2021	7	245	35
PLANNED	1/14/2021	2	106	53
PLANNED	1/14/2021	1	90	90
PLANNED	1/14/2021	1	12	12
PLANNED	1/14/2021	1	21	21
PLANNED	1/14/2021	3	111	37
PLANNED	1/14/2021	3	282	94
PLANNED	1/14/2021	3	129	43
PLANNED	1/14/2021	1	189	189
PLANNED	1/14/2021	4	92	23
PLANNED	1/14/2021	2	270	135
PLANNED	1/14/2021	1	45	45
PLANNED	1/14/2021	10	320	32
PLANNED	1/14/2021	1	66	66
PLANNED	1/14/2021	6	84	14
PLANNED	1/14/2021	1	30	30
PLANNED	1/14/2021	5	245	49
PLANNED	1/14/2021	2	86	43
PLANNED	1/14/2021	2	136	68
PLANNED	1/14/2021	1	26	26
PLANNED	1/14/2021	1	8	8
PLANNED	1/14/2021	2	104	52
PLANNED	1/14/2021	5	345	69
PLANNED	1/14/2021	2	144	72
PLANNED	1/14/2021	4	44	11
CUSTOMER REQUEST	1/14/2021	4	36	9
PLANNED	1/14/2021	1	262	262
PLANNED	1/14/2021	5	30	6
PLANNED	1/14/2021	1	26	26
PLANNED	1/14/2021	3	54	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/14/2021	4	96	24
PLANNED	1/14/2021	4	184	46
PLANNED	1/14/2021	7	1,022	146
PLANNED	1/14/2021	4	932	233
PLANNED	1/14/2021	2	38	19
PLANNED	1/14/2021	2	14	7
PLANNED	1/14/2021	1	54	54
PLANNED	1/14/2021	1	80	80
PLANNED	1/14/2021	12	1,128	94
PLANNED	1/14/2021	18	180	10
PLANNED	1/14/2021	4	1,188	297
PLANNED	1/14/2021	1	162	162
PLANNED	1/15/2021	1	113	113
PLANNED	1/15/2021	8	2,248	281
PLANNED	1/15/2021	2	322	161
PLANNED	1/15/2021	5	355	71
PLANNED	1/15/2021	16	960	60
PLANNED	1/15/2021	4	276	69
PLANNED	1/15/2021	4	828	207
PLANNED	1/15/2021	65	5,005	77
PLANNED	1/15/2021	4	310	84
PLANNED	1/15/2021	1	49	49
PLANNED	1/15/2021	3	126	42
PLANNED	1/15/2021	1	120	120
PLANNED	1/15/2021	9	378	42
CUSTOMER REQUEST	1/15/2021	1	401	401
PLANNED	1/15/2021	2	228	114
PLANNED	1/15/2021	1	179	179
PLANNED	1/15/2021	1	62	62
PLANNED	1/15/2021	22	1,364	62
PLANNED	1/15/2021	4	296	74
PLANNED	1/15/2021	10	1,800	180
PLANNED	1/15/2021	4	576	144
PLANNED	1/15/2021	2	186	93
PLANNED	1/15/2021	1	40	40
PLANNED	1/15/2021	2	366	183
PLANNED	1/15/2021	16	1,920	120
PLANNED	1/15/2021	92	8,464	92
PLANNED	1/15/2021	1	28	28
PLANNED	1/15/2021	12	480	40
PLANNED	1/15/2021	3	39	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/15/2021	2	282	141
PLANNED	1/15/2021	1	65	65
PLANNED	1/15/2021	1	38	38
PLANNED	1/15/2021	2	42	21
PLANNED	1/15/2021	3	39	13
PLANNED	1/15/2021	7	749	107
PLANNED	1/15/2021	2	232	116
PLANNED	1/15/2021	5	580	116
PLANNED	1/15/2021	2	276	138
PLANNED	1/15/2021	11	803	73
PLANNED	1/15/2021	6	42	7
PLANNED	1/15/2021	10	660	66
PLANNED	1/15/2021	3	57	19
PLANNED	1/15/2021	1	11	11
PLANNED	1/15/2021	2	76	38
PLANNED	1/15/2021	22	1,034	47
PLANNED	1/15/2021	5	395	79
PLANNED	1/15/2021	1	99	99
PLANNED	1/15/2021	3	135	45
PLANNED	1/15/2021	32	273	144
PLANNED	1/15/2021	1	26	26
PLANNED	1/15/2021	5	995	199
PLANNED	1/15/2021	2	218	109
PLANNED	1/15/2021	3	177	59
PLANNED	1/15/2021	3	33	11
PLANNED	1/15/2021	8	272	34
CUSTOMER REQUEST	1/15/2021	5	1,275	255
PLANNED	1/15/2021	8	448	56
PLANNED	1/15/2021	3	489	163
PLANNED	1/15/2021	23	1,127	49
PLANNED	1/15/2021	4	44	11
PLANNED	1/15/2021	1	20	20
PLANNED	1/15/2021	46	5,428	118
PLANNED	1/15/2021	4	188	47
PLANNED	1/15/2021	1	45	45
PLANNED	1/15/2021	13	117	9
PLANNED	1/15/2021	4	20	5
PLANNED	1/15/2021	2	98	49
PLANNED	1/15/2021	22	1,892	86
CUSTOMER REQUEST	1/15/2021	1	100	100
PLANNED	1/15/2021	2	154	77

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/15/2021	2	172	86
PLANNED	1/15/2021	1	91	91
PLANNED	1/15/2021	3	60	20
PLANNED	1/15/2021	4	44	11
PLANNED	1/15/2021	2	110	55
PLANNED	1/15/2021	4	124	31
CUSTOMER REQUEST	1/15/2021	970	23,280	24
PLANNED	1/15/2021	4	164	41
PLANNED	1/15/2021	5	55	11
PLANNED	1/15/2021	13	26	2
PLANNED	1/15/2021	2	28	14
PLANNED	1/15/2021	3	96	32
PLANNED	1/15/2021	1	15	15
CUSTOMER REQUEST	1/15/2021	1,389	32,291	35
PLANNED	1/15/2021	1	77	77
PLANNED	1/15/2021	5	230	46
CUSTOMER REQUEST	1/15/2021	1	44	44
CUSTOMER REQUEST	1/15/2021	1	63	63
PLANNED	1/15/2021	3	171	57
CUSTOMER REQUEST	1/15/2021	22	44	2
PLANNED	1/15/2021	1	108	108
PLANNED	1/16/2021	3	510	170
CUSTOMER REQUEST	1/16/2021	1	449	449
PLANNED	1/16/2021	2	432	216
PLANNED	1/16/2021	1	35	35
CUSTOMER REQUEST	1/16/2021	1	84	84
PLANNED	1/16/2021	1	114	114
PLANNED	1/16/2021	1	58	58
PLANNED	1/16/2021	1	121	121
PLANNED	1/16/2021	3	396	132
PLANNED	1/16/2021	1	80	80
PLANNED	1/16/2021	3	285	95
PLANNED	1/16/2021	17	901	53
PLANNED	1/16/2021	3	498	166
PLANNED	1/16/2021	1	221	221
PLANNED	1/17/2021	1	81	81
PLANNED	1/17/2021	6	120	20
PLANNED	1/17/2021	1	65	65
PLANNED	1/17/2021	1	39	39
PLANNED	1/17/2021	1	45	45
PLANNED	1/17/2021	2	144	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/17/2021	3	36	12
PLANNED	1/17/2021	12	1,332	111
PLANNED	1/18/2021	9	432	48
PLANNED	1/18/2021	3	315	105
PLANNED	1/18/2021	4	536	134
PLANNED	1/18/2021	1	61	61
PLANNED	1/18/2021	1	27	27
PLANNED	1/18/2021	4	132	33
PLANNED	1/18/2021	10	230	23
PLANNED	1/18/2021	1	8	8
PLANNED	1/18/2021	1	92	92
PLANNED	1/18/2021	2	148	74
PLANNED	1/18/2021	1	104	104
PLANNED	1/18/2021	1	62	62
PLANNED	1/18/2021	9	441	49
PLANNED	1/18/2021	2	38	19
PLANNED	1/18/2021	8	256	32
PLANNED	1/18/2021	2	234	117
PLANNED	1/18/2021	6	864	144
PLANNED	1/18/2021	1	427	427
PLANNED	1/18/2021	7	693	99
PLANNED	1/18/2021	3	480	160
PLANNED	1/18/2021	11	1,892	172
PLANNED	1/18/2021	1	165	165
PLANNED	1/18/2021	2	20	10
PLANNED	1/18/2021	1	85	85
PLANNED	1/18/2021	6	726	121
PLANNED	1/18/2021	14	2,086	149
PLANNED	1/18/2021	8	832	104
PLANNED	1/18/2021	1	147	147
PLANNED	1/18/2021	5	1,475	295
PLANNED	1/18/2021	4	184	46
PLANNED	1/18/2021	19	57	3
PLANNED	1/18/2021	6	420	70
PLANNED	1/18/2021	5	375	75
PLANNED	1/18/2021	7	602	86
PLANNED	1/18/2021	1	48	48
PLANNED	1/18/2021	5	410	82
PLANNED	1/18/2021	1	144	144
PLANNED	1/18/2021	6	690	115
PLANNED	1/18/2021	1	22	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/18/2021	6	156	26
PLANNED	1/18/2021	4	316	79
PLANNED	1/18/2021	1	24	24
PLANNED	1/18/2021	5	110	22
PLANNED	1/18/2021	1	25	25
PLANNED	1/18/2021	6	282	47
PLANNED	1/18/2021	9	648	72
PLANNED	1/18/2021	8	568	71
PLANNED	1/18/2021	7	140	20
PLANNED	1/18/2021	4	240	60
PLANNED	1/18/2021	10	1,310	131
PLANNED	1/18/2021	1	33	33
PLANNED	1/18/2021	1	79	79
PLANNED	1/18/2021	7	1,029	147
PLANNED	1/18/2021	5	500	100
PLANNED	1/18/2021	2	198	99
PLANNED	1/18/2021	13	1,131	87
PLANNED	1/18/2021	1	47	47
PLANNED	1/18/2021	13	1,027	79
PLANNED	1/18/2021	1	50	50
PLANNED	1/18/2021	6	294	49
PLANNED	1/18/2021	2	264	132
PLANNED	1/18/2021	8	126	42
PLANNED	1/18/2021	2	206	103
CUSTOMER REQUEST	1/18/2021	4	268	67
PLANNED	1/18/2021	1	154	154
PLANNED	1/18/2021	1	65	65
PLANNED	1/18/2021	1	18	18
PLANNED	1/18/2021	1	8	8
PLANNED	1/18/2021	1	76	76
PLANNED	1/18/2021	2	4	2
PLANNED	1/18/2021	1	53	53
PLANNED	1/18/2021	4	180	45
PLANNED	1/18/2021	9	368	100
PLANNED	1/18/2021	1	67	67
PLANNED	1/18/2021	2	134	67
PLANNED	1/18/2021	5	395	79
PLANNED	1/18/2021	1	77	77
PLANNED	1/18/2021	2	112	56
PLANNED	1/18/2021	2	284	142
PLANNED	1/18/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/18/2021	4	272	68
PLANNED	1/18/2021	2	68	34
PLANNED	1/18/2021	2	24	12
PLANNED	1/18/2021	1	33	33
PLANNED	1/18/2021	2	192	96
PLANNED	1/18/2021	5	30	6
PLANNED	1/18/2021	8	1,600	200
PLANNED	1/18/2021	1	163	163
PLANNED	1/18/2021	1	190	190
PLANNED	1/18/2021	1	87	87
PLANNED	1/18/2021	3	276	92
CUSTOMER REQUEST	1/18/2021	1	114	114
PLANNED	1/19/2021	2	304	152
PLANNED	1/19/2021	1	66	66
PLANNED	1/19/2021	4	1,784	446
PLANNED	1/19/2021	2	200	100
PLANNED	1/19/2021	14	2,170	155
PLANNED	1/19/2021	1	9	9
PLANNED	1/19/2021	1	91	91
PLANNED	1/19/2021	16	1,376	86
CUSTOMER REQUEST	1/19/2021	2	130	65
PLANNED	1/19/2021	3	240	80
PLANNED	1/19/2021	1	113	113
PLANNED	1/19/2021	4	696	174
PLANNED	1/19/2021	8	552	69
PLANNED	1/19/2021	7	427	61
PLANNED	1/19/2021	3	141	47
PLANNED	1/19/2021	1	70	70
PLANNED	1/19/2021	6	1,926	321
CUSTOMER REQUEST	1/19/2021	1	68	68
CUSTOMER REQUEST	1/19/2021	1	32	32
PLANNED	1/19/2021	3	297	99
PLANNED	1/19/2021	3	564	188
PLANNED	1/19/2021	1	65	65
PLANNED	1/19/2021	7	280	40
CUSTOMER REQUEST	1/19/2021	6	36	6
PLANNED	1/19/2021	1	122	122
PLANNED	1/19/2021	1	178	178
PLANNED	1/19/2021	2	26	13
PLANNED	1/19/2021	3	51	17
PLANNED	1/19/2021	5	250	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/19/2021	2	458	229
PLANNED	1/19/2021	1	64	64
PLANNED	1/19/2021	2	40	20
PLANNED	1/19/2021	2	234	117
PLANNED	1/19/2021	2	236	118
PLANNED	1/19/2021	5	235	47
PLANNED	1/19/2021	2	78	39
PLANNED	1/19/2021	5	555	111
PLANNED	1/19/2021	2	216	108
PLANNED	1/19/2021	8	376	47
PLANNED	1/19/2021	7	329	47
PLANNED	1/19/2021	1	150	150
PLANNED	1/19/2021	2	222	111
PLANNED	1/19/2021	1	83	83
PLANNED	1/19/2021	6	282	47
PLANNED	1/19/2021	5	395	79
PLANNED	1/19/2021	35	175	5
PLANNED	1/19/2021	3	255	85
PLANNED	1/19/2021	1	19	19
PLANNED	1/19/2021	5	15	3
PLANNED	1/19/2021	1	180	180
PLANNED	1/19/2021	1	14	14
PLANNED	1/19/2021	3	168	56
PLANNED	1/19/2021	7	504	72
PLANNED	1/19/2021	1	27	27
PLANNED	1/19/2021	3	318	106
PLANNED	1/19/2021	2	26	13
PLANNED	1/19/2021	37	8,843	239
PLANNED	1/19/2021	7	147	21
PLANNED	1/19/2021	2	376	188
PLANNED	1/19/2021	12	1,044	87
PLANNED	1/19/2021	12	1,044	87
PLANNED	1/19/2021	1	89	89
PLANNED	1/19/2021	10	830	83
PLANNED	1/19/2021	10	830	83
PLANNED	1/19/2021	13	1,391	107
PLANNED	1/19/2021	4	240	60
PLANNED	1/19/2021	6	384	64
PLANNED	1/19/2021	1	102	102
PLANNED	1/19/2021	3	174	58
PLANNED	1/19/2021	19	2,202	254

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/19/2021	9	963	107
PLANNED	1/19/2021	1	58	58
PLANNED	1/19/2021	4	740	185
PLANNED	1/19/2021	10	160	16
PLANNED	1/19/2021	3	498	166
PLANNED	1/19/2021	4	960	240
PLANNED	1/19/2021	7	1,099	157
PLANNED	1/19/2021	2	126	63
PLANNED	1/19/2021	4	348	87
PLANNED	1/19/2021	1	155	155
PLANNED	1/19/2021	6	270	45
PLANNED	1/19/2021	12	1,551	157
PLANNED	1/19/2021	1	115	115
PLANNED	1/19/2021	11	1,496	136
PLANNED	1/19/2021	5	655	131
PLANNED	1/19/2021	3	282	94
CUSTOMER REQUEST	1/19/2021	1	1	1
PLANNED	1/19/2021	7	420	60
PLANNED	1/19/2021	2	138	69
PLANNED	1/19/2021	4	40	10
PLANNED	1/19/2021	4	328	82
PLANNED	1/19/2021	1	89	89
PLANNED	1/19/2021	3	90	30
PLANNED	1/19/2021	8	600	75
PLANNED	1/19/2021	4	24	6
PLANNED	1/19/2021	6	168	28
PLANNED	1/19/2021	5	355	71
PLANNED	1/19/2021	5	40	8
PLANNED	1/19/2021	1	13	13
PLANNED	1/19/2021	2	6	3
PLANNED	1/19/2021	5	185	37
CUSTOMER REQUEST	1/19/2021	1	190	190
PLANNED	1/19/2021	2	160	80
PLANNED	1/19/2021	2	68	34
CUSTOMER REQUEST	1/19/2021	7	1,176	168
PLANNED	1/19/2021	2	142	71
PLANNED	1/19/2021	5	425	85
PLANNED	1/19/2021	2	102	51
CUSTOMER REQUEST	1/19/2021	1	24	24
PLANNED	1/19/2021	2	292	146
PLANNED	1/19/2021	1	287	287

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/19/2021	2	352	176
PLANNED	1/19/2021	4	744	186
PLANNED	1/19/2021	6	1,770	295
PLANNED	1/20/2021	3	180	60
PLANNED	1/20/2021	3	240	80
CUSTOMER REQUEST	1/20/2021	1	9	9
PLANNED	1/20/2021	2	178	89
PLANNED	1/20/2021	2	100	50
PLANNED	1/20/2021	8	480	60
PLANNED	1/20/2021	1	161	161
PLANNED	1/20/2021	4	248	62
PLANNED	1/20/2021	8	1,120	140
PLANNED	1/20/2021	5	490	98
PLANNED	1/20/2021	5	500	100
PLANNED	1/20/2021	6	588	98
PLANNED	1/20/2021	1	82	82
PLANNED	1/20/2021	5	340	68
PLANNED	1/20/2021	7	378	54
CUSTOMER REQUEST	1/20/2021	1	273	273
PLANNED	1/20/2021	11	319	29
PLANNED	1/20/2021	7	147	21
PLANNED	1/20/2021	2	268	134
PLANNED	1/20/2021	6	444	74
PLANNED	1/20/2021	2	394	197
PLANNED	1/20/2021	5	390	78
PLANNED	1/20/2021	48	8,928	186
PLANNED	1/20/2021	11	814	74
PLANNED	1/20/2021	2	314	157
PLANNED	1/20/2021	8	320	40
PLANNED	1/20/2021	4	440	110
PLANNED	1/20/2021	3	336	112
PLANNED	1/20/2021	3	345	115
PLANNED	1/20/2021	8	1,608	304
PLANNED	1/20/2021	11	11	1
PLANNED	1/20/2021	1	241	241
PLANNED	1/20/2021	1	130	130
PLANNED	1/20/2021	4	100	25
PLANNED	1/20/2021	2	230	142
PLANNED	1/20/2021	11	473	43
PLANNED	1/20/2021	3	81	27
PLANNED	1/20/2021	12	2,364	197

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/20/2021	4	784	196
PLANNED	1/20/2021	3	108	36
PLANNED	1/20/2021	4	80	20
PLANNED	1/20/2021	2	30	15
PLANNED	1/20/2021	21	189	9
PLANNED	1/20/2021	6	300	50
PLANNED	1/20/2021	1	180	180
PLANNED	1/20/2021	1	149	149
PLANNED	1/20/2021	19	1,178	62
PLANNED	1/20/2021	1	24	24
PLANNED	1/20/2021	43	4,773	111
PLANNED	1/20/2021	1	174	174
PLANNED	1/20/2021	1	31	31
PLANNED	1/20/2021	16	896	56
PLANNED	1/20/2021	6	354	59
PLANNED	1/20/2021	1	34	34
PLANNED	1/20/2021	11	1,034	94
PLANNED	1/20/2021	2	260	130
PLANNED	1/20/2021	2	74	37
PLANNED	1/20/2021	6	390	65
PLANNED	1/20/2021	4	216	54
PLANNED	1/20/2021	1	110	110
PLANNED	1/20/2021	4	336	84
PLANNED	1/20/2021	4	164	41
PLANNED	1/20/2021	11	154	14
PLANNED	1/20/2021	3	369	123
PLANNED	1/20/2021	8	184	23
PLANNED	1/20/2021	1	86	86
PLANNED	1/20/2021	66	11,022	167
PLANNED	1/20/2021	6	180	30
PLANNED	1/20/2021	9	146	58
PLANNED	1/20/2021	4	48	12
PLANNED	1/20/2021	1	365	365
PLANNED	1/20/2021	2	128	64
PLANNED	1/20/2021	8	280	35
PLANNED	1/20/2021	15	2,364	250
PLANNED	1/20/2021	9	63	7
PLANNED	1/20/2021	9	468	52
PLANNED	1/20/2021	10	830	235
PLANNED	1/20/2021	16	1,712	107
PLANNED	1/20/2021	2	118	59

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/20/2021	6	102	17
PLANNED	1/20/2021	5	525	105
PLANNED	1/20/2021	10	280	28
PLANNED	1/20/2021	11	484	44
PLANNED	1/20/2021	5	620	124
PLANNED	1/20/2021	12	204	17
PLANNED	1/20/2021	5	350	70
PLANNED	1/20/2021	11	396	36
PLANNED	1/20/2021	3	60	20
PLANNED	1/20/2021	4	176	44
PLANNED	1/20/2021	6	144	24
PLANNED	1/20/2021	2	112	56
PLANNED	1/20/2021	8	2,024	253
PLANNED	1/20/2021	2	120	60
PLANNED	1/20/2021	6	126	21
PLANNED	1/20/2021	4	136	34
PLANNED	1/20/2021	2	256	128
PLANNED	1/20/2021	1	32	32
PLANNED	1/20/2021	3	132	44
PLANNED	1/20/2021	1	107	107
PLANNED	1/20/2021	17	510	30
PLANNED	1/20/2021	8	1,152	144
PLANNED	1/20/2021	10	550	55
PLANNED	1/20/2021	6	114	19
PLANNED	1/20/2021	10	430	43
PLANNED	1/20/2021	12	384	32
PLANNED	1/20/2021	4	212	53
PLANNED	1/20/2021	1	17	17
PLANNED	1/20/2021	4	240	60
PLANNED	1/20/2021	2	50	25
PLANNED	1/20/2021	5	35	7
PLANNED	1/20/2021	4	284	71
PLANNED	1/20/2021	1	47	47
PLANNED	1/20/2021	1	127	127
PLANNED	1/20/2021	4	556	139
PLANNED	1/20/2021	1	125	125
CUSTOMER REQUEST	1/20/2021	9	54	6
PLANNED	1/20/2021	72	360	5
CUSTOMER REQUEST	1/20/2021	1	45	45
PLANNED	1/20/2021	2	4	2
PLANNED	1/20/2021	7	1,540	220

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/20/2021	1	78	78
PLANNED	1/20/2021	10	1,510	151
PLANNED	1/20/2021	34	2,788	82
PLANNED	1/20/2021	6	354	59
PLANNED	1/20/2021	2	38	19
PLANNED	1/20/2021	9	99	11
PLANNED	1/20/2021	3	225	75
PLANNED	1/20/2021	3	24	8
PLANNED	1/20/2021	1	32	32
PLANNED	1/20/2021	3	57	19
PLANNED	1/20/2021	2	178	89
PLANNED	1/20/2021	2	78	39
PLANNED	1/20/2021	1	8	8
PLANNED	1/20/2021	22	264	12
PLANNED	1/20/2021	2	34	17
PLANNED	1/20/2021	1	77	77
PLANNED	1/20/2021	9	558	62
PLANNED	1/20/2021	6	54	9
PLANNED	1/20/2021	1	84	84
PLANNED	1/20/2021	4	952	238
PLANNED	1/20/2021	3	420	140
PLANNED	1/20/2021	2	196	98
PLANNED	1/20/2021	1	117	117
PLANNED	1/20/2021	4	384	96
PLANNED	1/20/2021	8	424	53
PLANNED	1/21/2021	2	150	75
PLANNED	1/21/2021	3	354	118
PLANNED	1/21/2021	1	122	122
PLANNED	1/21/2021	2	374	187
PLANNED	1/21/2021	1	73	73
PLANNED	1/21/2021	2	76	38
PLANNED	1/21/2021	9	378	42
PLANNED	1/21/2021	4	164	41
PLANNED	1/21/2021	15	2,866	431
PLANNED	1/21/2021	3	153	51
PLANNED	1/21/2021	5	225	45
PLANNED	1/21/2021	2	114	57
PLANNED	1/21/2021	2	72	36
PLANNED	1/21/2021	1	59	59
PLANNED	1/21/2021	2	70	35
PLANNED	1/21/2021	3	459	153

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/21/2021	8	608	76
PLANNED	1/21/2021	6	246	41
CUSTOMER REQUEST	1/21/2021	25	7,825	313
PLANNED	1/21/2021	3	156	52
CUSTOMER REQUEST	1/21/2021	21	6,573	313
CUSTOMER REQUEST	1/21/2021	9	36	4
PLANNED	1/21/2021	1	79	79
CUSTOMER REQUEST	1/21/2021	1	34	34
PLANNED	1/21/2021	99	6,336	64
PLANNED	1/21/2021	8	296	37
PLANNED	1/21/2021	4	604	151
CUSTOMER REQUEST	1/21/2021	1	325	325
PLANNED	1/21/2021	1	249	249
PLANNED	1/21/2021	2	37	19
PLANNED	1/21/2021	4	536	134
PLANNED	1/21/2021	4	492	123
PLANNED	1/21/2021	5	30	6
PLANNED	1/21/2021	2	60	30
PLANNED	1/21/2021	3	159	53
PLANNED	1/21/2021	2	82	41
PLANNED	1/21/2021	5	300	60
PLANNED	1/21/2021	2	424	212
PLANNED	1/21/2021	2	502	251
PLANNED	1/21/2021	2	114	57
PLANNED	1/21/2021	1	600	600
PLANNED	1/21/2021	2	138	69
PLANNED	1/21/2021	1	344	344
PLANNED	1/21/2021	6	228	38
PLANNED	1/21/2021	9	1,134	126
PLANNED	1/21/2021	8	536	67
PLANNED	1/21/2021	1	44	44
PLANNED	1/21/2021	8	992	124
PLANNED	1/21/2021	3	156	52
PLANNED	1/21/2021	6	534	89
CUSTOMER REQUEST	1/21/2021	6	126	21
PLANNED	1/21/2021	6	336	56
PLANNED	1/21/2021	1	42	42
PLANNED	1/21/2021	8	688	86
PLANNED	1/21/2021	4	24	6
PLANNED	1/21/2021	4	456	114
PLANNED	1/21/2021	2	596	309

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/21/2021	6	582	97
PLANNED	1/21/2021	6	306	51
PLANNED	1/21/2021	4	140	35
PLANNED	1/21/2021	5	140	28
PLANNED	1/21/2021	2	220	110
PLANNED	1/21/2021	7	357	51
PLANNED	1/21/2021	3	249	83
PLANNED	1/21/2021	1	140	140
PLANNED	1/21/2021	1	23	23
PLANNED	1/21/2021	3	153	51
PLANNED	1/21/2021	4	176	44
PLANNED	1/21/2021	6	312	52
PLANNED	1/21/2021	2	138	69
PLANNED	1/21/2021	1	135	135
PLANNED	1/21/2021	1	39	39
PLANNED	1/21/2021	2	86	43
PLANNED	1/21/2021	1	37	37
CUSTOMER REQUEST	1/21/2021	1	16	16
PLANNED	1/21/2021	3	207	69
PLANNED	1/21/2021	9	450	50
PLANNED	1/21/2021	8	376	47
PLANNED	1/21/2021	1	21	21
PLANNED	1/21/2021	7	385	55
PLANNED	1/21/2021	1	201	201
PLANNED	1/21/2021	6	864	144
PLANNED	1/21/2021	1	198	198
PLANNED	1/21/2021	10	1,480	148
PLANNED	1/21/2021	1	141	141
PLANNED	1/21/2021	7	182	26
PLANNED	1/21/2021	1	78	78
PLANNED	1/21/2021	5	280	56
PLANNED	1/21/2021	6	240	40
PLANNED	1/21/2021	2	232	116
PLANNED	1/21/2021	1	19	19
CUSTOMER REQUEST	1/21/2021	2	346	173
PLANNED	1/21/2021	2	96	48
PLANNED	1/21/2021	1	45	45
PLANNED	1/21/2021	2	234	117
PLANNED	1/21/2021	105	2,415	23
PLANNED	1/21/2021	3	15	5
PLANNED	1/21/2021	4	176	44

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/21/2021	27	162	6
PLANNED	1/21/2021	8	360	45
PLANNED	1/21/2021	1	34	34
PLANNED	1/21/2021	3	225	75
PLANNED	1/21/2021	5	100	20
PLANNED	1/21/2021	1	126	126
PLANNED	1/21/2021	2	136	68
PLANNED	1/21/2021	9	9	1
PLANNED	1/21/2021	10	530	53
PLANNED	1/21/2021	3	42	14
PLANNED	1/21/2021	4	248	62
PLANNED	1/21/2021	1	13	13
PLANNED	1/21/2021	1	118	118
PLANNED	1/21/2021	4	212	53
PLANNED	1/21/2021	4	312	78
PLANNED	1/21/2021	6	204	34
CUSTOMER REQUEST	1/21/2021	1	26	26
PLANNED	1/21/2021	4	408	102
PLANNED	1/21/2021	5	285	57
PLANNED	1/21/2021	21	63	3
PLANNED	1/21/2021	1	53	53
PLANNED	1/21/2021	3	135	45
PLANNED	1/21/2021	1	110	110
PLANNED	1/21/2021	8	464	58
PLANNED	1/21/2021	4	212	53
PLANNED	1/21/2021	1	11	11
CUSTOMER REQUEST	1/21/2021	10	4,280	428
CUSTOMER REQUEST	1/21/2021	8	152	19
PLANNED	1/21/2021	8	136	17
PLANNED	1/21/2021	3	57	19
PLANNED	1/21/2021	9	252	28
PLANNED	1/21/2021	1	43	43
PLANNED	1/21/2021	4	184	46
PLANNED	1/21/2021	1	57	57
PLANNED	1/21/2021	10	150	15
PLANNED	1/21/2021	3	93	31
PLANNED	1/21/2021	1	6	6
PLANNED	1/21/2021	1	99	99
PLANNED	1/21/2021	28	3,276	117
PLANNED	1/21/2021	1	159	159
PLANNED	1/21/2021	2	238	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/21/2021	1	93	93
PLANNED	1/21/2021	1	124	124
PLANNED	1/22/2021	2	186	93
PLANNED	1/22/2021	15	2,595	173
PLANNED	1/22/2021	2	484	242
PLANNED	1/22/2021	4	120	30
PLANNED	1/22/2021	7	259	37
PLANNED	1/22/2021	2	362	181
PLANNED	1/22/2021	1	98	98
PLANNED	1/22/2021	10	560	56
PLANNED	1/22/2021	2	314	157
PLANNED	1/22/2021	6	642	107
PLANNED	1/22/2021	8	760	95
PLANNED	1/22/2021	7	672	96
PLANNED	1/22/2021	9	549	61
PLANNED	1/22/2021	1	87	87
PLANNED	1/22/2021	1	21	21
PLANNED	1/22/2021	2	58	29
PLANNED	1/22/2021	3	42	14
PLANNED	1/22/2021	3	1,293	431
PLANNED	1/22/2021	2	80	40
PLANNED	1/22/2021	2	102	51
PLANNED	1/22/2021	7	805	115
PLANNED	1/22/2021	6	768	128
PLANNED	1/22/2021	2	116	58
PLANNED	1/22/2021	3	117	39
PLANNED	1/22/2021	2	190	95
PLANNED	1/22/2021	8	1,440	180
PLANNED	1/22/2021	8	304	38
PLANNED	1/22/2021	4	720	180
PLANNED	1/22/2021	8	864	108
PLANNED	1/22/2021	7	1,757	251
PLANNED	1/22/2021	13	429	33
PLANNED	1/22/2021	2	12	6
PLANNED	1/22/2021	6	567	106
PLANNED	1/22/2021	8	680	85
PLANNED	1/22/2021	7	588	84
PLANNED	1/22/2021	2	586	293
PLANNED	1/22/2021	8	408	51
PLANNED	1/22/2021	3	288	96
PLANNED	1/22/2021	18	1,026	57

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/22/2021	4	186	141
PLANNED	1/22/2021	6	294	49
PLANNED	1/22/2021	2	50	25
PLANNED	1/22/2021	2	48	24
PLANNED	1/22/2021	2	22	11
PLANNED	1/22/2021	2	42	21
PLANNED	1/22/2021	2	38	19
PLANNED	1/22/2021	2	36	18
PLANNED	1/22/2021	2	308	154
PLANNED	1/22/2021	2	80	40
PLANNED	1/22/2021	54	1,674	31
PLANNED	1/22/2021	40	1,240	31
PLANNED	1/22/2021	2	30	15
PLANNED	1/22/2021	7	427	61
PLANNED	1/22/2021	9	153	17
PLANNED	1/22/2021	6	612	102
PLANNED	1/22/2021	4	620	155
PLANNED	1/22/2021	8	344	43
PLANNED	1/22/2021	2	136	68
PLANNED	1/22/2021	6	293	63
PLANNED	1/22/2021	7	714	102
CUSTOMER REQUEST	1/22/2021	1	221	221
PLANNED	1/22/2021	3	324	149
PLANNED	1/22/2021	3	855	285
PLANNED	1/22/2021	4	100	25
PLANNED	1/22/2021	3	975	325
CUSTOMER REQUEST	1/22/2021	21	9,954	474
PLANNED	1/22/2021	3	168	56
PLANNED	1/22/2021	1	129	129
PLANNED	1/22/2021	1	19	19
PLANNED	1/22/2021	7	896	128
PLANNED	1/22/2021	1	19	19
PLANNED	1/22/2021	240	2,160	9
PLANNED	1/22/2021	8	376	47
PLANNED	1/22/2021	8	104	13
PLANNED	1/22/2021	5	50	10
PLANNED	1/22/2021	13	221	17
PLANNED	1/22/2021	1	159	159
PLANNED	1/22/2021	9	963	107
CUSTOMER REQUEST	1/22/2021	2	54	27
PLANNED	1/22/2021	5	415	83

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/22/2021	6	684	114
PLANNED	1/22/2021	2	82	41
PLANNED	1/22/2021	3	33	11
PLANNED	1/22/2021	1	21	21
PLANNED	1/22/2021	8	588	94
CUSTOMER REQUEST	1/22/2021	5	85	17
PLANNED	1/22/2021	11	275	25
PLANNED	1/22/2021	9	369	41
PLANNED	1/22/2021	2	92	46
PLANNED	1/22/2021	40	880	22
PLANNED	1/22/2021	1	85	85
PLANNED	1/22/2021	10	150	15
PLANNED	1/22/2021	4	132	33
CUSTOMER REQUEST	1/22/2021	1	210	210
PLANNED	1/22/2021	1	24	24
PLANNED	1/22/2021	12	696	58
PLANNED	1/23/2021	1	11	11
PLANNED	1/23/2021	4	804	201
PLANNED	1/23/2021	138	1,242	9
PLANNED	1/23/2021	9	990	110
PLANNED	1/23/2021	3	363	121
PLANNED	1/23/2021	3	255	85
PLANNED	1/23/2021	2	454	227
PLANNED	1/23/2021	2	152	76
PLANNED	1/23/2021	10	440	44
PLANNED	1/23/2021	4	820	205
PLANNED	1/23/2021	6	276	46
PLANNED	1/23/2021	4	244	61
PLANNED	1/23/2021	2	114	57
PLANNED	1/23/2021	4	524	131
PLANNED	1/23/2021	9	27	3
PLANNED	1/23/2021	4	172	43
CUSTOMER REQUEST	1/23/2021	1	231	231
PLANNED	1/23/2021	6	12	2
PLANNED	1/23/2021	6	744	124
PLANNED	1/23/2021	1	313	313
CUSTOMER REQUEST	1/23/2021	6	732	122
PLANNED	1/24/2021	1	117	117
PLANNED	1/24/2021	10	590	59
PLANNED	1/24/2021	1	206	206
PLANNED	1/24/2021	1	201	201

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/24/2021	3	81	27
PLANNED	1/24/2021	5	2,530	506
PLANNED	1/24/2021	1	47	47
PLANNED	1/24/2021	2	114	57
PLANNED	1/25/2021	5	800	160
PLANNED	1/25/2021	1	48	48
PLANNED	1/25/2021	1	187	187
PLANNED	1/25/2021	11	231	21
CUSTOMER REQUEST	1/25/2021	25	8,978	391
PLANNED	1/25/2021	1	21	21
PLANNED	1/25/2021	4	112	28
PLANNED	1/25/2021	9	297	33
CUSTOMER REQUEST	1/25/2021	18	1,338	257
PLANNED	1/25/2021	8	128	16
PLANNED	1/25/2021	1	130	130
PLANNED	1/25/2021	1	119	119
PLANNED	1/25/2021	1	118	118
PLANNED	1/25/2021	4	456	114
PLANNED	1/25/2021	9	576	64
PLANNED	1/25/2021	89	445	5
PLANNED	1/25/2021	3	276	92
PLANNED	1/25/2021	1	54	54
PLANNED	1/25/2021	4	252	63
PLANNED	1/25/2021	4	52	13
PLANNED	1/25/2021	2	240	120
PLANNED	1/25/2021	11	693	63
PLANNED	1/25/2021	12	336	28
PLANNED	1/25/2021	6	396	121
PLANNED	1/25/2021	2	174	87
PLANNED	1/25/2021	7	70	10
PLANNED	1/25/2021	2	104	52
PLANNED	1/25/2021	2	496	248
PLANNED	1/25/2021	1	116	116
PLANNED	1/25/2021	14	392	28
PLANNED	1/25/2021	1	39	39
PLANNED	1/25/2021	1	58	58
CUSTOMER REQUEST	1/25/2021	7	714	102
PLANNED	1/25/2021	3	87	29
PLANNED	1/25/2021	2	170	85
PLANNED	1/25/2021	7	441	63
PLANNED	1/25/2021	8	520	65

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/25/2021	1	40	40
PLANNED	1/25/2021	8	744	93
PLANNED	1/25/2021	1	57	57
PLANNED	1/25/2021	7	469	67
PLANNED	1/25/2021	9	1,683	187
PLANNED	1/25/2021	3	252	84
PLANNED	1/25/2021	4	44	11
PLANNED	1/25/2021	3	273	91
PLANNED	1/25/2021	2	24	12
PLANNED	1/25/2021	2	20	10
PLANNED	1/25/2021	8	456	57
PLANNED	1/25/2021	1	135	135
PLANNED	1/25/2021	9	234	26
PLANNED	1/25/2021	10	310	31
PLANNED	1/25/2021	4	272	68
PLANNED	1/25/2021	22	638	29
PLANNED	1/25/2021	6	630	105
PLANNED	1/25/2021	3	78	26
PLANNED	1/25/2021	5	135	27
PLANNED	1/25/2021	12	396	33
PLANNED	1/25/2021	3	30	10
PLANNED	1/25/2021	6	216	36
PLANNED	1/25/2021	12	612	51
PLANNED	1/25/2021	12	12	1
PLANNED	1/25/2021	7	175	25
PLANNED	1/25/2021	11	11	1
PLANNED	1/25/2021	10	250	25
PLANNED	1/25/2021	6	432	72
PLANNED	1/25/2021	5	725	145
PLANNED	1/25/2021	1	19	19
PLANNED	1/25/2021	13	39	3
PLANNED	1/25/2021	15	15	1
PLANNED	1/25/2021	1	83	83
PLANNED	1/25/2021	7	224	32
PLANNED	1/25/2021	13	13	1
PLANNED	1/25/2021	4	200	50
PLANNED	1/25/2021	5	330	66
PLANNED	1/25/2021	1	39	39
PLANNED	1/25/2021	1	32	32
PLANNED	1/25/2021	6	246	41
PLANNED	1/25/2021	4	144	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/25/2021	2	30	15
PLANNED	1/25/2021	4	184	46
PLANNED	1/25/2021	6	342	57
PLANNED	1/25/2021	7	322	46
CUSTOMER REQUEST	1/25/2021	16	1,664	104
PLANNED	1/25/2021	1	122	122
PLANNED	1/25/2021	5	360	72
PLANNED	1/25/2021	13	1,092	84
PLANNED	1/25/2021	2	34	17
PLANNED	1/25/2021	8	448	56
PLANNED	1/25/2021	1	55	55
PLANNED	1/25/2021	3	165	55
PLANNED	1/25/2021	6	108	18
PLANNED	1/25/2021	3	99	33
PLANNED	1/25/2021	6	780	130
PLANNED	1/25/2021	2	318	159
PLANNED	1/25/2021	11	517	47
PLANNED	1/25/2021	2	30	15
PLANNED	1/25/2021	9	1,656	184
PLANNED	1/25/2021	6	126	21
PLANNED	1/25/2021	4	16	4
CUSTOMER REQUEST	1/25/2021	1	253	253
PLANNED	1/25/2021	1	80	80
PLANNED	1/25/2021	11	890	121
PLANNED	1/25/2021	5	385	77
PLANNED	1/25/2021	13	247	19
PLANNED	1/25/2021	3	294	98
PLANNED	1/25/2021	6	468	78
PLANNED	1/25/2021	3	330	110
PLANNED	1/25/2021	1	59	59
PLANNED	1/25/2021	1	49	49
PLANNED	1/25/2021	4	52	13
PLANNED	1/25/2021	3	48	16
PLANNED	1/25/2021	1	62	62
PLANNED	1/25/2021	4	88	22
PLANNED	1/25/2021	5	710	142
CUSTOMER REQUEST	1/25/2021	15	15	1
PLANNED	1/25/2021	7	385	55
PLANNED	1/25/2021	1	79	79
PLANNED	1/25/2021	1	104	104
PLANNED	1/25/2021	2	184	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/25/2021	2	44	22
PLANNED	1/25/2021	6	354	59
PLANNED	1/25/2021	4	452	113
PLANNED	1/25/2021	12	456	38
PLANNED	1/25/2021	8	80	10
PLANNED	1/25/2021	2	154	77
PLANNED	1/25/2021	2	80	40
PLANNED	1/25/2021	1	29	29
PLANNED	1/25/2021	2	30	15
PLANNED	1/25/2021	2	46	23
PLANNED	1/25/2021	13	156	12
PLANNED	1/25/2021	8	128	16
PLANNED	1/25/2021	2	60	30
PLANNED	1/25/2021	8	544	68
PLANNED	1/25/2021	7	371	53
PLANNED	1/25/2021	5	180	36
PLANNED	1/25/2021	14	1,610	175
PLANNED	1/25/2021	3	183	61
CUSTOMER REQUEST	1/25/2021	1	163	163
PLANNED	1/25/2021	2	88	44
PLANNED	1/25/2021	1	58	58
PLANNED	1/25/2021	8	96	12
PLANNED	1/25/2021	4	144	36
PLANNED	1/25/2021	1	44	44
PLANNED	1/25/2021	3	162	54
CUSTOMER REQUEST	1/25/2021	1	371	371
CUSTOMER REQUEST	1/25/2021	1	176	176
PLANNED	1/25/2021	14	1,862	133
PLANNED	1/25/2021	4	472	118
PLANNED	1/25/2021	8	144	18
PLANNED	1/25/2021	1	180	180
PLANNED	1/25/2021	1	179	179
PLANNED	1/25/2021	1	38	38
PLANNED	1/25/2021	1	62	62
PLANNED	1/25/2021	21	588	28
PLANNED	1/25/2021	1	80	80
PLANNED	1/25/2021	1	79	79
PLANNED	1/26/2021	3	213	71
PLANNED	1/26/2021	4	476	119
PLANNED	1/26/2021	1	137	137
PLANNED	1/26/2021	2	160	80

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/26/2021	2	80	40
PLANNED	1/26/2021	1	75	75
PLANNED	1/26/2021	1	64	64
PLANNED	1/26/2021	4	280	70
PLANNED	1/26/2021	3	519	173
PLANNED	1/26/2021	8	1,379	412
PLANNED	1/26/2021	8	616	77
PLANNED	1/26/2021	8	944	118
PLANNED	1/26/2021	2	72	36
PLANNED	1/26/2021	1	56	56
PLANNED	1/26/2021	8	248	31
PLANNED	1/26/2021	52	2,704	52
PLANNED	1/26/2021	1	39	39
PLANNED	1/26/2021	7	21	3
PLANNED	1/26/2021	1	128	128
PLANNED	1/26/2021	6	108	18
PLANNED	1/26/2021	2	278	139
PLANNED	1/26/2021	1	130	130
PLANNED	1/26/2021	1	83	83
PLANNED	1/26/2021	12	2,568	214
PLANNED	1/26/2021	1	104	104
PLANNED	1/26/2021	3	228	76
PLANNED	1/26/2021	8	1,680	210
PLANNED	1/26/2021	1	93	93
PLANNED	1/26/2021	1	14	14
PLANNED	1/26/2021	1	54	54
PLANNED	1/26/2021	3	162	54
PLANNED	1/26/2021	1	41	41
PLANNED	1/26/2021	8	448	56
PLANNED	1/26/2021	6	204	34
PLANNED	1/26/2021	1	135	135
PLANNED	1/26/2021	3	219	73
PLANNED	1/26/2021	3	399	133
PLANNED	1/26/2021	8	440	55
PLANNED	1/26/2021	8	392	49
PLANNED	1/26/2021	6	816	136
PLANNED	1/26/2021	10	330	33
PLANNED	1/26/2021	1	79	79
PLANNED	1/26/2021	4	108	27
PLANNED	1/26/2021	1	130	130
PLANNED	1/26/2021	4	88	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/26/2021	8	856	107
CUSTOMER REQUEST	1/26/2021	11	253	23
PLANNED	1/26/2021	8	344	43
PLANNED	1/26/2021	8	376	47
PLANNED	1/26/2021	5	950	190
PLANNED	1/26/2021	3	45	15
PLANNED	1/26/2021	5	750	150
PLANNED	1/26/2021	2	28	14
PLANNED	1/26/2021	8	712	89
PLANNED	1/26/2021	1	133	133
PLANNED	1/26/2021	9	873	97
PLANNED	1/26/2021	3	282	94
PLANNED	1/26/2021	2	30	15
PLANNED	1/26/2021	6	168	28
PLANNED	1/26/2021	10	1,110	111
PLANNED	1/26/2021	6	702	117
PLANNED	1/26/2021	1	20	20
PLANNED	1/26/2021	3	477	159
PLANNED	1/26/2021	7	805	115
PLANNED	1/26/2021	1	49	49
PLANNED	1/26/2021	4	180	45
PLANNED	1/26/2021	10	690	69
PLANNED	1/26/2021	2	30	15
PLANNED	1/26/2021	1	13	13
PLANNED	1/26/2021	8	448	56
PLANNED	1/26/2021	22	308	14
PLANNED	1/26/2021	8	1,080	135
PLANNED	1/26/2021	1	31	31
PLANNED	1/26/2021	12	228	19
PLANNED	1/26/2021	11	638	58
PLANNED	1/26/2021	3	54	18
PLANNED	1/26/2021	6	504	84
PLANNED	1/26/2021	8	1,032	129
PLANNED	1/26/2021	2	62	31
PLANNED	1/26/2021	5	50	10
PLANNED	1/26/2021	7	1,078	154
PLANNED	1/26/2021	5	325	65
PLANNED	1/26/2021	12	2,364	197
PLANNED	1/26/2021	10	810	81
PLANNED	1/26/2021	1	37	37
PLANNED	1/26/2021	6	138	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/26/2021	2	158	79
PLANNED	1/26/2021	3	252	84
PLANNED	1/26/2021	51	1,173	23
PLANNED	1/26/2021	8	616	77
PLANNED	1/26/2021	8	584	73
PLANNED	1/26/2021	1	131	131
PLANNED	1/26/2021	12	540	45
PLANNED	1/26/2021	10	310	31
PLANNED	1/26/2021	3	300	100
PLANNED	1/26/2021	8	320	40
PLANNED	1/26/2021	2	116	58
PLANNED	1/26/2021	1	85	85
PLANNED	1/26/2021	8	400	50
PLANNED	1/26/2021	16	656	41
PLANNED	1/26/2021	8	224	28
PLANNED	1/26/2021	8	832	104
PLANNED	1/26/2021	1	38	38
PLANNED	1/26/2021	6	90	15
PLANNED	1/26/2021	6	108	18
PLANNED	1/26/2021	16	80	5
PLANNED	1/26/2021	1	145	145
PLANNED	1/26/2021	17	1,020	60
PLANNED	1/26/2021	2	218	109
PLANNED	1/26/2021	5	1,185	237
PLANNED	1/26/2021	2	44	22
PLANNED	1/26/2021	16	160	10
PLANNED	1/26/2021	1	100	100
PLANNED	1/26/2021	4	52	13
PLANNED	1/26/2021	9	378	42
PLANNED	1/26/2021	2	34	17
PLANNED	1/26/2021	5	50	10
PLANNED	1/26/2021	2	220	110
PLANNED	1/26/2021	17	221	13
PLANNED	1/26/2021	8	536	67
PLANNED	1/26/2021	3	126	42
PLANNED	1/26/2021	23	966	42
CUSTOMER REQUEST	1/26/2021	22	330	15
PLANNED	1/26/2021	1	53	53
PLANNED	1/26/2021	1	64	64
PLANNED	1/26/2021	2	76	38
PLANNED	1/26/2021	2	190	95

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/26/2021	2	62	31
PLANNED	1/26/2021	1	32	32
PLANNED	1/26/2021	2	128	64
PLANNED	1/26/2021	1	47	47
PLANNED	1/26/2021	1	73	73
PLANNED	1/26/2021	1	21	21
PLANNED	1/26/2021	3	240	80
PLANNED	1/26/2021	1	26	26
PLANNED	1/26/2021	4	192	48
PLANNED	1/26/2021	1	11	11
PLANNED	1/26/2021	11	627	57
PLANNED	1/26/2021	2	204	102
PLANNED	1/26/2021	3	222	74
PLANNED	1/26/2021	5	955	191
PLANNED	1/26/2021	8	1,168	146
PLANNED	1/26/2021	4	1,012	253
PLANNED	1/27/2021	1	66	66
PLANNED	1/27/2021	1	47	47
PLANNED	1/27/2021	2	198	99
PLANNED	1/27/2021	4	464	116
PLANNED	1/27/2021	2	112	56
PLANNED	1/27/2021	9	459	51
PLANNED	1/27/2021	4	104	26
PLANNED	1/27/2021	2	52	26
PLANNED	1/27/2021	1	47	47
PLANNED	1/27/2021	11	616	56
PLANNED	1/27/2021	1	10	10
PLANNED	1/27/2021	2	156	78
PLANNED	1/27/2021	2	102	51
PLANNED	1/27/2021	2	194	97
PLANNED	1/27/2021	2	18	9
CUSTOMER REQUEST	1/27/2021	24	7,200	300
PLANNED	1/27/2021	2	402	201
PLANNED	1/27/2021	8	680	85
PLANNED	1/27/2021	2	172	86
PLANNED	1/27/2021	8	688	86
PLANNED	1/27/2021	6	354	59
PLANNED	1/27/2021	3	801	267
PLANNED	1/27/2021	3	231	77
PLANNED	1/27/2021	14	1,176	84
PLANNED	1/27/2021	6	288	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/27/2021	5	585	117
PLANNED	1/27/2021	7	294	42
PLANNED	1/27/2021	12	1,344	112
PLANNED	1/27/2021	5	220	44
PLANNED	1/27/2021	8	536	67
PLANNED	1/27/2021	1	99	99
PLANNED	1/27/2021	8	640	80
PLANNED	1/27/2021	2	6	3
PLANNED	1/27/2021	3	531	177
PLANNED	1/27/2021	1	147	147
PLANNED	1/27/2021	9	378	42
PLANNED	1/27/2021	6	432	72
PLANNED	1/27/2021	6	492	82
PLANNED	1/27/2021	10	10	1
PLANNED	1/27/2021	1	41	41
PLANNED	1/27/2021	2	166	83
PLANNED	1/27/2021	6	36	6
PLANNED	1/27/2021	7	287	41
PLANNED	1/27/2021	8	152	19
PLANNED	1/27/2021	10	670	67
PLANNED	1/27/2021	11	451	41
PLANNED	1/27/2021	7	182	26
CUSTOMER REQUEST	1/27/2021	8	64	8
PLANNED	1/27/2021	1	91	91
PLANNED	1/27/2021	2	64	32
PLANNED	1/27/2021	173	20,760	120
PLANNED	1/27/2021	2	10	5
PLANNED	1/27/2021	4	696	174
PLANNED	1/27/2021	3	171	57
PLANNED	1/27/2021	10	650	65
PLANNED	1/27/2021	1	363	363
PLANNED	1/27/2021	2	746	373
PLANNED	1/27/2021	3	651	217
PLANNED	1/27/2021	7	238	34
PLANNED	1/27/2021	6	186	31
PLANNED	1/27/2021	2	218	109
PLANNED	1/27/2021	2	136	68
PLANNED	1/27/2021	6	114	19
CUSTOMER REQUEST	1/27/2021	9	1,782	198
PLANNED	1/27/2021	2	12	6
PLANNED	1/27/2021	1	58	58

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/27/2021	5	30	6
PLANNED	1/27/2021	14	756	54
PLANNED	1/27/2021	7	231	33
PLANNED	1/27/2021	1	71	71
PLANNED	1/27/2021	4	652	163
PLANNED	1/27/2021	1	50	50
PLANNED	1/27/2021	3	93	31
PLANNED	1/27/2021	2	516	258
PLANNED	1/27/2021	7	210	30
PLANNED	1/27/2021	10	300	30
PLANNED	1/27/2021	3	36	12
PLANNED	1/27/2021	12	408	34
PLANNED	1/27/2021	3	243	81
PLANNED	1/27/2021	1	291	291
PLANNED	1/27/2021	6	1,548	258
PLANNED	1/27/2021	1	77	77
PLANNED	1/27/2021	16	3,104	194
PLANNED	1/27/2021	3	42	14
PLANNED	1/27/2021	61	4,026	66
PLANNED	1/27/2021	8	296	37
PLANNED	1/27/2021	7	1,176	168
PLANNED	1/27/2021	9	360	40
PLANNED	1/27/2021	1	36	36
PLANNED	1/27/2021	1	26	26
PLANNED	1/27/2021	22	5,164	948
PLANNED	1/27/2021	1	132	132
PLANNED	1/27/2021	2	268	134
CUSTOMER REQUEST	1/27/2021	1	250	250
PLANNED	1/27/2021	4	84	21
PLANNED	1/27/2021	3	504	168
PLANNED	1/27/2021	3	96	32
PLANNED	1/27/2021	1	73	73
PLANNED	1/27/2021	1	63	63
PLANNED	1/27/2021	4	708	177
PLANNED	1/27/2021	3	219	73
PLANNED	1/27/2021	3	237	79
PLANNED	1/27/2021	3	78	26
PLANNED	1/27/2021	1	136	136
PLANNED	1/27/2021	1	7	7
PLANNED	1/27/2021	3	405	135
PLANNED	1/27/2021	3	192	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/27/2021	2	30	15
CUSTOMER REQUEST	1/27/2021	1	201	201
PLANNED	1/27/2021	2	100	50
PLANNED	1/27/2021	5	65	13
PLANNED	1/27/2021	1	35	35
PLANNED	1/27/2021	2	220	110
CUSTOMER REQUEST	1/27/2021	1	80	80
PLANNED	1/27/2021	5	90	18
PLANNED	1/27/2021	2	24	12
PLANNED	1/27/2021	3	717	239
PLANNED	1/27/2021	2	78	39
PLANNED	1/27/2021	2	28	14
PLANNED	1/27/2021	6	90	15
PLANNED	1/27/2021	23	3,680	160
PLANNED	1/27/2021	1	127	127
PLANNED	1/27/2021	1	65	65
PLANNED	1/27/2021	3	231	77
PLANNED	1/27/2021	1	94	94
PLANNED	1/27/2021	1	189	189
PLANNED	1/27/2021	1	140	140
PLANNED	1/27/2021	2	304	152
PLANNED	1/27/2021	1	371	371
PLANNED	1/27/2021	5	610	122
PLANNED	1/27/2021	1	57	57
PLANNED	1/27/2021	2	22	11
CUSTOMER REQUEST	1/27/2021	6	1,242	207
PLANNED	1/28/2021	4	912	228
PLANNED	1/28/2021	4	376	94
PLANNED	1/28/2021	1	89	89
PLANNED	1/28/2021	1	160	160
PLANNED	1/28/2021	3	306	102
PLANNED	1/28/2021	1	27	27
PLANNED	1/28/2021	3	204	68
PLANNED	1/28/2021	1	247	247
PLANNED	1/28/2021	22	1,892	86
PLANNED	1/28/2021	2	212	106
PLANNED	1/28/2021	1	23	23
PLANNED	1/28/2021	6	1,212	202
PLANNED	1/28/2021	9	270	30
PLANNED	1/28/2021	5	675	135
PLANNED	1/28/2021	13	1,157	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/28/2021	12	972	81
PLANNED	1/28/2021	5	720	144
PLANNED	1/28/2021	8	112	14
PLANNED	1/28/2021	2	100	50
PLANNED	1/28/2021	4	960	240
PLANNED	1/28/2021	8	1,048	131
PLANNED	1/28/2021	10	1,310	131
PLANNED	1/28/2021	5	655	131
PLANNED	1/28/2021	7	91	13
PLANNED	1/28/2021	2	142	71
PLANNED	1/28/2021	3	42	14
PLANNED	1/28/2021	2	112	56
PLANNED	1/28/2021	2	150	75
PLANNED	1/28/2021	4	84	21
PLANNED	1/28/2021	1	134	134
PLANNED	1/28/2021	2	276	167
PLANNED	1/28/2021	9	342	38
PLANNED	1/28/2021	73	2,920	40
PLANNED	1/28/2021	1	62	62
PLANNED	1/28/2021	3	48	16
PLANNED	1/28/2021	3	72	24
PLANNED	1/28/2021	1	28	28
PLANNED	1/28/2021	9	207	23
PLANNED	1/28/2021	5	500	100
PLANNED	1/28/2021	3	1,032	344
PLANNED	1/28/2021	5	510	102
PLANNED	1/28/2021	9	486	54
PLANNED	1/28/2021	17	697	41
PLANNED	1/28/2021	4	68	17
PLANNED	1/28/2021	7	259	37
PLANNED	1/28/2021	1	139	139
PLANNED	1/28/2021	1	15	15
PLANNED	1/28/2021	1	42	42
PLANNED	1/28/2021	3	360	120
PLANNED	1/28/2021	2	22	11
PLANNED	1/28/2021	10	410	41
PLANNED	1/28/2021	1	55	55
PLANNED	1/28/2021	4	60	15
PLANNED	1/28/2021	9	351	39
PLANNED	1/28/2021	2	252	126
CUSTOMER REQUEST	1/28/2021	7	70	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/28/2021	17	17	1
PLANNED	1/28/2021	10	80	8
PLANNED	1/28/2021	1	14	14
PLANNED	1/28/2021	1	15	15
PLANNED	1/28/2021	8	328	41
PLANNED	1/28/2021	1	237	237
PLANNED	1/28/2021	4	184	46
PLANNED	1/28/2021	2	52	26
PLANNED	1/28/2021	3	168	56
PLANNED	1/28/2021	2	278	139
PLANNED	1/28/2021	11	22	2
PLANNED	1/28/2021	1	44	44
PLANNED	1/28/2021	2	18	9
PLANNED	1/28/2021	2	58	29
CUSTOMER REQUEST	1/28/2021	7	98	14
PLANNED	1/28/2021	10	530	53
PLANNED	1/28/2021	2	190	95
PLANNED	1/28/2021	3	33	11
CUSTOMER REQUEST	1/28/2021	9	288	32
PLANNED	1/28/2021	2	220	110
PLANNED	1/28/2021	14	2,940	210
PLANNED	1/28/2021	2	140	70
PLANNED	1/28/2021	10	30	3
PLANNED	1/28/2021	4	280	70
PLANNED	1/28/2021	4	56	14
PLANNED	1/28/2021	2	120	60
PLANNED	1/28/2021	3	252	84
PLANNED	1/28/2021	1	55	55
PLANNED	1/28/2021	1	17	17
PLANNED	1/28/2021	1	525	525
PLANNED	1/28/2021	22	4,224	192
CUSTOMER REQUEST	1/28/2021	4	1,148	287
PLANNED	1/28/2021	2	70	35
PLANNED	1/28/2021	4	144	36
PLANNED	1/28/2021	7	630	90
PLANNED	1/28/2021	7	1,568	224
PLANNED	1/28/2021	9	58	10
PLANNED	1/28/2021	6	228	38
PLANNED	1/28/2021	12	870	188
PLANNED	1/28/2021	3	93	31
CUSTOMER REQUEST	1/28/2021	6	12	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/28/2021	5	135	27
CUSTOMER REQUEST	1/28/2021	1	88	88
PLANNED	1/28/2021	2	60	30
PLANNED	1/28/2021	4	572	143
PLANNED	1/28/2021	2	174	87
CUSTOMER REQUEST	1/28/2021	7	42	6
PLANNED	1/28/2021	1	198	198
PLANNED	1/28/2021	8	208	26
PLANNED	1/28/2021	2	142	71
PLANNED	1/28/2021	3	81	27
PLANNED	1/28/2021	2	100	50
PLANNED	1/28/2021	2	370	185
PLANNED	1/28/2021	10	500	50
PLANNED	1/28/2021	2	58	29
PLANNED	1/28/2021	1	15	15
PLANNED	1/28/2021	2	234	117
PLANNED	1/28/2021	2	52	26
PLANNED	1/28/2021	1	111	111
PLANNED	1/28/2021	1	116	116
PLANNED	1/28/2021	2	302	151
PLANNED	1/28/2021	3	576	192
PLANNED	1/28/2021	2	300	150
PLANNED	1/28/2021	4	28	7
PLANNED	1/28/2021	2	204	102
PLANNED	1/28/2021	2	94	47
PLANNED	1/28/2021	1	3	3
PLANNED	1/28/2021	4	228	57
PLANNED	1/28/2021	5	525	105
PLANNED	1/28/2021	5	1,000	200
PLANNED	1/28/2021	1	154	154
CUSTOMER REQUEST	1/28/2021	3	675	225
PLANNED	1/28/2021	1	253	253
PLANNED	1/28/2021	1	167	167
PLANNED	1/28/2021	1	71	71
PLANNED	1/28/2021	5	440	88
PLANNED	1/28/2021	2	426	213
PLANNED	1/28/2021	5	785	157
PLANNED	1/28/2021	5	1,750	350
PLANNED	1/28/2021	1	335	335
PLANNED	1/28/2021	12	924	77
PLANNED	1/29/2021	3	321	107

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/29/2021	7	273	39
PLANNED	1/29/2021	9	612	68
PLANNED	1/29/2021	1	35	35
PLANNED	1/29/2021	3	222	74
CUSTOMER REQUEST	1/29/2021	1	1	2,162
PLANNED	1/29/2021	10	400	40
PLANNED	1/29/2021	10	360	36
PLANNED	1/29/2021	12	360	30
PLANNED	1/29/2021	8	216	27
PLANNED	1/29/2021	16	224	14
PLANNED	1/29/2021	2	186	93
PLANNED	1/29/2021	3	93	31
PLANNED	1/29/2021	11	517	47
PLANNED	1/29/2021	5	55	11
PLANNED	1/29/2021	2	114	57
PLANNED	1/29/2021	10	450	45
PLANNED	1/29/2021	9	1,251	139
PLANNED	1/29/2021	16	2,368	148
PLANNED	1/29/2021	1	12	12
PLANNED	1/29/2021	1	32	32
PLANNED	1/29/2021	5	220	44
CUSTOMER REQUEST	1/29/2021	9	36	4
CUSTOMER REQUEST	1/29/2021	3	1,278	426
CUSTOMER REQUEST	1/29/2021	13	237	100
PLANNED	1/29/2021	1	105	105
PLANNED	1/29/2021	3	45	15
PLANNED	1/29/2021	36	6,768	188
PLANNED	1/29/2021	4	556	139
PLANNED	1/29/2021	3	261	87
PLANNED	1/29/2021	2	316	158
PLANNED	1/29/2021	4	56	14
PLANNED	1/29/2021	2	92	46
PLANNED	1/29/2021	7	1,022	146
PLANNED	1/29/2021	1	103	103
PLANNED	1/29/2021	4	576	144
PLANNED	1/29/2021	3	84	28
PLANNED	1/29/2021	5	235	47
PLANNED	1/29/2021	3	198	66
PLANNED	1/29/2021	1	48	48
PLANNED	1/29/2021	3	429	143
PLANNED	1/29/2021	1	16	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	1/29/2021	1	369	369
PLANNED	1/29/2021	2	208	104
PLANNED	1/29/2021	5	60	12
PLANNED	1/29/2021	16	240	15
CUSTOMER REQUEST	1/29/2021	16	96	6
PLANNED	1/29/2021	5	70	14
PLANNED	1/29/2021	6	960	160
PLANNED	1/29/2021	3	36	12
PLANNED	1/29/2021	5	160	32
PLANNED	1/29/2021	35	1,330	38
PLANNED	1/29/2021	3	147	49
PLANNED	1/29/2021	5	135	27
PLANNED	1/29/2021	2	24	12
PLANNED	1/29/2021	6	114	19
PLANNED	1/29/2021	3	471	157
PLANNED	1/29/2021	11	690	174
PLANNED	1/29/2021	5	120	24
PLANNED	1/29/2021	1	25	25
PLANNED	1/29/2021	1	36	36
PLANNED	1/29/2021	9	45	5
PLANNED	1/29/2021	4	312	78
PLANNED	1/29/2021	7	161	23
PLANNED	1/29/2021	3	36	12
PLANNED	1/29/2021	4	420	105
PLANNED	1/29/2021	2	48	24
PLANNED	1/29/2021	10	150	15
PLANNED	1/29/2021	4	76	19
PLANNED	1/29/2021	1	81	81
PLANNED	1/29/2021	8	280	35
PLANNED	1/29/2021	2	234	117
PLANNED	1/29/2021	4	884	221
PLANNED	1/29/2021	8	432	54
PLANNED	1/29/2021	20	220	11
PLANNED	1/29/2021	12	1,344	112
PLANNED	1/29/2021	3	105	35
PLANNED	1/29/2021	1	126	126
PLANNED	1/29/2021	2	40	20
PLANNED	1/29/2021	5	80	16
PLANNED	1/29/2021	1	26	26
CUSTOMER REQUEST	1/29/2021	1	178	178
CUSTOMER REQUEST	1/30/2021	1	372	372

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	1/30/2021	1	241	241
PLANNED	1/30/2021	27	4,212	156
PLANNED	1/30/2021	4	340	85
PLANNED	1/30/2021	4	368	92
PLANNED	1/30/2021	1	357	357
PLANNED	1/30/2021	1	52	52
PLANNED	1/30/2021	2	536	268
PLANNED	1/30/2021	13	2,548	196
PLANNED	1/30/2021	1	254	254
PLANNED	1/30/2021	3	762	254
PLANNED	1/30/2021	8	1,456	182
PLANNED	1/30/2021	1	146	146
PLANNED	1/30/2021	6	474	79
PLANNED	1/30/2021	4	388	97
CUSTOMER REQUEST	1/30/2021	15	255	17
PLANNED	1/30/2021	8	144	18
PLANNED	1/31/2021	1	272	272
PLANNED	1/31/2021	1	113	113
PLANNED	1/31/2021	1	46	46
PLANNED	1/31/2021	3	123	41
CUSTOMER REQUEST	1/31/2021	1	48	48
CUSTOMER REQUEST	1/31/2021	1	20	20
CUSTOMER REQUEST	1/31/2021	4	664	166
PLANNED	2/1/2021	1	161	161
PLANNED	2/1/2021	9	2,475	275
PLANNED	2/1/2021	1	10	10
PLANNED	2/1/2021	10	150	15
PLANNED	2/1/2021	1	194	194
PLANNED	2/1/2021	3	567	189
PLANNED	2/1/2021	8	240	30
PLANNED	2/1/2021	2	212	106
PLANNED	2/1/2021	4	40	10
CUSTOMER REQUEST	2/1/2021	15	135	9
CUSTOMER REQUEST	2/1/2021	2	720	360
PLANNED	2/1/2021	2	270	135
PLANNED	2/1/2021	2	351	184
PLANNED	2/1/2021	1	141	141
PLANNED	2/1/2021	2	258	129
PLANNED	2/1/2021	5	85	17
PLANNED	2/1/2021	1	54	54
PLANNED	2/1/2021	1	69	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	2/1/2021	2	22	11
PLANNED	2/1/2021	4	32	8
PLANNED	2/1/2021	6	594	99
PLANNED	2/1/2021	5	150	30
PLANNED	2/1/2021	3	225	75
PLANNED	2/1/2021	3	39	13
PLANNED	2/1/2021	7	105	15
PLANNED	2/1/2021	9	333	37
PLANNED	2/1/2021	3	201	67
PLANNED	2/1/2021	3	72	24
PLANNED	2/1/2021	8	1,412	301
PLANNED	2/1/2021	5	110	22
PLANNED	2/1/2021	3	144	48
CUSTOMER REQUEST	2/1/2021	7	35	5
PLANNED	2/1/2021	3	288	96
PLANNED	2/1/2021	2	184	92
PLANNED	2/1/2021	3	189	63
PLANNED	2/1/2021	1	183	183
PLANNED	2/1/2021	6	78	13
CUSTOMER REQUEST	2/1/2021	1	37	37
PLANNED	2/1/2021	1	22	22
PLANNED	2/1/2021	1	14	14
PLANNED	2/1/2021	5	380	76
PLANNED	2/1/2021	1	11	11
PLANNED	2/1/2021	6	258	43
PLANNED	2/1/2021	7	378	54
PLANNED	2/1/2021	4	544	136
PLANNED	2/1/2021	6	282	47
PLANNED	2/1/2021	6	1,716	286
PLANNED	2/1/2021	6	1,158	193
PLANNED	2/1/2021	9	378	42
PLANNED	2/1/2021	2	254	127
PLANNED	2/1/2021	1	16	16
PLANNED	2/1/2021	2	158	79
PLANNED	2/1/2021	1	339	339
PLANNED	2/1/2021	4	148	37
CUSTOMER REQUEST	2/1/2021	4	16	4
PLANNED	2/1/2021	1	28	28
PLANNED	2/1/2021	3	39	13
PLANNED	2/1/2021	3	1,269	423
PLANNED	2/1/2021	8	232	29

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/1/2021	7	427	61
PLANNED	2/1/2021	6	90	15
PLANNED	2/1/2021	2	208	104
PLANNED	2/1/2021	7	168	24
PLANNED	2/1/2021	5	225	45
PLANNED	2/1/2021	3	603	201
PLANNED	2/1/2021	66	7,854	119
PLANNED	2/1/2021	4	436	109
PLANNED	2/1/2021	1	77	77
PLANNED	2/1/2021	87	1,479	17
PLANNED	2/1/2021	1	14	14
PLANNED	2/1/2021	4	124	31
PLANNED	2/1/2021	6	288	48
PLANNED	2/1/2021	6	12	2
PLANNED	2/1/2021	6	972	162
PLANNED	2/1/2021	4	212	53
PLANNED	2/1/2021	10	750	75
PLANNED	2/1/2021	8	40	5
PLANNED	2/1/2021	4	128	32
PLANNED	2/1/2021	5	100	20
PLANNED	2/1/2021	7	462	66
PLANNED	2/1/2021	1	253	253
PLANNED	2/1/2021	2	208	104
PLANNED	2/1/2021	9	603	67
PLANNED	2/1/2021	3	120	40
PLANNED	2/1/2021	3	129	43
PLANNED	2/1/2021	2	430	215
PLANNED	2/1/2021	1	36	36
PLANNED	2/1/2021	1	54	54
PLANNED	2/1/2021	12	540	45
PLANNED	2/1/2021	8	296	37
PLANNED	2/1/2021	1	106	106
PLANNED	2/1/2021	5	280	56
PLANNED	2/1/2021	16	2,370	153
PLANNED	2/1/2021	6	66	11
PLANNED	2/1/2021	3	9	3
PLANNED	2/1/2021	4	904	226
PLANNED	2/1/2021	5	160	32
PLANNED	2/1/2021	7	56	8
PLANNED	2/1/2021	13	4,875	375
PLANNED	2/1/2021	11	11	1

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/1/2021	7	504	72
PLANNED	2/1/2021	5	280	56
PLANNED	2/1/2021	23	276	12
PLANNED	2/1/2021	1	37	37
PLANNED	2/1/2021	2	290	174
PLANNED	2/1/2021	8	336	42
PLANNED	2/1/2021	8	256	32
PLANNED	2/1/2021	3	276	92
PLANNED	2/1/2021	1	61	61
PLANNED	2/1/2021	9	36	4
PLANNED	2/1/2021	1	104	104
PLANNED	2/1/2021	1	115	115
PLANNED	2/1/2021	4	532	133
PLANNED	2/1/2021	5	185	37
PLANNED	2/1/2021	2	52	26
PLANNED	2/1/2021	8	168	21
PLANNED	2/1/2021	1	51	51
PLANNED	2/1/2021	2	62	31
PLANNED	2/1/2021	4	476	119
PLANNED	2/1/2021	16	480	30
PLANNED	2/1/2021	6	324	54
PLANNED	2/1/2021	5	540	108
PLANNED	2/1/2021	4	116	29
PLANNED	2/1/2021	14	448	32
PLANNED	2/1/2021	9	882	98
PLANNED	2/1/2021	3	126	42
PLANNED	2/1/2021	1	86	86
PLANNED	2/1/2021	3	234	78
PLANNED	2/1/2021	4	40	10
PLANNED	2/1/2021	3	42	14
PLANNED	2/1/2021	1	11	11
PLANNED	2/1/2021	9	261	29
PLANNED	2/1/2021	3	63	21
PLANNED	2/1/2021	1	84	84
PLANNED	2/1/2021	13	520	40
PLANNED	2/1/2021	5	65	13
PLANNED	2/1/2021	8	352	44
PLANNED	2/1/2021	1	281	281
PLANNED	2/1/2021	20	6,140	307
PLANNED	2/2/2021	1	80	80
PLANNED	2/2/2021	2	108	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/2/2021	24	528	22
PLANNED	2/2/2021	3	144	48
PLANNED	2/2/2021	1	85	85
PLANNED	2/2/2021	1	93	93
PLANNED	2/2/2021	2	166	83
PLANNED	2/2/2021	3	207	69
PLANNED	2/2/2021	1	145	145
PLANNED	2/2/2021	3	171	57
PLANNED	2/2/2021	4	320	80
PLANNED	2/2/2021	3	378	126
PLANNED	2/2/2021	2	156	78
PLANNED	2/2/2021	5	1,015	203
PLANNED	2/2/2021	7	819	117
PLANNED	2/2/2021	8	944	118
PLANNED	2/2/2021	7	553	79
PLANNED	2/2/2021	3	138	46
PLANNED	2/2/2021	14	1,092	78
PLANNED	2/2/2021	6	726	121
PLANNED	2/2/2021	76	9,804	129
PLANNED	2/2/2021	1	41	41
PLANNED	2/2/2021	8	976	122
PLANNED	2/2/2021	8	1,072	134
PLANNED	2/2/2021	7	847	121
PLANNED	2/2/2021	2	252	126
PLANNED	2/2/2021	10	380	38
PLANNED	2/2/2021	1	222	222
PLANNED	2/2/2021	2	378	189
CUSTOMER REQUEST	2/2/2021	6	522	87
CUSTOMER REQUEST	2/2/2021	20	4,268	451
PLANNED	2/2/2021	1	12	12
PLANNED	2/2/2021	1	131	131
PLANNED	2/2/2021	11	1,001	91
PLANNED	2/2/2021	6	474	79
PLANNED	2/2/2021	3	225	75
PLANNED	2/2/2021	8	192	24
PLANNED	2/2/2021	5	300	60
PLANNED	2/2/2021	1	83	83
PLANNED	2/2/2021	5	390	78
PLANNED	2/2/2021	3	459	153
PLANNED	2/2/2021	9	585	65
PLANNED	2/2/2021	29	8,787	303

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/2/2021	22	1,826	83
PLANNED	2/2/2021	8	96	12
PLANNED	2/2/2021	8	336	42
PLANNED	2/2/2021	9	378	42
PLANNED	2/2/2021	1	147	147
PLANNED	2/2/2021	8	336	42
PLANNED	2/2/2021	1	47	47
PLANNED	2/2/2021	6	192	32
PLANNED	2/2/2021	9	747	83
PLANNED	2/2/2021	1	123	123
PLANNED	2/2/2021	11	814	74
PLANNED	2/2/2021	1	274	274
CUSTOMER REQUEST	2/2/2021	12	348	29
PLANNED	2/2/2021	1	46	46
PLANNED	2/2/2021	16	1,968	123
PLANNED	2/2/2021	6	306	51
PLANNED	2/2/2021	10	700	70
PLANNED	2/2/2021	6	420	70
PLANNED	2/2/2021	5	55	11
PLANNED	2/2/2021	7	413	59
PLANNED	2/2/2021	2	230	115
PLANNED	2/2/2021	1	30	30
PLANNED	2/2/2021	4	468	117
PLANNED	2/2/2021	24	768	32
PLANNED	2/2/2021	6	546	91
PLANNED	2/2/2021	8	704	88
PLANNED	2/2/2021	8	1,552	194
PLANNED	2/2/2021	2	30	15
PLANNED	2/2/2021	1	128	128
CUSTOMER REQUEST	2/2/2021	2	36	18
PLANNED	2/2/2021	2	182	91
PLANNED	2/2/2021	8	752	94
CUSTOMER REQUEST	2/2/2021	5	70	14
PLANNED	2/2/2021	14	308	22
CUSTOMER REQUEST	2/2/2021	29	13,991	499
PLANNED	2/2/2021	5	445	89
PLANNED	2/2/2021	7	623	89
PLANNED	2/2/2021	9	911	135
PLANNED	2/2/2021	3	435	145
PLANNED	2/2/2021	5	951	209
CUSTOMER REQUEST	2/2/2021	10	310	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/2/2021	73	6,862	94
PLANNED	2/2/2021	11	454	194
PLANNED	2/2/2021	3	297	99
PLANNED	2/2/2021	2	234	117
PLANNED	2/2/2021	3	117	39
PLANNED	2/2/2021	8	176	22
PLANNED	2/2/2021	1	75	75
PLANNED	2/2/2021	1	95	95
PLANNED	2/2/2021	2	60	30
PLANNED	2/2/2021	8	1,184	148
PLANNED	2/2/2021	5	250	50
PLANNED	2/2/2021	1	55	55
PLANNED	2/2/2021	4	388	97
PLANNED	2/2/2021	1	17	17
PLANNED	2/2/2021	5	130	26
PLANNED	2/2/2021	11	506	46
PLANNED	2/2/2021	7	392	56
PLANNED	2/2/2021	1	14	14
PLANNED	2/2/2021	6	168	28
PLANNED	2/2/2021	1	77	77
PLANNED	2/2/2021	11	1,210	110
PLANNED	2/2/2021	9	1,332	148
PLANNED	2/2/2021	5	90	18
PLANNED	2/2/2021	3	15	5
PLANNED	2/2/2021	2	72	36
PLANNED	2/2/2021	1	59	59
PLANNED	2/2/2021	1	59	59
PLANNED	2/2/2021	6	378	63
PLANNED	2/2/2021	2	36	18
PLANNED	2/2/2021	3	273	91
PLANNED	2/2/2021	3	567	189
PLANNED	2/2/2021	4	104	26
PLANNED	2/2/2021	2	234	117
PLANNED	2/2/2021	6	174	29
PLANNED	2/2/2021	1	26	26
PLANNED	2/2/2021	1	63	63
PLANNED	2/2/2021	8	320	40
PLANNED	2/2/2021	2	82	41
PLANNED	2/2/2021	11	748	68
PLANNED	2/2/2021	5	545	109
PLANNED	2/2/2021	1	47	47

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/2/2021	4	116	29
PLANNED	2/2/2021	6	660	110
PLANNED	2/2/2021	1	19	19
PLANNED	2/2/2021	8	248	31
PLANNED	2/2/2021	1	80	80
PLANNED	2/2/2021	2	46	23
PLANNED	2/2/2021	4	313	82
PLANNED	2/2/2021	3	81	27
PLANNED	2/2/2021	4	604	151
PLANNED	2/2/2021	8	656	82
PLANNED	2/2/2021	8	144	18
PLANNED	2/2/2021	6	186	31
PLANNED	2/2/2021	7	560	110
PLANNED	2/2/2021	8	56	7
PLANNED	2/2/2021	8	1,800	225
PLANNED	2/2/2021	2	164	82
PLANNED	2/2/2021	4	328	82
PLANNED	2/2/2021	1	23	23
PLANNED	2/3/2021	1	127	127
PLANNED	2/3/2021	1	75	75
PLANNED	2/3/2021	1	138	138
PLANNED	2/3/2021	4	772	193
CUSTOMER REQUEST	2/3/2021	6	744	124
PLANNED	2/3/2021	2	218	109
PLANNED	2/3/2021	3	300	100
PLANNED	2/3/2021	2	198	99
PLANNED	2/3/2021	1	104	104
PLANNED	2/3/2021	5	3,810	762
PLANNED	2/3/2021	2	434	217
PLANNED	2/3/2021	8	184	23
PLANNED	2/3/2021	3	405	135
PLANNED	2/3/2021	1	71	71
PLANNED	2/3/2021	8	600	75
PLANNED	2/3/2021	2	326	163
PLANNED	2/3/2021	10	770	77
PLANNED	2/3/2021	5	400	80
PLANNED	2/3/2021	7	980	140
PLANNED	2/3/2021	3	2,229	743
PLANNED	2/3/2021	1	51	51
PLANNED	2/3/2021	2	130	65
PLANNED	2/3/2021	18	1,872	104

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/3/2021	2	114	57
PLANNED	2/3/2021	7	329	47
PLANNED	2/3/2021	2	74	37
PLANNED	2/3/2021	16	2,240	140
PLANNED	2/3/2021	3	93	31
PLANNED	2/3/2021	1	400	400
PLANNED	2/3/2021	2	454	227
PLANNED	2/3/2021	4	452	113
PLANNED	2/3/2021	8	1,120	140
PLANNED	2/3/2021	6	246	41
PLANNED	2/3/2021	9	54	6
PLANNED	2/3/2021	4	192	48
PLANNED	2/3/2021	1	71	71
PLANNED	2/3/2021	1	19	19
PLANNED	2/3/2021	4	304	76
PLANNED	2/3/2021	2	54	27
PLANNED	2/3/2021	10	770	77
PLANNED	2/3/2021	7	147	21
PLANNED	2/3/2021	1	65	65
PLANNED	2/3/2021	1	138	138
PLANNED	2/3/2021	6	282	47
PLANNED	2/3/2021	2	26	13
PLANNED	2/3/2021	2	66	33
CUSTOMER REQUEST	2/3/2021	4	1,036	259
PLANNED	2/3/2021	10	730	73
PLANNED	2/3/2021	11	726	66
PLANNED	2/3/2021	8	64	8
PLANNED	2/3/2021	124	7,980	189
PLANNED	2/3/2021	4	888	222
PLANNED	2/3/2021	4	656	164
PLANNED	2/3/2021	2	24	12
PLANNED	2/3/2021	1	98	98
PLANNED	2/3/2021	2	45	26
PLANNED	2/3/2021	1	63	63
PLANNED	2/3/2021	8	360	45
PLANNED	2/3/2021	2	212	106
PLANNED	2/3/2021	2	278	139
PLANNED	2/3/2021	7	308	44
PLANNED	2/3/2021	8	360	45
PLANNED	2/3/2021	5	240	48
PLANNED	2/3/2021	8	424	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/3/2021	12	840	71
PLANNED	2/3/2021	6	288	48
PLANNED	2/3/2021	4	68	17
PLANNED	2/3/2021	4	28	7
PLANNED	2/3/2021	7	248	122
PLANNED	2/3/2021	1	35	35
PLANNED	2/3/2021	2	58	29
PLANNED	2/3/2021	2	30	15
PLANNED	2/3/2021	6	918	153
PLANNED	2/3/2021	5	80	16
PLANNED	2/3/2021	2	64	32
PLANNED	2/3/2021	1	34	34
PLANNED	2/3/2021	1	119	119
PLANNED	2/3/2021	4	348	87
CUSTOMER REQUEST	2/3/2021	12	72	6
PLANNED	2/3/2021	1	35	35
PLANNED	2/3/2021	4	208	52
PLANNED	2/3/2021	19	741	39
PLANNED	2/3/2021	1	18	18
PLANNED	2/3/2021	1	119	119
PLANNED	2/3/2021	9	594	66
PLANNED	2/3/2021	10	650	65
PLANNED	2/3/2021	12	876	73
PLANNED	2/3/2021	1	73	73
PLANNED	2/3/2021	39	2,574	66
PLANNED	2/3/2021	19	1,406	74
PLANNED	2/3/2021	2	56	28
PLANNED	2/3/2021	1	36	36
PLANNED	2/3/2021	8	136	17
PLANNED	2/3/2021	1	70	70
PLANNED	2/3/2021	12	504	42
PLANNED	2/3/2021	2	734	367
PLANNED	2/3/2021	2	302	151
PLANNED	2/3/2021	2	48	24
PLANNED	2/3/2021	9	27	3
CUSTOMER REQUEST	2/3/2021	1	391	391
PLANNED	2/3/2021	4	332	83
PLANNED	2/3/2021	2	242	121
PLANNED	2/3/2021	559	36,894	66
PLANNED	2/3/2021	1	74	74
PLANNED	2/3/2021	1	66	66

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/3/2021	1	95	95
PLANNED	2/3/2021	3	129	43
PLANNED	2/3/2021	5	640	128
PLANNED	2/3/2021	4	52	13
PLANNED	2/3/2021	2	12	6
PLANNED	2/3/2021	3	42	14
PLANNED	2/3/2021	9	225	25
PLANNED	2/3/2021	3	336	112
PLANNED	2/3/2021	8	248	31
PLANNED	2/3/2021	4	284	71
PLANNED	2/3/2021	5	525	105
PLANNED	2/3/2021	1	219	219
PLANNED	2/3/2021	2	98	49
PLANNED	2/3/2021	9	504	56
PLANNED	2/3/2021	3	336	112
PLANNED	2/3/2021	3	69	23
PLANNED	2/3/2021	1	109	109
PLANNED	2/3/2021	2	130	65
PLANNED	2/3/2021	2	32	16
PLANNED	2/3/2021	1	125	125
PLANNED	2/3/2021	1	14	14
PLANNED	2/3/2021	2	206	103
PLANNED	2/3/2021	2	144	72
PLANNED	2/3/2021	2	58	29
PLANNED	2/3/2021	2	210	105
PLANNED	2/3/2021	2	102	51
PLANNED	2/3/2021	1	250	250
PLANNED	2/3/2021	1	248	248
PLANNED	2/3/2021	4	332	83
PLANNED	2/3/2021	2	164	82
PLANNED	2/4/2021	2	242	121
PLANNED	2/4/2021	1	36	36
PLANNED	2/4/2021	1	66	66
PLANNED	2/4/2021	4	1,252	313
PLANNED	2/4/2021	1	4	4
PLANNED	2/4/2021	2	184	122
PLANNED	2/4/2021	7	532	76
PLANNED	2/4/2021	2	90	45
PLANNED	2/4/2021	8	328	41
PLANNED	2/4/2021	28	1,568	56
PLANNED	2/4/2021	2	138	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/4/2021	17	136	8
PLANNED	2/4/2021	9	297	33
PLANNED	2/4/2021	16	3,664	229
PLANNED	2/4/2021	8	1,400	175
PLANNED	2/4/2021	5	115	23
CUSTOMER REQUEST	2/4/2021	37	12,543	339
PLANNED	2/4/2021	4	624	156
PLANNED	2/4/2021	10	1,350	135
PLANNED	2/4/2021	14	1,442	103
CUSTOMER REQUEST	2/4/2021	13	169	13
PLANNED	2/4/2021	4	824	206
PLANNED	2/4/2021	1	78	78
PLANNED	2/4/2021	6	1,584	264
PLANNED	2/4/2021	1	70	70
PLANNED	2/4/2021	3	189	63
PLANNED	2/4/2021	4	1,056	264
PLANNED	2/4/2021	36	11,308	701
CUSTOMER REQUEST	2/4/2021	2	46	23
PLANNED	2/4/2021	6	1,536	256
PLANNED	2/4/2021	5	1,320	264
PLANNED	2/4/2021	8	856	107
PLANNED	2/4/2021	1	48	48
CUSTOMER REQUEST	2/4/2021	26	7,306	281
CUSTOMER REQUEST	2/4/2021	1	47	47
PLANNED	2/4/2021	6	96	16
CUSTOMER REQUEST	2/4/2021	9	1,755	195
PLANNED	2/4/2021	9	405	45
PLANNED	2/4/2021	2	58	29
PLANNED	2/4/2021	3	393	131
PLANNED	2/4/2021	10	140	14
PLANNED	2/4/2021	72	13,608	189
PLANNED	2/4/2021	4	364	91
PLANNED	2/4/2021	5	210	42
PLANNED	2/4/2021	1	18	18
PLANNED	2/4/2021	2	32	16
PLANNED	2/4/2021	11	440	40
PLANNED	2/4/2021	9	414	46
PLANNED	2/4/2021	4	1,732	433
PLANNED	2/4/2021	2	210	105
PLANNED	2/4/2021	3	267	89
PLANNED	2/4/2021	7	301	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/4/2021	3	351	117
PLANNED	2/4/2021	30	1,800	60
PLANNED	2/4/2021	5	280	56
PLANNED	2/4/2021	2	346	173
PLANNED	2/4/2021	2	66	33
PLANNED	2/4/2021	7	581	83
PLANNED	2/4/2021	1	129	129
PLANNED	2/4/2021	3	318	106
PLANNED	2/4/2021	1	7	7
PLANNED	2/4/2021	11	1,375	125
PLANNED	2/4/2021	29	6,757	233
PLANNED	2/4/2021	1	262	262
PLANNED	2/4/2021	3	66	22
PLANNED	2/4/2021	5	75	15
PLANNED	2/4/2021	3	105	35
PLANNED	2/4/2021	2	270	135
PLANNED	2/4/2021	7	406	58
PLANNED	2/4/2021	13	3,605	310
PLANNED	2/4/2021	3	39	13
PLANNED	2/4/2021	3	42	14
PLANNED	2/4/2021	1	83	83
PLANNED	2/4/2021	1	96	96
PLANNED	2/4/2021	2	62	31
PLANNED	2/4/2021	2	56	28
PLANNED	2/4/2021	1	221	221
PLANNED	2/4/2021	4	800	200
PLANNED	2/4/2021	11	297	27
PLANNED	2/4/2021	5	720	144
PLANNED	2/4/2021	8	1,152	144
PLANNED	2/4/2021	5	1,350	270
PLANNED	2/4/2021	43	11,524	268
PLANNED	2/4/2021	2	18	9
PLANNED	2/4/2021	16	464	29
PLANNED	2/4/2021	7	154	22
PLANNED	2/4/2021	6	132	22
PLANNED	2/4/2021	5	400	80
PLANNED	2/4/2021	10	20	2
PLANNED	2/4/2021	10	810	81
CUSTOMER REQUEST	2/4/2021	22	2,574	117
PLANNED	2/4/2021	18	630	35
PLANNED	2/4/2021	6	684	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/4/2021	6	576	96
CUSTOMER REQUEST	2/4/2021	1	211	211
PLANNED	2/4/2021	7	385	55
PLANNED	2/4/2021	1	106	106
PLANNED	2/4/2021	4	68	17
PLANNED	2/4/2021	1	111	111
PLANNED	2/4/2021	4	120	30
PLANNED	2/4/2021	14	266	19
PLANNED	2/4/2021	3	54	18
PLANNED	2/4/2021	3	231	77
PLANNED	2/4/2021	5	265	53
PLANNED	2/4/2021	5	115	23
PLANNED	2/4/2021	17	425	25
PLANNED	2/4/2021	6	138	23
PLANNED	2/4/2021	2	390	195
PLANNED	2/4/2021	1	17	17
PLANNED	2/4/2021	1	51	51
PLANNED	2/4/2021	1	171	171
PLANNED	2/4/2021	5	395	79
PLANNED	2/4/2021	2	52	26
PLANNED	2/4/2021	8	672	84
CUSTOMER REQUEST	2/4/2021	5	50	10
PLANNED	2/4/2021	1	50	50
PLANNED	2/4/2021	3	231	77
PLANNED	2/4/2021	5	130	26
PLANNED	2/4/2021	1	28	28
PLANNED	2/4/2021	1	99	99
PLANNED	2/4/2021	14	588	42
PLANNED	2/4/2021	3	30	10
PLANNED	2/4/2021	1	84	84
PLANNED	2/4/2021	3	177	59
PLANNED	2/4/2021	2	102	51
PLANNED	2/4/2021	5	282	86
PLANNED	2/4/2021	1	88	88
PLANNED	2/4/2021	4	44	11
PLANNED	2/4/2021	2	46	23
PLANNED	2/4/2021	6	30	5
PLANNED	2/4/2021	10	260	26
PLANNED	2/4/2021	7	42	6
PLANNED	2/4/2021	4	20	5
PLANNED	2/4/2021	2	44	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/4/2021	3	144	48
PLANNED	2/4/2021	4	96	24
PLANNED	2/4/2021	3	285	95
PLANNED	2/4/2021	2	32	16
PLANNED	2/4/2021	4	52	13
PLANNED	2/4/2021	10	50	5
PLANNED	2/4/2021	3	90	30
PLANNED	2/4/2021	3	30	10
PLANNED	2/4/2021	61	12,505	205
PLANNED	2/4/2021	14	434	31
CUSTOMER REQUEST	2/4/2021	1	154	154
PLANNED	2/4/2021	2	218	109
CUSTOMER REQUEST	2/4/2021	4	32	8
PLANNED	2/4/2021	1	46	46
PLANNED	2/4/2021	1	55	55
PLANNED	2/4/2021	2	170	85
PLANNED	2/4/2021	2	198	99
PLANNED	2/4/2021	1	185	185
PLANNED	2/5/2021	12	1,488	124
PLANNED	2/5/2021	3	69	23
PLANNED	2/5/2021	19	361	19
PLANNED	2/5/2021	1	57	57
CUSTOMER REQUEST	2/5/2021	9	180	20
PLANNED	2/5/2021	5	140	28
PLANNED	2/5/2021	6	180	30
PLANNED	2/5/2021	8	456	57
PLANNED	2/5/2021	2	304	152
PLANNED	2/5/2021	8	1,040	130
PLANNED	2/5/2021	9	1,170	130
PLANNED	2/5/2021	12	1,548	129
PLANNED	2/5/2021	5	335	67
PLANNED	2/5/2021	1	63	63
PLANNED	2/5/2021	19	2,983	157
PLANNED	2/5/2021	1	190	190
PLANNED	2/5/2021	2	142	71
PLANNED	2/5/2021	6	198	33
PLANNED	2/5/2021	1	111	111
PLANNED	2/5/2021	1	107	107
PLANNED	2/5/2021	2	190	95
PLANNED	2/5/2021	2	210	105
PLANNED	2/5/2021	1	93	93

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/5/2021	2	130	65
CUSTOMER REQUEST	2/5/2021	1	223	223
PLANNED	2/5/2021	1	22	22
PLANNED	2/5/2021	4	308	77
PLANNED	2/5/2021	12	312	26
PLANNED	2/5/2021	1	126	126
CUSTOMER REQUEST	2/5/2021	7	396	360
PLANNED	2/5/2021	2	434	217
PLANNED	2/5/2021	1	35	35
PLANNED	2/5/2021	11	77	7
PLANNED	2/5/2021	21	798	38
PLANNED	2/5/2021	3	15	5
PLANNED	2/5/2021	1	345	345
PLANNED	2/5/2021	4	272	68
PLANNED	2/5/2021	1	120	120
CUSTOMER REQUEST	2/5/2021	7	42	6
PLANNED	2/5/2021	1	189	189
PLANNED	2/5/2021	8	984	123
PLANNED	2/5/2021	3	12	4
PLANNED	2/5/2021	1	62	62
PLANNED	2/5/2021	6	84	14
PLANNED	2/5/2021	9	1,055	123
PLANNED	2/5/2021	2	178	89
CUSTOMER REQUEST	2/5/2021	3	63	21
PLANNED	2/5/2021	3	318	106
PLANNED	2/5/2021	1	15	15
PLANNED	2/5/2021	19	76	4
CUSTOMER REQUEST	2/5/2021	120	17,040	142
PLANNED	2/5/2021	1	131	131
PLANNED	2/5/2021	1	31	31
PLANNED	2/5/2021	7	812	116
PLANNED	2/5/2021	5	280	56
PLANNED	2/5/2021	4	36	9
PLANNED	2/5/2021	20	220	11
PLANNED	2/5/2021	5	120	24
PLANNED	2/5/2021	6	1,794	299
PLANNED	2/5/2021	1	2	2
PLANNED	2/5/2021	6	918	153
PLANNED	2/5/2021	2	12	6
PLANNED	2/5/2021	10	2,310	231
PLANNED	2/5/2021	7	609	87

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/5/2021	4	476	119
PLANNED	2/5/2021	4	16	4
PLANNED	2/5/2021	2	34	17
PLANNED	2/5/2021	2	98	49
PLANNED	2/5/2021	2	14	7
PLANNED	2/5/2021	1	54	54
PLANNED	2/5/2021	2	176	88
PLANNED	2/5/2021	1	59	59
PLANNED	2/5/2021	2	4	2
PLANNED	2/5/2021	9	153	17
PLANNED	2/5/2021	4	436	109
PLANNED	2/5/2021	18	342	19
PLANNED	2/5/2021	3	36	12
PLANNED	2/5/2021	1	6	6
PLANNED	2/5/2021	10	710	71
PLANNED	2/5/2021	7	91	13
PLANNED	2/5/2021	1	14	14
PLANNED	2/5/2021	9	234	26
PLANNED	2/5/2021	4	356	89
CUSTOMER REQUEST	2/5/2021	1	115	115
PLANNED	2/5/2021	2	290	145
PLANNED	2/5/2021	7	1,358	194
PLANNED	2/5/2021	2	292	146
PLANNED	2/5/2021	2	40	20
PLANNED	2/5/2021	10	200	20
PLANNED	2/5/2021	10	190	19
PLANNED	2/5/2021	1	114	114
PLANNED	2/5/2021	11	33	3
PLANNED	2/5/2021	5	85	17
PLANNED	2/5/2021	9	648	72
CUSTOMER REQUEST	2/5/2021	11	44	4
CUSTOMER REQUEST	2/5/2021	8	484	75
PLANNED	2/5/2021	562	38,778	69
PLANNED	2/5/2021	4	208	52
PLANNED	2/5/2021	7	28	4
PLANNED	2/5/2021	4	160	40
PLANNED	2/5/2021	4	336	84
PLANNED	2/5/2021	4	384	96
PLANNED	2/5/2021	1	8	8
PLANNED	2/5/2021	2	36	18
PLANNED	2/5/2021	1	68	68

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/5/2021	1	165	165
PLANNED	2/5/2021	5	905	181
PLANNED	2/6/2021	1	84	84
CUSTOMER REQUEST	2/6/2021	222	16,647	220
PLANNED	2/6/2021	4	616	154
PLANNED	2/6/2021	33	2,970	90
PLANNED	2/6/2021	4	316	79
PLANNED	2/6/2021	1	109	109
PLANNED	2/6/2021	2	216	108
PLANNED	2/6/2021	1	108	108
PLANNED	2/6/2021	1	107	107
CUSTOMER REQUEST	2/6/2021	1	181	181
PLANNED	2/6/2021	5	490	98
PLANNED	2/6/2021	4	120	30
PLANNED	2/6/2021	4	192	48
PLANNED	2/6/2021	4	620	155
PLANNED	2/6/2021	2	284	142
PLANNED	2/6/2021	2	166	83
PLANNED	2/6/2021	2	358	179
PLANNED	2/6/2021	1	443	443
PLANNED	2/6/2021	1	231	231
PLANNED	2/6/2021	1	217	217
CUSTOMER REQUEST	2/7/2021	1	171	171
PLANNED	2/7/2021	4	232	58
PLANNED	2/7/2021	3	86	35
CUSTOMER REQUEST	2/7/2021	4	108	27
PLANNED	2/7/2021	1	122	122
PLANNED	2/7/2021	1	64	64
PLANNED	2/7/2021	3	516	172
PLANNED	2/7/2021	3	231	77
PLANNED	2/7/2021	3	42	14
PLANNED	2/8/2021	1	7	7
PLANNED	2/8/2021	3	132	44
PLANNED	2/8/2021	2	306	153
PLANNED	2/8/2021	5	165	33
PLANNED	2/8/2021	1	172	172
PLANNED	2/8/2021	1	98	98
PLANNED	2/8/2021	4	452	113
PLANNED	2/8/2021	2	210	105
PLANNED	2/8/2021	2	194	97
PLANNED	2/8/2021	11	330	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/8/2021	2	70	35
PLANNED	2/8/2021	2	74	37
PLANNED	2/8/2021	3	213	71
PLANNED	2/8/2021	7	833	119
PLANNED	2/8/2021	9	1,089	121
PLANNED	2/8/2021	2	56	28
PLANNED	2/8/2021	8	304	38
PLANNED	2/8/2021	7	203	29
PLANNED	2/8/2021	2	16	8
PLANNED	2/8/2021	17	17	1
PLANNED	2/8/2021	3	141	47
PLANNED	2/8/2021	5	230	46
PLANNED	2/8/2021	1	73	73
PLANNED	2/8/2021	8	152	19
PLANNED	2/8/2021	51	5,967	117
PLANNED	2/8/2021	7	518	74
PLANNED	2/8/2021	4	52	13
PLANNED	2/8/2021	4	212	53
PLANNED	2/8/2021	2	184	92
PLANNED	2/8/2021	1	87	87
PLANNED	2/8/2021	9	432	48
PLANNED	2/8/2021	2	132	66
PLANNED	2/8/2021	1	75	75
PLANNED	2/8/2021	1	64	64
PLANNED	2/8/2021	3	210	70
PLANNED	2/8/2021	1	7	7
PLANNED	2/8/2021	12	12	1
PLANNED	2/8/2021	1	52	52
PLANNED	2/8/2021	8	112	14
PLANNED	2/8/2021	1	68	68
PLANNED	2/8/2021	7	399	57
PLANNED	2/8/2021	3	102	34
PLANNED	2/8/2021	3	408	136
PLANNED	2/8/2021	6	390	65
PLANNED	2/8/2021	12	684	57
PLANNED	2/8/2021	10	660	66
CUSTOMER REQUEST	2/8/2021	9	567	63
PLANNED	2/8/2021	7	105	15
PLANNED	2/8/2021	107	28,676	268
PLANNED	2/8/2021	9	414	46
PLANNED	2/8/2021	47	12,361	263

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/8/2021	13	403	31
PLANNED	2/8/2021	3	432	144
PLANNED	2/8/2021	7	378	54
PLANNED	2/8/2021	5	380	76
PLANNED	2/8/2021	8	128	16
PLANNED	2/8/2021	1	69	69
PLANNED	2/8/2021	1	36	36
PLANNED	2/8/2021	2	214	107
PLANNED	2/8/2021	9	549	61
PLANNED	2/8/2021	2	88	44
PLANNED	2/8/2021	2	126	63
PLANNED	2/8/2021	7	343	49
PLANNED	2/8/2021	5	140	28
PLANNED	2/8/2021	1	216	216
PLANNED	2/8/2021	5	380	76
PLANNED	2/8/2021	9	657	73
PLANNED	2/8/2021	5	405	81
PLANNED	2/8/2021	6	558	93
PLANNED	2/8/2021	9	153	17
PLANNED	2/8/2021	7	126	18
PLANNED	2/8/2021	6	396	66
PLANNED	2/8/2021	1	170	170
PLANNED	2/8/2021	3	696	232
PLANNED	2/8/2021	7	273	39
PLANNED	2/8/2021	1	23	23
PLANNED	2/8/2021	7	630	90
PLANNED	2/8/2021	3	99	33
PLANNED	2/8/2021	4	200	50
PLANNED	2/8/2021	6	360	60
PLANNED	2/8/2021	3	63	21
PLANNED	2/8/2021	8	320	40
PLANNED	2/8/2021	1	49	49
PLANNED	2/8/2021	1	123	123
PLANNED	2/8/2021	2	182	91
PLANNED	2/8/2021	6	204	34
PLANNED	2/8/2021	3	408	136
PLANNED	2/8/2021	1	105	105
PLANNED	2/8/2021	5	220	44
PLANNED	2/8/2021	2	180	90
PLANNED	2/8/2021	7	329	47
PLANNED	2/8/2021	4	148	37

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/8/2021	3	183	61
PLANNED	2/8/2021	13	234	18
PLANNED	2/8/2021	4	44	11
PLANNED	2/8/2021	6	138	23
PLANNED	2/8/2021	1	9	9
PLANNED	2/8/2021	1	6	6
PLANNED	2/8/2021	8	112	14
PLANNED	2/8/2021	3	387	129
PLANNED	2/8/2021	6	414	69
PLANNED	2/8/2021	3	438	146
PLANNED	2/8/2021	3	279	93
PLANNED	2/9/2021	3	612	204
PLANNED	2/9/2021	2	66	33
CUSTOMER REQUEST	2/9/2021	2	196	98
PLANNED	2/9/2021	1	33	33
PLANNED	2/9/2021	4	124	31
PLANNED	2/9/2021	21	2,016	96
PLANNED	2/9/2021	1	88	88
PLANNED	2/9/2021	7	217	31
PLANNED	2/9/2021	1	42	42
PLANNED	2/9/2021	1	126	126
PLANNED	2/9/2021	8	736	92
PLANNED	2/9/2021	3	171	57
PLANNED	2/9/2021	8	568	71
PLANNED	2/9/2021	3	180	60
PLANNED	2/9/2021	18	3,060	334
PLANNED	2/9/2021	13	2,886	222
PLANNED	2/9/2021	3	209	79
PLANNED	2/9/2021	10	680	68
PLANNED	2/9/2021	1	90	90
CUSTOMER REQUEST	2/9/2021	8	112	14
PLANNED	2/9/2021	3	153	51
PLANNED	2/9/2021	5	55	11
PLANNED	2/9/2021	2	260	130
PLANNED	2/9/2021	4	64	16
PLANNED	2/9/2021	3	351	117
PLANNED	2/9/2021	1	82	82
PLANNED	2/9/2021	7	581	83
PLANNED	2/9/2021	18	2,394	133
PLANNED	2/9/2021	4	56	14
CUSTOMER REQUEST	2/9/2021	16	192	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/9/2021	4	120	30
PLANNED	2/9/2021	2	122	61
PLANNED	2/9/2021	6	606	101
CUSTOMER REQUEST	2/9/2021	14	391	378
PLANNED	2/9/2021	43	4,472	104
PLANNED	2/9/2021	3	117	39
PLANNED	2/9/2021	9	324	36
PLANNED	2/9/2021	12	540	45
PLANNED	2/9/2021	5	260	52
PLANNED	2/9/2021	2	154	77
PLANNED	2/9/2021	1	88	88
PLANNED	2/9/2021	4	164	41
PLANNED	2/9/2021	1	113	113
PLANNED	2/9/2021	10	400	40
PLANNED	2/9/2021	3	321	107
PLANNED	2/9/2021	1	299	299
PLANNED	2/9/2021	6	1,626	271
PLANNED	2/9/2021	3	231	77
PLANNED	2/9/2021	6	834	139
PLANNED	2/9/2021	3	195	65
PLANNED	2/9/2021	12	300	25
PLANNED	2/9/2021	8	248	31
PLANNED	2/9/2021	7	609	87
PLANNED	2/9/2021	1	11	11
PLANNED	2/9/2021	2	264	132
PLANNED	2/9/2021	1	224	224
PLANNED	2/9/2021	10	270	27
PLANNED	2/9/2021	12	1,500	125
PLANNED	2/9/2021	1	182	182
PLANNED	2/9/2021	5	30	6
PLANNED	2/9/2021	9	522	58
PLANNED	2/9/2021	7	406	58
PLANNED	2/9/2021	11	1,474	134
PLANNED	2/9/2021	2	146	73
PLANNED	2/9/2021	2	108	54
CUSTOMER REQUEST	2/9/2021	3	12	4
PLANNED	2/9/2021	12	132	11
PLANNED	2/9/2021	10	60	6
PLANNED	2/9/2021	3	357	119
PLANNED	2/9/2021	1	55	55
PLANNED	2/9/2021	5	595	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/9/2021	7	119	17
PLANNED	2/9/2021	19	190	10
PLANNED	2/9/2021	9	81	9
PLANNED	2/9/2021	1	9	9
PLANNED	2/9/2021	16	400	25
PLANNED	2/9/2021	12	204	17
PLANNED	2/9/2021	7	406	58
PLANNED	2/9/2021	17	782	46
PLANNED	2/9/2021	59	2,714	46
PLANNED	2/9/2021	20	300	15
PLANNED	2/9/2021	2	102	51
PLANNED	2/9/2021	1	54	54
PLANNED	2/9/2021	2	214	107
PLANNED	2/9/2021	6	378	94
PLANNED	2/9/2021	2	136	68
PLANNED	2/9/2021	6	408	68
PLANNED	2/9/2021	14	340	50
PLANNED	2/9/2021	4	172	43
PLANNED	2/9/2021	1	201	201
PLANNED	2/9/2021	4	540	135
PLANNED	2/9/2021	9	504	56
PLANNED	2/9/2021	19	1,748	92
PLANNED	2/9/2021	8	986	287
PLANNED	2/9/2021	2	116	58
PLANNED	2/9/2021	11	143	13
PLANNED	2/9/2021	1	84	84
PLANNED	2/9/2021	4	68	17
PLANNED	2/9/2021	15	420	28
PLANNED	2/9/2021	3	27	9
PLANNED	2/9/2021	7	434	62
PLANNED	2/9/2021	4	336	84
PLANNED	2/9/2021	4	44	11
PLANNED	2/9/2021	4	216	54
PLANNED	2/9/2021	1	29	29
PLANNED	2/9/2021	2	194	97
PLANNED	2/9/2021	27	3,159	117
PLANNED	2/9/2021	3	90	30
PLANNED	2/9/2021	17	459	27
PLANNED	2/9/2021	12	1,032	86
PLANNED	2/9/2021	16	1,408	88
PLANNED	2/9/2021	9	1,596	210

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/9/2021	7	427	61
PLANNED	2/9/2021	1	148	148
PLANNED	2/9/2021	1	53	53
PLANNED	2/9/2021	2	274	137
PLANNED	2/9/2021	1	65	65
PLANNED	2/9/2021	8	104	13
PLANNED	2/9/2021	4	528	132
PLANNED	2/9/2021	1	78	78
PLANNED	2/9/2021	1	12	12
PLANNED	2/9/2021	6	576	96
PLANNED	2/9/2021	12	36	3
PLANNED	2/9/2021	6	420	70
PLANNED	2/9/2021	1	74	74
PLANNED	2/9/2021	2	270	135
PLANNED	2/9/2021	3	60	20
PLANNED	2/9/2021	7	84	12
PLANNED	2/9/2021	1	22	22
PLANNED	2/9/2021	3	45	15
PLANNED	2/9/2021	1	36	36
PLANNED	2/9/2021	2	32	16
PLANNED	2/9/2021	1	55	55
PLANNED	2/9/2021	1	12	12
PLANNED	2/9/2021	3	48	16
PLANNED	2/9/2021	1	40	40
PLANNED	2/9/2021	2	298	149
PLANNED	2/9/2021	2	20	10
CUSTOMER REQUEST	2/9/2021	1	69	69
CUSTOMER REQUEST	2/9/2021	27	972	36
CUSTOMER REQUEST	2/9/2021	1	96	96
CUSTOMER REQUEST	2/9/2021	1	48	48
PLANNED	2/9/2021	1	176	176
PLANNED	2/9/2021	1	256	256
PLANNED	2/9/2021	11	352	32
PLANNED	2/9/2021	2	148	74
CUSTOMER REQUEST	2/9/2021	14	812	58
PLANNED	2/9/2021	5	140	28
PLANNED	2/10/2021	1	162	162
PLANNED	2/10/2021	3	177	59
PLANNED	2/10/2021	2	164	82
PLANNED	2/10/2021	3	210	70
PLANNED	2/10/2021	1	47	47

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/10/2021	1	201	201
PLANNED	2/10/2021	1	224	224
PLANNED	2/10/2021	6	768	128
PLANNED	2/10/2021	17	1,566	99
PLANNED	2/10/2021	8	776	97
PLANNED	2/10/2021	7	616	88
CUSTOMER REQUEST	2/10/2021	1	62	62
PLANNED	2/10/2021	5	440	88
PLANNED	2/10/2021	6	276	46
PLANNED	2/10/2021	13	585	45
PLANNED	2/10/2021	5	645	129
PLANNED	2/10/2021	5	20	4
PLANNED	2/10/2021	8	2,664	333
PLANNED	2/10/2021	6	1,098	183
PLANNED	2/10/2021	23	368	16
PLANNED	2/10/2021	8	328	41
PLANNED	2/10/2021	1	77	77
PLANNED	2/10/2021	2	144	72
PLANNED	2/10/2021	13	2,522	194
CUSTOMER REQUEST	2/10/2021	9	81	9
PLANNED	2/10/2021	4	368	116
PLANNED	2/10/2021	1	72	72
PLANNED	2/10/2021	13	2,431	187
PLANNED	2/10/2021	7	1,183	169
PLANNED	2/10/2021	1	223	223
PLANNED	2/10/2021	1	72	72
PLANNED	2/10/2021	2	144	72
PLANNED	2/10/2021	19	4,142	218
PLANNED	2/10/2021	3	93	31
PLANNED	2/10/2021	9	774	86
PLANNED	2/10/2021	7	609	87
PLANNED	2/10/2021	32	1,632	51
PLANNED	2/10/2021	8	776	97
PLANNED	2/10/2021	8	864	108
PLANNED	2/10/2021	7	679	97
PLANNED	2/10/2021	3	156	52
PLANNED	2/10/2021	8	528	66
PLANNED	2/10/2021	17	3,366	198
PLANNED	2/10/2021	10	1,410	141
PLANNED	2/10/2021	2	294	147
PLANNED	2/10/2021	5	10	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/10/2021	8	760	95
PLANNED	2/10/2021	1	111	111
CUSTOMER REQUEST	2/10/2021	6	606	101
PLANNED	2/10/2021	4	212	77
PLANNED	2/10/2021	4	1,144	286
PLANNED	2/10/2021	2	36	18
PLANNED	2/10/2021	12	1,068	89
PLANNED	2/10/2021	3	48	16
PLANNED	2/10/2021	5	225	45
PLANNED	2/10/2021	3	186	62
PLANNED	2/10/2021	5	225	45
CUSTOMER REQUEST	2/10/2021	2	126	63
PLANNED	2/10/2021	7	133	19
PLANNED	2/10/2021	5	125	25
PLANNED	2/10/2021	4	516	129
PLANNED	2/10/2021	6	648	108
PLANNED	2/10/2021	4	464	116
PLANNED	2/10/2021	6	138	23
PLANNED	2/10/2021	1	129	129
PLANNED	2/10/2021	2	174	87
PLANNED	2/10/2021	10	1,190	119
PLANNED	2/10/2021	7	980	140
PLANNED	2/10/2021	1	37	37
PLANNED	2/10/2021	4	268	67
PLANNED	2/10/2021	12	1,716	143
PLANNED	2/10/2021	1	5	5
PLANNED	2/10/2021	5	295	59
PLANNED	2/10/2021	36	7,884	219
PLANNED	2/10/2021	1	75	75
PLANNED	2/10/2021	7	301	43
PLANNED	2/10/2021	1	49	49
PLANNED	2/10/2021	3	132	44
PLANNED	2/10/2021	2	130	65
PLANNED	2/10/2021	6	810	135
PLANNED	2/10/2021	7	210	30
PLANNED	2/10/2021	1	87	87
CUSTOMER REQUEST	2/10/2021	57	2,280	40
PLANNED	2/10/2021	6	876	146
PLANNED	2/10/2021	2	98	49
PLANNED	2/10/2021	15	840	56
PLANNED	2/10/2021	2	154	77

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/10/2021	8	1,560	195
PLANNED	2/10/2021	2	104	52
PLANNED	2/10/2021	1	60	60
PLANNED	2/10/2021	2	88	44
PLANNED	2/10/2021	4	100	25
PLANNED	2/10/2021	1	39	39
PLANNED	2/10/2021	1	32	32
PLANNED	2/10/2021	3	15	5
CUSTOMER REQUEST	2/10/2021	7	35	5
PLANNED	2/10/2021	8	664	83
PLANNED	2/10/2021	4	112	28
PLANNED	2/10/2021	3	15	5
PLANNED	2/10/2021	1	69	69
PLANNED	2/10/2021	2	158	79
PLANNED	2/10/2021	2	34	17
PLANNED	2/10/2021	1	41	41
PLANNED	2/10/2021	4	772	193
PLANNED	2/10/2021	1	37	37
PLANNED	2/10/2021	11	880	80
PLANNED	2/10/2021	3	822	274
PLANNED	2/10/2021	5	85	17
PLANNED	2/10/2021	3	183	61
PLANNED	2/10/2021	4	648	162
PLANNED	2/10/2021	2	68	34
PLANNED	2/10/2021	10	110	11
PLANNED	2/10/2021	1	121	121
PLANNED	2/10/2021	3	111	37
PLANNED	2/10/2021	3	69	23
PLANNED	2/10/2021	8	64	8
PLANNED	2/10/2021	5	420	84
PLANNED	2/10/2021	3	93	31
PLANNED	2/10/2021	4	256	64
PLANNED	2/10/2021	15	510	34
PLANNED	2/10/2021	19	2,812	148
PLANNED	2/10/2021	1	143	143
PLANNED	2/10/2021	3	258	86
CUSTOMER REQUEST	2/10/2021	3	9	3
PLANNED	2/10/2021	3	72	24
PLANNED	2/10/2021	3	180	60
PLANNED	2/10/2021	2	204	102
PLANNED	2/10/2021	3	195	65

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/10/2021	1	93	93
PLANNED	2/10/2021	1	13	13
PLANNED	2/10/2021	9	513	57
PLANNED	2/10/2021	1	106	106
PLANNED	2/10/2021	3	213	71
PLANNED	2/10/2021	13	1,053	81
PLANNED	2/10/2021	1	11	11
PLANNED	2/10/2021	2	386	193
PLANNED	2/10/2021	5	210	42
PLANNED	2/10/2021	1	9	9
PLANNED	2/10/2021	2	14	7
PLANNED	2/10/2021	4	72	18
PLANNED	2/10/2021	1	12	12
PLANNED	2/10/2021	4	340	85
PLANNED	2/10/2021	3	48	16
PLANNED	2/10/2021	1	58	58
PLANNED	2/10/2021	2	426	213
PLANNED	2/10/2021	1	85	85
PLANNED	2/10/2021	7	539	77
PLANNED	2/10/2021	5	505	101
CUSTOMER REQUEST	2/10/2021	9	909	101
CUSTOMER REQUEST	2/10/2021	3	423	141
PLANNED	2/11/2021	2	220	110
PLANNED	2/11/2021	3	639	213
PLANNED	2/11/2021	2	376	188
PLANNED	2/11/2021	1	59	59
PLANNED	2/11/2021	1	126	126
PLANNED	2/11/2021	3	249	83
PLANNED	2/11/2021	1	154	154
PLANNED	2/11/2021	4	208	52
PLANNED	2/11/2021	2	134	67
PLANNED	2/11/2021	9	963	107
PLANNED	2/11/2021	6	1,122	187
PLANNED	2/11/2021	1	187	187
PLANNED	2/11/2021	1	94	94
PLANNED	2/11/2021	1	221	221
PLANNED	2/11/2021	8	1,216	152
PLANNED	2/11/2021	4	608	152
PLANNED	2/11/2021	4	604	151
PLANNED	2/11/2021	6	324	54
PLANNED	2/11/2021	16	1,584	99

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/11/2021	8	416	52
PLANNED	2/11/2021	5	635	127
PLANNED	2/11/2021	3	825	275
PLANNED	2/11/2021	7	210	30
PLANNED	2/11/2021	78	11,934	153
PLANNED	2/11/2021	4	164	41
PLANNED	2/11/2021	13	1,144	88
PLANNED	2/11/2021	1	329	329
PLANNED	2/11/2021	4	400	100
CUSTOMER REQUEST	2/11/2021	76	14,592	192
CUSTOMER REQUEST	2/11/2021	2	24	12
PLANNED	2/11/2021	6	42	7
PLANNED	2/11/2021	3	612	204
PLANNED	2/11/2021	2	54	27
PLANNED	2/11/2021	10	1,900	190
PLANNED	2/11/2021	1	251	251
PLANNED	2/11/2021	3	21	7
PLANNED	2/11/2021	2	106	53
PLANNED	2/11/2021	7	1,302	186
PLANNED	2/11/2021	5	475	95
PLANNED	2/11/2021	7	420	60
PLANNED	2/11/2021	5	1,205	241
PLANNED	2/11/2021	2	28	14
PLANNED	2/11/2021	4	424	106
PLANNED	2/11/2021	4	652	163
PLANNED	2/11/2021	4	408	102
PLANNED	2/11/2021	1	54	54
PLANNED	2/11/2021	1	163	163
PLANNED	2/11/2021	2	54	27
PLANNED	2/11/2021	3	450	150
PLANNED	2/11/2021	28	2,912	104
PLANNED	2/11/2021	8	1,784	223
PLANNED	2/11/2021	3	69	23
CUSTOMER REQUEST	2/11/2021	1	153	153
PLANNED	2/11/2021	2	46	23
PLANNED	2/11/2021	2	100	50
PLANNED	2/11/2021	1	92	92
PLANNED	2/11/2021	4	52	13
PLANNED	2/11/2021	8	896	112
PLANNED	2/11/2021	19	342	18
PLANNED	2/11/2021	9	297	33

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/11/2021	3	423	141
PLANNED	2/11/2021	6	912	152
PLANNED	2/11/2021	3	537	179
PLANNED	2/11/2021	3	165	55
PLANNED	2/11/2021	2	34	17
PLANNED	2/11/2021	1	46	46
PLANNED	2/11/2021	7	63	9
PLANNED	2/11/2021	1	110	110
PLANNED	2/11/2021	5	225	45
PLANNED	2/11/2021	88	2,992	34
PLANNED	2/11/2021	2	14	7
PLANNED	2/11/2021	2	30	15
PLANNED	2/11/2021	2	250	125
PLANNED	2/11/2021	9	189	21
PLANNED	2/11/2021	4	96	24
CUSTOMER REQUEST	2/11/2021	1	401	401
PLANNED	2/11/2021	5	85	17
PLANNED	2/11/2021	5	210	42
PLANNED	2/11/2021	1	29	29
PLANNED	2/11/2021	7	966	138
PLANNED	2/11/2021	6	240	40
PLANNED	2/11/2021	8	264	33
PLANNED	2/11/2021	9	691	135
PLANNED	2/11/2021	2	14	7
PLANNED	2/11/2021	6	1,242	207
PLANNED	2/11/2021	5	135	27
PLANNED	2/11/2021	8	200	25
PLANNED	2/11/2021	6	150	25
PLANNED	2/11/2021	6	150	25
PLANNED	2/11/2021	8	592	74
PLANNED	2/11/2021	9	999	111
PLANNED	2/11/2021	7	1,022	146
PLANNED	2/11/2021	4	68	17
PLANNED	2/11/2021	7	56	8
PLANNED	2/11/2021	5	345	69
PLANNED	2/11/2021	7	7	1
PLANNED	2/11/2021	1	71	71
PLANNED	2/11/2021	4	228	57
PLANNED	2/11/2021	4	212	53
PLANNED	2/11/2021	8	760	95
PLANNED	2/11/2021	3	78	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/11/2021	9	1,197	133
PLANNED	2/11/2021	1	49	49
PLANNED	2/11/2021	4	300	75
PLANNED	2/11/2021	1	74	74
PLANNED	2/11/2021	4	376	94
PLANNED	2/11/2021	6	480	80
PLANNED	2/11/2021	1	84	84
PLANNED	2/11/2021	1	55	55
PLANNED	2/11/2021	1	56	56
PLANNED	2/11/2021	2	200	100
PLANNED	2/11/2021	1	55	55
PLANNED	2/11/2021	7	805	115
PLANNED	2/11/2021	4	168	42
PLANNED	2/11/2021	3	354	118
PLANNED	2/11/2021	1	79	79
PLANNED	2/11/2021	2	76	38
PLANNED	2/11/2021	113	4,746	42
CUSTOMER REQUEST	2/11/2021	6	18	3
PLANNED	2/11/2021	8	80	10
PLANNED	2/11/2021	2	146	73
PLANNED	2/11/2021	1	76	76
CUSTOMER REQUEST	2/11/2021	1	94	94
PLANNED	2/11/2021	3	66	22
PLANNED	2/11/2021	1	52	52
PLANNED	2/11/2021	1	44	44
PLANNED	2/11/2021	6	78	13
CUSTOMER REQUEST	2/11/2021	1	30	30
PLANNED	2/11/2021	3	519	173
PLANNED	2/11/2021	1	91	91
PLANNED	2/11/2021	4	308	77
PLANNED	2/11/2021	1	139	139
PLANNED	2/11/2021	1	194	194
PLANNED	2/11/2021	1	171	171
PLANNED	2/11/2021	10	3,470	347
PLANNED	2/12/2021	3	753	251
PLANNED	2/12/2021	1	264	264
PLANNED	2/12/2021	89	6,141	69
PLANNED	2/12/2021	1	120	120
PLANNED	2/12/2021	1	60	60
PLANNED	2/12/2021	2	284	142
PLANNED	2/12/2021	2	86	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/12/2021	1	100	100
PLANNED	2/12/2021	3	114	38
PLANNED	2/12/2021	2	114	57
PLANNED	2/12/2021	2	430	215
PLANNED	2/12/2021	2	64	32
PLANNED	2/12/2021	9	189	21
PLANNED	2/12/2021	9	279	31
PLANNED	2/12/2021	1	41	41
PLANNED	2/12/2021	6	444	74
PLANNED	2/12/2021	2	810	405
PLANNED	2/12/2021	1	405	405
PLANNED	2/12/2021	1	169	169
PLANNED	2/12/2021	1	81	81
PLANNED	2/12/2021	3	186	62
CUSTOMER REQUEST	2/12/2021	17	697	41
PLANNED	2/12/2021	4	156	39
PLANNED	2/12/2021	3	447	149
PLANNED	2/12/2021	3	132	44
CUSTOMER REQUEST	2/12/2021	5	1,250	250
PLANNED	2/12/2021	12	612	51
PLANNED	2/12/2021	1	171	171
PLANNED	2/12/2021	2	88	44
PLANNED	2/12/2021	4	124	31
PLANNED	2/12/2021	1	48	48
PLANNED	2/12/2021	1	86	86
PLANNED	2/12/2021	1	198	198
PLANNED	2/12/2021	1	224	224
PLANNED	2/12/2021	3	114	38
PLANNED	2/12/2021	1	367	367
PLANNED	2/12/2021	11	1,122	102
PLANNED	2/12/2021	1	103	103
PLANNED	2/12/2021	6	222	37
PLANNED	2/12/2021	2	246	123
PLANNED	2/12/2021	4	452	113
PLANNED	2/12/2021	1	52	52
PLANNED	2/12/2021	8	2,344	293
PLANNED	2/12/2021	8	552	69
PLANNED	2/12/2021	20	5,160	258
PLANNED	2/12/2021	10	1,350	135
PLANNED	2/12/2021	1	46	46
PLANNED	2/12/2021	2	48	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/12/2021	6	36	6
PLANNED	2/12/2021	4	88	22
PLANNED	2/12/2021	1	56	56
PLANNED	2/12/2021	5	965	193
PLANNED	2/12/2021	64	2,624	41
PLANNED	2/12/2021	8	24	3
PLANNED	2/12/2021	4	108	27
PLANNED	2/12/2021	11	1,199	109
PLANNED	2/12/2021	13	1,027	79
PLANNED	2/12/2021	3	72	24
PLANNED	2/12/2021	6	72	12
PLANNED	2/12/2021	7	35	5
CUSTOMER REQUEST	2/12/2021	1	195	195
PLANNED	2/12/2021	9	351	39
PLANNED	2/12/2021	2	176	88
PLANNED	2/12/2021	1	18	18
PLANNED	2/12/2021	4	552	138
PLANNED	2/12/2021	4	596	149
PLANNED	2/12/2021	2	88	44
PLANNED	2/12/2021	3	126	42
CUSTOMER REQUEST	2/12/2021	1,802	34,238	19
PLANNED	2/12/2021	5	645	129
PLANNED	2/12/2021	7	518	74
PLANNED	2/12/2021	11	77	7
PLANNED	2/12/2021	2	78	39
PLANNED	2/12/2021	5	120	24
PLANNED	2/12/2021	8	688	86
PLANNED	2/12/2021	4	36	9
PLANNED	2/12/2021	9	450	50
PLANNED	2/12/2021	3	420	140
PLANNED	2/12/2021	4	28	7
PLANNED	2/12/2021	7	56	8
PLANNED	2/12/2021	11	341	31
PLANNED	2/12/2021	3	66	22
PLANNED	2/12/2021	9	648	72
PLANNED	2/12/2021	8	824	103
PLANNED	2/12/2021	10	1,620	162
PLANNED	2/12/2021	5	105	21
PLANNED	2/12/2021	4	456	114
PLANNED	2/12/2021	17	493	29
PLANNED	2/12/2021	1	68	68

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/12/2021	2	586	293
CUSTOMER REQUEST	2/12/2021	1	109	109
CUSTOMER REQUEST	2/12/2021	1	86	86
PLANNED	2/12/2021	3	372	124
PLANNED	2/13/2021	2	102	51
CUSTOMER REQUEST	2/13/2021	1	47	47
PLANNED	2/13/2021	1	41	41
PLANNED	2/13/2021	1	425	425
PLANNED	2/13/2021	1	57	57
PLANNED	2/13/2021	5	315	63
PLANNED	2/13/2021	1	218	218
PLANNED	2/13/2021	2	226	113
PLANNED	2/13/2021	8	1,496	187
PLANNED	2/13/2021	3	48	16
PLANNED	2/13/2021	9	144	16
PLANNED	2/13/2021	6	594	99
PLANNED	2/13/2021	2	164	82
PLANNED	2/13/2021	4	456	114
PLANNED	2/13/2021	6	234	39
PLANNED	2/13/2021	58	21,866	377
PLANNED	2/13/2021	136	52,360	385
PLANNED	2/13/2021	14	28	2
PLANNED	2/13/2021	14	2,744	196
CUSTOMER REQUEST	2/14/2021	10	980	98
CUSTOMER REQUEST	2/14/2021	1	209	209
PLANNED	2/14/2021	8	744	93
PLANNED	2/14/2021	1	294	294
PLANNED	2/14/2021	2	540	270
PLANNED	2/14/2021	1	335	335
PLANNED	2/14/2021	8	2,360	295
PLANNED	2/14/2021	4	236	59
PLANNED	2/14/2021	5	95	19
PLANNED	2/14/2021	8	1,496	311
PLANNED	2/14/2021	6	1,338	359
CUSTOMER REQUEST	2/14/2021	1,944	71,928	37
PLANNED	2/14/2021	12	156	13
PLANNED	2/15/2021	4	228	57
PLANNED	2/15/2021	2	374	187
PLANNED	2/15/2021	1	27	27
CUSTOMER REQUEST	2/15/2021	3	573	191
PLANNED	2/15/2021	2	276	166

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/15/2021	1	266	266
PLANNED	2/15/2021	1	225	225
PLANNED	2/15/2021	7	392	56
PLANNED	2/15/2021	1	89	89
PLANNED	2/15/2021	9	369	41
PLANNED	2/15/2021	8	176	22
PLANNED	2/15/2021	11	594	54
PLANNED	2/15/2021	4	176	44
PLANNED	2/15/2021	6	384	64
PLANNED	2/15/2021	12	1,896	158
PLANNED	2/15/2021	13	2,834	218
PLANNED	2/15/2021	1	126	126
PLANNED	2/15/2021	1	87	87
PLANNED	2/15/2021	3	417	139
PLANNED	2/15/2021	9	1,494	166
PLANNED	2/15/2021	9	864	96
PLANNED	2/15/2021	8	488	61
PLANNED	2/15/2021	19	1,520	80
PLANNED	2/15/2021	1	37	37
PLANNED	2/15/2021	3	108	36
PLANNED	2/15/2021	4	116	29
PLANNED	2/15/2021	2	414	207
PLANNED	2/15/2021	5	205	41
PLANNED	2/15/2021	7	448	64
PLANNED	2/15/2021	20	7,340	367
PLANNED	2/15/2021	8	2,144	268
PLANNED	2/15/2021	3	150	50
PLANNED	2/15/2021	3	54	18
PLANNED	2/15/2021	1	45	45
PLANNED	2/15/2021	1	90	90
PLANNED	2/15/2021	7	21	3
PLANNED	2/15/2021	5	127	123
PLANNED	2/15/2021	1	23	23
PLANNED	2/15/2021	9	99	11
PLANNED	2/15/2021	10	400	40
PLANNED	2/15/2021	5	260	52
PLANNED	2/15/2021	1	146	146
PLANNED	2/15/2021	1	112	112
PLANNED	2/15/2021	3	144	48
PLANNED	2/15/2021	2	40	20
PLANNED	2/15/2021	5	440	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/15/2021	6	906	151
PLANNED	2/15/2021	19	133	7
PLANNED	2/15/2021	7	14	2
PLANNED	2/15/2021	1	61	61
PLANNED	2/15/2021	13	390	30
PLANNED	2/15/2021	8	464	58
PLANNED	2/15/2021	6	348	58
PLANNED	2/15/2021	1	193	193
PLANNED	2/15/2021	1	63	63
PLANNED	2/15/2021	4	684	171
PLANNED	2/15/2021	3	54	18
PLANNED	2/15/2021	7	1,421	203
PLANNED	2/15/2021	14	560	40
PLANNED	2/15/2021	6	354	59
PLANNED	2/15/2021	7	224	32
PLANNED	2/15/2021	1	43	43
PLANNED	2/15/2021	2	114	57
PLANNED	2/15/2021	2	296	148
PLANNED	2/15/2021	8	568	71
PLANNED	2/15/2021	3	87	29
PLANNED	2/15/2021	1	242	242
PLANNED	2/15/2021	11	726	66
PLANNED	2/15/2021	1	359	359
PLANNED	2/16/2021	1	203	203
PLANNED	2/16/2021	38	7,410	195
PLANNED	2/16/2021	1	87	87
PLANNED	2/16/2021	1	591	591
PLANNED	2/16/2021	11	1,815	165
PLANNED	2/16/2021	2	186	93
PLANNED	2/16/2021	8	792	99
PLANNED	2/16/2021	1	272	272
CUSTOMER REQUEST	2/16/2021	17	51	3
PLANNED	2/16/2021	3	408	136
PLANNED	2/16/2021	2	64	32
PLANNED	2/16/2021	1	148	148
PLANNED	2/16/2021	9	495	55
PLANNED	2/16/2021	4	560	140
PLANNED	2/16/2021	6	300	50
CUSTOMER REQUEST	2/16/2021	8	32	4
PLANNED	2/16/2021	1	40	40
PLANNED	2/16/2021	10	400	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/16/2021	2	70	35
CUSTOMER REQUEST	2/16/2021	1	6	6
PLANNED	2/16/2021	1	73	73
PLANNED	2/16/2021	3	213	71
PLANNED	2/16/2021	1	29	29
PLANNED	2/16/2021	10	760	76
PLANNED	2/16/2021	2	299	153
PLANNED	2/16/2021	1	160	160
PLANNED	2/16/2021	2	16	8
CUSTOMER REQUEST	2/16/2021	13	130	10
PLANNED	2/16/2021	7	327	99
PLANNED	2/16/2021	23	4,439	193
PLANNED	2/16/2021	7	182	26
PLANNED	2/16/2021	6	1,500	250
PLANNED	2/16/2021	1	49	49
PLANNED	2/16/2021	1	47	47
PLANNED	2/16/2021	18	1,080	60
PLANNED	2/16/2021	4	1,132	283
CUSTOMER REQUEST	2/16/2021	6	120	20
PLANNED	2/16/2021	6	666	111
PLANNED	2/16/2021	7	357	51
PLANNED	2/16/2021	2	84	42
PLANNED	2/16/2021	2	62	31
PLANNED	2/16/2021	1	150	150
PLANNED	2/16/2021	2	88	44
PLANNED	2/16/2021	5	590	118
PLANNED	2/16/2021	7	826	118
PLANNED	2/16/2021	6	462	77
PLANNED	2/16/2021	6	450	75
PLANNED	2/16/2021	7	371	53
PLANNED	2/16/2021	2	106	53
CUSTOMER REQUEST	2/16/2021	20	1,740	87
PLANNED	2/16/2021	1	171	171
CUSTOMER REQUEST	2/16/2021	2	24	12
PLANNED	2/16/2021	1	83	83
PLANNED	2/16/2021	10	590	59
PLANNED	2/16/2021	5	145	29
PLANNED	2/16/2021	12	672	56
PLANNED	2/16/2021	10	660	66
PLANNED	2/16/2021	18	1,062	59
PLANNED	2/16/2021	2	58	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/16/2021	3	60	20
PLANNED	2/16/2021	3	30	10
PLANNED	2/16/2021	1	43	43
PLANNED	2/16/2021	2	90	45
PLANNED	2/16/2021	14	1,372	98
PLANNED	2/16/2021	9	495	55
PLANNED	2/16/2021	3	51	17
PLANNED	2/16/2021	3	39	13
PLANNED	2/16/2021	11	517	47
PLANNED	2/16/2021	3	174	58
PLANNED	2/16/2021	1	200	200
PLANNED	2/16/2021	1	101	101
PLANNED	2/16/2021	8	184	23
PLANNED	2/16/2021	2	156	78
PLANNED	2/16/2021	4	448	112
PLANNED	2/16/2021	2	270	135
PLANNED	2/16/2021	2	140	70
PLANNED	2/16/2021	1	61	61
CUSTOMER REQUEST	2/16/2021	3	15	5
PLANNED	2/16/2021	4	368	92
PLANNED	2/16/2021	12	636	53
CUSTOMER REQUEST	2/16/2021	8	16	2
PLANNED	2/16/2021	1	65	65
PLANNED	2/16/2021	12	84	7
PLANNED	2/16/2021	4	256	64
PLANNED	2/16/2021	6	18	3
PLANNED	2/16/2021	1	16	16
PLANNED	2/16/2021	2	16	8
PLANNED	2/16/2021	1	18	18
PLANNED	2/16/2021	2	227	126
PLANNED	2/16/2021	1	58	58
PLANNED	2/16/2021	2	122	61
PLANNED	2/16/2021	4	196	49
PLANNED	2/16/2021	1	9	9
CUSTOMER REQUEST	2/16/2021	1	169	169
PLANNED	2/16/2021	1	57	57
PLANNED	2/16/2021	4	320	80
PLANNED	2/16/2021	5	865	173
PLANNED	2/16/2021	7	847	121
PLANNED	2/16/2021	8	1,520	190
PLANNED	2/16/2021	2	42	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/16/2021	2	280	140
PLANNED	2/16/2021	1	190	190
PLANNED	2/17/2021	1	117	117
PLANNED	2/17/2021	2	212	106
PLANNED	2/17/2021	2	82	41
PLANNED	2/17/2021	1	81	81
PLANNED	2/17/2021	8	480	60
PLANNED	2/17/2021	9	783	87
PLANNED	2/17/2021	4	572	143
PLANNED	2/17/2021	7	217	31
PLANNED	2/17/2021	17	731	43
PLANNED	2/17/2021	7	112	16
PLANNED	2/17/2021	2	68	34
PLANNED	2/17/2021	8	240	30
PLANNED	2/17/2021	2	164	82
CUSTOMER REQUEST	2/17/2021	1	49	49
PLANNED	2/17/2021	11	176	16
PLANNED	2/17/2021	10	50	5
PLANNED	2/17/2021	8	2,784	348
PLANNED	2/17/2021	1	24	24
PLANNED	2/17/2021	4	112	28
PLANNED	2/17/2021	4	164	41
PLANNED	2/17/2021	6	90	15
PLANNED	2/17/2021	15	2,715	181
PLANNED	2/17/2021	5	625	125
PLANNED	2/17/2021	4	424	106
CUSTOMER REQUEST	2/17/2021	4	64	16
PLANNED	2/17/2021	2	168	84
PLANNED	2/17/2021	1	89	89
PLANNED	2/17/2021	2	158	79
PLANNED	2/17/2021	8	712	89
PLANNED	2/17/2021	5	380	76
PLANNED	2/17/2021	8	632	79
PLANNED	2/17/2021	8	1,456	182
PLANNED	2/17/2021	8	1,232	154
PLANNED	2/17/2021	58	2,378	41
PLANNED	2/17/2021	11	110	10
PLANNED	2/17/2021	7	350	50
PLANNED	2/17/2021	8	400	50
PLANNED	2/17/2021	2	180	90
PLANNED	2/17/2021	2	122	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/17/2021	2	262	131
PLANNED	2/17/2021	3	270	90
PLANNED	2/17/2021	1	24	24
PLANNED	2/17/2021	8	736	92
PLANNED	2/17/2021	47	6,392	136
PLANNED	2/17/2021	5	1,845	369
PLANNED	2/17/2021	1	149	149
PLANNED	2/17/2021	1	91	91
PLANNED	2/17/2021	11	1,210	110
PLANNED	2/17/2021	1	79	79
PLANNED	2/17/2021	6	24	4
PLANNED	2/17/2021	2	42	21
CUSTOMER REQUEST	2/17/2021	7	84	12
PLANNED	2/17/2021	1	61	61
PLANNED	2/17/2021	1	103	103
PLANNED	2/17/2021	1	47	47
PLANNED	2/17/2021	1	104	104
PLANNED	2/17/2021	2	22	11
CUSTOMER REQUEST	2/17/2021	11	539	49
PLANNED	2/17/2021	5	530	106
CUSTOMER REQUEST	2/17/2021	7	7	1,624
CUSTOMER REQUEST	2/17/2021	1	1	1,623
PLANNED	2/17/2021	4	400	100
PLANNED	2/17/2021	5	90	18
PLANNED	2/17/2021	100	2,500	25
PLANNED	2/17/2021	2	48	24
PLANNED	2/17/2021	75	1,875	25
CUSTOMER REQUEST	2/17/2021	179	179	1
PLANNED	2/17/2021	3	69	23
PLANNED	2/17/2021	18	270	15
PLANNED	2/17/2021	4	260	65
PLANNED	2/17/2021	2	28	14
PLANNED	2/17/2021	2	300	150
PLANNED	2/17/2021	2	52	26
PLANNED	2/17/2021	3	591	197
PLANNED	2/17/2021	7	14	2
PLANNED	2/17/2021	1	44	44
PLANNED	2/17/2021	4	200	50
PLANNED	2/17/2021	4	196	49
PLANNED	2/17/2021	1	30	30
PLANNED	2/17/2021	6	144	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/17/2021	1	10	10
PLANNED	2/17/2021	4	184	46
PLANNED	2/17/2021	2	340	170
PLANNED	2/17/2021	8	32	4
PLANNED	2/17/2021	1	71	71
PLANNED	2/17/2021	14	490	35
PLANNED	2/17/2021	11	1,881	171
PLANNED	2/17/2021	2	202	101
PLANNED	2/17/2021	2	178	89
PLANNED	2/17/2021	6	1,050	175
PLANNED	2/17/2021	2	232	116
PLANNED	2/17/2021	1	44	44
PLANNED	2/17/2021	6	54	9
PLANNED	2/17/2021	1	86	86
PLANNED	2/17/2021	1	118	118
PLANNED	2/17/2021	6	678	113
PLANNED	2/17/2021	1	106	106
PLANNED	2/17/2021	1	101	101
PLANNED	2/17/2021	4	72	18
PLANNED	2/17/2021	3	265	109
PLANNED	2/17/2021	5	615	123
PLANNED	2/17/2021	4	264	66
PLANNED	2/17/2021	4	152	38
PLANNED	2/17/2021	1	45	45
PLANNED	2/17/2021	5	150	30
PLANNED	2/17/2021	1	41	41
PLANNED	2/17/2021	1	9	9
PLANNED	2/17/2021	2	52	26
PLANNED	2/17/2021	12	1,764	147
PLANNED	2/17/2021	1	180	180
PLANNED	2/17/2021	31	3,968	128
PLANNED	2/17/2021	1	204	204
PLANNED	2/18/2021	1	192	192
PLANNED	2/18/2021	11	715	65
PLANNED	2/18/2021	4	12	3
PLANNED	2/18/2021	2	58	29
PLANNED	2/18/2021	7	336	48
PLANNED	2/18/2021	3	333	177
PLANNED	2/18/2021	3	78	26
PLANNED	2/18/2021	3	186	62
PLANNED	2/18/2021	2	122	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/18/2021	8	376	47
PLANNED	2/18/2021	2	177	128
PLANNED	2/18/2021	1	112	112
PLANNED	2/18/2021	9	585	65
PLANNED	2/18/2021	2	40	20
PLANNED	2/18/2021	4	32	8
PLANNED	2/18/2021	3	3	1
PLANNED	2/18/2021	7	161	23
PLANNED	2/18/2021	1	69	69
PLANNED	2/18/2021	16	1,024	64
PLANNED	2/18/2021	2	110	55
CUSTOMER REQUEST	2/18/2021	12	3,636	303
PLANNED	2/18/2021	11	187	17
PLANNED	2/18/2021	3	177	59
PLANNED	2/18/2021	6	216	36
PLANNED	2/18/2021	3	291	97
PLANNED	2/18/2021	8	392	49
PLANNED	2/18/2021	8	352	44
PLANNED	2/18/2021	2	242	121
PLANNED	2/18/2021	5	768	184
PLANNED	2/18/2021	7	343	49
PLANNED	2/18/2021	7	245	35
PLANNED	2/18/2021	3	486	162
PLANNED	2/18/2021	5	575	115
PLANNED	2/18/2021	4	300	75
PLANNED	2/18/2021	18	2,520	140
PLANNED	2/18/2021	11	209	19
PLANNED	2/18/2021	10	3,960	396
PLANNED	2/18/2021	4	360	90
PLANNED	2/18/2021	1	88	88
PLANNED	2/18/2021	4	436	109
PLANNED	2/18/2021	6	876	146
PLANNED	2/18/2021	3	135	45
PLANNED	2/18/2021	1	74	74
PLANNED	2/18/2021	8	56	7
PLANNED	2/18/2021	3	258	86
PLANNED	2/18/2021	11	319	29
PLANNED	2/18/2021	8	1,136	142
PLANNED	2/18/2021	17	2,652	156
PLANNED	2/18/2021	1	160	160
PLANNED	2/18/2021	1	62	62

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/18/2021	8	24	3
PLANNED	2/18/2021	1	85	85
PLANNED	2/18/2021	14	798	57
PLANNED	2/18/2021	8	1,312	164
PLANNED	2/18/2021	6	1,362	227
PLANNED	2/18/2021	7	651	93
PLANNED	2/18/2021	1	70	70
PLANNED	2/18/2021	5	1,070	214
PLANNED	2/18/2021	2	154	77
PLANNED	2/18/2021	4	292	73
PLANNED	2/18/2021	4	268	67
PLANNED	2/18/2021	5	1,230	246
PLANNED	2/18/2021	7	147	21
PLANNED	2/18/2021	9	621	69
PLANNED	2/18/2021	5	245	49
PLANNED	2/18/2021	7	518	74
PLANNED	2/18/2021	1	29	29
PLANNED	2/18/2021	4	120	30
PLANNED	2/18/2021	4	584	146
PLANNED	2/18/2021	4	28	7
PLANNED	2/18/2021	9	477	53
CUSTOMER REQUEST	2/18/2021	11	308	28
PLANNED	2/18/2021	12	816	68
PLANNED	2/18/2021	13	923	71
PLANNED	2/18/2021	12	168	14
PLANNED	2/18/2021	2	130	65
PLANNED	2/18/2021	6	30	5
PLANNED	2/18/2021	7	218	54
PLANNED	2/18/2021	8	512	64
PLANNED	2/18/2021	1	122	122
PLANNED	2/18/2021	4	256	64
PLANNED	2/18/2021	2	554	277
PLANNED	2/18/2021	3	291	97
PLANNED	2/18/2021	3	183	61
PLANNED	2/18/2021	3	132	44
PLANNED	2/18/2021	5	130	26
CUSTOMER REQUEST	2/18/2021	11	264	24
PLANNED	2/18/2021	12	84	7
PLANNED	2/18/2021	1	84	84
PLANNED	2/18/2021	5	265	53
PLANNED	2/18/2021	7	301	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/18/2021	5	900	180
PLANNED	2/18/2021	3	318	106
PLANNED	2/18/2021	8	40	5
CUSTOMER REQUEST	2/18/2021	11	55	5
PLANNED	2/18/2021	4	96	24
PLANNED	2/18/2021	8	152	19
PLANNED	2/18/2021	8	536	67
PLANNED	2/18/2021	1	16	16
PLANNED	2/18/2021	2	76	38
PLANNED	2/18/2021	1	81	81
PLANNED	2/18/2021	2	322	161
PLANNED	2/18/2021	1	47	47
PLANNED	2/18/2021	2	74	37
PLANNED	2/18/2021	4	312	78
PLANNED	2/18/2021	3	126	42
PLANNED	2/18/2021	7	10,780	1,540
PLANNED	2/18/2021	1	119	119
PLANNED	2/18/2021	12	1,896	158
PLANNED	2/18/2021	2	114	57
PLANNED	2/18/2021	2	70	35
PLANNED	2/19/2021	3	717	239
PLANNED	2/19/2021	1	225	225
PLANNED	2/19/2021	12	2,532	211
PLANNED	2/19/2021	1	38	38
CUSTOMER REQUEST	2/19/2021	1	232	232
PLANNED	2/19/2021	8	480	60
PLANNED	2/19/2021	7	588	84
PLANNED	2/19/2021	2	18	9
PLANNED	2/19/2021	4	100	25
PLANNED	2/19/2021	1	51	51
PLANNED	2/19/2021	8	648	81
PLANNED	2/19/2021	6	330	55
PLANNED	2/19/2021	6	300	50
PLANNED	2/19/2021	2	52	26
PLANNED	2/19/2021	4	288	72
PLANNED	2/19/2021	3	81	27
PLANNED	2/19/2021	3	165	55
PLANNED	2/19/2021	3	180	60
PLANNED	2/19/2021	11	1,705	155
PLANNED	2/19/2021	9	225	25
PLANNED	2/19/2021	10	250	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/19/2021	16	256	16
PLANNED	2/19/2021	3	249	83
PLANNED	2/19/2021	8	72	9
PLANNED	2/19/2021	8	128	16
PLANNED	2/19/2021	8	128	16
PLANNED	2/19/2021	3	150	50
PLANNED	2/19/2021	32	512	16
PLANNED	2/19/2021	6	138	23
PLANNED	2/19/2021	1	68	68
PLANNED	2/19/2021	3	39	13
PLANNED	2/19/2021	5	125	25
PLANNED	2/19/2021	1	67	67
PLANNED	2/19/2021	1	47	47
PLANNED	2/19/2021	6	180	30
PLANNED	2/19/2021	3	150	50
PLANNED	2/19/2021	5	985	197
PLANNED	2/19/2021	7	217	31
PLANNED	2/19/2021	4	336	84
PLANNED	2/19/2021	4	144	36
PLANNED	2/19/2021	2	140	70
PLANNED	2/19/2021	6	486	81
PLANNED	2/19/2021	2	78	39
CUSTOMER REQUEST	2/19/2021	4	344	86
PLANNED	2/19/2021	1	159	159
PLANNED	2/19/2021	7	105	15
PLANNED	2/19/2021	3	294	98
PLANNED	2/19/2021	13	494	38
PLANNED	2/19/2021	6	252	42
PLANNED	2/19/2021	5	405	81
PLANNED	2/19/2021	10	280	28
PLANNED	2/19/2021	8	208	26
PLANNED	2/19/2021	15	675	45
PLANNED	2/19/2021	4	104	26
PLANNED	2/19/2021	7	427	61
PLANNED	2/19/2021	1	64	64
PLANNED	2/19/2021	1	10	10
PLANNED	2/19/2021	3	180	60
PLANNED	2/19/2021	8	376	47
PLANNED	2/19/2021	2	134	67
PLANNED	2/19/2021	2	10	5
CUSTOMER REQUEST	2/19/2021	1	191	191

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/19/2021	3	261	87
PLANNED	2/19/2021	1	93	93
PLANNED	2/20/2021	49	19,208	392
PLANNED	2/20/2021	4	400	100
PLANNED	2/20/2021	1	251	251
PLANNED	2/20/2021	8	24	3
PLANNED	2/20/2021	1	68	68
PLANNED	2/20/2021	9	171	19
CUSTOMER REQUEST	2/21/2021	1,569	68,355	55
PLANNED	2/21/2021	1	563	563
CUSTOMER REQUEST	2/21/2021	5	3,305	661
PLANNED	2/21/2021	3	246	82
PLANNED	2/21/2021	14	1,442	103
PLANNED	2/21/2021	3	255	85
PLANNED	2/21/2021	1	19	19
PLANNED	2/21/2021	5	560	112
PLANNED	2/21/2021	2	380	190
PLANNED	2/21/2021	1	163	163
PLANNED	2/21/2021	1	170	170
PLANNED	2/21/2021	3	201	67
PLANNED	2/21/2021	5	270	54
CUSTOMER REQUEST	2/22/2021	1	467	467
PLANNED	2/22/2021	1	65	65
PLANNED	2/22/2021	8	272	34
PLANNED	2/22/2021	6	888	148
PLANNED	2/22/2021	3	561	187
PLANNED	2/22/2021	9	531	59
PLANNED	2/22/2021	6	366	61
CUSTOMER REQUEST	2/22/2021	8	120	15
PLANNED	2/22/2021	10	260	26
CUSTOMER REQUEST	2/22/2021	3	24	8
PLANNED	2/22/2021	3	102	34
CUSTOMER REQUEST	2/22/2021	6	3,036	506
PLANNED	2/22/2021	2	88	44
PLANNED	2/22/2021	19	4,275	225
CUSTOMER REQUEST	2/22/2021	3	24	8
PLANNED	2/22/2021	2	116	58
PLANNED	2/22/2021	8	352	44
PLANNED	2/22/2021	2	330	165
PLANNED	2/22/2021	8	544	68
PLANNED	2/22/2021	4	352	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/22/2021	3	324	108
PLANNED	2/22/2021	3	447	149
PLANNED	2/22/2021	1	71	71
PLANNED	2/22/2021	2	226	113
PLANNED	2/22/2021	2	58	29
PLANNED	2/22/2021	3	438	146
PLANNED	2/22/2021	2	66	33
PLANNED	2/22/2021	3	354	118
PLANNED	2/22/2021	2	188	94
PLANNED	2/22/2021	8	296	37
CUSTOMER REQUEST	2/22/2021	1	67	67
PLANNED	2/22/2021	24	2,880	120
PLANNED	2/22/2021	3	537	179
PLANNED	2/22/2021	5	1,580	316
PLANNED	2/22/2021	1	57	57
PLANNED	2/22/2021	4	208	52
PLANNED	2/22/2021	2	44	22
CUSTOMER REQUEST	2/22/2021	1	954	954
PLANNED	2/22/2021	6	882	147
PLANNED	2/22/2021	1	6	6
PLANNED	2/22/2021	1	27	27
PLANNED	2/22/2021	8	1,072	134
PLANNED	2/22/2021	9	1,287	143
CUSTOMER REQUEST	2/22/2021	2	444	222
PLANNED	2/22/2021	1	165	165
CUSTOMER REQUEST	2/22/2021	1	7	7
PLANNED	2/22/2021	9	117	13
PLANNED	2/22/2021	12	384	32
PLANNED	2/22/2021	5	50	10
PLANNED	2/22/2021	5	340	68
PLANNED	2/22/2021	2	136	68
PLANNED	2/22/2021	1	36	36
PLANNED	2/22/2021	1	84	84
PLANNED	2/22/2021	3	318	106
PLANNED	2/22/2021	7	476	68
PLANNED	2/22/2021	7	742	106
PLANNED	2/22/2021	4	20	5
PLANNED	2/22/2021	11	55	5
PLANNED	2/22/2021	7	154	22
PLANNED	2/22/2021	4	96	24
PLANNED	2/22/2021	2	54	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/22/2021	5	35	7
PLANNED	2/22/2021	8	1,696	212
PLANNED	2/22/2021	1	31	31
CUSTOMER REQUEST	2/22/2021	2	4	2
PLANNED	2/22/2021	8	168	21
PLANNED	2/22/2021	7	147	21
PLANNED	2/22/2021	1	41	41
PLANNED	2/22/2021	11	1,287	117
PLANNED	2/22/2021	6	732	122
PLANNED	2/22/2021	6	42	7
PLANNED	2/22/2021	2	38	19
PLANNED	2/22/2021	2	134	67
PLANNED	2/22/2021	2	48	24
PLANNED	2/22/2021	4	164	41
PLANNED	2/22/2021	6	48	8
PLANNED	2/22/2021	3	282	94
PLANNED	2/22/2021	11	363	33
PLANNED	2/22/2021	2	92	46
PLANNED	2/22/2021	2	432	216
PLANNED	2/22/2021	10	2,540	254
PLANNED	2/22/2021	8	368	46
PLANNED	2/22/2021	10	50	5
PLANNED	2/22/2021	1	105	105
PLANNED	2/22/2021	1	23	23
PLANNED	2/22/2021	3	126	42
PLANNED	2/22/2021	4	524	131
PLANNED	2/22/2021	1	11	11
PLANNED	2/22/2021	3	48	16
PLANNED	2/22/2021	1	19	19
PLANNED	2/22/2021	4	280	70
PLANNED	2/22/2021	6	858	143
PLANNED	2/22/2021	2	284	142
PLANNED	2/22/2021	1	122	122
PLANNED	2/22/2021	9	45	5
PLANNED	2/22/2021	10	60	6
PLANNED	2/22/2021	3	132	44
PLANNED	2/22/2021	2	24	12
PLANNED	2/22/2021	3	123	41
PLANNED	2/22/2021	1	9	9
PLANNED	2/22/2021	10	1,010	101
PLANNED	2/22/2021	3	75	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/22/2021	7	1,134	162
PLANNED	2/22/2021	2	120	69
PLANNED	2/22/2021	4	204	51
PLANNED	2/22/2021	1	187	187
PLANNED	2/22/2021	3	66	32
PLANNED	2/22/2021	2	32	16
PLANNED	2/22/2021	6	120	20
PLANNED	2/22/2021	2	120	60
PLANNED	2/22/2021	1	58	58
PLANNED	2/22/2021	1	14	14
PLANNED	2/22/2021	18	504	28
PLANNED	2/22/2021	3	123	41
PLANNED	2/22/2021	5	35	7
PLANNED	2/22/2021	10	930	93
PLANNED	2/22/2021	1	60	60
PLANNED	2/22/2021	1	9	9
PLANNED	2/22/2021	1	14	14
PLANNED	2/22/2021	4	436	109
PLANNED	2/22/2021	7	364	52
PLANNED	2/22/2021	2	230	115
PLANNED	2/22/2021	1	9	9
PLANNED	2/22/2021	2	40	20
PLANNED	2/22/2021	1	10	10
PLANNED	2/22/2021	2	50	25
PLANNED	2/22/2021	1	29	29
PLANNED	2/22/2021	3	54	18
PLANNED	2/22/2021	4	140	35
CUSTOMER REQUEST	2/22/2021	1	514	514
PLANNED	2/22/2021	4	136	34
PLANNED	2/22/2021	1	15	15
CUSTOMER REQUEST	2/22/2021	1	244	244
PLANNED	2/22/2021	15	2,640	176
CUSTOMER REQUEST	2/22/2021	1	191	191
PLANNED	2/22/2021	27	3,915	145
PLANNED	2/22/2021	3	348	116
PLANNED	2/22/2021	1	50	50
CUSTOMER REQUEST	2/23/2021	18	2,682	149
PLANNED	2/23/2021	2	96	48
PLANNED	2/23/2021	1	256	256
PLANNED	2/23/2021	1	87	87
PLANNED	2/23/2021	4	940	235

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/23/2021	4	176	44
PLANNED	2/23/2021	1	55	55
PLANNED	2/23/2021	1	91	91
PLANNED	2/23/2021	5	125	25
PLANNED	2/23/2021	8	544	68
PLANNED	2/23/2021	1	275	275
PLANNED	2/23/2021	2	570	285
PLANNED	2/23/2021	4	268	67
PLANNED	2/23/2021	9	306	34
PLANNED	2/23/2021	8	320	40
PLANNED	2/23/2021	4	152	38
PLANNED	2/23/2021	4	1,016	254
PLANNED	2/23/2021	4	128	32
PLANNED	2/23/2021	2	121	62
PLANNED	2/23/2021	1	114	114
PLANNED	2/23/2021	74	14,060	190
PLANNED	2/23/2021	1	83	83
PLANNED	2/23/2021	9	234	26
PLANNED	2/23/2021	3	168	56
PLANNED	2/23/2021	2	64	32
CUSTOMER REQUEST	2/23/2021	1	280	280
PLANNED	2/23/2021	1	152	152
PLANNED	2/23/2021	9	1,260	140
PLANNED	2/23/2021	12	456	38
PLANNED	2/23/2021	6	96	16
PLANNED	2/23/2021	11	1,122	102
PLANNED	2/23/2021	4	300	75
PLANNED	2/23/2021	10	1,020	102
PLANNED	2/23/2021	10	1,060	106
PLANNED	2/23/2021	2	38	19
PLANNED	2/23/2021	7	805	115
PLANNED	2/23/2021	11	1,056	96
PLANNED	2/23/2021	51	6,222	122
PLANNED	2/23/2021	1	115	115
PLANNED	2/23/2021	9	837	93
PLANNED	2/23/2021	46	3,818	83
PLANNED	2/23/2021	3	696	232
PLANNED	2/23/2021	16	1,040	65
PLANNED	2/23/2021	2	144	72
PLANNED	2/23/2021	7	595	85
PLANNED	2/23/2021	1	21	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/23/2021	28	5,432	194
PLANNED	2/23/2021	1	42	42
PLANNED	2/23/2021	2	92	46
PLANNED	2/23/2021	6	414	69
PLANNED	2/23/2021	5	290	58
PLANNED	2/23/2021	10	320	32
PLANNED	2/23/2021	24	2,088	87
PLANNED	2/23/2021	6	804	134
PLANNED	2/23/2021	2	40	20
PLANNED	2/23/2021	2	348	174
PLANNED	2/23/2021	14	1,316	94
PLANNED	2/23/2021	250	50,625	206
CUSTOMER REQUEST	2/23/2021	10	290	29
PLANNED	2/23/2021	2	280	140
PLANNED	2/23/2021	1	128	128
PLANNED	2/23/2021	2	38	19
PLANNED	2/23/2021	4	24	6
PLANNED	2/23/2021	2	156	78
PLANNED	2/23/2021	7	469	67
PLANNED	2/23/2021	2	76	38
PLANNED	2/23/2021	2	102	51
PLANNED	2/23/2021	4	60	15
PLANNED	2/23/2021	4	48	12
PLANNED	2/23/2021	1	48	48
PLANNED	2/23/2021	1	79	79
PLANNED	2/23/2021	8	560	70
PLANNED	2/23/2021	6	420	70
PLANNED	2/23/2021	3	147	49
PLANNED	2/23/2021	7	490	70
PLANNED	2/23/2021	4	324	81
PLANNED	2/23/2021	1	90	90
PLANNED	2/23/2021	7	476	68
PLANNED	2/23/2021	7	455	65
PLANNED	2/23/2021	8	600	75
PLANNED	2/23/2021	2	80	40
PLANNED	2/23/2021	7	196	28
PLANNED	2/23/2021	3	72	24
PLANNED	2/23/2021	2	24	12
PLANNED	2/23/2021	5	320	64
PLANNED	2/23/2021	17	1,870	110
PLANNED	2/23/2021	1	394	394

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/23/2021	4	64	16
PLANNED	2/23/2021	2	272	136
PLANNED	2/23/2021	4	100	25
PLANNED	2/23/2021	4	84	21
PLANNED	2/23/2021	4	184	46
PLANNED	2/23/2021	7	812	116
PLANNED	2/23/2021	1	81	81
PLANNED	2/23/2021	2	150	75
PLANNED	2/23/2021	2	66	33
PLANNED	2/23/2021	2	80	40
PLANNED	2/23/2021	9	333	37
PLANNED	2/23/2021	1	88	88
PLANNED	2/23/2021	10	250	25
PLANNED	2/23/2021	9	495	55
PLANNED	2/23/2021	2	464	232
PLANNED	2/23/2021	4	112	28
PLANNED	2/23/2021	1	53	53
PLANNED	2/23/2021	1	18	18
PLANNED	2/23/2021	1	66	66
PLANNED	2/23/2021	3	84	28
PLANNED	2/23/2021	1	91	91
PLANNED	2/23/2021	5	945	189
PLANNED	2/23/2021	2	146	73
PLANNED	2/23/2021	2	145	79
PLANNED	2/23/2021	3	195	65
PLANNED	2/23/2021	5	270	54
PLANNED	2/23/2021	13	169	13
PLANNED	2/23/2021	8	216	27
PLANNED	2/23/2021	1	63	63
PLANNED	2/23/2021	1	9	9
PLANNED	2/23/2021	2	96	48
PLANNED	2/23/2021	8	136	17
PLANNED	2/23/2021	1	75	75
PLANNED	2/23/2021	4	436	109
PLANNED	2/23/2021	11	1,595	145
PLANNED	2/23/2021	1	31	31
PLANNED	2/23/2021	5	305	61
PLANNED	2/23/2021	1	110	110
PLANNED	2/23/2021	1	59	59
PLANNED	2/23/2021	1	113	113
CUSTOMER REQUEST	2/23/2021	1	108	108

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/24/2021	1	96	96
PLANNED	2/24/2021	1	65	65
PLANNED	2/24/2021	1	100	100
PLANNED	2/24/2021	8	768	96
PLANNED	2/24/2021	6	888	148
PLANNED	2/24/2021	3	120	40
PLANNED	2/24/2021	15	480	32
PLANNED	2/24/2021	2	158	90
PLANNED	2/24/2021	4	297	81
PLANNED	2/24/2021	10	310	31
PLANNED	2/24/2021	6	1,194	199
PLANNED	2/24/2021	4	356	89
PLANNED	2/24/2021	12	1,068	89
CUSTOMER REQUEST	2/24/2021	2	2	1,897
PLANNED	2/24/2021	3	147	49
PLANNED	2/24/2021	4	220	55
PLANNED	2/24/2021	9	468	52
PLANNED	2/24/2021	3	399	133
PLANNED	2/24/2021	2	416	208
PLANNED	2/24/2021	7	175	25
PLANNED	2/24/2021	3	525	175
PLANNED	2/24/2021	1	142	142
PLANNED	2/24/2021	1	127	127
PLANNED	2/24/2021	9	918	102
PLANNED	2/24/2021	2	78	39
PLANNED	2/24/2021	10	1,020	102
PLANNED	2/24/2021	6	858	143
PLANNED	2/24/2021	1	115	115
PLANNED	2/24/2021	9	459	51
CUSTOMER REQUEST	2/24/2021	18	1,251	377
PLANNED	2/24/2021	1	108	108
PLANNED	2/24/2021	7	224	32
PLANNED	2/24/2021	8	1,650	255
PLANNED	2/24/2021	8	40	5
PLANNED	2/24/2021	35	5,740	164
PLANNED	2/24/2021	9	567	63
PLANNED	2/24/2021	10	190	19
PLANNED	2/24/2021	3	333	173
PLANNED	2/24/2021	1	91	91
PLANNED	2/24/2021	6	456	76
PLANNED	2/24/2021	1	55	55

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/24/2021	4	144	36
PLANNED	2/24/2021	16	1,856	116
PLANNED	2/24/2021	10	1,200	120
PLANNED	2/24/2021	12	1,368	114
PLANNED	2/24/2021	20	2,280	114
PLANNED	2/24/2021	6	330	55
PLANNED	2/24/2021	2	856	428
PLANNED	2/24/2021	4	80	20
PLANNED	2/24/2021	3	15	5
PLANNED	2/24/2021	18	432	24
PLANNED	2/24/2021	7	2,191	313
PLANNED	2/24/2021	1	9	9
PLANNED	2/24/2021	72	11,520	160
PLANNED	2/24/2021	2	362	181
PLANNED	2/24/2021	17	136	8
PLANNED	2/24/2021	12	120	10
PLANNED	2/24/2021	6	342	57
PLANNED	2/24/2021	47	4,183	89
PLANNED	2/24/2021	4	16	4
PLANNED	2/24/2021	1	78	78
PLANNED	2/24/2021	45	5,175	115
CUSTOMER REQUEST	2/24/2021	6	84	14
PLANNED	2/24/2021	2	24	12
PLANNED	2/24/2021	13	1,677	129
PLANNED	2/24/2021	1	26	26
PLANNED	2/24/2021	7	98	14
PLANNED	2/24/2021	1	110	110
PLANNED	2/24/2021	1	103	103
PLANNED	2/24/2021	5	600	120
PLANNED	2/24/2021	8	176	22
PLANNED	2/24/2021	6	288	48
PLANNED	2/24/2021	1	67	67
PLANNED	2/24/2021	6	222	37
PLANNED	2/24/2021	6	120	20
PLANNED	2/24/2021	1	58	58
PLANNED	2/24/2021	5	155	31
PLANNED	2/24/2021	4	116	29
PLANNED	2/24/2021	3	87	29
PLANNED	2/24/2021	4	348	87
PLANNED	2/24/2021	2	66	33
PLANNED	2/24/2021	3	81	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/24/2021	1	20	20
PLANNED	2/24/2021	1	238	238
PLANNED	2/24/2021	4	160	40
PLANNED	2/24/2021	6	228	38
PLANNED	2/24/2021	3	171	57
PLANNED	2/24/2021	9	135	15
PLANNED	2/24/2021	6	198	33
PLANNED	2/24/2021	4	104	26
PLANNED	2/24/2021	5	75	15
PLANNED	2/24/2021	1	184	184
PLANNED	2/24/2021	4	160	40
PLANNED	2/24/2021	1	110	110
PLANNED	2/24/2021	1	40	40
PLANNED	2/24/2021	5	5	1
PLANNED	2/24/2021	2	86	45
PLANNED	2/24/2021	3	42	14
PLANNED	2/24/2021	1	137	137
PLANNED	2/24/2021	5	260	52
PLANNED	2/24/2021	2	366	183
PLANNED	2/24/2021	18	2,052	114
PLANNED	2/24/2021	1	80	80
CUSTOMER REQUEST	2/24/2021	2	10	5
PLANNED	2/24/2021	6	648	108
PLANNED	2/24/2021	1	24	24
PLANNED	2/24/2021	1	28	28
PLANNED	2/24/2021	1	109	109
PLANNED	2/24/2021	3	135	45
PLANNED	2/24/2021	1	12	12
PLANNED	2/24/2021	7	574	82
PLANNED	2/24/2021	4	248	62
PLANNED	2/24/2021	1	192	192
PLANNED	2/24/2021	1	144	144
PLANNED	2/24/2021	1	98	98
PLANNED	2/24/2021	5	335	67
PLANNED	2/24/2021	1	124	124
PLANNED	2/24/2021	1	130	130
PLANNED	2/24/2021	5	315	63
PLANNED	2/24/2021	1	82	82
PLANNED	2/24/2021	2	118	59
PLANNED	2/24/2021	2	424	212
PLANNED	2/25/2021	1	208	208

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/25/2021	1	153	153
PLANNED	2/25/2021	1	86	86
PLANNED	2/25/2021	3	117	39
PLANNED	2/25/2021	6	936	224
PLANNED	2/25/2021	5	1,330	293
PLANNED	2/25/2021	11	1,962	207
PLANNED	2/25/2021	8	592	74
PLANNED	2/25/2021	1	70	70
CUSTOMER REQUEST	2/25/2021	1	125	125
PLANNED	2/25/2021	1	97	97
PLANNED	2/25/2021	4	160	40
PLANNED	2/25/2021	1	197	197
PLANNED	2/25/2021	1	134	134
PLANNED	2/25/2021	14	2,114	151
PLANNED	2/25/2021	3	129	43
PLANNED	2/25/2021	2	648	324
PLANNED	2/25/2021	12	252	21
PLANNED	2/25/2021	6	234	39
PLANNED	2/25/2021	5	90	18
PLANNED	2/25/2021	1	157	157
PLANNED	2/25/2021	4	1,132	283
PLANNED	2/25/2021	3	81	27
PLANNED	2/25/2021	4	300	75
PLANNED	2/25/2021	1	81	81
PLANNED	2/25/2021	7	497	71
PLANNED	2/25/2021	1	163	163
PLANNED	2/25/2021	2	425	226
CUSTOMER REQUEST	2/25/2021	13	91	7
CUSTOMER REQUEST	2/25/2021	5	20	4
PLANNED	2/25/2021	15	180	12
PLANNED	2/25/2021	2	86	43
CUSTOMER REQUEST	2/25/2021	147	48,951	333
PLANNED	2/25/2021	9	45	5
PLANNED	2/25/2021	5	55	11
PLANNED	2/25/2021	3	66	22
PLANNED	2/25/2021	7	35	5
PLANNED	2/25/2021	5	180	36
PLANNED	2/25/2021	4	96	24
PLANNED	2/25/2021	2	76	38
PLANNED	2/25/2021	2	106	53
PLANNED	2/25/2021	1	173	173

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/25/2021	9	270	30
PLANNED	2/25/2021	7	210	30
PLANNED	2/25/2021	7	399	57
PLANNED	2/25/2021	3	174	58
PLANNED	2/25/2021	1	164	164
PLANNED	2/25/2021	2	82	41
PLANNED	2/25/2021	1	35	35
PLANNED	2/25/2021	2	490	245
PLANNED	2/25/2021	2	68	34
PLANNED	2/25/2021	2	40	20
PLANNED	2/25/2021	2	38	19
PLANNED	2/25/2021	3	171	57
CUSTOMER REQUEST	2/25/2021	9	90	10
PLANNED	2/25/2021	7	336	48
PLANNED	2/25/2021	1	235	235
PLANNED	2/25/2021	8	136	17
PLANNED	2/25/2021	4	48	12
PLANNED	2/25/2021	8	302	64
PLANNED	2/25/2021	3	309	229
PLANNED	2/25/2021	2	50	25
PLANNED	2/25/2021	3	93	31
PLANNED	2/25/2021	8	192	24
PLANNED	2/25/2021	6	474	79
PLANNED	2/25/2021	5	180	36
PLANNED	2/25/2021	1	41	41
PLANNED	2/25/2021	3	114	38
PLANNED	2/25/2021	3	33	11
PLANNED	2/25/2021	5	860	172
PLANNED	2/25/2021	3	306	102
PLANNED	2/25/2021	2	66	33
PLANNED	2/25/2021	6	714	119
PLANNED	2/25/2021	12	720	60
PLANNED	2/25/2021	10	740	74
PLANNED	2/25/2021	6	276	46
PLANNED	2/25/2021	18	2,808	156
PLANNED	2/25/2021	4	148	37
PLANNED	2/25/2021	4	372	93
PLANNED	2/25/2021	9	63	7
PLANNED	2/25/2021	10	840	84
PLANNED	2/25/2021	4	132	33
PLANNED	2/25/2021	3	9	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/25/2021	3	48	16
PLANNED	2/25/2021	4	236	59
PLANNED	2/25/2021	4	244	61
PLANNED	2/25/2021	1	95	95
PLANNED	2/25/2021	1	91	91
PLANNED	2/25/2021	5	40	8
PLANNED	2/25/2021	10	340	34
PLANNED	2/25/2021	8	16	2
PLANNED	2/25/2021	2	223	113
PLANNED	2/25/2021	6	288	48
PLANNED	2/25/2021	1	108	108
PLANNED	2/25/2021	7	812	116
PLANNED	2/25/2021	1	6	6
PLANNED	2/25/2021	9	18	2
PLANNED	2/25/2021	3	129	43
PLANNED	2/25/2021	1	35	35
PLANNED	2/25/2021	4	324	81
PLANNED	2/25/2021	2	52	26
PLANNED	2/25/2021	2	52	26
PLANNED	2/25/2021	16	704	44
PLANNED	2/25/2021	1	69	69
PLANNED	2/25/2021	1	52	52
PLANNED	2/25/2021	12	168	14
PLANNED	2/25/2021	6	114	19
PLANNED	2/25/2021	1	98	98
PLANNED	2/25/2021	2	74	37
PLANNED	2/25/2021	4	672	168
PLANNED	2/25/2021	2	92	46
PLANNED	2/25/2021	2	44	22
PLANNED	2/25/2021	1	15	15
PLANNED	2/25/2021	2	96	48
PLANNED	2/25/2021	1	91	91
PLANNED	2/25/2021	1	88	88
PLANNED	2/25/2021	1	325	325
PLANNED	2/25/2021	1	58	58
PLANNED	2/25/2021	5	795	159
PLANNED	2/25/2021	2	174	87
PLANNED	2/25/2021	2	174	87
PLANNED	2/25/2021	8	136	17
PLANNED	2/25/2021	1	45	45
PLANNED	2/25/2021	2	60	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/25/2021	3	735	245
PLANNED	2/25/2021	2	404	202
PLANNED	2/25/2021	3	267	89
PLANNED	2/25/2021	1	124	124
PLANNED	2/25/2021	1	56	56
PLANNED	2/25/2021	25	1,450	58
PLANNED	2/25/2021	4	332	83
PLANNED	2/25/2021	3	273	91
PLANNED	2/26/2021	10	370	37
PLANNED	2/26/2021	4	340	85
PLANNED	2/26/2021	1	325	325
PLANNED	2/26/2021	3	21	7
PLANNED	2/26/2021	3	135	45
PLANNED	2/26/2021	9	342	38
PLANNED	2/26/2021	7	413	59
PLANNED	2/26/2021	14	2,632	188
PLANNED	2/26/2021	11	1,980	180
PLANNED	2/26/2021	6	174	29
PLANNED	2/26/2021	8	664	83
PLANNED	2/26/2021	3	285	95
PLANNED	2/26/2021	7	280	40
PLANNED	2/26/2021	4	808	202
PLANNED	2/26/2021	2	88	44
PLANNED	2/26/2021	7	217	31
PLANNED	2/26/2021	23	2,691	117
PLANNED	2/26/2021	4	544	136
PLANNED	2/26/2021	15	630	42
CUSTOMER REQUEST	2/26/2021	51	614	314
PLANNED	2/26/2021	3	75	25
PLANNED	2/26/2021	6	60	10
PLANNED	2/26/2021	3	153	51
CUSTOMER REQUEST	2/26/2021	22	3,246	321
PLANNED	2/26/2021	7	175	25
PLANNED	2/26/2021	4	244	61
PLANNED	2/26/2021	1	39	39
PLANNED	2/26/2021	1	105	105
CUSTOMER REQUEST	2/26/2021	12	1,956	163
CUSTOMER REQUEST	2/26/2021	12	1,968	164
PLANNED	2/26/2021	1	135	135
PLANNED	2/26/2021	11	583	53
PLANNED	2/26/2021	10	1,470	147

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/26/2021	2	162	81
PLANNED	2/26/2021	4	48	12
PLANNED	2/26/2021	2	46	23
PLANNED	2/26/2021	4	56	14
PLANNED	2/26/2021	4	480	120
PLANNED	2/26/2021	5	400	80
PLANNED	2/26/2021	2	26	13
PLANNED	2/26/2021	4	204	51
CUSTOMER REQUEST	2/26/2021	1	20	20
PLANNED	2/26/2021	5	245	49
PLANNED	2/26/2021	2	92	46
CUSTOMER REQUEST	2/26/2021	1	180	180
PLANNED	2/26/2021	6	1,548	258
PLANNED	2/26/2021	8	1,208	151
PLANNED	2/26/2021	2	458	229
PLANNED	2/26/2021	10	530	53
PLANNED	2/26/2021	6	174	29
PLANNED	2/26/2021	11	440	40
PLANNED	2/26/2021	3	84	28
PLANNED	2/26/2021	7	196	28
PLANNED	2/26/2021	11	451	41
PLANNED	2/26/2021	4	104	26
PLANNED	2/26/2021	1	112	112
PLANNED	2/26/2021	4	64	16
CUSTOMER REQUEST	2/26/2021	8	1,336	167
PLANNED	2/26/2021	1	79	79
CUSTOMER REQUEST	2/26/2021	1	45	45
PLANNED	2/26/2021	1	8	8
PLANNED	2/26/2021	1	3	3
PLANNED	2/26/2021	1	73	73
PLANNED	2/26/2021	8	24	3
PLANNED	2/26/2021	1	192	192
PLANNED	2/26/2021	3	315	105
PLANNED	2/26/2021	2	30	15
PLANNED	2/26/2021	3	285	95
PLANNED	2/26/2021	8	552	69
PLANNED	2/26/2021	1	25	25
PLANNED	2/26/2021	9	315	35
PLANNED	2/26/2021	27	1,809	67
PLANNED	2/26/2021	5	380	76
PLANNED	2/26/2021	4	176	44

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/26/2021	13	936	72
PLANNED	2/26/2021	4	328	82
PLANNED	2/26/2021	1	52	52
PLANNED	2/26/2021	4	200	50
PLANNED	2/26/2021	2	214	107
PLANNED	2/26/2021	2	14	7
PLANNED	2/26/2021	11	1,518	138
PLANNED	2/26/2021	4	148	37
PLANNED	2/26/2021	3	132	44
PLANNED	2/26/2021	7	763	109
PLANNED	2/26/2021	4	120	30
PLANNED	2/26/2021	4	312	78
PLANNED	2/26/2021	4	624	156
PLANNED	2/26/2021	1	10	10
PLANNED	2/26/2021	3	258	86
CUSTOMER REQUEST	2/26/2021	1	249	249
PLANNED	2/26/2021	2	310	155
PLANNED	2/27/2021	9	369	41
PLANNED	2/27/2021	16	400	25
PLANNED	2/27/2021	3	384	128
PLANNED	2/27/2021	1	246	246
PLANNED	2/27/2021	7	2,345	335
PLANNED	2/27/2021	16	1,312	82
PLANNED	2/27/2021	2	150	75
PLANNED	2/27/2021	3	132	44
PLANNED	2/27/2021	1	38	38
PLANNED	2/27/2021	4	332	83
PLANNED	2/27/2021	1	93	93
PLANNED	2/27/2021	9	1,020	145
PLANNED	2/27/2021	3	228	76
PLANNED	2/27/2021	4	140	35
PLANNED	2/27/2021	12	1,512	126
PLANNED	2/27/2021	6	66	11
PLANNED	2/28/2021	2	862	431
PLANNED	2/28/2021	5	275	55
PLANNED	2/28/2021	8	616	77
PLANNED	2/28/2021	4	220	55
PLANNED	2/28/2021	18	828	46
PLANNED	2/28/2021	6	66	11
PLANNED	2/28/2021	5	185	37
PLANNED	2/28/2021	20	7,280	364

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	2/28/2021	13	4,381	337
PLANNED	2/28/2021	4	412	103
PLANNED	2/28/2021	8	2,180	364
PLANNED	2/28/2021	1	130	130
PLANNED	2/28/2021	8	24	3
PLANNED	2/28/2021	2	126	63
PLANNED	2/28/2021	1	21	21
PLANNED	2/28/2021	4	828	207
PLANNED	2/28/2021	2	104	52
PLANNED	2/28/2021	2	166	83
PLANNED	2/28/2021	2	72	36
PLANNED	3/1/2021	15	690	46
PLANNED	3/1/2021	29	1,537	53
PLANNED	3/1/2021	1	50	50
PLANNED	3/1/2021	4	379	120
PLANNED	3/1/2021	12	2,052	171
PLANNED	3/1/2021	13	2,132	164
PLANNED	3/1/2021	16	2,912	182
PLANNED	3/1/2021	8	496	62
PLANNED	3/1/2021	2	158	138
PLANNED	3/1/2021	7	189	27
PLANNED	3/1/2021	1	138	138
PLANNED	3/1/2021	2	338	169
PLANNED	3/1/2021	2	480	240
PLANNED	3/1/2021	3	462	154
PLANNED	3/1/2021	8	992	124
PLANNED	3/1/2021	2	24	12
PLANNED	3/1/2021	5	360	72
PLANNED	3/1/2021	3	39	13
PLANNED	3/1/2021	21	525	25
PLANNED	3/1/2021	5	210	42
PLANNED	3/1/2021	9	999	111
PLANNED	3/1/2021	4	104	26
PLANNED	3/1/2021	1	97	97
PLANNED	3/1/2021	10	580	58
CUSTOMER REQUEST	3/1/2021	6	120	20
PLANNED	3/1/2021	10	580	58
PLANNED	3/1/2021	5	650	130
PLANNED	3/1/2021	8	984	123
PLANNED	3/1/2021	5	530	106
PLANNED	3/1/2021	1	243	243

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/1/2021	8	848	106
PLANNED	3/1/2021	16	2,832	177
PLANNED	3/1/2021	7	742	106
PLANNED	3/1/2021	12	684	57
PLANNED	3/1/2021	3	90	30
PLANNED	3/1/2021	3	57	19
PLANNED	3/1/2021	2	462	231
PLANNED	3/1/2021	1	6	6
PLANNED	3/1/2021	1	66	66
PLANNED	3/1/2021	5	1,405	281
PLANNED	3/1/2021	3	231	77
PLANNED	3/1/2021	3	42	14
PLANNED	3/1/2021	4	468	117
PLANNED	3/1/2021	2	50	25
PLANNED	3/1/2021	15	525	35
PLANNED	3/1/2021	1	137	137
PLANNED	3/1/2021	2	24	12
PLANNED	3/1/2021	3	177	59
PLANNED	3/1/2021	2	192	96
PLANNED	3/1/2021	1	15	15
CUSTOMER REQUEST	3/1/2021	10	1,180	118
PLANNED	3/1/2021	1	97	97
PLANNED	3/1/2021	8	264	33
PLANNED	3/1/2021	12	372	31
PLANNED	3/1/2021	5	520	126
CUSTOMER REQUEST	3/1/2021	1	141	141
PLANNED	3/1/2021	8	312	39
PLANNED	3/1/2021	2	310	155
PLANNED	3/1/2021	2	32	16
PLANNED	3/1/2021	16	448	28
PLANNED	3/1/2021	10	400	40
PLANNED	3/1/2021	9	2,330	288
PLANNED	3/1/2021	9	405	45
PLANNED	3/1/2021	11	495	45
PLANNED	3/1/2021	1	25	25
PLANNED	3/1/2021	17	1,003	59
PLANNED	3/1/2021	22	154	7
PLANNED	3/1/2021	8	408	51
PLANNED	3/1/2021	5	220	44
PLANNED	3/1/2021	9	171	19
PLANNED	3/1/2021	3	181	161

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/1/2021	1	115	115
PLANNED	3/1/2021	4	24	6
PLANNED	3/1/2021	4	156	39
PLANNED	3/1/2021	5	525	105
PLANNED	3/1/2021	3	90	30
PLANNED	3/1/2021	3	291	97
PLANNED	3/1/2021	2	266	133
PLANNED	3/1/2021	4	84	21
PLANNED	3/1/2021	1	27	27
PLANNED	3/1/2021	2	150	75
PLANNED	3/1/2021	2	182	91
PLANNED	3/1/2021	3	72	24
PLANNED	3/1/2021	16	1,632	102
PLANNED	3/1/2021	20	1,840	92
PLANNED	3/1/2021	6	288	48
PLANNED	3/1/2021	5	765	153
PLANNED	3/1/2021	1	8	8
PLANNED	3/1/2021	5	90	18
PLANNED	3/1/2021	1	39	39
PLANNED	3/1/2021	1	12	12
PLANNED	3/1/2021	2	36	18
PLANNED	3/1/2021	7	539	77
PLANNED	3/1/2021	8	1,271	227
PLANNED	3/1/2021	8	648	81
PLANNED	3/1/2021	7	182	26
PLANNED	3/1/2021	4	276	69
PLANNED	3/1/2021	6	456	76
PLANNED	3/1/2021	1	32	32
PLANNED	3/1/2021	8	544	68
PLANNED	3/1/2021	4	276	69
PLANNED	3/1/2021	1	61	61
PLANNED	3/1/2021	1	35	35
PLANNED	3/1/2021	1	67	67
PLANNED	3/1/2021	1	12	12
PLANNED	3/1/2021	2	142	71
PLANNED	3/1/2021	2	70	35
PLANNED	3/1/2021	13	1,378	106
PLANNED	3/1/2021	1	116	116
PLANNED	3/1/2021	6	540	90
PLANNED	3/1/2021	5	520	104
PLANNED	3/1/2021	3	57	19

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/1/2021	1	28	28
PLANNED	3/1/2021	6	462	77
CUSTOMER REQUEST	3/1/2021	1	483	483
PLANNED	3/1/2021	7	81	18
PLANNED	3/1/2021	3	180	60
PLANNED	3/1/2021	2	308	154
PLANNED	3/1/2021	1	55	55
PLANNED	3/1/2021	4	80	20
PLANNED	3/1/2021	3	195	65
PLANNED	3/1/2021	1	84	84
PLANNED	3/1/2021	2	74	37
PLANNED	3/1/2021	2	88	44
PLANNED	3/1/2021	2	82	41
PLANNED	3/1/2021	9	405	45
PLANNED	3/1/2021	2	200	100
PLANNED	3/1/2021	2	154	77
PLANNED	3/2/2021	9	279	31
PLANNED	3/2/2021	2	176	111
PLANNED	3/2/2021	5	460	92
PLANNED	3/2/2021	7	357	51
PLANNED	3/2/2021	2	144	72
PLANNED	3/2/2021	1	37	37
PLANNED	3/2/2021	2	116	58
PLANNED	3/2/2021	1	271	271
PLANNED	3/2/2021	4	40	10
PLANNED	3/2/2021	3	45	15
PLANNED	3/2/2021	4	164	41
PLANNED	3/2/2021	2	473	383
CUSTOMER REQUEST	3/2/2021	44	18,832	428
PLANNED	3/2/2021	1	29	29
PLANNED	3/2/2021	3	105	35
PLANNED	3/2/2021	2	96	48
PLANNED	3/2/2021	1	125	125
PLANNED	3/2/2021	4	52	13
PLANNED	3/2/2021	7	666	132
PLANNED	3/2/2021	1	76	76
CUSTOMER REQUEST	3/2/2021	5	30	6
PLANNED	3/2/2021	3	138	46
PLANNED	3/2/2021	3	1,022	775
PLANNED	3/2/2021	2	62	31
CUSTOMER REQUEST	3/2/2021	1	116	116

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/2/2021	1	126	126
PLANNED	3/2/2021	1	28	28
PLANNED	3/2/2021	1	87	87
PLANNED	3/2/2021	12	348	29
PLANNED	3/2/2021	9	81	9
CUSTOMER REQUEST	3/2/2021	9	45	5
PLANNED	3/2/2021	21	1,491	71
PLANNED	3/2/2021	3	423	141
PLANNED	3/2/2021	5	734	184
PLANNED	3/2/2021	9	531	59
PLANNED	3/2/2021	1	115	115
PLANNED	3/2/2021	10	970	97
PLANNED	3/2/2021	4	140	35
CUSTOMER REQUEST	3/2/2021	31	6,634	214
PLANNED	3/2/2021	1	109	109
PLANNED	3/2/2021	3	207	87
CUSTOMER REQUEST	3/2/2021	13	884	68
PLANNED	3/2/2021	3	225	75
PLANNED	3/2/2021	4	84	21
PLANNED	3/2/2021	3	195	65
PLANNED	3/2/2021	14	2,562	183
PLANNED	3/2/2021	23	1,472	64
PLANNED	3/2/2021	6	216	36
PLANNED	3/2/2021	11	1,903	173
PLANNED	3/2/2021	6	174	29
PLANNED	3/2/2021	5	445	89
PLANNED	3/2/2021	8	368	46
PLANNED	3/2/2021	5	305	61
PLANNED	3/2/2021	8	424	53
PLANNED	3/2/2021	5	25	5
PLANNED	3/2/2021	1	7	7
PLANNED	3/2/2021	2	16	8
PLANNED	3/2/2021	8	635	150
PLANNED	3/2/2021	1	165	165
PLANNED	3/2/2021	6	282	47
PLANNED	3/2/2021	2	112	56
PLANNED	3/2/2021	17	459	27
PLANNED	3/2/2021	27	4,941	183
PLANNED	3/2/2021	10	240	24
PLANNED	3/2/2021	3	51	17
PLANNED	3/2/2021	2	70	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/2/2021	1	89	89
PLANNED	3/2/2021	1	90	90
PLANNED	3/2/2021	4	504	126
PLANNED	3/2/2021	2	238	119
CUSTOMER REQUEST	3/2/2021	7	91	13
PLANNED	3/2/2021	2	350	175
PLANNED	3/2/2021	3	429	143
PLANNED	3/2/2021	9	315	35
PLANNED	3/2/2021	2	286	143
PLANNED	3/2/2021	3	270	90
PLANNED	3/2/2021	1	25	25
PLANNED	3/2/2021	3	240	80
PLANNED	3/2/2021	1	153	153
PLANNED	3/2/2021	3	411	137
PLANNED	3/2/2021	6	66	11
PLANNED	3/2/2021	3	87	29
PLANNED	3/2/2021	13	520	40
PLANNED	3/2/2021	2	398	199
PLANNED	3/2/2021	2	50	25
PLANNED	3/2/2021	12	552	46
PLANNED	3/2/2021	2	388	194
PLANNED	3/2/2021	3	93	31
PLANNED	3/2/2021	2	238	119
PLANNED	3/2/2021	20	4,837	340
PLANNED	3/2/2021	1	37	37
CUSTOMER REQUEST	3/2/2021	1	123	123
PLANNED	3/2/2021	12	696	58
PLANNED	3/2/2021	5	5	1
PLANNED	3/2/2021	9	9	1
PLANNED	3/2/2021	12	360	30
PLANNED	3/2/2021	1	44	44
PLANNED	3/2/2021	1	30	30
CUSTOMER REQUEST	3/2/2021	2	72	36
PLANNED	3/2/2021	1	86	86
PLANNED	3/2/2021	1	136	136
PLANNED	3/2/2021	2	76	38
PLANNED	3/2/2021	1	78	78
PLANNED	3/2/2021	2	84	42
PLANNED	3/2/2021	2	99	56
PLANNED	3/2/2021	1	123	123
PLANNED	3/2/2021	1	27	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/2/2021	7	777	111
PLANNED	3/2/2021	3	399	133
PLANNED	3/2/2021	9	486	54
PLANNED	3/2/2021	7	217	31
PLANNED	3/2/2021	1	148	148
PLANNED	3/2/2021	9	423	47
PLANNED	3/2/2021	4	108	27
PLANNED	3/2/2021	1	111	111
PLANNED	3/2/2021	1	100	100
PLANNED	3/2/2021	2	88	44
PLANNED	3/2/2021	2	350	175
PLANNED	3/2/2021	2	6	3
PLANNED	3/2/2021	1	91	91
PLANNED	3/2/2021	2	180	90
PLANNED	3/2/2021	2	204	102
PLANNED	3/2/2021	9	405	45
PLANNED	3/2/2021	4	192	48
PLANNED	3/2/2021	8	560	70
PLANNED	3/2/2021	18	594	33
PLANNED	3/2/2021	5	165	33
PLANNED	3/2/2021	1	108	108
PLANNED	3/2/2021	3	75	25
PLANNED	3/2/2021	17	119	7
PLANNED	3/2/2021	2	66	33
PLANNED	3/2/2021	1	126	126
PLANNED	3/2/2021	42	2,520	60
PLANNED	3/2/2021	2	100	50
PLANNED	3/2/2021	7	112	16
PLANNED	3/2/2021	1	12	12
PLANNED	3/2/2021	1	126	126
PLANNED	3/2/2021	4	292	73
PLANNED	3/2/2021	1	10	10
PLANNED	3/2/2021	2	164	82
PLANNED	3/2/2021	1	17	17
PLANNED	3/2/2021	8	224	28
PLANNED	3/2/2021	3	183	61
PLANNED	3/2/2021	1	45	45
PLANNED	3/2/2021	3	171	57
PLANNED	3/2/2021	3	261	87
PLANNED	3/2/2021	2	48	24
PLANNED	3/2/2021	7	630	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/2/2021	10	636	70
PLANNED	3/2/2021	1	125	125
PLANNED	3/2/2021	2	526	263
PLANNED	3/2/2021	1	158	158
PLANNED	3/2/2021	1	107	107
CUSTOMER REQUEST	3/2/2021	1	88	88
PLANNED	3/3/2021	2	52	26
PLANNED	3/3/2021	3	174	58
PLANNED	3/3/2021	1	75	75
PLANNED	3/3/2021	4	148	37
PLANNED	3/3/2021	1	167	167
PLANNED	3/3/2021	2	98	51
PLANNED	3/3/2021	1	59	59
PLANNED	3/3/2021	99	36,036	364
PLANNED	3/3/2021	8	368	46
PLANNED	3/3/2021	1	284	284
PLANNED	3/3/2021	8	328	41
PLANNED	3/3/2021	5	170	34
PLANNED	3/3/2021	6	102	17
PLANNED	3/3/2021	9	765	85
PLANNED	3/3/2021	1	96	96
PLANNED	3/3/2021	7	224	32
PLANNED	3/3/2021	2	130	65
PLANNED	3/3/2021	3	33	11
PLANNED	3/3/2021	1	11	11
PLANNED	3/3/2021	13	1,092	84
PLANNED	3/3/2021	3	90	30
PLANNED	3/3/2021	2	214	107
PLANNED	3/3/2021	9	1,233	137
PLANNED	3/3/2021	1	92	92
PLANNED	3/3/2021	2	188	94
PLANNED	3/3/2021	7	84	12
PLANNED	3/3/2021	6	1,536	256
CUSTOMER REQUEST	3/3/2021	12	348	29
PLANNED	3/3/2021	3	3	249
PLANNED	3/3/2021	2	162	81
PLANNED	3/3/2021	1	16	16
PLANNED	3/3/2021	10	2,630	263
PLANNED	3/3/2021	7	1,834	262
PLANNED	3/3/2021	4	116	29
PLANNED	3/3/2021	1	146	146

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/3/2021	9	837	93
PLANNED	3/3/2021	9	738	82
PLANNED	3/3/2021	11	1,045	95
PLANNED	3/3/2021	1	213	213
PLANNED	3/3/2021	6	90	15
CUSTOMER REQUEST	3/3/2021	9	216	24
PLANNED	3/3/2021	2	246	123
PLANNED	3/3/2021	7	329	47
PLANNED	3/3/2021	4	152	38
PLANNED	3/3/2021	2	92	46
PLANNED	3/3/2021	20	3,900	195
PLANNED	3/3/2021	3	63	21
CUSTOMER REQUEST	3/3/2021	2	770	385
PLANNED	3/3/2021	16	1,440	90
PLANNED	3/3/2021	4	124	31
PLANNED	3/3/2021	8	528	66
PLANNED	3/3/2021	7	70	10
PLANNED	3/3/2021	11	891	81
PLANNED	3/3/2021	12	312	26
PLANNED	3/3/2021	8	160	20
PLANNED	3/3/2021	3	156	52
PLANNED	3/3/2021	1	173	173
PLANNED	3/3/2021	9	477	53
PLANNED	3/3/2021	3	375	125
PLANNED	3/3/2021	11	1,991	181
PLANNED	3/3/2021	4	156	39
PLANNED	3/3/2021	8	1,448	181
PLANNED	3/3/2021	3	234	78
PLANNED	3/3/2021	6	120	20
CUSTOMER REQUEST	3/3/2021	2	78	39
PLANNED	3/3/2021	5	365	73
PLANNED	3/3/2021	7	105	15
PLANNED	3/3/2021	12	1,296	108
PLANNED	3/3/2021	7	203	29
PLANNED	3/3/2021	5	175	35
CUSTOMER REQUEST	3/3/2021	1	38	38
PLANNED	3/3/2021	9	207	23
PLANNED	3/3/2021	4	1,048	262
CUSTOMER REQUEST	3/3/2021	4	75	72
CUSTOMER REQUEST	3/3/2021	3	174	58
PLANNED	3/3/2021	1	117	117

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/3/2021	3	42	14
PLANNED	3/3/2021	3	27	9
PLANNED	3/3/2021	5	410	82
CUSTOMER REQUEST	3/3/2021	88	2,640	30
PLANNED	3/3/2021	2	30	15
PLANNED	3/3/2021	6	252	42
PLANNED	3/3/2021	1	264	264
PLANNED	3/3/2021	6	426	71
PLANNED	3/3/2021	2	48	24
CUSTOMER REQUEST	3/3/2021	6	54	9
CUSTOMER REQUEST	3/3/2021	1	582	582
PLANNED	3/3/2021	4	124	31
PLANNED	3/3/2021	8	128	16
PLANNED	3/3/2021	1	109	109
PLANNED	3/3/2021	2	136	68
PLANNED	3/3/2021	8	664	83
PLANNED	3/3/2021	2	486	243
PLANNED	3/3/2021	1	94	94
PLANNED	3/3/2021	4	68	17
PLANNED	3/3/2021	5	650	130
PLANNED	3/3/2021	2	356	178
PLANNED	3/3/2021	45	6,930	202
PLANNED	3/3/2021	3	168	56
PLANNED	3/3/2021	5	80	16
CUSTOMER REQUEST	3/3/2021	23	230	10
PLANNED	3/3/2021	1	64	64
PLANNED	3/3/2021	3	108	36
PLANNED	3/3/2021	10	470	47
PLANNED	3/3/2021	6	282	47
PLANNED	3/3/2021	19	133	7
PLANNED	3/3/2021	4	624	156
PLANNED	3/3/2021	4	160	40
PLANNED	3/3/2021	2	312	156
PLANNED	3/3/2021	5	55	11
PLANNED	3/3/2021	1	40	40
PLANNED	3/3/2021	1	124	124
PLANNED	3/3/2021	3	132	44
PLANNED	3/3/2021	8	856	107
CUSTOMER REQUEST	3/3/2021	1	64	64
PLANNED	3/3/2021	5	450	90
PLANNED	3/3/2021	1	114	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/3/2021	1	75	75
PLANNED	3/3/2021	5	305	61
PLANNED	3/3/2021	5	240	48
PLANNED	3/3/2021	2	62	31
PLANNED	3/3/2021	1	102	102
PLANNED	3/3/2021	16	1,616	101
PLANNED	3/3/2021	17	1,887	111
PLANNED	3/3/2021	5	145	29
PLANNED	3/3/2021	5	470	94
PLANNED	3/3/2021	1	187	187
CUSTOMER REQUEST	3/3/2021	1	112	112
PLANNED	3/3/2021	3	162	54
PLANNED	3/3/2021	3	69	23
PLANNED	3/3/2021	2	98	49
PLANNED	3/3/2021	1	205	205
PLANNED	3/3/2021	1	106	106
PLANNED	3/3/2021	1	53	53
PLANNED	3/3/2021	9	135	15
PLANNED	3/3/2021	11	407	37
PLANNED	3/3/2021	1	112	112
PLANNED	3/3/2021	3	156	52
PLANNED	3/3/2021	14	728	52
PLANNED	3/3/2021	2	122	61
PLANNED	3/3/2021	3	96	32
PLANNED	3/3/2021	1	39	39
PLANNED	3/3/2021	2	208	104
PLANNED	3/3/2021	1	111	111
PLANNED	3/3/2021	3	405	135
PLANNED	3/3/2021	2	164	82
PLANNED	3/3/2021	3	264	88
PLANNED	3/3/2021	1	190	190
PLANNED	3/3/2021	6	270	45
PLANNED	3/3/2021	4	88	22
PLANNED	3/3/2021	3	336	112
PLANNED	3/3/2021	2	154	77
PLANNED	3/3/2021	1	89	89
PLANNED	3/3/2021	8	184	23
PLANNED	3/3/2021	2	96	48
CUSTOMER REQUEST	3/3/2021	1	124	124
PLANNED	3/3/2021	1	218	218
PLANNED	3/3/2021	1	75	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/3/2021	2	102	51
PLANNED	3/3/2021	2	224	112
PLANNED	3/3/2021	4	500	125
PLANNED	3/3/2021	3	597	199
PLANNED	3/3/2021	2	232	116
PLANNED	3/3/2021	8	720	90
PLANNED	3/4/2021	1	86	86
PLANNED	3/4/2021	4	200	50
PLANNED	3/4/2021	3	285	95
PLANNED	3/4/2021	2	106	53
PLANNED	3/4/2021	1	169	169
PLANNED	3/4/2021	9	1,898	292
PLANNED	3/4/2021	9	2,439	358
PLANNED	3/4/2021	8	1,152	144
PLANNED	3/4/2021	4	116	29
PLANNED	3/4/2021	4	344	86
PLANNED	3/4/2021	2	374	187
PLANNED	3/4/2021	25	1,800	72
PLANNED	3/4/2021	9	693	77
PLANNED	3/4/2021	8	616	77
PLANNED	3/4/2021	6	516	86
PLANNED	3/4/2021	1	108	108
PLANNED	3/4/2021	1	84	84
PLANNED	3/4/2021	1	251	251
PLANNED	3/4/2021	2	196	98
PLANNED	3/4/2021	4	200	50
PLANNED	3/4/2021	5	405	81
PLANNED	3/4/2021	12	420	35
PLANNED	3/4/2021	123	2,952	24
PLANNED	3/4/2021	1	69	69
PLANNED	3/4/2021	8	1,668	268
PLANNED	3/4/2021	11	847	77
PLANNED	3/4/2021	2	44	22
PLANNED	3/4/2021	2	304	152
PLANNED	3/4/2021	1	436	436
PLANNED	3/4/2021	1	29	29
CUSTOMER REQUEST	3/4/2021	1	200	200
PLANNED	3/4/2021	6	582	97
PLANNED	3/4/2021	4	204	51
PLANNED	3/4/2021	2	112	56
PLANNED	3/4/2021	5	110	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/4/2021	6	1,584	264
PLANNED	3/4/2021	3	363	121
PLANNED	3/4/2021	1	10	10
PLANNED	3/4/2021	2	120	60
PLANNED	3/4/2021	1	194	194
PLANNED	3/4/2021	35	1,890	54
CUSTOMER REQUEST	3/4/2021	9	63	7
PLANNED	3/4/2021	5	35	7
PLANNED	3/4/2021	1	194	194
PLANNED	3/4/2021	5	1,025	205
PLANNED	3/4/2021	5	1,035	207
PLANNED	3/4/2021	4	852	213
PLANNED	3/4/2021	2	26	13
PLANNED	3/4/2021	4	664	166
PLANNED	3/4/2021	4	660	165
PLANNED	3/4/2021	5	820	164
PLANNED	3/4/2021	4	660	165
PLANNED	3/4/2021	2	26	13
PLANNED	3/4/2021	9	1,152	128
PLANNED	3/4/2021	9	693	77
PLANNED	3/4/2021	6	240	40
PLANNED	3/4/2021	9	837	93
PLANNED	3/4/2021	9	693	77
PLANNED	3/4/2021	2	32	16
PLANNED	3/4/2021	1	337	337
PLANNED	3/4/2021	10	1,250	125
PLANNED	3/4/2021	4	28	7
PLANNED	3/4/2021	4	324	81
PLANNED	3/4/2021	3	342	114
PLANNED	3/4/2021	2	276	138
PLANNED	3/4/2021	7	1,547	221
PLANNED	3/4/2021	2	172	86
PLANNED	3/4/2021	8	624	78
PLANNED	3/4/2021	6	678	113
PLANNED	3/4/2021	80	2,880	36
PLANNED	3/4/2021	2	122	61
PLANNED	3/4/2021	17	323	19
PLANNED	3/4/2021	4	424	106
CUSTOMER REQUEST	3/4/2021	9	1,890	210
CUSTOMER REQUEST	3/4/2021	3	534	178
PLANNED	3/4/2021	1	244	244

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/4/2021	3	15	5
PLANNED	3/4/2021	2	50	25
PLANNED	3/4/2021	3	168	56
PLANNED	3/4/2021	3	39	13
PLANNED	3/4/2021	4	148	37
PLANNED	3/4/2021	12	1,140	95
PLANNED	3/4/2021	4	604	151
PLANNED	3/4/2021	2	14	7
PLANNED	3/4/2021	1	85	85
PLANNED	3/4/2021	6	1,692	282
PLANNED	3/4/2021	2	74	37
CUSTOMER REQUEST	3/4/2021	16	368	23
PLANNED	3/4/2021	114	10,830	95
PLANNED	3/4/2021	1	134	134
PLANNED	3/4/2021	5	375	75
PLANNED	3/4/2021	2	26	13
PLANNED	3/4/2021	1	59	59
PLANNED	3/4/2021	11	341	31
CUSTOMER REQUEST	3/4/2021	8	8	1
PLANNED	3/4/2021	2	168	84
PLANNED	3/4/2021	1	11	11
CUSTOMER REQUEST	3/4/2021	3	330	110
CUSTOMER REQUEST	3/4/2021	9	396	44
PLANNED	3/4/2021	7	182	26
PLANNED	3/4/2021	1	30	30
PLANNED	3/4/2021	8	168	21
PLANNED	3/4/2021	4	620	155
PLANNED	3/4/2021	12	1,056	88
PLANNED	3/4/2021	4	580	145
PLANNED	3/4/2021	25	1,725	69
PLANNED	3/4/2021	2	38	19
PLANNED	3/4/2021	1	86	86
PLANNED	3/4/2021	13	1,339	103
PLANNED	3/4/2021	4	28	7
PLANNED	3/4/2021	6	504	84
PLANNED	3/4/2021	1	1	1
PLANNED	3/4/2021	1	15	15
PLANNED	3/4/2021	5	95	19
PLANNED	3/4/2021	4	188	47
PLANNED	3/4/2021	2	272	136
PLANNED	3/4/2021	3	87	29

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/4/2021	2	22	11
PLANNED	3/4/2021	2	158	79
PLANNED	3/4/2021	8	136	17
PLANNED	3/4/2021	8	96	12
PLANNED	3/4/2021	6	126	21
PLANNED	3/4/2021	3	75	25
PLANNED	3/4/2021	1	48	48
PLANNED	3/4/2021	3	192	64
PLANNED	3/4/2021	5	440	88
PLANNED	3/4/2021	2	56	28
PLANNED	3/4/2021	1	74	74
PLANNED	3/4/2021	1	61	61
PLANNED	3/4/2021	3	33	11
PLANNED	3/4/2021	3	234	78
PLANNED	3/4/2021	3	141	47
PLANNED	3/4/2021	1	69	69
PLANNED	3/4/2021	5	65	13
PLANNED	3/4/2021	2	74	37
PLANNED	3/4/2021	2	208	104
PLANNED	3/4/2021	21	252	12
PLANNED	3/4/2021	1	70	70
PLANNED	3/4/2021	7	364	52
PLANNED	3/4/2021	6	192	32
PLANNED	3/4/2021	1	42	42
PLANNED	3/4/2021	3	324	108
PLANNED	3/4/2021	3	24	8
PLANNED	3/4/2021	1	101	101
PLANNED	3/4/2021	7	21	3
PLANNED	3/4/2021	6	336	56
PLANNED	3/4/2021	2	214	107
PLANNED	3/4/2021	1	49	49
PLANNED	3/4/2021	1	105	105
PLANNED	3/4/2021	2	108	54
PLANNED	3/4/2021	2	118	59
PLANNED	3/4/2021	8	512	64
PLANNED	3/4/2021	2	32	16
CUSTOMER REQUEST	3/4/2021	2	22	11
PLANNED	3/4/2021	6	60	10
PLANNED	3/4/2021	6	18	3
CUSTOMER REQUEST	3/4/2021	1	85	85
PLANNED	3/4/2021	2	404	202

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/4/2021	2	48	24
PLANNED	3/4/2021	2	38	19
PLANNED	3/4/2021	1	156	156
PLANNED	3/4/2021	1	72	72
PLANNED	3/4/2021	2	18	9
PLANNED	3/4/2021	11	286	26
PLANNED	3/4/2021	1	54	54
PLANNED	3/4/2021	2	132	66
PLANNED	3/4/2021	1	106	106
PLANNED	3/4/2021	4	88	22
CUSTOMER REQUEST	3/4/2021	1	212	212
PLANNED	3/4/2021	2	48	24
PLANNED	3/4/2021	7	133	19
CUSTOMER REQUEST	3/4/2021	1	75	75
PLANNED	3/4/2021	3	291	97
PLANNED	3/4/2021	2	410	205
PLANNED	3/4/2021	4	288	72
PLANNED	3/4/2021	7	2,891	413
PLANNED	3/4/2021	4	924	231
PLANNED	3/5/2021	8	914	124
PLANNED	3/5/2021	3	234	78
PLANNED	3/5/2021	17	1,258	74
CUSTOMER REQUEST	3/5/2021	1	499	499
PLANNED	3/5/2021	8	440	55
PLANNED	3/5/2021	1	20	20
PLANNED	3/5/2021	12	1,116	93
PLANNED	3/5/2021	1	207	207
PLANNED	3/5/2021	9	765	85
PLANNED	3/5/2021	3	159	53
PLANNED	3/5/2021	4	304	76
PLANNED	3/5/2021	1	351	351
CUSTOMER REQUEST	3/5/2021	13	4,017	309
PLANNED	3/5/2021	9	693	77
PLANNED	3/5/2021	8	432	54
PLANNED	3/5/2021	1	78	78
PLANNED	3/5/2021	1	38	38
PLANNED	3/5/2021	13	533	41
PLANNED	3/5/2021	9	378	42
PLANNED	3/5/2021	12	300	25
PLANNED	3/5/2021	4	392	98
PLANNED	3/5/2021	9	1,386	154

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/5/2021	2	224	112
PLANNED	3/5/2021	33	4,851	147
PLANNED	3/5/2021	1	33	33
PLANNED	3/5/2021	2	142	71
CUSTOMER REQUEST	3/5/2021	3	69	23
PLANNED	3/5/2021	3	60	20
PLANNED	3/5/2021	1	97	97
PLANNED	3/5/2021	2	78	39
PLANNED	3/5/2021	2	302	151
PLANNED	3/5/2021	4	624	156
PLANNED	3/5/2021	2	282	141
CUSTOMER REQUEST	3/5/2021	3	1,314	438
PLANNED	3/5/2021	11	253	23
PLANNED	3/5/2021	3	15	5
PLANNED	3/5/2021	1	92	92
PLANNED	3/5/2021	2	104	52
PLANNED	3/5/2021	24	1,320	55
PLANNED	3/5/2021	13	793	61
PLANNED	3/5/2021	3	156	52
PLANNED	3/5/2021	5	115	23
PLANNED	3/5/2021	8	648	81
PLANNED	3/5/2021	1	45	45
CUSTOMER REQUEST	3/5/2021	1	18	18
PLANNED	3/5/2021	12	924	77
PLANNED	3/5/2021	1	70	70
PLANNED	3/5/2021	8	56	7
PLANNED	3/5/2021	6	672	112
PLANNED	3/5/2021	1	44	44
PLANNED	3/5/2021	8	1,080	135
PLANNED	3/5/2021	6	804	134
PLANNED	3/5/2021	4	148	37
PLANNED	3/5/2021	2	180	90
PLANNED	3/5/2021	1	12	12
CUSTOMER REQUEST	3/5/2021	4	568	142
PLANNED	3/5/2021	1	15	15
PLANNED	3/5/2021	6	1,230	205
PLANNED	3/5/2021	8	1,536	192
PLANNED	3/5/2021	26	3,094	119
PLANNED	3/5/2021	18	1,854	103
CUSTOMER REQUEST	3/5/2021	1	69	69
PLANNED	3/5/2021	3	255	85

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/5/2021	1	66	66
PLANNED	3/5/2021	2	152	76
PLANNED	3/5/2021	6	78	13
PLANNED	3/5/2021	3	243	81
PLANNED	3/5/2021	1	162	162
PLANNED	3/5/2021	4	88	22
PLANNED	3/5/2021	7	392	56
PLANNED	3/5/2021	17	493	29
PLANNED	3/5/2021	5	100	20
PLANNED	3/5/2021	1	234	234
PLANNED	3/5/2021	7	553	79
PLANNED	3/5/2021	2	98	49
PLANNED	3/5/2021	4	76	19
PLANNED	3/5/2021	1	35	35
PLANNED	3/5/2021	1	59	59
PLANNED	3/5/2021	16	160	10
PLANNED	3/5/2021	1	218	218
PLANNED	3/5/2021	7	784	112
PLANNED	3/5/2021	10	1,190	119
PLANNED	3/5/2021	5	205	41
PLANNED	3/5/2021	2	42	21
PLANNED	3/5/2021	30	480	16
PLANNED	3/5/2021	4	88	22
PLANNED	3/5/2021	3	366	122
PLANNED	3/5/2021	3	96	32
PLANNED	3/5/2021	8	480	60
PLANNED	3/5/2021	3	42	14
PLANNED	3/5/2021	2	108	54
PLANNED	3/5/2021	3	51	17
PLANNED	3/5/2021	10	30	3
PLANNED	3/5/2021	2	116	58
PLANNED	3/5/2021	6	174	29
PLANNED	3/5/2021	5	150	30
PLANNED	3/5/2021	12	960	80
CUSTOMER REQUEST	3/5/2021	1	122	122
PLANNED	3/5/2021	6	168	28
PLANNED	3/6/2021	3	189	63
CUSTOMER REQUEST	3/6/2021	1	447	447
PLANNED	3/6/2021	4	388	97
PLANNED	3/6/2021	1	171	171
PLANNED	3/6/2021	1	242	242

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/6/2021	1	198	198
PLANNED	3/6/2021	2	380	190
PLANNED	3/6/2021	4	112	28
PLANNED	3/6/2021	1	163	163
PLANNED	3/6/2021	2	74	37
PLANNED	3/6/2021	13	1,118	86
PLANNED	3/6/2021	14	1,218	87
PLANNED	3/6/2021	5	340	68
CUSTOMER REQUEST	3/6/2021	1	129	129
CUSTOMER REQUEST	3/6/2021	11	176	16
PLANNED	3/7/2021	10	2,700	270
PLANNED	3/7/2021	8	720	90
PLANNED	3/7/2021	8	1,520	190
PLANNED	3/7/2021	1	52	52
PLANNED	3/7/2021	2	198	99
PLANNED	3/7/2021	1	71	71
PLANNED	3/7/2021	2	250	125
PLANNED	3/7/2021	1	112	112
PLANNED	3/7/2021	1	78	78
PLANNED	3/7/2021	2	202	101
PLANNED	3/7/2021	5	835	167
PLANNED	3/8/2021	1	209	209
PLANNED	3/8/2021	3	57	19
PLANNED	3/8/2021	2	206	108
PLANNED	3/8/2021	2	460	231
PLANNED	3/8/2021	1	61	61
PLANNED	3/8/2021	8	848	106
CUSTOMER REQUEST	3/8/2021	1	47	47
PLANNED	3/8/2021	4	430	151
PLANNED	3/8/2021	9	963	107
PLANNED	3/8/2021	5	521	119
PLANNED	3/8/2021	1	36	36
PLANNED	3/8/2021	1	119	119
PLANNED	3/8/2021	7	721	103
PLANNED	3/8/2021	9	936	104
PLANNED	3/8/2021	9	927	103
PLANNED	3/8/2021	6	408	68
PLANNED	3/8/2021	5	650	130
PLANNED	3/8/2021	3	90	30
PLANNED	3/8/2021	1	41	41
PLANNED	3/8/2021	12	432	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/8/2021	5	255	51
PLANNED	3/8/2021	10	50	5
PLANNED	3/8/2021	3	99	33
PLANNED	3/8/2021	65	6,045	93
PLANNED	3/8/2021	7	14	2
PLANNED	3/8/2021	7	322	46
PLANNED	3/8/2021	1	126	126
PLANNED	3/8/2021	8	1,176	147
PLANNED	3/8/2021	8	904	113
PLANNED	3/8/2021	3	96	32
PLANNED	3/8/2021	4	208	52
PLANNED	3/8/2021	2	92	46
PLANNED	3/8/2021	8	312	39
PLANNED	3/8/2021	14	1,330	95
PLANNED	3/8/2021	4	92	23
PLANNED	3/8/2021	18	1,740	98
PLANNED	3/8/2021	18	1,602	89
PLANNED	3/8/2021	18	1,710	95
PLANNED	3/8/2021	3	153	75
PLANNED	3/8/2021	7	525	75
PLANNED	3/8/2021	10	430	43
PLANNED	3/8/2021	2	22	11
PLANNED	3/8/2021	3	303	101
PLANNED	3/8/2021	5	195	39
PLANNED	3/8/2021	2	302	151
PLANNED	3/8/2021	12	876	73
PLANNED	3/8/2021	5	255	51
PLANNED	3/8/2021	1	87	87
PLANNED	3/8/2021	8	1,192	149
PLANNED	3/8/2021	2	150	75
CUSTOMER REQUEST	3/8/2021	13	2,262	174
PLANNED	3/8/2021	9	243	27
PLANNED	3/8/2021	8	288	36
PLANNED	3/8/2021	5	465	93
PLANNED	3/8/2021	10	250	25
PLANNED	3/8/2021	3	411	137
PLANNED	3/8/2021	2	133	79
CUSTOMER REQUEST	3/8/2021	26	1,029	159
CUSTOMER REQUEST	3/8/2021	1	388	388
PLANNED	3/8/2021	2	24	12
PLANNED	3/8/2021	5	20	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/8/2021	5	245	49
PLANNED	3/8/2021	3	204	68
PLANNED	3/8/2021	6	198	33
PLANNED	3/8/2021	4	140	35
PLANNED	3/8/2021	4	228	57
CUSTOMER REQUEST	3/8/2021	9	72	8
PLANNED	3/8/2021	2	70	35
PLANNED	3/8/2021	8	384	48
PLANNED	3/8/2021	19	2,109	111
PLANNED	3/8/2021	3	414	138
PLANNED	3/8/2021	4	144	36
PLANNED	3/8/2021	11	462	42
PLANNED	3/8/2021	1	4	4
PLANNED	3/8/2021	1	93	93
PLANNED	3/8/2021	3	273	91
PLANNED	3/8/2021	4	184	91
PLANNED	3/8/2021	1	127	127
PLANNED	3/8/2021	4	52	13
PLANNED	3/8/2021	5	775	155
PLANNED	3/8/2021	1	153	153
PLANNED	3/8/2021	2	200	100
PLANNED	3/8/2021	1	152	152
PLANNED	3/8/2021	3	117	39
PLANNED	3/8/2021	19	1,032	68
PLANNED	3/8/2021	7	203	29
PLANNED	3/8/2021	4	212	53
PLANNED	3/8/2021	1	144	144
PLANNED	3/8/2021	2	120	60
PLANNED	3/8/2021	8	1,008	126
PLANNED	3/8/2021	9	2,187	243
PLANNED	3/8/2021	6	786	131
PLANNED	3/8/2021	5	280	56
PLANNED	3/8/2021	12	1,644	137
PLANNED	3/8/2021	5	225	45
PLANNED	3/8/2021	4	176	44
PLANNED	3/8/2021	40	3,520	88
PLANNED	3/8/2021	2	284	142
PLANNED	3/8/2021	1	22	22
PLANNED	3/8/2021	2	96	48
PLANNED	3/8/2021	2	73	38
PLANNED	3/8/2021	1	40	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/8/2021	1	34	34
PLANNED	3/8/2021	4	312	78
PLANNED	3/8/2021	6	570	95
PLANNED	3/8/2021	2	292	146
PLANNED	3/8/2021	3	237	79
PLANNED	3/8/2021	4	200	50
PLANNED	3/8/2021	1	130	130
PLANNED	3/8/2021	10	130	13
PLANNED	3/8/2021	1	24	24
PLANNED	3/8/2021	7	280	40
PLANNED	3/8/2021	6	84	14
PLANNED	3/8/2021	3	96	32
PLANNED	3/8/2021	3	129	43
PLANNED	3/8/2021	1	14	14
PLANNED	3/8/2021	9	774	86
PLANNED	3/8/2021	6	414	69
PLANNED	3/8/2021	1	77	77
PLANNED	3/8/2021	6	300	50
PLANNED	3/8/2021	3	567	189
PLANNED	3/8/2021	6	432	72
PLANNED	3/8/2021	4	480	120
PLANNED	3/8/2021	5	95	19
PLANNED	3/8/2021	1	179	179
PLANNED	3/8/2021	6	996	166
PLANNED	3/8/2021	3	129	43
PLANNED	3/8/2021	1	164	164
PLANNED	3/8/2021	1	32	32
PLANNED	3/8/2021	7	1,176	180
PLANNED	3/8/2021	1	51	51
PLANNED	3/8/2021	9	567	63
PLANNED	3/8/2021	5	130	26
CUSTOMER REQUEST	3/8/2021	1	7	7
PLANNED	3/8/2021	1	33	33
PLANNED	3/8/2021	1	34	34
PLANNED	3/8/2021	7	154	22
PLANNED	3/8/2021	1	39	39
PLANNED	3/8/2021	1	150	150
PLANNED	3/8/2021	1	134	134
PLANNED	3/8/2021	4	708	177
PLANNED	3/8/2021	11	3,707	337
PLANNED	3/9/2021	1	92	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/9/2021	1	121	121
PLANNED	3/9/2021	3	108	36
PLANNED	3/9/2021	2	138	69
PLANNED	3/9/2021	8	1,256	157
PLANNED	3/9/2021	2	530	265
PLANNED	3/9/2021	2	388	194
PLANNED	3/9/2021	1	83	83
PLANNED	3/9/2021	2	302	151
PLANNED	3/9/2021	2	524	262
PLANNED	3/9/2021	8	136	17
PLANNED	3/9/2021	1	109	109
CUSTOMER REQUEST	3/9/2021	20	6,160	308
PLANNED	3/9/2021	2	32	16
PLANNED	3/9/2021	12	576	48
PLANNED	3/9/2021	17	1,360	80
PLANNED	3/9/2021	9	405	45
PLANNED	3/9/2021	8	832	104
PLANNED	3/9/2021	1	199	199
PLANNED	3/9/2021	8	560	70
CUSTOMER REQUEST	3/9/2021	31	341	11
PLANNED	3/9/2021	3	21	7
PLANNED	3/9/2021	4	352	88
PLANNED	3/9/2021	7	175	25
PLANNED	3/9/2021	1	15	15
PLANNED	3/9/2021	1	8	8
PLANNED	3/9/2021	4	240	60
PLANNED	3/9/2021	4	324	81
PLANNED	3/9/2021	4	152	38
PLANNED	3/9/2021	6	240	40
PLANNED	3/9/2021	8	800	100
PLANNED	3/9/2021	5	205	41
PLANNED	3/9/2021	1	51	51
PLANNED	3/9/2021	4	52	13
CUSTOMER REQUEST	3/9/2021	2	788	394
PLANNED	3/9/2021	16	2,240	140
PLANNED	3/9/2021	16	2,528	158
PLANNED	3/9/2021	1	335	335
PLANNED	3/9/2021	4	76	19
PLANNED	3/9/2021	11	33	3
PLANNED	3/9/2021	5	542	122
PLANNED	3/9/2021	11	869	79

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/9/2021	6	186	31
PLANNED	3/9/2021	8	632	79
PLANNED	3/9/2021	6	966	161
PLANNED	3/9/2021	2	94	47
PLANNED	3/9/2021	7	602	86
PLANNED	3/9/2021	2	108	54
PLANNED	3/9/2021	8	232	29
PLANNED	3/9/2021	6	1,170	195
PLANNED	3/9/2021	7	532	76
PLANNED	3/9/2021	2	198	99
PLANNED	3/9/2021	4	188	47
PLANNED	3/9/2021	5	235	47
PLANNED	3/9/2021	8	1,528	191
PLANNED	3/9/2021	10	1,130	113
PLANNED	3/9/2021	2	26	13
PLANNED	3/9/2021	3	105	35
CUSTOMER REQUEST	3/9/2021	16	160	10
CUSTOMER REQUEST	3/9/2021	1	258	258
PLANNED	3/9/2021	19	304	16
CUSTOMER REQUEST	3/9/2021	6	42	7
PLANNED	3/9/2021	11	770	70
PLANNED	3/9/2021	56	3,192	57
PLANNED	3/9/2021	8	272	34
PLANNED	3/9/2021	11	2,442	222
PLANNED	3/9/2021	10	10	1
PLANNED	3/9/2021	5	330	66
PLANNED	3/9/2021	3	672	224
PLANNED	3/9/2021	1	79	79
PLANNED	3/9/2021	2	250	125
PLANNED	3/9/2021	10	2,600	260
PLANNED	3/9/2021	3	342	114
PLANNED	3/9/2021	10	100	10
PLANNED	3/9/2021	3	177	59
PLANNED	3/9/2021	2	412	206
PLANNED	3/9/2021	7	119	17
CUSTOMER REQUEST	3/9/2021	1	7	7
PLANNED	3/9/2021	8	472	59
PLANNED	3/9/2021	3	196	83
PLANNED	3/9/2021	4	880	220
PLANNED	3/9/2021	1	179	179
CUSTOMER REQUEST	3/9/2021	14	1,540	110

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/9/2021	15	315	21
PLANNED	3/9/2021	4	168	42
PLANNED	3/9/2021	5	215	43
PLANNED	3/9/2021	2	125	105
CUSTOMER REQUEST	3/9/2021	10	80	8
PLANNED	3/9/2021	4	152	38
PLANNED	3/9/2021	6	246	41
PLANNED	3/9/2021	2	340	170
CUSTOMER REQUEST	3/9/2021	13	65	5
PLANNED	3/9/2021	1	57	57
PLANNED	3/9/2021	4	148	37
PLANNED	3/9/2021	3	417	139
PLANNED	3/9/2021	6	276	46
PLANNED	3/9/2021	10	220	22
PLANNED	3/9/2021	1	77	77
PLANNED	3/9/2021	33	924	28
PLANNED	3/9/2021	176	4,928	28
PLANNED	3/9/2021	8	744	93
PLANNED	3/9/2021	3	150	50
PLANNED	3/9/2021	4	340	85
PLANNED	3/9/2021	12	600	50
PLANNED	3/9/2021	1	172	172
CUSTOMER REQUEST	3/9/2021	16	688	43
PLANNED	3/9/2021	3	303	101
PLANNED	3/9/2021	4	324	81
PLANNED	3/9/2021	5	75	15
PLANNED	3/9/2021	4	376	94
PLANNED	3/9/2021	2	330	165
PLANNED	3/9/2021	10	450	45
PLANNED	3/9/2021	2	32	16
PLANNED	3/9/2021	7	189	27
PLANNED	3/9/2021	3	414	138
PLANNED	3/9/2021	2	30	15
PLANNED	3/9/2021	1	220	220
PLANNED	3/9/2021	6	1,404	234
PLANNED	3/9/2021	4	200	50
PLANNED	3/9/2021	4	104	26
PLANNED	3/9/2021	2	166	83
PLANNED	3/9/2021	10	350	35
PLANNED	3/9/2021	6	144	24
PLANNED	3/9/2021	6	102	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/9/2021	20	2,880	144
PLANNED	3/9/2021	1	59	59
PLANNED	3/9/2021	7	203	29
PLANNED	3/9/2021	12	36	3
PLANNED	3/9/2021	6	366	61
PLANNED	3/9/2021	3	417	139
PLANNED	3/9/2021	4	44	11
PLANNED	3/9/2021	2	558	279
CUSTOMER REQUEST	3/9/2021	6	77	17
PLANNED	3/9/2021	2	24	12
PLANNED	3/9/2021	3	57	19
PLANNED	3/9/2021	1	42	42
PLANNED	3/9/2021	2	72	36
PLANNED	3/9/2021	8	672	84
PLANNED	3/9/2021	11	11	1
PLANNED	3/9/2021	7	259	37
PLANNED	3/9/2021	8	440	55
PLANNED	3/9/2021	2	240	120
PLANNED	3/9/2021	7	308	44
PLANNED	3/9/2021	4	308	77
PLANNED	3/9/2021	3	138	46
PLANNED	3/9/2021	1	110	110
PLANNED	3/9/2021	1	12	12
PLANNED	3/9/2021	4	96	24
PLANNED	3/9/2021	4	124	31
PLANNED	3/9/2021	1	52	52
PLANNED	3/9/2021	2	44	22
PLANNED	3/9/2021	1	5	5
PLANNED	3/9/2021	2	200	100
PLANNED	3/9/2021	6	78	13
PLANNED	3/9/2021	1	34	34
PLANNED	3/9/2021	4	516	129
CUSTOMER REQUEST	3/9/2021	10	20	2
PLANNED	3/9/2021	4	704	176
PLANNED	3/9/2021	1	50	50
PLANNED	3/9/2021	6	762	127
PLANNED	3/9/2021	4	16	4
CUSTOMER REQUEST	3/9/2021	1	257	257
PLANNED	3/9/2021	5	270	54
PLANNED	3/9/2021	1	48	48
PLANNED	3/9/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/9/2021	2	74	37
CUSTOMER REQUEST	3/9/2021	1	157	157
CUSTOMER REQUEST	3/9/2021	1	388	388
PLANNED	3/9/2021	1	91	91
CUSTOMER REQUEST	3/9/2021	1	53	53
PLANNED	3/9/2021	3	435	145
PLANNED	3/9/2021	1	63	63
PLANNED	3/9/2021	11	1,210	110
PLANNED	3/9/2021	1	86	86
PLANNED	3/10/2021	15	4,365	291
PLANNED	3/10/2021	1	120	120
PLANNED	3/10/2021	2	208	104
PLANNED	3/10/2021	4	192	48
PLANNED	3/10/2021	1	56	56
PLANNED	3/10/2021	1	72	72
PLANNED	3/10/2021	9	396	44
PLANNED	3/10/2021	13	156	12
PLANNED	3/10/2021	9	27	3
PLANNED	3/10/2021	3	6	2
PLANNED	3/10/2021	1	79	79
PLANNED	3/10/2021	4	184	46
PLANNED	3/10/2021	8	264	33
PLANNED	3/10/2021	2	306	153
PLANNED	3/10/2021	5	215	43
PLANNED	3/10/2021	3	132	44
PLANNED	3/10/2021	1	30	30
PLANNED	3/10/2021	4	294	94
PLANNED	3/10/2021	8	680	85
PLANNED	3/10/2021	6	450	75
PLANNED	3/10/2021	14	784	56
PLANNED	3/10/2021	1	296	296
PLANNED	3/10/2021	3	18	6
PLANNED	3/10/2021	11	495	45
PLANNED	3/10/2021	4	663	168
PLANNED	3/10/2021	2	318	159
PLANNED	3/10/2021	2	300	150
PLANNED	3/10/2021	1	87	87
PLANNED	3/10/2021	10	650	65
PLANNED	3/10/2021	9	1,206	134
CUSTOMER REQUEST	3/10/2021	13	1,001	77
CUSTOMER REQUEST	3/10/2021	16	5,136	321

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/10/2021	1	153	153
PLANNED	3/10/2021	1	99	99
PLANNED	3/10/2021	1	118	118
PLANNED	3/10/2021	5	880	176
PLANNED	3/10/2021	8	640	80
PLANNED	3/10/2021	3	24	8
PLANNED	3/10/2021	4	28	7
PLANNED	3/10/2021	4	40	10
PLANNED	3/10/2021	34	4,386	129
CUSTOMER REQUEST	3/10/2021	1	86	86
PLANNED	3/10/2021	9	1,161	129
PLANNED	3/10/2021	2	36	18
PLANNED	3/10/2021	17	2,193	129
PLANNED	3/10/2021	8	1,032	129
PLANNED	3/10/2021	5	160	32
PLANNED	3/10/2021	4	156	39
PLANNED	3/10/2021	4	220	55
CUSTOMER REQUEST	3/10/2021	28	516	193
CUSTOMER REQUEST	3/10/2021	8	256	32
PLANNED	3/10/2021	7	252	36
PLANNED	3/10/2021	2	218	109
PLANNED	3/10/2021	5	825	165
PLANNED	3/10/2021	2	44	22
PLANNED	3/10/2021	11	1,144	104
PLANNED	3/10/2021	3	579	193
PLANNED	3/10/2021	8	352	44
PLANNED	3/10/2021	34	170	5
PLANNED	3/10/2021	2	48	24
PLANNED	3/10/2021	1	107	107
PLANNED	3/10/2021	1	14	14
PLANNED	3/10/2021	1	93	93
PLANNED	3/10/2021	36	2,016	56
PLANNED	3/10/2021	10	2,100	210
PLANNED	3/10/2021	1	39	39
CUSTOMER REQUEST	3/10/2021	11	297	27
PLANNED	3/10/2021	1	219	219
PLANNED	3/10/2021	2	290	145
PLANNED	3/10/2021	4	692	173
PLANNED	3/10/2021	2	196	98
PLANNED	3/10/2021	1	52	52
PLANNED	3/10/2021	6	1,008	168

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/10/2021	3	63	21
PLANNED	3/10/2021	12	2,016	168
PLANNED	3/10/2021	1	92	92
PLANNED	3/10/2021	10	2,110	211
PLANNED	3/10/2021	25	275	11
PLANNED	3/10/2021	5	705	141
CUSTOMER REQUEST	3/10/2021	8	40	5
PLANNED	3/10/2021	3	75	25
PLANNED	3/10/2021	61	7,869	129
CUSTOMER REQUEST	3/10/2021	10	160	16
PLANNED	3/10/2021	1	11	11
PLANNED	3/10/2021	8	376	47
PLANNED	3/10/2021	3	42	14
PLANNED	3/10/2021	4	56	14
PLANNED	3/10/2021	6	60	10
PLANNED	3/10/2021	4	292	73
PLANNED	3/10/2021	1	49	49
PLANNED	3/10/2021	3	387	129
PLANNED	3/10/2021	6	420	70
PLANNED	3/10/2021	18	324	18
PLANNED	3/10/2021	2	232	116
PLANNED	3/10/2021	5	330	66
PLANNED	3/10/2021	9	1,269	141
PLANNED	3/10/2021	6	366	61
CUSTOMER REQUEST	3/10/2021	28	3,472	124
PLANNED	3/10/2021	6	114	19
PLANNED	3/10/2021	2	162	81
PLANNED	3/10/2021	1	85	85
PLANNED	3/10/2021	4	460	115
PLANNED	3/10/2021	4	272	68
PLANNED	3/10/2021	34	102	3
PLANNED	3/10/2021	3	468	156
PLANNED	3/10/2021	2	325	218
PLANNED	3/10/2021	16	176	11
PLANNED	3/10/2021	4	56	14
PLANNED	3/10/2021	9	153	17
PLANNED	3/10/2021	1	7	7
PLANNED	3/10/2021	11	869	79
PLANNED	3/10/2021	12	684	57
PLANNED	3/10/2021	15	795	53
PLANNED	3/10/2021	6	120	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/10/2021	7	238	34
CUSTOMER REQUEST	3/10/2021	1	537	537
CUSTOMER REQUEST	3/10/2021	110	3,960	36
CUSTOMER REQUEST	3/10/2021	3	483	161
PLANNED	3/10/2021	16	144	9
PLANNED	3/10/2021	3	117	39
PLANNED	3/10/2021	1	12	12
PLANNED	3/10/2021	2	47	28
PLANNED	3/10/2021	8	2,136	267
PLANNED	3/10/2021	8	2,136	267
PLANNED	3/10/2021	9	2,403	267
PLANNED	3/10/2021	9	2,403	267
PLANNED	3/10/2021	7	336	48
PLANNED	3/10/2021	2	81	54
PLANNED	3/10/2021	2	30	15
PLANNED	3/10/2021	1	11	11
PLANNED	3/10/2021	3	225	75
PLANNED	3/10/2021	1	207	207
PLANNED	3/10/2021	4	132	33
PLANNED	3/10/2021	1	59	59
PLANNED	3/10/2021	1	127	127
PLANNED	3/10/2021	1	48	48
PLANNED	3/10/2021	4	64	16
PLANNED	3/10/2021	1	206	206
PLANNED	3/10/2021	2	96	48
PLANNED	3/10/2021	1	73	73
PLANNED	3/10/2021	2	306	160
PLANNED	3/10/2021	25	1,225	49
PLANNED	3/10/2021	1	158	158
PLANNED	3/10/2021	4	136	34
PLANNED	3/10/2021	7	196	28
PLANNED	3/10/2021	25	900	36
PLANNED	3/10/2021	6	522	87
PLANNED	3/10/2021	2	18	9
PLANNED	3/10/2021	3	36	12
PLANNED	3/10/2021	25	100	4
PLANNED	3/10/2021	1	37	37
PLANNED	3/10/2021	3	84	28
PLANNED	3/10/2021	2	24	12
PLANNED	3/10/2021	26	1,794	69
PLANNED	3/10/2021	8	337	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	3/10/2021	8	56	7
PLANNED	3/10/2021	11	198	18
PLANNED	3/10/2021	4	148	37
PLANNED	3/10/2021	13	143	11
PLANNED	3/10/2021	1	6	6
PLANNED	3/10/2021	6	534	89
PLANNED	3/10/2021	1	5	5
PLANNED	3/10/2021	2	172	86
CUSTOMER REQUEST	3/10/2021	1	143	143
CUSTOMER REQUEST	3/10/2021	8	152	19
CUSTOMER REQUEST	3/10/2021	1	36	36
PLANNED	3/10/2021	2	186	93
PLANNED	3/10/2021	8	928	116
PLANNED	3/10/2021	1	38	38
PLANNED	3/10/2021	1	23	23
PLANNED	3/10/2021	3	60	20
PLANNED	3/10/2021	7	1,337	272
PLANNED	3/10/2021	2	32	16
PLANNED	3/10/2021	24	4,680	195
PLANNED	3/10/2021	2	409	206
PLANNED	3/10/2021	9	18	2
CUSTOMER REQUEST	3/10/2021	1	193	193
PLANNED	3/10/2021	1	211	211
PLANNED	3/10/2021	5	90	18
CUSTOMER REQUEST	3/10/2021	1	120	120
PLANNED	3/10/2021	18	2,736	152
PLANNED	3/10/2021	1	21	21
PLANNED	3/10/2021	32	2,944	92
PLANNED	3/10/2021	4	220	55
PLANNED	3/10/2021	3	168	56
PLANNED	3/10/2021	6	198	33
PLANNED	3/10/2021	6	234	39
PLANNED	3/10/2021	6	108	18
PLANNED	3/10/2021	2	134	67
PLANNED	3/10/2021	2	56	28
PLANNED	3/10/2021	2	222	111
PLANNED	3/10/2021	9	279	31
PLANNED	3/10/2021	1	86	86
PLANNED	3/10/2021	6	420	70
PLANNED	3/10/2021	5	615	123
PLANNED	3/10/2021	1	122	122

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/10/2021	11	1,023	93
PLANNED	3/10/2021	4	1,344	336
PLANNED	3/10/2021	1	100	100
PLANNED	3/10/2021	1	52	52
PLANNED	3/10/2021	2	280	140
PLANNED	3/10/2021	1	98	98
PLANNED	3/11/2021	9	2,061	229
PLANNED	3/11/2021	2	270	135
PLANNED	3/11/2021	13	1,963	151
PLANNED	3/11/2021	1	177	177
PLANNED	3/11/2021	1	113	113
PLANNED	3/11/2021	1	44	44
PLANNED	3/11/2021	1	76	76
PLANNED	3/11/2021	2	80	40
PLANNED	3/11/2021	4	132	33
PLANNED	3/11/2021	1	83	83
PLANNED	3/11/2021	8	328	41
PLANNED	3/11/2021	1	129	129
PLANNED	3/11/2021	2	216	108
PLANNED	3/11/2021	1	50	50
PLANNED	3/11/2021	9	423	47
PLANNED	3/11/2021	9	792	88
PLANNED	3/11/2021	16	1,136	71
PLANNED	3/11/2021	4	200	50
PLANNED	3/11/2021	3	909	303
PLANNED	3/11/2021	17	1,887	111
PLANNED	3/11/2021	4	84	21
PLANNED	3/11/2021	1	114	114
PLANNED	3/11/2021	5	610	122
PLANNED	3/11/2021	2	472	236
PLANNED	3/11/2021	6	252	42
PLANNED	3/11/2021	3	132	44
PLANNED	3/11/2021	1	99	99
PLANNED	3/11/2021	4	472	118
PLANNED	3/11/2021	1	87	87
PLANNED	3/11/2021	8	1,024	128
PLANNED	3/11/2021	17	1,989	117
PLANNED	3/11/2021	2	324	162
PLANNED	3/11/2021	13	1,404	108
PLANNED	3/11/2021	3	519	173
PLANNED	3/11/2021	4	196	49

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/11/2021	10	3,120	312
CUSTOMER REQUEST	3/11/2021	7	28	4
PLANNED	3/11/2021	3	90	30
PLANNED	3/11/2021	12	1,032	86
PLANNED	3/11/2021	1	322	322
PLANNED	3/11/2021	1	27	27
CUSTOMER REQUEST	3/11/2021	5	115	23
PLANNED	3/11/2021	1	102	102
PLANNED	3/11/2021	4	612	153
PLANNED	3/11/2021	5	215	43
PLANNED	3/11/2021	4	268	67
PLANNED	3/11/2021	6	384	64
PLANNED	3/11/2021	14	2,618	187
PLANNED	3/11/2021	3	801	267
PLANNED	3/11/2021	4	508	127
PLANNED	3/11/2021	4	592	148
PLANNED	3/11/2021	3	96	32
PLANNED	3/11/2021	2	24	12
PLANNED	3/11/2021	3	30	10
PLANNED	3/11/2021	2	22	11
PLANNED	3/11/2021	6	456	76
PLANNED	3/11/2021	9	855	95
PLANNED	3/11/2021	5	145	29
PLANNED	3/11/2021	1	143	143
PLANNED	3/11/2021	7	287	41
PLANNED	3/11/2021	6	96	16
PLANNED	3/11/2021	2	134	67
PLANNED	3/11/2021	8	2,136	267
PLANNED	3/11/2021	5	80	16
PLANNED	3/11/2021	3	69	23
PLANNED	3/11/2021	2	14	7
PLANNED	3/11/2021	8	272	34
PLANNED	3/11/2021	3	114	38
PLANNED	3/11/2021	4	52	13
PLANNED	3/11/2021	1	26	26
PLANNED	3/11/2021	1	230	230
PLANNED	3/11/2021	8	160	20
CUSTOMER REQUEST	3/11/2021	3	312	104
PLANNED	3/11/2021	3	369	123
PLANNED	3/11/2021	5	235	47
CUSTOMER REQUEST	3/11/2021	1	227	227

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/11/2021	9	1,656	184
PLANNED	3/11/2021	6	384	64
PLANNED	3/11/2021	5	300	60
PLANNED	3/11/2021	7	133	19
PLANNED	3/11/2021	2	146	73
PLANNED	3/11/2021	7	7	1
PLANNED	3/11/2021	1	148	148
PLANNED	3/11/2021	4	288	72
PLANNED	3/11/2021	2	260	130
PLANNED	3/11/2021	5	25	5
PLANNED	3/11/2021	9	738	82
PLANNED	3/11/2021	22	1,078	49
PLANNED	3/11/2021	26	1,274	49
PLANNED	3/11/2021	8	936	117
PLANNED	3/11/2021	3	183	61
PLANNED	3/11/2021	8	240	30
PLANNED	3/11/2021	1	33	33
PLANNED	3/11/2021	5	200	40
PLANNED	3/11/2021	5	275	55
PLANNED	3/11/2021	4	356	89
PLANNED	3/11/2021	10	10	1
PLANNED	3/11/2021	13	390	30
PLANNED	3/11/2021	4	92	23
PLANNED	3/11/2021	8	448	56
PLANNED	3/11/2021	6	1,110	185
PLANNED	3/11/2021	2	248	124
PLANNED	3/11/2021	8	712	89
PLANNED	3/11/2021	1	36	36
PLANNED	3/11/2021	1	32	32
PLANNED	3/11/2021	4	804	201
PLANNED	3/11/2021	3	234	78
PLANNED	3/11/2021	3	273	91
PLANNED	3/11/2021	5	50	10
CUSTOMER REQUEST	3/11/2021	3	207	69
PLANNED	3/11/2021	2	282	141
PLANNED	3/11/2021	3	318	106
PLANNED	3/11/2021	6	348	58
PLANNED	3/11/2021	6	24	4
PLANNED	3/11/2021	3	75	25
PLANNED	3/11/2021	4	148	37
PLANNED	3/11/2021	5	235	47

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/11/2021	1	20	20
PLANNED	3/11/2021	2	118	59
PLANNED	3/11/2021	4	80	20
PLANNED	3/11/2021	6	114	19
PLANNED	3/11/2021	6	24	4
PLANNED	3/11/2021	3	18	6
PLANNED	3/11/2021	10	2,010	201
PLANNED	3/11/2021	6	168	28
PLANNED	3/11/2021	32	5,536	173
PLANNED	3/11/2021	2	214	107
PLANNED	3/11/2021	1	26	26
PLANNED	3/11/2021	19	722	38
PLANNED	3/11/2021	4	228	57
PLANNED	3/11/2021	7	469	67
PLANNED	3/11/2021	2	62	31
PLANNED	3/11/2021	3	21	7
PLANNED	3/11/2021	8	184	23
CUSTOMER REQUEST	3/11/2021	1	321	321
CUSTOMER REQUEST	3/11/2021	1	137	137
PLANNED	3/11/2021	1	110	110
PLANNED	3/11/2021	1	95	95
PLANNED	3/11/2021	1	90	90
PLANNED	3/11/2021	4	224	56
PLANNED	3/11/2021	1	55	55
PLANNED	3/11/2021	1	39	39
PLANNED	3/11/2021	2	434	217
PLANNED	3/11/2021	1	253	253
PLANNED	3/11/2021	1	31	31
PLANNED	3/11/2021	6	234	39
PLANNED	3/11/2021	31	527	17
PLANNED	3/11/2021	2	54	27
CUSTOMER REQUEST	3/11/2021	1	164	164
PLANNED	3/11/2021	1	269	269
PLANNED	3/11/2021	218	4,796	22
PLANNED	3/11/2021	3	321	107
PLANNED	3/11/2021	1	217	217
PLANNED	3/11/2021	2	734	367
PLANNED	3/11/2021	3	114	38
PLANNED	3/11/2021	47	8,601	183
PLANNED	3/11/2021	50	12,350	247
PLANNED	3/11/2021	5	910	182

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/11/2021	1	175	175
PLANNED	3/11/2021	29	4,002	138
PLANNED	3/11/2021	2	170	85
PLANNED	3/11/2021	31	9,083	293
PLANNED	3/11/2021	1	95	95
PLANNED	3/11/2021	13	1,482	114
PLANNED	3/11/2021	2	292	146
PLANNED	3/12/2021	1	205	205
PLANNED	3/12/2021	8	552	69
PLANNED	3/12/2021	1	72	72
PLANNED	3/12/2021	12	840	70
PLANNED	3/12/2021	1	64	64
PLANNED	3/12/2021	1	56	56
PLANNED	3/12/2021	1	75	75
PLANNED	3/12/2021	1	61	61
PLANNED	3/12/2021	1	117	117
PLANNED	3/12/2021	13	1,378	106
PLANNED	3/12/2021	8	192	24
PLANNED	3/12/2021	3	72	24
PLANNED	3/12/2021	6	270	45
PLANNED	3/12/2021	9	1,836	204
PLANNED	3/12/2021	4	800	200
PLANNED	3/12/2021	4	808	202
PLANNED	3/12/2021	2	242	121
PLANNED	3/12/2021	4	164	41
PLANNED	3/12/2021	4	292	73
PLANNED	3/12/2021	1	85	85
PLANNED	3/12/2021	3	240	80
CUSTOMER REQUEST	3/12/2021	1	283	283
PLANNED	3/12/2021	3	90	30
CUSTOMER REQUEST	3/12/2021	1	8	8
PLANNED	3/12/2021	8	1,240	155
PLANNED	3/12/2021	3	42	14
PLANNED	3/12/2021	31	9,052	292
PLANNED	3/12/2021	4	96	24
PLANNED	3/12/2021	1	83	83
PLANNED	3/12/2021	7	574	82
PLANNED	3/12/2021	5	785	157
PLANNED	3/12/2021	15	1,470	98
PLANNED	3/12/2021	64	5,120	80
CUSTOMER REQUEST	3/12/2021	2	138	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/12/2021	7	420	60
PLANNED	3/12/2021	2	142	71
PLANNED	3/12/2021	2	38	19
PLANNED	3/12/2021	2	166	83
CUSTOMER REQUEST	3/12/2021	5	30	6
PLANNED	3/12/2021	3	126	42
PLANNED	3/12/2021	4	556	139
PLANNED	3/12/2021	3	66	22
PLANNED	3/12/2021	2	332	166
PLANNED	3/12/2021	40	5,440	136
PLANNED	3/12/2021	15	885	59
PLANNED	3/12/2021	5	70	14
PLANNED	3/12/2021	4	632	158
PLANNED	3/12/2021	2	92	46
PLANNED	3/12/2021	6	648	108
PLANNED	3/12/2021	4	160	40
PLANNED	3/12/2021	10	310	31
PLANNED	3/12/2021	4	108	27
PLANNED	3/12/2021	7	420	60
PLANNED	3/12/2021	2	48	24
PLANNED	3/12/2021	13	1,300	100
PLANNED	3/12/2021	3	207	69
CUSTOMER REQUEST	3/12/2021	8	1,600	200
PLANNED	3/12/2021	1	96	96
PLANNED	3/12/2021	1	99	99
PLANNED	3/12/2021	4	668	167
PLANNED	3/12/2021	1	169	169
PLANNED	3/12/2021	6	624	104
PLANNED	3/12/2021	11	781	71
PLANNED	3/12/2021	2	36	18
PLANNED	3/12/2021	6	84	14
PLANNED	3/12/2021	2	166	83
PLANNED	3/12/2021	1	39	39
PLANNED	3/12/2021	5	65	13
CUSTOMER REQUEST	3/12/2021	81	4,860	60
PLANNED	3/12/2021	1	19	19
PLANNED	3/12/2021	8	312	39
PLANNED	3/12/2021	4	84	21
PLANNED	3/12/2021	3	75	25
PLANNED	3/12/2021	5	910	182
CUSTOMER REQUEST	3/12/2021	75	17,775	237

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/12/2021	1	66	66
PLANNED	3/12/2021	3	78	26
PLANNED	3/12/2021	14	308	22
PLANNED	3/12/2021	17	680	40
PLANNED	3/12/2021	12	1,608	134
PLANNED	3/12/2021	3	273	91
PLANNED	3/12/2021	11	264	24
CUSTOMER REQUEST	3/12/2021	4	392	98
PLANNED	3/12/2021	6	72	12
PLANNED	3/12/2021	20	700	35
PLANNED	3/12/2021	1	50	50
PLANNED	3/12/2021	1	142	142
PLANNED	3/12/2021	3	204	68
PLANNED	3/12/2021	12	408	34
PLANNED	3/12/2021	2	30	15
PLANNED	3/12/2021	3	27	9
PLANNED	3/12/2021	1	43	43
PLANNED	3/12/2021	7	112	16
PLANNED	3/12/2021	1	12	12
PLANNED	3/12/2021	137	548	4
PLANNED	3/12/2021	6	876	146
PLANNED	3/12/2021	4	76	19
PLANNED	3/12/2021	4	52	13
PLANNED	3/12/2021	14	378	27
PLANNED	3/12/2021	3	150	50
PLANNED	3/12/2021	1	8	8
PLANNED	3/12/2021	5	510	102
PLANNED	3/12/2021	7	448	64
PLANNED	3/12/2021	3	48	16
PLANNED	3/12/2021	1	21	21
PLANNED	3/12/2021	1	123	123
CUSTOMER REQUEST	3/12/2021	1	7	7
PLANNED	3/12/2021	3	201	67
PLANNED	3/12/2021	1	85	85
PLANNED	3/12/2021	1	117	117
PLANNED	3/12/2021	12	24	2
CUSTOMER REQUEST	3/12/2021	1	205	205
PLANNED	3/12/2021	13	130	10
CUSTOMER REQUEST	3/12/2021	1	9	9
PLANNED	3/12/2021	13	1,391	107
PLANNED	3/13/2021	1	172	172

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/13/2021	1	157	157
PLANNED	3/13/2021	4	204	51
PLANNED	3/13/2021	6	450	75
PLANNED	3/13/2021	1	216	216
PLANNED	3/13/2021	2	66	33
PLANNED	3/13/2021	12	3,288	274
PLANNED	3/13/2021	1	198	198
PLANNED	3/13/2021	1	8	8
CUSTOMER REQUEST	3/13/2021	17	3,570	210
PLANNED	3/13/2021	1	100	100
PLANNED	3/13/2021	2	234	117
PLANNED	3/13/2021	3	187	90
PLANNED	3/13/2021	2	208	104
PLANNED	3/13/2021	2	94	47
CUSTOMER REQUEST	3/13/2021	4	92	23
PLANNED	3/14/2021	3	621	207
CUSTOMER REQUEST	3/14/2021	35	2,835	81
PLANNED	3/14/2021	12	2,388	199
PLANNED	3/14/2021	10	1,290	129
CUSTOMER REQUEST	3/14/2021	1	190	190
PLANNED	3/14/2021	49	4,557	93
PLANNED	3/14/2021	1	7	7
PLANNED	3/14/2021	1	63	63
PLANNED	3/14/2021	2	290	145
PLANNED	3/14/2021	2	240	120
PLANNED	3/14/2021	2	264	132
PLANNED	3/15/2021	6	630	105
PLANNED	3/15/2021	2	146	73
PLANNED	3/15/2021	1	78	78
PLANNED	3/15/2021	3	111	37
PLANNED	3/15/2021	1	56	56
PLANNED	3/15/2021	13	2,093	161
PLANNED	3/15/2021	13	2,080	160
PLANNED	3/15/2021	12	1,896	158
PLANNED	3/15/2021	12	2,088	174
PLANNED	3/15/2021	20	1,780	89
PLANNED	3/15/2021	4	124	31
PLANNED	3/15/2021	10	1,700	170
PLANNED	3/15/2021	7	434	62
PLANNED	3/15/2021	4	244	61
PLANNED	3/15/2021	2	235	141

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/15/2021	4	200	50
PLANNED	3/15/2021	4	180	45
CUSTOMER REQUEST	3/15/2021	1	209	209
CUSTOMER REQUEST	3/15/2021	1	240	240
PLANNED	3/15/2021	4	176	59
PLANNED	3/15/2021	3	159	53
PLANNED	3/15/2021	2	258	129
PLANNED	3/15/2021	1	129	129
PLANNED	3/15/2021	4	904	226
PLANNED	3/15/2021	2	230	115
PLANNED	3/15/2021	3	54	18
PLANNED	3/15/2021	2	156	78
PLANNED	3/15/2021	3	507	169
PLANNED	3/15/2021	1	190	190
PLANNED	3/15/2021	1	72	72
PLANNED	3/15/2021	20	2,640	132
PLANNED	3/15/2021	19	817	43
PLANNED	3/15/2021	1	11	11
CUSTOMER REQUEST	3/15/2021	1	307	307
PLANNED	3/15/2021	1	22	22
PLANNED	3/15/2021	2	134	67
PLANNED	3/15/2021	16	1,936	121
PLANNED	3/15/2021	6	630	105
PLANNED	3/15/2021	11	473	43
PLANNED	3/15/2021	2	16	8
PLANNED	3/15/2021	7	56	8
PLANNED	3/15/2021	5	375	111
CUSTOMER REQUEST	3/15/2021	11	308	28
PLANNED	3/15/2021	7	2,135	305
PLANNED	3/15/2021	6	144	24
PLANNED	3/15/2021	3	234	78
PLANNED	3/15/2021	3	243	81
PLANNED	3/15/2021	1	79	79
PLANNED	3/15/2021	10	390	39
PLANNED	3/15/2021	7	2,814	402
PLANNED	3/15/2021	26	1,534	59
PLANNED	3/15/2021	3	141	47
PLANNED	3/15/2021	4	688	172
PLANNED	3/15/2021	4	132	33
PLANNED	3/15/2021	6	114	19
PLANNED	3/15/2021	1	77	77

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/15/2021	3	78	26
PLANNED	3/15/2021	8	680	85
PLANNED	3/15/2021	8	160	20
CUSTOMER REQUEST	3/15/2021	5	755	151
CUSTOMER REQUEST	3/15/2021	33	13,860	420
PLANNED	3/15/2021	4	56	14
PLANNED	3/15/2021	18	2,934	163
PLANNED	3/15/2021	5	340	68
PLANNED	3/15/2021	3	279	93
PLANNED	3/15/2021	4	112	28
PLANNED	3/15/2021	10	390	39
PLANNED	3/15/2021	6	102	17
PLANNED	3/15/2021	2	110	55
PLANNED	3/15/2021	14	3,150	225
PLANNED	3/15/2021	10	80	8
PLANNED	3/15/2021	2	22	11
PLANNED	3/15/2021	10	1,150	115
PLANNED	3/15/2021	15	1,245	83
PLANNED	3/15/2021	5	275	55
PLANNED	3/15/2021	7	581	83
PLANNED	3/15/2021	10	840	84
PLANNED	3/15/2021	8	744	93
PLANNED	3/15/2021	9	783	87
PLANNED	3/15/2021	9	882	98
PLANNED	3/15/2021	7	77	11
PLANNED	3/15/2021	6	66	11
PLANNED	3/15/2021	3	66	22
PLANNED	3/15/2021	5	85	17
PLANNED	3/15/2021	50	1,850	37
PLANNED	3/15/2021	7	1,631	233
PLANNED	3/15/2021	2	416	208
PLANNED	3/15/2021	4	100	25
CUSTOMER REQUEST	3/15/2021	7	644	92
PLANNED	3/15/2021	1	54	54
PLANNED	3/15/2021	1	27	27
PLANNED	3/15/2021	2	190	95
PLANNED	3/15/2021	3	351	117
PLANNED	3/15/2021	3	156	52
PLANNED	3/15/2021	4	48	12
PLANNED	3/15/2021	2	78	39
PLANNED	3/15/2021	7	98	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/15/2021	4	156	39
PLANNED	3/15/2021	2	32	16
PLANNED	3/15/2021	4	88	22
PLANNED	3/15/2021	27	2,430	90
PLANNED	3/15/2021	4	480	120
PLANNED	3/15/2021	4	128	32
PLANNED	3/15/2021	3	426	205
PLANNED	3/15/2021	10	3,020	302
PLANNED	3/15/2021	3	153	51
PLANNED	3/15/2021	6	750	125
PLANNED	3/15/2021	6	852	142
PLANNED	3/15/2021	2	8	4
PLANNED	3/15/2021	7	105	15
CUSTOMER REQUEST	3/15/2021	1	36	36
PLANNED	3/15/2021	3	21	7
PLANNED	3/15/2021	1	140	140
PLANNED	3/15/2021	31	1,209	39
PLANNED	3/15/2021	2	178	89
PLANNED	3/15/2021	7	413	59
CUSTOMER REQUEST	3/15/2021	1	34	34
PLANNED	3/15/2021	12	1,104	92
PLANNED	3/15/2021	4	124	31
PLANNED	3/15/2021	5	905	181
PLANNED	3/15/2021	1	61	61
PLANNED	3/15/2021	57	8,778	154
PLANNED	3/15/2021	4	16	4
PLANNED	3/15/2021	4	104	26
PLANNED	3/15/2021	1	79	79
PLANNED	3/15/2021	1	101	101
PLANNED	3/15/2021	1	52	52
PLANNED	3/15/2021	5	50	10
PLANNED	3/15/2021	3	228	76
PLANNED	3/15/2021	5	300	60
PLANNED	3/15/2021	2	186	93
PLANNED	3/15/2021	8	176	22
PLANNED	3/15/2021	4	356	89
PLANNED	3/15/2021	4	272	68
PLANNED	3/15/2021	7	119	17
PLANNED	3/15/2021	6	126	21
PLANNED	3/15/2021	8	232	29
PLANNED	3/15/2021	4	136	34

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/15/2021	1	96	96
CUSTOMER REQUEST	3/15/2021	1	97	97
PLANNED	3/15/2021	1	32	32
PLANNED	3/15/2021	5	125	25
PLANNED	3/15/2021	4	224	56
PLANNED	3/15/2021	23	1,656	72
PLANNED	3/15/2021	3	27	9
PLANNED	3/15/2021	1	107	107
PLANNED	3/15/2021	6	672	112
PLANNED	3/15/2021	1	3	3
PLANNED	3/15/2021	1	112	112
PLANNED	3/16/2021	5	385	77
PLANNED	3/16/2021	13	793	61
PLANNED	3/16/2021	1	157	157
PLANNED	3/16/2021	4	384	96
PLANNED	3/16/2021	1	160	160
PLANNED	3/16/2021	1	164	164
PLANNED	3/16/2021	4	100	25
PLANNED	3/16/2021	1	77	77
CUSTOMER REQUEST	3/16/2021	1	232	232
PLANNED	3/16/2021	8	240	30
CUSTOMER REQUEST	3/16/2021	9	369	41
PLANNED	3/16/2021	7	2,409	438
PLANNED	3/16/2021	3	232	95
PLANNED	3/16/2021	3	237	134
PLANNED	3/16/2021	1	45	45
PLANNED	3/16/2021	8	448	56
PLANNED	3/16/2021	4	64	16
PLANNED	3/16/2021	2	237	158
PLANNED	3/16/2021	11	187	17
PLANNED	3/16/2021	2	374	187
PLANNED	3/16/2021	3	75	25
CUSTOMER REQUEST	3/16/2021	8	112	14
PLANNED	3/16/2021	12	4,284	357
PLANNED	3/16/2021	8	2,256	282
PLANNED	3/16/2021	7	1,981	283
PLANNED	3/16/2021	5	1,415	283
CUSTOMER REQUEST	3/16/2021	1	278	278
PLANNED	3/16/2021	4	288	72
CUSTOMER REQUEST	3/16/2021	12	1,504	366
PLANNED	3/16/2021	3	30	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/16/2021	7	1,610	230
PLANNED	3/16/2021	1	63	63
PLANNED	3/16/2021	12	432	36
PLANNED	3/16/2021	14	840	60
PLANNED	3/16/2021	5	120	24
PLANNED	3/16/2021	5	790	158
PLANNED	3/16/2021	5	95	19
PLANNED	3/16/2021	2	68	34
PLANNED	3/16/2021	4	84	21
PLANNED	3/16/2021	3	66	22
PLANNED	3/16/2021	5	600	120
PLANNED	3/16/2021	8	424	53
PLANNED	3/16/2021	7	77	11
PLANNED	3/16/2021	2	82	41
PLANNED	3/16/2021	8	64	8
PLANNED	3/16/2021	5	800	160
PLANNED	3/16/2021	4	132	33
PLANNED	3/16/2021	3	120	40
PLANNED	3/16/2021	4	144	36
PLANNED	3/16/2021	4	464	116
PLANNED	3/16/2021	4	144	36
PLANNED	3/16/2021	1	93	93
PLANNED	3/16/2021	4	28	7
PLANNED	3/16/2021	6	120	20
PLANNED	3/16/2021	2	8	4
PLANNED	3/16/2021	24	2,736	114
PLANNED	3/16/2021	5	95	19
CUSTOMER REQUEST	3/16/2021	2	250	125
PLANNED	3/16/2021	10	2,010	201
PLANNED	3/16/2021	1	63	63
PLANNED	3/16/2021	2	320	160
PLANNED	3/16/2021	3	117	39
PLANNED	3/16/2021	11	1,034	94
PLANNED	3/16/2021	4	56	14
PLANNED	3/16/2021	24	2,472	103
PLANNED	3/16/2021	24	2,472	103
PLANNED	3/16/2021	2	270	135
PLANNED	3/16/2021	1	103	103
PLANNED	3/16/2021	15	1,515	101
PLANNED	3/16/2021	2	60	30
PLANNED	3/16/2021	9	1,008	112

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/16/2021	2	54	27
PLANNED	3/16/2021	3	42	14
CUSTOMER REQUEST	3/16/2021	8	64	8
PLANNED	3/16/2021	1	113	113
PLANNED	3/16/2021	10	1,210	121
PLANNED	3/16/2021	2	174	87
PLANNED	3/16/2021	6	948	158
PLANNED	3/16/2021	4	180	45
PLANNED	3/16/2021	2	340	170
PLANNED	3/16/2021	2	1,920	960
PLANNED	3/16/2021	3	66	22
PLANNED	3/16/2021	3	108	36
PLANNED	3/16/2021	3	69	23
PLANNED	3/16/2021	2	92	46
PLANNED	3/16/2021	3	268	141
PLANNED	3/16/2021	6	120	20
PLANNED	3/16/2021	4	28	7
PLANNED	3/16/2021	4	752	188
PLANNED	3/16/2021	4	68	17
PLANNED	3/16/2021	1	127	127
PLANNED	3/16/2021	5	70	14
PLANNED	3/16/2021	3	54	18
PLANNED	3/16/2021	1	4	4
PLANNED	3/16/2021	7	1,197	171
PLANNED	3/16/2021	15	2,385	159
PLANNED	3/16/2021	12	1,764	147
PLANNED	3/16/2021	4	160	40
PLANNED	3/16/2021	9	270	30
PLANNED	3/16/2021	23	1,909	83
CUSTOMER REQUEST	3/16/2021	1	281	281
PLANNED	3/16/2021	8	936	117
PLANNED	3/16/2021	8	1,048	131
PLANNED	3/16/2021	10	2,090	209
CUSTOMER REQUEST	3/16/2021	8	48	6
PLANNED	3/16/2021	4	76	19
PLANNED	3/16/2021	3	111	37
PLANNED	3/16/2021	6	1,326	221
PLANNED	3/16/2021	2	116	58
PLANNED	3/16/2021	8	1,000	125
PLANNED	3/16/2021	11	968	88
PLANNED	3/16/2021	64	3,840	60

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/16/2021	2	1,756	878
PLANNED	3/16/2021	4	232	58
PLANNED	3/16/2021	9	558	62
PLANNED	3/16/2021	4	468	117
PLANNED	3/16/2021	3	54	18
PLANNED	3/16/2021	4	464	116
PLANNED	3/16/2021	1	207	207
PLANNED	3/16/2021	5	380	84
PLANNED	3/16/2021	3	141	47
PLANNED	3/16/2021	2	18	9
PLANNED	3/16/2021	2	108	54
PLANNED	3/16/2021	1	76	76
PLANNED	3/16/2021	1	1	1
PLANNED	3/16/2021	2	90	45
PLANNED	3/16/2021	4	172	43
PLANNED	3/16/2021	5	220	44
PLANNED	3/16/2021	6	282	47
PLANNED	3/16/2021	1	66	66
PLANNED	3/16/2021	4	284	71
PLANNED	3/16/2021	4	256	64
PLANNED	3/16/2021	4	92	23
CUSTOMER REQUEST	3/16/2021	9	153	17
PLANNED	3/16/2021	2	212	106
PLANNED	3/16/2021	1	50	50
PLANNED	3/16/2021	5	120	24
PLANNED	3/16/2021	4	272	68
PLANNED	3/16/2021	7	147	21
PLANNED	3/16/2021	1	54	54
PLANNED	3/16/2021	2	120	60
PLANNED	3/16/2021	1	209	209
PLANNED	3/16/2021	3	336	112
PLANNED	3/16/2021	3	138	46
PLANNED	3/16/2021	4	116	29
PLANNED	3/16/2021	7	847	121
PLANNED	3/16/2021	2	138	69
PLANNED	3/16/2021	1	130	130
PLANNED	3/16/2021	1	755	755
PLANNED	3/16/2021	5	435	87
PLANNED	3/16/2021	3	207	69
PLANNED	3/16/2021	5	220	44
PLANNED	3/16/2021	3	51	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/16/2021	4	68	17
PLANNED	3/16/2021	5	85	17
PLANNED	3/16/2021	5	260	52
CUSTOMER REQUEST	3/16/2021	13	1,131	87
PLANNED	3/16/2021	4	56	14
CUSTOMER REQUEST	3/16/2021	12	72	6
PLANNED	3/16/2021	8	264	33
PLANNED	3/16/2021	1	4	4
PLANNED	3/16/2021	1	65	65
PLANNED	3/16/2021	2	92	46
PLANNED	3/16/2021	11	451	41
PLANNED	3/16/2021	4	176	44
PLANNED	3/16/2021	2	34	17
PLANNED	3/16/2021	5	1,095	219
PLANNED	3/16/2021	3	354	118
PLANNED	3/16/2021	8	928	116
CUSTOMER REQUEST	3/16/2021	40	12,600	315
PLANNED	3/16/2021	7	861	123
PLANNED	3/16/2021	2	138	69
PLANNED	3/17/2021	3	471	157
PLANNED	3/17/2021	1	19	19
PLANNED	3/17/2021	1	233	233
PLANNED	3/17/2021	1	146	146
PLANNED	3/17/2021	1	20	20
PLANNED	3/17/2021	17	2,652	156
PLANNED	3/17/2021	2	92	46
PLANNED	3/17/2021	7	210	30
PLANNED	3/17/2021	4	168	42
PLANNED	3/17/2021	1	187	187
PLANNED	3/17/2021	2	232	116
PLANNED	3/17/2021	3	78	26
PLANNED	3/17/2021	1	303	303
PLANNED	3/17/2021	5	380	76
PLANNED	3/17/2021	2	90	45
PLANNED	3/17/2021	1	175	175
PLANNED	3/17/2021	1	47	47
PLANNED	3/17/2021	12	984	82
PLANNED	3/17/2021	1	119	119
PLANNED	3/17/2021	6	498	83
PLANNED	3/17/2021	23	3,128	136
PLANNED	3/17/2021	4	72	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/17/2021	2	176	88
PLANNED	3/17/2021	3	117	39
PLANNED	3/17/2021	6	1,320	220
PLANNED	3/17/2021	1	135	135
PLANNED	3/17/2021	7	770	110
PLANNED	3/17/2021	2	210	108
PLANNED	3/17/2021	4	500	167
PLANNED	3/17/2021	1	84	84
PLANNED	3/17/2021	4	132	33
CUSTOMER REQUEST	3/17/2021	1	151	151
PLANNED	3/17/2021	2	82	41
PLANNED	3/17/2021	1	79	79
PLANNED	3/17/2021	1	206	206
PLANNED	3/17/2021	10	1,680	168
PLANNED	3/17/2021	4	104	26
PLANNED	3/17/2021	3	57	19
PLANNED	3/17/2021	4	148	37
PLANNED	3/17/2021	8	1,168	146
PLANNED	3/17/2021	7	1,099	157
PLANNED	3/17/2021	8	1,328	166
PLANNED	3/17/2021	3	201	67
PLANNED	3/17/2021	4	364	91
PLANNED	3/17/2021	12	900	75
PLANNED	3/17/2021	2	242	121
PLANNED	3/17/2021	25	750	30
PLANNED	3/17/2021	5	554	124
PLANNED	3/17/2021	5	460	92
PLANNED	3/17/2021	21	21	1
PLANNED	3/17/2021	5	705	141
PLANNED	3/17/2021	1	35	35
CUSTOMER REQUEST	3/17/2021	5	10	2
CUSTOMER REQUEST	3/17/2021	1	40	40
PLANNED	3/17/2021	2	140	70
PLANNED	3/17/2021	2	318	159
PLANNED	3/17/2021	4	92	23
PLANNED	3/17/2021	1	60	60
PLANNED	3/17/2021	4	168	42
CUSTOMER REQUEST	3/17/2021	2	276	138
PLANNED	3/17/2021	1	60	60
PLANNED	3/17/2021	63	3,717	59
PLANNED	3/17/2021	5	65	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/17/2021	8	96	12
PLANNED	3/17/2021	4	124	31
PLANNED	3/17/2021	4	212	53
PLANNED	3/17/2021	2	40	20
PLANNED	3/17/2021	2	76	38
PLANNED	3/17/2021	4	716	179
PLANNED	3/17/2021	2	148	74
PLANNED	3/17/2021	17	34	2
CUSTOMER REQUEST	3/17/2021	17	646	38
PLANNED	3/17/2021	7	392	56
PLANNED	3/17/2021	3	69	23
PLANNED	3/17/2021	8	224	28
PLANNED	3/17/2021	3	51	17
PLANNED	3/17/2021	12	624	52
PLANNED	3/17/2021	3	141	47
PLANNED	3/17/2021	8	464	58
PLANNED	3/17/2021	7	854	122
PLANNED	3/17/2021	1	71	71
PLANNED	3/17/2021	3	663	221
PLANNED	3/17/2021	6	138	23
PLANNED	3/17/2021	7	63	9
PLANNED	3/17/2021	2	66	33
PLANNED	3/17/2021	2	58	29
PLANNED	3/17/2021	5	400	80
PLANNED	3/17/2021	4	400	100
PLANNED	3/17/2021	1	49	49
PLANNED	3/17/2021	2	156	78
PLANNED	3/17/2021	5	150	30
PLANNED	3/17/2021	1	285	285
CUSTOMER REQUEST	3/17/2021	1	197	197
PLANNED	3/17/2021	7	196	28
PLANNED	3/17/2021	6	1,020	170
PLANNED	3/17/2021	1	22	22
PLANNED	3/17/2021	8	64	8
PLANNED	3/17/2021	5	80	16
PLANNED	3/17/2021	2	36	18
PLANNED	3/17/2021	1	9	9
PLANNED	3/17/2021	8	1,416	177
PLANNED	3/17/2021	3	30	10
PLANNED	3/17/2021	3	90	30
PLANNED	3/17/2021	2	26	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/17/2021	6	240	40
PLANNED	3/17/2021	9	639	71
PLANNED	3/17/2021	1	61	61
PLANNED	3/17/2021	1	61	61
PLANNED	3/17/2021	2	40	20
CUSTOMER REQUEST	3/17/2021	4	316	79
PLANNED	3/17/2021	3	339	113
PLANNED	3/17/2021	8	264	33
PLANNED	3/17/2021	5	635	127
CUSTOMER REQUEST	3/17/2021	23	483	21
PLANNED	3/17/2021	6	1,944	324
PLANNED	3/17/2021	7	98	14
PLANNED	3/17/2021	5	60	12
PLANNED	3/17/2021	3	3	1
PLANNED	3/17/2021	4	48	12
PLANNED	3/17/2021	2	52	26
PLANNED	3/17/2021	2	202	101
CUSTOMER REQUEST	3/17/2021	1	103	103
PLANNED	3/17/2021	2	98	49
PLANNED	3/17/2021	5	75	15
PLANNED	3/17/2021	10	330	33
PLANNED	3/17/2021	3	129	43
PLANNED	3/17/2021	2	52	26
PLANNED	3/17/2021	1	15	15
PLANNED	3/17/2021	2	170	85
PLANNED	3/17/2021	4	104	26
PLANNED	3/17/2021	7	420	60
PLANNED	3/17/2021	4	84	21
PLANNED	3/17/2021	1	106	106
PLANNED	3/17/2021	6	990	165
PLANNED	3/17/2021	2	204	102
PLANNED	3/17/2021	1	159	159
PLANNED	3/17/2021	1	15	15
PLANNED	3/17/2021	3	99	33
PLANNED	3/17/2021	3	213	82
PLANNED	3/17/2021	2	64	32
PLANNED	3/17/2021	3	108	36
PLANNED	3/17/2021	4	56	14
PLANNED	3/17/2021	2	118	59
PLANNED	3/17/2021	4	84	21
PLANNED	3/17/2021	2	6	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/17/2021	2	140	70
PLANNED	3/17/2021	1	1	1
PLANNED	3/17/2021	3	517	201
PLANNED	3/17/2021	4	156	39
PLANNED	3/17/2021	13	494	38
PLANNED	3/17/2021	4	72	18
PLANNED	3/17/2021	2	142	71
PLANNED	3/17/2021	1	24	24
PLANNED	3/17/2021	1	56	56
PLANNED	3/17/2021	2	260	130
PLANNED	3/17/2021	9	175	61
PLANNED	3/17/2021	2	50	25
PLANNED	3/17/2021	6	882	147
PLANNED	3/17/2021	2	244	122
PLANNED	3/17/2021	4	32	8
PLANNED	3/17/2021	14	490	35
PLANNED	3/17/2021	3	39	13
PLANNED	3/17/2021	7	749	107
PLANNED	3/17/2021	10	360	36
PLANNED	3/17/2021	4	200	50
PLANNED	3/17/2021	1	94	94
PLANNED	3/17/2021	7	378	54
PLANNED	3/17/2021	1	17	17
PLANNED	3/17/2021	1	12	12
PLANNED	3/17/2021	1	14	14
PLANNED	3/17/2021	1	34	34
PLANNED	3/17/2021	6	144	24
PLANNED	3/17/2021	1	61	61
PLANNED	3/17/2021	1	53	53
PLANNED	3/17/2021	28	700	25
PLANNED	3/17/2021	1	63	63
PLANNED	3/17/2021	1	65	65
PLANNED	3/17/2021	1	88	88
PLANNED	3/17/2021	25	10,625	425
PLANNED	3/17/2021	2	58	29
PLANNED	3/17/2021	1	81	81
PLANNED	3/17/2021	1	233	233
PLANNED	3/18/2021	3	477	159
PLANNED	3/18/2021	4	212	53
PLANNED	3/18/2021	12	660	55
PLANNED	3/18/2021	13	1,014	78

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	3/18/2021	13	520	40
PLANNED	3/18/2021	3	540	180
PLANNED	3/18/2021	1	45	45
PLANNED	3/18/2021	4	328	82
PLANNED	3/18/2021	1	291	291
PLANNED	3/18/2021	2	72	36
PLANNED	3/18/2021	3	123	41
PLANNED	3/18/2021	7	1,001	143
PLANNED	3/18/2021	6	852	142
PLANNED	3/18/2021	7	1,617	231
PLANNED	3/18/2021	2	210	131
PLANNED	3/18/2021	1	138	138
PLANNED	3/18/2021	13	312	24
PLANNED	3/18/2021	4	112	28
PLANNED	3/18/2021	10	390	39
PLANNED	3/18/2021	3	183	74
PLANNED	3/18/2021	4	828	207
PLANNED	3/18/2021	1	37	37
PLANNED	3/18/2021	2	232	116
PLANNED	3/18/2021	1	13	13
PLANNED	3/18/2021	3	114	38
PLANNED	3/18/2021	4	88	22
PLANNED	3/18/2021	1	87	87
PLANNED	3/18/2021	4	344	86
PLANNED	3/18/2021	10	1,530	153
PLANNED	3/18/2021	2	96	48
PLANNED	3/18/2021	5	20	4
PLANNED	3/18/2021	2	126	63
PLANNED	3/18/2021	3	300	100
PLANNED	3/18/2021	7	1,029	147
PLANNED	3/18/2021	3	408	136
PLANNED	3/18/2021	1	15	15
CUSTOMER REQUEST	3/18/2021	8	592	74
PLANNED	3/18/2021	1	28	28
PLANNED	3/18/2021	4	144	36
PLANNED	3/18/2021	1	73	73
PLANNED	3/18/2021	7	1,141	163
PLANNED	3/18/2021	3	45	15
PLANNED	3/18/2021	6	594	99
CUSTOMER REQUEST	3/18/2021	56	11,312	202
PLANNED	3/18/2021	2	174	87

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/18/2021	7	126	18
PLANNED	3/18/2021	11	946	86
PLANNED	3/18/2021	6	1,104	184
CUSTOMER REQUEST	3/18/2021	46	2,760	60
PLANNED	3/18/2021	12	1,116	93
PLANNED	3/18/2021	3	636	212
PLANNED	3/18/2021	2	236	118
PLANNED	3/18/2021	5	380	76
PLANNED	3/18/2021	4	716	179
PLANNED	3/18/2021	1	21	21
CUSTOMER REQUEST	3/18/2021	28	924	33
PLANNED	3/18/2021	9	963	107
PLANNED	3/18/2021	11	297	27
PLANNED	3/18/2021	2	150	75
PLANNED	3/18/2021	2	18	9
PLANNED	3/18/2021	20	1,340	67
PLANNED	3/18/2021	4	152	38
PLANNED	3/18/2021	1	28	28
PLANNED	3/18/2021	1	24	24
PLANNED	3/18/2021	1	19	19
PLANNED	3/18/2021	4	44	11
PLANNED	3/18/2021	1	38	38
PLANNED	3/18/2021	6	216	36
PLANNED	3/18/2021	1	63	63
PLANNED	3/18/2021	252	9,828	39
PLANNED	3/18/2021	1	89	89
PLANNED	3/18/2021	1	26	26
PLANNED	3/18/2021	18	702	39
PLANNED	3/18/2021	16	640	40
PLANNED	3/18/2021	4	104	26
PLANNED	3/18/2021	3	42	14
PLANNED	3/18/2021	4	172	43
PLANNED	3/18/2021	11	1,727	157
PLANNED	3/18/2021	5	150	30
PLANNED	3/18/2021	4	380	95
PLANNED	3/18/2021	6	348	58
PLANNED	3/18/2021	6	66	11
PLANNED	3/18/2021	8	1,296	162
PLANNED	3/18/2021	1	36	36
PLANNED	3/18/2021	2	208	104
PLANNED	3/18/2021	3	69	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/18/2021	4	108	27
PLANNED	3/18/2021	13	1,326	102
PLANNED	3/18/2021	2	40	20
PLANNED	3/18/2021	7	756	108
PLANNED	3/18/2021	6	366	61
CUSTOMER REQUEST	3/18/2021	5	815	163
PLANNED	3/18/2021	9	1,215	135
PLANNED	3/18/2021	3	264	88
PLANNED	3/18/2021	4	120	30
PLANNED	3/18/2021	3	42	14
PLANNED	3/18/2021	1	78	78
PLANNED	3/18/2021	6	288	48
PLANNED	3/18/2021	1	86	86
PLANNED	3/18/2021	5	85	17
PLANNED	3/18/2021	3	33	11
PLANNED	3/18/2021	2	72	114
PLANNED	3/18/2021	9	1,170	130
PLANNED	3/18/2021	2	26	13
PLANNED	3/18/2021	2	34	17
PLANNED	3/18/2021	3	87	29
PLANNED	3/18/2021	2	68	34
PLANNED	3/18/2021	4	236	59
PLANNED	3/18/2021	5	140	28
PLANNED	3/18/2021	6	360	60
PLANNED	3/18/2021	5	40	8
PLANNED	3/18/2021	8	304	38
PLANNED	3/18/2021	34	10,132	298
PLANNED	3/18/2021	3	366	122
CUSTOMER REQUEST	3/18/2021	1	507	507
PLANNED	3/18/2021	6	814	261
PLANNED	3/18/2021	4	64	16
PLANNED	3/18/2021	15	330	22
PLANNED	3/18/2021	3	207	69
PLANNED	3/18/2021	8	224	28
PLANNED	3/18/2021	3	111	37
PLANNED	3/18/2021	1	91	91
PLANNED	3/18/2021	2	148	74
PLANNED	3/18/2021	4	136	61
PLANNED	3/18/2021	3	261	87
PLANNED	3/18/2021	2	196	98
PLANNED	3/18/2021	3	195	65

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/18/2021	8	968	121
PLANNED	3/18/2021	1	75	75
PLANNED	3/18/2021	4	88	22
PLANNED	3/18/2021	12	1,680	140
PLANNED	3/18/2021	25	2,700	108
PLANNED	3/18/2021	4	44	11
PLANNED	3/18/2021	4	8	2
PLANNED	3/18/2021	3	39	13
PLANNED	3/18/2021	1	76	76
PLANNED	3/18/2021	6	432	72
PLANNED	3/18/2021	4	60	15
PLANNED	3/18/2021	1	74	74
PLANNED	3/18/2021	5	145	29
PLANNED	3/18/2021	10	210	21
PLANNED	3/18/2021	2	38	19
PLANNED	3/18/2021	4	92	23
PLANNED	3/18/2021	4	56	14
CUSTOMER REQUEST	3/18/2021	1	232	232
PLANNED	3/18/2021	6	24	4
PLANNED	3/18/2021	1	114	114
PLANNED	3/18/2021	1	59	59
PLANNED	3/18/2021	8	64	8
PLANNED	3/18/2021	1	65	65
PLANNED	3/18/2021	3	618	206
PLANNED	3/18/2021	8	2,296	287
PLANNED	3/18/2021	1	227	227
CUSTOMER REQUEST	3/18/2021	33	5,676	172
PLANNED	3/18/2021	1	18	18
PLANNED	3/18/2021	5	215	43
PLANNED	3/18/2021	1	385	385
PLANNED	3/18/2021	2	270	135
PLANNED	3/19/2021	1	74	74
PLANNED	3/19/2021	16	32	2
PLANNED	3/19/2021	17	2,397	141
PLANNED	3/19/2021	8	952	119
PLANNED	3/19/2021	10	1,020	102
PLANNED	3/19/2021	5	245	49
PLANNED	3/19/2021	10	1,160	116
PLANNED	3/19/2021	2	30	15
PLANNED	3/19/2021	3	66	22
PLANNED	3/19/2021	2	62	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/19/2021	4	128	32
PLANNED	3/19/2021	9	243	27
PLANNED	3/19/2021	2	100	50
PLANNED	3/19/2021	3	129	43
CUSTOMER REQUEST	3/19/2021	75	25,650	342
PLANNED	3/19/2021	5	1,765	353
PLANNED	3/19/2021	3	324	108
PLANNED	3/19/2021	4	528	132
PLANNED	3/19/2021	4	80	20
PLANNED	3/19/2021	5	260	52
PLANNED	3/19/2021	21	840	40
PLANNED	3/19/2021	13	117	9
PLANNED	3/19/2021	4	104	26
PLANNED	3/19/2021	1	51	51
PLANNED	3/19/2021	7	826	118
PLANNED	3/19/2021	4	112	28
CUSTOMER REQUEST	3/19/2021	8	752	94
PLANNED	3/19/2021	2	202	101
PLANNED	3/19/2021	1	69	69
PLANNED	3/19/2021	1	156	156
PLANNED	3/19/2021	5	185	37
PLANNED	3/19/2021	2	94	47
PLANNED	3/19/2021	6	144	24
PLANNED	3/19/2021	5	351	93
PLANNED	3/19/2021	11	330	30
PLANNED	3/19/2021	4	188	47
PLANNED	3/19/2021	1	334	334
PLANNED	3/19/2021	18	1,368	76
PLANNED	3/19/2021	1	26	26
PLANNED	3/19/2021	8	368	46
PLANNED	3/19/2021	2	242	141
PLANNED	3/19/2021	4	128	32
PLANNED	3/19/2021	5	365	73
PLANNED	3/19/2021	15	270	18
PLANNED	3/19/2021	22	3,058	139
PLANNED	3/19/2021	3	117	39
PLANNED	3/19/2021	2	66	33
PLANNED	3/19/2021	6	1,014	169
PLANNED	3/19/2021	6	1,626	271
PLANNED	3/19/2021	10	5,010	501
PLANNED	3/19/2021	9	324	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/19/2021	5	65	13
PLANNED	3/19/2021	1	132	132
PLANNED	3/19/2021	8	1,488	186
PLANNED	3/19/2021	8	160	20
PLANNED	3/19/2021	6	60	10
PLANNED	3/19/2021	8	608	76
PLANNED	3/19/2021	1	224	224
CUSTOMER REQUEST	3/19/2021	10	960	96
PLANNED	3/19/2021	11	781	71
PLANNED	3/19/2021	2	26	13
PLANNED	3/19/2021	3	135	45
PLANNED	3/19/2021	1	32	32
PLANNED	3/19/2021	1	24	24
PLANNED	3/19/2021	21	504	24
PLANNED	3/19/2021	4	56	14
PLANNED	3/19/2021	7	168	24
PLANNED	3/19/2021	12	768	64
PLANNED	3/19/2021	11	418	38
PLANNED	3/19/2021	1	14	14
PLANNED	3/19/2021	5	415	83
PLANNED	3/19/2021	19	1,577	83
PLANNED	3/19/2021	5	75	15
PLANNED	3/19/2021	4	32	8
PLANNED	3/19/2021	1	13	13
PLANNED	3/19/2021	2	14	7
PLANNED	3/19/2021	2	34	17
PLANNED	3/19/2021	4	104	26
PLANNED	3/19/2021	5	255	51
PLANNED	3/19/2021	4	168	42
CUSTOMER REQUEST	3/19/2021	7	105	15
PLANNED	3/19/2021	4	48	12
PLANNED	3/19/2021	2	166	83
PLANNED	3/19/2021	4	100	25
PLANNED	3/19/2021	11	1,518	138
PLANNED	3/19/2021	2	2	1
PLANNED	3/19/2021	14	1,260	90
CUSTOMER REQUEST	3/19/2021	9	405	45
PLANNED	3/19/2021	5	50	10
PLANNED	3/19/2021	4	44	11
PLANNED	3/19/2021	2	44	22
PLANNED	3/19/2021	4	100	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/19/2021	4	32	8
PLANNED	3/19/2021	2	28	14
PLANNED	3/19/2021	3	456	152
PLANNED	3/19/2021	1	76	76
CUSTOMER REQUEST	3/19/2021	12	168	14
CUSTOMER REQUEST	3/19/2021	2	2	1
PLANNED	3/19/2021	1	30	30
CUSTOMER REQUEST	3/19/2021	1	161	161
PLANNED	3/19/2021	3	81	27
PLANNED	3/19/2021	7	833	119
PLANNED	3/19/2021	1	30	30
PLANNED	3/19/2021	1	108	108
PLANNED	3/19/2021	1	47	47
PLANNED	3/19/2021	3	78	26
PLANNED	3/19/2021	3	141	47
PLANNED	3/19/2021	15	2,475	165
PLANNED	3/19/2021	44	8,052	183
PLANNED	3/19/2021	5	1,130	226
CUSTOMER REQUEST	3/19/2021	1	129	129
PLANNED	3/20/2021	1	96	96
PLANNED	3/20/2021	15	2,160	144
PLANNED	3/20/2021	4	408	102
PLANNED	3/20/2021	1	537	537
CUSTOMER REQUEST	3/20/2021	1	126	126
PLANNED	3/20/2021	1	171	171
PLANNED	3/20/2021	7	665	95
PLANNED	3/20/2021	1	309	309
PLANNED	3/20/2021	9	603	67
PLANNED	3/20/2021	13	2,119	163
PLANNED	3/20/2021	11	1,386	126
PLANNED	3/20/2021	1	408	408
PLANNED	3/20/2021	1	473	473
PLANNED	3/20/2021	2	848	424
PLANNED	3/20/2021	8	608	76
PLANNED	3/20/2021	2	52	26
PLANNED	3/20/2021	9	417	103
PLANNED	3/20/2021	4	1,196	299
PLANNED	3/20/2021	22	1,896	138
PLANNED	3/20/2021	4	208	52
PLANNED	3/20/2021	2	126	63
PLANNED	3/20/2021	1	14	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/20/2021	2	38	19
PLANNED	3/20/2021	1	273	273
PLANNED	3/21/2021	4	40	10
PLANNED	3/21/2021	4	708	177
PLANNED	3/21/2021	19	2,109	111
PLANNED	3/21/2021	4	440	110
PLANNED	3/21/2021	4	488	122
CUSTOMER REQUEST	3/21/2021	87	21,489	247
PLANNED	3/21/2021	3	396	132
PLANNED	3/21/2021	1	16	16
PLANNED	3/21/2021	1	156	156
PLANNED	3/21/2021	1	19	19
PLANNED	3/21/2021	1	65	65
PLANNED	3/21/2021	1	26	26
CUSTOMER REQUEST	3/21/2021	6	198	33
PLANNED	3/21/2021	3	87	29
PLANNED	3/21/2021	1	101	101
PLANNED	3/21/2021	1	54	54
PLANNED	3/21/2021	10	280	28
PLANNED	3/21/2021	10	1,450	145
PLANNED	3/21/2021	5	315	63
PLANNED	3/21/2021	3	207	69
PLANNED	3/21/2021	2	264	132
PLANNED	3/22/2021	1	13	13
PLANNED	3/22/2021	4	172	43
PLANNED	3/22/2021	1	50	50
PLANNED	3/22/2021	2	266	154
PLANNED	3/22/2021	2	206	103
PLANNED	3/22/2021	2	62	31
PLANNED	3/22/2021	2	230	115
PLANNED	3/22/2021	1	128	128
CUSTOMER REQUEST	3/22/2021	7	308	44
PLANNED	3/22/2021	5	135	27
PLANNED	3/22/2021	16	2,974	203
CUSTOMER REQUEST	3/22/2021	76	23,560	310
PLANNED	3/22/2021	4	504	126
PLANNED	3/22/2021	26	2,704	104
PLANNED	3/22/2021	1	215	215
PLANNED	3/22/2021	5	135	27
PLANNED	3/22/2021	2	80	40
PLANNED	3/22/2021	5	180	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/22/2021	3	291	97
PLANNED	3/22/2021	4	96	24
PLANNED	3/22/2021	3	60	20
PLANNED	3/22/2021	18	972	54
PLANNED	3/22/2021	9	603	67
PLANNED	3/22/2021	3	33	11
PLANNED	3/22/2021	3	147	49
CUSTOMER REQUEST	3/22/2021	1	35	35
PLANNED	3/22/2021	7	238	34
PLANNED	3/22/2021	41	2,665	65
PLANNED	3/22/2021	1	36	36
PLANNED	3/22/2021	9	558	62
PLANNED	3/22/2021	17	5,264	528
PLANNED	3/22/2021	6	24	4
PLANNED	3/22/2021	17	4,488	264
PLANNED	3/22/2021	3	432	144
PLANNED	3/22/2021	7	889	127
PLANNED	3/22/2021	9	1,125	125
PLANNED	3/22/2021	1	81	81
PLANNED	3/22/2021	36	5,004	139
PLANNED	3/22/2021	9	720	80
PLANNED	3/22/2021	4	132	33
PLANNED	3/22/2021	27	3,807	141
PLANNED	3/22/2021	22	1,936	116
PLANNED	3/22/2021	8	120	15
PLANNED	3/22/2021	3	87	29
PLANNED	3/22/2021	3	51	17
PLANNED	3/22/2021	3	66	22
PLANNED	3/22/2021	1	16	16
PLANNED	3/22/2021	4	40	10
PLANNED	3/22/2021	1	14	14
PLANNED	3/22/2021	3	327	109
PLANNED	3/22/2021	4	64	16
PLANNED	3/22/2021	6	30	5
PLANNED	3/22/2021	8	272	34
PLANNED	3/22/2021	3	450	150
PLANNED	3/22/2021	1	20	20
PLANNED	3/22/2021	2	210	105
PLANNED	3/22/2021	1	14	14
PLANNED	3/22/2021	3	150	50
PLANNED	3/22/2021	6	162	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/22/2021	1	407	407
PLANNED	3/22/2021	4	1,400	350
PLANNED	3/22/2021	6	42	7
PLANNED	3/22/2021	1	95	95
CUSTOMER REQUEST	3/22/2021	9	315	35
PLANNED	3/22/2021	4	164	41
PLANNED	3/22/2021	2	90	45
PLANNED	3/22/2021	4	40	10
PLANNED	3/22/2021	2	16	8
PLANNED	3/22/2021	2	28	14
PLANNED	3/22/2021	7	42	6
PLANNED	3/22/2021	5	55	11
PLANNED	3/22/2021	1	77	77
PLANNED	3/22/2021	2	78	39
PLANNED	3/22/2021	3	66	22
PLANNED	3/22/2021	11	143	13
PLANNED	3/22/2021	1	107	107
PLANNED	3/22/2021	2	768	384
PLANNED	3/22/2021	8	240	30
PLANNED	3/22/2021	4	76	19
PLANNED	3/22/2021	4	96	24
PLANNED	3/22/2021	9	1,278	142
PLANNED	3/22/2021	1	22	22
PLANNED	3/22/2021	1	282	282
PLANNED	3/22/2021	3	945	315
PLANNED	3/22/2021	4	32	8
PLANNED	3/22/2021	3	228	76
CUSTOMER REQUEST	3/22/2021	9	2,034	226
PLANNED	3/22/2021	3	18	6
PLANNED	3/22/2021	1	412	412
PLANNED	3/22/2021	2	42	21
PLANNED	3/22/2021	7	441	63
PLANNED	3/22/2021	9	162	18
PLANNED	3/22/2021	31	961	31
PLANNED	3/22/2021	3	42	14
PLANNED	3/22/2021	4	44	11
PLANNED	3/22/2021	4	148	37
PLANNED	3/22/2021	2	128	64
PLANNED	3/22/2021	2	130	65
PLANNED	3/22/2021	9	936	104
PLANNED	3/22/2021	6	48	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/22/2021	7	133	19
PLANNED	3/22/2021	9	576	64
CUSTOMER REQUEST	3/22/2021	2	26	13
PLANNED	3/22/2021	3	135	45
PLANNED	3/22/2021	6	162	27
PLANNED	3/22/2021	4	32	8
PLANNED	3/22/2021	3	150	50
PLANNED	3/22/2021	3	261	87
PLANNED	3/22/2021	4	144	36
PLANNED	3/22/2021	3	102	34
PLANNED	3/22/2021	7	273	39
PLANNED	3/22/2021	2	26	13
PLANNED	3/22/2021	4	60	15
PLANNED	3/22/2021	3	531	177
PLANNED	3/22/2021	11	1,155	105
PLANNED	3/22/2021	2	302	151
PLANNED	3/22/2021	3	525	175
PLANNED	3/22/2021	2	48	24
PLANNED	3/22/2021	6	84	14
PLANNED	3/22/2021	7	854	122
PLANNED	3/22/2021	12	1,908	159
PLANNED	3/22/2021	4	664	166
PLANNED	3/22/2021	4	408	102
PLANNED	3/22/2021	4	92	23
PLANNED	3/22/2021	11	1,122	102
PLANNED	3/22/2021	4	180	45
PLANNED	3/22/2021	3	114	38
PLANNED	3/22/2021	3	99	33
PLANNED	3/22/2021	2	172	86
PLANNED	3/22/2021	3	78	26
PLANNED	3/22/2021	6	1,098	183
PLANNED	3/22/2021	5	80	37
PLANNED	3/22/2021	3	144	48
PLANNED	3/22/2021	8	72	9
PLANNED	3/22/2021	4	88	22
PLANNED	3/22/2021	3	237	79
PLANNED	3/22/2021	4	220	55
PLANNED	3/22/2021	2	34	17
PLANNED	3/22/2021	4	444	111
PLANNED	3/22/2021	2	91	63
PLANNED	3/22/2021	8	408	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/22/2021	10	1,180	118
CUSTOMER REQUEST	3/22/2021	2	60	30
PLANNED	3/22/2021	4	100	25
PLANNED	3/22/2021	1	113	113
PLANNED	3/22/2021	4	164	41
PLANNED	3/22/2021	3	315	105
PLANNED	3/22/2021	3	201	67
PLANNED	3/22/2021	2	316	158
PLANNED	3/22/2021	1	69	69
PLANNED	3/22/2021	2	86	43
PLANNED	3/22/2021	7	490	70
PLANNED	3/22/2021	10	460	46
PLANNED	3/22/2021	2	326	163
PLANNED	3/22/2021	4	204	51
PLANNED	3/22/2021	4	288	72
PLANNED	3/22/2021	1	72	72
PLANNED	3/22/2021	1	116	116
PLANNED	3/22/2021	2	64	32
PLANNED	3/22/2021	2	296	148
PLANNED	3/22/2021	9	369	41
PLANNED	3/22/2021	4	92	23
PLANNED	3/22/2021	9	495	55
PLANNED	3/22/2021	2	148	74
PLANNED	3/22/2021	1	46	46
PLANNED	3/22/2021	1	13	13
PLANNED	3/22/2021	6	138	23
PLANNED	3/22/2021	3	267	89
PLANNED	3/22/2021	12	360	30
PLANNED	3/22/2021	6	576	96
PLANNED	3/22/2021	3	138	46
PLANNED	3/22/2021	12	264	22
PLANNED	3/22/2021	3	588	196
PLANNED	3/22/2021	1	57	57
PLANNED	3/23/2021	1	159	159
PLANNED	3/23/2021	3	225	75
PLANNED	3/23/2021	4	180	45
PLANNED	3/23/2021	2	206	103
PLANNED	3/23/2021	4	124	31
PLANNED	3/23/2021	5	580	116
PLANNED	3/23/2021	2	636	318
CUSTOMER REQUEST	3/23/2021	1	194	194

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/23/2021	1	81	81
PLANNED	3/23/2021	4	188	47
PLANNED	3/23/2021	5	180	36
PLANNED	3/23/2021	9	261	29
PLANNED	3/23/2021	1	105	105
PLANNED	3/23/2021	3	438	146
PLANNED	3/23/2021	1	105	105
PLANNED	3/23/2021	1	252	252
PLANNED	3/23/2021	6	792	132
PLANNED	3/23/2021	10	930	93
PLANNED	3/23/2021	9	279	31
PLANNED	3/23/2021	2	62	31
PLANNED	3/23/2021	5	525	105
PLANNED	3/23/2021	3	552	184
PLANNED	3/23/2021	2	28	14
PLANNED	3/23/2021	4	128	32
PLANNED	3/23/2021	7	2,912	416
PLANNED	3/23/2021	16	160	10
PLANNED	3/23/2021	2	76	38
PLANNED	3/23/2021	6	108	18
PLANNED	3/23/2021	14	1,386	99
PLANNED	3/23/2021	8	760	95
CUSTOMER REQUEST	3/23/2021	5	260	52
PLANNED	3/23/2021	8	416	52
PLANNED	3/23/2021	8	416	52
PLANNED	3/23/2021	1	40	40
PLANNED	3/23/2021	1	67	67
PLANNED	3/23/2021	2	274	137
CUSTOMER REQUEST	3/23/2021	38	1,764	407
PLANNED	3/23/2021	3	753	251
PLANNED	3/23/2021	2	90	45
PLANNED	3/23/2021	4	120	30
PLANNED	3/23/2021	41	2,829	69
PLANNED	3/23/2021	2	208	104
PLANNED	3/23/2021	1	189	189
CUSTOMER REQUEST	3/23/2021	6	396	66
PLANNED	3/23/2021	11	297	27
PLANNED	3/23/2021	2	168	84
PLANNED	3/23/2021	6	216	36
PLANNED	3/23/2021	9	1,539	171
PLANNED	3/23/2021	3	105	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/23/2021	12	1,236	103
PLANNED	3/23/2021	1	111	111
PLANNED	3/23/2021	1	132	132
PLANNED	3/23/2021	1	110	110
PLANNED	3/23/2021	12	420	35
PLANNED	3/23/2021	13	1,274	98
CUSTOMER REQUEST	3/23/2021	1	263	263
PLANNED	3/23/2021	3	129	43
PLANNED	3/23/2021	4	1,036	259
PLANNED	3/23/2021	1	96	96
PLANNED	3/23/2021	4	920	230
PLANNED	3/23/2021	1	15	15
PLANNED	3/23/2021	38	3,382	89
PLANNED	3/23/2021	4	920	230
PLANNED	3/23/2021	6	300	50
PLANNED	3/23/2021	1	78	78
PLANNED	3/23/2021	27	2,457	91
PLANNED	3/23/2021	3	519	173
PLANNED	3/23/2021	2	88	44
PLANNED	3/23/2021	7	1,736	248
PLANNED	3/23/2021	2	228	114
PLANNED	3/23/2021	9	27	3
PLANNED	3/23/2021	8	576	72
PLANNED	3/23/2021	9	81	9
PLANNED	3/23/2021	5	275	55
CUSTOMER REQUEST	3/23/2021	8	128	16
PLANNED	3/23/2021	2	266	133
CUSTOMER REQUEST	3/23/2021	77	8,085	105
PLANNED	3/23/2021	4	192	48
PLANNED	3/23/2021	7	602	86
PLANNED	3/23/2021	2	40	20
PLANNED	3/23/2021	6	30	5
PLANNED	3/23/2021	25	300	12
PLANNED	3/23/2021	4	112	28
PLANNED	3/23/2021	2	62	31
CUSTOMER REQUEST	3/23/2021	8	512	64
PLANNED	3/23/2021	1	444	444
PLANNED	3/23/2021	6	138	23
PLANNED	3/23/2021	3	108	36
PLANNED	3/23/2021	15	45	3
PLANNED	3/23/2021	2	438	219

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/23/2021	4	184	46
PLANNED	3/23/2021	4	100	25
CUSTOMER REQUEST	3/23/2021	2	60	30
PLANNED	3/23/2021	4	168	42
PLANNED	3/23/2021	10	230	23
PLANNED	3/23/2021	1	25	25
PLANNED	3/23/2021	6	768	128
PLANNED	3/23/2021	1	78	78
PLANNED	3/23/2021	6	126	21
PLANNED	3/23/2021	1	58	58
CUSTOMER REQUEST	3/23/2021	8	112	14
PLANNED	3/23/2021	1	120	120
PLANNED	3/23/2021	6	240	40
PLANNED	3/23/2021	3	395	183
PLANNED	3/23/2021	2	170	85
PLANNED	3/23/2021	4	8	2
PLANNED	3/23/2021	3	402	134
PLANNED	3/23/2021	6	180	30
PLANNED	3/23/2021	1	49	49
PLANNED	3/23/2021	3	312	104
PLANNED	3/23/2021	2	62	31
PLANNED	3/23/2021	19	1,653	87
PLANNED	3/23/2021	12	2,508	209
PLANNED	3/23/2021	9	54	6
PLANNED	3/23/2021	1	39	39
PLANNED	3/23/2021	5	135	27
PLANNED	3/23/2021	8	880	110
PLANNED	3/23/2021	5	845	169
PLANNED	3/23/2021	3	261	87
PLANNED	3/23/2021	4	256	64
PLANNED	3/23/2021	5	337	103
PLANNED	3/23/2021	6	1,188	198
PLANNED	3/23/2021	1	22	22
PLANNED	3/23/2021	4	128	32
PLANNED	3/23/2021	4	460	115
PLANNED	3/23/2021	1	75	75
PLANNED	3/23/2021	2	46	23
PLANNED	3/23/2021	1	11	11
PLANNED	3/23/2021	37	148	4
PLANNED	3/23/2021	4	56	14
PLANNED	3/23/2021	4	192	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/23/2021	3	213	71
PLANNED	3/23/2021	1	77	77
PLANNED	3/23/2021	2	64	32
PLANNED	3/23/2021	2	74	37
PLANNED	3/23/2021	16	32	2
PLANNED	3/23/2021	6	12	2
PLANNED	3/23/2021	3	78	26
PLANNED	3/23/2021	4	180	45
PLANNED	3/23/2021	1	13	13
PLANNED	3/23/2021	2	82	91
PLANNED	3/23/2021	2	148	74
PLANNED	3/23/2021	2	150	75
PLANNED	3/23/2021	2	484	242
CUSTOMER REQUEST	3/23/2021	4	8	2
PLANNED	3/23/2021	3	135	45
PLANNED	3/23/2021	2	414	207
PLANNED	3/23/2021	2	354	177
PLANNED	3/23/2021	6	156	26
PLANNED	3/23/2021	3	444	148
PLANNED	3/23/2021	3	78	26
PLANNED	3/23/2021	4	588	147
PLANNED	3/23/2021	2	170	85
PLANNED	3/23/2021	1	60	60
PLANNED	3/23/2021	12	1,200	100
PLANNED	3/23/2021	3	297	99
PLANNED	3/23/2021	3	78	26
PLANNED	3/23/2021	11	1,397	127
PLANNED	3/23/2021	4	588	147
PLANNED	3/23/2021	1	30	30
PLANNED	3/23/2021	1	50	50
PLANNED	3/23/2021	9	360	40
PLANNED	3/23/2021	13	2,613	201
PLANNED	3/23/2021	2	180	90
PLANNED	3/23/2021	8	1,016	127
PLANNED	3/23/2021	2	60	30
PLANNED	3/23/2021	1	101	101
PLANNED	3/23/2021	2	42	21
PLANNED	3/23/2021	2	94	47
PLANNED	3/23/2021	7	217	31
CUSTOMER REQUEST	3/23/2021	1	102	102
CUSTOMER REQUEST	3/23/2021	1	242	242

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/23/2021	10	340	34
PLANNED	3/23/2021	2	410	205
PLANNED	3/23/2021	1	232	232
PLANNED	3/23/2021	1	176	176
PLANNED	3/23/2021	2	370	185
PLANNED	3/24/2021	5	260	52
PLANNED	3/24/2021	1	236	236
PLANNED	3/24/2021	8	2,000	250
PLANNED	3/24/2021	1	248	248
PLANNED	3/24/2021	1	63	63
PLANNED	3/24/2021	4	676	169
PLANNED	3/24/2021	3	183	61
PLANNED	3/24/2021	6	606	101
PLANNED	3/24/2021	12	801	100
PLANNED	3/24/2021	1	43	43
PLANNED	3/24/2021	6	1,128	188
PLANNED	3/24/2021	5	325	65
PLANNED	3/24/2021	16	800	50
PLANNED	3/24/2021	1	263	263
PLANNED	3/24/2021	5	441	130
PLANNED	3/24/2021	5	635	127
PLANNED	3/24/2021	4	704	176
PLANNED	3/24/2021	4	288	72
PLANNED	3/24/2021	1	14	14
PLANNED	3/24/2021	3	234	78
PLANNED	3/24/2021	2	284	142
PLANNED	3/24/2021	8	320	40
PLANNED	3/24/2021	2	266	133
PLANNED	3/24/2021	15	1,740	116
PLANNED	3/24/2021	4	280	70
PLANNED	3/24/2021	21	1,176	56
PLANNED	3/24/2021	1	52	52
PLANNED	3/24/2021	2	84	42
PLANNED	3/24/2021	1	75	75
PLANNED	3/24/2021	2	234	168
PLANNED	3/24/2021	1	28	28
PLANNED	3/24/2021	1	28	28
PLANNED	3/24/2021	2	58	29
PLANNED	3/24/2021	1	112	112
PLANNED	3/24/2021	18	540	30
PLANNED	3/24/2021	16	176	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/24/2021	8	216	27
PLANNED	3/24/2021	6	354	59
PLANNED	3/24/2021	3	84	28
PLANNED	3/24/2021	1	13	13
PLANNED	3/24/2021	7	686	98
PLANNED	3/24/2021	1	253	253
CUSTOMER REQUEST	3/24/2021	7	28	4
PLANNED	3/24/2021	3	51	17
CUSTOMER REQUEST	3/24/2021	20	200	10
PLANNED	3/24/2021	2	104	52
PLANNED	3/24/2021	1	24	24
PLANNED	3/24/2021	2	230	115
PLANNED	3/24/2021	12	996	83
PLANNED	3/24/2021	1	225	225
PLANNED	3/24/2021	3	102	34
PLANNED	3/24/2021	2	94	47
PLANNED	3/24/2021	4	44	11
PLANNED	3/24/2021	3	96	32
PLANNED	3/24/2021	1	85	85
PLANNED	3/24/2021	2	86	43
PLANNED	3/24/2021	12	552	46
PLANNED	3/24/2021	2	72	36
PLANNED	3/24/2021	22	6,270	285
PLANNED	3/24/2021	1	93	93
PLANNED	3/24/2021	1	28	28
PLANNED	3/24/2021	4	156	39
PLANNED	3/24/2021	13	104	8
PLANNED	3/24/2021	10	770	77
PLANNED	3/24/2021	27	4,644	172
PLANNED	3/24/2021	5	471	135
PLANNED	3/24/2021	3	66	22
PLANNED	3/24/2021	14	252	18
PLANNED	3/24/2021	1	99	99
CUSTOMER REQUEST	3/24/2021	1	234	234
PLANNED	3/24/2021	13	546	42
PLANNED	3/24/2021	3	114	38
PLANNED	3/24/2021	3	420	140
PLANNED	3/24/2021	2	94	47
PLANNED	3/24/2021	2	58	29
PLANNED	3/24/2021	1	159	159
PLANNED	3/24/2021	2	64	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/24/2021	4	92	23
PLANNED	3/24/2021	7	770	110
PLANNED	3/24/2021	1	15	15
PLANNED	3/24/2021	7	651	93
PLANNED	3/24/2021	6	85	70
PLANNED	3/24/2021	10	360	36
PLANNED	3/24/2021	41	3,567	87
PLANNED	3/24/2021	14	84	6
PLANNED	3/24/2021	1	40	40
PLANNED	3/24/2021	1	14	14
PLANNED	3/24/2021	8	264	33
PLANNED	3/24/2021	6	72	12
PLANNED	3/24/2021	9	1,050	168
PLANNED	3/24/2021	2	104	67
PLANNED	3/24/2021	5	250	50
PLANNED	3/24/2021	2	66	33
PLANNED	3/24/2021	1	78	78
PLANNED	3/24/2021	7	63	9
PLANNED	3/24/2021	4	148	37
PLANNED	3/24/2021	2	16	8
PLANNED	3/24/2021	9	495	55
PLANNED	3/24/2021	8	560	70
PLANNED	3/24/2021	7	434	62
PLANNED	3/24/2021	1	65	65
PLANNED	3/24/2021	5	55	11
PLANNED	3/24/2021	2	74	37
PLANNED	3/24/2021	2	60	30
PLANNED	3/24/2021	5	360	72
PLANNED	3/24/2021	2	306	153
PLANNED	3/24/2021	11	825	75
PLANNED	3/24/2021	7	595	85
PLANNED	3/24/2021	6	264	44
PLANNED	3/24/2021	2	206	103
PLANNED	3/24/2021	1	119	119
PLANNED	3/24/2021	2	124	62
PLANNED	3/24/2021	7	1,547	221
PLANNED	3/24/2021	2	210	105
PLANNED	3/24/2021	2	208	104
PLANNED	3/24/2021	1	14	14
PLANNED	3/24/2021	5	10	2
PLANNED	3/24/2021	1	72	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/24/2021	6	210	35
PLANNED	3/24/2021	7	105	15
PLANNED	3/24/2021	5	5	1
PLANNED	3/24/2021	5	65	13
PLANNED	3/24/2021	4	128	32
PLANNED	3/24/2021	5	344	112
PLANNED	3/24/2021	3	87	29
PLANNED	3/24/2021	4	120	30
PLANNED	3/24/2021	28	700	25
PLANNED	3/24/2021	4	120	30
PLANNED	3/24/2021	4	108	27
PLANNED	3/24/2021	2	196	98
PLANNED	3/24/2021	102	6,528	64
PLANNED	3/24/2021	11	2,860	260
PLANNED	3/24/2021	2	88	44
PLANNED	3/24/2021	2	100	50
PLANNED	3/24/2021	4	128	32
PLANNED	3/24/2021	1	80	80
PLANNED	3/24/2021	4	448	112
PLANNED	3/24/2021	5	165	33
PLANNED	3/24/2021	16	160	10
PLANNED	3/24/2021	2	184	92
PLANNED	3/24/2021	2	78	39
PLANNED	3/24/2021	1	76	76
PLANNED	3/24/2021	1	38	38
PLANNED	3/24/2021	8	336	42
PLANNED	3/24/2021	4	88	22
PLANNED	3/24/2021	1	17	17
PLANNED	3/24/2021	13	1,924	148
PLANNED	3/24/2021	2	124	62
PLANNED	3/24/2021	21	1,890	90
PLANNED	3/24/2021	2	34	17
PLANNED	3/24/2021	3	288	96
PLANNED	3/24/2021	2	26	13
PLANNED	3/24/2021	4	96	24
PLANNED	3/24/2021	2	318	159
PLANNED	3/24/2021	4	160	40
PLANNED	3/24/2021	2	160	80
PLANNED	3/24/2021	1	63	63
PLANNED	3/24/2021	10	390	39
PLANNED	3/24/2021	4	200	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/24/2021	16	224	14
PLANNED	3/24/2021	2	162	81
PLANNED	3/24/2021	9	477	53
PLANNED	3/24/2021	3	96	32
PLANNED	3/24/2021	6	594	99
PLANNED	3/24/2021	1	76	76
PLANNED	3/24/2021	3	336	112
PLANNED	3/24/2021	4	564	141
PLANNED	3/24/2021	1	48	48
PLANNED	3/24/2021	3	207	69
PLANNED	3/24/2021	2	206	103
CUSTOMER REQUEST	3/24/2021	1	398	398
CUSTOMER REQUEST	3/24/2021	1	275	275
PLANNED	3/24/2021	1	87	87
PLANNED	3/24/2021	1	193	193
CUSTOMER REQUEST	3/24/2021	3	1,578	526
PLANNED	3/24/2021	1	65	65
PLANNED	3/24/2021	2	86	43
PLANNED	3/24/2021	1	19	19
PLANNED	3/24/2021	3	153	51
PLANNED	3/24/2021	1	125	125
PLANNED	3/24/2021	5	848	307
PLANNED	3/24/2021	2	68	34
PLANNED	3/24/2021	1	199	199
PLANNED	3/24/2021	9	396	44
PLANNED	3/24/2021	1	65	65
PLANNED	3/25/2021	3	594	198
PLANNED	3/25/2021	1	210	210
PLANNED	3/25/2021	131	27,117	207
PLANNED	3/25/2021	1	188	188
PLANNED	3/25/2021	7	203	29
PLANNED	3/25/2021	1	93	93
PLANNED	3/25/2021	1	134	134
PLANNED	3/25/2021	6	618	103
PLANNED	3/25/2021	12	984	82
CUSTOMER REQUEST	3/25/2021	2	33	24
PLANNED	3/25/2021	6	1,058	307
PLANNED	3/25/2021	1	21	21
PLANNED	3/25/2021	1	440	440
PLANNED	3/25/2021	2	70	35
PLANNED	3/25/2021	4	535	189

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/25/2021	2	132	66
PLANNED	3/25/2021	1	86	86
PLANNED	3/25/2021	7	406	58
PLANNED	3/25/2021	2	158	79
PLANNED	3/25/2021	9	594	66
PLANNED	3/25/2021	2	108	67
PLANNED	3/25/2021	7	611	152
PLANNED	3/25/2021	2	254	127
PLANNED	3/25/2021	1	155	155
PLANNED	3/25/2021	27	1,107	41
PLANNED	3/25/2021	4	1,240	310
PLANNED	3/25/2021	1	3	3
PLANNED	3/25/2021	4	388	97
PLANNED	3/25/2021	6	366	61
PLANNED	3/25/2021	2	172	86
CUSTOMER REQUEST	3/25/2021	1	38	38
PLANNED	3/25/2021	6	204	34
PLANNED	3/25/2021	1	215	215
PLANNED	3/25/2021	12	864	72
PLANNED	3/25/2021	5	35	7
PLANNED	3/25/2021	8	400	75
PLANNED	3/25/2021	2	232	127
PLANNED	3/25/2021	1	15	15
PLANNED	3/25/2021	2	26	13
PLANNED	3/25/2021	6	894	149
PLANNED	3/25/2021	1	90	90
PLANNED	3/25/2021	5	230	46
PLANNED	3/25/2021	23	1,242	54
PLANNED	3/25/2021	2	506	253
PLANNED	3/25/2021	19	19	1
PLANNED	3/25/2021	9	972	108
PLANNED	3/25/2021	1	21	21
PLANNED	3/25/2021	4	1,088	272
PLANNED	3/25/2021	2	78	39
PLANNED	3/25/2021	3	390	130
PLANNED	3/25/2021	4	980	245
PLANNED	3/25/2021	1	173	173
PLANNED	3/25/2021	11	3,179	289
PLANNED	3/25/2021	2	92	46
PLANNED	3/25/2021	9	702	78
PLANNED	3/25/2021	3	411	137

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/25/2021	10	400	40
CUSTOMER REQUEST	3/25/2021	25	1,200	48
PLANNED	3/25/2021	3	369	123
PLANNED	3/25/2021	5	190	38
PLANNED	3/25/2021	3	123	41
PLANNED	3/25/2021	26	9,750	375
PLANNED	3/25/2021	3	96	32
PLANNED	3/25/2021	9	504	56
PLANNED	3/25/2021	23	1,173	51
PLANNED	3/25/2021	1	131	131
PLANNED	3/25/2021	1	17	17
PLANNED	3/25/2021	1	24	24
PLANNED	3/25/2021	2	66	33
PLANNED	3/25/2021	2	122	61
PLANNED	3/25/2021	7	14	2
PLANNED	3/25/2021	1	170	170
PLANNED	3/25/2021	6	762	127
CUSTOMER REQUEST	3/25/2021	2	57	30
PLANNED	3/25/2021	4	292	73
PLANNED	3/25/2021	4	268	67
PLANNED	3/25/2021	3	105	35
PLANNED	3/25/2021	3	243	81
PLANNED	3/25/2021	3	138	46
PLANNED	3/25/2021	7	238	34
PLANNED	3/25/2021	6	1,074	179
PLANNED	3/25/2021	1	43	43
CUSTOMER REQUEST	3/25/2021	3	99	33
PLANNED	3/25/2021	10	430	43
PLANNED	3/25/2021	10	2,840	284
PLANNED	3/25/2021	3	117	39
PLANNED	3/25/2021	2	34	17
PLANNED	3/25/2021	19	2,850	150
PLANNED	3/25/2021	9	216	24
PLANNED	3/25/2021	2	322	161
PLANNED	3/25/2021	2	144	72
PLANNED	3/25/2021	3	417	139
PLANNED	3/25/2021	7	1,057	151
PLANNED	3/25/2021	4	148	37
PLANNED	3/25/2021	27	2,106	78
PLANNED	3/25/2021	1	17	17
PLANNED	3/25/2021	5	188	60

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/25/2021	2	292	146
PLANNED	3/25/2021	28	2,548	91
PLANNED	3/25/2021	3	291	97
PLANNED	3/25/2021	4	220	55
PLANNED	3/25/2021	8	144	18
PLANNED	3/25/2021	2	24	12
PLANNED	3/25/2021	8	856	107
PLANNED	3/25/2021	1	69	69
PLANNED	3/25/2021	1	21	21
CUSTOMER REQUEST	3/25/2021	1	54	54
PLANNED	3/25/2021	2	82	41
PLANNED	3/25/2021	2	112	56
PLANNED	3/25/2021	1	55	55
PLANNED	3/25/2021	12	300	25
PLANNED	3/25/2021	1	12	12
PLANNED	3/25/2021	8	808	101
PLANNED	3/25/2021	4	92	23
PLANNED	3/25/2021	5	245	49
PLANNED	3/25/2021	4	760	190
PLANNED	3/25/2021	4	764	191
PLANNED	3/25/2021	1	43	43
PLANNED	3/25/2021	1	3	3
PLANNED	3/25/2021	1	84	84
PLANNED	3/25/2021	1	158	158
PLANNED	3/25/2021	2	74	37
PLANNED	3/25/2021	1	17	17
PLANNED	3/25/2021	3	441	147
PLANNED	3/25/2021	4	356	89
PLANNED	3/25/2021	2	102	51
PLANNED	3/25/2021	1	15	15
PLANNED	3/25/2021	4	120	30
PLANNED	3/25/2021	4	156	39
PLANNED	3/25/2021	2	342	171
PLANNED	3/25/2021	4	628	157
PLANNED	3/25/2021	2	96	49
PLANNED	3/25/2021	10	2,980	298
PLANNED	3/25/2021	2	28	14
PLANNED	3/25/2021	1	71	71
PLANNED	3/25/2021	3	36	12
CUSTOMER REQUEST	3/25/2021	1	96	96
PLANNED	3/25/2021	14	504	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/25/2021	3	72	24
PLANNED	3/25/2021	1	28	28
PLANNED	3/25/2021	7	63	9
PLANNED	3/25/2021	2	24	12
PLANNED	3/25/2021	2	26	13
PLANNED	3/25/2021	5	250	50
PLANNED	3/25/2021	2	138	69
PLANNED	3/25/2021	1	63	63
PLANNED	3/25/2021	2	86	43
PLANNED	3/25/2021	4	176	44
PLANNED	3/25/2021	4	400	100
PLANNED	3/25/2021	3	441	147
PLANNED	3/25/2021	2	148	74
PLANNED	3/25/2021	13	286	22
PLANNED	3/25/2021	2	70	35
PLANNED	3/25/2021	2	140	70
PLANNED	3/25/2021	6	444	74
PLANNED	3/25/2021	3	39	13
CUSTOMER REQUEST	3/25/2021	1	58	58
PLANNED	3/25/2021	2	130	65
PLANNED	3/25/2021	4	868	217
PLANNED	3/25/2021	16	384	24
PLANNED	3/25/2021	1	77	77
PLANNED	3/25/2021	1	16	16
PLANNED	3/25/2021	2	32	16
PLANNED	3/25/2021	3	159	63
PLANNED	3/25/2021	2	188	94
PLANNED	3/25/2021	3	117	39
PLANNED	3/25/2021	6	738	123
PLANNED	3/25/2021	1	129	129
PLANNED	3/25/2021	5	90	18
PLANNED	3/25/2021	7	175	25
PLANNED	3/25/2021	10	530	53
PLANNED	3/25/2021	2	168	84
PLANNED	3/25/2021	1	89	89
PLANNED	3/25/2021	10	690	69
PLANNED	3/25/2021	3	144	48
PLANNED	3/25/2021	1	62	62
PLANNED	3/25/2021	1	129	129
PLANNED	3/25/2021	1	86	86
PLANNED	3/25/2021	2	70	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/25/2021	1	51	51
PLANNED	3/25/2021	17	1,377	81
PLANNED	3/25/2021	8	1,752	219
PLANNED	3/25/2021	1	130	130
PLANNED	3/26/2021	1	43	43
PLANNED	3/26/2021	1	251	251
PLANNED	3/26/2021	8	904	113
PLANNED	3/26/2021	1	101	101
PLANNED	3/26/2021	3	216	72
PLANNED	3/26/2021	5	360	72
PLANNED	3/26/2021	1	122	122
PLANNED	3/26/2021	2	134	67
PLANNED	3/26/2021	7	245	35
PLANNED	3/26/2021	1	638	638
PLANNED	3/26/2021	1	28	28
PLANNED	3/26/2021	2	84	42
PLANNED	3/26/2021	1	20	20
PLANNED	3/26/2021	2	72	36
PLANNED	3/26/2021	1	75	75
PLANNED	3/26/2021	2	136	68
PLANNED	3/26/2021	2	186	123
PLANNED	3/26/2021	2	20	10
PLANNED	3/26/2021	16	3,072	192
PLANNED	3/26/2021	2	253	133
PLANNED	3/26/2021	5	25	5
PLANNED	3/26/2021	9	819	91
CUSTOMER REQUEST	3/26/2021	2	66	33
PLANNED	3/26/2021	3	63	21
PLANNED	3/26/2021	8	440	55
PLANNED	3/26/2021	1	7	7
PLANNED	3/26/2021	1	10	10
PLANNED	3/26/2021	1	154	154
PLANNED	3/26/2021	3	30	10
PLANNED	3/26/2021	2	42	21
PLANNED	3/26/2021	1	45	45
PLANNED	3/26/2021	3	87	29
PLANNED	3/26/2021	3	816	272
PLANNED	3/26/2021	2	56	28
PLANNED	3/26/2021	14	994	71
PLANNED	3/26/2021	1	230	230
PLANNED	3/26/2021	3	225	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/26/2021	1	102	102
PLANNED	3/26/2021	6	216	36
PLANNED	3/26/2021	8	3,456	432
PLANNED	3/26/2021	4	68	17
PLANNED	3/26/2021	2	22	11
PLANNED	3/26/2021	2	52	26
PLANNED	3/26/2021	5	625	125
PLANNED	3/26/2021	20	1,480	74
PLANNED	3/26/2021	1	241	241
PLANNED	3/26/2021	2	14	7
PLANNED	3/26/2021	2	226	113
PLANNED	3/26/2021	4	88	22
PLANNED	3/26/2021	1	68	68
PLANNED	3/26/2021	10	420	42
PLANNED	3/26/2021	4	352	88
CUSTOMER REQUEST	3/26/2021	1	320	320
CUSTOMER REQUEST	3/26/2021	3	12	4
PLANNED	3/26/2021	6	60	10
CUSTOMER REQUEST	3/26/2021	1	203	203
PLANNED	3/26/2021	6	264	44
PLANNED	3/26/2021	16	384	24
CUSTOMER REQUEST	3/26/2021	34	16,320	480
PLANNED	3/26/2021	2	82	41
PLANNED	3/26/2021	1	247	247
PLANNED	3/26/2021	2	446	223
PLANNED	3/26/2021	3	303	101
CUSTOMER REQUEST	3/26/2021	7	245	35
PLANNED	3/26/2021	2	30	15
PLANNED	3/26/2021	4	496	124
PLANNED	3/26/2021	4	36	9
CUSTOMER REQUEST	3/26/2021	7	56	8
PLANNED	3/26/2021	5	115	23
PLANNED	3/26/2021	11	33	3
PLANNED	3/26/2021	18	468	26
PLANNED	3/26/2021	4	528	132
CUSTOMER REQUEST	3/26/2021	6	42	7
PLANNED	3/26/2021	16	1,424	89
PLANNED	3/26/2021	1	122	122
PLANNED	3/26/2021	13	442	34
CUSTOMER REQUEST	3/26/2021	8	104	13
PLANNED	3/26/2021	3	153	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/26/2021	3	48	16
PLANNED	3/26/2021	2	34	17
CUSTOMER REQUEST	3/26/2021	1	183	183
CUSTOMER REQUEST	3/26/2021	7	42	6
PLANNED	3/26/2021	3	165	55
PLANNED	3/26/2021	8	296	37
PLANNED	3/26/2021	12	312	26
PLANNED	3/26/2021	1	95	95
PLANNED	3/26/2021	2	78	39
PLANNED	3/26/2021	1	70	70
PLANNED	3/26/2021	2	678	339
PLANNED	3/26/2021	1	16	16
PLANNED	3/26/2021	1	31	31
PLANNED	3/26/2021	4	76	19
PLANNED	3/26/2021	9	432	48
PLANNED	3/26/2021	1	93	93
PLANNED	3/26/2021	2	74	37
PLANNED	3/26/2021	3	87	29
PLANNED	3/26/2021	15	270	18
PLANNED	3/26/2021	2	30	15
PLANNED	3/26/2021	1	34	34
PLANNED	3/26/2021	1	74	74
PLANNED	3/26/2021	4	60	15
PLANNED	3/26/2021	2	12	6
PLANNED	3/26/2021	1	24	24
PLANNED	3/26/2021	13	1,287	99
PLANNED	3/26/2021	3	111	37
PLANNED	3/26/2021	2	18	9
PLANNED	3/26/2021	5	770	154
PLANNED	3/26/2021	3	84	28
PLANNED	3/26/2021	3	51	17
PLANNED	3/26/2021	16	272	17
PLANNED	3/26/2021	4	60	15
PLANNED	3/26/2021	3	27	9
PLANNED	3/26/2021	1	265	265
PLANNED	3/26/2021	3	186	62
PLANNED	3/26/2021	2	20	10
PLANNED	3/26/2021	5	345	69
PLANNED	3/26/2021	11	627	57
PLANNED	3/26/2021	1	53	53
PLANNED	3/26/2021	3	36	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	3/26/2021	1	351	351
PLANNED	3/26/2021	1	57	57
PLANNED	3/26/2021	2	76	38
PLANNED	3/26/2021	4	84	21
PLANNED	3/26/2021	2	148	74
PLANNED	3/26/2021	4	256	64
PLANNED	3/26/2021	3	231	93
PLANNED	3/26/2021	1	144	144
CUSTOMER REQUEST	3/26/2021	7	133	19
PLANNED	3/26/2021	1	52	52
PLANNED	3/26/2021	2	254	127
CUSTOMER REQUEST	3/26/2021	1	47	47
PLANNED	3/26/2021	1	123	123
PLANNED	3/26/2021	11	550	50
PLANNED	3/26/2021	7	2,996	428
CUSTOMER REQUEST	3/26/2021	1	80	80
PLANNED	3/26/2021	2	6	3
PLANNED	3/26/2021	5	670	134
PLANNED	3/26/2021	1	35	35
PLANNED	3/26/2021	13	3,601	277
PLANNED	3/27/2021	1	36	36
PLANNED	3/27/2021	2	304	152
PLANNED	3/27/2021	1	248	248
PLANNED	3/27/2021	3	570	190
PLANNED	3/27/2021	1	249	249
PLANNED	3/27/2021	1	344	344
PLANNED	3/27/2021	6	630	105
PLANNED	3/27/2021	2	212	106
PLANNED	3/27/2021	1	221	221
CUSTOMER REQUEST	3/27/2021	1	80	80
PLANNED	3/27/2021	1	146	146
PLANNED	3/27/2021	1	90	90
PLANNED	3/27/2021	4	335	101
PLANNED	3/27/2021	6	324	54
PLANNED	3/27/2021	2	284	142
PLANNED	3/27/2021	2	144	72
PLANNED	3/27/2021	2	114	57
PLANNED	3/27/2021	4	824	206
CUSTOMER REQUEST	3/28/2021	11	1,562	142
PLANNED	3/28/2021	5	551	183
PLANNED	3/28/2021	2	150	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/28/2021	4	216	54
PLANNED	3/28/2021	3	387	129
PLANNED	3/28/2021	20	4,140	207
PLANNED	3/28/2021	2	58	29
PLANNED	3/28/2021	1	24	24
PLANNED	3/28/2021	7	1,407	201
PLANNED	3/28/2021	2	110	55
PLANNED	3/28/2021	5	220	44
PLANNED	3/28/2021	4	88	22
PLANNED	3/28/2021	5	235	47
PLANNED	3/28/2021	2	252	126
PLANNED	3/28/2021	1	253	253
CUSTOMER REQUEST	3/28/2021	1	80	80
PLANNED	3/29/2021	3	108	36
PLANNED	3/29/2021	4	476	188
PLANNED	3/29/2021	1	156	156
PLANNED	3/29/2021	2	58	29
PLANNED	3/29/2021	3	189	63
PLANNED	3/29/2021	7	476	68
PLANNED	3/29/2021	1	292	292
PLANNED	3/29/2021	4	128	32
PLANNED	3/29/2021	7	329	47
PLANNED	3/29/2021	10	200	20
PLANNED	3/29/2021	3	237	79
PLANNED	3/29/2021	3	111	37
CUSTOMER REQUEST	3/29/2021	12	204	17
PLANNED	3/29/2021	6	462	77
PLANNED	3/29/2021	4	1,324	331
PLANNED	3/29/2021	5	390	78
CUSTOMER REQUEST	3/29/2021	50	15,900	318
PLANNED	3/29/2021	4	148	37
PLANNED	3/29/2021	8	40	5
PLANNED	3/29/2021	2	384	192
PLANNED	3/29/2021	2	268	134
PLANNED	3/29/2021	2	182	136
PLANNED	3/29/2021	2	46	23
PLANNED	3/29/2021	3	1,047	349
PLANNED	3/29/2021	6	492	82
PLANNED	3/29/2021	1	289	289
PLANNED	3/29/2021	4	468	117
PLANNED	3/29/2021	4	344	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/29/2021	4	84	21
PLANNED	3/29/2021	1	92	92
PLANNED	3/29/2021	6	198	33
PLANNED	3/29/2021	1	117	117
PLANNED	3/29/2021	6	348	58
PLANNED	3/29/2021	2	476	238
PLANNED	3/29/2021	10	2,190	219
PLANNED	3/29/2021	1	22	22
PLANNED	3/29/2021	1	14	14
PLANNED	3/29/2021	1	76	76
PLANNED	3/29/2021	2	212	106
PLANNED	3/29/2021	2	14	7
PLANNED	3/29/2021	3	129	43
PLANNED	3/29/2021	1	62	62
PLANNED	3/29/2021	3	93	31
PLANNED	3/29/2021	5	955	191
PLANNED	3/29/2021	8	1,536	192
PLANNED	3/29/2021	11	341	31
PLANNED	3/29/2021	3	96	32
PLANNED	3/29/2021	4	480	120
PLANNED	3/29/2021	1	11	11
PLANNED	3/29/2021	1	32	32
PLANNED	3/29/2021	2	176	88
PLANNED	3/29/2021	21	126	6
PLANNED	3/29/2021	9	729	81
PLANNED	3/29/2021	3	93	31
PLANNED	3/29/2021	4	88	22
PLANNED	3/29/2021	5	1,115	391
PLANNED	3/29/2021	3	90	30
PLANNED	3/29/2021	4	1,108	277
PLANNED	3/29/2021	1	216	216
PLANNED	3/29/2021	3	72	24
PLANNED	3/29/2021	1	18	18
PLANNED	3/29/2021	9	270	30
PLANNED	3/29/2021	2	170	85
PLANNED	3/29/2021	5	220	44
PLANNED	3/29/2021	16	1,024	64
PLANNED	3/29/2021	2	108	54
CUSTOMER REQUEST	3/29/2021	1	114	114
PLANNED	3/29/2021	1	31	31
PLANNED	3/29/2021	1	102	102

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/29/2021	11	836	76
PLANNED	3/29/2021	3	180	60
PLANNED	3/29/2021	4	172	43
PLANNED	3/29/2021	1	15	15
PLANNED	3/29/2021	5	70	14
PLANNED	3/29/2021	3	210	70
PLANNED	3/29/2021	2	334	167
PLANNED	3/29/2021	1	461	461
PLANNED	3/29/2021	5	240	48
PLANNED	3/29/2021	7	322	46
PLANNED	3/29/2021	1	118	118
PLANNED	3/29/2021	1	28	28
PLANNED	3/29/2021	5	215	43
PLANNED	3/29/2021	1	83	83
PLANNED	3/29/2021	4	68	17
PLANNED	3/29/2021	5	155	31
PLANNED	3/29/2021	10	830	83
PLANNED	3/29/2021	5	225	45
PLANNED	3/29/2021	4	1,236	309
PLANNED	3/29/2021	7	1,442	206
PLANNED	3/29/2021	4	92	23
PLANNED	3/29/2021	2	114	57
PLANNED	3/29/2021	12	192	16
PLANNED	3/29/2021	2	82	52
PLANNED	3/29/2021	2	106	53
PLANNED	3/29/2021	2	180	90
PLANNED	3/29/2021	1	19	19
PLANNED	3/29/2021	3	54	18
PLANNED	3/29/2021	10	2,410	241
PLANNED	3/29/2021	2	78	39
PLANNED	3/29/2021	9	2,709	301
PLANNED	3/29/2021	4	88	22
PLANNED	3/29/2021	4	1,428	357
PLANNED	3/29/2021	2	314	157
PLANNED	3/29/2021	3	78	26
PLANNED	3/29/2021	2	152	76
PLANNED	3/29/2021	3	39	13
PLANNED	3/29/2021	16	880	55
PLANNED	3/29/2021	16	944	59
PLANNED	3/29/2021	7	49	7
PLANNED	3/29/2021	1	38	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/29/2021	8	48	6
PLANNED	3/29/2021	9	261	29
PLANNED	3/29/2021	2	42	21
PLANNED	3/29/2021	9	324	36
PLANNED	3/29/2021	2	159	98
PLANNED	3/29/2021	4	100	25
PLANNED	3/29/2021	2	52	26
PLANNED	3/29/2021	3	117	39
PLANNED	3/29/2021	1	81	81
CUSTOMER REQUEST	3/29/2021	1	52	52
PLANNED	3/29/2021	2	126	63
PLANNED	3/29/2021	6	204	34
PLANNED	3/29/2021	5	90	18
PLANNED	3/29/2021	1	76	76
PLANNED	3/29/2021	2	508	254
PLANNED	3/29/2021	2	70	35
PLANNED	3/29/2021	19	2,907	153
PLANNED	3/29/2021	3	456	152
PLANNED	3/29/2021	10	260	26
PLANNED	3/29/2021	1	27	27
PLANNED	3/29/2021	1	22	22
PLANNED	3/29/2021	4	96	24
PLANNED	3/29/2021	4	76	19
PLANNED	3/29/2021	9	711	79
PLANNED	3/29/2021	14	1,022	73
PLANNED	3/29/2021	2	92	46
PLANNED	3/29/2021	7	553	79
PLANNED	3/29/2021	3	72	24
PLANNED	3/29/2021	10	270	27
PLANNED	3/29/2021	2	92	46
PLANNED	3/29/2021	1	131	131
PLANNED	3/29/2021	2	510	255
PLANNED	3/29/2021	2	72	36
PLANNED	3/29/2021	1	30	30
PLANNED	3/29/2021	1	7	7
PLANNED	3/29/2021	3	393	131
PLANNED	3/29/2021	2	34	17
PLANNED	3/29/2021	2	102	51
PLANNED	3/29/2021	9	126	14
PLANNED	3/29/2021	2	392	196
PLANNED	3/29/2021	1	121	121

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/29/2021	1	32	32
PLANNED	3/29/2021	2	4	2
PLANNED	3/29/2021	5	510	102
PLANNED	3/29/2021	4	538	170
PLANNED	3/29/2021	3	117	39
CUSTOMER REQUEST	3/29/2021	4	20	5
PLANNED	3/29/2021	3	42	14
CUSTOMER REQUEST	3/29/2021	4	124	31
PLANNED	3/29/2021	3	315	105
PLANNED	3/29/2021	4	184	46
PLANNED	3/29/2021	3	12	4
PLANNED	3/29/2021	11	704	64
PLANNED	3/29/2021	2	114	57
PLANNED	3/29/2021	8	32	4
PLANNED	3/29/2021	1	161	161
PLANNED	3/29/2021	3	369	123
CUSTOMER REQUEST	3/29/2021	5	15	3
PLANNED	3/29/2021	6	96	16
PLANNED	3/29/2021	7	21	3
PLANNED	3/29/2021	12	492	41
PLANNED	3/29/2021	8	760	95
PLANNED	3/29/2021	1	111	111
PLANNED	3/29/2021	3	33	11
PLANNED	3/29/2021	19	1,330	70
PLANNED	3/29/2021	3	1,101	367
PLANNED	3/29/2021	1	194	194
PLANNED	3/29/2021	1	196	196
PLANNED	3/29/2021	1	205	205
PLANNED	3/29/2021	10	1,440	144
PLANNED	3/29/2021	13	806	62
PLANNED	3/29/2021	9	180	20
PLANNED	3/29/2021	1	53	53
PLANNED	3/29/2021	4	684	171
PLANNED	3/29/2021	3	75	25
PLANNED	3/30/2021	1	47	47
PLANNED	3/30/2021	5	225	45
PLANNED	3/30/2021	6	204	34
PLANNED	3/30/2021	4	132	33
PLANNED	3/30/2021	9	297	33
CUSTOMER REQUEST	3/30/2021	1	203	203
PLANNED	3/30/2021	2	194	97

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/30/2021	1	62	62
PLANNED	3/30/2021	3	519	283
PLANNED	3/30/2021	3	497	345
PLANNED	3/30/2021	4	156	39
PLANNED	3/30/2021	7	763	109
PLANNED	3/30/2021	3	48	16
PLANNED	3/30/2021	2	108	54
PLANNED	3/30/2021	14	924	66
PLANNED	3/30/2021	3	66	22
PLANNED	3/30/2021	4	132	33
PLANNED	3/30/2021	8	416	52
PLANNED	3/30/2021	13	910	70
PLANNED	3/30/2021	2	120	60
PLANNED	3/30/2021	4	456	114
PLANNED	3/30/2021	3	165	55
PLANNED	3/30/2021	18	396	22
PLANNED	3/30/2021	1	59	59
PLANNED	3/30/2021	1	57	57
PLANNED	3/30/2021	3	181	80
CUSTOMER REQUEST	3/30/2021	2	94	47
PLANNED	3/30/2021	4	108	27
PLANNED	3/30/2021	6	18	3
PLANNED	3/30/2021	2	120	60
PLANNED	3/30/2021	6	150	25
PLANNED	3/30/2021	6	1,650	418
PLANNED	3/30/2021	5	450	90
PLANNED	3/30/2021	5	445	89
PLANNED	3/30/2021	5	445	89
PLANNED	3/30/2021	48	48	1
CUSTOMER REQUEST	3/30/2021	1	435	435
PLANNED	3/30/2021	1	39	39
PLANNED	3/30/2021	2	42	21
CUSTOMER REQUEST	3/30/2021	1	189	189
PLANNED	3/30/2021	8	168	21
PLANNED	3/30/2021	2	698	349
PLANNED	3/30/2021	7	2,048	400
PLANNED	3/30/2021	4	56	14
PLANNED	3/30/2021	8	424	53
PLANNED	3/30/2021	29	3,074	106
CUSTOMER REQUEST	3/30/2021	1	307	307
PLANNED	3/30/2021	3	84	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/30/2021	1	127	127
PLANNED	3/30/2021	7	182	26
PLANNED	3/30/2021	4	152	38
PLANNED	3/30/2021	3	555	185
CUSTOMER REQUEST	3/30/2021	40	2,240	56
PLANNED	3/30/2021	5	365	73
PLANNED	3/30/2021	4	908	227
PLANNED	3/30/2021	4	228	57
PLANNED	3/30/2021	4	60	15
PLANNED	3/30/2021	1	112	112
PLANNED	3/30/2021	6	168	28
PLANNED	3/30/2021	4	120	30
PLANNED	3/30/2021	12	4,056	338
PLANNED	3/30/2021	6	474	79
PLANNED	3/30/2021	6	282	47
PLANNED	3/30/2021	1	165	165
PLANNED	3/30/2021	16	400	25
PLANNED	3/30/2021	2	76	38
CUSTOMER REQUEST	3/30/2021	3	369	123
PLANNED	3/30/2021	1	225	225
PLANNED	3/30/2021	2	132	66
CUSTOMER REQUEST	3/30/2021	3	351	117
PLANNED	3/30/2021	1	137	137
PLANNED	3/30/2021	8	400	50
PLANNED	3/30/2021	1	140	140
PLANNED	3/30/2021	6	342	57
PLANNED	3/30/2021	2	372	186
PLANNED	3/30/2021	7	357	51
PLANNED	3/30/2021	1	35	35
PLANNED	3/30/2021	4	236	59
PLANNED	3/30/2021	3	15	5
PLANNED	3/30/2021	1	103	103
PLANNED	3/30/2021	3	57	19
PLANNED	3/30/2021	4	108	27
PLANNED	3/30/2021	1	3	3
PLANNED	3/30/2021	14	2,702	193
PLANNED	3/30/2021	2	328	164
PLANNED	3/30/2021	1	36	36
PLANNED	3/30/2021	8	1,408	176
PLANNED	3/30/2021	8	672	84
PLANNED	3/30/2021	4	88	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/30/2021	4	716	179
PLANNED	3/30/2021	10	760	76
PLANNED	3/30/2021	7	538	82
PLANNED	3/30/2021	3	72	24
PLANNED	3/30/2021	4	140	35
PLANNED	3/30/2021	6	1,698	283
PLANNED	3/30/2021	4	144	36
PLANNED	3/30/2021	3	171	57
CUSTOMER REQUEST	3/30/2021	1	43	43
PLANNED	3/30/2021	9	90	10
PLANNED	3/30/2021	4	360	90
PLANNED	3/30/2021	13	507	39
PLANNED	3/30/2021	6	1,164	194
PLANNED	3/30/2021	5	65	13
PLANNED	3/30/2021	2	266	133
PLANNED	3/30/2021	2	134	67
PLANNED	3/30/2021	4	80	20
PLANNED	3/30/2021	4	136	34
PLANNED	3/30/2021	5	505	101
PLANNED	3/30/2021	19	247	13
PLANNED	3/30/2021	4	140	35
PLANNED	3/30/2021	9	306	34
PLANNED	3/30/2021	4	52	13
PLANNED	3/30/2021	8	688	86
PLANNED	3/30/2021	4	784	196
PLANNED	3/30/2021	3	87	29
PLANNED	3/30/2021	4	96	24
PLANNED	3/30/2021	10	300	30
PLANNED	3/30/2021	3	316	116
PLANNED	3/30/2021	2	91	47
PLANNED	3/30/2021	2	356	178
PLANNED	3/30/2021	4	100	25
PLANNED	3/30/2021	3	504	168
CUSTOMER REQUEST	3/30/2021	1	530	530
PLANNED	3/30/2021	5	75	15
PLANNED	3/30/2021	1	27	27
PLANNED	3/30/2021	2	372	186
PLANNED	3/30/2021	7	165	69
PLANNED	3/30/2021	2	66	33
PLANNED	3/30/2021	1	13	13
CUSTOMER REQUEST	3/30/2021	1	26	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/30/2021	3	244	141
PLANNED	3/30/2021	8	288	36
PLANNED	3/30/2021	3	327	109
PLANNED	3/30/2021	4	220	55
PLANNED	3/30/2021	1	47	47
PLANNED	3/30/2021	2	66	33
PLANNED	3/30/2021	3	42	14
PLANNED	3/30/2021	14	1,554	111
PLANNED	3/30/2021	4	68	17
PLANNED	3/30/2021	3	156	52
CUSTOMER REQUEST	3/30/2021	1	120	120
PLANNED	3/30/2021	3	303	101
PLANNED	3/30/2021	5	205	41
PLANNED	3/30/2021	3	213	71
CUSTOMER REQUEST	3/30/2021	1	117	117
PLANNED	3/30/2021	1	104	104
CUSTOMER REQUEST	3/30/2021	1	207	207
CUSTOMER REQUEST	3/30/2021	1	30	30
PLANNED	3/30/2021	3	582	194
PLANNED	3/30/2021	1	1,564	1,564
PLANNED	3/30/2021	2	538	269
PLANNED	3/30/2021	1	147	147
PLANNED	3/30/2021	1	210	210
PLANNED	3/30/2021	30	3,030	101
PLANNED	3/30/2021	9	2,592	288
CUSTOMER REQUEST	3/31/2021	1	530	530
PLANNED	3/31/2021	1	125	125
PLANNED	3/31/2021	1	152	152
PLANNED	3/31/2021	16	3,680	230
PLANNED	3/31/2021	4	76	19
PLANNED	3/31/2021	1	9	9
PLANNED	3/31/2021	1	70	70
PLANNED	3/31/2021	8	584	73
PLANNED	3/31/2021	5	400	80
PLANNED	3/31/2021	2	126	63
PLANNED	3/31/2021	2	466	233
PLANNED	3/31/2021	1	61	61
CUSTOMER REQUEST	3/31/2021	6	150	25
PLANNED	3/31/2021	1	133	133

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/31/2021	2	270	135
PLANNED	3/31/2021	4	88	22
PLANNED	3/31/2021	1	9	9
PLANNED	3/31/2021	2	484	242
PLANNED	3/31/2021	8	288	36
CUSTOMER REQUEST	3/31/2021	44	13,596	309
CUSTOMER REQUEST	3/31/2021	8	24	3
CUSTOMER REQUEST	3/31/2021	1	76	76
PLANNED	3/31/2021	6	570	95
PLANNED	3/31/2021	4	112	28
CUSTOMER REQUEST	3/31/2021	1	540	540
CUSTOMER REQUEST	3/31/2021	1	309	309
PLANNED	3/31/2021	1	134	134
PLANNED	3/31/2021	1	80	80
PLANNED	3/31/2021	22	2,640	120
PLANNED	3/31/2021	15	210	14
PLANNED	3/31/2021	7	21	3
PLANNED	3/31/2021	3	30	10
PLANNED	3/31/2021	6	732	122
PLANNED	3/31/2021	3	391	151
PLANNED	3/31/2021	10	1,450	145
PLANNED	3/31/2021	6	852	142
PLANNED	3/31/2021	1	29	29
PLANNED	3/31/2021	6	114	19
PLANNED	3/31/2021	1	94	94
PLANNED	3/31/2021	6	536	156
PLANNED	3/31/2021	2	178	89
PLANNED	3/31/2021	5	105	21
PLANNED	3/31/2021	17	136	8
PLANNED	3/31/2021	1	27	27
PLANNED	3/31/2021	2	36	18
PLANNED	3/31/2021	4	144	36
PLANNED	3/31/2021	1	329	329
PLANNED	3/31/2021	31	4,805	155
PLANNED	3/31/2021	1	45	45
CUSTOMER REQUEST	3/31/2021	12	504	42
PLANNED	3/31/2021	1	35	35
PLANNED	3/31/2021	1	102	102
PLANNED	3/31/2021	1	102	102
PLANNED	3/31/2021	7	350	50
PLANNED	3/31/2021	2	188	94

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/31/2021	1	14	14
PLANNED	3/31/2021	5	458	94
PLANNED	3/31/2021	1	99	99
PLANNED	3/31/2021	1	320	320
PLANNED	3/31/2021	2	20	10
PLANNED	3/31/2021	2	220	110
PLANNED	3/31/2021	4	116	29
PLANNED	3/31/2021	8	616	77
PLANNED	3/31/2021	4	300	75
PLANNED	3/31/2021	4	492	123
PLANNED	3/31/2021	2	344	172
PLANNED	3/31/2021	37	814	22
PLANNED	3/31/2021	3	36	12
PLANNED	3/31/2021	2	268	134
PLANNED	3/31/2021	1	128	128
PLANNED	3/31/2021	3	360	120
PLANNED	3/31/2021	4	256	64
PLANNED	3/31/2021	14	420	30
PLANNED	3/31/2021	1	87	87
PLANNED	3/31/2021	3	1,161	387
PLANNED	3/31/2021	1	21	21
PLANNED	3/31/2021	10	560	56
PLANNED	3/31/2021	4	120	30
PLANNED	3/31/2021	2	6	3
PLANNED	3/31/2021	39	4,173	107
PLANNED	3/31/2021	5	405	81
PLANNED	3/31/2021	8	1,080	135
PLANNED	3/31/2021	3	417	139
PLANNED	3/31/2021	1	11	11
PLANNED	3/31/2021	2	18	9
PLANNED	3/31/2021	2	90	45
PLANNED	3/31/2021	4	160	40
CUSTOMER REQUEST	3/31/2021	3	57	19
PLANNED	3/31/2021	30	630	21
PLANNED	3/31/2021	1	166	166
PLANNED	3/31/2021	1	21	21
PLANNED	3/31/2021	1	31	31
PLANNED	3/31/2021	6	1,602	267
PLANNED	3/31/2021	3	60	20
PLANNED	3/31/2021	2	308	154
PLANNED	3/31/2021	2	42	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/31/2021	7	532	76
PLANNED	3/31/2021	3	195	65
PLANNED	3/31/2021	1	95	95
PLANNED	3/31/2021	3	264	88
PLANNED	3/31/2021	1	27	27
CUSTOMER REQUEST	3/31/2021	1	38	38
PLANNED	3/31/2021	8	1,344	168
PLANNED	3/31/2021	5	185	37
PLANNED	3/31/2021	2	112	56
PLANNED	3/31/2021	3	561	187
PLANNED	3/31/2021	2	144	72
PLANNED	3/31/2021	4	60	15
PLANNED	3/31/2021	2	18	9
PLANNED	3/31/2021	3	30	10
PLANNED	3/31/2021	3	387	129
PLANNED	3/31/2021	1	23	23
PLANNED	3/31/2021	6	270	45
PLANNED	3/31/2021	8	1,424	178
PLANNED	3/31/2021	14	280	20
PLANNED	3/31/2021	3	204	68
PLANNED	3/31/2021	8	1,016	127
PLANNED	3/31/2021	13	104	8
PLANNED	3/31/2021	4	196	49
PLANNED	3/31/2021	14	1,554	111
PLANNED	3/31/2021	4	192	48
PLANNED	3/31/2021	9	135	15
CUSTOMER REQUEST	3/31/2021	2	66	33
PLANNED	3/31/2021	7	98	14
PLANNED	3/31/2021	7	399	57
PLANNED	3/31/2021	4	92	23
CUSTOMER REQUEST	3/31/2021	7	490	70
PLANNED	3/31/2021	1	17	17
PLANNED	3/31/2021	8	256	32
PLANNED	3/31/2021	4	128	32
PLANNED	3/31/2021	4	92	23
PLANNED	3/31/2021	4	100	25
PLANNED	3/31/2021	3	27	9
PLANNED	3/31/2021	27	540	20
PLANNED	3/31/2021	6	234	39
PLANNED	3/31/2021	4	16	4
PLANNED	3/31/2021	7	602	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/31/2021	4	552	138
PLANNED	3/31/2021	4	320	80
CUSTOMER REQUEST	3/31/2021	1	151	151
PLANNED	3/31/2021	3	57	19
PLANNED	3/31/2021	2	76	53
PLANNED	3/31/2021	3	162	54
PLANNED	3/31/2021	1	53	53
CUSTOMER REQUEST	3/31/2021	2	24	12
PLANNED	3/31/2021	4	608	152
PLANNED	3/31/2021	1	20	20
PLANNED	3/31/2021	2	202	101
PLANNED	3/31/2021	5	450	90
PLANNED	3/31/2021	2	50	25
PLANNED	3/31/2021	15	90	6
PLANNED	3/31/2021	4	60	15
PLANNED	3/31/2021	4	100	25
PLANNED	3/31/2021	4	152	38
PLANNED	3/31/2021	9	558	62
PLANNED	3/31/2021	1	100	100
PLANNED	3/31/2021	4	28	7
PLANNED	3/31/2021	6	1,302	217
PLANNED	3/31/2021	1	20	20
PLANNED	3/31/2021	1	40	40
PLANNED	3/31/2021	6	30	5
PLANNED	3/31/2021	15	75	5
PLANNED	3/31/2021	3	327	109
PLANNED	3/31/2021	13	728	56
PLANNED	3/31/2021	2	292	146
PLANNED	3/31/2021	1	42	42
PLANNED	3/31/2021	4	228	57
PLANNED	3/31/2021	4	60	15
PLANNED	3/31/2021	2	72	36
CUSTOMER REQUEST	3/31/2021	8	32	4
PLANNED	3/31/2021	2	109	66
PLANNED	3/31/2021	6	204	34
PLANNED	3/31/2021	2	114	57
PLANNED	3/31/2021	1	63	63
PLANNED	3/31/2021	1	89	89
PLANNED	3/31/2021	5	200	40
PLANNED	3/31/2021	1	67	67
PLANNED	3/31/2021	3	63	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	3/31/2021	6	180	30
PLANNED	3/31/2021	1	22	22
PLANNED	3/31/2021	1	66	66
PLANNED	3/31/2021	2	110	61
PLANNED	3/31/2021	7	455	65
PLANNED	3/31/2021	6	120	20
CUSTOMER REQUEST	3/31/2021	1	264	264
PLANNED	3/31/2021	6	348	58
PLANNED	3/31/2021	7	105	15
PLANNED	3/31/2021	6	96	16
PLANNED	3/31/2021	3	48	16
PLANNED	3/31/2021	2	228	114
PLANNED	3/31/2021	2	120	65
CUSTOMER REQUEST	3/31/2021	1	119	119
PLANNED	3/31/2021	2	88	44
PLANNED	3/31/2021	86	2,106	31
PLANNED	3/31/2021	15	330	22
PLANNED	3/31/2021	2	26	13
PLANNED	3/31/2021	12	1,536	128
PLANNED	3/31/2021	12	3,300	275
PLANNED	3/31/2021	1	195	195
PLANNED	3/31/2021	3	138	46
PLANNED	3/31/2021	1	69	69
PLANNED	3/31/2021	27	4,374	162
PLANNED	4/1/2021	3	351	117
PLANNED	4/1/2021	1	72	72
PLANNED	4/1/2021	3	258	86
PLANNED	4/1/2021	1	57	57
PLANNED	4/1/2021	11	1,001	91
PLANNED	4/1/2021	3	300	100
PLANNED	4/1/2021	5	35	7
PLANNED	4/1/2021	3	387	129
CUSTOMER REQUEST	4/1/2021	1	423	423
CUSTOMER REQUEST	4/1/2021	1	40	40
PLANNED	4/1/2021	1	38	38
PLANNED	4/1/2021	4	240	81
PLANNED	4/1/2021	1	68	68
PLANNED	4/1/2021	1	421	421
PLANNED	4/1/2021	1	45	45
PLANNED	4/1/2021	4	104	26
PLANNED	4/1/2021	2	294	147

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/1/2021	2	40	20
CUSTOMER REQUEST	4/1/2021	12	1,476	123
CUSTOMER REQUEST	4/1/2021	5	105	21
PLANNED	4/1/2021	6	186	31
PLANNED	4/1/2021	14	1,946	139
PLANNED	4/1/2021	11	1,155	217
PLANNED	4/1/2021	4	268	67
PLANNED	4/1/2021	1	168	168
PLANNED	4/1/2021	3	123	41
PLANNED	4/1/2021	13	208	16
CUSTOMER REQUEST	4/1/2021	17	85	5
PLANNED	4/1/2021	1	177	177
PLANNED	4/1/2021	2	82	41
PLANNED	4/1/2021	1	141	141
PLANNED	4/1/2021	8	480	60
PLANNED	4/1/2021	10	350	35
PLANNED	4/1/2021	1	220	220
PLANNED	4/1/2021	6	1,380	230
PLANNED	4/1/2021	6	324	54
PLANNED	4/1/2021	10	1,260	126
PLANNED	4/1/2021	2	276	138
CUSTOMER REQUEST	4/1/2021	2	286	143
CUSTOMER REQUEST	4/1/2021	80	9,200	115
PLANNED	4/1/2021	2	140	70
PLANNED	4/1/2021	3	108	36
PLANNED	4/1/2021	2	224	112
CUSTOMER REQUEST	4/1/2021	1	584	584
PLANNED	4/1/2021	5	200	40
PLANNED	4/1/2021	6	306	51
PLANNED	4/1/2021	7	42	6
PLANNED	4/1/2021	4	152	38
PLANNED	4/1/2021	5	200	40
CUSTOMER REQUEST	4/1/2021	5	40	8
PLANNED	4/1/2021	8	824	103
CUSTOMER REQUEST	4/1/2021	17	2,149	181
PLANNED	4/1/2021	7	721	103
PLANNED	4/1/2021	4	60	15
PLANNED	4/1/2021	3	24	8
PLANNED	4/1/2021	8	824	103
PLANNED	4/1/2021	2	130	65
PLANNED	4/1/2021	1	92	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/1/2021	7	329	47
CUSTOMER REQUEST	4/1/2021	61	3,599	59
PLANNED	4/1/2021	8	496	62
PLANNED	4/1/2021	5	345	69
CUSTOMER REQUEST	4/1/2021	6	18	3
CUSTOMER REQUEST	4/1/2021	7	309	273
PLANNED	4/1/2021	4	580	145
PLANNED	4/1/2021	3	66	22
CUSTOMER REQUEST	4/1/2021	1	15	15
PLANNED	4/1/2021	2	278	139
PLANNED	4/1/2021	6	258	43
PLANNED	4/1/2021	1	263	263
PLANNED	4/1/2021	1	21	21
PLANNED	4/1/2021	2	260	130
PLANNED	4/1/2021	5	55	11
PLANNED	4/1/2021	11	1,892	172
CUSTOMER REQUEST	4/1/2021	5	365	73
PLANNED	4/1/2021	11	2,431	221
PLANNED	4/1/2021	3	105	35
PLANNED	4/1/2021	7	49	7
PLANNED	4/1/2021	4	580	145
PLANNED	4/1/2021	6	396	66
PLANNED	4/1/2021	2	8	4
PLANNED	4/1/2021	4	108	27
PLANNED	4/1/2021	4	872	218
CUSTOMER REQUEST	4/1/2021	5	555	111
CUSTOMER REQUEST	4/1/2021	1	113	113
PLANNED	4/1/2021	5	140	28
PLANNED	4/1/2021	3	78	26
PLANNED	4/1/2021	10	580	58
PLANNED	4/1/2021	9	306	34
PLANNED	4/1/2021	1	23	23
PLANNED	4/1/2021	16	1,360	85
CUSTOMER REQUEST	4/1/2021	7	126	18
PLANNED	4/1/2021	13	130	10
PLANNED	4/1/2021	3	464	319
PLANNED	4/1/2021	6	456	76
PLANNED	4/1/2021	2	202	101
PLANNED	4/1/2021	4	8	2
PLANNED	4/1/2021	4	444	111
PLANNED	4/1/2021	3	129	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/1/2021	8	752	94
PLANNED	4/1/2021	3	429	143
PLANNED	4/1/2021	2	126	63
CUSTOMER REQUEST	4/1/2021	6	108	18
PLANNED	4/1/2021	2	618	309
PLANNED	4/1/2021	2	226	113
PLANNED	4/1/2021	2	188	94
PLANNED	4/1/2021	1	116	116
PLANNED	4/1/2021	4	264	66
PLANNED	4/1/2021	5	205	41
PLANNED	4/1/2021	10	110	11
PLANNED	4/1/2021	5	705	141
PLANNED	4/1/2021	3	300	100
PLANNED	4/1/2021	2	12	6
CUSTOMER REQUEST	4/1/2021	10	790	79
CUSTOMER REQUEST	4/1/2021	1	31	31
PLANNED	4/1/2021	3	75	25
PLANNED	4/1/2021	3	165	55
PLANNED	4/1/2021	5	160	32
PLANNED	4/1/2021	5	215	43
PLANNED	4/1/2021	5	80	16
PLANNED	4/1/2021	8	464	58
CUSTOMER REQUEST	4/1/2021	1	135	135
CUSTOMER REQUEST	4/1/2021	11	605	55
PLANNED	4/1/2021	4	132	33
CUSTOMER REQUEST	4/1/2021	9	54	6
PLANNED	4/1/2021	12	168	14
PLANNED	4/1/2021	9	2,142	238
PLANNED	4/1/2021	11	374	34
PLANNED	4/1/2021	2	20	10
PLANNED	4/1/2021	1	42	42
PLANNED	4/1/2021	10	400	40
PLANNED	4/1/2021	3	27	9
PLANNED	4/1/2021	6	384	64
PLANNED	4/1/2021	1	30	30
PLANNED	4/1/2021	4	40	10
CUSTOMER REQUEST	4/1/2021	6	54	9
PLANNED	4/1/2021	2	160	80
PLANNED	4/1/2021	2	171	97
PLANNED	4/1/2021	4	32	8
PLANNED	4/1/2021	5	160	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/1/2021	30	2,430	81
PLANNED	4/1/2021	3	345	115
PLANNED	4/1/2021	4	88	22
PLANNED	4/1/2021	4	532	133
PLANNED	4/1/2021	4	52	13
PLANNED	4/1/2021	3	57	19
PLANNED	4/1/2021	2	186	93
PLANNED	4/1/2021	1	88	88
PLANNED	4/1/2021	3	242	114
PLANNED	4/1/2021	2	20	10
PLANNED	4/1/2021	1	240	240
PLANNED	4/1/2021	2	38	34
PLANNED	4/1/2021	3	60	20
PLANNED	4/1/2021	5	115	23
PLANNED	4/1/2021	6	72	12
PLANNED	4/1/2021	1	80	80
PLANNED	4/1/2021	8	96	12
PLANNED	4/1/2021	2	40	20
PLANNED	4/1/2021	1	227	227
PLANNED	4/1/2021	6	750	125
PLANNED	4/1/2021	10	1,210	121
PLANNED	4/1/2021	3	246	82
CUSTOMER REQUEST	4/1/2021	4	464	116
PLANNED	4/1/2021	1	110	110
PLANNED	4/1/2021	7	287	41
PLANNED	4/1/2021	2	178	89
PLANNED	4/1/2021	4	64	16
PLANNED	4/1/2021	3	63	21
PLANNED	4/1/2021	10	920	92
PLANNED	4/1/2021	3	216	72
PLANNED	4/1/2021	4	928	232
PLANNED	4/1/2021	2	44	22
PLANNED	4/1/2021	1	77	77
PLANNED	4/1/2021	1	10	10
CUSTOMER REQUEST	4/1/2021	1	130	130
PLANNED	4/1/2021	16	256	16
PLANNED	4/1/2021	1	192	192
PLANNED	4/1/2021	2	360	180
PLANNED	4/1/2021	7	980	140
PLANNED	4/1/2021	2	196	98
PLANNED	4/1/2021	1	487	487

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/1/2021	2	104	52
PLANNED	4/1/2021	2	86	43
PLANNED	4/1/2021	11	946	86
PLANNED	4/1/2021	1	134	134
PLANNED	4/1/2021	2	180	90
PLANNED	4/2/2021	1	111	111
PLANNED	4/2/2021	14	1,876	134
PLANNED	4/2/2021	1	186	186
PLANNED	4/2/2021	4	180	45
PLANNED	4/2/2021	3	168	56
PLANNED	4/2/2021	1	132	132
PLANNED	4/2/2021	2	302	151
PLANNED	4/2/2021	2	548	274
PLANNED	4/2/2021	2	42	21
PLANNED	4/2/2021	1	100	100
PLANNED	4/2/2021	3	51	17
PLANNED	4/2/2021	1	74	74
PLANNED	4/2/2021	1	131	131
PLANNED	4/2/2021	10	770	77
PLANNED	4/2/2021	3	87	29
PLANNED	4/2/2021	4	200	50
PLANNED	4/2/2021	3	759	253
CUSTOMER REQUEST	4/2/2021	2	72	36
PLANNED	4/2/2021	4	276	69
PLANNED	4/2/2021	7	784	112
PLANNED	4/2/2021	2	210	105
PLANNED	4/2/2021	3	21	7
PLANNED	4/2/2021	10	710	71
PLANNED	4/2/2021	10	1,620	162
PLANNED	4/2/2021	4	124	31
PLANNED	4/2/2021	7	812	116
PLANNED	4/2/2021	2	170	85
CUSTOMER REQUEST	4/2/2021	14	5,054	361
PLANNED	4/2/2021	9	1,989	221
PLANNED	4/2/2021	4	28	7
PLANNED	4/2/2021	6	816	136
PLANNED	4/2/2021	3	147	49
PLANNED	4/2/2021	4	840	210
PLANNED	4/2/2021	3	114	38
PLANNED	4/2/2021	2	318	159
PLANNED	4/2/2021	6	384	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/2/2021	7	525	75
PLANNED	4/2/2021	7	294	42
PLANNED	4/2/2021	1	63	63
PLANNED	4/2/2021	9	1,089	121
PLANNED	4/2/2021	10	670	67
PLANNED	4/2/2021	8	160	20
PLANNED	4/2/2021	6	1,026	171
PLANNED	4/2/2021	2	286	143
PLANNED	4/2/2021	1	192	192
PLANNED	4/2/2021	1	182	182
PLANNED	4/2/2021	2	122	61
PLANNED	4/2/2021	4	168	42
PLANNED	4/2/2021	5	350	70
PLANNED	4/2/2021	8	968	121
PLANNED	4/2/2021	7	924	132
PLANNED	4/2/2021	1	39	39
PLANNED	4/2/2021	1	73	73
PLANNED	4/2/2021	4	356	89
PLANNED	4/2/2021	2	286	143
PLANNED	4/2/2021	3	66	22
PLANNED	4/2/2021	2	52	26
PLANNED	4/2/2021	10	310	31
PLANNED	4/2/2021	3	165	55
PLANNED	4/2/2021	2	4	2
CUSTOMER REQUEST	4/2/2021	1	72	72
PLANNED	4/2/2021	6	606	101
PLANNED	4/2/2021	3	435	145
CUSTOMER REQUEST	4/2/2021	4	16	4
PLANNED	4/2/2021	1	57	57
PLANNED	4/2/2021	5	165	33
PLANNED	4/2/2021	2	12	6
PLANNED	4/2/2021	3	75	25
PLANNED	4/2/2021	1	84	84
PLANNED	4/2/2021	2	144	72
PLANNED	4/2/2021	1	139	139
PLANNED	4/2/2021	1	21	21
PLANNED	4/2/2021	2	14	7
PLANNED	4/2/2021	8	128	16
PLANNED	4/2/2021	1	12	12
PLANNED	4/2/2021	2	358	179
PLANNED	4/2/2021	3	54	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/2/2021	59	1,534	26
PLANNED	4/2/2021	7	651	93
PLANNED	4/2/2021	7	294	42
PLANNED	4/2/2021	7	168	24
PLANNED	4/2/2021	1	67	67
PLANNED	4/2/2021	8	224	28
PLANNED	4/2/2021	5	180	36
PLANNED	4/2/2021	1	27	27
PLANNED	4/2/2021	7	7	1
PLANNED	4/2/2021	3	213	71
PLANNED	4/2/2021	1	102	102
PLANNED	4/2/2021	2	146	73
PLANNED	4/3/2021	3	741	247
PLANNED	4/3/2021	1	215	215
PLANNED	4/3/2021	1	55	55
PLANNED	4/3/2021	1	164	164
PLANNED	4/3/2021	9	2,142	238
PLANNED	4/3/2021	3	246	82
PLANNED	4/3/2021	1	228	228
PLANNED	4/3/2021	1	73	73
PLANNED	4/3/2021	13	26	2
PLANNED	4/3/2021	2	60	30
PLANNED	4/3/2021	2	398	199
PLANNED	4/3/2021	2	120	60
PLANNED	4/3/2021	2	184	92
PLANNED	4/3/2021	4	356	89
PLANNED	4/3/2021	20	840	42
PLANNED	4/3/2021	2	34	17
PLANNED	4/3/2021	2	108	54
PLANNED	4/3/2021	2	152	76
PLANNED	4/3/2021	1	96	96
PLANNED	4/3/2021	2	266	133
PLANNED	4/3/2021	3	297	99
PLANNED	4/4/2021	3	705	235
PLANNED	4/4/2021	3	174	58
PLANNED	4/4/2021	26	3,796	146
PLANNED	4/4/2021	7	210	30
CUSTOMER REQUEST	4/4/2021	2	142	71
PLANNED	4/4/2021	1	51	51
PLANNED	4/4/2021	16	1,760	110
PLANNED	4/4/2021	2	104	52

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	4/5/2021	2	248	124
PLANNED	4/5/2021	4	204	51
PLANNED	4/5/2021	1	93	93
PLANNED	4/5/2021	3	813	271
PLANNED	4/5/2021	2	224	144
PLANNED	4/5/2021	2	162	81
PLANNED	4/5/2021	3	396	132
CUSTOMER REQUEST	4/5/2021	1	47	47
PLANNED	4/5/2021	1	147	147
PLANNED	4/5/2021	8	1,112	139
PLANNED	4/5/2021	3	150	50
PLANNED	4/5/2021	1	153	153
PLANNED	4/5/2021	10	2,330	233
PLANNED	4/5/2021	1	207	207
CUSTOMER REQUEST	4/5/2021	1	221	221
PLANNED	4/5/2021	10	1,160	116
PLANNED	4/5/2021	4	136	34
PLANNED	4/5/2021	24	1,200	50
PLANNED	4/5/2021	2	274	137
PLANNED	4/5/2021	1	121	121
PLANNED	4/5/2021	3	72	24
PLANNED	4/5/2021	1	77	77
PLANNED	4/5/2021	12	696	58
PLANNED	4/5/2021	2	82	41
PLANNED	4/5/2021	4	128	32
PLANNED	4/5/2021	1	90	90
CUSTOMER REQUEST	4/5/2021	1	306	306
PLANNED	4/5/2021	1	604	604
CUSTOMER REQUEST	4/5/2021	5	390	78
PLANNED	4/5/2021	3	510	170
PLANNED	4/5/2021	20	840	42
PLANNED	4/5/2021	10	2,790	382
PLANNED	4/5/2021	1	32	32
PLANNED	4/5/2021	7	707	101
PLANNED	4/5/2021	8	784	98
PLANNED	4/5/2021	2	54	27
PLANNED	4/5/2021	10	810	81
PLANNED	4/5/2021	17	3,228	340
PLANNED	4/5/2021	3	354	118
PLANNED	4/5/2021	1	98	98
PLANNED	4/5/2021	4	36	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/5/2021	4	156	39
PLANNED	4/5/2021	16	1,248	78
PLANNED	4/5/2021	2	194	97
CUSTOMER REQUEST	4/5/2021	1	54	54
PLANNED	4/5/2021	1	17	17
PLANNED	4/5/2021	16	1,264	79
PLANNED	4/5/2021	4	1,088	272
PLANNED	4/5/2021	1	273	273
PLANNED	4/5/2021	2	122	61
PLANNED	4/5/2021	1	84	84
PLANNED	4/5/2021	1	1	1
PLANNED	4/5/2021	2	300	150
PLANNED	4/5/2021	10	1,290	129
PLANNED	4/5/2021	2	22	11
PLANNED	4/5/2021	1	137	137
PLANNED	4/5/2021	12	1,728	144
PLANNED	4/5/2021	3	477	159
PLANNED	4/5/2021	1	68	68
PLANNED	4/5/2021	8	128	16
PLANNED	4/5/2021	3	198	66
PLANNED	4/5/2021	1	163	163
PLANNED	4/5/2021	3	234	78
PLANNED	4/5/2021	7	98	14
PLANNED	4/5/2021	4	640	160
PLANNED	4/5/2021	10	810	81
PLANNED	4/5/2021	6	186	31
PLANNED	4/5/2021	1	60	60
PLANNED	4/5/2021	1	72	72
PLANNED	4/5/2021	3	114	38
PLANNED	4/5/2021	3	438	146
PLANNED	4/5/2021	8	248	31
PLANNED	4/5/2021	1	99	99
PLANNED	4/5/2021	5	245	49
PLANNED	4/5/2021	9	1,269	141
PLANNED	4/5/2021	2	330	165
PLANNED	4/5/2021	1	137	137
CUSTOMER REQUEST	4/5/2021	8	120	15
PLANNED	4/5/2021	1	16	16
PLANNED	4/5/2021	10	300	146
PLANNED	4/5/2021	16	864	54
PLANNED	4/5/2021	14	1,036	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/5/2021	1	109	109
PLANNED	4/5/2021	2	82	41
PLANNED	4/5/2021	6	150	25
PLANNED	4/5/2021	1	48	48
PLANNED	4/5/2021	3	6	2
PLANNED	4/5/2021	9	522	58
PLANNED	4/5/2021	1	18	18
PLANNED	4/5/2021	1	170	170
PLANNED	4/5/2021	2	200	100
PLANNED	4/5/2021	9	517	108
PLANNED	4/5/2021	10	270	27
PLANNED	4/5/2021	5	230	46
PLANNED	4/5/2021	5	210	42
PLANNED	4/5/2021	2	46	23
PLANNED	4/5/2021	2	238	119
PLANNED	4/5/2021	1	77	77
PLANNED	4/5/2021	29	957	33
PLANNED	4/5/2021	4	92	23
CUSTOMER REQUEST	4/5/2021	8	168	21
PLANNED	4/5/2021	1	74	74
PLANNED	4/5/2021	4	368	92
PLANNED	4/5/2021	6	1,110	185
PLANNED	4/5/2021	10	130	13
PLANNED	4/5/2021	3	336	112
PLANNED	4/5/2021	2	42	21
PLANNED	4/5/2021	2	30	15
PLANNED	4/5/2021	1	117	117
PLANNED	4/5/2021	3	75	25
PLANNED	4/5/2021	1	208	208
PLANNED	4/5/2021	4	156	39
PLANNED	4/5/2021	4	396	99
PLANNED	4/5/2021	1	206	206
PLANNED	4/5/2021	6	384	64
PLANNED	4/5/2021	5	290	58
PLANNED	4/5/2021	1	21	21
PLANNED	4/5/2021	2	56	28
PLANNED	4/5/2021	10	260	26
PLANNED	4/5/2021	2	62	31
PLANNED	4/5/2021	1	3	3
PLANNED	4/5/2021	2	120	60
PLANNED	4/5/2021	1	54	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/5/2021	1	186	186
PLANNED	4/5/2021	2	154	77
CUSTOMER REQUEST	4/5/2021	7	175	25
PLANNED	4/5/2021	5	100	20
PLANNED	4/5/2021	8	208	26
PLANNED	4/5/2021	2	68	34
PLANNED	4/5/2021	1	67	67
PLANNED	4/5/2021	4	112	28
PLANNED	4/5/2021	1	131	131
PLANNED	4/5/2021	5	155	31
PLANNED	4/5/2021	8	144	18
PLANNED	4/5/2021	2	150	75
PLANNED	4/5/2021	3	219	73
PLANNED	4/5/2021	1	103	103
PLANNED	4/5/2021	4	72	18
PLANNED	4/5/2021	7	301	43
PLANNED	4/5/2021	5	80	16
PLANNED	4/5/2021	2	140	70
PLANNED	4/5/2021	1	41	41
PLANNED	4/5/2021	1	42	42
PLANNED	4/5/2021	1	227	227
PLANNED	4/5/2021	2	118	59
PLANNED	4/5/2021	2	72	36
PLANNED	4/5/2021	2	22	11
PLANNED	4/5/2021	5	730	146
PLANNED	4/5/2021	2	142	71
PLANNED	4/5/2021	4	132	33
PLANNED	4/5/2021	2	202	101
PLANNED	4/5/2021	2	72	36
PLANNED	4/5/2021	2	78	39
PLANNED	4/5/2021	2	40	20
PLANNED	4/5/2021	4	124	31
PLANNED	4/5/2021	2	324	162
PLANNED	4/5/2021	10	130	13
PLANNED	4/5/2021	1	30	30
PLANNED	4/5/2021	2	234	117
PLANNED	4/5/2021	3	186	62
PLANNED	4/5/2021	1	105	105
CUSTOMER REQUEST	4/5/2021	1	297	297
PLANNED	4/5/2021	1	53	53
PLANNED	4/5/2021	3	570	190

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/5/2021	2	94	47
PLANNED	4/5/2021	2	2	1
PLANNED	4/5/2021	2	42	21
PLANNED	4/5/2021	19	6,156	324
PLANNED	4/5/2021	1	34	34
CUSTOMER REQUEST	4/6/2021	615	25,830	42
PLANNED	4/6/2021	1	346	346
PLANNED	4/6/2021	2	146	73
PLANNED	4/6/2021	3	87	29
PLANNED	4/6/2021	4	724	181
PLANNED	4/6/2021	3	186	62
PLANNED	4/6/2021	1	146	146
PLANNED	4/6/2021	2	720	360
PLANNED	4/6/2021	2	252	126
PLANNED	4/6/2021	1	116	116
PLANNED	4/6/2021	1	105	105
PLANNED	4/6/2021	5	2,435	487
PLANNED	4/6/2021	1	135	135
PLANNED	4/6/2021	3	294	98
PLANNED	4/6/2021	2	196	98
PLANNED	4/6/2021	1	88	88
PLANNED	4/6/2021	1	157	157
PLANNED	4/6/2021	1	85	85
PLANNED	4/6/2021	5	90	18
CUSTOMER REQUEST	4/6/2021	10	160	16
PLANNED	4/6/2021	40	4,560	114
PLANNED	4/6/2021	2	56	28
PLANNED	4/6/2021	5	325	65
CUSTOMER REQUEST	4/6/2021	14	168	12
PLANNED	4/6/2021	1	61	61
PLANNED	4/6/2021	5	50	10
CUSTOMER REQUEST	4/6/2021	11	1,199	109
PLANNED	4/6/2021	3	177	59
PLANNED	4/6/2021	8	1,520	190
PLANNED	4/6/2021	11	231	21
PLANNED	4/6/2021	2	196	98
PLANNED	4/6/2021	41	7,257	177
PLANNED	4/6/2021	6	1,062	177
PLANNED	4/6/2021	1	85	85
CUSTOMER REQUEST	4/6/2021	3	66	22
PLANNED	4/6/2021	2	80	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/6/2021	8	360	45
PLANNED	4/6/2021	4	136	34
PLANNED	4/6/2021	10	370	37
PLANNED	4/6/2021	17	2,318	274
PLANNED	4/6/2021	7	168	24
PLANNED	4/6/2021	2	254	127
PLANNED	4/6/2021	2	56	28
PLANNED	4/6/2021	1	126	126
PLANNED	4/6/2021	1	65	65
PLANNED	4/6/2021	3	144	48
PLANNED	4/6/2021	1	10	10
PLANNED	4/6/2021	27	4,104	152
PLANNED	4/6/2021	1	76	76
PLANNED	4/6/2021	2	120	60
PLANNED	4/6/2021	9	234	26
PLANNED	4/6/2021	3	12	4
PLANNED	4/6/2021	5	365	73
PLANNED	4/6/2021	9	108	12
PLANNED	4/6/2021	1	8	8
PLANNED	4/6/2021	8	1,064	133
PLANNED	4/6/2021	13	1,664	128
PLANNED	4/6/2021	69	11,115	177
CUSTOMER REQUEST	4/6/2021	23	230	10
PLANNED	4/6/2021	4	188	47
PLANNED	4/6/2021	6	402	67
PLANNED	4/6/2021	4	48	12
PLANNED	4/6/2021	20	720	36
PLANNED	4/6/2021	2	344	172
PLANNED	4/6/2021	2	166	83
PLANNED	4/6/2021	1	19	19
PLANNED	4/6/2021	4	1,156	289
PLANNED	4/6/2021	3	219	73
PLANNED	4/6/2021	4	236	59
PLANNED	4/6/2021	4	336	84
PLANNED	4/6/2021	9	540	60
PLANNED	4/6/2021	4	52	13
PLANNED	4/6/2021	10	630	63
PLANNED	4/6/2021	3	36	12
PLANNED	4/6/2021	5	755	151
PLANNED	4/6/2021	1	126	126
PLANNED	4/6/2021	3	36	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/6/2021	4	12	3
PLANNED	4/6/2021	2	124	62
PLANNED	4/6/2021	3	78	26
PLANNED	4/6/2021	5	100	20
PLANNED	4/6/2021	3	33	11
PLANNED	4/6/2021	1	50	50
PLANNED	4/6/2021	2	68	34
PLANNED	4/6/2021	3	129	43
PLANNED	4/6/2021	3	276	92
PLANNED	4/6/2021	3	36	12
PLANNED	4/6/2021	5	115	23
PLANNED	4/6/2021	4	100	25
PLANNED	4/6/2021	1	50	50
PLANNED	4/6/2021	3	81	27
PLANNED	4/6/2021	1	11	11
PLANNED	4/6/2021	7	336	48
PLANNED	4/6/2021	2	120	60
PLANNED	4/6/2021	3	411	171
PLANNED	4/6/2021	1	35	35
PLANNED	4/6/2021	1	7	7
PLANNED	4/6/2021	2	36	18
PLANNED	4/6/2021	2	32	16
PLANNED	4/6/2021	6	234	111
PLANNED	4/6/2021	3	366	122
PLANNED	4/6/2021	1	86	86
PLANNED	4/6/2021	1	9	9
PLANNED	4/6/2021	2	24	12
PLANNED	4/6/2021	1	32	32
PLANNED	4/6/2021	8	72	9
PLANNED	4/6/2021	5	215	43
PLANNED	4/6/2021	4	100	25
PLANNED	4/6/2021	3	180	60
PLANNED	4/6/2021	1	36	36
PLANNED	4/6/2021	1	19	19
PLANNED	4/6/2021	1	9	9
PLANNED	4/6/2021	6	30	5
PLANNED	4/6/2021	5	135	27
PLANNED	4/6/2021	2	270	135
PLANNED	4/6/2021	18	792	44
PLANNED	4/6/2021	4	428	107
PLANNED	4/6/2021	2	30	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/6/2021	2	126	63
PLANNED	4/6/2021	3	81	27
CUSTOMER REQUEST	4/6/2021	4	124	31
PLANNED	4/6/2021	4	12	3
PLANNED	4/6/2021	4	116	29
PLANNED	4/6/2021	1	89	89
PLANNED	4/6/2021	7	1,036	148
PLANNED	4/6/2021	7	5,439	777
PLANNED	4/6/2021	3	51	17
PLANNED	4/6/2021	3	135	45
PLANNED	4/6/2021	4	600	150
PLANNED	4/6/2021	4	1,184	296
PLANNED	4/6/2021	2	40	20
PLANNED	4/6/2021	2	44	22
PLANNED	4/6/2021	12	12	1
PLANNED	4/6/2021	3	36	12
PLANNED	4/6/2021	3	219	73
PLANNED	4/6/2021	7	784	112
PLANNED	4/6/2021	4	412	103
PLANNED	4/6/2021	2	164	82
PLANNED	4/6/2021	4	76	19
PLANNED	4/6/2021	8	1,016	127
PLANNED	4/6/2021	1	144	144
PLANNED	4/6/2021	3	279	93
PLANNED	4/6/2021	2	123	89
PLANNED	4/6/2021	2	370	185
PLANNED	4/6/2021	5	660	132
PLANNED	4/6/2021	2	32	16
PLANNED	4/6/2021	2	96	48
PLANNED	4/6/2021	4	104	26
PLANNED	4/6/2021	1	82	82
PLANNED	4/6/2021	2	14	7
PLANNED	4/6/2021	8	176	22
PLANNED	4/6/2021	1	34	34
PLANNED	4/6/2021	1	23	23
PLANNED	4/6/2021	2	312	156
PLANNED	4/6/2021	2	152	76
PLANNED	4/6/2021	2	312	156
PLANNED	4/6/2021	3	108	36
PLANNED	4/6/2021	2	74	37
PLANNED	4/6/2021	21	1,575	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/6/2021	1	16	16
PLANNED	4/6/2021	2	12	6
PLANNED	4/6/2021	4	72	18
PLANNED	4/6/2021	13	1,946	170
PLANNED	4/6/2021	8	240	30
PLANNED	4/6/2021	9	306	34
PLANNED	4/6/2021	18	90	5
PLANNED	4/6/2021	1	64	64
PLANNED	4/6/2021	2	54	27
PLANNED	4/6/2021	3	84	28
PLANNED	4/6/2021	1	132	132
PLANNED	4/6/2021	2	170	85
PLANNED	4/6/2021	2	36	18
PLANNED	4/6/2021	23	805	35
PLANNED	4/6/2021	2	84	42
PLANNED	4/6/2021	2	148	74
PLANNED	4/6/2021	8	696	87
PLANNED	4/6/2021	1	83	83
PLANNED	4/6/2021	4	260	65
CUSTOMER REQUEST	4/6/2021	5	55	11
CUSTOMER REQUEST	4/6/2021	1	359	359
PLANNED	4/6/2021	2	216	108
PLANNED	4/6/2021	8	872	109
PLANNED	4/6/2021	1	68	68
PLANNED	4/6/2021	1	66	66
PLANNED	4/6/2021	3	117	39
PLANNED	4/6/2021	1	118	118
CUSTOMER REQUEST	4/6/2021	3	45	15
PLANNED	4/6/2021	1	74	74
PLANNED	4/6/2021	1	127	127
PLANNED	4/6/2021	8	2,112	264
PLANNED	4/7/2021	3	336	112
PLANNED	4/7/2021	1	61	61
PLANNED	4/7/2021	1	167	167
PLANNED	4/7/2021	1	153	153
PLANNED	4/7/2021	8	32	4
PLANNED	4/7/2021	6	204	34
PLANNED	4/7/2021	4	140	35
PLANNED	4/7/2021	1	81	81
PLANNED	4/7/2021	4	308	77
PLANNED	4/7/2021	4	184	46

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/7/2021	3	417	139
PLANNED	4/7/2021	4	152	38
PLANNED	4/7/2021	1	51	51
PLANNED	4/7/2021	3	3	1
PLANNED	4/7/2021	3	171	57
CUSTOMER REQUEST	4/7/2021	1	366	366
PLANNED	4/7/2021	1	76	76
PLANNED	4/7/2021	5	100	20
PLANNED	4/7/2021	11	869	79
CUSTOMER REQUEST	4/7/2021	1	14	14
PLANNED	4/7/2021	2	130	65
PLANNED	4/7/2021	1	71	71
PLANNED	4/7/2021	9	252	28
PLANNED	4/7/2021	1	69	69
PLANNED	4/7/2021	23	1,824	138
PLANNED	4/7/2021	1	69	69
PLANNED	4/7/2021	1	65	65
PLANNED	4/7/2021	20	1,964	129
PLANNED	4/7/2021	7	560	80
PLANNED	4/7/2021	7	294	42
PLANNED	4/7/2021	1	72	72
PLANNED	4/7/2021	1	186	186
PLANNED	4/7/2021	2	524	262
PLANNED	4/7/2021	2	48	24
PLANNED	4/7/2021	1	96	96
PLANNED	4/7/2021	2	128	64
PLANNED	4/7/2021	4	88	22
PLANNED	4/7/2021	2	64	32
PLANNED	4/7/2021	3	324	108
PLANNED	4/7/2021	7	602	86
PLANNED	4/7/2021	9	2,394	266
PLANNED	4/7/2021	19	399	21
PLANNED	4/7/2021	7	203	29
PLANNED	4/7/2021	4	200	50
PLANNED	4/7/2021	10	680	68
PLANNED	4/7/2021	3	165	55
PLANNED	4/7/2021	7	469	67
CUSTOMER REQUEST	4/7/2021	8	192	24
PLANNED	4/7/2021	12	456	38
CUSTOMER REQUEST	4/7/2021	60	11,940	199
CUSTOMER REQUEST	4/7/2021	6	72	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/7/2021	4	116	29
PLANNED	4/7/2021	3	45	15
PLANNED	4/7/2021	2	94	47
PLANNED	4/7/2021	3	114	38
PLANNED	4/7/2021	1	247	247
PLANNED	4/7/2021	4	320	80
CUSTOMER REQUEST	4/7/2021	10	60	6
PLANNED	4/7/2021	3	102	34
PLANNED	4/7/2021	3	63	21
PLANNED	4/7/2021	1	331	331
PLANNED	4/7/2021	4	248	62
PLANNED	4/7/2021	7	903	129
PLANNED	4/7/2021	2	212	106
PLANNED	4/7/2021	1	131	131
PLANNED	4/7/2021	8	416	52
PLANNED	4/7/2021	4	140	35
PLANNED	4/7/2021	4	4	1
PLANNED	4/7/2021	5	395	79
PLANNED	4/7/2021	2	158	79
PLANNED	4/7/2021	2	28	14
PLANNED	4/7/2021	2	222	111
PLANNED	4/7/2021	1	76	76
PLANNED	4/7/2021	5	900	180
PLANNED	4/7/2021	1	17	17
PLANNED	4/7/2021	1	26	26
PLANNED	4/7/2021	3	42	14
PLANNED	4/7/2021	25	3,825	153
PLANNED	4/7/2021	5	730	146
PLANNED	4/7/2021	4	204	51
PLANNED	4/7/2021	3	60	20
CUSTOMER REQUEST	4/7/2021	1	58	58
PLANNED	4/7/2021	55	220	4
PLANNED	4/7/2021	2	214	107
PLANNED	4/7/2021	6	648	108
PLANNED	4/7/2021	5	415	83
PLANNED	4/7/2021	8	248	31
PLANNED	4/7/2021	1	26	26
PLANNED	4/7/2021	2	112	56
PLANNED	4/7/2021	3	48	16
PLANNED	4/7/2021	1	13	13
PLANNED	4/7/2021	1	1	1

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/7/2021	2	86	43
PLANNED	4/7/2021	13	2,197	169
PLANNED	4/7/2021	2	550	275
PLANNED	4/7/2021	39	1,092	28
PLANNED	4/7/2021	5	1,075	215
PLANNED	4/7/2021	2	22	11
PLANNED	4/7/2021	2	192	96
PLANNED	4/7/2021	2	684	342
PLANNED	4/7/2021	6	474	79
PLANNED	4/7/2021	3	411	137
PLANNED	4/7/2021	1	15	15
PLANNED	4/7/2021	4	160	40
PLANNED	4/7/2021	2	30	15
PLANNED	4/7/2021	6	18	3
PLANNED	4/7/2021	7	980	140
PLANNED	4/7/2021	2	54	27
PLANNED	4/7/2021	3	435	145
PLANNED	4/7/2021	4	388	97
PLANNED	4/7/2021	18	1,206	67
PLANNED	4/7/2021	3	48	16
PLANNED	4/7/2021	3	432	144
PLANNED	4/7/2021	18	1,170	65
PLANNED	4/7/2021	1	70	70
PLANNED	4/7/2021	16	800	50
PLANNED	4/7/2021	3	147	49
PLANNED	4/7/2021	1	13	13
PLANNED	4/7/2021	2	148	74
PLANNED	4/7/2021	1	92	92
PLANNED	4/7/2021	2	70	35
PLANNED	4/7/2021	3	93	31
PLANNED	4/7/2021	1	41	41
CUSTOMER REQUEST	4/7/2021	143	10,010	70
PLANNED	4/7/2021	1	18	18
PLANNED	4/7/2021	1	10	10
PLANNED	4/7/2021	7	399	57
PLANNED	4/7/2021	1	133	133
PLANNED	4/7/2021	14	112	8
CUSTOMER REQUEST	4/7/2021	6	132	22
PLANNED	4/7/2021	1	104	104
PLANNED	4/7/2021	2	6	3
PLANNED	4/7/2021	3	57	19

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/7/2021	1	41	41
PLANNED	4/7/2021	4	92	23
PLANNED	4/7/2021	1	34	34
PLANNED	4/7/2021	6	288	48
PLANNED	4/7/2021	3	48	16
PLANNED	4/7/2021	3	51	17
PLANNED	4/7/2021	2	150	75
PLANNED	4/7/2021	3	237	79
PLANNED	4/7/2021	1	51	51
PLANNED	4/7/2021	2	4	2
PLANNED	4/7/2021	34	986	29
PLANNED	4/7/2021	15	360	24
CUSTOMER REQUEST	4/7/2021	2	130	65
CUSTOMER REQUEST	4/7/2021	1	10	10
PLANNED	4/7/2021	4	76	19
PLANNED	4/7/2021	6	390	65
CUSTOMER REQUEST	4/7/2021	1	96	96
PLANNED	4/7/2021	1	30	30
PLANNED	4/7/2021	4	840	210
PLANNED	4/7/2021	2	64	32
PLANNED	4/7/2021	1	9	9
PLANNED	4/7/2021	1	69	69
PLANNED	4/7/2021	3	126	42
PLANNED	4/7/2021	2	66	38
PLANNED	4/7/2021	3	183	61
PLANNED	4/7/2021	1	130	130
PLANNED	4/7/2021	4	80	20
PLANNED	4/7/2021	3	39	13
PLANNED	4/7/2021	2	120	60
PLANNED	4/7/2021	2	42	21
PLANNED	4/7/2021	2	177	91
PLANNED	4/7/2021	5	245	49
PLANNED	4/7/2021	3	93	31
PLANNED	4/7/2021	1	84	84
PLANNED	4/7/2021	5	210	42
PLANNED	4/7/2021	7	175	25
PLANNED	4/7/2021	3	438	146
PLANNED	4/7/2021	2	138	69
PLANNED	4/7/2021	2	134	67
PLANNED	4/7/2021	1	65	65
PLANNED	4/7/2021	3	84	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/7/2021	11	2,178	198
PLANNED	4/7/2021	8	584	73
PLANNED	4/7/2021	3	141	47
PLANNED	4/7/2021	1	127	127
PLANNED	4/7/2021	3	171	57
PLANNED	4/7/2021	9	378	42
PLANNED	4/7/2021	18	540	30
PLANNED	4/7/2021	2	88	44
PLANNED	4/7/2021	2	28	14
CUSTOMER REQUEST	4/7/2021	1	41	41
PLANNED	4/7/2021	51	1,326	26
PLANNED	4/7/2021	4	464	116
PLANNED	4/7/2021	1	6	6
PLANNED	4/7/2021	2	334	167
PLANNED	4/7/2021	1	300	300
CUSTOMER REQUEST	4/7/2021	1	173	173
PLANNED	4/7/2021	15	180	12
PLANNED	4/7/2021	35	18,095	517
PLANNED	4/7/2021	24	4,944	206
PLANNED	4/7/2021	5	575	115
PLANNED	4/7/2021	1	83	83
PLANNED	4/7/2021	1	272	272
PLANNED	4/7/2021	1	122	122
PLANNED	4/7/2021	2	426	213
PLANNED	4/8/2021	15	1,605	107
PLANNED	4/8/2021	1	164	164
PLANNED	4/8/2021	6	594	99
PLANNED	4/8/2021	25	125	5
PLANNED	4/8/2021	1	65	65
PLANNED	4/8/2021	12	1,704	142
PLANNED	4/8/2021	2	378	189
PLANNED	4/8/2021	18	1,602	89
PLANNED	4/8/2021	6	384	64
PLANNED	4/8/2021	8	504	63
PLANNED	4/8/2021	4	292	73
PLANNED	4/8/2021	2	64	32
PLANNED	4/8/2021	2	42	21
PLANNED	4/8/2021	2	198	99
PLANNED	4/8/2021	4	552	138
PLANNED	4/8/2021	3	312	104
PLANNED	4/8/2021	2	82	41

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/8/2021	1	120	120
PLANNED	4/8/2021	2	192	96
PLANNED	4/8/2021	1	29	29
PLANNED	4/8/2021	3	267	89
CUSTOMER REQUEST	4/8/2021	11	3,091	281
PLANNED	4/8/2021	2	36	18
PLANNED	4/8/2021	1	205	205
CUSTOMER REQUEST	4/8/2021	8	32	4
PLANNED	4/8/2021	3	729	243
PLANNED	4/8/2021	8	528	66
PLANNED	4/8/2021	1	61	61
PLANNED	4/8/2021	1	1	1
PLANNED	4/8/2021	3	438	146
PLANNED	4/8/2021	5	303	279
PLANNED	4/8/2021	7	63	9
PLANNED	4/8/2021	1	77	77
PLANNED	4/8/2021	6	210	35
PLANNED	4/8/2021	1	20	20
PLANNED	4/8/2021	2	230	115
PLANNED	4/8/2021	1	30	30
PLANNED	4/8/2021	5	140	28
PLANNED	4/8/2021	2	80	40
PLANNED	4/8/2021	7	1,463	209
PLANNED	4/8/2021	1	36	36
PLANNED	4/8/2021	16	832	52
PLANNED	4/8/2021	2	106	53
PLANNED	4/8/2021	1	176	176
PLANNED	4/8/2021	1	183	183
PLANNED	4/8/2021	3	102	34
PLANNED	4/8/2021	129	27,993	217
CUSTOMER REQUEST	4/8/2021	1	253	253
PLANNED	4/8/2021	1	26	26
PLANNED	4/8/2021	10	2,050	205
PLANNED	4/8/2021	2	60	30
PLANNED	4/8/2021	7	1,253	179
PLANNED	4/8/2021	2	26	13
PLANNED	4/8/2021	5	535	107
PLANNED	4/8/2021	1	56	56
PLANNED	4/8/2021	8	680	85
PLANNED	4/8/2021	8	672	84
PLANNED	4/8/2021	9	81	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/8/2021	7	441	63
PLANNED	4/8/2021	3	264	88
PLANNED	4/8/2021	4	132	33
PLANNED	4/8/2021	3	87	29
PLANNED	4/8/2021	5	395	79
PLANNED	4/8/2021	3	78	26
PLANNED	4/8/2021	7	819	117
CUSTOMER REQUEST	4/8/2021	4	96	24
PLANNED	4/8/2021	1	98	98
PLANNED	4/8/2021	3	387	195
PLANNED	4/8/2021	1	53	53
PLANNED	4/8/2021	4	268	67
PLANNED	4/8/2021	2	496	248
PLANNED	4/8/2021	2	296	148
PLANNED	4/8/2021	1	19	19
PLANNED	4/8/2021	4	80	20
PLANNED	4/8/2021	2	432	216
PLANNED	4/8/2021	3	189	63
PLANNED	4/8/2021	2	182	91
PLANNED	4/8/2021	22	22	1
PLANNED	4/8/2021	2	332	166
PLANNED	4/8/2021	1	123	123
CUSTOMER REQUEST	4/8/2021	3	231	107
PLANNED	4/8/2021	3	36	12
PLANNED	4/8/2021	2	166	83
PLANNED	4/8/2021	15	1,050	70
PLANNED	4/8/2021	1	196	196
PLANNED	4/8/2021	4	460	115
PLANNED	4/8/2021	6	42	7
PLANNED	4/8/2021	5	850	170
PLANNED	4/8/2021	13	2,028	156
PLANNED	4/8/2021	2	340	170
PLANNED	4/8/2021	6	510	85
PLANNED	4/8/2021	2	114	57
PLANNED	4/8/2021	2	50	25
PLANNED	4/8/2021	6	1,194	199
PLANNED	4/8/2021	1	464	464
PLANNED	4/8/2021	1	51	51
PLANNED	4/8/2021	6	390	65
CUSTOMER REQUEST	4/8/2021	1	53	53
PLANNED	4/8/2021	4	476	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/8/2021	4	84	21
PLANNED	4/8/2021	2	136	68
PLANNED	4/8/2021	2	48	24
PLANNED	4/8/2021	3	132	44
PLANNED	4/8/2021	2	20	10
PLANNED	4/8/2021	2	238	119
PLANNED	4/8/2021	2	292	146
CUSTOMER REQUEST	4/8/2021	8	176	22
PLANNED	4/8/2021	3	114	38
PLANNED	4/8/2021	13	2,418	186
PLANNED	4/8/2021	7	56	8
PLANNED	4/8/2021	4	32	8
PLANNED	4/8/2021	2	160	80
PLANNED	4/8/2021	3	99	33
PLANNED	4/8/2021	2	116	58
PLANNED	4/8/2021	4	56	14
PLANNED	4/8/2021	2	156	78
PLANNED	4/8/2021	1	16	16
PLANNED	4/8/2021	6	72	12
PLANNED	4/8/2021	3	114	38
PLANNED	4/8/2021	4	92	23
PLANNED	4/8/2021	10	390	39
PLANNED	4/8/2021	1	36	36
PLANNED	4/8/2021	3	123	54
PLANNED	4/8/2021	4	480	120
PLANNED	4/8/2021	2	42	21
PLANNED	4/8/2021	4	72	18
PLANNED	4/8/2021	1	70	70
PLANNED	4/8/2021	4	304	76
PLANNED	4/8/2021	8	200	25
PLANNED	4/8/2021	1	33	33
PLANNED	4/8/2021	6	150	25
PLANNED	4/8/2021	6	150	25
PLANNED	4/8/2021	5	125	25
PLANNED	4/8/2021	6	162	27
PLANNED	4/8/2021	3	54	18
PLANNED	4/8/2021	2	58	29
PLANNED	4/8/2021	1	82	82
PLANNED	4/8/2021	7	77	11
PLANNED	4/8/2021	5	120	24
PLANNED	4/8/2021	1	67	67

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/8/2021	2	46	23
PLANNED	4/8/2021	6	60	10
PLANNED	4/8/2021	1	116	116
PLANNED	4/8/2021	2	60	30
PLANNED	4/8/2021	2	56	28
PLANNED	4/8/2021	3	54	18
PLANNED	4/8/2021	3	48	16
PLANNED	4/8/2021	8	80	10
PLANNED	4/8/2021	26	1,794	69
PLANNED	4/8/2021	3	90	30
PLANNED	4/8/2021	7	49	7
PLANNED	4/8/2021	3	732	244
PLANNED	4/8/2021	4	64	16
PLANNED	4/8/2021	8	96	12
PLANNED	4/8/2021	4	248	62
PLANNED	4/8/2021	3	321	107
PLANNED	4/8/2021	2	204	102
PLANNED	4/8/2021	2	34	17
PLANNED	4/8/2021	2	256	128
CUSTOMER REQUEST	4/8/2021	1	31	31
PLANNED	4/8/2021	2	204	102
PLANNED	4/8/2021	2	126	63
PLANNED	4/8/2021	3	15	5
PLANNED	4/8/2021	1	19	19
PLANNED	4/8/2021	9	153	17
PLANNED	4/8/2021	1	110	110
PLANNED	4/8/2021	1	29	29
PLANNED	4/8/2021	4	96	24
PLANNED	4/8/2021	3	102	34
PLANNED	4/8/2021	2	108	54
PLANNED	4/8/2021	1	35	35
PLANNED	4/8/2021	4	192	48
PLANNED	4/8/2021	2	104	52
PLANNED	4/8/2021	8	584	73
PLANNED	4/8/2021	2	60	30
PLANNED	4/8/2021	2	60	30
PLANNED	4/8/2021	5	75	15
PLANNED	4/8/2021	1	146	146
PLANNED	4/8/2021	2	516	258
PLANNED	4/8/2021	1	1	1
PLANNED	4/8/2021	3	90	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/8/2021	3	498	166
PLANNED	4/8/2021	10	3,350	335
PLANNED	4/8/2021	1	87	87
PLANNED	4/8/2021	2	104	52
PLANNED	4/8/2021	1	232	232
PLANNED	4/8/2021	1	218	218
PLANNED	4/8/2021	5	2,100	420
PLANNED	4/8/2021	2	270	135
PLANNED	4/8/2021	7	1,414	202
PLANNED	4/8/2021	1	113	113
PLANNED	4/8/2021	1	73	73
PLANNED	4/8/2021	10	1,950	195
PLANNED	4/8/2021	4	696	174
PLANNED	4/9/2021	2	138	69
PLANNED	4/9/2021	27	3,915	145
PLANNED	4/9/2021	5	1,555	311
PLANNED	4/9/2021	1	74	74
PLANNED	4/9/2021	5	80	16
PLANNED	4/9/2021	4	676	169
PLANNED	4/9/2021	1	139	139
PLANNED	4/9/2021	2	530	265
PLANNED	4/9/2021	6	96	16
PLANNED	4/9/2021	8	712	89
PLANNED	4/9/2021	6	534	89
PLANNED	4/9/2021	7	623	89
PLANNED	4/9/2021	2	448	224
PLANNED	4/9/2021	8	704	88
PLANNED	4/9/2021	12	1,010	181
PLANNED	4/9/2021	2	400	200
PLANNED	4/9/2021	1	133	133
PLANNED	4/9/2021	6	630	105
PLANNED	4/9/2021	7	812	116
PLANNED	4/9/2021	8	848	106
PLANNED	4/9/2021	2	232	116
PLANNED	4/9/2021	8	808	101
PLANNED	4/9/2021	7	728	104
PLANNED	4/9/2021	1	54	54
PLANNED	4/9/2021	1	146	146
PLANNED	4/9/2021	3	156	52
PLANNED	4/9/2021	2	92	46
PLANNED	4/9/2021	2	148	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/9/2021	7	504	72
PLANNED	4/9/2021	2	54	27
CUSTOMER REQUEST	4/9/2021	5	45	9
PLANNED	4/9/2021	4	96	24
PLANNED	4/9/2021	4	340	85
CUSTOMER REQUEST	4/9/2021	7	231	33
PLANNED	4/9/2021	12	96	8
PLANNED	4/9/2021	9	324	36
PLANNED	4/9/2021	4	48	12
PLANNED	4/9/2021	4	164	41
PLANNED	4/9/2021	23	1,978	86
PLANNED	4/9/2021	1	59	59
PLANNED	4/9/2021	15	1,050	70
PLANNED	4/9/2021	17	1,071	63
CUSTOMER REQUEST	4/9/2021	1	79	79
PLANNED	4/9/2021	5	270	54
PLANNED	4/9/2021	3	51	17
PLANNED	4/9/2021	1	177	177
PLANNED	4/9/2021	5	455	91
PLANNED	4/9/2021	10	1,000	100
PLANNED	4/9/2021	8	96	12
PLANNED	4/9/2021	3	90	30
PLANNED	4/9/2021	11	1,100	100
PLANNED	4/9/2021	2	182	91
PLANNED	4/9/2021	2	82	41
PLANNED	4/9/2021	3	201	67
PLANNED	4/9/2021	20	240	12
PLANNED	4/9/2021	4	324	81
PLANNED	4/9/2021	4	236	59
PLANNED	4/9/2021	1	74	74
PLANNED	4/9/2021	3	174	58
PLANNED	4/9/2021	4	164	41
PLANNED	4/9/2021	2	84	42
PLANNED	4/9/2021	7	168	24
PLANNED	4/9/2021	1	18	18
PLANNED	4/9/2021	9	144	16
PLANNED	4/9/2021	9	216	24
CUSTOMER REQUEST	4/9/2021	4	76	19
PLANNED	4/9/2021	1	41	41
PLANNED	4/9/2021	131	786	6
PLANNED	4/9/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/9/2021	9	783	87
PLANNED	4/9/2021	6	846	141
PLANNED	4/9/2021	9	369	41
PLANNED	4/9/2021	2	48	24
PLANNED	4/9/2021	1	78	78
PLANNED	4/9/2021	1	66	66
CUSTOMER REQUEST	4/9/2021	7	42	6
PLANNED	4/9/2021	5	95	19
PLANNED	4/9/2021	3	199	95
PLANNED	4/9/2021	1	130	130
CUSTOMER REQUEST	4/9/2021	1	221	221
PLANNED	4/9/2021	1	211	211
PLANNED	4/9/2021	1	114	114
PLANNED	4/9/2021	8	112	14
PLANNED	4/9/2021	4	670	248
PLANNED	4/9/2021	13	455	35
CUSTOMER REQUEST	4/9/2021	8	788	370
PLANNED	4/9/2021	1	116	116
PLANNED	4/9/2021	3	174	58
CUSTOMER REQUEST	4/9/2021	5	25	5
PLANNED	4/9/2021	3	690	230
PLANNED	4/9/2021	1	54	54
PLANNED	4/9/2021	6	222	37
PLANNED	4/9/2021	2	134	67
PLANNED	4/9/2021	4	72	18
PLANNED	4/9/2021	5	360	72
PLANNED	4/9/2021	6	552	92
PLANNED	4/9/2021	2	66	33
PLANNED	4/9/2021	1	6	6
PLANNED	4/9/2021	1	29	29
PLANNED	4/9/2021	8	1,104	138
PLANNED	4/9/2021	4	128	32
PLANNED	4/9/2021	4	128	32
PLANNED	4/9/2021	4	48	12
PLANNED	4/9/2021	1	6	6
PLANNED	4/9/2021	2	18	9
CUSTOMER REQUEST	4/9/2021	1	28	28
PLANNED	4/9/2021	9	36	4
PLANNED	4/9/2021	1	66	66
PLANNED	4/9/2021	7	448	64
PLANNED	4/9/2021	11	264	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/9/2021	19	836	44
PLANNED	4/9/2021	13	1,261	97
PLANNED	4/9/2021	2	152	76
PLANNED	4/9/2021	4	72	18
PLANNED	4/9/2021	2	56	28
PLANNED	4/9/2021	2	134	67
CUSTOMER REQUEST	4/9/2021	1	62	62
PLANNED	4/9/2021	7	805	115
CUSTOMER REQUEST	4/9/2021	4	16	4
CUSTOMER REQUEST	4/9/2021	1	244	244
PLANNED	4/9/2021	2	276	138
CUSTOMER REQUEST	4/9/2021	1	138	138
PLANNED	4/9/2021	3	81	27
CUSTOMER REQUEST	4/10/2021	40	12,448	1,136
PLANNED	4/10/2021	2	268	134
PLANNED	4/10/2021	9	1,089	121
PLANNED	4/10/2021	7	1,148	164
PLANNED	4/10/2021	28	1,344	48
PLANNED	4/10/2021	12	2,160	180
PLANNED	4/10/2021	2	206	103
PLANNED	4/10/2021	4	1,288	322
PLANNED	4/10/2021	3	894	298
PLANNED	4/10/2021	5	430	86
PLANNED	4/10/2021	1	264	264
PLANNED	4/10/2021	5	430	86
PLANNED	4/10/2021	1	99	99
PLANNED	4/10/2021	24	1,416	59
PLANNED	4/11/2021	7	301	43
CUSTOMER REQUEST	4/11/2021	78	2,652	34
PLANNED	4/11/2021	18	1,746	97
PLANNED	4/11/2021	4	52	13
CUSTOMER REQUEST	4/11/2021	1	110	110
PLANNED	4/11/2021	7	1,085	155
PLANNED	4/11/2021	2	36	18
CUSTOMER REQUEST	4/11/2021	2	876	438
CUSTOMER REQUEST	4/11/2021	1,901	57,030	30
CUSTOMER REQUEST	4/12/2021	81	22,194	274
PLANNED	4/12/2021	1	86	86
PLANNED	4/12/2021	2	258	129
PLANNED	4/12/2021	3	903	301
PLANNED	4/12/2021	2	470	235

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/12/2021	1	13	13
PLANNED	4/12/2021	1	68	68
PLANNED	4/12/2021	3	156	52
PLANNED	4/12/2021	1	39	39
PLANNED	4/12/2021	6	162	27
PLANNED	4/12/2021	8	834	127
PLANNED	4/12/2021	6	324	54
PLANNED	4/12/2021	1	247	247
PLANNED	4/12/2021	14	784	56
PLANNED	4/12/2021	4	116	29
PLANNED	4/12/2021	6	78	13
PLANNED	4/12/2021	1	169	169
PLANNED	4/12/2021	2	28	14
CUSTOMER REQUEST	4/12/2021	1	388	388
PLANNED	4/12/2021	6	390	65
PLANNED	4/12/2021	9	117	13
PLANNED	4/12/2021	7	161	23
PLANNED	4/12/2021	3	249	83
PLANNED	4/12/2021	1	18	18
PLANNED	4/12/2021	2	74	37
PLANNED	4/12/2021	6	72	12
CUSTOMER REQUEST	4/12/2021	1	318	318
PLANNED	4/12/2021	1	25	25
PLANNED	4/12/2021	1	30	30
PLANNED	4/12/2021	1	237	237
PLANNED	4/12/2021	8	104	13
PLANNED	4/12/2021	8	1,048	131
PLANNED	4/12/2021	3	87	29
PLANNED	4/12/2021	4	52	13
PLANNED	4/12/2021	1	37	37
PLANNED	4/12/2021	6	60	10
PLANNED	4/12/2021	7	189	27
PLANNED	4/12/2021	4	296	74
PLANNED	4/12/2021	1	202	202
PLANNED	4/12/2021	10	270	27
PLANNED	4/12/2021	2	342	171
PLANNED	4/12/2021	1	2	2
PLANNED	4/12/2021	2	130	65
PLANNED	4/12/2021	8	96	12
PLANNED	4/12/2021	8	424	53
PLANNED	4/12/2021	6	54	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/12/2021	6	48	8
PLANNED	4/12/2021	2	12	6
PLANNED	4/12/2021	8	296	37
PLANNED	4/12/2021	2	320	160
PLANNED	4/12/2021	8	176	22
PLANNED	4/12/2021	6	372	62
PLANNED	4/12/2021	4	20	5
PLANNED	4/12/2021	2	62	31
PLANNED	4/12/2021	1	133	133
PLANNED	4/12/2021	1	6	6
PLANNED	4/12/2021	5	100	20
PLANNED	4/12/2021	10	1,360	136
PLANNED	4/12/2021	4	172	43
PLANNED	4/12/2021	2	16	8
PLANNED	4/12/2021	3	45	15
PLANNED	4/12/2021	1	6	6
PLANNED	4/12/2021	2	198	99
PLANNED	4/12/2021	9	1,044	116
PLANNED	4/12/2021	6	720	120
PLANNED	4/12/2021	1	30	30
PLANNED	4/12/2021	5	110	22
PLANNED	4/12/2021	12	1,260	105
PLANNED	4/12/2021	4	44	11
PLANNED	4/12/2021	5	40	8
PLANNED	4/12/2021	1	16	16
PLANNED	4/12/2021	2	212	106
PLANNED	4/12/2021	6	36	6
PLANNED	4/12/2021	5	640	128
PLANNED	4/12/2021	71	781	11
PLANNED	4/12/2021	1	16	16
PLANNED	4/12/2021	3	105	35
PLANNED	4/12/2021	2	28	14
PLANNED	4/12/2021	2	86	43
PLANNED	4/12/2021	4	76	19
PLANNED	4/12/2021	3	171	57
PLANNED	4/12/2021	2	152	76
PLANNED	4/12/2021	1	12	12
PLANNED	4/12/2021	7	327	237
PLANNED	4/12/2021	6	150	25
PLANNED	4/12/2021	3	54	18
PLANNED	4/12/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/12/2021	7	154	22
PLANNED	4/12/2021	1	169	169
PLANNED	4/12/2021	14	294	21
PLANNED	4/12/2021	14	462	33
CUSTOMER REQUEST	4/12/2021	9	297	33
PLANNED	4/12/2021	2	126	63
PLANNED	4/12/2021	1	249	249
PLANNED	4/12/2021	1	149	149
PLANNED	4/12/2021	4	284	71
PLANNED	4/12/2021	25	1,550	62
PLANNED	4/12/2021	3	102	34
PLANNED	4/12/2021	1	173	173
PLANNED	4/13/2021	6	1,152	192
PLANNED	4/13/2021	8	1,616	202
PLANNED	4/13/2021	3	102	34
PLANNED	4/13/2021	2	34	17
PLANNED	4/13/2021	1	96	96
CUSTOMER REQUEST	4/13/2021	11	3,366	306
PLANNED	4/13/2021	6	150	25
PLANNED	4/13/2021	19	532	28
PLANNED	4/13/2021	1	295	295
PLANNED	4/13/2021	4	324	81
PLANNED	4/13/2021	1	293	293
PLANNED	4/13/2021	1	75	75
PLANNED	4/13/2021	9	225	25
PLANNED	4/13/2021	8	368	46
PLANNED	4/13/2021	9	189	21
PLANNED	4/13/2021	9	414	46
PLANNED	4/13/2021	3	261	87
PLANNED	4/13/2021	2	830	415
PLANNED	4/13/2021	1	277	277
PLANNED	4/13/2021	3	375	125
CUSTOMER REQUEST	4/13/2021	1	20	20
PLANNED	4/13/2021	12	2,892	241
CUSTOMER REQUEST	4/13/2021	2	12	6
CUSTOMER REQUEST	4/13/2021	8	440	55
PLANNED	4/13/2021	3	237	79
PLANNED	4/13/2021	13	1,573	121
PLANNED	4/13/2021	6	420	70
PLANNED	4/13/2021	6	462	77
PLANNED	4/13/2021	6	534	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/13/2021	4	456	114
PLANNED	4/13/2021	2	154	77
PLANNED	4/13/2021	9	468	52
PLANNED	4/13/2021	17	3,689	217
CUSTOMER REQUEST	4/13/2021	56	6,552	117
PLANNED	4/13/2021	4	40	10
PLANNED	4/13/2021	1	53	53
PLANNED	4/13/2021	1	72	72
PLANNED	4/13/2021	2	4	2
CUSTOMER REQUEST	4/13/2021	8	147	126
PLANNED	4/13/2021	15	4,770	318
PLANNED	4/13/2021	5	130	26
PLANNED	4/13/2021	4	48	12
PLANNED	4/13/2021	9	189	21
PLANNED	4/13/2021	2	316	158
PLANNED	4/13/2021	4	60	15
PLANNED	4/13/2021	4	180	45
PLANNED	4/13/2021	5	350	70
PLANNED	4/13/2021	22	4,928	224
PLANNED	4/13/2021	1	209	209
PLANNED	4/13/2021	6	468	78
PLANNED	4/13/2021	8	624	78
PLANNED	4/13/2021	1	43	43
PLANNED	4/13/2021	6	846	141
PLANNED	4/13/2021	2	130	65
PLANNED	4/13/2021	5	190	38
PLANNED	4/13/2021	5	180	36
PLANNED	4/13/2021	1	87	87
PLANNED	4/13/2021	5	835	167
PLANNED	4/13/2021	6	156	26
PLANNED	4/13/2021	2	156	78
PLANNED	4/13/2021	1	71	71
PLANNED	4/13/2021	3	573	191
PLANNED	4/13/2021	1	7	7
PLANNED	4/13/2021	1	291	291
PLANNED	4/13/2021	1	20	20
CUSTOMER REQUEST	4/13/2021	1	473	473
PLANNED	4/13/2021	38	7,486	197
PLANNED	4/13/2021	3	27	9
PLANNED	4/13/2021	2	48	24
PLANNED	4/13/2021	5	630	126

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/13/2021	15	2,490	166
PLANNED	4/13/2021	7	105	15
PLANNED	4/13/2021	9	2,052	228
PLANNED	4/13/2021	6	300	50
PLANNED	4/13/2021	2	222	111
PLANNED	4/13/2021	3	495	165
PLANNED	4/13/2021	3	78	26
PLANNED	4/13/2021	5	150	30
PLANNED	4/13/2021	5	135	27
PLANNED	4/13/2021	24	864	36
PLANNED	4/13/2021	10	1,220	122
PLANNED	4/13/2021	4	180	45
PLANNED	4/13/2021	4	288	72
PLANNED	4/13/2021	2	220	110
PLANNED	4/13/2021	4	232	58
PLANNED	4/13/2021	4	68	17
PLANNED	4/13/2021	15	1,110	74
PLANNED	4/13/2021	10	300	30
CUSTOMER REQUEST	4/13/2021	3	51	17
PLANNED	4/13/2021	1	63	63
PLANNED	4/13/2021	7	889	127
PLANNED	4/13/2021	2	232	116
CUSTOMER REQUEST	4/13/2021	6	30	5
PLANNED	4/13/2021	3	177	59
PLANNED	4/13/2021	1	68	68
PLANNED	4/13/2021	2	148	74
PLANNED	4/13/2021	1	29	29
PLANNED	4/13/2021	13	468	36
PLANNED	4/13/2021	2	438	219
PLANNED	4/13/2021	5	115	23
PLANNED	4/13/2021	1	29	29
PLANNED	4/13/2021	10	530	53
CUSTOMER REQUEST	4/13/2021	4	536	134
PLANNED	4/13/2021	5	545	109
PLANNED	4/13/2021	3	120	40
PLANNED	4/13/2021	4	52	13
PLANNED	4/13/2021	15	465	31
PLANNED	4/13/2021	1	66	66
PLANNED	4/13/2021	1	30	30
PLANNED	4/13/2021	7	336	48
PLANNED	4/13/2021	2	70	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/13/2021	3	27	9
CUSTOMER REQUEST	4/13/2021	1	68	68
PLANNED	4/13/2021	2	54	27
PLANNED	4/13/2021	1	21	21
PLANNED	4/13/2021	16	640	40
PLANNED	4/13/2021	1	89	89
PLANNED	4/13/2021	6	444	74
PLANNED	4/13/2021	3	345	115
PLANNED	4/13/2021	4	452	113
PLANNED	4/13/2021	6	696	116
PLANNED	4/13/2021	2	262	131
PLANNED	4/13/2021	4	416	104
PLANNED	4/13/2021	1	22	22
PLANNED	4/13/2021	1	116	116
PLANNED	4/13/2021	3	42	14
PLANNED	4/13/2021	9	243	27
PLANNED	4/13/2021	2	138	69
PLANNED	4/13/2021	3	150	50
PLANNED	4/13/2021	1	97	97
PLANNED	4/13/2021	6	480	80
PLANNED	4/13/2021	2	442	221
PLANNED	4/13/2021	3	126	42
PLANNED	4/13/2021	1	143	143
CUSTOMER REQUEST	4/13/2021	1	170	170
PLANNED	4/13/2021	2	68	34
PLANNED	4/13/2021	5	200	40
PLANNED	4/13/2021	1	3	3
PLANNED	4/13/2021	9	108	12
PLANNED	4/13/2021	1	139	139
PLANNED	4/13/2021	7	371	53
PLANNED	4/13/2021	8	72	9
CUSTOMER REQUEST	4/13/2021	1,130	28,488	36
PLANNED	4/13/2021	1	53	53
PLANNED	4/13/2021	2	76	38
CUSTOMER REQUEST	4/13/2021	1	96	96
PLANNED	4/13/2021	7	532	76
PLANNED	4/13/2021	4	332	83
PLANNED	4/13/2021	1	320	320
PLANNED	4/13/2021	8	248	31
PLANNED	4/13/2021	4	20	5
PLANNED	4/13/2021	1	4	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/13/2021	4	912	267
PLANNED	4/13/2021	1	112	112
PLANNED	4/13/2021	1	75	75
PLANNED	4/13/2021	1	183	183
PLANNED	4/13/2021	7	224	32
PLANNED	4/14/2021	1	31	31
PLANNED	4/14/2021	1	71	71
PLANNED	4/14/2021	3	441	147
PLANNED	4/14/2021	1	115	115
PLANNED	4/14/2021	2	950	475
PLANNED	4/14/2021	1	454	454
PLANNED	4/14/2021	4	108	27
PLANNED	4/14/2021	7	1,113	159
PLANNED	4/14/2021	3	276	92
PLANNED	4/14/2021	5	555	111
PLANNED	4/14/2021	4	244	61
PLANNED	4/14/2021	2	62	31
PLANNED	4/14/2021	15	2,280	152
PLANNED	4/14/2021	1	80	80
PLANNED	4/14/2021	8	256	32
PLANNED	4/14/2021	7	497	71
PLANNED	4/14/2021	2	18	9
PLANNED	4/14/2021	1	61	61
PLANNED	4/14/2021	5	355	71
PLANNED	4/14/2021	5	355	71
CUSTOMER REQUEST	4/14/2021	1	208	208
PLANNED	4/14/2021	8	1,192	149
PLANNED	4/14/2021	7	371	53
PLANNED	4/14/2021	2	58	29
PLANNED	4/14/2021	2	18	9
PLANNED	4/14/2021	1	82	82
PLANNED	4/14/2021	14	8,582	613
PLANNED	4/14/2021	3	165	55
PLANNED	4/14/2021	1	66	66
PLANNED	4/14/2021	3	6	2
PLANNED	4/14/2021	12	60	5
PLANNED	4/14/2021	4	52	13
PLANNED	4/14/2021	4	244	61
PLANNED	4/14/2021	1	122	122
PLANNED	4/14/2021	5	480	96
PLANNED	4/14/2021	1	50	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/14/2021	5	375	75
PLANNED	4/14/2021	6	552	92
PLANNED	4/14/2021	9	1,035	115
PLANNED	4/14/2021	1	16	16
PLANNED	4/14/2021	2	154	77
PLANNED	4/14/2021	2	158	79
PLANNED	4/14/2021	1	356	356
PLANNED	4/14/2021	6	529	249
PLANNED	4/14/2021	1	14	14
CUSTOMER REQUEST	4/14/2021	10	1,770	177
PLANNED	4/14/2021	2	30	15
PLANNED	4/14/2021	22	2,728	124
PLANNED	4/14/2021	5	510	102
PLANNED	4/14/2021	5	305	61
PLANNED	4/14/2021	2	2	1
PLANNED	4/14/2021	4	84	21
PLANNED	4/14/2021	4	580	145
PLANNED	4/14/2021	3	288	96
PLANNED	4/14/2021	5	60	12
PLANNED	4/14/2021	3	582	194
PLANNED	4/14/2021	2	250	125
CUSTOMER REQUEST	4/14/2021	3	111	37
PLANNED	4/14/2021	3	171	57
PLANNED	4/14/2021	5	50	10
PLANNED	4/14/2021	2	412	206
PLANNED	4/14/2021	1	31	31
CUSTOMER REQUEST	4/14/2021	36	24,156	671
PLANNED	4/14/2021	9	405	45
PLANNED	4/14/2021	4	56	14
PLANNED	4/14/2021	2	42	21
PLANNED	4/14/2021	1	18	18
PLANNED	4/14/2021	8	720	90
PLANNED	4/14/2021	4	456	114
PLANNED	4/14/2021	7	154	22
PLANNED	4/14/2021	9	423	47
PLANNED	4/14/2021	10	110	11
PLANNED	4/14/2021	3	66	22
PLANNED	4/14/2021	7	49	7
PLANNED	4/14/2021	7	84	12
PLANNED	4/14/2021	7	70	10
PLANNED	4/14/2021	2	46	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/14/2021	2	178	89
PLANNED	4/14/2021	4	24	6
PLANNED	4/14/2021	7	77	11
PLANNED	4/14/2021	2	260	130
PLANNED	4/14/2021	4	44	11
PLANNED	4/14/2021	4	156	39
PLANNED	4/14/2021	2	96	48
PLANNED	4/14/2021	2	476	238
PLANNED	4/14/2021	2	626	313
PLANNED	4/14/2021	24	3,192	133
PLANNED	4/14/2021	1	146	146
PLANNED	4/14/2021	4	288	72
PLANNED	4/14/2021	4	292	73
PLANNED	4/14/2021	6	144	24
PLANNED	4/14/2021	3	180	60
PLANNED	4/14/2021	9	225	25
PLANNED	4/14/2021	1	56	56
PLANNED	4/14/2021	6	474	79
PLANNED	4/14/2021	2	122	61
PLANNED	4/14/2021	2	30	15
PLANNED	4/14/2021	10	200	20
PLANNED	4/14/2021	2	80	40
PLANNED	4/14/2021	8	1,480	185
PLANNED	4/14/2021	6	6	1
PLANNED	4/14/2021	10	380	38
PLANNED	4/14/2021	9	594	66
PLANNED	4/14/2021	1	103	103
PLANNED	4/14/2021	10	1,550	155
PLANNED	4/14/2021	4	460	115
PLANNED	4/14/2021	4	96	24
PLANNED	4/14/2021	1	28	28
PLANNED	4/14/2021	1	80	80
PLANNED	4/14/2021	2	98	49
PLANNED	4/14/2021	3	246	82
PLANNED	4/14/2021	2	82	41
PLANNED	4/14/2021	34	6,222	183
PLANNED	4/14/2021	4	92	23
PLANNED	4/14/2021	9	198	22
PLANNED	4/14/2021	3	153	51
PLANNED	4/14/2021	7	70	10
PLANNED	4/14/2021	4	148	37

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/14/2021	7	399	57
PLANNED	4/14/2021	8	496	62
PLANNED	4/14/2021	3	162	54
PLANNED	4/14/2021	1	21	21
PLANNED	4/14/2021	3	825	275
PLANNED	4/14/2021	5	140	28
PLANNED	4/14/2021	1	103	103
PLANNED	4/14/2021	4	80	20
PLANNED	4/14/2021	1	47	47
PLANNED	4/14/2021	9	495	55
PLANNED	4/14/2021	8	104	13
PLANNED	4/14/2021	3	78	26
PLANNED	4/14/2021	11	484	44
PLANNED	4/14/2021	7	21	3
PLANNED	4/14/2021	2	30	15
PLANNED	4/14/2021	4	332	83
PLANNED	4/14/2021	3	69	23
PLANNED	4/14/2021	1	178	178
PLANNED	4/14/2021	3	195	65
PLANNED	4/14/2021	1	242	242
PLANNED	4/14/2021	4	180	45
PLANNED	4/14/2021	2	128	64
PLANNED	4/14/2021	1	97	97
PLANNED	4/14/2021	4	472	118
PLANNED	4/14/2021	1	58	58
PLANNED	4/14/2021	11	693	63
PLANNED	4/14/2021	3	123	41
PLANNED	4/14/2021	10	460	46
PLANNED	4/14/2021	2	60	30
PLANNED	4/14/2021	3	258	86
PLANNED	4/14/2021	2	54	27
PLANNED	4/14/2021	4	104	26
PLANNED	4/14/2021	2	114	57
PLANNED	4/14/2021	7	28	4
CUSTOMER REQUEST	4/14/2021	1	192	192
PLANNED	4/14/2021	5	155	31
PLANNED	4/14/2021	1	48	48
PLANNED	4/14/2021	2	132	66
PLANNED	4/14/2021	1	97	97
PLANNED	4/14/2021	14	168	12
PLANNED	4/14/2021	8	632	79

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/14/2021	4	460	115
PLANNED	4/14/2021	4	224	56
PLANNED	4/14/2021	2	228	114
PLANNED	4/14/2021	2	200	100
PLANNED	4/14/2021	3	30	10
PLANNED	4/14/2021	2	198	110
PLANNED	4/14/2021	1	76	76
PLANNED	4/14/2021	2	192	96
PLANNED	4/14/2021	2	90	45
PLANNED	4/14/2021	1	60	60
PLANNED	4/14/2021	1	51	51
PLANNED	4/14/2021	4	568	142
PLANNED	4/14/2021	3	147	49
CUSTOMER REQUEST	4/14/2021	1	36	36
PLANNED	4/14/2021	2	112	56
PLANNED	4/14/2021	3	378	126
PLANNED	4/14/2021	6	624	104
PLANNED	4/14/2021	2	482	241
CUSTOMER REQUEST	4/14/2021	1	76	76
PLANNED	4/14/2021	1	186	186
PLANNED	4/14/2021	3	426	142
PLANNED	4/14/2021	1	119	119
PLANNED	4/14/2021	2	40	20
PLANNED	4/14/2021	3	315	105
PLANNED	4/14/2021	1	80	80
PLANNED	4/14/2021	1	298	298
PLANNED	4/14/2021	2	444	222
PLANNED	4/14/2021	1	74	74
PLANNED	4/14/2021	1	105	105
PLANNED	4/15/2021	1	62	62
PLANNED	4/15/2021	1	190	190
PLANNED	4/15/2021	4	64	16
PLANNED	4/15/2021	1	123	123
PLANNED	4/15/2021	6	126	21
PLANNED	4/15/2021	19	2,318	122
PLANNED	4/15/2021	2	10	5
PLANNED	4/15/2021	4	168	42
PLANNED	4/15/2021	10	630	63
PLANNED	4/15/2021	2	168	84
PLANNED	4/15/2021	1	102	102
PLANNED	4/15/2021	1	31	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/15/2021	11	286	26
PLANNED	4/15/2021	6	942	157
PLANNED	4/15/2021	7	126	18
PLANNED	4/15/2021	2	198	99
PLANNED	4/15/2021	2	140	70
PLANNED	4/15/2021	5	200	40
PLANNED	4/15/2021	26	6,240	240
CUSTOMER REQUEST	4/15/2021	9	2,004	228
PLANNED	4/15/2021	2	222	111
PLANNED	4/15/2021	14	224	16
PLANNED	4/15/2021	13	234	18
CUSTOMER REQUEST	4/15/2021	17	238	14
PLANNED	4/15/2021	3	330	110
PLANNED	4/15/2021	10	40	4
PLANNED	4/15/2021	6	144	24
PLANNED	4/15/2021	1	19	19
PLANNED	4/15/2021	5	1,170	234
PLANNED	4/15/2021	25	1,665	154
PLANNED	4/15/2021	2	56	28
PLANNED	4/15/2021	8	80	10
PLANNED	4/15/2021	6	48	8
PLANNED	4/15/2021	4	268	67
PLANNED	4/15/2021	2	232	116
PLANNED	4/15/2021	2	102	51
PLANNED	4/15/2021	6	144	24
PLANNED	4/15/2021	1	72	72
PLANNED	4/15/2021	1	79	79
PLANNED	4/15/2021	4	495	150
PLANNED	4/15/2021	3	63	21
PLANNED	4/15/2021	7	252	36
PLANNED	4/15/2021	3	36	12
PLANNED	4/15/2021	5	145	29
CUSTOMER REQUEST	4/15/2021	10	560	56
PLANNED	4/15/2021	6	1,662	277
PLANNED	4/15/2021	9	144	16
PLANNED	4/15/2021	7	14	2
PLANNED	4/15/2021	5	55	11
PLANNED	4/15/2021	95	2,500	148
PLANNED	4/15/2021	8	336	42
PLANNED	4/15/2021	2	10	5
PLANNED	4/15/2021	4	176	44

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/15/2021	2	524	262
PLANNED	4/15/2021	13	26	2
PLANNED	4/15/2021	5	495	99
PLANNED	4/15/2021	4	72	18
PLANNED	4/15/2021	2	22	11
PLANNED	4/15/2021	10	820	82
PLANNED	4/15/2021	6	906	151
PLANNED	4/15/2021	11	44	4
PLANNED	4/15/2021	4	68	17
PLANNED	4/15/2021	4	60	15
CUSTOMER REQUEST	4/15/2021	11	44	4
PLANNED	4/15/2021	4	68	17
PLANNED	4/15/2021	2	20	10
PLANNED	4/15/2021	14	168	12
PLANNED	4/15/2021	1	18	18
PLANNED	4/15/2021	2	60	30
CUSTOMER REQUEST	4/15/2021	4	672	168
PLANNED	4/15/2021	8	1,360	170
PLANNED	4/15/2021	6	366	61
PLANNED	4/15/2021	21	693	33
PLANNED	4/15/2021	2	158	79
PLANNED	4/15/2021	5	195	39
PLANNED	4/15/2021	8	536	67
PLANNED	4/15/2021	2	216	108
PLANNED	4/15/2021	1	98	98
PLANNED	4/15/2021	3	84	28
CUSTOMER REQUEST	4/15/2021	7	70	10
PLANNED	4/15/2021	9	594	118
PLANNED	4/15/2021	2	116	58
PLANNED	4/15/2021	1	81	81
PLANNED	4/15/2021	2	52	26
PLANNED	4/15/2021	18	2,664	148
PLANNED	4/15/2021	3	141	47
PLANNED	4/15/2021	2	36	18
PLANNED	4/15/2021	4	68	17
PLANNED	4/15/2021	1	13	13
PLANNED	4/15/2021	5	115	23
PLANNED	4/15/2021	1	70	70
PLANNED	4/15/2021	9	738	82
PLANNED	4/15/2021	6	654	109
PLANNED	4/15/2021	5	665	133

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/15/2021	3	39	13
PLANNED	4/15/2021	12	1,692	141
PLANNED	4/15/2021	14	686	49
PLANNED	4/15/2021	6	144	24
PLANNED	4/15/2021	2	216	108
PLANNED	4/15/2021	8	280	35
PLANNED	4/15/2021	5	95	19
PLANNED	4/15/2021	1	197	197
PLANNED	4/15/2021	5	100	20
PLANNED	4/15/2021	9	927	103
PLANNED	4/15/2021	2	94	47
PLANNED	4/15/2021	1	124	124
PLANNED	4/15/2021	4	608	152
PLANNED	4/15/2021	1	11	11
PLANNED	4/15/2021	3	328	118
PLANNED	4/15/2021	6	774	129
PLANNED	4/15/2021	10	40	4
PLANNED	4/15/2021	1	18	18
PLANNED	4/15/2021	1	37	37
PLANNED	4/15/2021	7	1,925	275
PLANNED	4/15/2021	3	60	20
CUSTOMER REQUEST	4/15/2021	1	443	443
CUSTOMER REQUEST	4/15/2021	1	14	14
PLANNED	4/15/2021	2	38	19
PLANNED	4/15/2021	4	132	33
PLANNED	4/15/2021	1	24	24
CUSTOMER REQUEST	4/15/2021	7	21	3
PLANNED	4/15/2021	7	231	33
PLANNED	4/15/2021	1	23	23
PLANNED	4/15/2021	2	166	83
PLANNED	4/15/2021	3	57	19
PLANNED	4/15/2021	14	854	61
PLANNED	4/15/2021	4	596	149
PLANNED	4/15/2021	2	94	47
PLANNED	4/15/2021	7	875	125
PLANNED	4/15/2021	9	549	61
PLANNED	4/15/2021	13	169	13
PLANNED	4/15/2021	4	516	129
PLANNED	4/15/2021	1	56	56
PLANNED	4/15/2021	2	182	91
PLANNED	4/15/2021	1	111	111

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/15/2021	10	390	39
PLANNED	4/15/2021	8	312	39
PLANNED	4/15/2021	1	23	23
PLANNED	4/15/2021	1	25	25
PLANNED	4/15/2021	1	75	75
PLANNED	4/15/2021	4	44	11
PLANNED	4/15/2021	1	33	33
PLANNED	4/15/2021	2	94	47
PLANNED	4/15/2021	6	1,644	274
PLANNED	4/15/2021	5	480	96
PLANNED	4/15/2021	8	792	99
PLANNED	4/15/2021	2	172	86
PLANNED	4/15/2021	5	430	86
PLANNED	4/15/2021	1	89	89
PLANNED	4/15/2021	1	34	34
PLANNED	4/15/2021	10	380	38
CUSTOMER REQUEST	4/15/2021	1	293	293
PLANNED	4/15/2021	1	52	52
PLANNED	4/15/2021	6	84	14
PLANNED	4/15/2021	16	320	20
PLANNED	4/15/2021	6	288	48
PLANNED	4/15/2021	1	8	8
PLANNED	4/15/2021	2	320	160
PLANNED	4/15/2021	18	2,898	161
CUSTOMER REQUEST	4/15/2021	1	151	151
PLANNED	4/15/2021	6	864	144
PLANNED	4/15/2021	5	1,375	275
PLANNED	4/15/2021	2	232	116
PLANNED	4/15/2021	3	408	136
PLANNED	4/15/2021	9	2,133	237
PLANNED	4/15/2021	40	3,600	90
PLANNED	4/15/2021	5	555	111
PLANNED	4/16/2021	1	204	204
PLANNED	4/16/2021	12	1,464	122
PLANNED	4/16/2021	1	222	222
PLANNED	4/16/2021	1	104	104
PLANNED	4/16/2021	2	284	142
PLANNED	4/16/2021	4	552	138
PLANNED	4/16/2021	4	576	144
PLANNED	4/16/2021	5	1,475	295
PLANNED	4/16/2021	7	322	46

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/16/2021	3	291	97
CUSTOMER REQUEST	4/16/2021	1	36	36
PLANNED	4/16/2021	4	172	43
PLANNED	4/16/2021	15	1,815	121
PLANNED	4/16/2021	2	156	78
PLANNED	4/16/2021	2	268	134
PLANNED	4/16/2021	2	74	37
PLANNED	4/16/2021	1	137	137
CUSTOMER REQUEST	4/16/2021	16	176	11
PLANNED	4/16/2021	2	470	235
PLANNED	4/16/2021	1	40	40
PLANNED	4/16/2021	3	432	144
CUSTOMER REQUEST	4/16/2021	5	20	4
PLANNED	4/16/2021	5	835	167
CUSTOMER REQUEST	4/16/2021	15	3,780	252
PLANNED	4/16/2021	2	78	39
PLANNED	4/16/2021	3	132	44
PLANNED	4/16/2021	12	300	25
PLANNED	4/16/2021	1	152	152
PLANNED	4/16/2021	6	420	70
CUSTOMER REQUEST	4/16/2021	1	235	235
PLANNED	4/16/2021	6	132	22
PLANNED	4/16/2021	3	9	3
PLANNED	4/16/2021	3	6	2
PLANNED	4/16/2021	113	7,684	68
CUSTOMER REQUEST	4/16/2021	1	100	100
CUSTOMER REQUEST	4/16/2021	13	4,381	337
PLANNED	4/16/2021	2	134	67
PLANNED	4/16/2021	4	900	225
CUSTOMER REQUEST	4/16/2021	1	74	74
PLANNED	4/16/2021	2	72	36
PLANNED	4/16/2021	3	144	48
PLANNED	4/16/2021	2	64	32
CUSTOMER REQUEST	4/16/2021	1	78	78
CUSTOMER REQUEST	4/16/2021	7	126	18
PLANNED	4/16/2021	10	350	35
PLANNED	4/16/2021	2	36	18
PLANNED	4/16/2021	1	15	15
PLANNED	4/16/2021	2	138	69
PLANNED	4/16/2021	6	600	100
PLANNED	4/16/2021	1	90	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/16/2021	8	1,024	128
PLANNED	4/16/2021	10	1,330	133
PLANNED	4/16/2021	12	84	7
PLANNED	4/16/2021	2	184	92
PLANNED	4/16/2021	1	8	8
CUSTOMER REQUEST	4/16/2021	3	93	31
PLANNED	4/16/2021	8	728	91
PLANNED	4/16/2021	8	72	9
PLANNED	4/16/2021	1	41	41
PLANNED	4/16/2021	1	64	64
PLANNED	4/16/2021	2	42	21
PLANNED	4/16/2021	4	84	21
PLANNED	4/16/2021	5	590	118
CUSTOMER REQUEST	4/16/2021	6	1,152	192
PLANNED	4/16/2021	1	146	146
PLANNED	4/16/2021	1	51	51
PLANNED	4/16/2021	2	374	187
PLANNED	4/16/2021	3	57	19
PLANNED	4/16/2021	5	105	21
CUSTOMER REQUEST	4/16/2021	1	64	64
PLANNED	4/16/2021	8	192	24
PLANNED	4/16/2021	2	84	42
PLANNED	4/16/2021	4	72	18
PLANNED	4/16/2021	7	1,057	151
PLANNED	4/16/2021	3	339	113
CUSTOMER REQUEST	4/16/2021	7	126	18
CUSTOMER REQUEST	4/16/2021	1	427	427
PLANNED	4/16/2021	16	144	9
CUSTOMER REQUEST	4/16/2021	1	140	140
PLANNED	4/16/2021	4	288	72
CUSTOMER REQUEST	4/16/2021	1	136	136
PLANNED	4/16/2021	1	86	86
CUSTOMER REQUEST	4/16/2021	1	36	36
PLANNED	4/17/2021	1	203	203
PLANNED	4/17/2021	1	406	406
CUSTOMER REQUEST	4/17/2021	1	398	398
PLANNED	4/17/2021	1	145	145
CUSTOMER REQUEST	4/17/2021	4	1,156	289
PLANNED	4/17/2021	1	293	293
PLANNED	4/17/2021	1	26	26
PLANNED	4/17/2021	4	296	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	4/17/2021	1	1,012	1,012
PLANNED	4/17/2021	2	208	104
PLANNED	4/17/2021	1	294	294
PLANNED	4/17/2021	3	885	295
PLANNED	4/17/2021	1	308	308
PLANNED	4/17/2021	2	268	134
PLANNED	4/17/2021	1	291	291
PLANNED	4/17/2021	2	26	13
PLANNED	4/17/2021	6	928	204
PLANNED	4/18/2021	2	366	183
PLANNED	4/18/2021	8	1,576	197
PLANNED	4/18/2021	3	237	79
PLANNED	4/18/2021	1	88	88
PLANNED	4/18/2021	2	198	99
CUSTOMER REQUEST	4/18/2021	12	3,348	279
PLANNED	4/18/2021	2	196	98
PLANNED	4/18/2021	4	704	176
PLANNED	4/18/2021	1	111	111
PLANNED	4/18/2021	1	23	23
PLANNED	4/18/2021	2	112	56
PLANNED	4/18/2021	1	133	133
PLANNED	4/18/2021	13	130	10
PLANNED	4/18/2021	6	180	30
PLANNED	4/19/2021	3	96	32
PLANNED	4/19/2021	6	1,992	332
PLANNED	4/19/2021	6	1,626	271
PLANNED	4/19/2021	3	1,128	376
PLANNED	4/19/2021	4	124	31
PLANNED	4/19/2021	4	56	14
PLANNED	4/19/2021	4	240	60
PLANNED	4/19/2021	3	603	201
PLANNED	4/19/2021	12	3,612	301
PLANNED	4/19/2021	12	3,228	269
PLANNED	4/19/2021	8	1,864	269
PLANNED	4/19/2021	4	248	62
PLANNED	4/19/2021	54	4,644	86
PLANNED	4/19/2021	4	108	27
CUSTOMER REQUEST	4/19/2021	14	2,198	157
PLANNED	4/19/2021	9	135	15
PLANNED	4/19/2021	12	468	39
PLANNED	4/19/2021	6	552	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/19/2021	4	372	93
PLANNED	4/19/2021	7	203	29
PLANNED	4/19/2021	8	256	32
PLANNED	4/19/2021	1	11	11
PLANNED	4/19/2021	8	568	71
PLANNED	4/19/2021	5	130	26
PLANNED	4/19/2021	6	582	97
PLANNED	4/19/2021	30	4,320	144
CUSTOMER REQUEST	4/19/2021	8	104	13
PLANNED	4/19/2021	2	172	86
PLANNED	4/19/2021	8	800	100
PLANNED	4/19/2021	8	800	100
PLANNED	4/19/2021	7	700	100
PLANNED	4/19/2021	4	100	25
PLANNED	4/19/2021	1	15	15
PLANNED	4/19/2021	10	590	59
PLANNED	4/19/2021	13	741	57
PLANNED	4/19/2021	3	213	71
CUSTOMER REQUEST	4/19/2021	18	288	16
PLANNED	4/19/2021	2	46	23
CUSTOMER REQUEST	4/19/2021	1	271	271
PLANNED	4/19/2021	1	17	17
CUSTOMER REQUEST	4/19/2021	10	340	34
PLANNED	4/19/2021	4	112	28
PLANNED	4/19/2021	2	58	29
PLANNED	4/19/2021	6	594	99
PLANNED	4/19/2021	7	644	92
PLANNED	4/19/2021	8	488	61
PLANNED	4/19/2021	4	152	38
PLANNED	4/19/2021	5	325	65
PLANNED	4/19/2021	7	1,673	239
PLANNED	4/19/2021	3	81	27
PLANNED	4/19/2021	4	236	59
PLANNED	4/19/2021	3	159	53
CUSTOMER REQUEST	4/19/2021	1	303	303
PLANNED	4/19/2021	13	299	23
CUSTOMER REQUEST	4/19/2021	70	10,990	157
PLANNED	4/19/2021	2	212	106
CUSTOMER REQUEST	4/19/2021	14	2,912	208
PLANNED	4/19/2021	3	168	56
PLANNED	4/19/2021	7	420	60

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/19/2021	6	360	60
PLANNED	4/19/2021	4	500	125
PLANNED	4/19/2021	6	150	25
PLANNED	4/19/2021	8	224	28
PLANNED	4/19/2021	7	98	14
PLANNED	4/19/2021	4	664	166
PLANNED	4/19/2021	20	3,360	168
PLANNED	4/19/2021	3	225	75
CUSTOMER REQUEST	4/19/2021	3	1,677	559
CUSTOMER REQUEST	4/19/2021	1	1,215	1,215
PLANNED	4/19/2021	4	280	70
CUSTOMER REQUEST	4/19/2021	1	63	63
PLANNED	4/19/2021	2	200	100
PLANNED	4/19/2021	1	92	92
PLANNED	4/19/2021	1	91	91
PLANNED	4/19/2021	4	1,022	320
PLANNED	4/19/2021	1	22	22
PLANNED	4/19/2021	18	4,572	254
PLANNED	4/20/2021	3	411	137
PLANNED	4/20/2021	1	318	318
PLANNED	4/20/2021	17	1,598	94
PLANNED	4/20/2021	4	364	91
PLANNED	4/20/2021	3	159	53
PLANNED	4/20/2021	4	116	29
PLANNED	4/20/2021	3	492	164
PLANNED	4/20/2021	6	1,728	288
PLANNED	4/20/2021	5	435	87
CUSTOMER REQUEST	4/20/2021	1	122	122
CUSTOMER REQUEST	4/20/2021	16	6,880	430
PLANNED	4/20/2021	8	368	46
PLANNED	4/20/2021	5	450	90
PLANNED	4/20/2021	9	810	90
PLANNED	4/20/2021	6	540	90
PLANNED	4/20/2021	40	3,760	94
PLANNED	4/20/2021	6	540	90
CUSTOMER REQUEST	4/20/2021	6	24	4
PLANNED	4/20/2021	1	326	326
PLANNED	4/20/2021	3	33	11
CUSTOMER REQUEST	4/20/2021	21	525	25
CUSTOMER REQUEST	4/20/2021	7	106	70
PLANNED	4/20/2021	1	326	326

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	4/20/2021	1	218	218
PLANNED	4/20/2021	1	363	363
PLANNED	4/20/2021	16	2,368	148
PLANNED	4/20/2021	3	33	11
PLANNED	4/20/2021	9	225	25
CUSTOMER REQUEST	4/20/2021	184	34,960	190
PLANNED	4/20/2021	5	400	80
PLANNED	4/20/2021	6	78	13
PLANNED	4/20/2021	3	45	15
PLANNED	4/20/2021	9	594	66
PLANNED	4/20/2021	3	63	21
PLANNED	4/20/2021	9	468	52
PLANNED	4/20/2021	71	11,147	157
PLANNED	4/20/2021	2	132	66
CUSTOMER REQUEST	4/20/2021	4	88	22
PLANNED	4/20/2021	3	132	44
PLANNED	4/20/2021	3	483	161
PLANNED	4/20/2021	10	790	79
PLANNED	4/20/2021	9	207	23
PLANNED	4/20/2021	8	80	10
PLANNED	4/20/2021	1	17	17
PLANNED	4/20/2021	1	37	37
PLANNED	4/20/2021	9	747	83
PLANNED	4/20/2021	1	47	47
PLANNED	4/20/2021	8	352	44
PLANNED	4/20/2021	7	637	91
PLANNED	4/20/2021	3	75	25
PLANNED	4/20/2021	5	200	40
CUSTOMER REQUEST	4/20/2021	71	21,584	304
PLANNED	4/20/2021	1	19	19
PLANNED	4/20/2021	4	148	37
PLANNED	4/20/2021	3	222	74
PLANNED	4/20/2021	8	2,512	314
PLANNED	4/20/2021	3	234	78
PLANNED	4/20/2021	6	120	20
PLANNED	4/20/2021	17	2,635	155
CUSTOMER REQUEST	4/20/2021	9	225	25
PLANNED	4/20/2021	5	720	144
PLANNED	4/20/2021	10	100	10
PLANNED	4/20/2021	18	1,188	66
PLANNED	4/20/2021	1	64	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	4/20/2021	15	255	17
PLANNED	4/20/2021	8	816	102
PLANNED	4/20/2021	4	36	9
PLANNED	4/20/2021	6	42	7
PLANNED	4/20/2021	9	387	43
PLANNED	4/20/2021	2	46	23
CUSTOMER REQUEST	4/20/2021	5	330	66
PLANNED	4/20/2021	3	57	19
PLANNED	4/20/2021	1	12	12
PLANNED	4/20/2021	2	46	23
PLANNED	4/20/2021	7	854	122
PLANNED	4/20/2021	2	38	19
PLANNED	4/20/2021	1	30	30
CUSTOMER REQUEST	4/20/2021	9	441	49
PLANNED	4/20/2021	5	200	40
PLANNED	4/20/2021	8	232	29
PLANNED	4/20/2021	3	273	91
PLANNED	4/20/2021	3	252	84
PLANNED	4/20/2021	13	663	51
CUSTOMER REQUEST	4/20/2021	12	192	16
PLANNED	4/20/2021	4	240	60
PLANNED	4/20/2021	3	162	54
PLANNED	4/20/2021	7	189	27
PLANNED	4/20/2021	18	1,710	95
PLANNED	4/20/2021	6	384	64
PLANNED	4/20/2021	8	80	10
PLANNED	4/20/2021	9	315	35
PLANNED	4/20/2021	20	20	1
PLANNED	4/20/2021	12	204	17
PLANNED	4/20/2021	2	62	31
PLANNED	4/20/2021	23	3,289	143
PLANNED	4/20/2021	7	245	35
PLANNED	4/20/2021	1	158	158
PLANNED	4/20/2021	1	189	189
PLANNED	4/20/2021	4	24	6
PLANNED	4/20/2021	1	13	13
CUSTOMER REQUEST	4/20/2021	1	403	403
PLANNED	4/20/2021	42	1,890	45
PLANNED	4/20/2021	1	109	109
PLANNED	4/20/2021	4	700	175
PLANNED	4/20/2021	1	76	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/20/2021	1	328	328
PLANNED	4/20/2021	1	387	387
PLANNED	4/20/2021	1	43	43
PLANNED	4/20/2021	1	208	208
PLANNED	4/21/2021	2	360	180
CUSTOMER REQUEST	4/21/2021	3	744	248
PLANNED	4/21/2021	4	388	97
PLANNED	4/21/2021	3	330	110
PLANNED	4/21/2021	7	574	82
PLANNED	4/21/2021	5	50	10
PLANNED	4/21/2021	3	93	31
CUSTOMER REQUEST	4/21/2021	1	99	99
PLANNED	4/21/2021	2	644	322
PLANNED	4/21/2021	4	356	89
PLANNED	4/21/2021	8	120	15
PLANNED	4/21/2021	6	594	99
PLANNED	4/21/2021	10	850	85
PLANNED	4/21/2021	1	140	140
PLANNED	4/21/2021	10	100	10
PLANNED	4/21/2021	10	1,180	118
PLANNED	4/21/2021	4	752	188
PLANNED	4/21/2021	21	5,061	241
PLANNED	4/21/2021	3	198	66
PLANNED	4/21/2021	1	77	77
PLANNED	4/21/2021	1	96	96
PLANNED	4/21/2021	8	104	13
PLANNED	4/21/2021	4	796	199
PLANNED	4/21/2021	3	408	136
PLANNED	4/21/2021	1	9	9
PLANNED	4/21/2021	4	92	23
PLANNED	4/21/2021	1	134	134
PLANNED	4/21/2021	2	28	14
PLANNED	4/21/2021	12	684	57
PLANNED	4/21/2021	3	228	76
PLANNED	4/21/2021	33	6,468	196
PLANNED	4/21/2021	27	5,265	195
PLANNED	4/21/2021	3	321	107
PLANNED	4/21/2021	1	33	33
PLANNED	4/21/2021	17	3,298	194
PLANNED	4/21/2021	6	900	150
PLANNED	4/21/2021	26	5,096	196

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/21/2021	8	184	23
PLANNED	4/21/2021	12	2,028	169
PLANNED	4/21/2021	5	120	24
PLANNED	4/21/2021	10	210	21
PLANNED	4/21/2021	1	125	125
PLANNED	4/21/2021	6	198	33
PLANNED	4/21/2021	7	973	139
PLANNED	4/21/2021	25	1,800	72
PLANNED	4/21/2021	9	1,251	139
PLANNED	4/21/2021	3	6	2
PLANNED	4/21/2021	6	576	96
PLANNED	4/21/2021	10	1,390	139
PLANNED	4/21/2021	2	134	67
PLANNED	4/21/2021	3	93	31
PLANNED	4/21/2021	14	742	53
PLANNED	4/21/2021	22	4,818	219
PLANNED	4/21/2021	14	742	53
PLANNED	4/21/2021	12	1,392	116
PLANNED	4/21/2021	10	150	15
PLANNED	4/21/2021	2	194	97
PLANNED	4/21/2021	1	91	91
PLANNED	4/21/2021	1	21	21
PLANNED	4/21/2021	3	42	14
PLANNED	4/21/2021	1	54	54
PLANNED	4/21/2021	3	66	22
PLANNED	4/21/2021	8	96	12
PLANNED	4/21/2021	2	16	8
PLANNED	4/21/2021	4	44	11
PLANNED	4/21/2021	4	72	18
PLANNED	4/21/2021	3	89	33
PLANNED	4/21/2021	7	511	73
PLANNED	4/21/2021	1	73	73
PLANNED	4/21/2021	6	66	11
PLANNED	4/21/2021	8	880	110
PLANNED	4/21/2021	1	126	126
PLANNED	4/21/2021	2	264	135
PLANNED	4/21/2021	1	102	102
PLANNED	4/21/2021	3	123	41
PLANNED	4/21/2021	2	30	15
PLANNED	4/21/2021	6	222	37
PLANNED	4/21/2021	8	288	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/21/2021	2	32	16
PLANNED	4/21/2021	3	54	18
PLANNED	4/21/2021	4	108	27
PLANNED	4/21/2021	1	163	163
PLANNED	4/21/2021	14	546	39
PLANNED	4/21/2021	4	116	29
PLANNED	4/21/2021	5	150	30
PLANNED	4/21/2021	2	68	34
PLANNED	4/21/2021	3	378	126
PLANNED	4/21/2021	6	450	75
PLANNED	4/21/2021	9	324	36
PLANNED	4/21/2021	50	500	10
PLANNED	4/21/2021	1	77	77
PLANNED	4/21/2021	2	8	4
PLANNED	4/21/2021	4	64	16
PLANNED	4/21/2021	2	16	8
PLANNED	4/21/2021	6	48	8
PLANNED	4/21/2021	4	48	12
PLANNED	4/21/2021	3	21	7
PLANNED	4/21/2021	4	40	10
PLANNED	4/21/2021	8	720	90
PLANNED	4/21/2021	1	10	10
PLANNED	4/21/2021	2	72	36
PLANNED	4/21/2021	2	82	41
PLANNED	4/21/2021	1	42	42
PLANNED	4/21/2021	1	18	18
PLANNED	4/21/2021	9	603	67
CUSTOMER REQUEST	4/21/2021	3	282	94
PLANNED	4/21/2021	4	80	20
PLANNED	4/21/2021	5	60	12
PLANNED	4/21/2021	25	825	33
PLANNED	4/21/2021	19	988	52
PLANNED	4/21/2021	1	25	25
CUSTOMER REQUEST	4/21/2021	1	229	229
PLANNED	4/21/2021	2	384	192
PLANNED	4/21/2021	3	21	7
PLANNED	4/21/2021	2	46	23
PLANNED	4/21/2021	12	408	34
PLANNED	4/21/2021	1	63	63
PLANNED	4/21/2021	2	48	24
PLANNED	4/21/2021	1	53	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/21/2021	2	208	104
PLANNED	4/21/2021	8	424	53
PLANNED	4/21/2021	2	56	28
PLANNED	4/21/2021	4	52	13
PLANNED	4/21/2021	4	420	105
PLANNED	4/21/2021	10	1,090	109
PLANNED	4/21/2021	1	53	53
CUSTOMER REQUEST	4/21/2021	12	732	61
PLANNED	4/21/2021	2	30	15
PLANNED	4/21/2021	2	130	65
PLANNED	4/21/2021	2	172	86
PLANNED	4/21/2021	2	14	7
PLANNED	4/21/2021	10	1,070	107
PLANNED	4/21/2021	3	645	215
PLANNED	4/21/2021	5	280	56
CUSTOMER REQUEST	4/21/2021	1	144	144
PLANNED	4/21/2021	2	80	40
PLANNED	4/21/2021	8	1,136	142
PLANNED	4/21/2021	4	180	45
PLANNED	4/21/2021	9	1,188	132
PLANNED	4/21/2021	1	11	11
PLANNED	4/21/2021	2	82	41
PLANNED	4/21/2021	1	46	46
PLANNED	4/21/2021	2	182	91
PLANNED	4/21/2021	5	70	14
PLANNED	4/21/2021	4	232	58
PLANNED	4/21/2021	2	160	80
PLANNED	4/21/2021	2	54	27
PLANNED	4/21/2021	43	3,741	87
PLANNED	4/21/2021	2	142	71
PLANNED	4/21/2021	1	62	62
PLANNED	4/21/2021	1	63	63
PLANNED	4/21/2021	1	26	26
CUSTOMER REQUEST	4/21/2021	420	151,200	360
PLANNED	4/21/2021	5	580	116
PLANNED	4/21/2021	1	235	235
PLANNED	4/21/2021	1	509	509
PLANNED	4/21/2021	1	64	64
PLANNED	4/22/2021	2	662	331
CUSTOMER REQUEST	4/22/2021	1	298	298
PLANNED	4/22/2021	2	178	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/22/2021	5	145	29
PLANNED	4/22/2021	1	261	261
PLANNED	4/22/2021	6	366	61
PLANNED	4/22/2021	1	82	82
PLANNED	4/22/2021	3	36	12
PLANNED	4/22/2021	1	173	173
PLANNED	4/22/2021	2	350	175
PLANNED	4/22/2021	2	302	151
PLANNED	4/22/2021	5	820	164
PLANNED	4/22/2021	10	370	37
PLANNED	4/22/2021	2	182	91
PLANNED	4/22/2021	4	132	33
PLANNED	4/22/2021	4	52	13
PLANNED	4/22/2021	6	78	13
PLANNED	4/22/2021	9	738	82
PLANNED	4/22/2021	2	374	187
PLANNED	4/22/2021	3	114	38
PLANNED	4/22/2021	9	1,674	186
PLANNED	4/22/2021	4	52	13
PLANNED	4/22/2021	2	248	124
PLANNED	4/22/2021	2	278	139
PLANNED	4/22/2021	5	255	51
PLANNED	4/22/2021	3	573	191
PLANNED	4/22/2021	5	485	97
PLANNED	4/22/2021	1	107	107
PLANNED	4/22/2021	3	390	130
PLANNED	4/22/2021	3	312	104
PLANNED	4/22/2021	5	15	3
PLANNED	4/22/2021	6	186	31
PLANNED	4/22/2021	1	128	128
PLANNED	4/22/2021	4	92	23
PLANNED	4/22/2021	2	42	21
PLANNED	4/22/2021	4	276	69
PLANNED	4/22/2021	3	327	109
PLANNED	4/22/2021	5	345	69
PLANNED	4/22/2021	3	93	31
PLANNED	4/22/2021	4	360	90
PLANNED	4/22/2021	4	8	2
PLANNED	4/22/2021	73	10,804	148
CUSTOMER REQUEST	4/22/2021	5	25	5
PLANNED	4/22/2021	1	31	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/22/2021	1	64	64
PLANNED	4/22/2021	4	124	31
PLANNED	4/22/2021	1	25	25
PLANNED	4/22/2021	2	18	9
PLANNED	4/22/2021	4	284	71
PLANNED	4/22/2021	7	777	111
PLANNED	4/22/2021	10	840	84
PLANNED	4/22/2021	7	497	71
PLANNED	4/22/2021	2	150	75
PLANNED	4/22/2021	4	40	10
PLANNED	4/22/2021	4	28	7
PLANNED	4/22/2021	4	36	9
PLANNED	4/22/2021	2	46	23
PLANNED	4/22/2021	7	441	63
PLANNED	4/22/2021	2	506	253
PLANNED	4/22/2021	9	387	43
CUSTOMER REQUEST	4/22/2021	16	5,776	361
PLANNED	4/22/2021	1	53	53
PLANNED	4/22/2021	1	7	7
CUSTOMER REQUEST	4/22/2021	11	231	21
PLANNED	4/22/2021	8	336	42
PLANNED	4/22/2021	4	424	106
CUSTOMER REQUEST	4/22/2021	1	76	76
PLANNED	4/22/2021	21	4,599	219
PLANNED	4/22/2021	2	90	45
PLANNED	4/22/2021	2	80	40
PLANNED	4/22/2021	4	20	5
PLANNED	4/22/2021	31	4,650	150
PLANNED	4/22/2021	2	134	67
CUSTOMER REQUEST	4/22/2021	21	4,641	221
PLANNED	4/22/2021	1	132	132
PLANNED	4/22/2021	4	68	17
PLANNED	4/22/2021	2	38	19
CUSTOMER REQUEST	4/22/2021	3	204	68
PLANNED	4/22/2021	8	384	48
PLANNED	4/22/2021	4	124	31
CUSTOMER REQUEST	4/22/2021	12	5,016	418
PLANNED	4/22/2021	14	4,592	328
PLANNED	4/22/2021	45	12,600	280
PLANNED	4/22/2021	1	88	88
PLANNED	4/22/2021	3	39	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/22/2021	4	84	21
PLANNED	4/22/2021	2	124	62
PLANNED	4/22/2021	2	168	84
PLANNED	4/22/2021	10	70	7
PLANNED	4/22/2021	16	592	37
PLANNED	4/22/2021	1	160	160
CUSTOMER REQUEST	4/22/2021	1	370	370
PLANNED	4/22/2021	14	154	11
PLANNED	4/22/2021	18	450	25
PLANNED	4/22/2021	4	964	241
PLANNED	4/22/2021	8	656	82
PLANNED	4/22/2021	9	738	82
PLANNED	4/22/2021	7	588	84
PLANNED	4/22/2021	9	819	91
PLANNED	4/22/2021	8	752	94
CUSTOMER REQUEST	4/22/2021	8	160	20
PLANNED	4/22/2021	10	870	87
PLANNED	4/22/2021	8	688	86
PLANNED	4/22/2021	9	774	86
PLANNED	4/22/2021	8	416	52
CUSTOMER REQUEST	4/22/2021	23	11,224	488
PLANNED	4/22/2021	5	35	7
PLANNED	4/22/2021	7	602	86
PLANNED	4/22/2021	6	786	131
PLANNED	4/22/2021	2	84	42
PLANNED	4/22/2021	1	239	239
PLANNED	4/22/2021	1	13	13
PLANNED	4/22/2021	2	16	8
PLANNED	4/22/2021	4	456	114
PLANNED	4/22/2021	3	225	75
PLANNED	4/22/2021	6	462	77
PLANNED	4/22/2021	4	688	172
PLANNED	4/22/2021	1	28	28
PLANNED	4/22/2021	12	840	70
PLANNED	4/22/2021	6	444	74
PLANNED	4/22/2021	5	20	4
PLANNED	4/22/2021	10	2,950	295
PLANNED	4/22/2021	3	72	24
PLANNED	4/22/2021	2	140	70
PLANNED	4/22/2021	1	29	29
PLANNED	4/22/2021	4	44	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/22/2021	1	45	45
PLANNED	4/22/2021	4	28	7
PLANNED	4/22/2021	4	64	16
PLANNED	4/22/2021	43	2,193	51
PLANNED	4/22/2021	12	1,188	99
PLANNED	4/22/2021	10	400	40
PLANNED	4/22/2021	2	192	96
PLANNED	4/22/2021	7	77	11
PLANNED	4/22/2021	3	42	14
PLANNED	4/22/2021	2	24	12
CUSTOMER REQUEST	4/22/2021	10	160	16
PLANNED	4/22/2021	5	105	21
PLANNED	4/22/2021	2	220	110
PLANNED	4/22/2021	2	330	165
PLANNED	4/22/2021	2	260	130
PLANNED	4/22/2021	3	66	22
PLANNED	4/22/2021	1	193	193
PLANNED	4/22/2021	3	45	15
PLANNED	4/22/2021	3	237	79
PLANNED	4/22/2021	2	152	76
PLANNED	4/22/2021	1	74	74
PLANNED	4/22/2021	8	176	22
PLANNED	4/22/2021	5	210	42
PLANNED	4/22/2021	4	64	16
PLANNED	4/22/2021	1	62	62
PLANNED	4/22/2021	3	291	97
PLANNED	4/22/2021	11	1,045	95
PLANNED	4/22/2021	16	1,152	72
PLANNED	4/22/2021	1	55	55
PLANNED	4/22/2021	1	85	85
PLANNED	4/22/2021	1	40	40
PLANNED	4/22/2021	1	39	39
PLANNED	4/22/2021	6	348	58
CUSTOMER REQUEST	4/22/2021	4	60	15
PLANNED	4/22/2021	3	48	16
PLANNED	4/22/2021	4	300	75
PLANNED	4/22/2021	3	342	114
PLANNED	4/22/2021	4	172	43
PLANNED	4/22/2021	6	66	11
PLANNED	4/22/2021	2	208	104
PLANNED	4/22/2021	1	78	78

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/22/2021	2	120	60
PLANNED	4/22/2021	3	63	21
PLANNED	4/22/2021	1	63	63
PLANNED	4/22/2021	2	114	57
PLANNED	4/22/2021	1	42	42
PLANNED	4/22/2021	1	13	13
PLANNED	4/22/2021	3	201	67
PLANNED	4/22/2021	7	245	35
PLANNED	4/22/2021	1	15	15
PLANNED	4/22/2021	1	71	71
CUSTOMER REQUEST	4/22/2021	5	275	55
PLANNED	4/22/2021	5	180	36
CUSTOMER REQUEST	4/22/2021	3	4,632	1,544
PLANNED	4/22/2021	3	120	40
PLANNED	4/22/2021	1	94	94
PLANNED	4/22/2021	1	38	38
PLANNED	4/22/2021	16	2,944	184
PLANNED	4/22/2021	21	3,129	149
PLANNED	4/22/2021	1	106	106
PLANNED	4/22/2021	5	750	150
PLANNED	4/23/2021	1	354	354
PLANNED	4/23/2021	1	64	64
PLANNED	4/23/2021	3	498	166
PLANNED	4/23/2021	1	92	92
PLANNED	4/23/2021	6	660	110
PLANNED	4/23/2021	2	100	50
PLANNED	4/23/2021	3	147	49
PLANNED	4/23/2021	8	904	113
PLANNED	4/23/2021	4	384	96
CUSTOMER REQUEST	4/23/2021	17	6,868	404
PLANNED	4/23/2021	4	112	28
PLANNED	4/23/2021	8	864	108
PLANNED	4/23/2021	12	396	33
PLANNED	4/23/2021	4	160	40
PLANNED	4/23/2021	11	66	6
PLANNED	4/23/2021	3	360	120
PLANNED	4/23/2021	4	64	16
PLANNED	4/23/2021	2	170	85
PLANNED	4/23/2021	8	240	30
PLANNED	4/23/2021	1	34	34
PLANNED	4/23/2021	1	50	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/23/2021	3	363	121
PLANNED	4/23/2021	1	56	56
PLANNED	4/23/2021	84	4,284	51
PLANNED	4/23/2021	34	1,802	53
PLANNED	4/23/2021	3	189	63
PLANNED	4/23/2021	5	660	132
PLANNED	4/23/2021	8	40	5
PLANNED	4/23/2021	5	600	120
PLANNED	4/23/2021	6	438	73
PLANNED	4/23/2021	3	24	8
PLANNED	4/23/2021	3	21	7
PLANNED	4/23/2021	6	894	149
CUSTOMER REQUEST	4/23/2021	5	300	60
PLANNED	4/23/2021	4	320	80
PLANNED	4/23/2021	1	155	155
PLANNED	4/23/2021	3	762	254
PLANNED	4/23/2021	5	170	34
PLANNED	4/23/2021	5	30	6
PLANNED	4/23/2021	3	426	142
PLANNED	4/23/2021	4	24	6
PLANNED	4/23/2021	4	380	95
PLANNED	4/23/2021	1	11	11
PLANNED	4/23/2021	16	1,760	110
PLANNED	4/23/2021	3	270	90
PLANNED	4/23/2021	1	17	17
PLANNED	4/23/2021	3	261	87
CUSTOMER REQUEST	4/23/2021	1	10	10
PLANNED	4/23/2021	3	636	212
PLANNED	4/23/2021	1	61	61
PLANNED	4/23/2021	3	99	33
PLANNED	4/23/2021	7	42	6
PLANNED	4/23/2021	8	1,840	230
PLANNED	4/23/2021	5	80	16
PLANNED	4/23/2021	4	120	30
PLANNED	4/23/2021	2	90	45
PLANNED	4/23/2021	2	258	129
CUSTOMER REQUEST	4/23/2021	7	161	23
PLANNED	4/23/2021	10	1,610	161
PLANNED	4/23/2021	1	147	147
PLANNED	4/23/2021	6	564	94
CUSTOMER REQUEST	4/23/2021	1	451	451

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/23/2021	4	400	100
PLANNED	4/23/2021	2	62	31
PLANNED	4/23/2021	8	136	17
PLANNED	4/23/2021	3	57	19
PLANNED	4/23/2021	7	28	4
PLANNED	4/23/2021	19	2,641	139
PLANNED	4/23/2021	8	312	39
PLANNED	4/23/2021	8	40	5
CUSTOMER REQUEST	4/23/2021	7	378	54
PLANNED	4/23/2021	6	84	14
PLANNED	4/23/2021	1	72	72
PLANNED	4/23/2021	2	78	39
PLANNED	4/23/2021	9	981	109
PLANNED	4/23/2021	3	78	26
PLANNED	4/23/2021	10	840	84
PLANNED	4/23/2021	4	328	82
PLANNED	4/23/2021	1	42	42
PLANNED	4/23/2021	1	86	86
PLANNED	4/23/2021	5	65	13
PLANNED	4/23/2021	4	104	26
PLANNED	4/23/2021	4	184	46
CUSTOMER REQUEST	4/23/2021	4	28	7
PLANNED	4/23/2021	5	320	64
PLANNED	4/23/2021	1	17	17
PLANNED	4/23/2021	1	24	24
PLANNED	4/23/2021	1	111	111
PLANNED	4/23/2021	6	198	33
PLANNED	4/23/2021	1	14	14
PLANNED	4/23/2021	3	60	20
PLANNED	4/23/2021	3	207	69
PLANNED	4/23/2021	5	660	132
PLANNED	4/23/2021	6	756	126
PLANNED	4/23/2021	4	72	18
PLANNED	4/23/2021	10	1,010	101
CUSTOMER REQUEST	4/23/2021	10	150	15
PLANNED	4/23/2021	1	77	77
PLANNED	4/23/2021	2	168	84
PLANNED	4/23/2021	10	330	33
PLANNED	4/23/2021	4	20	5
PLANNED	4/23/2021	2	30	15
CUSTOMER REQUEST	4/23/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/23/2021	1	2	2
PLANNED	4/23/2021	5	120	24
PLANNED	4/23/2021	2	44	22
PLANNED	4/23/2021	4	68	17
CUSTOMER REQUEST	4/23/2021	1	213	213
PLANNED	4/23/2021	1	88	88
PLANNED	4/23/2021	2	94	47
PLANNED	4/23/2021	4	528	132
PLANNED	4/23/2021	2	66	33
PLANNED	4/23/2021	10	140	14
PLANNED	4/23/2021	1	124	124
PLANNED	4/23/2021	4	180	45
PLANNED	4/23/2021	3	39	13
PLANNED	4/23/2021	24	1,104	46
PLANNED	4/23/2021	5	95	19
CUSTOMER REQUEST	4/23/2021	1	106	106
PLANNED	4/24/2021	5	325	65
PLANNED	4/24/2021	8	3,192	399
PLANNED	4/24/2021	7	161	23
PLANNED	4/24/2021	1	81	81
PLANNED	4/24/2021	11	1,221	111
PLANNED	4/24/2021	1	52	52
PLANNED	4/24/2021	13	2,327	179
PLANNED	4/24/2021	1	96	96
PLANNED	4/24/2021	3	411	137
PLANNED	4/24/2021	11	3,069	279
PLANNED	4/24/2021	2	172	86
PLANNED	4/24/2021	1	206	206
PLANNED	4/24/2021	5	555	111
PLANNED	4/24/2021	2	126	63
PLANNED	4/24/2021	2	362	181
PLANNED	4/24/2021	1	131	131
PLANNED	4/24/2021	4	236	59
PLANNED	4/24/2021	4	432	108
PLANNED	4/24/2021	4	20	5
PLANNED	4/24/2021	6	360	60
PLANNED	4/25/2021	1	255	255
PLANNED	4/25/2021	15	2,033	164
PLANNED	4/25/2021	2	364	182
PLANNED	4/25/2021	1	77	77
PLANNED	4/25/2021	4	340	85

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/25/2021	6	252	42
PLANNED	4/25/2021	2	178	89
PLANNED	4/25/2021	1	297	297
PLANNED	4/25/2021	4	152	38
PLANNED	4/25/2021	10	490	49
PLANNED	4/25/2021	2	158	79
PLANNED	4/25/2021	1	314	314
PLANNED	4/26/2021	1	157	157
PLANNED	4/26/2021	7	1,029	147
PLANNED	4/26/2021	4	212	53
PLANNED	4/26/2021	1	73	73
PLANNED	4/26/2021	4	560	140
PLANNED	4/26/2021	8	2,112	264
PLANNED	4/26/2021	4	250	69
PLANNED	4/26/2021	1	81	81
PLANNED	4/26/2021	1	34	34
PLANNED	4/26/2021	4	144	36
PLANNED	4/26/2021	6	450	75
PLANNED	4/26/2021	5	35	7
PLANNED	4/26/2021	4	416	138
CUSTOMER REQUEST	4/26/2021	1	60	60
PLANNED	4/26/2021	3	210	70
PLANNED	4/26/2021	2	76	38
PLANNED	4/26/2021	2	24	12
CUSTOMER REQUEST	4/26/2021	9	252	28
PLANNED	4/26/2021	1	203	203
PLANNED	4/26/2021	1	64	64
CUSTOMER REQUEST	4/26/2021	1	131	131
CUSTOMER REQUEST	4/26/2021	28	224	8
PLANNED	4/26/2021	8	336	42
PLANNED	4/26/2021	3	153	51
PLANNED	4/26/2021	2	204	102
PLANNED	4/26/2021	6	438	73
CUSTOMER REQUEST	4/26/2021	1	227	227
PLANNED	4/26/2021	2	28	14
PLANNED	4/26/2021	1	47	47
PLANNED	4/26/2021	2	248	124
PLANNED	4/26/2021	2	4	2
PLANNED	4/26/2021	3	105	35
PLANNED	4/26/2021	5	85	17
PLANNED	4/26/2021	1	185	185

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/26/2021	7	441	63
PLANNED	4/26/2021	4	476	119
PLANNED	4/26/2021	5	25	5
PLANNED	4/26/2021	6	360	60
PLANNED	4/26/2021	6	48	8
PLANNED	4/26/2021	4	164	41
PLANNED	4/26/2021	4	164	41
PLANNED	4/26/2021	5	365	73
PLANNED	4/26/2021	2	258	129
PLANNED	4/26/2021	33	5,343	188
PLANNED	4/26/2021	2	34	17
PLANNED	4/26/2021	1	25	25
PLANNED	4/26/2021	5	75	15
PLANNED	4/26/2021	6	90	15
PLANNED	4/26/2021	4	72	18
PLANNED	4/26/2021	1	142	142
PLANNED	4/26/2021	1	84	84
PLANNED	4/26/2021	2	138	69
PLANNED	4/26/2021	2	52	26
CUSTOMER REQUEST	4/26/2021	37	26,714	722
PLANNED	4/26/2021	9	1,224	136
PLANNED	4/26/2021	4	204	51
PLANNED	4/26/2021	1	27	27
PLANNED	4/26/2021	9	432	48
PLANNED	4/26/2021	2	88	44
PLANNED	4/26/2021	3	66	22
PLANNED	4/26/2021	2	58	29
PLANNED	4/26/2021	1	10	10
PLANNED	4/26/2021	2	30	15
PLANNED	4/26/2021	4	412	103
PLANNED	4/26/2021	1	12	12
PLANNED	4/26/2021	7	245	35
PLANNED	4/26/2021	1	18	18
PLANNED	4/26/2021	2	42	21
PLANNED	4/26/2021	1	213	213
PLANNED	4/26/2021	3	57	19
PLANNED	4/26/2021	8	112	14
PLANNED	4/26/2021	7	133	19
PLANNED	4/26/2021	3	198	66
PLANNED	4/26/2021	2	14	7
PLANNED	4/26/2021	1	36	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/26/2021	1	27	27
PLANNED	4/26/2021	1	37	37
PLANNED	4/26/2021	4	52	13
PLANNED	4/26/2021	2	282	141
PLANNED	4/26/2021	2	180	90
PLANNED	4/26/2021	10	1,180	118
PLANNED	4/26/2021	3	135	45
PLANNED	4/26/2021	13	195	15
PLANNED	4/26/2021	2	60	30
PLANNED	4/26/2021	1	12	12
PLANNED	4/26/2021	5	45	9
PLANNED	4/26/2021	4	68	17
PLANNED	4/26/2021	2	106	53
PLANNED	4/26/2021	1	78	78
PLANNED	4/26/2021	2	151	90
PLANNED	4/26/2021	7	42	6
PLANNED	4/26/2021	4	240	60
PLANNED	4/26/2021	7	140	20
PLANNED	4/26/2021	1	9	9
PLANNED	4/26/2021	3	246	82
PLANNED	4/26/2021	3	33	11
CUSTOMER REQUEST	4/26/2021	3	156	52
PLANNED	4/26/2021	2	36	18
PLANNED	4/26/2021	1	107	107
PLANNED	4/26/2021	3	225	75
PLANNED	4/26/2021	2	104	52
PLANNED	4/26/2021	3	162	54
PLANNED	4/26/2021	2	280	140
PLANNED	4/26/2021	2	60	30
PLANNED	4/26/2021	3	132	44
PLANNED	4/26/2021	1	12	12
PLANNED	4/26/2021	2	30	15
PLANNED	4/26/2021	2	82	41
PLANNED	4/26/2021	3	66	22
PLANNED	4/26/2021	1	99	99
PLANNED	4/26/2021	4	296	74
PLANNED	4/26/2021	4	64	16
PLANNED	4/26/2021	4	284	71
PLANNED	4/26/2021	1	18	18
PLANNED	4/26/2021	1	75	75
PLANNED	4/26/2021	2	78	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/26/2021	1	14	14
PLANNED	4/26/2021	6	564	94
PLANNED	4/26/2021	2	54	27
PLANNED	4/26/2021	1	126	126
PLANNED	4/26/2021	3	204	68
PLANNED	4/26/2021	1	41	41
PLANNED	4/26/2021	4	200	50
PLANNED	4/26/2021	1	102	102
PLANNED	4/26/2021	17	1,734	102
PLANNED	4/26/2021	2	88	44
PLANNED	4/26/2021	5	1,240	248
PLANNED	4/26/2021	6	168	28
PLANNED	4/26/2021	3	1,110	370
PLANNED	4/26/2021	1	126	126
PLANNED	4/26/2021	3	351	117
PLANNED	4/26/2021	5	415	83
PLANNED	4/26/2021	2	158	79
PLANNED	4/26/2021	1	257	257
PLANNED	4/27/2021	1	145	145
PLANNED	4/27/2021	52	5,304	102
PLANNED	4/27/2021	1	131	131
PLANNED	4/27/2021	1	46	46
PLANNED	4/27/2021	2	78	39
PLANNED	4/27/2021	1	76	76
PLANNED	4/27/2021	4	128	32
PLANNED	4/27/2021	4	664	166
PLANNED	4/27/2021	2	165	86
PLANNED	4/27/2021	1	52	52
PLANNED	4/27/2021	4	152	38
PLANNED	4/27/2021	1	51	51
PLANNED	4/27/2021	6	702	117
PLANNED	4/27/2021	7	875	125
PLANNED	4/27/2021	8	200	25
PLANNED	4/27/2021	2	60	30
PLANNED	4/27/2021	2	536	268
CUSTOMER REQUEST	4/27/2021	16	6,000	375
PLANNED	4/27/2021	10	1,990	199
PLANNED	4/27/2021	3	78	26
PLANNED	4/27/2021	1	496	496
PLANNED	4/27/2021	2	218	109
PLANNED	4/27/2021	7	161	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/27/2021	7	126	18
PLANNED	4/27/2021	1	314	314
PLANNED	4/27/2021	1	1	177
PLANNED	4/27/2021	4	424	106
PLANNED	4/27/2021	14	1,120	80
CUSTOMER REQUEST	4/27/2021	5	435	87
CUSTOMER REQUEST	4/27/2021	10	310	31
PLANNED	4/27/2021	12	48	4
PLANNED	4/27/2021	3	42	14
PLANNED	4/27/2021	6	1,245	221
PLANNED	4/27/2021	4	348	87
CUSTOMER REQUEST	4/27/2021	1	351	351
PLANNED	4/27/2021	63	7,749	123
PLANNED	4/27/2021	56	11,480	205
PLANNED	4/27/2021	2	28	14
PLANNED	4/27/2021	10	280	28
PLANNED	4/27/2021	6	1,584	264
PLANNED	4/27/2021	13	130	10
PLANNED	4/27/2021	2	86	43
PLANNED	4/27/2021	2	482	241
PLANNED	4/27/2021	3	39	13
PLANNED	4/27/2021	2	60	30
PLANNED	4/27/2021	1	39	39
PLANNED	4/27/2021	3	6	2
PLANNED	4/27/2021	5	10	2
PLANNED	4/27/2021	2	136	68
PLANNED	4/27/2021	2	206	103
PLANNED	4/27/2021	2	34	17
PLANNED	4/27/2021	4	364	91
PLANNED	4/27/2021	11	1,968	233
PLANNED	4/27/2021	2	358	179
PLANNED	4/27/2021	1	494	494
PLANNED	4/27/2021	1	44	44
PLANNED	4/27/2021	1	196	196
PLANNED	4/27/2021	3	117	39
PLANNED	4/27/2021	8	512	64
PLANNED	4/27/2021	7	77	11
PLANNED	4/27/2021	1	120	120
PLANNED	4/27/2021	2	136	68
CUSTOMER REQUEST	4/27/2021	13	52	4
PLANNED	4/27/2021	7	168	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/27/2021	3	816	272
PLANNED	4/27/2021	2	30	15
PLANNED	4/27/2021	6	54	9
PLANNED	4/27/2021	5	95	19
PLANNED	4/27/2021	1	66	66
CUSTOMER REQUEST	4/27/2021	4	16	4
PLANNED	4/27/2021	1	46	46
PLANNED	4/27/2021	2	410	205
PLANNED	4/27/2021	23	3,496	152
PLANNED	4/27/2021	3	75	25
PLANNED	4/27/2021	17	3,026	178
PLANNED	4/27/2021	3	204	68
PLANNED	4/27/2021	1	6	6
PLANNED	4/27/2021	13	78	6
PLANNED	4/27/2021	4	488	122
PLANNED	4/27/2021	6	582	97
PLANNED	4/27/2021	2	174	87
PLANNED	4/27/2021	3	258	86
CUSTOMER REQUEST	4/27/2021	6	198	33
PLANNED	4/27/2021	8	608	76
PLANNED	4/27/2021	3	69	23
PLANNED	4/27/2021	4	184	46
PLANNED	4/27/2021	9	126	14
PLANNED	4/27/2021	2	30	15
PLANNED	4/27/2021	4	52	13
PLANNED	4/27/2021	3	18	6
PLANNED	4/27/2021	1	56	56
CUSTOMER REQUEST	4/27/2021	9	117	13
PLANNED	4/27/2021	6	414	69
PLANNED	4/27/2021	12	828	69
PLANNED	4/27/2021	8	808	101
PLANNED	4/27/2021	3	210	70
PLANNED	4/27/2021	2	96	48
PLANNED	4/27/2021	2	260	130
PLANNED	4/27/2021	1	74	74
PLANNED	4/27/2021	11	583	53
PLANNED	4/27/2021	1	29	29
PLANNED	4/27/2021	7	91	13
PLANNED	4/27/2021	2	146	73
PLANNED	4/27/2021	18	1,584	88
PLANNED	4/27/2021	1	147	147

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/27/2021	4	172	43
PLANNED	4/27/2021	2	204	102
PLANNED	4/27/2021	14	728	52
PLANNED	4/27/2021	3	48	16
PLANNED	4/27/2021	4	496	124
PLANNED	4/27/2021	6	24	4
PLANNED	4/27/2021	8	72	9
PLANNED	4/27/2021	4	344	86
PLANNED	4/27/2021	2	22	11
PLANNED	4/27/2021	8	216	27
PLANNED	4/27/2021	1	26	26
PLANNED	4/27/2021	2	128	64
PLANNED	4/27/2021	11	132	12
PLANNED	4/27/2021	2	140	70
PLANNED	4/27/2021	3	111	37
PLANNED	4/27/2021	7	182	26
PLANNED	4/27/2021	11	681	139
CUSTOMER REQUEST	4/27/2021	10	70	7
PLANNED	4/27/2021	2	32	16
PLANNED	4/27/2021	8	328	41
PLANNED	4/27/2021	7	273	39
PLANNED	4/27/2021	11	44	4
PLANNED	4/27/2021	2	84	42
CUSTOMER REQUEST	4/27/2021	3	309	103
PLANNED	4/27/2021	8	552	69
PLANNED	4/27/2021	7	441	63
PLANNED	4/27/2021	5	155	31
PLANNED	4/27/2021	3	60	20
PLANNED	4/27/2021	1	167	167
PLANNED	4/27/2021	5	483	145
PLANNED	4/27/2021	2	32	16
PLANNED	4/27/2021	6	504	84
PLANNED	4/27/2021	4	72	18
PLANNED	4/27/2021	4	744	186
PLANNED	4/27/2021	4	88	22
PLANNED	4/27/2021	1	61	61
PLANNED	4/27/2021	2	116	58
PLANNED	4/27/2021	10	80	8
PLANNED	4/27/2021	5	485	97
PLANNED	4/27/2021	7	266	38
PLANNED	4/27/2021	11	1,078	98

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/27/2021	7	616	88
PLANNED	4/27/2021	2	26	13
PLANNED	4/27/2021	6	54	9
PLANNED	4/27/2021	3	66	22
PLANNED	4/27/2021	4	68	17
PLANNED	4/27/2021	3	185	67
PLANNED	4/27/2021	12	36	3
PLANNED	4/27/2021	1	79	79
PLANNED	4/27/2021	1	83	83
PLANNED	4/27/2021	12	408	34
PLANNED	4/27/2021	2	66	33
PLANNED	4/27/2021	7	175	25
PLANNED	4/27/2021	1	40	40
PLANNED	4/27/2021	1	117	117
PLANNED	4/27/2021	1	56	56
PLANNED	4/27/2021	10	250	25
PLANNED	4/27/2021	5	335	67
PLANNED	4/27/2021	7	7	1
PLANNED	4/27/2021	1	59	59
PLANNED	4/27/2021	10	1,020	102
PLANNED	4/27/2021	2	182	91
PLANNED	4/27/2021	6	234	39
PLANNED	4/27/2021	8	352	44
PLANNED	4/27/2021	1	19	19
PLANNED	4/27/2021	2	60	30
PLANNED	4/27/2021	8	760	95
PLANNED	4/27/2021	2	86	43
PLANNED	4/27/2021	2	80	40
PLANNED	4/27/2021	12	204	17
CUSTOMER REQUEST	4/27/2021	4	21	15
PLANNED	4/27/2021	23	414	18
PLANNED	4/27/2021	6	264	44
CUSTOMER REQUEST	4/27/2021	1	121	121
PLANNED	4/27/2021	1	58	58
PLANNED	4/27/2021	4	204	51
PLANNED	4/27/2021	1	26	26
PLANNED	4/27/2021	1	38	38
PLANNED	4/27/2021	4	60	15
PLANNED	4/27/2021	2	42	21
PLANNED	4/27/2021	1	91	91
PLANNED	4/27/2021	3	336	112

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	4/27/2021	1	775	775
PLANNED	4/27/2021	1	84	84
PLANNED	4/27/2021	1	101	101
PLANNED	4/28/2021	3	507	169
PLANNED	4/28/2021	11	1,001	91
PLANNED	4/28/2021	1	84	84
PLANNED	4/28/2021	1	63	63
PLANNED	4/28/2021	3	108	36
PLANNED	4/28/2021	7	1,064	152
PLANNED	4/28/2021	1	162	162
PLANNED	4/28/2021	4	461	136
PLANNED	4/28/2021	1	83	83
PLANNED	4/28/2021	2	558	279
PLANNED	4/28/2021	3	93	31
PLANNED	4/28/2021	2	200	100
PLANNED	4/28/2021	6	192	32
PLANNED	4/28/2021	6	630	105
PLANNED	4/28/2021	6	624	104
PLANNED	4/28/2021	3	48	16
PLANNED	4/28/2021	12	1,368	114
PLANNED	4/28/2021	9	1,008	112
PLANNED	4/28/2021	5	520	104
PLANNED	4/28/2021	12	1,344	112
PLANNED	4/28/2021	10	1,120	112
PLANNED	4/28/2021	2	124	62
PLANNED	4/28/2021	7	147	21
PLANNED	4/28/2021	1	11	11
PLANNED	4/28/2021	3	365	156
PLANNED	4/28/2021	7	224	32
PLANNED	4/28/2021	3	519	173
PLANNED	4/28/2021	8	744	93
PLANNED	4/28/2021	3	12	4
PLANNED	4/28/2021	2	92	46
PLANNED	4/28/2021	7	798	114
PLANNED	4/28/2021	4	48	12
PLANNED	4/28/2021	3	237	79
PLANNED	4/28/2021	2	220	110
PLANNED	4/28/2021	8	704	88
PLANNED	4/28/2021	59	5,487	93
PLANNED	4/28/2021	10	660	66
PLANNED	4/28/2021	1	45	45

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/28/2021	4	1,620	405
PLANNED	4/28/2021	2	124	62
PLANNED	4/28/2021	3	390	130
PLANNED	4/28/2021	4	116	29
PLANNED	4/28/2021	1	223	223
PLANNED	4/28/2021	5	185	37
PLANNED	4/28/2021	3	39	13
PLANNED	4/28/2021	9	1,368	152
PLANNED	4/28/2021	2	160	80
PLANNED	4/28/2021	1	21	21
PLANNED	4/28/2021	1	44	44
PLANNED	4/28/2021	1	75	75
PLANNED	4/28/2021	2	210	105
PLANNED	4/28/2021	14	98	43
PLANNED	4/28/2021	4	136	34
PLANNED	4/28/2021	1	267	267
PLANNED	4/28/2021	1	54	54
PLANNED	4/28/2021	4	124	31
CUSTOMER REQUEST	4/28/2021	7	511	73
PLANNED	4/28/2021	5	40	8
PLANNED	4/28/2021	3	162	54
PLANNED	4/28/2021	2	158	79
PLANNED	4/28/2021	5	15	3
PLANNED	4/28/2021	1	37	37
PLANNED	4/28/2021	4	184	46
PLANNED	4/28/2021	12	624	52
PLANNED	4/28/2021	11	572	52
PLANNED	4/28/2021	3	120	40
CUSTOMER REQUEST	4/28/2021	8	8	1
PLANNED	4/28/2021	1	23	23
PLANNED	4/28/2021	4	40	10
PLANNED	4/28/2021	2	200	100
PLANNED	4/28/2021	2	204	102
PLANNED	4/28/2021	7	301	43
PLANNED	4/28/2021	5	425	85
PLANNED	4/28/2021	7	98	14
PLANNED	4/28/2021	16	1,232	77
PLANNED	4/28/2021	4	760	190
PLANNED	4/28/2021	1	42	42
PLANNED	4/28/2021	1	158	158
PLANNED	4/28/2021	4	216	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/28/2021	2	24	12
PLANNED	4/28/2021	4	340	85
PLANNED	4/28/2021	1	22	22
PLANNED	4/28/2021	7	336	48
PLANNED	4/28/2021	3	60	20
PLANNED	4/28/2021	23	2,392	104
PLANNED	4/28/2021	6	162	27
PLANNED	4/28/2021	6	132	22
PLANNED	4/28/2021	12	888	74
PLANNED	4/28/2021	6	1,494	249
PLANNED	4/28/2021	3	27	9
PLANNED	4/28/2021	2	40	20
PLANNED	4/28/2021	23	4,876	212
PLANNED	4/28/2021	4	984	246
PLANNED	4/28/2021	2	288	144
PLANNED	4/28/2021	1	251	251
PLANNED	4/28/2021	2	50	25
PLANNED	4/28/2021	3	123	41
PLANNED	4/28/2021	1	57	57
PLANNED	4/28/2021	4	292	73
PLANNED	4/28/2021	2	184	92
CUSTOMER REQUEST	4/28/2021	7	49	7
PLANNED	4/28/2021	7	63	9
PLANNED	4/28/2021	3	240	80
PLANNED	4/28/2021	4	484	121
PLANNED	4/28/2021	3	123	41
PLANNED	4/28/2021	12	960	80
PLANNED	4/28/2021	4	72	18
PLANNED	4/28/2021	1	25	25
PLANNED	4/28/2021	1	41	41
PLANNED	4/28/2021	3	297	99
PLANNED	4/28/2021	11	1,254	114
PLANNED	4/28/2021	7	140	20
PLANNED	4/28/2021	3	180	60
PLANNED	4/28/2021	4	172	43
PLANNED	4/28/2021	7	140	20
PLANNED	4/28/2021	6	126	21
PLANNED	4/28/2021	5	440	88
PLANNED	4/28/2021	2	266	133
PLANNED	4/28/2021	2	32	16
PLANNED	4/28/2021	4	252	63

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/28/2021	4	540	135
PLANNED	4/28/2021	2	38	19
PLANNED	4/28/2021	9	873	97
PLANNED	4/28/2021	9	864	96
PLANNED	4/28/2021	3	63	21
PLANNED	4/28/2021	14	182	13
PLANNED	4/28/2021	9	1,647	183
PLANNED	4/28/2021	4	176	44
PLANNED	4/28/2021	5	35	7
PLANNED	4/28/2021	2	185	110
PLANNED	4/28/2021	1	9	9
PLANNED	4/28/2021	8	24	3
PLANNED	4/28/2021	1	111	111
PLANNED	4/28/2021	4	28	7
PLANNED	4/28/2021	6	276	46
PLANNED	4/28/2021	4	124	31
PLANNED	4/28/2021	3	453	151
PLANNED	4/28/2021	1	38	38
PLANNED	4/28/2021	13	1,391	107
PLANNED	4/28/2021	18	234	13
PLANNED	4/28/2021	12	1,284	107
PLANNED	4/28/2021	7	749	107
PLANNED	4/28/2021	1	83	83
PLANNED	4/28/2021	1	97	97
PLANNED	4/28/2021	1	55	55
PLANNED	4/28/2021	1	40	40
PLANNED	4/28/2021	1	22	22
PLANNED	4/28/2021	3	189	63
PLANNED	4/28/2021	13	442	34
PLANNED	4/28/2021	13	26	2
PLANNED	4/28/2021	6	504	138
PLANNED	4/28/2021	2	156	78
PLANNED	4/28/2021	3	27	9
PLANNED	4/28/2021	1	31	31
PLANNED	4/28/2021	2	12	6
PLANNED	4/28/2021	2	88	86
PLANNED	4/28/2021	5	145	29
PLANNED	4/28/2021	4	64	16
PLANNED	4/28/2021	1	62	62
PLANNED	4/28/2021	26	4,242	172
PLANNED	4/28/2021	4	388	97

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/28/2021	11	825	75
CUSTOMER REQUEST	4/28/2021	3	33	11
PLANNED	4/28/2021	1	170	170
PLANNED	4/28/2021	1	51	51
PLANNED	4/28/2021	1	9	9
PLANNED	4/28/2021	15	600	40
PLANNED	4/28/2021	2	184	92
PLANNED	4/28/2021	4	92	23
PLANNED	4/28/2021	2	164	82
PLANNED	4/28/2021	12	456	38
PLANNED	4/28/2021	6	270	45
PLANNED	4/28/2021	3	273	91
PLANNED	4/28/2021	2	142	71
CUSTOMER REQUEST	4/28/2021	6	786	131
PLANNED	4/28/2021	1	31	31
PLANNED	4/28/2021	1	16	16
PLANNED	4/28/2021	1	33	33
PLANNED	4/28/2021	1	12	12
CUSTOMER REQUEST	4/28/2021	1	93	93
CUSTOMER REQUEST	4/28/2021	3	672	224
PLANNED	4/28/2021	25	14,975	599
PLANNED	4/28/2021	1	105	105
PLANNED	4/28/2021	4	468	117
PLANNED	4/29/2021	10	150	15
PLANNED	4/29/2021	10	1,550	155
PLANNED	4/29/2021	1	54	54
PLANNED	4/29/2021	1	225	225
PLANNED	4/29/2021	1	65	65
PLANNED	4/29/2021	1	354	354
PLANNED	4/29/2021	4	860	215
PLANNED	4/29/2021	2	334	167
PLANNED	4/29/2021	4	184	46
PLANNED	4/29/2021	4	132	33
PLANNED	4/29/2021	12	2,772	231
PLANNED	4/29/2021	2	154	99
PLANNED	4/29/2021	4	32	8
PLANNED	4/29/2021	6	1,986	331
PLANNED	4/29/2021	4	604	151
PLANNED	4/29/2021	2	254	127
PLANNED	4/29/2021	3	490	323
PLANNED	4/29/2021	1	71	71

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/29/2021	2	234	117
PLANNED	4/29/2021	2	18	9
PLANNED	4/29/2021	2	48	24
PLANNED	4/29/2021	6	2,160	360
PLANNED	4/29/2021	15	825	55
PLANNED	4/29/2021	14	1,904	136
PLANNED	4/29/2021	9	1,224	136
PLANNED	4/29/2021	8	1,088	136
PLANNED	4/29/2021	2	320	160
PLANNED	4/29/2021	7	245	35
PLANNED	4/29/2021	1	62	62
PLANNED	4/29/2021	4	340	85
PLANNED	4/29/2021	10	1,330	133
PLANNED	4/29/2021	6	372	62
PLANNED	4/29/2021	2	64	32
PLANNED	4/29/2021	2	182	91
CUSTOMER REQUEST	4/29/2021	3	864	288
PLANNED	4/29/2021	4	124	31
CUSTOMER REQUEST	4/29/2021	8	32	4
PLANNED	4/29/2021	1	189	189
PLANNED	4/29/2021	1	264	264
PLANNED	4/29/2021	1	182	182
PLANNED	4/29/2021	5	2,435	487
PLANNED	4/29/2021	4	172	43
PLANNED	4/29/2021	1	132	132
PLANNED	4/29/2021	3	102	34
PLANNED	4/29/2021	2	70	35
PLANNED	4/29/2021	8	872	109
PLANNED	4/29/2021	5	145	29
PLANNED	4/29/2021	1	404	404
PLANNED	4/29/2021	2	240	120
PLANNED	4/29/2021	4	108	27
PLANNED	4/29/2021	4	204	51
PLANNED	4/29/2021	4	1,316	329
PLANNED	4/29/2021	4	136	34
PLANNED	4/29/2021	27	6,102	226
CUSTOMER REQUEST	4/29/2021	7	952	136
CUSTOMER REQUEST	4/29/2021	3	84	28
PLANNED	4/29/2021	1	202	202
PLANNED	4/29/2021	5	110	22
PLANNED	4/29/2021	9	576	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/29/2021	3	162	54
PLANNED	4/29/2021	4	116	29
PLANNED	4/29/2021	1	17	17
PLANNED	4/29/2021	2	72	36
PLANNED	4/29/2021	1	219	219
PLANNED	4/29/2021	1	162	162
PLANNED	4/29/2021	4	120	30
PLANNED	4/29/2021	1	7	7
PLANNED	4/29/2021	4	332	83
PLANNED	4/29/2021	5	50	10
PLANNED	4/29/2021	3	171	57
PLANNED	4/29/2021	15	180	12
PLANNED	4/29/2021	11	2,882	262
PLANNED	4/29/2021	4	28	7
PLANNED	4/29/2021	8	504	63
PLANNED	4/29/2021	8	480	60
PLANNED	4/29/2021	5	720	144
PLANNED	4/29/2021	3	99	33
PLANNED	4/29/2021	1	112	112
CUSTOMER REQUEST	4/29/2021	6	498	83
PLANNED	4/29/2021	1	268	268
PLANNED	4/29/2021	5	1,065	213
PLANNED	4/29/2021	94	5,640	60
CUSTOMER REQUEST	4/29/2021	16	1,680	105
PLANNED	4/29/2021	1	159	159
PLANNED	4/29/2021	11	341	31
PLANNED	4/29/2021	5	145	29
PLANNED	4/29/2021	3	63	21
PLANNED	4/29/2021	1	103	103
PLANNED	4/29/2021	6	1,290	215
CUSTOMER REQUEST	4/29/2021	1	112	112
PLANNED	4/29/2021	6	30	5
PLANNED	4/29/2021	2	72	36
PLANNED	4/29/2021	1	49	49
PLANNED	4/29/2021	7	476	68
PLANNED	4/29/2021	9	459	51
PLANNED	4/29/2021	2	66	33
PLANNED	4/29/2021	1	8	8
PLANNED	4/29/2021	7	1,967	281
PLANNED	4/29/2021	2	118	59
PLANNED	4/29/2021	12	372	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/29/2021	8	440	55
PLANNED	4/29/2021	2	52	26
PLANNED	4/29/2021	6	66	11
CUSTOMER REQUEST	4/29/2021	6	210	35
PLANNED	4/29/2021	3	159	53
CUSTOMER REQUEST	4/29/2021	9	547	451
CUSTOMER REQUEST	4/29/2021	35	105	3
PLANNED	4/29/2021	2	134	67
PLANNED	4/29/2021	2	28	14
PLANNED	4/29/2021	6	36	6
PLANNED	4/29/2021	6	270	45
PLANNED	4/29/2021	6	270	45
CUSTOMER REQUEST	4/29/2021	6	390	65
PLANNED	4/29/2021	4	352	88
PLANNED	4/29/2021	4	104	26
PLANNED	4/29/2021	6	462	77
PLANNED	4/29/2021	6	888	148
PLANNED	4/29/2021	6	252	42
PLANNED	4/29/2021	12	204	17
PLANNED	4/29/2021	6	72	12
PLANNED	4/29/2021	5	390	78
PLANNED	4/29/2021	1	53	53
PLANNED	4/29/2021	6	186	31
PLANNED	4/29/2021	4	196	49
PLANNED	4/29/2021	11	968	88
PLANNED	4/29/2021	4	132	33
PLANNED	4/29/2021	22	682	31
PLANNED	4/29/2021	1	113	113
PLANNED	4/29/2021	3	48	16
PLANNED	4/29/2021	3	36	12
PLANNED	4/29/2021	3	72	24
PLANNED	4/29/2021	3	168	56
PLANNED	4/29/2021	5	425	85
PLANNED	4/29/2021	1	41	41
PLANNED	4/29/2021	2	84	42
PLANNED	4/29/2021	4	88	22
PLANNED	4/29/2021	5	535	107
PLANNED	4/29/2021	20	1,620	81
PLANNED	4/29/2021	3	24	8
PLANNED	4/29/2021	25	600	24
PLANNED	4/29/2021	2	68	34

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/29/2021	1	31	31
PLANNED	4/29/2021	2	188	94
PLANNED	4/29/2021	5	70	14
PLANNED	4/29/2021	45	1,485	33
PLANNED	4/29/2021	12	468	39
PLANNED	4/29/2021	7	105	15
PLANNED	4/29/2021	1	114	114
PLANNED	4/29/2021	3	24	8
PLANNED	4/29/2021	1	58	58
PLANNED	4/29/2021	1	90	90
PLANNED	4/29/2021	3	105	35
PLANNED	4/29/2021	7	245	35
PLANNED	4/29/2021	3	39	13
PLANNED	4/29/2021	9	270	30
CUSTOMER REQUEST	4/29/2021	6	102	17
PLANNED	4/29/2021	2	80	40
PLANNED	4/29/2021	2	18	9
PLANNED	4/29/2021	2	24	12
PLANNED	4/29/2021	14	980	70
PLANNED	4/29/2021	4	224	56
PLANNED	4/29/2021	4	44	11
PLANNED	4/29/2021	2	66	33
PLANNED	4/29/2021	3	36	12
PLANNED	4/29/2021	2	38	19
PLANNED	4/29/2021	3	21	7
CUSTOMER REQUEST	4/29/2021	5	70	14
PLANNED	4/29/2021	13	273	21
PLANNED	4/29/2021	4	20	5
PLANNED	4/29/2021	2	26	13
PLANNED	4/29/2021	4	64	16
CUSTOMER REQUEST	4/29/2021	1	80	80
CUSTOMER REQUEST	4/29/2021	19	19,532	1,028
PLANNED	4/29/2021	1	68	68
PLANNED	4/29/2021	2	16	8
PLANNED	4/29/2021	2	594	297
CUSTOMER REQUEST	4/29/2021	23	943	41
PLANNED	4/29/2021	12	2,772	231
PLANNED	4/29/2021	1	121	121
PLANNED	4/29/2021	1	8	8
PLANNED	4/29/2021	1	71	71
CUSTOMER REQUEST	4/29/2021	1	209	209

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/29/2021	5	140	28
PLANNED	4/29/2021	3	24	8
PLANNED	4/29/2021	2	118	59
PLANNED	4/29/2021	11	1,529	139
PLANNED	4/29/2021	2	770	385
PLANNED	4/29/2021	6	732	122
PLANNED	4/29/2021	1	13	13
PLANNED	4/29/2021	8	840	105
PLANNED	4/29/2021	1	127	127
PLANNED	4/30/2021	1	70	70
PLANNED	4/30/2021	2	212	106
PLANNED	4/30/2021	11	825	75
PLANNED	4/30/2021	1	76	76
PLANNED	4/30/2021	6	360	60
PLANNED	4/30/2021	2	106	53
PLANNED	4/30/2021	2	168	84
PLANNED	4/30/2021	10	1,280	128
PLANNED	4/30/2021	3	369	123
PLANNED	4/30/2021	1	27	27
PLANNED	4/30/2021	1	19	19
PLANNED	4/30/2021	3	348	116
PLANNED	4/30/2021	14	392	28
PLANNED	4/30/2021	2	558	279
PLANNED	4/30/2021	7	126	18
PLANNED	4/30/2021	2	8	4
PLANNED	4/30/2021	4	540	135
PLANNED	4/30/2021	3	51	17
PLANNED	4/30/2021	2	354	177
PLANNED	4/30/2021	4	40	10
PLANNED	4/30/2021	7	154	22
PLANNED	4/30/2021	3	75	25
PLANNED	4/30/2021	4	64	16
PLANNED	4/30/2021	8	264	33
PLANNED	4/30/2021	6	444	74
PLANNED	4/30/2021	2	180	90
PLANNED	4/30/2021	6	1,014	169
PLANNED	4/30/2021	9	666	74
CUSTOMER REQUEST	4/30/2021	10	2,710	271
PLANNED	4/30/2021	10	270	27
PLANNED	4/30/2021	5	685	137
CUSTOMER REQUEST	4/30/2021	21	6,720	320

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/30/2021	6	258	43
CUSTOMER REQUEST	4/30/2021	19	4,997	263
PLANNED	4/30/2021	3	24	8
PLANNED	4/30/2021	13	988	76
PLANNED	4/30/2021	1	85	85
PLANNED	4/30/2021	6	168	28
PLANNED	4/30/2021	5	105	21
PLANNED	4/30/2021	2	148	74
PLANNED	4/30/2021	1	31	31
PLANNED	4/30/2021	4	116	29
CUSTOMER REQUEST	4/30/2021	2	76	38
PLANNED	4/30/2021	12	264	22
PLANNED	4/30/2021	2	76	38
PLANNED	4/30/2021	4	32	8
PLANNED	4/30/2021	27	4,131	153
PLANNED	4/30/2021	2	24	12
PLANNED	4/30/2021	2	82	41
PLANNED	4/30/2021	2	16	8
CUSTOMER REQUEST	4/30/2021	11	803	73
PLANNED	4/30/2021	3	300	100
PLANNED	4/30/2021	1	34	34
PLANNED	4/30/2021	1	16	16
PLANNED	4/30/2021	10	340	34
PLANNED	4/30/2021	2	270	135
PLANNED	4/30/2021	4	32	8
PLANNED	4/30/2021	1	52	52
PLANNED	4/30/2021	2	38	19
CUSTOMER REQUEST	4/30/2021	91	2,457	27
CUSTOMER REQUEST	4/30/2021	8	136	17
PLANNED	4/30/2021	2	168	84
PLANNED	4/30/2021	4	196	49
PLANNED	4/30/2021	1	61	61
PLANNED	4/30/2021	1	75	75
PLANNED	4/30/2021	3	63	21
PLANNED	4/30/2021	5	465	93
PLANNED	4/30/2021	1	114	114
PLANNED	4/30/2021	6	1,296	216
PLANNED	4/30/2021	2	38	19
PLANNED	4/30/2021	2	260	130
PLANNED	4/30/2021	1	20	20
PLANNED	4/30/2021	4	60	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	4/30/2021	5	1,170	234
PLANNED	4/30/2021	5	85	17
PLANNED	4/30/2021	3	162	54
CUSTOMER REQUEST	4/30/2021	1	369	369
PLANNED	4/30/2021	1	61	61
PLANNED	4/30/2021	2	28	14
PLANNED	4/30/2021	4	388	109
PLANNED	4/30/2021	1	221	221
PLANNED	4/30/2021	1	72	72
PLANNED	4/30/2021	10	170	17
PLANNED	4/30/2021	13	702	54
PLANNED	4/30/2021	14	756	54
PLANNED	4/30/2021	12	600	50
PLANNED	4/30/2021	4	288	72
PLANNED	4/30/2021	2	42	21
PLANNED	4/30/2021	1	31	31
PLANNED	4/30/2021	1	37	37
PLANNED	4/30/2021	8	200	25
PLANNED	4/30/2021	4	60	15
PLANNED	4/30/2021	4	176	44
PLANNED	4/30/2021	11	110	10
CUSTOMER REQUEST	4/30/2021	5	255	51
PLANNED	4/30/2021	13	780	60
PLANNED	4/30/2021	1	25	25
PLANNED	4/30/2021	3	69	23
CUSTOMER REQUEST	4/30/2021	3	117	39
PLANNED	4/30/2021	8	224	28
PLANNED	4/30/2021	6	126	21
PLANNED	4/30/2021	5	135	27
CUSTOMER REQUEST	4/30/2021	1	55	55
PLANNED	4/30/2021	12	108	9
PLANNED	4/30/2021	1	144	144
PLANNED	4/30/2021	5	45	9
PLANNED	4/30/2021	3	51	17
PLANNED	4/30/2021	1	110	110
PLANNED	4/30/2021	1	60	60
CUSTOMER REQUEST	4/30/2021	1	220	220
PLANNED	4/30/2021	9	117	13
PLANNED	4/30/2021	3	165	55
PLANNED	4/30/2021	2	236	118
PLANNED	4/30/2021	4	428	107

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/1/2021	19	2,280	120
PLANNED	5/1/2021	3	354	118
PLANNED	5/1/2021	2	316	158
PLANNED	5/1/2021	1	223	223
PLANNED	5/1/2021	1	160	160
PLANNED	5/1/2021	8	3,624	453
PLANNED	5/1/2021	5	690	138
PLANNED	5/1/2021	1	215	215
PLANNED	5/1/2021	3	303	101
PLANNED	5/1/2021	1	130	130
PLANNED	5/1/2021	8	1,816	227
PLANNED	5/1/2021	6	876	146
PLANNED	5/1/2021	5	475	95
PLANNED	5/1/2021	6	894	149
PLANNED	5/1/2021	3	333	111
PLANNED	5/1/2021	5	900	180
PLANNED	5/1/2021	1	81	81
PLANNED	5/1/2021	1	101	101
PLANNED	5/1/2021	3	183	61
PLANNED	5/1/2021	2	46	23
CUSTOMER REQUEST	5/1/2021	1	181	181
PLANNED	5/2/2021	2	392	196
PLANNED	5/2/2021	4	3,576	894
PLANNED	5/2/2021	19	3,249	171
PLANNED	5/2/2021	1	15	15
PLANNED	5/2/2021	5	820	164
PLANNED	5/2/2021	3	525	175
PLANNED	5/2/2021	5	980	196
PLANNED	5/2/2021	6	612	102
PLANNED	5/2/2021	7	1,484	212
PLANNED	5/2/2021	11	143	13
PLANNED	5/2/2021	5	95	19
PLANNED	5/2/2021	2	398	199
PLANNED	5/2/2021	3	60	20
PLANNED	5/2/2021	6	894	149
PLANNED	5/2/2021	1	256	256
PLANNED	5/2/2021	1	107	107
CUSTOMER REQUEST	5/2/2021	1	138	138
PLANNED	5/2/2021	12	2,112	176
PLANNED	5/3/2021	10	2,790	279
PLANNED	5/3/2021	4	688	172

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/3/2021	1	105	105
PLANNED	5/3/2021	1	31	31
PLANNED	5/3/2021	1	164	164
PLANNED	5/3/2021	1	171	171
PLANNED	5/3/2021	1	73	73
PLANNED	5/3/2021	2	146	73
PLANNED	5/3/2021	2	86	43
PLANNED	5/3/2021	1	157	157
PLANNED	5/3/2021	2	80	40
PLANNED	5/3/2021	2	212	106
PLANNED	5/3/2021	3	81	27
PLANNED	5/3/2021	4	68	17
PLANNED	5/3/2021	3	654	218
PLANNED	5/3/2021	4	60	15
PLANNED	5/3/2021	5	220	44
PLANNED	5/3/2021	1	10	10
PLANNED	5/3/2021	5	60	12
PLANNED	5/3/2021	9	621	69
PLANNED	5/3/2021	5	240	48
PLANNED	5/3/2021	12	1,128	94
PLANNED	5/3/2021	6	204	35
PLANNED	5/3/2021	2	72	36
PLANNED	5/3/2021	2	172	86
PLANNED	5/3/2021	10	2,840	284
PLANNED	5/3/2021	1	9	9
PLANNED	5/3/2021	1	8	8
PLANNED	5/3/2021	10	700	70
PLANNED	5/3/2021	7	490	70
PLANNED	5/3/2021	2	38	19
PLANNED	5/3/2021	2	64	32
PLANNED	5/3/2021	2	82	41
PLANNED	5/3/2021	3	585	195
PLANNED	5/3/2021	1	119	119
PLANNED	5/3/2021	3	24	8
PLANNED	5/3/2021	4	284	71
PLANNED	5/3/2021	2	60	30
PLANNED	5/3/2021	1	186	186
PLANNED	5/3/2021	1	247	247
PLANNED	5/3/2021	1	75	75
PLANNED	5/3/2021	1	63	63
PLANNED	5/3/2021	6	678	113

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/3/2021	1	48	48
PLANNED	5/3/2021	4	1,420	355
PLANNED	5/3/2021	3	399	133
PLANNED	5/3/2021	19	6,118	322
PLANNED	5/3/2021	1	9	9
PLANNED	5/3/2021	3	30	10
PLANNED	5/3/2021	2	134	67
PLANNED	5/3/2021	1	115	115
PLANNED	5/3/2021	4	268	67
PLANNED	5/3/2021	3	21	7
PLANNED	5/3/2021	2	114	57
PLANNED	5/3/2021	2	166	83
PLANNED	5/3/2021	1	148	148
PLANNED	5/3/2021	1	80	80
PLANNED	5/3/2021	2	450	225
PLANNED	5/3/2021	2	20	10
PLANNED	5/3/2021	7	973	139
PLANNED	5/3/2021	7	973	139
PLANNED	5/3/2021	8	1,064	133
PLANNED	5/3/2021	7	1,106	158
PLANNED	5/3/2021	1	15	15
PLANNED	5/3/2021	6	222	37
PLANNED	5/3/2021	9	1,287	143
PLANNED	5/3/2021	8	1,224	153
PLANNED	5/3/2021	8	1,176	147
PLANNED	5/3/2021	4	28	7
PLANNED	5/3/2021	3	393	131
PLANNED	5/3/2021	2	222	111
PLANNED	5/3/2021	18	792	44
PLANNED	5/3/2021	2	6	3
PLANNED	5/3/2021	1	114	114
PLANNED	5/3/2021	7	3,094	442
PLANNED	5/3/2021	1	126	126
PLANNED	5/3/2021	5	265	109
PLANNED	5/3/2021	4	92	23
PLANNED	5/3/2021	4	48	12
PLANNED	5/3/2021	2	232	116
PLANNED	5/3/2021	2	338	169
PLANNED	5/3/2021	2	144	72
PLANNED	5/3/2021	1	41	41
PLANNED	5/3/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/3/2021	1	247	247
PLANNED	5/3/2021	1	67	67
PLANNED	5/3/2021	2	348	174
CUSTOMER REQUEST	5/3/2021	4	28	7
PLANNED	5/3/2021	2	92	46
PLANNED	5/3/2021	1	148	148
PLANNED	5/3/2021	2	68	34
PLANNED	5/3/2021	6	864	144
PLANNED	5/3/2021	9	1,017	113
PLANNED	5/3/2021	2	70	35
PLANNED	5/3/2021	4	236	59
PLANNED	5/3/2021	5	236	79
PLANNED	5/3/2021	3	453	151
PLANNED	5/3/2021	1	11	11
PLANNED	5/3/2021	1	25	25
PLANNED	5/3/2021	4	40	10
PLANNED	5/3/2021	4	136	34
PLANNED	5/3/2021	1	17	17
PLANNED	5/3/2021	9	729	81
PLANNED	5/3/2021	10	620	62
PLANNED	5/3/2021	18	1,332	74
PLANNED	5/3/2021	1	8	8
PLANNED	5/3/2021	1	16	16
PLANNED	5/3/2021	6	486	81
PLANNED	5/3/2021	7	1,134	162
PLANNED	5/3/2021	6	486	81
PLANNED	5/3/2021	1	50	50
PLANNED	5/3/2021	4	60	15
PLANNED	5/3/2021	7	140	20
PLANNED	5/3/2021	1	10	10
PLANNED	5/3/2021	3	393	131
PLANNED	5/3/2021	4	328	82
PLANNED	5/3/2021	3	309	103
PLANNED	5/3/2021	2	108	54
PLANNED	5/3/2021	8	424	53
PLANNED	5/3/2021	2	244	122
CUSTOMER REQUEST	5/3/2021	1	192	192
PLANNED	5/3/2021	1	1	1
PLANNED	5/3/2021	6	534	89
PLANNED	5/3/2021	1	25	25
PLANNED	5/3/2021	37	5,032	136

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/3/2021	11	85	65
PLANNED	5/3/2021	8	128	16
PLANNED	5/3/2021	4	56	14
PLANNED	5/3/2021	1	13	13
PLANNED	5/3/2021	2	40	20
PLANNED	5/3/2021	7	973	139
PLANNED	5/3/2021	49	2,842	58
PLANNED	5/3/2021	12	1,176	98
PLANNED	5/3/2021	1	95	95
PLANNED	5/3/2021	12	2,844	237
PLANNED	5/3/2021	3	657	219
PLANNED	5/3/2021	1	96	96
PLANNED	5/3/2021	9	693	77
PLANNED	5/3/2021	5	360	72
PLANNED	5/3/2021	3	92	35
PLANNED	5/3/2021	1	19	19
PLANNED	5/3/2021	2	62	31
PLANNED	5/3/2021	30	1,740	58
PLANNED	5/3/2021	5	40	8
CUSTOMER REQUEST	5/3/2021	1	5	5
PLANNED	5/3/2021	15	3,780	252
PLANNED	5/3/2021	1	156	156
PLANNED	5/3/2021	1	7	7
PLANNED	5/3/2021	3	276	92
PLANNED	5/3/2021	7	259	37
PLANNED	5/3/2021	7	252	36
PLANNED	5/3/2021	2	78	39
PLANNED	5/3/2021	4	48	12
PLANNED	5/3/2021	4	88	22
PLANNED	5/3/2021	2	28	14
PLANNED	5/3/2021	3	240	80
PLANNED	5/3/2021	18	828	46
PLANNED	5/3/2021	7	210	30
PLANNED	5/3/2021	6	132	22
PLANNED	5/3/2021	1	118	118
PLANNED	5/3/2021	4	288	72
PLANNED	5/3/2021	3	60	20
PLANNED	5/3/2021	2	16	8
PLANNED	5/3/2021	3	210	70
PLANNED	5/3/2021	5	140	28
PLANNED	5/3/2021	2	62	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/3/2021	2	164	82
PLANNED	5/3/2021	2	130	65
PLANNED	5/3/2021	4	512	128
PLANNED	5/3/2021	1	8	8
PLANNED	5/3/2021	2	60	30
PLANNED	5/3/2021	2	238	119
PLANNED	5/3/2021	2	66	33
PLANNED	5/3/2021	1	51	51
PLANNED	5/3/2021	1	96	96
PLANNED	5/3/2021	6	108	18
PLANNED	5/3/2021	4	224	56
PLANNED	5/3/2021	5	100	20
PLANNED	5/3/2021	2	134	67
PLANNED	5/3/2021	2	192	96
PLANNED	5/3/2021	2	14	7
PLANNED	5/3/2021	2	268	134
PLANNED	5/3/2021	1	78	78
PLANNED	5/3/2021	4	436	109
PLANNED	5/3/2021	4	132	33
PLANNED	5/3/2021	1	136	136
PLANNED	5/3/2021	4	296	74
PLANNED	5/3/2021	1	130	130
PLANNED	5/3/2021	17	3,519	207
PLANNED	5/3/2021	1	81	81
PLANNED	5/3/2021	17	3,179	187
PLANNED	5/3/2021	4	788	197
PLANNED	5/3/2021	1	47	47
PLANNED	5/4/2021	1	108	108
PLANNED	5/4/2021	2	258	129
PLANNED	5/4/2021	34	4,726	139
PLANNED	5/4/2021	13	676	52
PLANNED	5/4/2021	6	6	1
PLANNED	5/4/2021	3	831	277
PLANNED	5/4/2021	4	1,228	307
PLANNED	5/4/2021	1	252	252
PLANNED	5/4/2021	2	152	76
PLANNED	5/4/2021	1	132	132
PLANNED	5/4/2021	12	1,488	124
PLANNED	5/4/2021	1	158	158
PLANNED	5/4/2021	25	1,075	43
PLANNED	5/4/2021	2	212	106

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	1	52	52
PLANNED	5/4/2021	3	258	86
PLANNED	5/4/2021	4	952	238
PLANNED	5/4/2021	12	336	28
PLANNED	5/4/2021	2	136	68
PLANNED	5/4/2021	1	93	93
PLANNED	5/4/2021	4	272	68
PLANNED	5/4/2021	9	927	103
PLANNED	5/4/2021	4	428	107
PLANNED	5/4/2021	9	1,017	113
PLANNED	5/4/2021	5	705	141
PLANNED	5/4/2021	8	72	9
PLANNED	5/4/2021	3	174	58
PLANNED	5/4/2021	1	70	70
PLANNED	5/4/2021	7	1,120	160
PLANNED	5/4/2021	7	1,120	160
PLANNED	5/4/2021	9	1,386	154
PLANNED	5/4/2021	9	585	65
PLANNED	5/4/2021	1	111	111
PLANNED	5/4/2021	2	42	21
PLANNED	5/4/2021	1	39	39
PLANNED	5/4/2021	3	72	24
PLANNED	5/4/2021	8	96	12
PLANNED	5/4/2021	1	139	139
PLANNED	5/4/2021	2	146	73
PLANNED	5/4/2021	6	144	24
PLANNED	5/4/2021	12	1,152	96
PLANNED	5/4/2021	1	43	43
PLANNED	5/4/2021	1	18	18
CUSTOMER REQUEST	5/4/2021	4	72	18
PLANNED	5/4/2021	17	527	31
PLANNED	5/4/2021	5	250	50
PLANNED	5/4/2021	4	444	111
PLANNED	5/4/2021	3	9	3
PLANNED	5/4/2021	6	114	19
PLANNED	5/4/2021	4	72	18
PLANNED	5/4/2021	8	560	70
PLANNED	5/4/2021	4	124	31
PLANNED	5/4/2021	8	336	42
PLANNED	5/4/2021	2	22	11
PLANNED	5/4/2021	3	54	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	2	20	10
PLANNED	5/4/2021	1	64	64
PLANNED	5/4/2021	2	18	9
PLANNED	5/4/2021	2	22	11
PLANNED	5/4/2021	2	490	245
PLANNED	5/4/2021	8	296	37
PLANNED	5/4/2021	5	413	121
PLANNED	5/4/2021	4	68	17
PLANNED	5/4/2021	52	6,136	118
PLANNED	5/4/2021	1	264	264
PLANNED	5/4/2021	5	125	25
PLANNED	5/4/2021	2	42	21
PLANNED	5/4/2021	2	16	8
PLANNED	5/4/2021	3	222	74
PLANNED	5/4/2021	1	58	58
PLANNED	5/4/2021	31	1,984	64
PLANNED	5/4/2021	1	87	87
PLANNED	5/4/2021	16	2,032	127
PLANNED	5/4/2021	11	1,386	126
PLANNED	5/4/2021	3	360	120
PLANNED	5/4/2021	1	109	109
PLANNED	5/4/2021	4	120	30
PLANNED	5/4/2021	4	480	120
PLANNED	5/4/2021	1	13	13
PLANNED	5/4/2021	1	225	225
PLANNED	5/4/2021	4	532	133
PLANNED	5/4/2021	3	360	120
PLANNED	5/4/2021	8	552	69
PLANNED	5/4/2021	5	365	73
PLANNED	5/4/2021	1	139	139
PLANNED	5/4/2021	27	1,755	65
PLANNED	5/4/2021	10	1,730	173
PLANNED	5/4/2021	110	2,200	20
PLANNED	5/4/2021	1	146	146
CUSTOMER REQUEST	5/4/2021	1	84	84
PLANNED	5/4/2021	3	132	44
PLANNED	5/4/2021	9	1,719	191
PLANNED	5/4/2021	3	219	73
PLANNED	5/4/2021	2	146	73
PLANNED	5/4/2021	9	495	55
PLANNED	5/4/2021	5	5	1

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	1	10	10
PLANNED	5/4/2021	3	36	12
PLANNED	5/4/2021	2	224	112
PLANNED	5/4/2021	9	288	32
PLANNED	5/4/2021	3	78	26
PLANNED	5/4/2021	2	24	12
PLANNED	5/4/2021	6	492	82
PLANNED	5/4/2021	1	132	132
PLANNED	5/4/2021	2	90	45
PLANNED	5/4/2021	3	228	76
PLANNED	5/4/2021	12	144	12
PLANNED	5/4/2021	1	140	140
PLANNED	5/4/2021	4	112	28
PLANNED	5/4/2021	2	150	75
PLANNED	5/4/2021	4	64	16
PLANNED	5/4/2021	3	627	209
PLANNED	5/4/2021	4	36	9
PLANNED	5/4/2021	2	16	8
PLANNED	5/4/2021	2	120	60
PLANNED	5/4/2021	1	41	41
PLANNED	5/4/2021	12	384	32
PLANNED	5/4/2021	2	24	12
PLANNED	5/4/2021	2	396	198
PLANNED	5/4/2021	2	24	12
PLANNED	5/4/2021	3	435	145
PLANNED	5/4/2021	2	226	113
PLANNED	5/4/2021	2	574	287
PLANNED	5/4/2021	16	117	102
PLANNED	5/4/2021	4	48	12
PLANNED	5/4/2021	2	274	137
PLANNED	5/4/2021	7	476	68
PLANNED	5/4/2021	4	220	55
PLANNED	5/4/2021	4	112	28
PLANNED	5/4/2021	10	890	89
PLANNED	5/4/2021	4	284	71
PLANNED	5/4/2021	1	77	77
PLANNED	5/4/2021	3	549	183
PLANNED	5/4/2021	2	16	8
PLANNED	5/4/2021	2	306	153
PLANNED	5/4/2021	2	68	34
PLANNED	5/4/2021	3	81	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	12	3,653	437
PLANNED	5/4/2021	4	84	21
CUSTOMER REQUEST	5/4/2021	1	386	386
PLANNED	5/4/2021	3	183	61
PLANNED	5/4/2021	1	12	12
CUSTOMER REQUEST	5/4/2021	1	95	95
PLANNED	5/4/2021	1	241	241
PLANNED	5/4/2021	13	845	65
CUSTOMER REQUEST	5/4/2021	8	8	1
CUSTOMER REQUEST	5/4/2021	1	117	117
PLANNED	5/4/2021	2	162	81
PLANNED	5/4/2021	2	140	70
PLANNED	5/4/2021	1	24	24
CUSTOMER REQUEST	5/4/2021	10	880	88
PLANNED	5/4/2021	4	156	39
PLANNED	5/4/2021	7	1,477	211
PLANNED	5/4/2021	3	99	33
PLANNED	5/4/2021	4	44	11
PLANNED	5/4/2021	4	84	21
PLANNED	5/4/2021	11	1,353	123
PLANNED	5/4/2021	2	450	225
PLANNED	5/4/2021	8	168	21
PLANNED	5/4/2021	1	12	12
PLANNED	5/4/2021	2	256	128
PLANNED	5/4/2021	17	3,077	181
PLANNED	5/4/2021	3	24	8
PLANNED	5/4/2021	23	1,679	73
PLANNED	5/4/2021	2	40	20
PLANNED	5/4/2021	1	157	157
PLANNED	5/4/2021	3	141	47
PLANNED	5/4/2021	3	60	20
PLANNED	5/4/2021	2	124	62
PLANNED	5/4/2021	3	87	29
PLANNED	5/4/2021	3	159	53
PLANNED	5/4/2021	8	168	21
PLANNED	5/4/2021	3	42	14
PLANNED	5/4/2021	3	297	99
PLANNED	5/4/2021	1	8	8
PLANNED	5/4/2021	5	225	45
PLANNED	5/4/2021	5	70	14
PLANNED	5/4/2021	4	340	85

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	4	852	213
PLANNED	5/4/2021	3	75	25
PLANNED	5/4/2021	10	570	57
PLANNED	5/4/2021	8	520	65
PLANNED	5/4/2021	6	276	46
PLANNED	5/4/2021	3	102	34
PLANNED	5/4/2021	6	150	25
PLANNED	5/4/2021	4	264	66
PLANNED	5/4/2021	2	60	30
PLANNED	5/4/2021	1	225	225
PLANNED	5/4/2021	1	60	60
PLANNED	5/4/2021	2	88	44
PLANNED	5/4/2021	2	78	39
PLANNED	5/4/2021	2	156	78
PLANNED	5/4/2021	4	28	7
PLANNED	5/4/2021	12	1,188	99
PLANNED	5/4/2021	3	216	72
PLANNED	5/4/2021	3	36	12
PLANNED	5/4/2021	4	176	44
PLANNED	5/4/2021	110	2,420	22
PLANNED	5/4/2021	3	300	100
PLANNED	5/4/2021	2	18	9
PLANNED	5/4/2021	1	95	95
CUSTOMER REQUEST	5/4/2021	1	191	191
CUSTOMER REQUEST	5/4/2021	1	89	89
CUSTOMER REQUEST	5/4/2021	1	169	169
PLANNED	5/4/2021	7	329	47
PLANNED	5/4/2021	3	102	34
PLANNED	5/4/2021	1	57	57
PLANNED	5/4/2021	1	168	168
PLANNED	5/4/2021	1	27	27
PLANNED	5/4/2021	8	120	15
PLANNED	5/4/2021	8	512	64
PLANNED	5/4/2021	1	120	120
PLANNED	5/4/2021	1	136	136
PLANNED	5/4/2021	1	273	273
PLANNED	5/4/2021	2	150	75
PLANNED	5/4/2021	2	328	164
PLANNED	5/4/2021	1	32	32
PLANNED	5/4/2021	8	456	57
PLANNED	5/4/2021	1	146	146

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/4/2021	1	33	33
PLANNED	5/5/2021	1	125	125
PLANNED	5/5/2021	1	126	126
PLANNED	5/5/2021	8	693	221
PLANNED	5/5/2021	1	103	103
PLANNED	5/5/2021	4	8	2
PLANNED	5/5/2021	12	96	8
PLANNED	5/5/2021	9	1,756	262
PLANNED	5/5/2021	5	175	35
PLANNED	5/5/2021	2	170	85
PLANNED	5/5/2021	1	13	13
PLANNED	5/5/2021	24	3,864	161
PLANNED	5/5/2021	7	427	61
PLANNED	5/5/2021	1	81	81
PLANNED	5/5/2021	4	432	108
PLANNED	5/5/2021	1	103	103
PLANNED	5/5/2021	3	24	8
PLANNED	5/5/2021	3	666	222
PLANNED	5/5/2021	1	222	222
PLANNED	5/5/2021	6	84	14
PLANNED	5/5/2021	4	88	22
PLANNED	5/5/2021	2	158	79
PLANNED	5/5/2021	5	205	41
PLANNED	5/5/2021	3	75	25
PLANNED	5/5/2021	6	600	100
PLANNED	5/5/2021	15	1,095	73
PLANNED	5/5/2021	11	737	67
PLANNED	5/5/2021	6	42	7
PLANNED	5/5/2021	3	310	162
PLANNED	5/5/2021	6	18	3
PLANNED	5/5/2021	7	49	7
PLANNED	5/5/2021	2	194	97
PLANNED	5/5/2021	8	64	8
PLANNED	5/5/2021	1	10	10
PLANNED	5/5/2021	2	350	175
PLANNED	5/5/2021	5	45	9
PLANNED	5/5/2021	2	160	80
PLANNED	5/5/2021	2	34	17
PLANNED	5/5/2021	2	288	144
PLANNED	5/5/2021	4	4	1
CUSTOMER REQUEST	5/5/2021	7	280	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/5/2021	8	1,728	216
PLANNED	5/5/2021	4	244	61
CUSTOMER REQUEST	5/5/2021	4	56	14
PLANNED	5/5/2021	2	212	106
PLANNED	5/5/2021	1	22	22
PLANNED	5/5/2021	9	1,080	120
PLANNED	5/5/2021	7	385	55
PLANNED	5/5/2021	9	1,026	114
PLANNED	5/5/2021	7	784	112
PLANNED	5/5/2021	4	100	25
PLANNED	5/5/2021	1	36	36
PLANNED	5/5/2021	1	59	59
PLANNED	5/5/2021	2	118	59
PLANNED	5/5/2021	4	16	4
PLANNED	5/5/2021	1	132	132
PLANNED	5/5/2021	8	752	94
PLANNED	5/5/2021	2	418	209
PLANNED	5/5/2021	2	24	12
PLANNED	5/5/2021	1	146	146
PLANNED	5/5/2021	5	55	11
PLANNED	5/5/2021	4	1,312	328
PLANNED	5/5/2021	3	51	17
PLANNED	5/5/2021	2	416	208
PLANNED	5/5/2021	5	1,020	204
PLANNED	5/5/2021	4	736	184
PLANNED	5/5/2021	5	70	14
PLANNED	5/5/2021	33	4,686	142
PLANNED	5/5/2021	1	6	6
PLANNED	5/5/2021	1	99	99
CUSTOMER REQUEST	5/5/2021	3	54	18
PLANNED	5/5/2021	10	310	31
PLANNED	5/5/2021	1	20	20
PLANNED	5/5/2021	4	180	45
PLANNED	5/5/2021	2	32	16
PLANNED	5/5/2021	4	148	37
PLANNED	5/5/2021	3	6	2
PLANNED	5/5/2021	1	6	6
PLANNED	5/5/2021	3	447	149
PLANNED	5/5/2021	4	84	21
PLANNED	5/5/2021	4	752	188
PLANNED	5/5/2021	1	10	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/5/2021	3	51	17
PLANNED	5/5/2021	5	1,245	249
PLANNED	5/5/2021	6	546	91
PLANNED	5/5/2021	8	40	5
PLANNED	5/5/2021	4	1,016	254
PLANNED	5/5/2021	4	408	102
PLANNED	5/5/2021	3	45	15
PLANNED	5/5/2021	1	10	10
PLANNED	5/5/2021	4	48	12
PLANNED	5/5/2021	5	305	61
PLANNED	5/5/2021	3	189	63
PLANNED	5/5/2021	8	1,096	137
PLANNED	5/5/2021	6	60	10
PLANNED	5/5/2021	5	690	138
PLANNED	5/5/2021	5	685	137
PLANNED	5/5/2021	7	700	100
PLANNED	5/5/2021	2	22	11
PLANNED	5/5/2021	2	24	12
PLANNED	5/5/2021	2	92	46
PLANNED	5/5/2021	3	45	15
PLANNED	5/5/2021	2	140	70
PLANNED	5/5/2021	1	10	10
PLANNED	5/5/2021	6	870	145
PLANNED	5/5/2021	10	1,060	106
PLANNED	5/5/2021	5	185	37
PLANNED	5/5/2021	6	696	116
PLANNED	5/5/2021	3	246	82
PLANNED	5/5/2021	10	1,380	138
PLANNED	5/5/2021	5	1,265	253
PLANNED	5/5/2021	4	668	167
PLANNED	5/5/2021	3	27	9
PLANNED	5/5/2021	1	10	10
PLANNED	5/5/2021	4	108	27
PLANNED	5/5/2021	6	216	36
PLANNED	5/5/2021	1	153	153
PLANNED	5/5/2021	11	869	79
PLANNED	5/5/2021	1	90	90
PLANNED	5/5/2021	4	182	78
PLANNED	5/5/2021	1	64	64
PLANNED	5/5/2021	4	44	11
PLANNED	5/5/2021	1	38	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/5/2021	1	85	85
PLANNED	5/5/2021	3	81	27
CUSTOMER REQUEST	5/5/2021	2	56	28
CUSTOMER REQUEST	5/5/2021	1	104	104
PLANNED	5/5/2021	4	32	8
PLANNED	5/5/2021	3	291	97
PLANNED	5/5/2021	2	154	77
PLANNED	5/5/2021	1	62	62
PLANNED	5/5/2021	4	84	21
PLANNED	5/5/2021	2	4	2
PLANNED	5/5/2021	1	8	8
PLANNED	5/5/2021	1	65	65
PLANNED	5/5/2021	10	60	6
CUSTOMER REQUEST	5/5/2021	8	8	1
PLANNED	5/5/2021	2	22	11
PLANNED	5/5/2021	1	37	37
PLANNED	5/5/2021	3	174	58
PLANNED	5/5/2021	7	105	15
PLANNED	5/5/2021	29	9,164	316
PLANNED	5/5/2021	4	44	11
PLANNED	5/5/2021	1	7	7
PLANNED	5/5/2021	3	30	10
PLANNED	5/5/2021	39	624	16
PLANNED	5/5/2021	11	110	10
PLANNED	5/5/2021	1	48	48
PLANNED	5/5/2021	2	92	46
PLANNED	5/5/2021	3	279	93
PLANNED	5/5/2021	8	48	6
PLANNED	5/5/2021	4	132	33
PLANNED	5/5/2021	4	216	54
PLANNED	5/5/2021	2	14	7
PLANNED	5/5/2021	4	56	14
PLANNED	5/5/2021	5	346	134
PLANNED	5/5/2021	2	238	119
PLANNED	5/5/2021	2	46	23
PLANNED	5/5/2021	7	56	8
PLANNED	5/5/2021	4	96	24
PLANNED	5/5/2021	1	184	184
PLANNED	5/5/2021	7	105	15
PLANNED	5/5/2021	4	796	199
PLANNED	5/5/2021	5	170	34

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/5/2021	2	78	39
PLANNED	5/5/2021	3	99	33
PLANNED	5/5/2021	1	238	238
PLANNED	5/5/2021	2	252	126
PLANNED	5/5/2021	4	108	27
PLANNED	5/5/2021	2	18	9
PLANNED	5/5/2021	3	45	15
PLANNED	5/5/2021	1	36	36
PLANNED	5/5/2021	4	40	10
PLANNED	5/5/2021	10	660	66
PLANNED	5/5/2021	3	33	11
PLANNED	5/5/2021	8	152	19
PLANNED	5/5/2021	4	36	9
PLANNED	5/5/2021	2	26	13
PLANNED	5/5/2021	1	235	235
PLANNED	5/5/2021	3	51	17
PLANNED	5/5/2021	3	126	42
PLANNED	5/5/2021	2	116	58
PLANNED	5/5/2021	3	111	37
PLANNED	5/5/2021	9	324	36
PLANNED	5/5/2021	4	332	83
PLANNED	5/5/2021	5	75	15
PLANNED	5/5/2021	2	4	2
PLANNED	5/5/2021	8	808	101
PLANNED	5/5/2021	3	45	15
PLANNED	5/5/2021	7	238	34
PLANNED	5/5/2021	1	143	143
PLANNED	5/5/2021	3	48	16
PLANNED	5/5/2021	4	540	135
PLANNED	5/5/2021	2	12	6
PLANNED	5/5/2021	1	78	78
PLANNED	5/5/2021	3	222	122
PLANNED	5/5/2021	1	55	55
PLANNED	5/5/2021	7	315	45
PLANNED	5/5/2021	3	174	58
PLANNED	5/5/2021	1	64	64
PLANNED	5/5/2021	3	57	19
PLANNED	5/5/2021	1	41	41
PLANNED	5/5/2021	8	1,072	134
PLANNED	5/5/2021	1	57	57
PLANNED	5/5/2021	2	104	52

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/5/2021	6	114	19
PLANNED	5/5/2021	2	190	95
PLANNED	5/5/2021	2	102	51
PLANNED	5/5/2021	7	70	10
PLANNED	5/5/2021	1	37	37
PLANNED	5/5/2021	3	69	23
PLANNED	5/5/2021	1	12	12
PLANNED	5/5/2021	2	44	22
PLANNED	5/5/2021	1	208	208
PLANNED	5/5/2021	3	336	112
PLANNED	5/5/2021	1	21	21
PLANNED	5/5/2021	2	104	52
PLANNED	5/5/2021	3	117	39
PLANNED	5/5/2021	3	66	22
PLANNED	5/5/2021	1	44	44
PLANNED	5/5/2021	1	145	145
PLANNED	5/5/2021	2	24	12
PLANNED	5/5/2021	1	50	50
PLANNED	5/5/2021	2	54	27
PLANNED	5/5/2021	1	40	40
PLANNED	5/5/2021	3	48	16
PLANNED	5/5/2021	3	51	17
PLANNED	5/5/2021	1	23	23
PLANNED	5/5/2021	3	168	56
PLANNED	5/5/2021	10	200	20
PLANNED	5/5/2021	2	302	151
PLANNED	5/5/2021	1	126	126
PLANNED	5/5/2021	2	174	87
PLANNED	5/5/2021	2	154	77
PLANNED	5/6/2021	1	341	341
PLANNED	5/6/2021	2	204	102
PLANNED	5/6/2021	8	352	44
PLANNED	5/6/2021	3	516	172
PLANNED	5/6/2021	7	343	49
PLANNED	5/6/2021	4	572	143
CUSTOMER REQUEST	5/6/2021	6	510	85
PLANNED	5/6/2021	2	72	36
PLANNED	5/6/2021	3	45	15
CUSTOMER REQUEST	5/6/2021	36	5,580	155
PLANNED	5/6/2021	2	270	135
PLANNED	5/6/2021	8	992	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/6/2021	1	76	76
PLANNED	5/6/2021	3	336	112
PLANNED	5/6/2021	8	160	20
PLANNED	5/6/2021	4	368	146
PLANNED	5/6/2021	14	420	30
PLANNED	5/6/2021	2	964	482
PLANNED	5/6/2021	2	146	73
PLANNED	5/6/2021	5	615	168
PLANNED	5/6/2021	7	707	101
PLANNED	5/6/2021	6	606	101
PLANNED	5/6/2021	6	606	101
PLANNED	5/6/2021	1	138	138
PLANNED	5/6/2021	8	504	63
PLANNED	5/6/2021	10	630	63
PLANNED	5/6/2021	13	1,326	102
PLANNED	5/6/2021	2	276	138
PLANNED	5/6/2021	3	147	49
PLANNED	5/6/2021	1	115	115
PLANNED	5/6/2021	2	488	244
PLANNED	5/6/2021	2	38	19
PLANNED	5/6/2021	21	2,394	114
CUSTOMER REQUEST	5/6/2021	6	168	28
PLANNED	5/6/2021	4	60	15
PLANNED	5/6/2021	8	176	22
PLANNED	5/6/2021	2	26	13
PLANNED	5/6/2021	13	2,002	154
PLANNED	5/6/2021	1	101	101
PLANNED	5/6/2021	5	945	189
PLANNED	5/6/2021	2	136	68
PLANNED	5/6/2021	5	440	88
PLANNED	5/6/2021	1	50	50
PLANNED	5/6/2021	4	512	128
PLANNED	5/6/2021	2	184	92
PLANNED	5/6/2021	3	42	14
PLANNED	5/6/2021	1	5	5
PLANNED	5/6/2021	4	192	48
PLANNED	5/6/2021	2	230	115
PLANNED	5/6/2021	1	10	10
PLANNED	5/6/2021	2	108	54
PLANNED	5/6/2021	2	44	22
PLANNED	5/6/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/6/2021	2	22	11
PLANNED	5/6/2021	4	356	89
PLANNED	5/6/2021	3	36	12
PLANNED	5/6/2021	4	564	141
PLANNED	5/6/2021	1	30	30
PLANNED	5/6/2021	2	324	162
PLANNED	5/6/2021	4	132	33
PLANNED	5/6/2021	53	583	11
PLANNED	5/6/2021	29	3,886	134
PLANNED	5/6/2021	5	1,120	224
PLANNED	5/6/2021	1	139	139
PLANNED	5/6/2021	3	108	36
PLANNED	5/6/2021	6	264	44
CUSTOMER REQUEST	5/6/2021	10	160	16
CUSTOMER REQUEST	5/6/2021	1	61	61
PLANNED	5/6/2021	4	300	75
PLANNED	5/6/2021	1	56	56
PLANNED	5/6/2021	10	930	104
PLANNED	5/6/2021	4	604	151
PLANNED	5/6/2021	2	156	78
PLANNED	5/6/2021	9	396	44
PLANNED	5/6/2021	10	1,740	174
PLANNED	5/6/2021	2	22	11
PLANNED	5/6/2021	4	48	12
PLANNED	5/6/2021	4	684	171
PLANNED	5/6/2021	2	62	31
PLANNED	5/6/2021	2	40	20
PLANNED	5/6/2021	3	39	13
PLANNED	5/6/2021	4	100	25
PLANNED	5/6/2021	1	17	17
PLANNED	5/6/2021	3	45	15
PLANNED	5/6/2021	8	648	81
PLANNED	5/6/2021	3	27	9
PLANNED	5/6/2021	9	963	107
PLANNED	5/6/2021	8	1,448	181
PLANNED	5/6/2021	1	79	79
PLANNED	5/6/2021	4	584	146
PLANNED	5/6/2021	3	434	198
PLANNED	5/6/2021	1	259	259
PLANNED	5/6/2021	1	16	16
PLANNED	5/6/2021	2	48	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/6/2021	3	369	123
PLANNED	5/6/2021	6	420	70
PLANNED	5/6/2021	3	222	74
PLANNED	5/6/2021	1	18	18
PLANNED	5/6/2021	2	68	34
PLANNED	5/6/2021	3	48	16
PLANNED	5/6/2021	3	57	19
PLANNED	5/6/2021	8	120	15
PLANNED	5/6/2021	2	148	74
PLANNED	5/6/2021	4	164	41
PLANNED	5/6/2021	2	179	125
PLANNED	5/6/2021	2	62	31
PLANNED	5/6/2021	5	140	28
PLANNED	5/6/2021	2	28	14
PLANNED	5/6/2021	4	132	33
PLANNED	5/6/2021	1	63	63
PLANNED	5/6/2021	1	35	35
PLANNED	5/6/2021	23	3,105	135
PLANNED	5/6/2021	7	70	10
PLANNED	5/6/2021	2	190	95
PLANNED	5/6/2021	4	56	14
PLANNED	5/6/2021	3	150	50
PLANNED	5/6/2021	1	2	2
PLANNED	5/6/2021	5	100	20
PLANNED	5/6/2021	5	65	13
PLANNED	5/6/2021	15	555	37
PLANNED	5/6/2021	1	110	110
PLANNED	5/6/2021	2	288	144
PLANNED	5/6/2021	8	136	17
PLANNED	5/6/2021	5	1,115	223
PLANNED	5/6/2021	7	119	17
PLANNED	5/6/2021	4	60	15
PLANNED	5/6/2021	1	13	13
PLANNED	5/6/2021	5	180	36
PLANNED	5/6/2021	1	86	86
PLANNED	5/6/2021	3	84	28
PLANNED	5/6/2021	2	26	13
PLANNED	5/6/2021	4	560	140
PLANNED	5/6/2021	1	19	19
PLANNED	5/6/2021	4	328	82
PLANNED	5/6/2021	3	45	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/6/2021	25	4,675	187
PLANNED	5/6/2021	9	594	66
PLANNED	5/6/2021	3	72	24
PLANNED	5/6/2021	2	24	12
PLANNED	5/6/2021	4	468	117
CUSTOMER REQUEST	5/6/2021	6	60	10
PLANNED	5/6/2021	1	15	15
PLANNED	5/6/2021	5	489	121
PLANNED	5/6/2021	1	18	18
PLANNED	5/6/2021	2	114	57
PLANNED	5/6/2021	3	132	44
PLANNED	5/6/2021	3	81	27
PLANNED	5/6/2021	9	585	65
PLANNED	5/6/2021	13	195	15
PLANNED	5/6/2021	4	108	27
PLANNED	5/6/2021	1	48	48
PLANNED	5/6/2021	2	80	40
PLANNED	5/6/2021	17	136	8
PLANNED	5/6/2021	2	168	84
PLANNED	5/6/2021	2	226	113
PLANNED	5/6/2021	2	30	15
PLANNED	5/6/2021	1	10	10
PLANNED	5/6/2021	3	42	14
PLANNED	5/6/2021	3	24	8
PLANNED	5/6/2021	3	66	22
PLANNED	5/6/2021	3	33	11
PLANNED	5/6/2021	8	200	25
PLANNED	5/6/2021	1	73	73
PLANNED	5/6/2021	5	55	11
PLANNED	5/6/2021	2	74	37
PLANNED	5/6/2021	3	24	8
PLANNED	5/6/2021	2	136	68
PLANNED	5/6/2021	8	184	23
PLANNED	5/6/2021	2	270	135
PLANNED	5/6/2021	3	39	13
PLANNED	5/6/2021	12	288	24
PLANNED	5/6/2021	2	110	55
PLANNED	5/6/2021	2	116	58
PLANNED	5/6/2021	1	28	28
PLANNED	5/6/2021	1	183	183
PLANNED	5/6/2021	1	105	105

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/6/2021	1	176	176
PLANNED	5/6/2021	17	51	3
CUSTOMER REQUEST	5/6/2021	1	186	186
PLANNED	5/6/2021	12	480	40
CUSTOMER REQUEST	5/6/2021	1	1,030	1,030
PLANNED	5/6/2021	23	368	16
PLANNED	5/6/2021	1	210	210
PLANNED	5/6/2021	1	176	176
PLANNED	5/6/2021	9	531	59
PLANNED	5/6/2021	4	564	141
PLANNED	5/6/2021	1	97	97
PLANNED	5/6/2021	1	232	232
PLANNED	5/6/2021	7	1,288	184
PLANNED	5/7/2021	6	4,284	714
PLANNED	5/7/2021	6	570	95
PLANNED	5/7/2021	17	3,264	192
PLANNED	5/7/2021	3	321	107
PLANNED	5/7/2021	3	138	46
PLANNED	5/7/2021	1	7	7
PLANNED	5/7/2021	4	56	14
PLANNED	5/7/2021	3	192	64
PLANNED	5/7/2021	3	81	27
PLANNED	5/7/2021	20	800	40
PLANNED	5/7/2021	2	97	74
PLANNED	5/7/2021	1	92	92
PLANNED	5/7/2021	2	40	20
PLANNED	5/7/2021	3	93	31
PLANNED	5/7/2021	3	21	7
PLANNED	5/7/2021	1	23	23
PLANNED	5/7/2021	3	230	96
PLANNED	5/7/2021	4	48	12
PLANNED	5/7/2021	1	207	207
PLANNED	5/7/2021	6	216	36
CUSTOMER REQUEST	5/7/2021	17	5,176	387
PLANNED	5/7/2021	4	112	28
PLANNED	5/7/2021	3	24	8
PLANNED	5/7/2021	6	450	75
PLANNED	5/7/2021	2	212	106
PLANNED	5/7/2021	2	228	114
PLANNED	5/7/2021	2	332	166
PLANNED	5/7/2021	3	72	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/7/2021	5	730	146
PLANNED	5/7/2021	8	352	44
PLANNED	5/7/2021	1	34	34
PLANNED	5/7/2021	1	28	28
CUSTOMER REQUEST	5/7/2021	92	27,784	302
PLANNED	5/7/2021	2	14	7
PLANNED	5/7/2021	2	24	12
PLANNED	5/7/2021	1	29	29
PLANNED	5/7/2021	31	3,441	111
PLANNED	5/7/2021	2	62	31
PLANNED	5/7/2021	1	123	123
PLANNED	5/7/2021	2	110	60
PLANNED	5/7/2021	2	172	86
PLANNED	5/7/2021	12	240	20
PLANNED	5/7/2021	1	16	16
PLANNED	5/7/2021	1	99	99
PLANNED	5/7/2021	4	96	24
PLANNED	5/7/2021	2	84	42
PLANNED	5/7/2021	5	500	100
PLANNED	5/7/2021	1	79	79
PLANNED	5/7/2021	4	1,088	272
PLANNED	5/7/2021	5	1,360	272
PLANNED	5/7/2021	18	1,530	85
PLANNED	5/7/2021	1	72	72
PLANNED	5/7/2021	6	1,632	272
PLANNED	5/7/2021	12	348	29
PLANNED	5/7/2021	8	400	50
PLANNED	5/7/2021	11	44	4
PLANNED	5/7/2021	2	34	17
PLANNED	5/7/2021	28	1,064	38
PLANNED	5/7/2021	2	44	22
PLANNED	5/7/2021	2	152	76
PLANNED	5/7/2021	2	194	97
PLANNED	5/7/2021	2	24	12
PLANNED	5/7/2021	1	504	504
PLANNED	5/7/2021	4	128	32
PLANNED	5/7/2021	4	108	27
PLANNED	5/7/2021	2	318	159
PLANNED	5/7/2021	2	158	79
CUSTOMER REQUEST	5/7/2021	3	201	67
PLANNED	5/7/2021	50	9,650	193

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/7/2021	2	194	97
PLANNED	5/7/2021	2	204	102
PLANNED	5/7/2021	2	58	29
PLANNED	5/7/2021	2	294	147
PLANNED	5/7/2021	11	649	59
PLANNED	5/7/2021	1	107	107
PLANNED	5/7/2021	17	595	35
PLANNED	5/7/2021	7	737	152
PLANNED	5/7/2021	6	72	12
PLANNED	5/7/2021	9	1,962	218
PLANNED	5/7/2021	10	250	25
PLANNED	5/7/2021	9	603	67
PLANNED	5/7/2021	1	21	21
PLANNED	5/7/2021	2	42	21
PLANNED	5/7/2021	3	36	12
PLANNED	5/7/2021	2	30	15
PLANNED	5/7/2021	2	20	10
PLANNED	5/7/2021	1	36	36
PLANNED	5/7/2021	1	11	11
PLANNED	5/7/2021	2	60	30
PLANNED	5/7/2021	6	498	83
PLANNED	5/7/2021	1	13	13
PLANNED	5/7/2021	4	72	18
PLANNED	5/7/2021	2	126	63
PLANNED	5/7/2021	2	16	8
PLANNED	5/7/2021	7	238	34
PLANNED	5/7/2021	11	22	2
PLANNED	5/7/2021	5	90	18
PLANNED	5/7/2021	4	64	16
PLANNED	5/7/2021	1	57	57
PLANNED	5/7/2021	5	105	21
PLANNED	5/7/2021	3	51	17
PLANNED	5/7/2021	3	57	19
PLANNED	5/7/2021	3	3	1
PLANNED	5/7/2021	7	133	19
CUSTOMER REQUEST	5/7/2021	1	21	21
PLANNED	5/7/2021	1	18	18
PLANNED	5/7/2021	16	240	15
PLANNED	5/7/2021	37	3,589	97
PLANNED	5/7/2021	6	630	105
CUSTOMER REQUEST	5/7/2021	1	115	115

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/7/2021	5	300	60
PLANNED	5/7/2021	5	300	60
PLANNED	5/7/2021	3	195	65
PLANNED	5/7/2021	4	356	89
PLANNED	5/7/2021	4	48	12
PLANNED	5/7/2021	7	28	4
PLANNED	5/7/2021	1	3	3
PLANNED	5/7/2021	4	48	12
PLANNED	5/7/2021	2	40	20
PLANNED	5/7/2021	1	3	3
PLANNED	5/7/2021	14	2,464	176
PLANNED	5/7/2021	7	77	11
PLANNED	5/7/2021	1	102	102
PLANNED	5/7/2021	9	234	26
PLANNED	5/7/2021	1	180	180
PLANNED	5/7/2021	8	1,648	206
CUSTOMER REQUEST	5/8/2021	1	77	77
CUSTOMER REQUEST	5/8/2021	1	333	333
PLANNED	5/8/2021	2	104	52
PLANNED	5/8/2021	1	127	127
CUSTOMER REQUEST	5/8/2021	5	1,045	209
PLANNED	5/8/2021	1	52	52
PLANNED	5/8/2021	1	159	159
PLANNED	5/8/2021	2	162	81
PLANNED	5/8/2021	4	272	68
PLANNED	5/8/2021	1	40	40
CUSTOMER REQUEST	5/8/2021	1	232	232
PLANNED	5/8/2021	9	792	88
CUSTOMER REQUEST	5/8/2021	1	748	748
PLANNED	5/8/2021	1	109	109
PLANNED	5/8/2021	1	17	17
CUSTOMER REQUEST	5/9/2021	6	774	129
PLANNED	5/9/2021	10	800	80
PLANNED	5/9/2021	2	347	186
PLANNED	5/9/2021	1	185	185
PLANNED	5/9/2021	8	720	90
PLANNED	5/9/2021	12	1,500	125
PLANNED	5/9/2021	1	120	120
CUSTOMER REQUEST	5/9/2021	45	12,420	540
PLANNED	5/9/2021	2	110	55
PLANNED	5/9/2021	1	54	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/9/2021	712	16,471	103
CUSTOMER REQUEST	5/9/2021	8	280	35
CUSTOMER REQUEST	5/10/2021	1	367	367
PLANNED	5/10/2021	2	164	88
CUSTOMER REQUEST	5/10/2021	100	8,100	81
PLANNED	5/10/2021	1	7	7
PLANNED	5/10/2021	3	78	26
PLANNED	5/10/2021	1	38	38
PLANNED	5/10/2021	4	84	21
PLANNED	5/10/2021	1	30	30
PLANNED	5/10/2021	1	4	4
PLANNED	5/10/2021	4	356	89
PLANNED	5/10/2021	1	7	7
PLANNED	5/10/2021	5	90	18
PLANNED	5/10/2021	3	888	296
PLANNED	5/10/2021	2	258	129
PLANNED	5/10/2021	1	103	103
PLANNED	5/10/2021	1	306	306
PLANNED	5/10/2021	5	105	21
PLANNED	5/10/2021	1	8	8
PLANNED	5/10/2021	9	351	39
CUSTOMER REQUEST	5/10/2021	21	1,050	50
PLANNED	5/10/2021	7	287	41
PLANNED	5/10/2021	1	328	328
PLANNED	5/10/2021	8	448	56
PLANNED	5/10/2021	3	273	91
PLANNED	5/10/2021	2	16	8
PLANNED	5/10/2021	8	2,896	362
PLANNED	5/10/2021	9	1,917	213
PLANNED	5/10/2021	45	17,010	378
PLANNED	5/10/2021	2	10	5
PLANNED	5/10/2021	9	162	18
PLANNED	5/10/2021	16	1,296	81
PLANNED	5/10/2021	30	930	31
PLANNED	5/10/2021	5	250	50
PLANNED	5/10/2021	15	2,655	177
PLANNED	5/10/2021	1	7	7
PLANNED	5/10/2021	15	2,460	164
PLANNED	5/10/2021	4	72	18
PLANNED	5/10/2021	16	2,448	153
PLANNED	5/10/2021	5	190	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/10/2021	2	16	8
PLANNED	5/10/2021	1	6	6
PLANNED	5/10/2021	4	136	34
PLANNED	5/10/2021	1	15	15
PLANNED	5/10/2021	2	240	120
PLANNED	5/10/2021	14	1,680	120
PLANNED	5/10/2021	4	200	50
CUSTOMER REQUEST	5/10/2021	1	139	139
PLANNED	5/10/2021	1	8	8
PLANNED	5/10/2021	1	65	65
PLANNED	5/10/2021	8	1,772	301
PLANNED	5/10/2021	4	252	63
PLANNED	5/10/2021	8	192	24
PLANNED	5/10/2021	8	112	14
PLANNED	5/10/2021	2	16	8
CUSTOMER REQUEST	5/10/2021	7	1,190	170
PLANNED	5/10/2021	2	164	82
PLANNED	5/10/2021	1	128	128
PLANNED	5/10/2021	6	276	46
PLANNED	5/10/2021	2	20	10
PLANNED	5/10/2021	12	2,268	189
PLANNED	5/10/2021	6	120	20
PLANNED	5/10/2021	1	9	9
PLANNED	5/10/2021	4	552	138
PLANNED	5/10/2021	10	840	84
PLANNED	5/10/2021	1	35	35
PLANNED	5/10/2021	3	6	2
PLANNED	5/10/2021	2	6	3
PLANNED	5/10/2021	37	1,665	45
PLANNED	5/10/2021	2	4	2
PLANNED	5/10/2021	3	75	25
PLANNED	5/10/2021	87	16,356	188
PLANNED	5/10/2021	4	272	68
PLANNED	5/10/2021	4	676	169
PLANNED	5/10/2021	1	170	170
PLANNED	5/10/2021	2	18	9
PLANNED	5/10/2021	2	28	14
PLANNED	5/10/2021	2	38	19
PLANNED	5/10/2021	5	1,140	228
PLANNED	5/10/2021	1	7	7
PLANNED	5/10/2021	42	630	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/10/2021	6	204	34
CUSTOMER REQUEST	5/10/2021	63	378	6
PLANNED	5/10/2021	4	292	73
PLANNED	5/10/2021	10	610	61
PLANNED	5/10/2021	36	1,620	45
PLANNED	5/10/2021	2	180	90
PLANNED	5/10/2021	2	12	6
CUSTOMER REQUEST	5/10/2021	21	168	8
PLANNED	5/10/2021	2	58	29
PLANNED	5/10/2021	3	6	2
PLANNED	5/10/2021	1	104	104
PLANNED	5/10/2021	4	68	17
PLANNED	5/10/2021	1	6	6
PLANNED	5/10/2021	1	245	245
PLANNED	5/10/2021	31	10,734	349
PLANNED	5/10/2021	3	51	17
PLANNED	5/10/2021	2	198	99
PLANNED	5/10/2021	1	5	5
PLANNED	5/10/2021	2	606	303
PLANNED	5/10/2021	1	13	13
PLANNED	5/10/2021	6	24	4
PLANNED	5/10/2021	2	30	15
PLANNED	5/10/2021	3	36	12
PLANNED	5/10/2021	1	10	10
PLANNED	5/10/2021	1	22	22
PLANNED	5/10/2021	1	10	10
PLANNED	5/10/2021	12	372	31
PLANNED	5/10/2021	3	87	29
PLANNED	5/10/2021	28	1,064	38
PLANNED	5/10/2021	1	10	10
PLANNED	5/10/2021	9	1,269	141
PLANNED	5/10/2021	2	250	125
PLANNED	5/10/2021	3	33	11
PLANNED	5/10/2021	4	40	10
PLANNED	5/10/2021	3	213	71
PLANNED	5/10/2021	4	80	20
PLANNED	5/10/2021	7	343	49
PLANNED	5/10/2021	1	9	9
PLANNED	5/10/2021	1	17	17
PLANNED	5/10/2021	7	147	21
PLANNED	5/10/2021	6	330	55

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/10/2021	4	72	18
CUSTOMER REQUEST	5/10/2021	6	138	23
PLANNED	5/10/2021	2	58	29
PLANNED	5/10/2021	4	44	11
PLANNED	5/10/2021	35	3,885	111
PLANNED	5/10/2021	4	60	15
PLANNED	5/10/2021	1	226	226
PLANNED	5/10/2021	21	588	28
PLANNED	5/10/2021	2	39	27
PLANNED	5/10/2021	17	85	5
PLANNED	5/10/2021	2	52	26
PLANNED	5/10/2021	2	258	129
PLANNED	5/10/2021	10	420	42
PLANNED	5/10/2021	4	360	114
PLANNED	5/10/2021	2	22	11
PLANNED	5/10/2021	1	11	11
PLANNED	5/10/2021	1	20	20
PLANNED	5/10/2021	5	90	18
PLANNED	5/10/2021	1	2	2
PLANNED	5/10/2021	2	20	10
PLANNED	5/10/2021	3	63	21
PLANNED	5/10/2021	6	48	8
PLANNED	5/10/2021	2	38	19
PLANNED	5/10/2021	15	540	36
PLANNED	5/10/2021	3	48	16
PLANNED	5/10/2021	1	10	10
PLANNED	5/10/2021	13	65	5
PLANNED	5/10/2021	4	36	9
PLANNED	5/10/2021	2	40	20
PLANNED	5/10/2021	1	127	127
PLANNED	5/10/2021	2	126	102
PLANNED	5/10/2021	2	40	20
PLANNED	5/10/2021	9	459	51
PLANNED	5/10/2021	2	196	98
PLANNED	5/10/2021	8	144	18
PLANNED	5/10/2021	9	549	61
PLANNED	5/10/2021	3	63	21
PLANNED	5/10/2021	1	84	84
PLANNED	5/10/2021	2	110	55
PLANNED	5/10/2021	6	324	54
PLANNED	5/10/2021	4	224	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/10/2021	1	306	306
PLANNED	5/10/2021	3	270	90
PLANNED	5/11/2021	1	160	160
PLANNED	5/11/2021	1	118	118
PLANNED	5/11/2021	1	70	70
PLANNED	5/11/2021	2	88	44
PLANNED	5/11/2021	4	92	23
PLANNED	5/11/2021	1	13	13
PLANNED	5/11/2021	1	8	8
PLANNED	5/11/2021	1	341	341
PLANNED	5/11/2021	6	828	253
PLANNED	5/11/2021	3	102	34
PLANNED	5/11/2021	4	72	18
PLANNED	5/11/2021	1	15	15
PLANNED	5/11/2021	7	63	9
CUSTOMER REQUEST	5/11/2021	12	4,536	378
PLANNED	5/11/2021	193	17,177	89
PLANNED	5/11/2021	10	160	16
PLANNED	5/11/2021	3	108	36
CUSTOMER REQUEST	5/11/2021	6	2,178	363
PLANNED	5/11/2021	4	108	27
PLANNED	5/11/2021	8	2,272	284
CUSTOMER REQUEST	5/11/2021	3	1,449	483
PLANNED	5/11/2021	6	510	85
PLANNED	5/11/2021	1	65	65
PLANNED	5/11/2021	2	36	18
PLANNED	5/11/2021	1	10	10
PLANNED	5/11/2021	2	466	233
PLANNED	5/11/2021	1	9	9
PLANNED	5/11/2021	8	248	31
PLANNED	5/11/2021	6	144	24
PLANNED	5/11/2021	1	76	76
PLANNED	5/11/2021	2	140	70
PLANNED	5/11/2021	4	132	33
PLANNED	5/11/2021	1	14	14
PLANNED	5/11/2021	5	45	9
PLANNED	5/11/2021	1	199	199
PLANNED	5/11/2021	1	7	7
PLANNED	5/11/2021	8	624	78
PLANNED	5/11/2021	2	34	17
PLANNED	5/11/2021	2	228	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/11/2021	3	63	21
PLANNED	5/11/2021	9	468	52
PLANNED	5/11/2021	5	455	91
PLANNED	5/11/2021	4	528	132
PLANNED	5/11/2021	5	455	91
PLANNED	5/11/2021	11	1,650	150
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	1	110	110
PLANNED	5/11/2021	1	7	7
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	2	40	20
PLANNED	5/11/2021	15	1,740	116
PLANNED	5/11/2021	3	285	95
PLANNED	5/11/2021	7	462	66
PLANNED	5/11/2021	1	127	127
PLANNED	5/11/2021	8	1,376	172
PLANNED	5/11/2021	5	530	106
PLANNED	5/11/2021	5	610	122
PLANNED	5/11/2021	2	62	31
PLANNED	5/11/2021	2	14	7
PLANNED	5/11/2021	2	20	10
PLANNED	5/11/2021	2	74	37
PLANNED	5/11/2021	8	640	80
PLANNED	5/11/2021	1	13	13
PLANNED	5/11/2021	1	8	8
PLANNED	5/11/2021	2	154	77
PLANNED	5/11/2021	1	234	234
PLANNED	5/11/2021	1	13	13
PLANNED	5/11/2021	4	616	154
PLANNED	5/11/2021	2	76	38
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	18	4,500	250
PLANNED	5/11/2021	3	480	160
PLANNED	5/11/2021	3	384	128
PLANNED	5/11/2021	5	570	114
PLANNED	5/11/2021	3	135	45
PLANNED	5/11/2021	20	820	41
PLANNED	5/11/2021	1	109	109
PLANNED	5/11/2021	4	40	10
CUSTOMER REQUEST	5/11/2021	16	5,264	329
PLANNED	5/11/2021	3	36	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/11/2021	3	21	7
PLANNED	5/11/2021	2	100	50
PLANNED	5/11/2021	2	58	29
PLANNED	5/11/2021	16	2,208	138
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	4	376	94
PLANNED	5/11/2021	16	4,672	292
PLANNED	5/11/2021	5	695	139
PLANNED	5/11/2021	1	224	224
PLANNED	5/11/2021	8	584	73
PLANNED	5/11/2021	3	108	36
PLANNED	5/11/2021	2	146	73
PLANNED	5/11/2021	6	246	41
PLANNED	5/11/2021	1	33	33
PLANNED	5/11/2021	2	14	7
PLANNED	5/11/2021	7	189	27
PLANNED	5/11/2021	3	21	7
PLANNED	5/11/2021	5	175	35
PLANNED	5/11/2021	3	51	17
PLANNED	5/11/2021	2	42	21
PLANNED	5/11/2021	8	456	57
PLANNED	5/11/2021	2	52	26
PLANNED	5/11/2021	1	217	217
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	2	208	104
PLANNED	5/11/2021	12	936	78
PLANNED	5/11/2021	11	539	49
PLANNED	5/11/2021	14	1,092	78
PLANNED	5/11/2021	18	900	50
PLANNED	5/11/2021	4	28	7
PLANNED	5/11/2021	4	176	44
PLANNED	5/11/2021	1	4	4
PLANNED	5/11/2021	6	90	15
PLANNED	5/11/2021	2	202	101
PLANNED	5/11/2021	3	18	6
PLANNED	5/11/2021	2	192	96
PLANNED	5/11/2021	1	1	1
PLANNED	5/11/2021	1	5	5
PLANNED	5/11/2021	14	896	64
PLANNED	5/11/2021	7	294	42
PLANNED	5/11/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/11/2021	1	131	131
PLANNED	5/11/2021	1	47	47
PLANNED	5/11/2021	4	160	40
PLANNED	5/11/2021	3	18	6
PLANNED	5/11/2021	7	721	103
PLANNED	5/11/2021	2	44	22
PLANNED	5/11/2021	2	34	17
PLANNED	5/11/2021	2	40	20
PLANNED	5/11/2021	6	66	11
PLANNED	5/11/2021	1	50	50
PLANNED	5/11/2021	2	32	16
PLANNED	5/11/2021	13	845	65
PLANNED	5/11/2021	2	192	96
PLANNED	5/11/2021	3	18	6
PLANNED	5/11/2021	5	310	62
PLANNED	5/11/2021	3	75	25
PLANNED	5/11/2021	2	30	15
PLANNED	5/11/2021	2	182	91
PLANNED	5/11/2021	2	12	6
PLANNED	5/11/2021	2	32	16
PLANNED	5/11/2021	2	122	61
PLANNED	5/11/2021	10	580	58
PLANNED	5/11/2021	3	87	29
PLANNED	5/11/2021	3	84	28
PLANNED	5/11/2021	3	177	59
PLANNED	5/11/2021	7	644	92
PLANNED	5/11/2021	9	333	37
PLANNED	5/11/2021	7	301	43
PLANNED	5/11/2021	8	40	5
PLANNED	5/11/2021	3	51	17
PLANNED	5/11/2021	4	80	20
PLANNED	5/11/2021	22	7,898	359
PLANNED	5/11/2021	8	200	25
PLANNED	5/11/2021	8	240	30
PLANNED	5/11/2021	3	87	29
PLANNED	5/11/2021	2	168	84
PLANNED	5/11/2021	2	56	28
PLANNED	5/11/2021	2	136	68
PLANNED	5/11/2021	1	12	12
PLANNED	5/11/2021	2	172	86
PLANNED	5/11/2021	3	27	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/11/2021	9	351	39
PLANNED	5/11/2021	3	195	65
PLANNED	5/11/2021	4	32	8
PLANNED	5/11/2021	14	1,344	96
PLANNED	5/11/2021	4	52	13
PLANNED	5/11/2021	2	20	10
PLANNED	5/11/2021	3	69	23
PLANNED	5/11/2021	1	10	10
PLANNED	5/11/2021	5	20	4
PLANNED	5/11/2021	2	36	18
PLANNED	5/11/2021	36	3,564	99
PLANNED	5/11/2021	3	48	16
PLANNED	5/11/2021	2	222	111
PLANNED	5/11/2021	8	32	4
PLANNED	5/11/2021	14	238	17
PLANNED	5/11/2021	3	24	8
PLANNED	5/11/2021	3	39	13
PLANNED	5/11/2021	10	110	11
PLANNED	5/11/2021	5	627	149
PLANNED	5/11/2021	5	80	16
PLANNED	5/11/2021	2	62	31
PLANNED	5/11/2021	1	90	90
PLANNED	5/11/2021	1	11	11
PLANNED	5/11/2021	2	334	167
PLANNED	5/11/2021	9	531	59
PLANNED	5/11/2021	103	3,708	36
PLANNED	5/11/2021	11	396	36
PLANNED	5/11/2021	2	20	10
CUSTOMER REQUEST	5/11/2021	1	138	138
CUSTOMER REQUEST	5/11/2021	2	64	32
PLANNED	5/11/2021	1	6	6
PLANNED	5/11/2021	2	228	114
PLANNED	5/11/2021	1	99	99
PLANNED	5/11/2021	8	240	30
CUSTOMER REQUEST	5/11/2021	1	125	125
PLANNED	5/11/2021	1	9	9
PLANNED	5/11/2021	1	140	140
PLANNED	5/11/2021	1	58	58
PLANNED	5/11/2021	8	24	3
PLANNED	5/11/2021	3	321	107
CUSTOMER REQUEST	5/11/2021	1	713	713

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/11/2021	1	55	55
PLANNED	5/11/2021	3	165	55
CUSTOMER REQUEST	5/11/2021	1	58	58
PLANNED	5/11/2021	3	282	94
PLANNED	5/11/2021	1	130	130
PLANNED	5/11/2021	10	890	89
PLANNED	5/11/2021	4	132	33
PLANNED	5/11/2021	3	156	52
PLANNED	5/11/2021	3	72	24
PLANNED	5/11/2021	3	90	30
CUSTOMER REQUEST	5/11/2021	1	56	56
CUSTOMER REQUEST	5/11/2021	1	182	182
PLANNED	5/11/2021	1	164	164
PLANNED	5/11/2021	3	87	29
PLANNED	5/11/2021	11	2,992	272
PLANNED	5/12/2021	27	243	9
PLANNED	5/12/2021	1	70	70
PLANNED	5/12/2021	2	98	49
PLANNED	5/12/2021	6	48	8
PLANNED	5/12/2021	2	177	96
PLANNED	5/12/2021	4	256	64
PLANNED	5/12/2021	3	264	88
PLANNED	5/12/2021	2	16	8
PLANNED	5/12/2021	1	28	28
PLANNED	5/12/2021	1	9	9
PLANNED	5/12/2021	10	100	10
PLANNED	5/12/2021	7	560	80
PLANNED	5/12/2021	4	64	16
PLANNED	5/12/2021	4	28	7
PLANNED	5/12/2021	5	35	7
PLANNED	5/12/2021	7	343	49
PLANNED	5/12/2021	3	27	9
PLANNED	5/12/2021	6	174	29
PLANNED	5/12/2021	7	1,134	162
PLANNED	5/12/2021	1	22	22
PLANNED	5/12/2021	3	30	10
PLANNED	5/12/2021	1	8	8
PLANNED	5/12/2021	3	399	211
PLANNED	5/12/2021	27	8,019	297
PLANNED	5/12/2021	3	354	118
PLANNED	5/12/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/12/2021	13	1,794	138
PLANNED	5/12/2021	1	6	6
PLANNED	5/12/2021	4	184	46
PLANNED	5/12/2021	2	18	9
PLANNED	5/12/2021	14	1,568	112
PLANNED	5/12/2021	4	128	32
PLANNED	5/12/2021	8	16	2
PLANNED	5/12/2021	7	203	29
PLANNED	5/12/2021	1	89	89
PLANNED	5/12/2021	5	90	18
PLANNED	5/12/2021	2	10	5
PLANNED	5/12/2021	3	309	103
PLANNED	5/12/2021	1	13	13
CUSTOMER REQUEST	5/12/2021	18	6,120	340
PLANNED	5/12/2021	4	124	31
PLANNED	5/12/2021	14	1,806	129
PLANNED	5/12/2021	13	1,768	136
PLANNED	5/12/2021	5	120	24
PLANNED	5/12/2021	6	366	61
CUSTOMER REQUEST	5/12/2021	6	48	8
PLANNED	5/12/2021	3	30	10
PLANNED	5/12/2021	21	3,738	178
PLANNED	5/12/2021	31	6,076	196
PLANNED	5/12/2021	8	1,104	138
PLANNED	5/12/2021	33	6,237	189
PLANNED	5/12/2021	30	5,880	196
PLANNED	5/12/2021	4	52	13
PLANNED	5/12/2021	5	280	56
PLANNED	5/12/2021	7	1,617	231
PLANNED	5/12/2021	42	6,384	152
PLANNED	5/12/2021	2	48	24
PLANNED	5/12/2021	1	6	6
PLANNED	5/12/2021	5	300	60
CUSTOMER REQUEST	5/12/2021	2	482	241
PLANNED	5/12/2021	1	318	318
PLANNED	5/12/2021	13	39	3
PLANNED	5/12/2021	1	9	9
PLANNED	5/12/2021	3	21	7
PLANNED	5/12/2021	3	33	11
PLANNED	5/12/2021	2	18	9
PLANNED	5/12/2021	2	102	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/12/2021	113	21,696	192
PLANNED	5/12/2021	3	24	8
PLANNED	5/12/2021	2	247	143
PLANNED	5/12/2021	11	561	51
PLANNED	5/12/2021	1	8	8
CUSTOMER REQUEST	5/12/2021	11	374	34
PLANNED	5/12/2021	1	26	26
CUSTOMER REQUEST	5/12/2021	16	3,372	281
PLANNED	5/12/2021	3	153	51
PLANNED	5/12/2021	22	6,204	282
PLANNED	5/12/2021	6	66	11
PLANNED	5/12/2021	6	372	62
CUSTOMER REQUEST	5/12/2021	42	19,908	474
CUSTOMER REQUEST	5/12/2021	1	349	349
PLANNED	5/12/2021	12	48	4
PLANNED	5/12/2021	2	144	72
PLANNED	5/12/2021	6	162	27
PLANNED	5/12/2021	2	26	13
PLANNED	5/12/2021	8	128	16
PLANNED	5/12/2021	2	206	103
PLANNED	5/12/2021	1	184	184
PLANNED	5/12/2021	2	228	114
PLANNED	5/12/2021	2	8	4
PLANNED	5/12/2021	1	11	11
PLANNED	5/12/2021	8	504	63
CUSTOMER REQUEST	5/12/2021	2	520	260
PLANNED	5/12/2021	2	64	32
PLANNED	5/12/2021	6	402	67
PLANNED	5/12/2021	8	864	108
PLANNED	5/12/2021	2	6	3
PLANNED	5/12/2021	7	644	92
PLANNED	5/12/2021	1	18	18
PLANNED	5/12/2021	3	99	33
PLANNED	5/12/2021	6	1,020	170
PLANNED	5/12/2021	35	5,565	159
PLANNED	5/12/2021	1	258	258
PLANNED	5/12/2021	5	50	10
PLANNED	5/12/2021	3	330	110
PLANNED	5/12/2021	14	1,812	305
PLANNED	5/12/2021	7	1,659	237
PLANNED	5/12/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/12/2021	3	33	11
PLANNED	5/12/2021	12	720	60
PLANNED	5/12/2021	1	16	16
PLANNED	5/12/2021	4	332	83
PLANNED	5/12/2021	4	28	7
PLANNED	5/12/2021	4	168	42
PLANNED	5/12/2021	1	7	7
PLANNED	5/12/2021	1	33	33
PLANNED	5/12/2021	1	47	47
PLANNED	5/12/2021	4	136	34
PLANNED	5/12/2021	5	700	140
PLANNED	5/12/2021	7	630	90
PLANNED	5/12/2021	2	96	48
PLANNED	5/12/2021	1	62	62
PLANNED	5/12/2021	4	40	10
PLANNED	5/12/2021	4	112	28
PLANNED	5/12/2021	6	1,038	173
PLANNED	5/12/2021	3	30	10
PLANNED	5/12/2021	1	341	341
PLANNED	5/12/2021	4	56	14
CUSTOMER REQUEST	5/12/2021	7	364	52
PLANNED	5/12/2021	31	1,891	61
PLANNED	5/12/2021	5	120	24
PLANNED	5/12/2021	2	48	24
PLANNED	5/12/2021	3	93	31
PLANNED	5/12/2021	1	66	66
PLANNED	5/12/2021	2	440	220
PLANNED	5/12/2021	7	168	24
PLANNED	5/12/2021	3	69	23
PLANNED	5/12/2021	2	34	17
PLANNED	5/12/2021	4	120	30
PLANNED	5/12/2021	6	222	37
PLANNED	5/12/2021	1	58	58
PLANNED	5/12/2021	5	55	11
PLANNED	5/12/2021	5	65	13
PLANNED	5/12/2021	8	184	23
PLANNED	5/12/2021	8	480	60
PLANNED	5/12/2021	1	11	11
PLANNED	5/12/2021	2	256	128
PLANNED	5/12/2021	4	582	154
PLANNED	5/12/2021	2	34	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/12/2021	8	80	10
PLANNED	5/12/2021	1	22	22
PLANNED	5/12/2021	3	30	10
PLANNED	5/12/2021	10	140	14
PLANNED	5/12/2021	5	760	152
PLANNED	5/12/2021	3	267	89
PLANNED	5/12/2021	1	11	11
PLANNED	5/12/2021	3	69	23
PLANNED	5/12/2021	4	188	47
PLANNED	5/12/2021	8	168	21
PLANNED	5/12/2021	2	48	24
PLANNED	5/12/2021	1	16	16
PLANNED	5/12/2021	1	32	32
PLANNED	5/12/2021	1	17	17
CUSTOMER REQUEST	5/12/2021	1	123	123
PLANNED	5/12/2021	13	65	5
PLANNED	5/12/2021	4	36	9
PLANNED	5/12/2021	13	351	27
PLANNED	5/12/2021	1	15	15
PLANNED	5/12/2021	2	18	9
PLANNED	5/12/2021	1	18	18
CUSTOMER REQUEST	5/12/2021	30	2,010	67
PLANNED	5/12/2021	1	20	20
PLANNED	5/12/2021	1	63	63
PLANNED	5/12/2021	2	230	115
PLANNED	5/12/2021	2	148	74
PLANNED	5/12/2021	1	7	7
PLANNED	5/12/2021	3	111	37
PLANNED	5/12/2021	8	168	21
PLANNED	5/12/2021	2	216	108
PLANNED	5/12/2021	35	105	3
PLANNED	5/12/2021	5	635	127
PLANNED	5/12/2021	2	40	20
PLANNED	5/12/2021	4	72	18
PLANNED	5/12/2021	1	6	6
PLANNED	5/12/2021	3	15	5
PLANNED	5/12/2021	1	4	4
PLANNED	5/12/2021	9	1,242	138
PLANNED	5/12/2021	8	648	81
PLANNED	5/12/2021	6	372	62
PLANNED	5/12/2021	4	60	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/12/2021	2	30	15
PLANNED	5/12/2021	1	141	141
PLANNED	5/12/2021	4	492	123
PLANNED	5/12/2021	4	64	16
PLANNED	5/12/2021	6	420	70
PLANNED	5/12/2021	1	39	39
CUSTOMER REQUEST	5/12/2021	5	1,045	209
PLANNED	5/12/2021	14	42	3
PLANNED	5/12/2021	3	141	47
PLANNED	5/12/2021	2	440	220
CUSTOMER REQUEST	5/12/2021	419	66,202	158
PLANNED	5/12/2021	1	47	47
CUSTOMER REQUEST	5/12/2021	1,791	64,153	37
PLANNED	5/12/2021	2	120	60
PLANNED	5/12/2021	11	198	18
PLANNED	5/12/2021	1	106	106
PLANNED	5/12/2021	1	16	16
PLANNED	5/12/2021	2	20	10
PLANNED	5/12/2021	2	742	371
PLANNED	5/12/2021	4	1,180	295
PLANNED	5/12/2021	1	260	260
PLANNED	5/12/2021	1	124	124
PLANNED	5/12/2021	1	214	214
PLANNED	5/12/2021	1	103	103
PLANNED	5/12/2021	1	198	198
PLANNED	5/12/2021	1	140	140
PLANNED	5/12/2021	4	796	199
PLANNED	5/12/2021	1	57	57
PLANNED	5/13/2021	2	114	57
PLANNED	5/13/2021	11	1,826	166
PLANNED	5/13/2021	1	20	20
PLANNED	5/13/2021	3	117	39
PLANNED	5/13/2021	4	28	7
PLANNED	5/13/2021	3	150	50
PLANNED	5/13/2021	4	320	80
PLANNED	5/13/2021	1	65	65
PLANNED	5/13/2021	1	51	51
PLANNED	5/13/2021	7	854	122
PLANNED	5/13/2021	2	154	77
PLANNED	5/13/2021	2	298	149
PLANNED	5/13/2021	3	225	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/13/2021	3	42	14
CUSTOMER REQUEST	5/13/2021	19	6,042	318
PLANNED	5/13/2021	1	8	8
PLANNED	5/13/2021	5	1,085	217
PLANNED	5/13/2021	10	200	20
PLANNED	5/13/2021	43	2,322	54
PLANNED	5/13/2021	42	2,646	63
PLANNED	5/13/2021	36	2,196	61
PLANNED	5/13/2021	5	310	62
PLANNED	5/13/2021	1	102	102
PLANNED	5/13/2021	2	206	103
PLANNED	5/13/2021	3	378	126
PLANNED	5/13/2021	1	102	102
PLANNED	5/13/2021	2	250	125
PLANNED	5/13/2021	3	312	104
PLANNED	5/13/2021	1	22	22
PLANNED	5/13/2021	1	102	102
PLANNED	5/13/2021	3	312	104
PLANNED	5/13/2021	3	306	102
PLANNED	5/13/2021	3	189	63
PLANNED	5/13/2021	1	102	102
PLANNED	5/13/2021	1	102	102
PLANNED	5/13/2021	4	128	32
PLANNED	5/13/2021	2	26	13
PLANNED	5/13/2021	8	2,136	267
PLANNED	5/13/2021	4	976	244
PLANNED	5/13/2021	3	69	23
PLANNED	5/13/2021	14	1,078	77
PLANNED	5/13/2021	4	56	14
PLANNED	5/13/2021	7	1,281	183
PLANNED	5/13/2021	5	40	8
PLANNED	5/13/2021	1	18	18
PLANNED	5/13/2021	3	444	148
PLANNED	5/13/2021	10	150	15
PLANNED	5/13/2021	2	316	158
PLANNED	5/13/2021	56	16,744	299
PLANNED	5/13/2021	1	160	160
PLANNED	5/13/2021	1	68	68
PLANNED	5/13/2021	4	232	58
PLANNED	5/13/2021	2	206	109
PLANNED	5/13/2021	2	26	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/13/2021	1	27	27
CUSTOMER REQUEST	5/13/2021	8	312	39
PLANNED	5/13/2021	137	15,481	113
PLANNED	5/13/2021	20	1,380	69
PLANNED	5/13/2021	5	65	13
PLANNED	5/13/2021	1	210	210
PLANNED	5/13/2021	10	2,490	249
PLANNED	5/13/2021	3	39	13
CUSTOMER REQUEST	5/13/2021	16	5,008	313
PLANNED	5/13/2021	17	3,400	200
PLANNED	5/13/2021	2	160	80
CUSTOMER REQUEST	5/13/2021	8	104	13
PLANNED	5/13/2021	1	7	7
PLANNED	5/13/2021	6	588	98
CUSTOMER REQUEST	5/13/2021	8	200	25
PLANNED	5/13/2021	7	357	51
PLANNED	5/13/2021	7	994	142
PLANNED	5/13/2021	4	240	60
PLANNED	5/13/2021	4	204	51
PLANNED	5/13/2021	1	131	131
CUSTOMER REQUEST	5/13/2021	8	291	124
PLANNED	5/13/2021	19	1,178	62
PLANNED	5/13/2021	1	5	5
PLANNED	5/13/2021	2	178	89
PLANNED	5/13/2021	3	36	12
PLANNED	5/13/2021	4	48	12
PLANNED	5/13/2021	4	164	41
PLANNED	5/13/2021	1	44	44
PLANNED	5/13/2021	2	80	40
PLANNED	5/13/2021	1	144	144
PLANNED	5/13/2021	3	325	172
PLANNED	5/13/2021	6	342	57
PLANNED	5/13/2021	3	222	74
PLANNED	5/13/2021	5	375	75
PLANNED	5/13/2021	8	1,912	239
PLANNED	5/13/2021	3	522	174
PLANNED	5/13/2021	3	63	21
PLANNED	5/13/2021	7	665	95
PLANNED	5/13/2021	2	44	22
CUSTOMER REQUEST	5/13/2021	102	26,112	256
PLANNED	5/13/2021	1	3	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/13/2021	2	106	53
PLANNED	5/13/2021	1	70	70
PLANNED	5/13/2021	15	390	26
PLANNED	5/13/2021	1	41	41
PLANNED	5/13/2021	2	26	13
PLANNED	5/13/2021	6	522	87
PLANNED	5/13/2021	7	406	58
PLANNED	5/13/2021	4	224	56
PLANNED	5/13/2021	1	9	9
PLANNED	5/13/2021	2	108	54
PLANNED	5/13/2021	1	31	31
PLANNED	5/13/2021	6	60	10
PLANNED	5/13/2021	10	40	4
PLANNED	5/13/2021	6	534	89
PLANNED	5/13/2021	7	378	54
PLANNED	5/13/2021	3	315	105
PLANNED	5/13/2021	1	129	129
PLANNED	5/13/2021	4	72	18
PLANNED	5/13/2021	1	142	142
CUSTOMER REQUEST	5/13/2021	7	343	49
PLANNED	5/13/2021	3	138	46
PLANNED	5/13/2021	12	12	1
PLANNED	5/13/2021	1	171	171
PLANNED	5/13/2021	4	64	16
PLANNED	5/13/2021	3	33	11
PLANNED	5/13/2021	2	40	20
PLANNED	5/13/2021	4	248	62
PLANNED	5/13/2021	2	126	63
PLANNED	5/13/2021	1	126	126
PLANNED	5/13/2021	1	43	43
PLANNED	5/13/2021	2	258	129
PLANNED	5/13/2021	2	134	67
PLANNED	5/13/2021	1	65	65
CUSTOMER REQUEST	5/13/2021	15	465	31
PLANNED	5/13/2021	3	33	11
PLANNED	5/13/2021	2	332	166
PLANNED	5/13/2021	12	996	83
PLANNED	5/13/2021	3	21	7
PLANNED	5/13/2021	2	58	29
PLANNED	5/13/2021	5	435	87
PLANNED	5/13/2021	2	24	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/13/2021	4	84	21
PLANNED	5/13/2021	6	504	84
PLANNED	5/13/2021	3	420	140
CUSTOMER REQUEST	5/13/2021	2	246	123
CUSTOMER REQUEST	5/13/2021	8	16	2
PLANNED	5/13/2021	9	270	30
PLANNED	5/13/2021	13	130	10
PLANNED	5/13/2021	9	423	47
PLANNED	5/13/2021	1	200	200
PLANNED	5/13/2021	3	192	64
PLANNED	5/13/2021	10	1,200	120
PLANNED	5/13/2021	4	40	10
PLANNED	5/13/2021	3	27	9
PLANNED	5/13/2021	14	882	63
PLANNED	5/13/2021	10	40	4
PLANNED	5/13/2021	5	1,075	215
PLANNED	5/13/2021	4	36	9
PLANNED	5/13/2021	7	70	10
PLANNED	5/13/2021	3	48	16
PLANNED	5/13/2021	1	16	16
PLANNED	5/13/2021	5	80	16
PLANNED	5/13/2021	2	24	12
PLANNED	5/13/2021	2	108	54
PLANNED	5/13/2021	4	100	25
PLANNED	5/13/2021	2	30	15
PLANNED	5/13/2021	8	1,296	162
PLANNED	5/13/2021	1	24	24
PLANNED	5/13/2021	4	56	14
PLANNED	5/13/2021	2	54	27
PLANNED	5/13/2021	3	39	13
CUSTOMER REQUEST	5/13/2021	1	418	418
PLANNED	5/13/2021	4	144	36
PLANNED	5/13/2021	6	24	4
PLANNED	5/13/2021	2	119	73
PLANNED	5/13/2021	4	68	17
PLANNED	5/13/2021	3	54	18
PLANNED	5/13/2021	2	390	195
PLANNED	5/13/2021	6	84	14
PLANNED	5/13/2021	2	32	16
PLANNED	5/13/2021	11	979	89
PLANNED	5/13/2021	4	352	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/13/2021	2	132	66
PLANNED	5/13/2021	4	92	23
CUSTOMER REQUEST	5/13/2021	5	50	10
PLANNED	5/13/2021	1	17	17
PLANNED	5/13/2021	5	324	102
PLANNED	5/13/2021	2	26	13
PLANNED	5/13/2021	1	60	60
PLANNED	5/13/2021	5	80	16
PLANNED	5/13/2021	1	25	25
CUSTOMER REQUEST	5/13/2021	1	177	177
PLANNED	5/13/2021	5	115	23
PLANNED	5/13/2021	2	54	27
PLANNED	5/13/2021	1	23	23
PLANNED	5/13/2021	1	29	29
PLANNED	5/13/2021	2	310	155
PLANNED	5/13/2021	2	86	43
PLANNED	5/13/2021	3	36	12
PLANNED	5/13/2021	8	32	4
PLANNED	5/13/2021	1	9	9
PLANNED	5/13/2021	1	223	223
PLANNED	5/13/2021	36	7,596	211
PLANNED	5/13/2021	1	65	65
PLANNED	5/13/2021	1	218	218
PLANNED	5/13/2021	1	241	241
PLANNED	5/13/2021	1	129	129
PLANNED	5/13/2021	1	169	169
PLANNED	5/13/2021	2	578	289
PLANNED	5/14/2021	3	189	63
PLANNED	5/14/2021	4	200	50
PLANNED	5/14/2021	3	162	54
PLANNED	5/14/2021	2	102	51
PLANNED	5/14/2021	15	3,480	232
PLANNED	5/14/2021	1	61	61
PLANNED	5/14/2021	16	2,848	178
PLANNED	5/14/2021	34	2,754	81
PLANNED	5/14/2021	22	2,090	95
PLANNED	5/14/2021	1	5	5
PLANNED	5/14/2021	8	224	28
PLANNED	5/14/2021	8	320	40
PLANNED	5/14/2021	4	180	45
PLANNED	5/14/2021	12	1,836	153

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/14/2021	2	86	43
PLANNED	5/14/2021	7	147	21
PLANNED	5/14/2021	6	78	13
PLANNED	5/14/2021	16	400	25
PLANNED	5/14/2021	4	1,064	266
PLANNED	5/14/2021	5	95	19
PLANNED	5/14/2021	1	26	26
PLANNED	5/14/2021	7	1,498	214
PLANNED	5/14/2021	3	75	25
PLANNED	5/14/2021	2	115	62
PLANNED	5/14/2021	1	19	19
PLANNED	5/14/2021	6	336	56
PLANNED	5/14/2021	6	552	92
PLANNED	5/14/2021	1	124	124
PLANNED	5/14/2021	7	91	13
PLANNED	5/14/2021	4	436	109
PLANNED	5/14/2021	35	1,750	50
PLANNED	5/14/2021	1	18	18
PLANNED	5/14/2021	13	247	19
PLANNED	5/14/2021	4	448	112
PLANNED	5/14/2021	12	240	20
PLANNED	5/14/2021	1	14	14
PLANNED	5/14/2021	2	160	80
PLANNED	5/14/2021	5	455	91
PLANNED	5/14/2021	2	120	60
PLANNED	5/14/2021	2	168	84
PLANNED	5/14/2021	3	96	32
PLANNED	5/14/2021	1	276	276
PLANNED	5/14/2021	6	72	12
CUSTOMER REQUEST	5/14/2021	1	54	54
PLANNED	5/14/2021	10	340	34
PLANNED	5/14/2021	1	10	10
PLANNED	5/14/2021	1	195	195
PLANNED	5/14/2021	4	564	141
CUSTOMER REQUEST	5/14/2021	8	1,464	183
PLANNED	5/14/2021	2	52	26
PLANNED	5/14/2021	22	3,553	183
PLANNED	5/14/2021	6	84	14
PLANNED	5/14/2021	5	70	14
PLANNED	5/14/2021	1	12	12
PLANNED	5/14/2021	6	974	217

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/14/2021	4	812	203
PLANNED	5/14/2021	3	324	108
PLANNED	5/14/2021	1	81	81
CUSTOMER REQUEST	5/14/2021	4	808	202
CUSTOMER REQUEST	5/14/2021	1	278	278
PLANNED	5/14/2021	1	205	205
PLANNED	5/14/2021	7	140	20
PLANNED	5/14/2021	3	150	50
PLANNED	5/14/2021	5	100	20
PLANNED	5/14/2021	1	10	10
PLANNED	5/14/2021	4	500	125
PLANNED	5/14/2021	6	552	92
PLANNED	5/14/2021	4	420	105
PLANNED	5/14/2021	4	60	15
PLANNED	5/14/2021	11	352	32
PLANNED	5/14/2021	1	7	7
PLANNED	5/14/2021	6	678	113
PLANNED	5/14/2021	1	57	57
PLANNED	5/14/2021	2	26	13
PLANNED	5/14/2021	1	20	20
PLANNED	5/14/2021	9	108	12
PLANNED	5/14/2021	5	105	21
PLANNED	5/14/2021	5	460	92
PLANNED	5/14/2021	2	176	88
PLANNED	5/14/2021	5	35	7
PLANNED	5/14/2021	3	135	45
PLANNED	5/14/2021	4	112	28
PLANNED	5/14/2021	8	240	30
PLANNED	5/14/2021	2	16	8
PLANNED	5/14/2021	1	15	15
PLANNED	5/14/2021	1	29	29
PLANNED	5/14/2021	1	15	15
PLANNED	5/14/2021	11	99	9
PLANNED	5/14/2021	15	450	30
PLANNED	5/14/2021	2	110	55
PLANNED	5/14/2021	7	315	45
PLANNED	5/14/2021	1	14	14
PLANNED	5/14/2021	1	43	43
PLANNED	5/14/2021	7	665	95
PLANNED	5/14/2021	2	104	52
PLANNED	5/14/2021	1	37	37

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/14/2021	1	91	91
PLANNED	5/14/2021	58	116	2
CUSTOMER REQUEST	5/14/2021	1	10	10
PLANNED	5/14/2021	1	64	64
PLANNED	5/14/2021	2	186	93
PLANNED	5/14/2021	1	78	78
PLANNED	5/14/2021	1	178	178
PLANNED	5/14/2021	4	92	23
PLANNED	5/15/2021	1	27	27
PLANNED	5/15/2021	1	272	272
PLANNED	5/15/2021	2	166	83
PLANNED	5/15/2021	2	50	25
PLANNED	5/15/2021	1	72	72
PLANNED	5/15/2021	26	3,900	150
PLANNED	5/15/2021	2	190	95
PLANNED	5/15/2021	2	64	32
PLANNED	5/15/2021	4	729	204
PLANNED	5/15/2021	7	938	134
PLANNED	5/15/2021	1	55	55
PLANNED	5/15/2021	1	231	231
PLANNED	5/15/2021	2	207	117
PLANNED	5/15/2021	4	1,440	360
PLANNED	5/15/2021	2	144	72
PLANNED	5/15/2021	2	74	37
PLANNED	5/15/2021	2	90	45
PLANNED	5/15/2021	1	46	46
PLANNED	5/15/2021	2	112	56
CUSTOMER REQUEST	5/15/2021	1	122	122
CUSTOMER REQUEST	5/15/2021	1,612	26,561	26
PLANNED	5/15/2021	1	38	38
PLANNED	5/15/2021	1	146	146
CUSTOMER REQUEST	5/16/2021	1	504	504
PLANNED	5/16/2021	15	931	113
PLANNED	5/16/2021	7	1,309	187
PLANNED	5/16/2021	2	224	112
PLANNED	5/16/2021	4	524	131
PLANNED	5/16/2021	1	312	312
PLANNED	5/16/2021	5	485	97
PLANNED	5/16/2021	3	540	180
PLANNED	5/16/2021	1	192	192
PLANNED	5/16/2021	6	1,590	265

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/16/2021	1	251	251
PLANNED	5/16/2021	4	264	66
PLANNED	5/17/2021	1	39	39
PLANNED	5/17/2021	3	252	84
PLANNED	5/17/2021	1	123	123
PLANNED	5/17/2021	9	2,007	223
PLANNED	5/17/2021	6	828	138
PLANNED	5/17/2021	1	7	7
PLANNED	5/17/2021	3	42	14
PLANNED	5/17/2021	1	17	17
PLANNED	5/17/2021	2	450	225
PLANNED	5/17/2021	1	6	6
PLANNED	5/17/2021	3	75	25
PLANNED	5/17/2021	1	6	6
PLANNED	5/17/2021	1	5	5
PLANNED	5/17/2021	1	9	9
PLANNED	5/17/2021	4	72	18
PLANNED	5/17/2021	3	1,116	372
PLANNED	5/17/2021	5	120	24
PLANNED	5/17/2021	1	8	8
PLANNED	5/17/2021	4	908	227
PLANNED	5/17/2021	8	376	47
PLANNED	5/17/2021	2	798	399
PLANNED	5/17/2021	1	399	399
PLANNED	5/17/2021	2	222	111
PLANNED	5/17/2021	1	8	8
PLANNED	5/17/2021	1	8	8
PLANNED	5/17/2021	4	336	84
PLANNED	5/17/2021	1	110	110
PLANNED	5/17/2021	6	156	26
PLANNED	5/17/2021	1	21	21
PLANNED	5/17/2021	1	218	218
PLANNED	5/17/2021	2	62	31
PLANNED	5/17/2021	4	200	50
PLANNED	5/17/2021	1	72	72
PLANNED	5/17/2021	1	172	172
PLANNED	5/17/2021	4	208	52
PLANNED	5/17/2021	1	209	209
PLANNED	5/17/2021	3	156	52
PLANNED	5/17/2021	5	40	8
PLANNED	5/17/2021	2	104	52

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/17/2021	2	104	52
PLANNED	5/17/2021	1	60	60
PLANNED	5/17/2021	8	648	81
PLANNED	5/17/2021	7	539	77
PLANNED	5/17/2021	21	2,625	125
PLANNED	5/17/2021	5	260	52
PLANNED	5/17/2021	7	567	81
PLANNED	5/17/2021	6	480	80
PLANNED	5/17/2021	1	7	7
PLANNED	5/17/2021	1	9	9
PLANNED	5/17/2021	4	96	24
PLANNED	5/17/2021	6	1,058	219
PLANNED	5/17/2021	2	704	352
PLANNED	5/17/2021	8	2,816	352
PLANNED	5/17/2021	2	704	352
PLANNED	5/17/2021	2	12	6
PLANNED	5/17/2021	2	90	45
PLANNED	5/17/2021	4	112	28
PLANNED	5/17/2021	9	72	8
PLANNED	5/17/2021	2	86	43
PLANNED	5/17/2021	2	222	111
PLANNED	5/17/2021	13	2,626	202
PLANNED	5/17/2021	5	1,390	278
PLANNED	5/17/2021	8	760	95
PLANNED	5/17/2021	8	192	24
PLANNED	5/17/2021	5	360	72
PLANNED	5/17/2021	12	708	138
CUSTOMER REQUEST	5/17/2021	2	660	330
PLANNED	5/17/2021	1	9	9
PLANNED	5/17/2021	1	9	9
PLANNED	5/17/2021	1	105	105
CUSTOMER REQUEST	5/17/2021	2	16	8
PLANNED	5/17/2021	2	38	19
PLANNED	5/17/2021	2	48	24
PLANNED	5/17/2021	25	3,100	124
PLANNED	5/17/2021	18	2,250	125
PLANNED	5/17/2021	7	567	81
PLANNED	5/17/2021	9	1,269	141
PLANNED	5/17/2021	2	162	81
PLANNED	5/17/2021	1	158	158
PLANNED	5/17/2021	1	18	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/17/2021	4	72	18
PLANNED	5/17/2021	13	156	12
PLANNED	5/17/2021	3	21	7
PLANNED	5/17/2021	7	175	25
PLANNED	5/17/2021	3	108	36
PLANNED	5/17/2021	10	240	24
PLANNED	5/17/2021	5	345	69
PLANNED	5/17/2021	1	30	30
PLANNED	5/17/2021	2	34	17
PLANNED	5/17/2021	6	1,008	168
PLANNED	5/17/2021	1	101	101
PLANNED	5/17/2021	12	2,016	168
PLANNED	5/17/2021	7	1,092	156
PLANNED	5/17/2021	2	142	71
PLANNED	5/17/2021	6	918	153
PLANNED	5/17/2021	10	860	86
PLANNED	5/17/2021	4	136	34
PLANNED	5/17/2021	1	8	8
PLANNED	5/17/2021	2	92	46
PLANNED	5/17/2021	4	92	23
PLANNED	5/17/2021	1	194	194
PLANNED	5/17/2021	1	14	14
CUSTOMER REQUEST	5/17/2021	7	917	131
PLANNED	5/17/2021	2	14	7
PLANNED	5/17/2021	8	680	85
PLANNED	5/17/2021	1	19	19
PLANNED	5/17/2021	1	114	114
PLANNED	5/17/2021	2	268	134
PLANNED	5/17/2021	5	80	16
PLANNED	5/17/2021	1	78	78
PLANNED	5/17/2021	3	261	87
CUSTOMER REQUEST	5/17/2021	14	756	54
PLANNED	5/17/2021	2	22	11
PLANNED	5/17/2021	5	145	29
PLANNED	5/17/2021	8	240	30
PLANNED	5/17/2021	5	300	60
PLANNED	5/17/2021	1	28	28
PLANNED	5/17/2021	5	25	5
PLANNED	5/17/2021	3	84	28
PLANNED	5/17/2021	7	84	12
PLANNED	5/17/2021	11	836	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/17/2021	9	414	46
PLANNED	5/17/2021	9	630	70
PLANNED	5/17/2021	14	980	70
PLANNED	5/17/2021	4	96	24
PLANNED	5/17/2021	4	292	73
PLANNED	5/17/2021	2	14	7
PLANNED	5/17/2021	4	72	18
PLANNED	5/17/2021	8	1,792	224
PLANNED	5/17/2021	6	240	40
PLANNED	5/17/2021	1	6	6
PLANNED	5/17/2021	13	390	30
PLANNED	5/17/2021	12	432	36
PLANNED	5/17/2021	1	5	5
PLANNED	5/17/2021	8	1,544	193
PLANNED	5/17/2021	4	236	59
PLANNED	5/17/2021	3	84	28
PLANNED	5/17/2021	8	216	27
PLANNED	5/17/2021	1	10	10
PLANNED	5/17/2021	3	33	11
PLANNED	5/17/2021	3	132	44
PLANNED	5/17/2021	1	127	127
PLANNED	5/17/2021	3	87	29
PLANNED	5/17/2021	2	62	31
PLANNED	5/17/2021	1	94	94
PLANNED	5/17/2021	1	5	5
PLANNED	5/17/2021	1	76	76
PLANNED	5/17/2021	1	81	81
CUSTOMER REQUEST	5/17/2021	6	168	28
PLANNED	5/17/2021	2	98	49
PLANNED	5/17/2021	3	141	47
PLANNED	5/17/2021	4	76	19
PLANNED	5/17/2021	2	140	70
PLANNED	5/17/2021	1	75	75
PLANNED	5/17/2021	3	200	71
PLANNED	5/17/2021	11	187	17
PLANNED	5/17/2021	8	264	33
PLANNED	5/17/2021	5	30	6
PLANNED	5/17/2021	7	714	152
PLANNED	5/17/2021	1	119	119
PLANNED	5/17/2021	3	321	107
PLANNED	5/17/2021	10	690	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/17/2021	10	620	62
PLANNED	5/17/2021	1	74	74
PLANNED	5/17/2021	4	120	30
PLANNED	5/17/2021	2	90	45
PLANNED	5/17/2021	1	119	119
PLANNED	5/17/2021	8	184	23
PLANNED	5/17/2021	7	21	3
PLANNED	5/17/2021	2	76	38
PLANNED	5/17/2021	1	80	80
PLANNED	5/17/2021	1	90	90
PLANNED	5/17/2021	1	78	78
PLANNED	5/17/2021	1	25	25
PLANNED	5/17/2021	1	209	209
PLANNED	5/17/2021	2	86	43
PLANNED	5/17/2021	5	410	82
PLANNED	5/17/2021	21	5,082	242
PLANNED	5/17/2021	1	144	144
PLANNED	5/17/2021	61	305	5
PLANNED	5/17/2021	8	1,008	126
PLANNED	5/17/2021	3	747	249
PLANNED	5/18/2021	1	46	46
PLANNED	5/18/2021	1	86	86
PLANNED	5/18/2021	12	324	27
PLANNED	5/18/2021	1	153	153
PLANNED	5/18/2021	1	13	13
PLANNED	5/18/2021	3	146	51
PLANNED	5/18/2021	2	227	153
PLANNED	5/18/2021	1	36	36
PLANNED	5/18/2021	1	237	237
PLANNED	5/18/2021	1	290	290
PLANNED	5/18/2021	4	44	11
CUSTOMER REQUEST	5/18/2021	19	1,829	234
PLANNED	5/18/2021	1	7	7
PLANNED	5/18/2021	1	6	6
PLANNED	5/18/2021	1	11	11
PLANNED	5/18/2021	7	1,281	183
PLANNED	5/18/2021	25	1,425	57
PLANNED	5/18/2021	3	126	42
PLANNED	5/18/2021	3	30	10
PLANNED	5/18/2021	1	123	123
PLANNED	5/18/2021	9	1,935	215

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/18/2021	2	18	9
PLANNED	5/18/2021	2	20	10
PLANNED	5/18/2021	1	24	24
PLANNED	5/18/2021	5	865	173
PLANNED	5/18/2021	9	1,314	146
PLANNED	5/18/2021	12	264	22
CUSTOMER REQUEST	5/18/2021	12	3,492	291
CUSTOMER REQUEST	5/18/2021	8	64	8
PLANNED	5/18/2021	2	268	134
PLANNED	5/18/2021	2	334	167
PLANNED	5/18/2021	14	518	37
PLANNED	5/18/2021	6	666	111
PLANNED	5/18/2021	1	58	58
PLANNED	5/18/2021	1	6	6
PLANNED	5/18/2021	1	115	115
PLANNED	5/18/2021	2	62	31
PLANNED	5/18/2021	1	13	13
PLANNED	5/18/2021	7	259	37
PLANNED	5/18/2021	1	19	19
PLANNED	5/18/2021	2	618	309
PLANNED	5/18/2021	2	170	85
PLANNED	5/18/2021	1	5	5
PLANNED	5/18/2021	1	29	29
PLANNED	5/18/2021	1	105	105
PLANNED	5/18/2021	26	5,928	228
CUSTOMER REQUEST	5/18/2021	17	272	16
PLANNED	5/18/2021	4	772	193
PLANNED	5/18/2021	3	156	52
PLANNED	5/18/2021	1	195	195
CUSTOMER REQUEST	5/18/2021	62	9,548	154
PLANNED	5/18/2021	4	92	23
PLANNED	5/18/2021	3	245	107
PLANNED	5/18/2021	5	340	68
PLANNED	5/18/2021	4	100	25
PLANNED	5/18/2021	1	155	155
PLANNED	5/18/2021	2	18	9
PLANNED	5/18/2021	1	4	4
PLANNED	5/18/2021	2	88	44
PLANNED	5/18/2021	2	380	190
PLANNED	5/18/2021	3	248	104
PLANNED	5/18/2021	1	24	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/18/2021	6	42	7
PLANNED	5/18/2021	6	372	62
PLANNED	5/18/2021	3	408	136
PLANNED	5/18/2021	2	46	23
PLANNED	5/18/2021	19	1,444	76
PLANNED	5/18/2021	7	224	32
PLANNED	5/18/2021	10	2,040	204
PLANNED	5/18/2021	1	6	6
PLANNED	5/18/2021	1	8	8
PLANNED	5/18/2021	4	128	32
PLANNED	5/18/2021	2	224	112
PLANNED	5/18/2021	9	405	45
PLANNED	5/18/2021	8	100	51
PLANNED	5/18/2021	3	525	175
PLANNED	5/18/2021	4	100	25
PLANNED	5/18/2021	4	32	8
PLANNED	5/18/2021	1	8	8
PLANNED	5/18/2021	3	30	10
PLANNED	5/18/2021	8	504	63
PLANNED	5/18/2021	8	528	66
PLANNED	5/18/2021	2	106	53
PLANNED	5/18/2021	3	312	104
PLANNED	5/18/2021	2	116	58
PLANNED	5/18/2021	2	16	8
PLANNED	5/18/2021	1	8	8
PLANNED	5/18/2021	2	14	7
PLANNED	5/18/2021	1	82	82
CUSTOMER REQUEST	5/18/2021	35	910	26
PLANNED	5/18/2021	3	24	8
PLANNED	5/18/2021	1	10	10
PLANNED	5/18/2021	1	7	7
PLANNED	5/18/2021	4	92	23
PLANNED	5/18/2021	2	62	31
PLANNED	5/18/2021	9	72	8
PLANNED	5/18/2021	2	110	55
PLANNED	5/18/2021	4	184	46
PLANNED	5/18/2021	4	36	9
PLANNED	5/18/2021	4	300	138
PLANNED	5/18/2021	2	72	36
PLANNED	5/18/2021	1	7	7
CUSTOMER REQUEST	5/18/2021	17	102	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/18/2021	23	4,531	197
PLANNED	5/18/2021	5	687	177
PLANNED	5/18/2021	8	656	82
PLANNED	5/18/2021	1	13	13
PLANNED	5/18/2021	7	770	110
PLANNED	5/18/2021	1	8	8
PLANNED	5/18/2021	3	264	88
PLANNED	5/18/2021	7	287	41
PLANNED	5/18/2021	9	684	76
PLANNED	5/18/2021	8	648	81
PLANNED	5/18/2021	1	12	12
PLANNED	5/18/2021	2	14	7
PLANNED	5/18/2021	5	445	89
PLANNED	5/18/2021	2	70	35
PLANNED	5/18/2021	2	26	13
PLANNED	5/18/2021	1	9	9
PLANNED	5/18/2021	1	189	189
PLANNED	5/18/2021	4	112	28
PLANNED	5/18/2021	11	2,541	231
PLANNED	5/18/2021	6	18	3
PLANNED	5/18/2021	1	37	37
PLANNED	5/18/2021	4	116	29
PLANNED	5/18/2021	2	38	19
PLANNED	5/18/2021	1	162	162
PLANNED	5/18/2021	1	14	14
PLANNED	5/18/2021	4	248	62
PLANNED	5/18/2021	4	148	37
PLANNED	5/18/2021	1	23	23
PLANNED	5/18/2021	1	103	103
PLANNED	5/18/2021	4	96	24
PLANNED	5/18/2021	7	154	22
PLANNED	5/18/2021	77	3,221	198
PLANNED	5/18/2021	1	93	93
PLANNED	5/18/2021	1	11	11
PLANNED	5/18/2021	2	82	41
PLANNED	5/18/2021	1	13	13
PLANNED	5/18/2021	4	668	167
PLANNED	5/18/2021	9	207	23
PLANNED	5/18/2021	4	48	12
PLANNED	5/18/2021	7	448	64
PLANNED	5/18/2021	54	4,320	80

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/18/2021	10	390	39
PLANNED	5/18/2021	4	624	156
PLANNED	5/18/2021	3	126	42
PLANNED	5/18/2021	1	18	18
PLANNED	5/18/2021	1	10	10
PLANNED	5/18/2021	5	105	21
PLANNED	5/18/2021	8	336	42
PLANNED	5/18/2021	1	36	36
PLANNED	5/18/2021	1	7	7
PLANNED	5/18/2021	10	1,000	100
PLANNED	5/18/2021	1	7	7
PLANNED	5/18/2021	1	14	14
PLANNED	5/18/2021	2	28	14
PLANNED	5/18/2021	3	21	7
PLANNED	5/18/2021	2	82	41
PLANNED	5/18/2021	1	12	12
PLANNED	5/18/2021	33	428	80
PLANNED	5/18/2021	1	7	7
PLANNED	5/18/2021	1	14	14
PLANNED	5/18/2021	5	265	53
PLANNED	5/18/2021	4	80	20
PLANNED	5/18/2021	5	665	133
PLANNED	5/18/2021	1	18	18
PLANNED	5/18/2021	3	45	15
PLANNED	5/18/2021	3	159	53
PLANNED	5/18/2021	3	60	20
PLANNED	5/18/2021	1	8	8
PLANNED	5/18/2021	1	43	43
PLANNED	5/18/2021	15	285	19
PLANNED	5/18/2021	7	252	36
PLANNED	5/18/2021	1	88	88
PLANNED	5/18/2021	3	87	29
PLANNED	5/18/2021	1	47	47
PLANNED	5/18/2021	10	2,000	200
PLANNED	5/18/2021	1	20	20
PLANNED	5/18/2021	2	160	80
PLANNED	5/18/2021	2	246	123
PLANNED	5/18/2021	4	112	28
PLANNED	5/18/2021	1	46	46
PLANNED	5/18/2021	4	652	163
PLANNED	5/18/2021	1	15	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/18/2021	1	55	55
PLANNED	5/18/2021	2	148	74
PLANNED	5/18/2021	1	11	11
PLANNED	5/18/2021	1	98	98
PLANNED	5/18/2021	2	244	122
PLANNED	5/18/2021	3	72	24
PLANNED	5/18/2021	2	170	85
PLANNED	5/18/2021	1	124	124
PLANNED	5/18/2021	1	25	25
PLANNED	5/18/2021	2	184	105
PLANNED	5/18/2021	1	24	24
PLANNED	5/18/2021	4	112	28
PLANNED	5/18/2021	2	366	183
PLANNED	5/18/2021	5	75	15
PLANNED	5/18/2021	2	66	33
PLANNED	5/18/2021	1	1	1
PLANNED	5/18/2021	12	1,584	132
PLANNED	5/18/2021	1	69	69
PLANNED	5/18/2021	2	150	75
PLANNED	5/18/2021	1	56	56
PLANNED	5/18/2021	6	600	100
PLANNED	5/18/2021	1	72	72
PLANNED	5/18/2021	11	891	81
CUSTOMER REQUEST	5/18/2021	18	5,094	283
PLANNED	5/18/2021	1	97	97
PLANNED	5/19/2021	10	2,640	264
PLANNED	5/19/2021	10	750	75
PLANNED	5/19/2021	1	102	102
PLANNED	5/19/2021	1	189	189
PLANNED	5/19/2021	1	155	155
PLANNED	5/19/2021	2	152	76
PLANNED	5/19/2021	26	2,730	105
PLANNED	5/19/2021	5	395	79
PLANNED	5/19/2021	5	525	105
PLANNED	5/19/2021	25	3,050	122
PLANNED	5/19/2021	17	2,074	122
PLANNED	5/19/2021	1	52	52
PLANNED	5/19/2021	4	232	86
PLANNED	5/19/2021	2	97	79
PLANNED	5/19/2021	2	129	65
PLANNED	5/19/2021	1	75	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/19/2021	2	247	163
PLANNED	5/19/2021	6	852	142
PLANNED	5/19/2021	1	7	7
PLANNED	5/19/2021	1	33	33
PLANNED	5/19/2021	2	96	48
PLANNED	5/19/2021	2	24	12
PLANNED	5/19/2021	4	80	20
PLANNED	5/19/2021	5	120	24
PLANNED	5/19/2021	2	278	139
PLANNED	5/19/2021	1	12	12
PLANNED	5/19/2021	3	375	125
PLANNED	5/19/2021	29	3,915	135
PLANNED	5/19/2021	5	1,280	256
PLANNED	5/19/2021	7	392	56
PLANNED	5/19/2021	8	464	58
PLANNED	5/19/2021	5	540	108
PLANNED	5/19/2021	3	435	145
PLANNED	5/19/2021	2	10	5
PLANNED	5/19/2021	3	231	77
PLANNED	5/19/2021	9	396	44
PLANNED	5/19/2021	7	245	35
PLANNED	5/19/2021	1	24	24
PLANNED	5/19/2021	2	12	6
PLANNED	5/19/2021	3	363	121
PLANNED	5/19/2021	13	273	21
PLANNED	5/19/2021	7	784	112
PLANNED	5/19/2021	6	324	54
PLANNED	5/19/2021	6	1,038	173
PLANNED	5/19/2021	9	72	8
PLANNED	5/19/2021	2	230	115
CUSTOMER REQUEST	5/19/2021	2	101	54
PLANNED	5/19/2021	7	1,379	197
PLANNED	5/19/2021	4	2,888	722
PLANNED	5/19/2021	1	12	12
PLANNED	5/19/2021	1	166	166
PLANNED	5/19/2021	4	432	108
PLANNED	5/19/2021	2	314	157
CUSTOMER REQUEST	5/19/2021	1	196	196
PLANNED	5/19/2021	2	70	35
PLANNED	5/19/2021	3	378	126
PLANNED	5/19/2021	2	32	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/19/2021	5	75	15
PLANNED	5/19/2021	5	650	130
PLANNED	5/19/2021	1	206	206
PLANNED	5/19/2021	2	123	69
PLANNED	5/19/2021	21	2,835	135
PLANNED	5/19/2021	1	73	73
PLANNED	5/19/2021	7	602	86
PLANNED	5/19/2021	10	3,310	331
CUSTOMER REQUEST	5/19/2021	36	15,336	426
PLANNED	5/19/2021	1	18	18
PLANNED	5/19/2021	2	36	18
PLANNED	5/19/2021	36	6,012	167
PLANNED	5/19/2021	18	2,124	118
CUSTOMER REQUEST	5/19/2021	6	576	96
PLANNED	5/19/2021	2	276	138
CUSTOMER REQUEST	5/19/2021	8	24	3
PLANNED	5/19/2021	1	8	8
PLANNED	5/19/2021	4	532	133
PLANNED	5/19/2021	6	522	87
PLANNED	5/19/2021	4	112	28
PLANNED	5/19/2021	9	1,395	155
PLANNED	5/19/2021	7	1,078	154
PLANNED	5/19/2021	7	119	17
PLANNED	5/19/2021	4	172	43
PLANNED	5/19/2021	2	14	7
PLANNED	5/19/2021	2	416	208
PLANNED	5/19/2021	2	52	26
PLANNED	5/19/2021	1	89	89
PLANNED	5/19/2021	11	1,595	145
PLANNED	5/19/2021	4	444	111
PLANNED	5/19/2021	7	140	20
PLANNED	5/19/2021	1	9	9
PLANNED	5/19/2021	57	12,141	213
PLANNED	5/19/2021	1	13	13
PLANNED	5/19/2021	1	7	7
PLANNED	5/19/2021	8	2,336	292
PLANNED	5/19/2021	2	64	32
PLANNED	5/19/2021	4	192	48
CUSTOMER REQUEST	5/19/2021	8	40	5
PLANNED	5/19/2021	2	266	133
PLANNED	5/19/2021	4	160	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/19/2021	7	273	39
PLANNED	5/19/2021	1	87	87
PLANNED	5/19/2021	6	12	2
PLANNED	5/19/2021	2	50	25
PLANNED	5/19/2021	1	20	20
PLANNED	5/19/2021	6	516	86
PLANNED	5/19/2021	1	5	5
PLANNED	5/19/2021	4	96	24
PLANNED	5/19/2021	1	29	29
PLANNED	5/19/2021	3	150	50
CUSTOMER REQUEST	5/19/2021	40	3,560	89
CUSTOMER REQUEST	5/19/2021	2	172	164
PLANNED	5/19/2021	6	576	96
CUSTOMER REQUEST	5/19/2021	1	20	20
PLANNED	5/19/2021	7	749	107
PLANNED	5/19/2021	4	356	89
PLANNED	5/19/2021	4	56	14
PLANNED	5/19/2021	12	2,592	216
PLANNED	5/19/2021	1	359	359
PLANNED	5/19/2021	5	275	55
PLANNED	5/19/2021	1	7	7
PLANNED	5/19/2021	2	56	28
PLANNED	5/19/2021	8	264	33
PLANNED	5/19/2021	3	111	37
PLANNED	5/19/2021	6	210	35
CUSTOMER REQUEST	5/19/2021	1	291	291
PLANNED	5/19/2021	8	120	15
PLANNED	5/19/2021	4	452	113
PLANNED	5/19/2021	9	990	110
PLANNED	5/19/2021	30	3,420	114
PLANNED	5/19/2021	8	496	62
PLANNED	5/19/2021	4	680	170
PLANNED	5/19/2021	4	40	10
PLANNED	5/19/2021	2	156	78
PLANNED	5/19/2021	1	5	5
PLANNED	5/19/2021	14	2,912	208
PLANNED	5/19/2021	3	39	13
PLANNED	5/19/2021	3	90	30
PLANNED	5/19/2021	13	260	20
PLANNED	5/19/2021	7	546	78
PLANNED	5/19/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/19/2021	2	208	104
PLANNED	5/19/2021	3	351	117
PLANNED	5/19/2021	2	248	124
PLANNED	5/19/2021	3	18	6
PLANNED	5/19/2021	3	72	24
PLANNED	5/19/2021	8	8	1
PLANNED	5/19/2021	3	153	51
PLANNED	5/19/2021	6	186	64
PLANNED	5/19/2021	1	5	5
PLANNED	5/19/2021	2	38	19
PLANNED	5/19/2021	3	81	27
PLANNED	5/19/2021	2	12	6
PLANNED	5/19/2021	2	134	67
PLANNED	5/19/2021	8	29	8
PLANNED	5/19/2021	2	44	22
PLANNED	5/19/2021	1	31	31
PLANNED	5/19/2021	1	125	125
PLANNED	5/19/2021	5	245	49
PLANNED	5/19/2021	3	54	18
PLANNED	5/19/2021	5	130	26
PLANNED	5/19/2021	2	154	77
PLANNED	5/19/2021	2	10	5
PLANNED	5/19/2021	2	16	8
PLANNED	5/19/2021	6	294	49
PLANNED	5/19/2021	3	45	15
PLANNED	5/19/2021	11	165	15
PLANNED	5/19/2021	7	287	41
PLANNED	5/19/2021	2	120	60
PLANNED	5/19/2021	11	748	68
PLANNED	5/19/2021	12	2,628	219
PLANNED	5/19/2021	12	588	49
PLANNED	5/19/2021	3	159	53
PLANNED	5/19/2021	1	236	236
PLANNED	5/19/2021	13	312	24
PLANNED	5/19/2021	2	30	15
PLANNED	5/19/2021	2	42	21
CUSTOMER REQUEST	5/19/2021	8	48	6
PLANNED	5/19/2021	1	72	72
PLANNED	5/19/2021	2	14	7
PLANNED	5/19/2021	4	456	114
PLANNED	5/19/2021	7	273	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/19/2021	6	186	31
PLANNED	5/19/2021	2	142	71
PLANNED	5/19/2021	3	288	96
CUSTOMER REQUEST	5/19/2021	8	160	20
PLANNED	5/19/2021	3	249	83
PLANNED	5/19/2021	2	176	88
PLANNED	5/19/2021	1	17	17
PLANNED	5/19/2021	4	80	20
PLANNED	5/19/2021	4	56	14
PLANNED	5/19/2021	2	676	338
PLANNED	5/19/2021	2	140	70
PLANNED	5/19/2021	1	264	264
PLANNED	5/19/2021	1	53	53
PLANNED	5/19/2021	1	10	10
PLANNED	5/19/2021	2	332	166
PLANNED	5/19/2021	4	92	23
PLANNED	5/19/2021	2	206	123
PLANNED	5/19/2021	1	70	70
PLANNED	5/19/2021	4	120	30
PLANNED	5/19/2021	1	51	51
PLANNED	5/19/2021	8	576	72
PLANNED	5/19/2021	1	143	143
PLANNED	5/19/2021	1	99	99
PLANNED	5/19/2021	24	2,616	109
PLANNED	5/19/2021	2	180	90
PLANNED	5/19/2021	4	636	159
PLANNED	5/19/2021	1	30	30
CUSTOMER REQUEST	5/19/2021	1	3	3
PLANNED	5/19/2021	10	750	75
PLANNED	5/20/2021	1	25	25
PLANNED	5/20/2021	2	78	39
PLANNED	5/20/2021	1	211	211
PLANNED	5/20/2021	1	141	141
PLANNED	5/20/2021	9	972	108
PLANNED	5/20/2021	1	106	106
PLANNED	5/20/2021	1	82	82
PLANNED	5/20/2021	1	37	37
PLANNED	5/20/2021	1	129	129
PLANNED	5/20/2021	2	74	37
PLANNED	5/20/2021	2	58	29
PLANNED	5/20/2021	3	120	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/20/2021	26	936	36
PLANNED	5/20/2021	11	99	9
PLANNED	5/20/2021	2	166	83
PLANNED	5/20/2021	1	22	22
PLANNED	5/20/2021	3	204	68
PLANNED	5/20/2021	4	116	29
PLANNED	5/20/2021	4	48	12
PLANNED	5/20/2021	1	8	8
PLANNED	5/20/2021	6	144	24
CUSTOMER REQUEST	5/20/2021	8	408	51
PLANNED	5/20/2021	4	328	82
PLANNED	5/20/2021	2	290	145
PLANNED	5/20/2021	4	584	146
PLANNED	5/20/2021	2	184	92
PLANNED	5/20/2021	2	114	57
PLANNED	5/20/2021	10	320	32
PLANNED	5/20/2021	9	153	17
CUSTOMER REQUEST	5/20/2021	11	2,739	249
PLANNED	5/20/2021	1	10	10
PLANNED	5/20/2021	8	416	52
PLANNED	5/20/2021	1	102	102
PLANNED	5/20/2021	2	670	335
PLANNED	5/20/2021	4	604	151
PLANNED	5/20/2021	9	477	53
PLANNED	5/20/2021	3	69	23
PLANNED	5/20/2021	3	144	48
CUSTOMER REQUEST	5/20/2021	6	36	6
PLANNED	5/20/2021	3	117	39
PLANNED	5/20/2021	2	14	7
PLANNED	5/20/2021	2	18	9
PLANNED	5/20/2021	21	3,309	219
PLANNED	5/20/2021	1	20	20
PLANNED	5/20/2021	4	44	11
PLANNED	5/20/2021	4	72	18
PLANNED	5/20/2021	1	143	143
PLANNED	5/20/2021	18	774	43
PLANNED	5/20/2021	1	141	141
PLANNED	5/20/2021	4	352	88
PLANNED	5/20/2021	19	817	43
PLANNED	5/20/2021	1	127	127
PLANNED	5/20/2021	1	124	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/20/2021	10	140	14
PLANNED	5/20/2021	17	2,159	127
PLANNED	5/20/2021	1	6	6
PLANNED	5/20/2021	9	1,143	127
PLANNED	5/20/2021	3	420	140
PLANNED	5/20/2021	19	3,344	176
PLANNED	5/20/2021	2	62	31
PLANNED	5/20/2021	1	5	5
PLANNED	5/20/2021	11	836	76
CUSTOMER REQUEST	5/20/2021	20	180	9
PLANNED	5/20/2021	4	584	146
PLANNED	5/20/2021	1	18	18
PLANNED	5/20/2021	1	7	7
PLANNED	5/20/2021	2	106	53
PLANNED	5/20/2021	3	36	12
PLANNED	5/20/2021	7	665	95
PLANNED	5/20/2021	4	84	21
PLANNED	5/20/2021	5	125	25
PLANNED	5/20/2021	13	1,210	121
PLANNED	5/20/2021	4	116	29
PLANNED	5/20/2021	2	134	67
PLANNED	5/20/2021	6	114	19
PLANNED	5/20/2021	8	1,000	125
PLANNED	5/20/2021	2	128	64
PLANNED	5/20/2021	7	903	129
PLANNED	5/20/2021	9	1,170	130
PLANNED	5/20/2021	9	1,035	115
CUSTOMER REQUEST	5/20/2021	1,017	31,527	31
PLANNED	5/20/2021	4	160	40
PLANNED	5/20/2021	29	5,916	204
PLANNED	5/20/2021	9	117	13
PLANNED	5/20/2021	2	10	5
PLANNED	5/20/2021	12	960	80
PLANNED	5/20/2021	2	160	80
PLANNED	5/20/2021	1	24	24
PLANNED	5/20/2021	4	76	19
PLANNED	5/20/2021	2	238	119
PLANNED	5/20/2021	8	24	3
PLANNED	5/20/2021	3	48	16
PLANNED	5/20/2021	6	144	24
PLANNED	5/20/2021	5	1,010	202

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/20/2021	1	66	66
PLANNED	5/20/2021	5	65	13
PLANNED	5/20/2021	1	119	119
PLANNED	5/20/2021	2	154	77
PLANNED	5/20/2021	16	2,752	172
PLANNED	5/20/2021	6	1,422	237
PLANNED	5/20/2021	11	671	61
PLANNED	5/20/2021	5	790	158
PLANNED	5/20/2021	5	285	57
PLANNED	5/20/2021	6	72	12
PLANNED	5/20/2021	2	64	32
PLANNED	5/20/2021	5	20	4
PLANNED	5/20/2021	4	128	32
PLANNED	5/20/2021	2	308	154
PLANNED	5/20/2021	5	95	19
PLANNED	5/20/2021	3	417	139
PLANNED	5/20/2021	1	370	370
PLANNED	5/20/2021	8	240	30
PLANNED	5/20/2021	1	100	100
PLANNED	5/20/2021	2	64	32
PLANNED	5/20/2021	7	700	100
PLANNED	5/20/2021	1	55	55
PLANNED	5/20/2021	4	328	82
PLANNED	5/20/2021	1	27	27
PLANNED	5/20/2021	141	2,256	16
PLANNED	5/20/2021	1	27	27
PLANNED	5/20/2021	4	44	11
PLANNED	5/20/2021	9	1,251	139
PLANNED	5/20/2021	2	350	175
PLANNED	5/20/2021	6	114	19
PLANNED	5/20/2021	7	28	4
PLANNED	5/20/2021	1	43	43
PLANNED	5/20/2021	4	228	57
PLANNED	5/20/2021	8	407	119
PLANNED	5/20/2021	1	43	43
PLANNED	5/20/2021	3	51	17
PLANNED	5/20/2021	13	312	24
CUSTOMER REQUEST	5/20/2021	22	2,970	135
PLANNED	5/20/2021	1	52	52
PLANNED	5/20/2021	4	100	25
PLANNED	5/20/2021	5	25	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/20/2021	2	50	25
PLANNED	5/20/2021	6	450	75
PLANNED	5/20/2021	14	826	59
PLANNED	5/20/2021	2	72	36
PLANNED	5/20/2021	554	8,864	16
PLANNED	5/20/2021	1	9	9
PLANNED	5/20/2021	6	78	13
PLANNED	5/20/2021	8	1,040	130
PLANNED	5/20/2021	1	52	52
PLANNED	5/20/2021	1	19	19
PLANNED	5/20/2021	2	276	138
PLANNED	5/20/2021	5	45	9
PLANNED	5/20/2021	1	65	65
PLANNED	5/20/2021	1	130	130
PLANNED	5/20/2021	4	204	51
PLANNED	5/20/2021	1	196	196
PLANNED	5/20/2021	4	224	56
PLANNED	5/20/2021	2	106	53
PLANNED	5/20/2021	2	138	69
PLANNED	5/20/2021	3	567	189
PLANNED	5/20/2021	2	96	48
PLANNED	5/20/2021	1	89	89
CUSTOMER REQUEST	5/20/2021	8	56	7
PLANNED	5/20/2021	3	48	16
PLANNED	5/20/2021	2	26	13
PLANNED	5/20/2021	4	292	73
PLANNED	5/20/2021	3	348	116
PLANNED	5/20/2021	3	444	148
PLANNED	5/20/2021	11	627	57
PLANNED	5/20/2021	1	16	16
PLANNED	5/20/2021	1	51	51
PLANNED	5/20/2021	1	153	153
PLANNED	5/20/2021	3	273	91
PLANNED	5/20/2021	1	232	232
PLANNED	5/20/2021	9	306	34
PLANNED	5/20/2021	1	100	100
PLANNED	5/20/2021	5	865	173
PLANNED	5/20/2021	8	1,176	147
PLANNED	5/20/2021	9	369	41
PLANNED	5/20/2021	4	420	105
PLANNED	5/20/2021	1	81	81

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/20/2021	2	56	28
PLANNED	5/20/2021	4	224	56
PLANNED	5/20/2021	9	63	7
CUSTOMER REQUEST	5/20/2021	8	80	10
PLANNED	5/20/2021	6	354	59
PLANNED	5/20/2021	8	520	65
PLANNED	5/20/2021	10	470	47
PLANNED	5/20/2021	2	118	59
PLANNED	5/20/2021	61	4,941	81
PLANNED	5/20/2021	16	784	49
PLANNED	5/20/2021	1	93	93
PLANNED	5/20/2021	3	144	48
PLANNED	5/20/2021	5	560	112
PLANNED	5/20/2021	1	131	131
PLANNED	5/20/2021	14	1,288	92
PLANNED	5/20/2021	1	166	166
PLANNED	5/20/2021	1	68	68
PLANNED	5/20/2021	1	80	80
PLANNED	5/20/2021	3	114	38
PLANNED	5/20/2021	9	99	11
PLANNED	5/20/2021	1	78	78
PLANNED	5/21/2021	21	2,940	140
PLANNED	5/21/2021	1	32	32
PLANNED	5/21/2021	18	4,284	238
PLANNED	5/21/2021	1	173	173
PLANNED	5/21/2021	1	166	166
PLANNED	5/21/2021	2	274	137
PLANNED	5/21/2021	1	32	32
PLANNED	5/21/2021	6	174	29
PLANNED	5/21/2021	2	126	63
PLANNED	5/21/2021	1	38	38
PLANNED	5/21/2021	1	12	12
PLANNED	5/21/2021	4	48	12
PLANNED	5/21/2021	6	162	27
PLANNED	5/21/2021	1	8	8
PLANNED	5/21/2021	3	93	31
CUSTOMER REQUEST	5/21/2021	10	110	11
PLANNED	5/21/2021	1	145	145
PLANNED	5/21/2021	1	62	62
PLANNED	5/21/2021	1	8	8
PLANNED	5/21/2021	3	483	161

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/21/2021	1	8	8
PLANNED	5/21/2021	2	170	85
PLANNED	5/21/2021	1	19	19
PLANNED	5/21/2021	6	318	53
PLANNED	5/21/2021	1	8	8
CUSTOMER REQUEST	5/21/2021	6	126	21
PLANNED	5/21/2021	3	159	53
CUSTOMER REQUEST	5/21/2021	1	183	183
PLANNED	5/21/2021	7	1,414	202
PLANNED	5/21/2021	9	1,314	146
PLANNED	5/21/2021	2	190	95
PLANNED	5/21/2021	1	80	80
PLANNED	5/21/2021	8	1,096	137
CUSTOMER REQUEST	5/21/2021	12	72	6
PLANNED	5/21/2021	6	78	13
PLANNED	5/21/2021	6	36	6
PLANNED	5/21/2021	10	560	56
PLANNED	5/21/2021	5	175	35
PLANNED	5/21/2021	5	65	13
PLANNED	5/21/2021	3	378	126
CUSTOMER REQUEST	5/21/2021	3	120	40
PLANNED	5/21/2021	1	29	29
PLANNED	5/21/2021	1	22	22
PLANNED	5/21/2021	5	275	55
PLANNED	5/21/2021	9	198	22
PLANNED	5/21/2021	6	132	22
PLANNED	5/21/2021	2	126	63
PLANNED	5/21/2021	20	860	43
PLANNED	5/21/2021	36	468	13
PLANNED	5/21/2021	18	414	23
PLANNED	5/21/2021	1	109	109
PLANNED	5/21/2021	9	9	1
PLANNED	5/21/2021	4	788	197
PLANNED	5/21/2021	1	3	3
PLANNED	5/21/2021	21	546	26
CUSTOMER REQUEST	5/21/2021	9	2,700	300
PLANNED	5/21/2021	4	52	13
PLANNED	5/21/2021	8	136	17
PLANNED	5/21/2021	21	1,995	95
PLANNED	5/21/2021	4	664	166
PLANNED	5/21/2021	2	158	79

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/21/2021	5	185	37
PLANNED	5/21/2021	4	412	115
PLANNED	5/21/2021	3	129	87
PLANNED	5/21/2021	4	518	137
PLANNED	5/21/2021	4	52	13
PLANNED	5/21/2021	1	84	84
PLANNED	5/21/2021	5	1,015	203
PLANNED	5/21/2021	7	1,260	180
CUSTOMER REQUEST	5/21/2021	10	50	5
PLANNED	5/21/2021	4	52	13
PLANNED	5/21/2021	1	73	73
PLANNED	5/21/2021	10	1,460	146
PLANNED	5/21/2021	1	71	71
CUSTOMER REQUEST	5/21/2021	3	405	135
PLANNED	5/21/2021	17	1,037	61
PLANNED	5/21/2021	1	104	104
PLANNED	5/21/2021	2	60	30
PLANNED	5/21/2021	1	153	153
PLANNED	5/21/2021	4	52	13
PLANNED	5/21/2021	5	130	26
PLANNED	5/21/2021	8	272	34
PLANNED	5/21/2021	1	11	11
PLANNED	5/21/2021	1	83	83
PLANNED	5/21/2021	5	150	30
PLANNED	5/21/2021	2	102	51
PLANNED	5/21/2021	1	8	8
PLANNED	5/21/2021	9	243	27
PLANNED	5/21/2021	1	59	59
PLANNED	5/21/2021	11	242	22
PLANNED	5/21/2021	1	47	47
PLANNED	5/21/2021	6	378	63
PLANNED	5/21/2021	4	116	29
PLANNED	5/21/2021	6	336	56
CUSTOMER REQUEST	5/21/2021	3	147	49
PLANNED	5/21/2021	1	170	170
PLANNED	5/21/2021	6	84	14
PLANNED	5/21/2021	9	1,008	112
PLANNED	5/21/2021	35	3,010	86
PLANNED	5/21/2021	5	170	34
PLANNED	5/21/2021	3	195	65
PLANNED	5/21/2021	9	261	29

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	5/21/2021	11	187	17
PLANNED	5/21/2021	3	171	57
PLANNED	5/21/2021	2	62	31
PLANNED	5/21/2021	11	286	26
CUSTOMER REQUEST	5/21/2021	1	289	289
CUSTOMER REQUEST	5/21/2021	1	61	61
PLANNED	5/21/2021	2	168	84
PLANNED	5/21/2021	1	80	80
PLANNED	5/21/2021	3	249	83
CUSTOMER REQUEST	5/21/2021	1	416	416
CUSTOMER REQUEST	5/21/2021	1,785	10,827	23
CUSTOMER REQUEST	5/21/2021	239	29,636	124
PLANNED	5/21/2021	4	144	36
PLANNED	5/21/2021	6	234	39
PLANNED	5/21/2021	1	52	52
PLANNED	5/21/2021	7	686	98
PLANNED	5/22/2021	2	532	266
PLANNED	5/22/2021	1	578	578
PLANNED	5/22/2021	3	876	292
PLANNED	5/22/2021	1	110	110
PLANNED	5/22/2021	1	286	286
PLANNED	5/22/2021	1	197	197
PLANNED	5/22/2021	1	124	124
PLANNED	5/22/2021	1	284	284
PLANNED	5/22/2021	3	279	114
PLANNED	5/22/2021	1	257	257
PLANNED	5/22/2021	2	296	148
PLANNED	5/22/2021	6	930	155
PLANNED	5/22/2021	5	400	80
PLANNED	5/22/2021	3	60	20
PLANNED	5/22/2021	2	144	72
PLANNED	5/22/2021	15	1,770	118
PLANNED	5/22/2021	8	604	133
PLANNED	5/22/2021	2	66	33
PLANNED	5/22/2021	1	48	48
CUSTOMER REQUEST	5/22/2021	1	236	236
CUSTOMER REQUEST	5/22/2021	1	299	299
PLANNED	5/22/2021	4	356	89
PLANNED	5/22/2021	21	1,617	77
PLANNED	5/22/2021	1	60	60
PLANNED	5/22/2021	9	1,116	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/22/2021	8	368	46
CUSTOMER REQUEST	5/22/2021	484	484	1
CUSTOMER REQUEST	5/22/2021	1,754	547,262	348
CUSTOMER REQUEST	5/22/2021	1,367	196,790	409
PLANNED	5/22/2021	3	1,503	501
CUSTOMER REQUEST	5/22/2021	3	186	62
CUSTOMER REQUEST	5/22/2021	2,015	98,491	161
CUSTOMER REQUEST	5/22/2021	1	397	397
PLANNED	5/23/2021	6	1,566	261
PLANNED	5/23/2021	5	505	101
CUSTOMER REQUEST	5/23/2021	9	3,060	340
CUSTOMER REQUEST	5/23/2021	2	1,446	723
PLANNED	5/23/2021	1	104	104
PLANNED	5/23/2021	1	161	161
PLANNED	5/23/2021	1	126	126
PLANNED	5/23/2021	1	227	227
PLANNED	5/23/2021	1	180	180
PLANNED	5/23/2021	1	101	101
PLANNED	5/23/2021	5	440	88
PLANNED	5/23/2021	2	372	186
PLANNED	5/23/2021	6	606	101
PLANNED	5/23/2021	3	303	101
PLANNED	5/23/2021	4	444	111
PLANNED	5/23/2021	1	7	7
PLANNED	5/23/2021	1	102	102
PLANNED	5/23/2021	1	47	47
PLANNED	5/23/2021	6	462	77
PLANNED	5/23/2021	1	213	213
PLANNED	5/23/2021	7	1,890	270
PLANNED	5/23/2021	1	140	140
PLANNED	5/23/2021	171	22,743	133
PLANNED	5/24/2021	3	357	119
PLANNED	5/24/2021	4	1,112	278
CUSTOMER REQUEST	5/24/2021	1	632	632
PLANNED	5/24/2021	8	2,504	313
PLANNED	5/24/2021	1	227	227
PLANNED	5/24/2021	4	382	108
PLANNED	5/24/2021	1	5	5
PLANNED	5/24/2021	2	192	96
PLANNED	5/24/2021	14	98	7
PLANNED	5/24/2021	1	75	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/24/2021	4	204	51
PLANNED	5/24/2021	1	7	7
PLANNED	5/24/2021	1	109	109
PLANNED	5/24/2021	11	242	22
PLANNED	5/24/2021	5	80	16
PLANNED	5/24/2021	2	120	60
PLANNED	5/24/2021	7	595	85
PLANNED	5/24/2021	5	1,135	227
PLANNED	5/24/2021	6	1,362	227
PLANNED	5/24/2021	1	11	11
PLANNED	5/24/2021	2	18	9
PLANNED	5/24/2021	4	256	64
PLANNED	5/24/2021	1	32	32
PLANNED	5/24/2021	5	735	147
PLANNED	5/24/2021	1	8	8
PLANNED	5/24/2021	1	10	10
PLANNED	5/24/2021	2	42	21
PLANNED	5/24/2021	2	62	31
PLANNED	5/24/2021	3	57	19
PLANNED	5/24/2021	3	42	14
PLANNED	5/24/2021	12	516	43
PLANNED	5/24/2021	2	28	14
PLANNED	5/24/2021	5	400	96
PLANNED	5/24/2021	6	880	262
PLANNED	5/24/2021	4	486	143
PLANNED	5/24/2021	3	21	7
PLANNED	5/24/2021	1	9	9
PLANNED	5/24/2021	16	832	52
PLANNED	5/24/2021	3	24	8
PLANNED	5/24/2021	1	9	9
PLANNED	5/24/2021	16	1,520	95
PLANNED	5/24/2021	4	36	9
PLANNED	5/24/2021	4	568	142
PLANNED	5/24/2021	1	26	26
PLANNED	5/24/2021	2	28	14
PLANNED	5/24/2021	9	2,352	523
PLANNED	5/24/2021	4	588	147
PLANNED	5/24/2021	4	52	13
CUSTOMER REQUEST	5/24/2021	1	1	1
PLANNED	5/24/2021	4	60	15
PLANNED	5/24/2021	1	15	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/24/2021	3	21	7
PLANNED	5/24/2021	1	41	41
PLANNED	5/24/2021	3	372	124
PLANNED	5/24/2021	5	805	161
PLANNED	5/24/2021	10	390	39
PLANNED	5/24/2021	4	140	35
PLANNED	5/24/2021	4	236	59
PLANNED	5/24/2021	8	1,032	129
PLANNED	5/24/2021	5	615	123
PLANNED	5/24/2021	3	69	23
PLANNED	5/24/2021	1	14	14
PLANNED	5/24/2021	1	148	148
PLANNED	5/24/2021	1	101	101
PLANNED	5/24/2021	8	576	72
PLANNED	5/24/2021	1	187	187
PLANNED	5/24/2021	4	148	37
PLANNED	5/24/2021	3	69	23
PLANNED	5/24/2021	1	110	110
PLANNED	5/24/2021	4	48	12
PLANNED	5/24/2021	3	18	6
PLANNED	5/24/2021	2	494	247
PLANNED	5/24/2021	7	231	33
PLANNED	5/24/2021	1	27	27
PLANNED	5/24/2021	1	56	56
PLANNED	5/24/2021	2	24	12
PLANNED	5/24/2021	3	36	12
PLANNED	5/24/2021	44	9,636	219
PLANNED	5/24/2021	46	8,418	183
CUSTOMER REQUEST	5/24/2021	6	72	12
PLANNED	5/24/2021	4	100	25
PLANNED	5/24/2021	2	62	31
PLANNED	5/24/2021	13	910	70
PLANNED	5/24/2021	6	966	161
PLANNED	5/24/2021	1	23	23
PLANNED	5/24/2021	6	234	39
PLANNED	5/24/2021	2	18	9
PLANNED	5/24/2021	1	58	58
PLANNED	5/24/2021	2	198	99
PLANNED	5/24/2021	3	72	24
PLANNED	5/24/2021	3	190	128
PLANNED	5/24/2021	3	130	67

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/24/2021	5	75	15
PLANNED	5/24/2021	1	10	10
PLANNED	5/24/2021	5	120	24
PLANNED	5/24/2021	2	20	10
PLANNED	5/24/2021	1	13	13
PLANNED	5/24/2021	1	11	11
PLANNED	5/24/2021	8	296	37
PLANNED	5/24/2021	10	4,400	440
PLANNED	5/24/2021	3	57	19
PLANNED	5/24/2021	3	39	13
CUSTOMER REQUEST	5/24/2021	8	2,160	270
CUSTOMER REQUEST	5/24/2021	6	1,632	272
PLANNED	5/24/2021	4	556	139
PLANNED	5/24/2021	4	120	30
PLANNED	5/24/2021	10	430	43
PLANNED	5/24/2021	5	60	12
PLANNED	5/24/2021	5	75	15
PLANNED	5/24/2021	2	274	137
PLANNED	5/24/2021	2	32	16
PLANNED	5/24/2021	1	9	9
PLANNED	5/24/2021	2	32	16
PLANNED	5/24/2021	2	308	154
PLANNED	5/24/2021	1	51	51
PLANNED	5/24/2021	2	42	21
PLANNED	5/24/2021	10	350	35
PLANNED	5/24/2021	1	7	7
PLANNED	5/24/2021	2	64	32
PLANNED	5/24/2021	1	54	54
PLANNED	5/24/2021	1	10	10
PLANNED	5/24/2021	10	1,290	129
PLANNED	5/24/2021	6	996	166
PLANNED	5/24/2021	2	10	5
CUSTOMER REQUEST	5/24/2021	8	1,664	208
PLANNED	5/24/2021	1	64	64
CUSTOMER REQUEST	5/24/2021	5	1,045	209
PLANNED	5/24/2021	2	528	264
PLANNED	5/24/2021	2	12	6
PLANNED	5/24/2021	2	116	58
PLANNED	5/24/2021	6	396	66
PLANNED	5/24/2021	1	16	16
PLANNED	5/24/2021	1	5	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/24/2021	1	100	100
PLANNED	5/24/2021	2	278	139
PLANNED	5/24/2021	4	476	119
PLANNED	5/24/2021	2	52	26
PLANNED	5/24/2021	2	34	17
PLANNED	5/24/2021	3	195	65
PLANNED	5/24/2021	6	318	53
PLANNED	5/24/2021	3	48	16
PLANNED	5/24/2021	9	288	32
PLANNED	5/24/2021	2	34	17
PLANNED	5/24/2021	2	38	19
PLANNED	5/24/2021	1	79	79
PLANNED	5/24/2021	2	10	5
PLANNED	5/24/2021	3	84	28
PLANNED	5/24/2021	1	146	146
PLANNED	5/24/2021	3	132	44
PLANNED	5/24/2021	2	32	16
PLANNED	5/24/2021	2	86	43
PLANNED	5/24/2021	1	5	5
PLANNED	5/24/2021	1	135	135
PLANNED	5/24/2021	2	56	28
PLANNED	5/24/2021	2	94	47
PLANNED	5/24/2021	1	90	90
PLANNED	5/24/2021	8	224	28
PLANNED	5/24/2021	1	67	67
PLANNED	5/24/2021	4	84	21
PLANNED	5/24/2021	2	152	76
PLANNED	5/24/2021	3	96	32
PLANNED	5/24/2021	3	42	14
PLANNED	5/24/2021	4	244	61
PLANNED	5/24/2021	1	79	79
CUSTOMER REQUEST	5/24/2021	1	876	876
PLANNED	5/24/2021	7	1,204	172
PLANNED	5/24/2021	5	135	27
PLANNED	5/24/2021	1	237	237
PLANNED	5/24/2021	6	240	40
CUSTOMER REQUEST	5/25/2021	2,189	34,515	28
PLANNED	5/25/2021	1	79	79
PLANNED	5/25/2021	4	184	46
PLANNED	5/25/2021	1	144	144
PLANNED	5/25/2021	1	11	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/25/2021	47	3,008	64
PLANNED	5/25/2021	7	157	23
PLANNED	5/25/2021	8	344	43
CUSTOMER REQUEST	5/25/2021	16	296	266
PLANNED	5/25/2021	1	161	161
PLANNED	5/25/2021	5	1,195	239
PLANNED	5/25/2021	10	550	55
PLANNED	5/25/2021	4	172	43
PLANNED	5/25/2021	2	28	14
PLANNED	5/25/2021	2	50	25
PLANNED	5/25/2021	2	232	116
CUSTOMER REQUEST	5/25/2021	12	3,708	309
PLANNED	5/25/2021	1	5	5
CUSTOMER REQUEST	5/25/2021	6	2,730	455
PLANNED	5/25/2021	2	16	8
PLANNED	5/25/2021	6	120	20
PLANNED	5/25/2021	1	10	10
PLANNED	5/25/2021	6	66	11
PLANNED	5/25/2021	1	6	6
PLANNED	5/25/2021	3	122	56
PLANNED	5/25/2021	6	36	6
PLANNED	5/25/2021	2	48	24
PLANNED	5/25/2021	1	9	9
PLANNED	5/25/2021	1	2	2
PLANNED	5/25/2021	7	273	39
PLANNED	5/25/2021	3	36	12
PLANNED	5/25/2021	1	112	112
PLANNED	5/25/2021	1	44	44
PLANNED	5/25/2021	2	14	7
PLANNED	5/25/2021	4	88	22
PLANNED	5/25/2021	4	56	14
PLANNED	5/25/2021	5	155	31
PLANNED	5/25/2021	2	16	8
PLANNED	5/25/2021	3	465	155
PLANNED	5/25/2021	8	1,312	164
PLANNED	5/25/2021	7	826	118
PLANNED	5/25/2021	1	164	164
PLANNED	5/25/2021	1	16	16
PLANNED	5/25/2021	1	144	144
PLANNED	5/25/2021	1	148	148
PLANNED	5/25/2021	14	392	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/25/2021	2	174	132
PLANNED	5/25/2021	1	121	121
PLANNED	5/25/2021	4	116	29
PLANNED	5/25/2021	4	48	12
PLANNED	5/25/2021	1	6	6
PLANNED	5/25/2021	2	500	250
PLANNED	5/25/2021	6	60	10
PLANNED	5/25/2021	28	4,998	183
PLANNED	5/25/2021	7	105	15
PLANNED	5/25/2021	5	15	3
PLANNED	5/25/2021	5	5	1
PLANNED	5/25/2021	2	92	46
PLANNED	5/25/2021	3	66	22
PLANNED	5/25/2021	3	69	32
PLANNED	5/25/2021	2	10	5
PLANNED	5/25/2021	8	168	21
PLANNED	5/25/2021	4	48	12
PLANNED	5/25/2021	6	1,080	180
PLANNED	5/25/2021	4	1,168	292
PLANNED	5/25/2021	7	840	120
PLANNED	5/25/2021	7	819	117
PLANNED	5/25/2021	2	116	58
CUSTOMER REQUEST	5/25/2021	6	1,584	264
PLANNED	5/25/2021	2	10	5
CUSTOMER REQUEST	5/25/2021	7	174	126
PLANNED	5/25/2021	17	799	47
PLANNED	5/25/2021	44	8,624	196
PLANNED	5/25/2021	1	91	91
PLANNED	5/25/2021	2	150	75
PLANNED	5/25/2021	2	28	14
PLANNED	5/25/2021	12	4,308	359
PLANNED	5/25/2021	1	19	19
PLANNED	5/25/2021	1	5	5
PLANNED	5/25/2021	3	72	24
PLANNED	5/25/2021	5	640	128
PLANNED	5/25/2021	4	24	6
PLANNED	5/25/2021	1	5	5
PLANNED	5/25/2021	46	6,946	151
PLANNED	5/25/2021	3	113	53
PLANNED	5/25/2021	1	9	9
PLANNED	5/25/2021	16	896	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/25/2021	1	10	10
PLANNED	5/25/2021	10	100	10
PLANNED	5/25/2021	2	66	33
PLANNED	5/25/2021	4	64	16
PLANNED	5/25/2021	1	58	58
PLANNED	5/25/2021	6	1,380	230
PLANNED	5/25/2021	5	105	21
PLANNED	5/25/2021	2	18	9
PLANNED	5/25/2021	9	216	24
PLANNED	5/25/2021	3	18	6
PLANNED	5/25/2021	2	188	94
PLANNED	5/25/2021	1	8	8
PLANNED	5/25/2021	1	11	11
PLANNED	5/25/2021	33	10,857	329
PLANNED	5/25/2021	1	55	55
PLANNED	5/25/2021	1	137	137
PLANNED	5/25/2021	6	696	116
PLANNED	5/25/2021	8	928	116
PLANNED	5/25/2021	7	812	116
PLANNED	5/25/2021	6	222	37
PLANNED	5/25/2021	3	63	21
PLANNED	5/25/2021	1	19	19
PLANNED	5/25/2021	19	3,800	200
PLANNED	5/25/2021	1	10	10
PLANNED	5/25/2021	10	2,090	209
PLANNED	5/25/2021	10	2,210	221
PLANNED	5/25/2021	2	32	16
PLANNED	5/25/2021	3	21	7
CUSTOMER REQUEST	5/25/2021	9	369	41
PLANNED	5/25/2021	7	406	58
PLANNED	5/25/2021	4	36	9
PLANNED	5/25/2021	3	24	8
PLANNED	5/25/2021	2	196	119
PLANNED	5/25/2021	4	28	7
PLANNED	5/25/2021	2	26	13
CUSTOMER REQUEST	5/25/2021	5	15	3
PLANNED	5/25/2021	5	75	15
PLANNED	5/25/2021	2	336	168
PLANNED	5/25/2021	2	35	20
PLANNED	5/25/2021	7	609	87
PLANNED	5/25/2021	3	199	80

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/25/2021	4	28	7
PLANNED	5/25/2021	2	54	27
PLANNED	5/25/2021	4	84	21
PLANNED	5/25/2021	2	224	112
PLANNED	5/25/2021	2	4	2
PLANNED	5/25/2021	1	2	2
PLANNED	5/25/2021	1	108	108
PLANNED	5/25/2021	1	4	4
PLANNED	5/25/2021	4	32	8
PLANNED	5/25/2021	1	111	111
PLANNED	5/25/2021	7	84	12
PLANNED	5/25/2021	1	25	25
PLANNED	5/25/2021	2	214	107
PLANNED	5/25/2021	33	2,871	87
PLANNED	5/25/2021	7	175	25
PLANNED	5/25/2021	6	222	37
PLANNED	5/25/2021	3	48	16
PLANNED	5/25/2021	4	40	10
PLANNED	5/25/2021	1	34	34
PLANNED	5/25/2021	1	15	15
PLANNED	5/25/2021	1	13	13
PLANNED	5/25/2021	1	68	68
PLANNED	5/25/2021	4	296	74
PLANNED	5/25/2021	2	126	63
PLANNED	5/25/2021	2	10	5
PLANNED	5/25/2021	4	120	30
PLANNED	5/25/2021	1	99	99
PLANNED	5/25/2021	2	14	7
PLANNED	5/25/2021	1	6	6
PLANNED	5/25/2021	30	9,890	393
PLANNED	5/25/2021	46	4,048	88
PLANNED	5/25/2021	2	366	183
PLANNED	5/25/2021	3	36	12
PLANNED	5/25/2021	2	22	11
PLANNED	5/25/2021	4	44	11
PLANNED	5/25/2021	10	30	3
PLANNED	5/25/2021	16	512	32
PLANNED	5/25/2021	2	304	152
PLANNED	5/25/2021	3	117	39
PLANNED	5/25/2021	5	117	51
PLANNED	5/25/2021	1	20	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/25/2021	1	11	11
PLANNED	5/25/2021	1	83	83
PLANNED	5/25/2021	1	12	12
PLANNED	5/25/2021	5	55	11
PLANNED	5/25/2021	5	260	52
PLANNED	5/25/2021	1	93	93
PLANNED	5/25/2021	1	54	54
PLANNED	5/25/2021	1	108	108
PLANNED	5/25/2021	5	120	24
PLANNED	5/25/2021	11	242	22
PLANNED	5/25/2021	16	528	33
PLANNED	5/25/2021	1	83	83
CUSTOMER REQUEST	5/25/2021	1	330	330
PLANNED	5/25/2021	3	78	26
PLANNED	5/25/2021	1	60	60
PLANNED	5/25/2021	2	12	6
PLANNED	5/25/2021	3	126	42
PLANNED	5/25/2021	2	236	118
PLANNED	5/25/2021	2	350	175
PLANNED	5/25/2021	1	159	159
PLANNED	5/25/2021	1	178	178
PLANNED	5/25/2021	5	230	46
PLANNED	5/25/2021	1	45	45
CUSTOMER REQUEST	5/25/2021	1	202	202
PLANNED	5/25/2021	2	118	59
PLANNED	5/26/2021	3	291	97
PLANNED	5/26/2021	1	24	24
PLANNED	5/26/2021	5	685	137
PLANNED	5/26/2021	1	41	41
PLANNED	5/26/2021	41	2,788	68
PLANNED	5/26/2021	3	117	39
PLANNED	5/26/2021	2	250	125
PLANNED	5/26/2021	3	435	145
CUSTOMER REQUEST	5/26/2021	1	391	391
PLANNED	5/26/2021	1	56	56
PLANNED	5/26/2021	5	505	101
PLANNED	5/26/2021	21	1,050	50
PLANNED	5/26/2021	5	230	46
PLANNED	5/26/2021	3	267	89
PLANNED	5/26/2021	3	198	66
PLANNED	5/26/2021	7	1,596	228

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	2	176	88
PLANNED	5/26/2021	2	56	28
PLANNED	5/26/2021	1	62	62
PLANNED	5/26/2021	4	268	67
PLANNED	5/26/2021	1	9	9
PLANNED	5/26/2021	2	210	105
PLANNED	5/26/2021	1	21	21
PLANNED	5/26/2021	4	48	12
PLANNED	5/26/2021	1	51	51
PLANNED	5/26/2021	4	52	13
PLANNED	5/26/2021	6	1,272	212
PLANNED	5/26/2021	4	1,124	281
PLANNED	5/26/2021	4	228	57
PLANNED	5/26/2021	2	16	8
PLANNED	5/26/2021	2	38	19
PLANNED	5/26/2021	2	424	212
PLANNED	5/26/2021	1	193	193
PLANNED	5/26/2021	7	1,344	192
PLANNED	5/26/2021	15	1,125	75
PLANNED	5/26/2021	4	144	36
PLANNED	5/26/2021	7	252	36
PLANNED	5/26/2021	6	534	89
PLANNED	5/26/2021	2	20	10
PLANNED	5/26/2021	2	98	49
PLANNED	5/26/2021	2	98	49
PLANNED	5/26/2021	1	102	102
PLANNED	5/26/2021	4	604	151
PLANNED	5/26/2021	5	205	41
PLANNED	5/26/2021	2	46	23
PLANNED	5/26/2021	4	48	12
PLANNED	5/26/2021	1	25	25
PLANNED	5/26/2021	21	1,365	65
PLANNED	5/26/2021	2	10	5
PLANNED	5/26/2021	9	108	12
PLANNED	5/26/2021	1	11	11
PLANNED	5/26/2021	10	1,600	160
PLANNED	5/26/2021	48	1,120	31
PLANNED	5/26/2021	4	164	41
PLANNED	5/26/2021	1	21	21
PLANNED	5/26/2021	3	30	10
PLANNED	5/26/2021	2	22	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	2	14	7
PLANNED	5/26/2021	7	196	28
PLANNED	5/26/2021	1	125	125
PLANNED	5/26/2021	4	160	40
CUSTOMER REQUEST	5/26/2021	1	33	33
PLANNED	5/26/2021	4	32	8
PLANNED	5/26/2021	4	148	37
PLANNED	5/26/2021	2	144	72
PLANNED	5/26/2021	7	217	31
PLANNED	5/26/2021	1	8	8
PLANNED	5/26/2021	5	528	176
PLANNED	5/26/2021	4	168	42
PLANNED	5/26/2021	5	370	74
PLANNED	5/26/2021	16	2,140	223
PLANNED	5/26/2021	5	378	116
CUSTOMER REQUEST	5/26/2021	1	359	359
PLANNED	5/26/2021	2	162	81
PLANNED	5/26/2021	4	776	194
PLANNED	5/26/2021	1	118	118
PLANNED	5/26/2021	4	532	133
PLANNED	5/26/2021	7	987	141
PLANNED	5/26/2021	3	15	5
PLANNED	5/26/2021	14	1,904	136
PLANNED	5/26/2021	3	69	23
PLANNED	5/26/2021	3	582	194
PLANNED	5/26/2021	4	104	26
PLANNED	5/26/2021	3	36	12
PLANNED	5/26/2021	7	35	5
PLANNED	5/26/2021	8	760	95
PLANNED	5/26/2021	9	585	65
PLANNED	5/26/2021	1	203	203
PLANNED	5/26/2021	3	159	53
PLANNED	5/26/2021	3	228	76
PLANNED	5/26/2021	2	32	16
PLANNED	5/26/2021	13	169	13
PLANNED	5/26/2021	1	5	5
PLANNED	5/26/2021	1	15	15
PLANNED	5/26/2021	1	5	5
PLANNED	5/26/2021	1	18	18
PLANNED	5/26/2021	4	28	7
PLANNED	5/26/2021	11	935	85

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	2	224	112
PLANNED	5/26/2021	2	92	46
CUSTOMER REQUEST	5/26/2021	8	80	10
PLANNED	5/26/2021	1	11	11
PLANNED	5/26/2021	1	62	62
PLANNED	5/26/2021	1	17	17
PLANNED	5/26/2021	6	276	46
PLANNED	5/26/2021	6	594	99
PLANNED	5/26/2021	7	196	28
PLANNED	5/26/2021	3	24	8
PLANNED	5/26/2021	2	20	10
PLANNED	5/26/2021	3	33	11
PLANNED	5/26/2021	2	26	13
PLANNED	5/26/2021	5	135	27
PLANNED	5/26/2021	1	247	247
PLANNED	5/26/2021	4	480	120
PLANNED	5/26/2021	42	10,122	241
PLANNED	5/26/2021	15	75	5
PLANNED	5/26/2021	11	1,078	98
PLANNED	5/26/2021	2	26	13
PLANNED	5/26/2021	2	10	5
PLANNED	5/26/2021	1	6	6
PLANNED	5/26/2021	1	246	246
PLANNED	5/26/2021	3	96	32
PLANNED	5/26/2021	1	8	8
PLANNED	5/26/2021	2	680	340
PLANNED	5/26/2021	8	616	77
PLANNED	5/26/2021	8	304	38
PLANNED	5/26/2021	7	343	49
PLANNED	5/26/2021	67	6,700	100
PLANNED	5/26/2021	3	21	7
PLANNED	5/26/2021	2	136	68
PLANNED	5/26/2021	1	8	8
PLANNED	5/26/2021	63	6,237	99
PLANNED	5/26/2021	4	68	17
PLANNED	5/26/2021	3	339	113
PLANNED	5/26/2021	1	8	8
PLANNED	5/26/2021	2	86	43
CUSTOMER REQUEST	5/26/2021	1	182	182
PLANNED	5/26/2021	3	36	12
PLANNED	5/26/2021	7	525	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	5	375	75
PLANNED	5/26/2021	1	13	13
PLANNED	5/26/2021	2	100	50
PLANNED	5/26/2021	13	91	7
PLANNED	5/26/2021	2	76	38
PLANNED	5/26/2021	4	140	35
PLANNED	5/26/2021	31	2,790	90
PLANNED	5/26/2021	3	33	11
PLANNED	5/26/2021	4	184	46
PLANNED	5/26/2021	2	38	19
PLANNED	5/26/2021	11	825	75
PLANNED	5/26/2021	3	63	21
PLANNED	5/26/2021	2	28	14
PLANNED	5/26/2021	1	15	15
PLANNED	5/26/2021	7	70	10
PLANNED	5/26/2021	6	348	58
PLANNED	5/26/2021	3	120	40
CUSTOMER REQUEST	5/26/2021	8	992	124
PLANNED	5/26/2021	2	18	9
PLANNED	5/26/2021	6	48	8
PLANNED	5/26/2021	1	16	16
PLANNED	5/26/2021	2	120	60
PLANNED	5/26/2021	1	7	7
PLANNED	5/26/2021	8	112	14
PLANNED	5/26/2021	4	100	25
PLANNED	5/26/2021	3	30	10
PLANNED	5/26/2021	3	966	322
PLANNED	5/26/2021	5	770	154
PLANNED	5/26/2021	1	16	16
PLANNED	5/26/2021	4	308	77
PLANNED	5/26/2021	8	232	29
PLANNED	5/26/2021	3	171	57
PLANNED	5/26/2021	3	201	67
PLANNED	5/26/2021	1	103	103
PLANNED	5/26/2021	1	29	29
PLANNED	5/26/2021	1	7	7
PLANNED	5/26/2021	2	18	9
PLANNED	5/26/2021	4	152	38
PLANNED	5/26/2021	4	140	35
PLANNED	5/26/2021	5	535	107
PLANNED	5/26/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	4	228	57
PLANNED	5/26/2021	1	90	90
PLANNED	5/26/2021	8	296	37
PLANNED	5/26/2021	2	10	5
PLANNED	5/26/2021	3	33	11
PLANNED	5/26/2021	2	8	4
PLANNED	5/26/2021	4	116	29
PLANNED	5/26/2021	1	13	13
PLANNED	5/26/2021	8	40	5
PLANNED	5/26/2021	1	9	9
PLANNED	5/26/2021	8	976	122
PLANNED	5/26/2021	2	12	6
PLANNED	5/26/2021	2	12	6
PLANNED	5/26/2021	1	4	4
PLANNED	5/26/2021	7	49	7
PLANNED	5/26/2021	8	864	108
PLANNED	5/26/2021	1	9	9
PLANNED	5/26/2021	6	72	12
PLANNED	5/26/2021	2	82	41
PLANNED	5/26/2021	8	544	68
PLANNED	5/26/2021	4	64	16
PLANNED	5/26/2021	2	10	5
PLANNED	5/26/2021	2	330	165
PLANNED	5/26/2021	10	870	87
PLANNED	5/26/2021	6	522	87
PLANNED	5/26/2021	2	16	8
PLANNED	5/26/2021	4	264	66
PLANNED	5/26/2021	2	170	85
PLANNED	5/26/2021	1	11	11
PLANNED	5/26/2021	4	156	39
PLANNED	5/26/2021	2	10	5
CUSTOMER REQUEST	5/26/2021	5	60	12
PLANNED	5/26/2021	10	430	43
PLANNED	5/26/2021	2	8	4
PLANNED	5/26/2021	3	90	30
PLANNED	5/26/2021	4	152	38
PLANNED	5/26/2021	4	140	35
PLANNED	5/26/2021	1	86	86
PLANNED	5/26/2021	2	24	12
PLANNED	5/26/2021	1	53	53
PLANNED	5/26/2021	2	30	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	1	5	5
PLANNED	5/26/2021	1	155	155
PLANNED	5/26/2021	1	10	10
PLANNED	5/26/2021	1	23	23
PLANNED	5/26/2021	2	138	69
PLANNED	5/26/2021	10	224	63
PLANNED	5/26/2021	2	10	5
PLANNED	5/26/2021	2	68	34
PLANNED	5/26/2021	33	10,329	313
PLANNED	5/26/2021	4	780	195
PLANNED	5/26/2021	2	14	7
PLANNED	5/26/2021	2	30	15
PLANNED	5/26/2021	4	56	14
PLANNED	5/26/2021	1	5	5
PLANNED	5/26/2021	1	24	24
PLANNED	5/26/2021	1	66	66
PLANNED	5/26/2021	1	12	12
PLANNED	5/26/2021	4	112	28
PLANNED	5/26/2021	5	695	139
PLANNED	5/26/2021	2	24	12
PLANNED	5/26/2021	1	69	69
PLANNED	5/26/2021	6	114	19
PLANNED	5/26/2021	2	44	22
PLANNED	5/26/2021	1	91	91
PLANNED	5/26/2021	4	268	67
PLANNED	5/26/2021	2	18	9
PLANNED	5/26/2021	2	32	23
PLANNED	5/26/2021	2	22	11
PLANNED	5/26/2021	2	44	22
PLANNED	5/26/2021	1	86	86
PLANNED	5/26/2021	6	150	25
PLANNED	5/26/2021	6	246	41
PLANNED	5/26/2021	3	261	87
PLANNED	5/26/2021	2	280	140
PLANNED	5/26/2021	1	113	113
PLANNED	5/26/2021	2	196	98
PLANNED	5/26/2021	1	95	95
PLANNED	5/26/2021	1	40	40
PLANNED	5/26/2021	1	80	80
CUSTOMER REQUEST	5/26/2021	1	154	154
PLANNED	5/26/2021	6	2,604	434

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/26/2021	2	128	64
PLANNED	5/26/2021	1	237	237
PLANNED	5/26/2021	3	378	126
PLANNED	5/26/2021	1	133	133
PLANNED	5/26/2021	1	308	308
PLANNED	5/26/2021	1	106	106
PLANNED	5/26/2021	2	182	91
PLANNED	5/26/2021	6	1,410	235
PLANNED	5/27/2021	4	168	42
PLANNED	5/27/2021	7	392	56
PLANNED	5/27/2021	1	257	257
PLANNED	5/27/2021	10	2,310	231
PLANNED	5/27/2021	1	251	251
PLANNED	5/27/2021	2	270	135
PLANNED	5/27/2021	8	1,128	141
PLANNED	5/27/2021	2	116	58
PLANNED	5/27/2021	8	728	91
PLANNED	5/27/2021	8	696	87
PLANNED	5/27/2021	1	248	248
PLANNED	5/27/2021	3	126	56
CUSTOMER REQUEST	5/27/2021	1	212	212
PLANNED	5/27/2021	1	25	25
CUSTOMER REQUEST	5/27/2021	1	131	131
PLANNED	5/27/2021	4	116	29
PLANNED	5/27/2021	1	18	18
PLANNED	5/27/2021	2	14	7
PLANNED	5/27/2021	1	215	215
PLANNED	5/27/2021	1	73	73
PLANNED	5/27/2021	4	232	58
CUSTOMER REQUEST	5/27/2021	12	4,884	407
PLANNED	5/27/2021	26	3,978	153
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	4	160	40
PLANNED	5/27/2021	4	156	39
PLANNED	5/27/2021	4	116	29
CUSTOMER REQUEST	5/27/2021	11	4,312	392
PLANNED	5/27/2021	4	100	25
PLANNED	5/27/2021	1	125	125
PLANNED	5/27/2021	3	210	70
PLANNED	5/27/2021	3	21	7
PLANNED	5/27/2021	1	10	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	2	258	129
PLANNED	5/27/2021	2	60	30
PLANNED	5/27/2021	8	184	23
PLANNED	5/27/2021	1	53	53
PLANNED	5/27/2021	1	61	61
PLANNED	5/27/2021	2	133	78
PLANNED	5/27/2021	8	960	120
PLANNED	5/27/2021	1	8	8
PLANNED	5/27/2021	2	119	69
PLANNED	5/27/2021	29	58	2
PLANNED	5/27/2021	1	70	70
PLANNED	5/27/2021	1	9	9
PLANNED	5/27/2021	4	280	70
PLANNED	5/27/2021	4	732	183
PLANNED	5/27/2021	4	427	137
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	4	276	69
PLANNED	5/27/2021	2	396	198
PLANNED	5/27/2021	1	11	11
PLANNED	5/27/2021	9	1,773	197
PLANNED	5/27/2021	4	236	59
CUSTOMER REQUEST	5/27/2021	2	130	65
PLANNED	5/27/2021	4	132	33
PLANNED	5/27/2021	1	11	11
PLANNED	5/27/2021	1	89	89
PLANNED	5/27/2021	1	10	10
PLANNED	5/27/2021	3	6	2
PLANNED	5/27/2021	4	724	181
PLANNED	5/27/2021	5	75	15
PLANNED	5/27/2021	3	412	200
PLANNED	5/27/2021	2	634	317
PLANNED	5/27/2021	1	8	8
PLANNED	5/27/2021	1	6	6
PLANNED	5/27/2021	3	654	218
PLANNED	5/27/2021	12	876	73
PLANNED	5/27/2021	8	448	56
PLANNED	5/27/2021	6	330	55
PLANNED	5/27/2021	2	24	12
PLANNED	5/27/2021	6	450	75
PLANNED	5/27/2021	58	4,350	75

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	3	27	9
PLANNED	5/27/2021	13	1,989	153
PLANNED	5/27/2021	6	624	104
PLANNED	5/27/2021	6	594	99
PLANNED	5/27/2021	2	18	9
PLANNED	5/27/2021	5	35	7
PLANNED	5/27/2021	2	248	133
PLANNED	5/27/2021	1	16	16
PLANNED	5/27/2021	1	15	15
PLANNED	5/27/2021	5	225	45
PLANNED	5/27/2021	2	12	6
PLANNED	5/27/2021	5	100	20
PLANNED	5/27/2021	1	23	23
PLANNED	5/27/2021	4	52	13
PLANNED	5/27/2021	1	58	58
PLANNED	5/27/2021	1	11	11
PLANNED	5/27/2021	3	45	15
PLANNED	5/27/2021	3	57	19
PLANNED	5/27/2021	7	317	77
PLANNED	5/27/2021	4	4	1
PLANNED	5/27/2021	6	852	142
CUSTOMER REQUEST	5/27/2021	17	119	7
PLANNED	5/27/2021	3	39	13
PLANNED	5/27/2021	1	10	10
PLANNED	5/27/2021	2	814	407
PLANNED	5/27/2021	2	280	140
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	7	926	194
PLANNED	5/27/2021	3	1,359	453
PLANNED	5/27/2021	2	38	19
PLANNED	5/27/2021	10	2,810	281
PLANNED	5/27/2021	4	112	28
PLANNED	5/27/2021	50	9,150	183
PLANNED	5/27/2021	3	57	19
PLANNED	5/27/2021	1	10	10
CUSTOMER REQUEST	5/27/2021	1	321	321
PLANNED	5/27/2021	3	417	139
PLANNED	5/27/2021	2	49	48
PLANNED	5/27/2021	1	22	22
PLANNED	5/27/2021	6	1,086	181
PLANNED	5/27/2021	4	132	33

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	1	52	52
PLANNED	5/27/2021	7	1,155	165
PLANNED	5/27/2021	16	5,184	324
PLANNED	5/27/2021	3	264	88
PLANNED	5/27/2021	3	132	44
PLANNED	5/27/2021	1	8	8
PLANNED	5/27/2021	1	8	8
PLANNED	5/27/2021	6	660	110
PLANNED	5/27/2021	1	20	20
PLANNED	5/27/2021	2	116	58
PLANNED	5/27/2021	2	112	56
CUSTOMER REQUEST	5/27/2021	8	48	6
PLANNED	5/27/2021	12	4,116	343
PLANNED	5/27/2021	4	508	127
PLANNED	5/27/2021	1	14	14
PLANNED	5/27/2021	3	18	6
PLANNED	5/27/2021	3	21	7
PLANNED	5/27/2021	4	84	21
PLANNED	5/27/2021	40	560	14
PLANNED	5/27/2021	2	50	25
PLANNED	5/27/2021	1	68	68
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	2	196	98
PLANNED	5/27/2021	16	416	26
PLANNED	5/27/2021	5	65	13
PLANNED	5/27/2021	1	11	11
PLANNED	5/27/2021	1	58	58
CUSTOMER REQUEST	5/27/2021	8	56	7
PLANNED	5/27/2021	1	26	26
PLANNED	5/27/2021	2	20	10
PLANNED	5/27/2021	2	38	19
PLANNED	5/27/2021	9	270	30
PLANNED	5/27/2021	8	184	23
PLANNED	5/27/2021	1	39	39
PLANNED	5/27/2021	3	77	47
PLANNED	5/27/2021	3	126	42
PLANNED	5/27/2021	1	6	6
PLANNED	5/27/2021	3	402	134
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	6	192	32
PLANNED	5/27/2021	2	26	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	4	112	28
PLANNED	5/27/2021	4	164	41
PLANNED	5/27/2021	2	62	31
PLANNED	5/27/2021	2	22	11
PLANNED	5/27/2021	2	16	8
PLANNED	5/27/2021	9	249	44
PLANNED	5/27/2021	10	130	13
PLANNED	5/27/2021	2	12	6
PLANNED	5/27/2021	1	7	7
PLANNED	5/27/2021	4	36	9
PLANNED	5/27/2021	2	56	28
PLANNED	5/27/2021	2	114	57
PLANNED	5/27/2021	1	32	32
PLANNED	5/27/2021	1	411	411
PLANNED	5/27/2021	1	381	381
PLANNED	5/27/2021	2	14	7
PLANNED	5/27/2021	2	46	23
PLANNED	5/27/2021	4	48	12
PLANNED	5/27/2021	3	111	37
PLANNED	5/27/2021	1	167	167
PLANNED	5/27/2021	1	9	9
PLANNED	5/27/2021	1	12	12
PLANNED	5/27/2021	6	162	27
PLANNED	5/27/2021	8	208	26
PLANNED	5/27/2021	6	156	26
PLANNED	5/27/2021	8	208	26
PLANNED	5/27/2021	2	105	54
PLANNED	5/27/2021	6	156	26
PLANNED	5/27/2021	4	44	11
PLANNED	5/27/2021	2	174	87
PLANNED	5/27/2021	8	152	19
PLANNED	5/27/2021	1	119	119
PLANNED	5/27/2021	3	21	7
PLANNED	5/27/2021	5	40	8
PLANNED	5/27/2021	3	387	129
PLANNED	5/27/2021	8	1,448	181
PLANNED	5/27/2021	4	4	1
PLANNED	5/27/2021	10	1,500	150
PLANNED	5/27/2021	6	276	46
PLANNED	5/27/2021	5	135	27
PLANNED	5/27/2021	1	74	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	4	400	100
PLANNED	5/27/2021	4	76	19
PLANNED	5/27/2021	4	52	13
PLANNED	5/27/2021	7	777	111
PLANNED	5/27/2021	2	254	143
PLANNED	5/27/2021	8	192	24
PLANNED	5/27/2021	10	240	24
PLANNED	5/27/2021	10	240	24
PLANNED	5/27/2021	7	7	1
PLANNED	5/27/2021	8	200	25
PLANNED	5/27/2021	1	153	153
PLANNED	5/27/2021	1	16	16
PLANNED	5/27/2021	12	72	6
PLANNED	5/27/2021	6	96	16
PLANNED	5/27/2021	2	62	31
PLANNED	5/27/2021	4	112	28
PLANNED	5/27/2021	3	21	7
PLANNED	5/27/2021	2	14	7
PLANNED	5/27/2021	2	30	15
PLANNED	5/27/2021	1	2	2
PLANNED	5/27/2021	10	130	13
PLANNED	5/27/2021	1	71	71
PLANNED	5/27/2021	3	147	49
PLANNED	5/27/2021	1	6	6
PLANNED	5/27/2021	7	1,435	205
PLANNED	5/27/2021	5	590	118
PLANNED	5/27/2021	5	145	29
PLANNED	5/27/2021	10	650	65
CUSTOMER REQUEST	5/27/2021	1	114	114
CUSTOMER REQUEST	5/27/2021	17	153	9
PLANNED	5/27/2021	6	102	17
PLANNED	5/27/2021	1	61	61
PLANNED	5/27/2021	14	70	5
PLANNED	5/27/2021	2	48	24
PLANNED	5/27/2021	4	200	50
PLANNED	5/27/2021	1	24	24
PLANNED	5/27/2021	5	180	36
PLANNED	5/27/2021	4	40	10
CUSTOMER REQUEST	5/27/2021	11	891	81
PLANNED	5/27/2021	1	40	40
PLANNED	5/27/2021	2	152	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/27/2021	13	1,846	142
PLANNED	5/27/2021	3	90	30
PLANNED	5/27/2021	5	455	91
CUSTOMER REQUEST	5/27/2021	1,464	24,888	17
PLANNED	5/27/2021	1	153	153
PLANNED	5/27/2021	7	301	43
PLANNED	5/27/2021	1	88	88
PLANNED	5/27/2021	2	66	33
PLANNED	5/27/2021	1	213	213
PLANNED	5/27/2021	3	36	12
PLANNED	5/27/2021	1	319	319
PLANNED	5/27/2021	18	2,880	160
PLANNED	5/27/2021	7	364	52
PLANNED	5/28/2021	6	630	105
PLANNED	5/28/2021	3	159	53
PLANNED	5/28/2021	10	940	94
PLANNED	5/28/2021	2	16	8
PLANNED	5/28/2021	2	178	89
PLANNED	5/28/2021	4	328	82
PLANNED	5/28/2021	2	242	121
PLANNED	5/28/2021	5	355	71
PLANNED	5/28/2021	4	153	45
PLANNED	5/28/2021	1	6	6
PLANNED	5/28/2021	4	100	25
PLANNED	5/28/2021	3	132	44
PLANNED	5/28/2021	1	6	6
PLANNED	5/28/2021	7	812	116
PLANNED	5/28/2021	2	335	168
PLANNED	5/28/2021	4	116	29
PLANNED	5/28/2021	1	6	6
PLANNED	5/28/2021	5	370	74
PLANNED	5/28/2021	1	146	146
PLANNED	5/28/2021	1	5	5
PLANNED	5/28/2021	8	144	18
PLANNED	5/28/2021	5	45	9
PLANNED	5/28/2021	28	352	190
PLANNED	5/28/2021	2	18	9
PLANNED	5/28/2021	3	27	9
CUSTOMER REQUEST	5/28/2021	10	2,700	270
PLANNED	5/28/2021	2	738	369
PLANNED	5/28/2021	2	78	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/28/2021	4	36	9
PLANNED	5/28/2021	1	28	28
PLANNED	5/28/2021	7	133	19
CUSTOMER REQUEST	5/28/2021	23	5,244	228
PLANNED	5/28/2021	2	18	9
PLANNED	5/28/2021	1	178	178
PLANNED	5/28/2021	2	140	70
PLANNED	5/28/2021	3	267	89
PLANNED	5/28/2021	3	21	7
PLANNED	5/28/2021	2	52	26
PLANNED	5/28/2021	2	14	7
PLANNED	5/28/2021	4	175	68
PLANNED	5/28/2021	9	594	188
PLANNED	5/28/2021	4	180	45
PLANNED	5/28/2021	1	28	28
PLANNED	5/28/2021	2	38	19
PLANNED	5/28/2021	5	350	70
PLANNED	5/28/2021	4	40	10
PLANNED	5/28/2021	4	84	21
PLANNED	5/28/2021	1	9	9
PLANNED	5/28/2021	2	216	108
PLANNED	5/28/2021	4	276	69
PLANNED	5/28/2021	10	1,250	125
PLANNED	5/28/2021	5	30	6
PLANNED	5/28/2021	1	160	160
PLANNED	5/28/2021	7	504	72
PLANNED	5/28/2021	6	606	101
PLANNED	5/28/2021	2	4	2
PLANNED	5/28/2021	3	66	22
PLANNED	5/28/2021	1	64	64
CUSTOMER REQUEST	5/28/2021	1	72	72
PLANNED	5/28/2021	1	228	228
PLANNED	5/28/2021	1	2	2
PLANNED	5/28/2021	2	58	29
PLANNED	5/28/2021	2	134	67
PLANNED	5/28/2021	4	144	36
PLANNED	5/28/2021	1	10	10
PLANNED	5/28/2021	4	48	12
PLANNED	5/28/2021	2	44	22
PLANNED	5/28/2021	1	175	175
PLANNED	5/28/2021	5	25	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/28/2021	4	236	59
PLANNED	5/28/2021	5	115	23
PLANNED	5/28/2021	3	90	30
PLANNED	5/28/2021	4	200	50
PLANNED	5/28/2021	1	15	15
PLANNED	5/28/2021	4	52	13
PLANNED	5/28/2021	8	176	22
PLANNED	5/28/2021	1	65	65
PLANNED	5/28/2021	4	184	46
PLANNED	5/28/2021	6	72	12
PLANNED	5/28/2021	1	29	29
PLANNED	5/28/2021	19	1,615	85
PLANNED	5/28/2021	1	24	24
PLANNED	5/28/2021	1	28	28
PLANNED	5/28/2021	2	48	24
PLANNED	5/28/2021	5	45	9
PLANNED	5/28/2021	9	225	25
PLANNED	5/28/2021	5	50	10
PLANNED	5/28/2021	3	39	13
PLANNED	5/28/2021	6	72	12
PLANNED	5/28/2021	8	792	99
PLANNED	5/28/2021	10	960	96
PLANNED	5/28/2021	5	110	22
PLANNED	5/28/2021	2	290	145
CUSTOMER REQUEST	5/28/2021	1	418	418
CUSTOMER REQUEST	5/28/2021	1	336	336
PLANNED	5/28/2021	3	87	29
PLANNED	5/28/2021	9	540	60
PLANNED	5/28/2021	7	28	4
PLANNED	5/28/2021	4	340	85
PLANNED	5/28/2021	5	100	20
PLANNED	5/28/2021	2	82	41
PLANNED	5/28/2021	3	108	36
PLANNED	5/28/2021	2	90	45
CUSTOMER REQUEST	5/28/2021	1	480	480
CUSTOMER REQUEST	5/28/2021	1	204	204
PLANNED	5/28/2021	1	29	29
PLANNED	5/28/2021	1	15	15
PLANNED	5/28/2021	7	42	6
CUSTOMER REQUEST	5/28/2021	1	71	71
PLANNED	5/29/2021	3	186	62

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/29/2021	4	508	127
CUSTOMER REQUEST	5/29/2021	6	1,566	261
PLANNED	5/29/2021	26	3,120	120
PLANNED	5/29/2021	4	272	68
PLANNED	5/29/2021	8	920	115
PLANNED	5/29/2021	1	220	220
PLANNED	5/29/2021	1	63	63
PLANNED	5/29/2021	3	684	228
PLANNED	5/29/2021	6	18	3
PLANNED	5/29/2021	45	3,150	70
PLANNED	5/29/2021	3	318	106
PLANNED	5/29/2021	5	1,215	243
PLANNED	5/29/2021	26	8,060	310
PLANNED	5/29/2021	1	51	51
PLANNED	5/29/2021	4	324	81
CUSTOMER REQUEST	5/29/2021	1	276	276
PLANNED	5/29/2021	7	623	89
PLANNED	5/29/2021	1	51	51
PLANNED	5/29/2021	2	148	74
PLANNED	5/29/2021	2	64	32
PLANNED	5/29/2021	24	168	7
PLANNED	5/29/2021	4	284	71
PLANNED	5/29/2021	7	203	29
PLANNED	5/29/2021	2	120	60
CUSTOMER REQUEST	5/29/2021	1	158	158
PLANNED	5/29/2021	6	396	66
PLANNED	5/29/2021	7	14	2
PLANNED	5/29/2021	1	92	92
PLANNED	5/29/2021	4	32	8
PLANNED	5/29/2021	77	10,241	133
PLANNED	5/30/2021	2	354	177
PLANNED	5/30/2021	1	47	47
PLANNED	5/30/2021	2	192	96
PLANNED	5/30/2021	2	158	79
PLANNED	5/30/2021	3	201	67
PLANNED	5/30/2021	2	240	120
PLANNED	5/30/2021	8	1,000	125
PLANNED	5/30/2021	1	49	49
PLANNED	5/30/2021	5	160	32
PLANNED	5/30/2021	1	48	48
PLANNED	5/30/2021	4	808	202

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	5/30/2021	3	222	74
PLANNED	5/30/2021	4	216	54
PLANNED	5/30/2021	1	80	80
PLANNED	5/30/2021	6	186	31
PLANNED	5/30/2021	1	69	69
CUSTOMER REQUEST	5/30/2021	69	25,530	370
PLANNED	5/30/2021	4	72	18
PLANNED	5/30/2021	2	26	14
PLANNED	5/30/2021	5	195	39
PLANNED	5/31/2021	1	27	27
PLANNED	5/31/2021	5	920	184
PLANNED	5/31/2021	36	4,320	120
PLANNED	5/31/2021	8	200	25
PLANNED	5/31/2021	12	147	31
CUSTOMER REQUEST	5/31/2021	1	102	102
CUSTOMER REQUEST	5/31/2021	23	529	23
PLANNED	6/1/2021	8	664	83
PLANNED	6/1/2021	2	58	29
PLANNED	6/1/2021	6	180	30
PLANNED	6/1/2021	2	278	139
PLANNED	6/1/2021	2	2	1
PLANNED	6/1/2021	4	80	20
PLANNED	6/1/2021	1	90	90
PLANNED	6/1/2021	2	124	62
PLANNED	6/1/2021	2	38	19
PLANNED	6/1/2021	2	86	55
PLANNED	6/1/2021	2	296	148
PLANNED	6/1/2021	11	330	30
PLANNED	6/1/2021	1	72	72
PLANNED	6/1/2021	1	39	39
PLANNED	6/1/2021	1	23	23
PLANNED	6/1/2021	3	303	101
PLANNED	6/1/2021	11	2,233	203
PLANNED	6/1/2021	3	48	16
PLANNED	6/1/2021	8	104	13
PLANNED	6/1/2021	1	202	202
PLANNED	6/1/2021	1	510	510
PLANNED	6/1/2021	1	2	2
PLANNED	6/1/2021	2	158	79
PLANNED	6/1/2021	6	36	6
PLANNED	6/1/2021	1	25	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/1/2021	8	944	118
PLANNED	6/1/2021	1	17	17
PLANNED	6/1/2021	10	100	10
PLANNED	6/1/2021	6	54	9
PLANNED	6/1/2021	2	30	15
PLANNED	6/1/2021	5	85	17
PLANNED	6/1/2021	4	112	28
PLANNED	6/1/2021	25	4,450	178
PLANNED	6/1/2021	1	22	22
PLANNED	6/1/2021	1	24	24
PLANNED	6/1/2021	2	60	30
PLANNED	6/1/2021	1	115	115
PLANNED	6/1/2021	3	261	87
PLANNED	6/1/2021	2	128	64
PLANNED	6/1/2021	1	6	6
PLANNED	6/1/2021	14	1,316	94
PLANNED	6/1/2021	13	1,365	105
PLANNED	6/1/2021	1	74	74
PLANNED	6/1/2021	3	240	80
PLANNED	6/1/2021	9	783	87
PLANNED	6/1/2021	8	696	87
PLANNED	6/1/2021	13	1,287	99
PLANNED	6/1/2021	1	17	17
PLANNED	6/1/2021	1	9	9
PLANNED	6/1/2021	4	204	51
PLANNED	6/1/2021	2	311	159
PLANNED	6/1/2021	32	2,720	85
PLANNED	6/1/2021	9	1,413	157
PLANNED	6/1/2021	14	1,260	90
PLANNED	6/1/2021	2	14	7
PLANNED	6/1/2021	1	26	26
PLANNED	6/1/2021	1	75	75
PLANNED	6/1/2021	1	19	19
PLANNED	6/1/2021	7	77	11
CUSTOMER REQUEST	6/1/2021	1	204	204
PLANNED	6/1/2021	6	744	124
PLANNED	6/1/2021	3	84	28
PLANNED	6/1/2021	1	12	12
PLANNED	6/1/2021	1	11	11
PLANNED	6/1/2021	3	471	157
PLANNED	6/1/2021	5	100	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/1/2021	1	52	52
PLANNED	6/1/2021	11	55	5
PLANNED	6/1/2021	2	68	34
PLANNED	6/1/2021	2	22	11
PLANNED	6/1/2021	6	120	20
PLANNED	6/1/2021	6	516	86
PLANNED	6/1/2021	8	104	13
PLANNED	6/1/2021	2	158	79
PLANNED	6/1/2021	10	680	68
PLANNED	6/1/2021	3	255	85
PLANNED	6/1/2021	2	224	112
PLANNED	6/1/2021	2	30	15
PLANNED	6/1/2021	2	44	22
PLANNED	6/1/2021	8	32	4
PLANNED	6/1/2021	10	1,546	172
PLANNED	6/1/2021	12	12	1
PLANNED	6/1/2021	11	594	54
PLANNED	6/1/2021	6	642	107
PLANNED	6/1/2021	1	66	66
PLANNED	6/1/2021	4	200	50
PLANNED	6/1/2021	3	144	48
PLANNED	6/1/2021	2	36	18
PLANNED	6/1/2021	1	12	12
PLANNED	6/1/2021	2	28	14
PLANNED	6/1/2021	1	249	249
PLANNED	6/1/2021	1	48	48
PLANNED	6/1/2021	4	8	2
PLANNED	6/1/2021	3	123	41
CUSTOMER REQUEST	6/1/2021	1	25	25
PLANNED	6/1/2021	3	123	41
PLANNED	6/1/2021	2	122	61
PLANNED	6/1/2021	1	7	7
PLANNED	6/1/2021	2	88	44
PLANNED	6/1/2021	18	756	42
PLANNED	6/1/2021	11	319	29
PLANNED	6/1/2021	3	60	20
PLANNED	6/1/2021	2	634	317
PLANNED	6/1/2021	2	279	159
PLANNED	6/1/2021	2	14	7
PLANNED	6/1/2021	13	624	48
PLANNED	6/1/2021	13	780	60

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/1/2021	1	7	7
PLANNED	6/1/2021	1	7	7
PLANNED	6/1/2021	2	28	14
PLANNED	6/1/2021	3	30	10
PLANNED	6/1/2021	5	40	8
PLANNED	6/1/2021	2	14	7
PLANNED	6/1/2021	3	213	71
PLANNED	6/1/2021	1	8	8
PLANNED	6/1/2021	3	70	44
PLANNED	6/1/2021	8	616	77
PLANNED	6/1/2021	1	12	12
PLANNED	6/1/2021	4	276	69
PLANNED	6/1/2021	3	123	41
PLANNED	6/1/2021	1	8	8
PLANNED	6/1/2021	6	582	97
PLANNED	6/1/2021	1	20	20
PLANNED	6/1/2021	7	49	7
PLANNED	6/1/2021	4	24	6
PLANNED	6/1/2021	4	164	41
PLANNED	6/1/2021	4	32	8
PLANNED	6/1/2021	3	132	44
PLANNED	6/1/2021	1	13	13
PLANNED	6/1/2021	4	60	15
PLANNED	6/1/2021	1	88	88
PLANNED	6/1/2021	2	16	8
PLANNED	6/1/2021	7	1,533	219
PLANNED	6/1/2021	3	42	14
PLANNED	6/1/2021	3	33	11
PLANNED	6/1/2021	7	140	20
PLANNED	6/1/2021	1	15	15
PLANNED	6/1/2021	3	30	10
PLANNED	6/1/2021	6	180	30
PLANNED	6/1/2021	1	7	7
PLANNED	6/1/2021	2	8	4
PLANNED	6/1/2021	2	260	130
PLANNED	6/1/2021	1	19	19
PLANNED	6/1/2021	4	36	9
PLANNED	6/1/2021	4	60	15
PLANNED	6/1/2021	7	252	36
PLANNED	6/1/2021	3	120	40
PLANNED	6/1/2021	1	125	125

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/1/2021	11	143	13
PLANNED	6/1/2021	1	13	13
PLANNED	6/1/2021	3	343	133
PLANNED	6/1/2021	2	212	106
PLANNED	6/1/2021	1	123	123
PLANNED	6/1/2021	1	7	7
PLANNED	6/1/2021	6	180	30
PLANNED	6/1/2021	2	64	32
PLANNED	6/1/2021	23	2,093	91
PLANNED	6/1/2021	2	34	17
PLANNED	6/1/2021	2	277	196
PLANNED	6/1/2021	7	126	18
PLANNED	6/1/2021	1	6	6
PLANNED	6/1/2021	3	84	28
PLANNED	6/1/2021	6	852	142
PLANNED	6/1/2021	2	162	81
PLANNED	6/1/2021	1	109	109
PLANNED	6/1/2021	10	1,940	194
PLANNED	6/1/2021	8	368	46
PLANNED	6/1/2021	10	1,410	141
PLANNED	6/1/2021	7	259	37
PLANNED	6/1/2021	4	280	70
PLANNED	6/1/2021	2	24	12
PLANNED	6/1/2021	4	76	19
PLANNED	6/1/2021	1	74	74
PLANNED	6/1/2021	3	195	91
PLANNED	6/1/2021	3	312	104
PLANNED	6/1/2021	2	38	19
PLANNED	6/1/2021	1	5	5
PLANNED	6/1/2021	5	195	39
PLANNED	6/1/2021	2	84	42
PLANNED	6/1/2021	3	366	203
PLANNED	6/1/2021	3	126	42
PLANNED	6/1/2021	3	78	26
PLANNED	6/1/2021	1	48	48
PLANNED	6/1/2021	1	34	34
PLANNED	6/1/2021	1	18	18
PLANNED	6/1/2021	5	85	17
PLANNED	6/1/2021	11	1,441	131
PLANNED	6/1/2021	1	91	91
PLANNED	6/1/2021	2	80	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	6/1/2021	4	24	6
PLANNED	6/1/2021	1	16	16
PLANNED	6/1/2021	1	8	8
PLANNED	6/1/2021	1	29	29
CUSTOMER REQUEST	6/1/2021	1	63	63
PLANNED	6/1/2021	3	135	45
PLANNED	6/1/2021	3	63	21
PLANNED	6/1/2021	2	40	20
PLANNED	6/1/2021	6	78	13
PLANNED	6/1/2021	2	46	23
PLANNED	6/1/2021	5	590	118
PLANNED	6/1/2021	2	54	27
PLANNED	6/1/2021	3	345	115
PLANNED	6/1/2021	3	45	15
PLANNED	6/1/2021	2	18	9
PLANNED	6/1/2021	1	117	117
PLANNED	6/1/2021	7	175	25
PLANNED	6/1/2021	1	8	8
PLANNED	6/1/2021	4	116	29
PLANNED	6/1/2021	4	92	23
CUSTOMER REQUEST	6/1/2021	1	140	140
PLANNED	6/1/2021	13	1,170	90
PLANNED	6/1/2021	15	1,095	73
PLANNED	6/1/2021	1	80	80
PLANNED	6/1/2021	2	280	140
PLANNED	6/1/2021	2	106	53
PLANNED	6/1/2021	10	1,600	160
PLANNED	6/2/2021	6	576	96
PLANNED	6/2/2021	1	218	218
PLANNED	6/2/2021	5	1,205	241
PLANNED	6/2/2021	1	42	42
PLANNED	6/2/2021	41	7,011	171
PLANNED	6/2/2021	9	720	80
PLANNED	6/2/2021	1	147	147
PLANNED	6/2/2021	1	28	28
PLANNED	6/2/2021	10	190	19
PLANNED	6/2/2021	5	585	117
PLANNED	6/2/2021	1	274	274
PLANNED	6/2/2021	3	96	32
PLANNED	6/2/2021	3	24	8
PLANNED	6/2/2021	3	27	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	4	56	14
PLANNED	6/2/2021	4	68	17
PLANNED	6/2/2021	4	80	20
PLANNED	6/2/2021	1	89	89
PLANNED	6/2/2021	13	1,261	97
PLANNED	6/2/2021	3	321	107
PLANNED	6/2/2021	3	174	58
PLANNED	6/2/2021	4	588	147
PLANNED	6/2/2021	1	137	137
PLANNED	6/2/2021	1	174	174
PLANNED	6/2/2021	3	27	9
PLANNED	6/2/2021	1	11	11
PLANNED	6/2/2021	2	210	105
PLANNED	6/2/2021	1	89	89
PLANNED	6/2/2021	4	32	8
PLANNED	6/2/2021	8	112	14
PLANNED	6/2/2021	4	144	36
PLANNED	6/2/2021	3	63	21
PLANNED	6/2/2021	1	29	29
PLANNED	6/2/2021	3	51	17
PLANNED	6/2/2021	1	9	9
PLANNED	6/2/2021	4	370	114
PLANNED	6/2/2021	2	330	165
PLANNED	6/2/2021	1	6	6
PLANNED	6/2/2021	9	667	113
PLANNED	6/2/2021	2	32	16
PLANNED	6/2/2021	2	22	11
PLANNED	6/2/2021	6	504	84
PLANNED	6/2/2021	1	62	62
PLANNED	6/2/2021	2	16	8
PLANNED	6/2/2021	2	178	89
PLANNED	6/2/2021	5	105	21
PLANNED	6/2/2021	8	352	44
PLANNED	6/2/2021	9	117	13
PLANNED	6/2/2021	2	238	119
PLANNED	6/2/2021	2	204	102
PLANNED	6/2/2021	8	448	56
PLANNED	6/2/2021	2	368	184
PLANNED	6/2/2021	2	228	114
PLANNED	6/2/2021	1	10	10
PLANNED	6/2/2021	2	95	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	1	117	117
PLANNED	6/2/2021	1	8	8
PLANNED	6/2/2021	1	86	86
PLANNED	6/2/2021	4	148	37
PLANNED	6/2/2021	2	70	35
PLANNED	6/2/2021	2	32	16
PLANNED	6/2/2021	29	5,307	183
PLANNED	6/2/2021	1	6	6
PLANNED	6/2/2021	9	522	58
PLANNED	6/2/2021	8	2,280	285
PLANNED	6/2/2021	2	180	91
PLANNED	6/2/2021	5	65	13
PLANNED	6/2/2021	2	38	19
PLANNED	6/2/2021	1	88	88
PLANNED	6/2/2021	2	49	28
PLANNED	6/2/2021	3	45	15
PLANNED	6/2/2021	3	63	21
PLANNED	6/2/2021	2	28	14
PLANNED	6/2/2021	1	8	8
PLANNED	6/2/2021	10	490	49
PLANNED	6/2/2021	10	414	87
PLANNED	6/2/2021	2	102	51
PLANNED	6/2/2021	6	450	115
PLANNED	6/2/2021	8	168	21
PLANNED	6/2/2021	2	32	16
PLANNED	6/2/2021	5	85	17
PLANNED	6/2/2021	9	162	18
PLANNED	6/2/2021	36	5,112	142
PLANNED	6/2/2021	1	133	133
PLANNED	6/2/2021	2	264	132
PLANNED	6/2/2021	2	18	9
PLANNED	6/2/2021	8	640	80
CUSTOMER REQUEST	6/2/2021	5	550	110
PLANNED	6/2/2021	12	84	7
PLANNED	6/2/2021	2	949	478
PLANNED	6/2/2021	9	1,377	153
PLANNED	6/2/2021	45	8,010	178
PLANNED	6/2/2021	32	5,280	165
PLANNED	6/2/2021	4	36	9
PLANNED	6/2/2021	8	384	48
PLANNED	6/2/2021	26	312	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	3	459	153
PLANNED	6/2/2021	4	416	104
PLANNED	6/2/2021	4	40	10
PLANNED	6/2/2021	4	536	134
PLANNED	6/2/2021	36	972	27
PLANNED	6/2/2021	8	609	78
PLANNED	6/2/2021	41	246	6
PLANNED	6/2/2021	7	175	25
PLANNED	6/2/2021	1	5	5
PLANNED	6/2/2021	4	780	195
PLANNED	6/2/2021	14	1,148	82
PLANNED	6/2/2021	1	26	26
PLANNED	6/2/2021	9	198	22
PLANNED	6/2/2021	6	988	293
PLANNED	6/2/2021	17	119	7
PLANNED	6/2/2021	4	76	19
PLANNED	6/2/2021	3	36	12
PLANNED	6/2/2021	2	72	36
PLANNED	6/2/2021	6	66	11
PLANNED	6/2/2021	7	987	141
PLANNED	6/2/2021	1	14	14
PLANNED	6/2/2021	6	1,008	168
PLANNED	6/2/2021	1	121	121
PLANNED	6/2/2021	1	37	37
PLANNED	6/2/2021	2	162	81
PLANNED	6/2/2021	10	120	12
PLANNED	6/2/2021	6	180	30
PLANNED	6/2/2021	3	3	1
PLANNED	6/2/2021	4	148	37
PLANNED	6/2/2021	3	18	6
PLANNED	6/2/2021	2	18	9
PLANNED	6/2/2021	1	14	14
PLANNED	6/2/2021	2	114	57
PLANNED	6/2/2021	6	48	8
CUSTOMER REQUEST	6/2/2021	12	216	18
PLANNED	6/2/2021	1	304	304
PLANNED	6/2/2021	1	304	304
PLANNED	6/2/2021	5	40	8
PLANNED	6/2/2021	1	40	40
PLANNED	6/2/2021	11	1,782	162
PLANNED	6/2/2021	14	728	52

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	2	64	32
PLANNED	6/2/2021	2	14	7
CUSTOMER REQUEST	6/2/2021	1	92	92
PLANNED	6/2/2021	2	54	27
PLANNED	6/2/2021	1	14	14
PLANNED	6/2/2021	4	24	6
PLANNED	6/2/2021	1	103	103
PLANNED	6/2/2021	2	176	88
PLANNED	6/2/2021	11	242	22
PLANNED	6/2/2021	11	253	23
PLANNED	6/2/2021	2	330	165
PLANNED	6/2/2021	12	264	22
PLANNED	6/2/2021	4	84	21
PLANNED	6/2/2021	4	28	7
PLANNED	6/2/2021	1	8	8
PLANNED	6/2/2021	4	100	25
PLANNED	6/2/2021	5	70	14
PLANNED	6/2/2021	2	12	6
PLANNED	6/2/2021	4	88	22
PLANNED	6/2/2021	4	684	171
PLANNED	6/2/2021	6	48	8
PLANNED	6/2/2021	3	615	205
PLANNED	6/2/2021	7	105	15
PLANNED	6/2/2021	6	246	41
PLANNED	6/2/2021	2	16	8
PLANNED	6/2/2021	1	10	10
PLANNED	6/2/2021	2	18	9
PLANNED	6/2/2021	4	44	11
PLANNED	6/2/2021	2	130	65
PLANNED	6/2/2021	1	17	17
PLANNED	6/2/2021	17	1,275	75
PLANNED	6/2/2021	3	54	18
PLANNED	6/2/2021	9	486	54
PLANNED	6/2/2021	9	639	71
PLANNED	6/2/2021	2	16	8
PLANNED	6/2/2021	2	26	13
PLANNED	6/2/2021	4	188	47
PLANNED	6/2/2021	1	9	9
PLANNED	6/2/2021	4	684	171
PLANNED	6/2/2021	8	368	46
PLANNED	6/2/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	3	21	7
PLANNED	6/2/2021	4	32	8
PLANNED	6/2/2021	4	44	11
PLANNED	6/2/2021	4	56	14
PLANNED	6/2/2021	20	320	16
PLANNED	6/2/2021	4	28	7
PLANNED	6/2/2021	2	138	69
PLANNED	6/2/2021	2	78	39
PLANNED	6/2/2021	1	9	9
PLANNED	6/2/2021	4	388	97
PLANNED	6/2/2021	1	4	4
PLANNED	6/2/2021	2	56	28
PLANNED	6/2/2021	4	100	25
PLANNED	6/2/2021	8	528	66
PLANNED	6/2/2021	3	102	34
PLANNED	6/2/2021	2	24	12
PLANNED	6/2/2021	4	40	10
PLANNED	6/2/2021	1	9	9
PLANNED	6/2/2021	12	420	35
PLANNED	6/2/2021	11	341	31
PLANNED	6/2/2021	11	363	33
PLANNED	6/2/2021	1	1	1
PLANNED	6/2/2021	2	54	27
PLANNED	6/2/2021	2	20	10
PLANNED	6/2/2021	6	66	11
PLANNED	6/2/2021	1	65	65
PLANNED	6/2/2021	4	200	50
PLANNED	6/2/2021	6	66	11
PLANNED	6/2/2021	33	1,518	46
PLANNED	6/2/2021	4	168	42
PLANNED	6/2/2021	2	188	94
PLANNED	6/2/2021	1	10	10
PLANNED	6/2/2021	5	50	10
PLANNED	6/2/2021	4	140	35
PLANNED	6/2/2021	31	4,929	159
PLANNED	6/2/2021	3	36	12
PLANNED	6/2/2021	1	58	58
PLANNED	6/2/2021	2	308	154
PLANNED	6/2/2021	3	54	18
PLANNED	6/2/2021	3	222	74
PLANNED	6/2/2021	2	74	37

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	4	36	9
PLANNED	6/2/2021	6	72	12
PLANNED	6/2/2021	10	1,200	120
PLANNED	6/2/2021	6	504	84
PLANNED	6/2/2021	1	69	69
PLANNED	6/2/2021	16	768	48
PLANNED	6/2/2021	1	7	7
PLANNED	6/2/2021	2	8	4
PLANNED	6/2/2021	4	332	83
PLANNED	6/2/2021	4	104	26
PLANNED	6/2/2021	2	18	9
PLANNED	6/2/2021	1	13	13
PLANNED	6/2/2021	2	56	28
PLANNED	6/2/2021	12	180	15
PLANNED	6/2/2021	8	120	15
PLANNED	6/2/2021	1	6	6
PLANNED	6/2/2021	4	40	10
PLANNED	6/2/2021	3	27	9
PLANNED	6/2/2021	3	36	12
PLANNED	6/2/2021	1	13	13
PLANNED	6/2/2021	4	24	6
PLANNED	6/2/2021	2	292	146
PLANNED	6/2/2021	1	10	10
PLANNED	6/2/2021	3	42	14
PLANNED	6/2/2021	12	132	11
PLANNED	6/2/2021	2	10	5
PLANNED	6/2/2021	2	134	67
PLANNED	6/2/2021	4	68	17
PLANNED	6/2/2021	1	126	126
PLANNED	6/2/2021	1	19	19
PLANNED	6/2/2021	1	154	154
PLANNED	6/2/2021	3	90	30
PLANNED	6/2/2021	4	132	33
PLANNED	6/2/2021	1	59	59
PLANNED	6/2/2021	1	450	450
PLANNED	6/2/2021	1	23	23
PLANNED	6/2/2021	3	84	28
PLANNED	6/2/2021	9	81	9
PLANNED	6/2/2021	1	92	92
PLANNED	6/2/2021	2	146	73
PLANNED	6/2/2021	2	112	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/2/2021	2	164	82
PLANNED	6/2/2021	4	44	11
PLANNED	6/2/2021	5	65	13
PLANNED	6/2/2021	2	40	20
PLANNED	6/2/2021	3	66	22
CUSTOMER REQUEST	6/2/2021	1	154	154
PLANNED	6/2/2021	1	36	36
PLANNED	6/2/2021	36	108	3
PLANNED	6/2/2021	41	82	2
PLANNED	6/2/2021	1	44	44
CUSTOMER REQUEST	6/2/2021	1	84	84
PLANNED	6/2/2021	1	17	17
PLANNED	6/2/2021	4	636	159
CUSTOMER REQUEST	6/2/2021	8	384	48
PLANNED	6/2/2021	1	146	146
PLANNED	6/2/2021	1	120	120
PLANNED	6/2/2021	14	518	37
PLANNED	6/2/2021	12	432	36
CUSTOMER REQUEST	6/2/2021	2	46	23
PLANNED	6/2/2021	18	3,294	183
PLANNED	6/2/2021	1	88	88
PLANNED	6/3/2021	2	428	214
PLANNED	6/3/2021	2	192	96
PLANNED	6/3/2021	1	14	14
PLANNED	6/3/2021	1	111	111
PLANNED	6/3/2021	5	241	61
PLANNED	6/3/2021	4	148	37
PLANNED	6/3/2021	2	466	233
PLANNED	6/3/2021	1	11	11
PLANNED	6/3/2021	11	396	36
PLANNED	6/3/2021	8	224	28
PLANNED	6/3/2021	1	10	10
PLANNED	6/3/2021	5	495	99
PLANNED	6/3/2021	2	20	10
PLANNED	6/3/2021	2	66	33
PLANNED	6/3/2021	7	1,981	283
PLANNED	6/3/2021	2	130	65
PLANNED	6/3/2021	11	1,925	175
PLANNED	6/3/2021	5	140	28
PLANNED	6/3/2021	7	658	94
PLANNED	6/3/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	2	32	16
PLANNED	6/3/2021	11	1,122	102
PLANNED	6/3/2021	1	61	61
PLANNED	6/3/2021	8	1,016	127
PLANNED	6/3/2021	4	64	16
PLANNED	6/3/2021	2	16	8
PLANNED	6/3/2021	1	155	155
PLANNED	6/3/2021	4	396	127
PLANNED	6/3/2021	2	14	7
PLANNED	6/3/2021	7	399	57
PLANNED	6/3/2021	4	84	21
PLANNED	6/3/2021	1	6	6
PLANNED	6/3/2021	4	100	25
CUSTOMER REQUEST	6/3/2021	1	206	206
PLANNED	6/3/2021	1	7	7
PLANNED	6/3/2021	4	716	217
PLANNED	6/3/2021	1	59	59
PLANNED	6/3/2021	8	448	56
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	2	340	170
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	7	84	12
PLANNED	6/3/2021	2	160	80
PLANNED	6/3/2021	1	31	31
PLANNED	6/3/2021	10	520	52
PLANNED	6/3/2021	2	172	86
PLANNED	6/3/2021	1	6	6
PLANNED	6/3/2021	9	504	56
PLANNED	6/3/2021	10	530	53
PLANNED	6/3/2021	17	2,499	147
PLANNED	6/3/2021	3	24	8
PLANNED	6/3/2021	6	846	141
PLANNED	6/3/2021	1	46	46
PLANNED	6/3/2021	4	160	40
PLANNED	6/3/2021	10	180	18
PLANNED	6/3/2021	6	976	206
PLANNED	6/3/2021	4	112	28
PLANNED	6/3/2021	7	1,386	198
PLANNED	6/3/2021	12	1,548	129
PLANNED	6/3/2021	2	422	211
PLANNED	6/3/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	39	3,042	78
PLANNED	6/3/2021	1	56	56
PLANNED	6/3/2021	1	13	13
PLANNED	6/3/2021	2	402	201
PLANNED	6/3/2021	2	444	222
PLANNED	6/3/2021	2	10	5
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	2	222	111
PLANNED	6/3/2021	3	33	11
PLANNED	6/3/2021	1	105	105
PLANNED	6/3/2021	5	135	27
PLANNED	6/3/2021	1	141	141
PLANNED	6/3/2021	8	208	26
PLANNED	6/3/2021	32	4,480	140
PLANNED	6/3/2021	4	160	40
PLANNED	6/3/2021	5	120	24
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	2	14	7
CUSTOMER REQUEST	6/3/2021	5	310	282
PLANNED	6/3/2021	1	54	54
PLANNED	6/3/2021	5	60	12
PLANNED	6/3/2021	3	81	27
CUSTOMER REQUEST	6/3/2021	4	424	106
PLANNED	6/3/2021	6	132	22
PLANNED	6/3/2021	1	70	70
PLANNED	6/3/2021	1	616	616
PLANNED	6/3/2021	1	16	16
PLANNED	6/3/2021	1	103	103
PLANNED	6/3/2021	5	175	35
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	4	112	28
PLANNED	6/3/2021	9	855	95
PLANNED	6/3/2021	8	1,640	205
PLANNED	6/3/2021	2	268	134
CUSTOMER REQUEST	6/3/2021	4	1,040	260
PLANNED	6/3/2021	15	2,940	196
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	12	912	76
PLANNED	6/3/2021	3	51	17
PLANNED	6/3/2021	4	72	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	6	78	13
PLANNED	6/3/2021	4	116	29
PLANNED	6/3/2021	9	252	28
PLANNED	6/3/2021	2	70	35
PLANNED	6/3/2021	6	174	29
PLANNED	6/3/2021	4	425	107
PLANNED	6/3/2021	2	30	15
PLANNED	6/3/2021	3	48	16
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	6	210	35
PLANNED	6/3/2021	9	207	23
PLANNED	6/3/2021	1	9	9
PLANNED	6/3/2021	15	3,030	202
PLANNED	6/3/2021	9	603	67
PLANNED	6/3/2021	3	24	8
PLANNED	6/3/2021	12	1,200	100
PLANNED	6/3/2021	2	120	60
PLANNED	6/3/2021	2	22	11
PLANNED	6/3/2021	9	495	55
PLANNED	6/3/2021	6	300	50
CUSTOMER REQUEST	6/3/2021	2	42	21
PLANNED	6/3/2021	3	567	189
PLANNED	6/3/2021	4	32	8
PLANNED	6/3/2021	1	10	10
PLANNED	6/3/2021	1	29	29
PLANNED	6/3/2021	3	15	5
PLANNED	6/3/2021	3	42	14
PLANNED	6/3/2021	4	64	16
PLANNED	6/3/2021	2	216	108
PLANNED	6/3/2021	40	3,120	78
PLANNED	6/3/2021	2	126	63
PLANNED	6/3/2021	4	92	23
PLANNED	6/3/2021	1	81	81
PLANNED	6/3/2021	1	59	59
PLANNED	6/3/2021	5	35	7
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	5	180	36
PLANNED	6/3/2021	9	306	34
CUSTOMER REQUEST	6/3/2021	1	399	399
PLANNED	6/3/2021	4	40	10
PLANNED	6/3/2021	13	2,262	174

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	2	40	20
PLANNED	6/3/2021	31	1,085	35
PLANNED	6/3/2021	5	95	19
PLANNED	6/3/2021	3	24	8
PLANNED	6/3/2021	6	1,452	242
PLANNED	6/3/2021	1	5	5
PLANNED	6/3/2021	4	368	92
PLANNED	6/3/2021	7	889	127
PLANNED	6/3/2021	2	88	44
PLANNED	6/3/2021	3	21	7
PLANNED	6/3/2021	1	7	7
PLANNED	6/3/2021	2	24	12
PLANNED	6/3/2021	4	36	9
PLANNED	6/3/2021	1	5	5
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	2	130	65
PLANNED	6/3/2021	2	297	181
PLANNED	6/3/2021	3	380	154
PLANNED	6/3/2021	12	960	80
PLANNED	6/3/2021	1	67	67
PLANNED	6/3/2021	2	12	6
PLANNED	6/3/2021	7	224	32
PLANNED	6/3/2021	1	5	5
PLANNED	6/3/2021	2	30	15
PLANNED	6/3/2021	1	57	57
PLANNED	6/3/2021	2	12	6
PLANNED	6/3/2021	9	54	6
PLANNED	6/3/2021	2	148	74
PLANNED	6/3/2021	8	40	5
PLANNED	6/3/2021	2	36	18
PLANNED	6/3/2021	4	224	56
PLANNED	6/3/2021	1	105	105
PLANNED	6/3/2021	1	57	57
PLANNED	6/3/2021	1	95	95
PLANNED	6/3/2021	5	120	24
PLANNED	6/3/2021	3	126	42
PLANNED	6/3/2021	4	236	59
PLANNED	6/3/2021	2	34	17
PLANNED	6/3/2021	1	77	77
CUSTOMER REQUEST	6/3/2021	29	2,523	87
PLANNED	6/3/2021	8	532	448

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	5	455	91
PLANNED	6/3/2021	12	3,504	292
PLANNED	6/3/2021	8	96	12
PLANNED	6/3/2021	5	205	41
PLANNED	6/3/2021	6	1,110	185
PLANNED	6/3/2021	4	28	7
PLANNED	6/3/2021	7	504	72
PLANNED	6/3/2021	6	90	15
PLANNED	6/3/2021	2	34	17
PLANNED	6/3/2021	12	1,956	163
PLANNED	6/3/2021	1	8	8
PLANNED	6/3/2021	1	43	43
PLANNED	6/3/2021	4	120	30
PLANNED	6/3/2021	10	440	44
PLANNED	6/3/2021	4	552	138
PLANNED	6/3/2021	7	126	18
PLANNED	6/3/2021	2	40	20
PLANNED	6/3/2021	12	1,008	84
PLANNED	6/3/2021	3	81	27
PLANNED	6/3/2021	3	81	27
PLANNED	6/3/2021	1	53	53
PLANNED	6/3/2021	3	126	42
PLANNED	6/3/2021	1	53	53
PLANNED	6/3/2021	12	372	31
PLANNED	6/3/2021	3	42	14
PLANNED	6/3/2021	5	255	51
PLANNED	6/3/2021	5	175	35
PLANNED	6/3/2021	4	252	63
PLANNED	6/3/2021	4	44	11
PLANNED	6/3/2021	2	28	14
PLANNED	6/3/2021	3	78	26
PLANNED	6/3/2021	4	116	29
CUSTOMER REQUEST	6/3/2021	1	260	260
PLANNED	6/3/2021	5	24	8
PLANNED	6/3/2021	1	81	81
PLANNED	6/3/2021	3	135	45
PLANNED	6/3/2021	39	624	16
PLANNED	6/3/2021	2	18	9
PLANNED	6/3/2021	5	395	79
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	5	100	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/3/2021	2	10	5
PLANNED	6/3/2021	3	39	13
PLANNED	6/3/2021	2	16	8
PLANNED	6/3/2021	2	40	20
PLANNED	6/3/2021	4	24	6
PLANNED	6/3/2021	4	32	8
PLANNED	6/3/2021	4	24	6
PLANNED	6/3/2021	2	6	3
PLANNED	6/3/2021	2	12	6
PLANNED	6/3/2021	4	476	119
PLANNED	6/3/2021	4	36	9
PLANNED	6/3/2021	3	30	10
PLANNED	6/3/2021	13	2,730	210
PLANNED	6/3/2021	46	3,542	77
PLANNED	6/3/2021	1	197	197
PLANNED	6/3/2021	6	522	87
PLANNED	6/3/2021	21	3,024	144
PLANNED	6/3/2021	7	469	67
PLANNED	6/4/2021	1	61	61
PLANNED	6/4/2021	8	176	22
PLANNED	6/4/2021	10	1,510	151
PLANNED	6/4/2021	4	430	120
PLANNED	6/4/2021	7	140	20
PLANNED	6/4/2021	3	234	78
PLANNED	6/4/2021	2	22	11
PLANNED	6/4/2021	1	6	6
PLANNED	6/4/2021	3	195	65
PLANNED	6/4/2021	3	27	9
PLANNED	6/4/2021	6	84	14
PLANNED	6/4/2021	5	30	6
PLANNED	6/4/2021	2	20	10
PLANNED	6/4/2021	8	264	33
PLANNED	6/4/2021	7	231	33
PLANNED	6/4/2021	8	240	30
PLANNED	6/4/2021	5	645	129
PLANNED	6/4/2021	3	6	2
PLANNED	6/4/2021	2	230	115
PLANNED	6/4/2021	2	448	224
CUSTOMER REQUEST	6/4/2021	4	984	246
PLANNED	6/4/2021	4	24	6
PLANNED	6/4/2021	1	74	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/4/2021	5	75	15
PLANNED	6/4/2021	4	427	131
PLANNED	6/4/2021	4	244	61
PLANNED	6/4/2021	2	80	40
PLANNED	6/4/2021	3	648	216
PLANNED	6/4/2021	9	72	8
PLANNED	6/4/2021	8	544	68
PLANNED	6/4/2021	4	32	8
PLANNED	6/4/2021	5	600	120
PLANNED	6/4/2021	6	120	20
PLANNED	6/4/2021	9	1,341	149
PLANNED	6/4/2021	2	16	8
PLANNED	6/4/2021	5	45	9
PLANNED	6/4/2021	1	132	132
PLANNED	6/4/2021	4	48	12
PLANNED	6/4/2021	1	101	101
PLANNED	6/4/2021	2	66	33
PLANNED	6/4/2021	1	25	25
PLANNED	6/4/2021	4	20	5
PLANNED	6/4/2021	40	80	2
PLANNED	6/4/2021	9	423	47
PLANNED	6/4/2021	12	2,028	169
PLANNED	6/4/2021	41	4,018	98
PLANNED	6/4/2021	8	488	61
PLANNED	6/4/2021	4	416	104
PLANNED	6/4/2021	9	549	61
PLANNED	6/4/2021	29	4,263	147
PLANNED	6/4/2021	3	204	68
CUSTOMER REQUEST	6/4/2021	1	38	38
PLANNED	6/4/2021	5	160	32
PLANNED	6/4/2021	2	200	100
PLANNED	6/4/2021	2	12	6
PLANNED	6/4/2021	2	14	7
PLANNED	6/4/2021	5	155	31
PLANNED	6/4/2021	3	21	7
PLANNED	6/4/2021	4	92	23
PLANNED	6/4/2021	4	636	159
PLANNED	6/4/2021	5	295	59
PLANNED	6/4/2021	1	5	5
PLANNED	6/4/2021	4	340	85
PLANNED	6/4/2021	12	204	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/4/2021	1	9	9
PLANNED	6/4/2021	1	298	298
PLANNED	6/4/2021	4	20	5
PLANNED	6/4/2021	1	20	20
PLANNED	6/4/2021	4	52	13
PLANNED	6/4/2021	2	44	22
PLANNED	6/4/2021	11	4,125	375
PLANNED	6/4/2021	7	1,232	176
PLANNED	6/4/2021	2	16	8
PLANNED	6/4/2021	17	1,462	86
PLANNED	6/4/2021	27	1,269	47
PLANNED	6/4/2021	1	58	58
PLANNED	6/4/2021	4	20	5
PLANNED	6/4/2021	1	16	16
PLANNED	6/4/2021	10	1,620	162
PLANNED	6/4/2021	9	1,305	145
PLANNED	6/4/2021	4	28	7
PLANNED	6/4/2021	8	72	9
PLANNED	6/4/2021	4	44	11
PLANNED	6/4/2021	4	20	5
PLANNED	6/4/2021	1	45	45
PLANNED	6/4/2021	4	372	93
PLANNED	6/4/2021	2	12	6
PLANNED	6/4/2021	9	216	24
PLANNED	6/4/2021	1	12	12
PLANNED	6/4/2021	30	5,340	178
CUSTOMER REQUEST	6/4/2021	42	2,058	49
PLANNED	6/4/2021	5	10	174
PLANNED	6/4/2021	1	6	6
PLANNED	6/4/2021	4	32	8
PLANNED	6/4/2021	25	4,025	161
CUSTOMER REQUEST	6/4/2021	9	18	2
PLANNED	6/4/2021	4	40	10
PLANNED	6/4/2021	5	665	133
PLANNED	6/4/2021	9	432	48
PLANNED	6/4/2021	4	40	10
PLANNED	6/4/2021	8	160	20
PLANNED	6/4/2021	4	64	16
PLANNED	6/4/2021	4	4	1
PLANNED	6/4/2021	2	158	79
PLANNED	6/4/2021	4	44	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/4/2021	1	72	72
PLANNED	6/4/2021	1	132	132
PLANNED	6/4/2021	2	100	50
PLANNED	6/4/2021	3	9	3
PLANNED	6/4/2021	2	22	11
PLANNED	6/4/2021	5	40	8
PLANNED	6/4/2021	10	810	81
PLANNED	6/4/2021	9	153	17
PLANNED	6/4/2021	3	48	16
PLANNED	6/4/2021	8	1,072	176
PLANNED	6/4/2021	4	196	49
PLANNED	6/4/2021	9	252	28
PLANNED	6/4/2021	1	50	50
PLANNED	6/4/2021	4	24	6
PLANNED	6/4/2021	14	868	62
PLANNED	6/4/2021	2	214	107
PLANNED	6/4/2021	8	1,656	207
PLANNED	6/4/2021	3	336	112
CUSTOMER REQUEST	6/4/2021	3	51	17
PLANNED	6/4/2021	6	114	19
PLANNED	6/4/2021	2	26	13
PLANNED	6/4/2021	3	36	12
PLANNED	6/4/2021	3	69	23
PLANNED	6/4/2021	2	10	5
PLANNED	6/4/2021	1	40	40
PLANNED	6/4/2021	4	24	6
PLANNED	6/4/2021	1	70	70
PLANNED	6/4/2021	3	18	6
PLANNED	6/4/2021	4	656	164
PLANNED	6/4/2021	1	11	11
PLANNED	6/4/2021	3	240	80
PLANNED	6/4/2021	9	144	16
PLANNED	6/4/2021	1	7	7
PLANNED	6/4/2021	2	20	10
PLANNED	6/4/2021	4	72	18
PLANNED	6/4/2021	3	378	126
PLANNED	6/4/2021	3	45	15
PLANNED	6/4/2021	2	108	54
PLANNED	6/4/2021	2	186	93
PLANNED	6/4/2021	20	340	17
PLANNED	6/4/2021	7	413	59

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/4/2021	2	20	10
PLANNED	6/4/2021	5	205	41
PLANNED	6/4/2021	4	400	100
PLANNED	6/4/2021	2	114	57
PLANNED	6/4/2021	10	40	4
PLANNED	6/4/2021	3	345	115
PLANNED	6/4/2021	2	32	16
CUSTOMER REQUEST	6/4/2021	1	183	183
CUSTOMER REQUEST	6/4/2021	1	190	190
PLANNED	6/4/2021	5	265	53
PLANNED	6/4/2021	2	58	29
PLANNED	6/4/2021	2	156	78
PLANNED	6/4/2021	1	91	91
PLANNED	6/5/2021	1	324	324
PLANNED	6/5/2021	4	384	96
PLANNED	6/5/2021	2	288	144
PLANNED	6/5/2021	3	333	111
PLANNED	6/5/2021	2	628	314
PLANNED	6/5/2021	5	2,150	430
PLANNED	6/5/2021	8	1,136	142
PLANNED	6/5/2021	2	416	353
PLANNED	6/5/2021	8	208	26
PLANNED	6/5/2021	20	3,080	154
PLANNED	6/5/2021	2	220	110
PLANNED	6/5/2021	3	156	52
PLANNED	6/5/2021	1	130	130
PLANNED	6/5/2021	4	288	72
PLANNED	6/5/2021	12	1,236	103
PLANNED	6/5/2021	5	365	73
PLANNED	6/5/2021	12	1,732	157
PLANNED	6/5/2021	3	396	132
PLANNED	6/5/2021	1	91	91
PLANNED	6/5/2021	1	117	117
PLANNED	6/5/2021	3	21	7
CUSTOMER REQUEST	6/5/2021	1	109	109
PLANNED	6/5/2021	2	204	102
PLANNED	6/5/2021	1	280	280
PLANNED	6/5/2021	3	159	53
CUSTOMER REQUEST	6/6/2021	54	2,700	50
PLANNED	6/6/2021	2	646	323
PLANNED	6/6/2021	2	646	323

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/6/2021	12	2,256	188
PLANNED	6/6/2021	12	4,236	353
PLANNED	6/6/2021	1	528	528
PLANNED	6/6/2021	12	2,760	230
PLANNED	6/6/2021	2	8	4
PLANNED	6/6/2021	10	710	71
PLANNED	6/6/2021	4	388	97
PLANNED	6/6/2021	1	270	270
PLANNED	6/6/2021	2	276	138
PLANNED	6/6/2021	1	250	250
PLANNED	6/6/2021	1	89	89
PLANNED	6/6/2021	6	900	150
PLANNED	6/6/2021	6	708	118
PLANNED	6/6/2021	2	258	129
PLANNED	6/6/2021	1	70	70
PLANNED	6/6/2021	4	660	165
PLANNED	6/6/2021	1	81	81
PLANNED	6/6/2021	8	800	100
PLANNED	6/6/2021	1	79	79
PLANNED	6/6/2021	1	123	123
PLANNED	6/6/2021	12	1,728	144
PLANNED	6/6/2021	45	1,305	29
PLANNED	6/6/2021	11	264	24
PLANNED	6/6/2021	2	26	13
PLANNED	6/6/2021	8	112	14
PLANNED	6/6/2021	3	63	21
CUSTOMER REQUEST	6/6/2021	31	3,844	124
PLANNED	6/7/2021	2	310	155
PLANNED	6/7/2021	2	128	64
PLANNED	6/7/2021	4	108	27
PLANNED	6/7/2021	1	17	17
PLANNED	6/7/2021	8	144	18
PLANNED	6/7/2021	2	28	14
PLANNED	6/7/2021	3	48	16
PLANNED	6/7/2021	2	34	17
PLANNED	6/7/2021	7	490	70
PLANNED	6/7/2021	3	151	79
PLANNED	6/7/2021	7	119	17
PLANNED	6/7/2021	3	39	13
PLANNED	6/7/2021	2	18	9
PLANNED	6/7/2021	4	144	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	4	88	22
PLANNED	6/7/2021	4	64	16
PLANNED	6/7/2021	4	124	31
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	2	176	94
PLANNED	6/7/2021	2	18	9
PLANNED	6/7/2021	2	205	111
PLANNED	6/7/2021	4	520	130
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	3	254	105
PLANNED	6/7/2021	5	120	24
PLANNED	6/7/2021	11	2,495	241
PLANNED	6/7/2021	7	1,109	193
PLANNED	6/7/2021	2	28	14
PLANNED	6/7/2021	1	5	5
PLANNED	6/7/2021	2	414	207
PLANNED	6/7/2021	5	50	10
PLANNED	6/7/2021	2	24	12
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	2	18	9
PLANNED	6/7/2021	1	91	91
PLANNED	6/7/2021	2	16	8
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	6	60	10
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	4	116	29
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	3	33	11
PLANNED	6/7/2021	3	174	58
PLANNED	6/7/2021	1	9	9
CUSTOMER REQUEST	6/7/2021	5	220	44
PLANNED	6/7/2021	1	152	152
PLANNED	6/7/2021	3	24	8
PLANNED	6/7/2021	6	84	14
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	9	1,071	119
PLANNED	6/7/2021	1	13	13
PLANNED	6/7/2021	5	75	15
PLANNED	6/7/2021	2	24	12
PLANNED	6/7/2021	2	28	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	4	96	24
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	4	488	122
PLANNED	6/7/2021	2	46	23
PLANNED	6/7/2021	1	11	11
PLANNED	6/7/2021	2	22	11
PLANNED	6/7/2021	1	11	11
CUSTOMER REQUEST	6/7/2021	10	160	16
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	1	283	283
PLANNED	6/7/2021	2	40	20
PLANNED	6/7/2021	3	42	14
PLANNED	6/7/2021	7	448	64
PLANNED	6/7/2021	18	2,952	164
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	5	474	125
PLANNED	6/7/2021	1	2	2
PLANNED	6/7/2021	2	286	143
PLANNED	6/7/2021	1	125	125
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	2	106	53
PLANNED	6/7/2021	2	305	170
PLANNED	6/7/2021	49	833	17
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	8	480	60
PLANNED	6/7/2021	2	12	6
PLANNED	6/7/2021	3	174	58
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	5	1,555	311
PLANNED	6/7/2021	1	182	182
PLANNED	6/7/2021	9	990	110
PLANNED	6/7/2021	1	80	80
PLANNED	6/7/2021	2	30	15
CUSTOMER REQUEST	6/7/2021	1	1,414	1,414
PLANNED	6/7/2021	2	16	8
PLANNED	6/7/2021	2	182	91
PLANNED	6/7/2021	1	191	191
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	13	299	23
PLANNED	6/7/2021	8	400	50
PLANNED	6/7/2021	2	38	19

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	25	275	11
PLANNED	6/7/2021	4	116	29
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	3	33	11
PLANNED	6/7/2021	2	101	77
PLANNED	6/7/2021	2	125	75
PLANNED	6/7/2021	1	17	17
PLANNED	6/7/2021	5	165	33
PLANNED	6/7/2021	1	14	14
PLANNED	6/7/2021	1	16	16
PLANNED	6/7/2021	2	16	8
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	4	156	39
PLANNED	6/7/2021	1	13	13
PLANNED	6/7/2021	6	144	24
PLANNED	6/7/2021	1	139	139
PLANNED	6/7/2021	8	304	38
PLANNED	6/7/2021	1	5	5
PLANNED	6/7/2021	2	20	10
PLANNED	6/7/2021	1	67	67
PLANNED	6/7/2021	4	48	12
PLANNED	6/7/2021	6	78	13
PLANNED	6/7/2021	1	202	202
CUSTOMER REQUEST	6/7/2021	4	80	20
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	5	75	15
PLANNED	6/7/2021	2	44	22
PLANNED	6/7/2021	1	16	16
PLANNED	6/7/2021	7	588	84
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	3	570	190
PLANNED	6/7/2021	3	138	46
PLANNED	6/7/2021	1	60	60
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	10	240	24
PLANNED	6/7/2021	3	24	8
PLANNED	6/7/2021	13	3,913	301
CUSTOMER REQUEST	6/7/2021	1	1,691	1,691
PLANNED	6/7/2021	2	56	28
PLANNED	6/7/2021	3	27	9
PLANNED	6/7/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	3	48	16
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	5	110	22
PLANNED	6/7/2021	4	20	5
PLANNED	6/7/2021	1	54	54
PLANNED	6/7/2021	20	920	46
PLANNED	6/7/2021	1	18	18
PLANNED	6/7/2021	4	1,196	299
PLANNED	6/7/2021	7	35	5
PLANNED	6/7/2021	6	336	56
PLANNED	6/7/2021	4	76	19
PLANNED	6/7/2021	7	392	56
PLANNED	6/7/2021	4	188	47
PLANNED	6/7/2021	7	210	30
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	5	940	188
PLANNED	6/7/2021	2	40	20
PLANNED	6/7/2021	8	112	14
PLANNED	6/7/2021	4	40	10
PLANNED	6/7/2021	3	90	30
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	13	78	6
PLANNED	6/7/2021	6	234	39
PLANNED	6/7/2021	1	13	13
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	4	40	10
PLANNED	6/7/2021	7	252	36
PLANNED	6/7/2021	4	84	21
PLANNED	6/7/2021	1	11	11
PLANNED	6/7/2021	5	85	17
PLANNED	6/7/2021	1	13	13
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	1	18	18
PLANNED	6/7/2021	1	19	19
PLANNED	6/7/2021	2	232	116

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	4	152	38
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	12	432	36
PLANNED	6/7/2021	4	84	21
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	4	32	8
PLANNED	6/7/2021	1	5	5
PLANNED	6/7/2021	18	198	11
PLANNED	6/7/2021	2	22	11
PLANNED	6/7/2021	2	12	6
PLANNED	6/7/2021	9	378	42
PLANNED	6/7/2021	4	100	25
PLANNED	6/7/2021	2	10	5
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	14	1,246	89
PLANNED	6/7/2021	1	15	15
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	14	1,820	130
PLANNED	6/7/2021	10	96	60
PLANNED	6/7/2021	1	4	4
PLANNED	6/7/2021	2	36	18
PLANNED	6/7/2021	6	1,320	220
PLANNED	6/7/2021	2	16	8
PLANNED	6/7/2021	4	48	12
PLANNED	6/7/2021	2	50	25
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	2	16	8
PLANNED	6/7/2021	1	12	12
PLANNED	6/7/2021	1	10	10
CUSTOMER REQUEST	6/7/2021	8	152	19
PLANNED	6/7/2021	2	10	5
PLANNED	6/7/2021	4	652	163
PLANNED	6/7/2021	4	32	8
PLANNED	6/7/2021	1	27	27
PLANNED	6/7/2021	1	85	85
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	1	15	15
PLANNED	6/7/2021	1	88	88
PLANNED	6/7/2021	5	125	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	1	21	21
PLANNED	6/7/2021	2	172	87
PLANNED	6/7/2021	1	7	7
CUSTOMER REQUEST	6/7/2021	10	80	8
PLANNED	6/7/2021	5	155	31
PLANNED	6/7/2021	1	10	10
PLANNED	6/7/2021	4	28	7
PLANNED	6/7/2021	2	10	5
PLANNED	6/7/2021	1	4	4
PLANNED	6/7/2021	1	5	5
PLANNED	6/7/2021	3	27	9
PLANNED	6/7/2021	1	5	5
PLANNED	6/7/2021	1	40	40
PLANNED	6/7/2021	6	144	24
PLANNED	6/7/2021	2	90	45
PLANNED	6/7/2021	1	11	11
PLANNED	6/7/2021	1	25	25
PLANNED	6/7/2021	1	15	15
PLANNED	6/7/2021	1	16	16
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	5	860	172
PLANNED	6/7/2021	3	45	15
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	1	71	71
PLANNED	6/7/2021	10	120	12
PLANNED	6/7/2021	6	54	9
PLANNED	6/7/2021	1	17	17
PLANNED	6/7/2021	4	644	161
PLANNED	6/7/2021	1	11	11
PLANNED	6/7/2021	3	72	24
PLANNED	6/7/2021	2	54	46
PLANNED	6/7/2021	3	21	7
PLANNED	6/7/2021	2	256	128
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	3	12	4
PLANNED	6/7/2021	3	177	59
PLANNED	6/7/2021	2	266	133
PLANNED	6/7/2021	2	56	28
PLANNED	6/7/2021	4	104	26
PLANNED	6/7/2021	3	48	16
PLANNED	6/7/2021	1	101	101

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/7/2021	1	14	14
PLANNED	6/7/2021	2	20	10
PLANNED	6/7/2021	3	39	13
PLANNED	6/7/2021	1	126	126
PLANNED	6/7/2021	5	175	35
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	3	18	6
PLANNED	6/7/2021	6	48	8
PLANNED	6/7/2021	1	163	163
PLANNED	6/7/2021	9	126	14
PLANNED	6/7/2021	2	34	17
PLANNED	6/7/2021	4	52	13
PLANNED	6/7/2021	2	18	9
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	1	9	9
CUSTOMER REQUEST	6/7/2021	1	60	60
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	1	102	102
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	2	12	6
PLANNED	6/7/2021	1	12	12
PLANNED	6/7/2021	1	17	17
PLANNED	6/7/2021	1	8	8
PLANNED	6/7/2021	2	14	7
PLANNED	6/7/2021	1	6	6
PLANNED	6/7/2021	1	17	17
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	1	15	15
PLANNED	6/7/2021	1	7	7
PLANNED	6/7/2021	1	9	9
PLANNED	6/7/2021	3	108	36
PLANNED	6/7/2021	1	102	102
PLANNED	6/7/2021	2	136	68
PLANNED	6/7/2021	1	188	188
PLANNED	6/8/2021	1	78	78
PLANNED	6/8/2021	1	49	49
PLANNED	6/8/2021	8	232	29
PLANNED	6/8/2021	1	56	56
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	3	69	23
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	1	135	135
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	2	20	10
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	1	15	15
PLANNED	6/8/2021	5	80	16
PLANNED	6/8/2021	3	45	15
PLANNED	6/8/2021	1	248	248
PLANNED	6/8/2021	4	64	16
PLANNED	6/8/2021	5	75	15
PLANNED	6/8/2021	2	182	91
PLANNED	6/8/2021	1	48	48
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	13	1,742	134
PLANNED	6/8/2021	13	26	2
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	3	309	103
PLANNED	6/8/2021	2	28	14
PLANNED	6/8/2021	4	40	10
PLANNED	6/8/2021	1	147	147
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	386	193
PLANNED	6/8/2021	3	267	89
PLANNED	6/8/2021	1	16	16
PLANNED	6/8/2021	2	149	86
PLANNED	6/8/2021	1	16	16
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	40	20
PLANNED	6/8/2021	6	108	18
PLANNED	6/8/2021	3	21	7
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	3	378	126

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	1	173	173
PLANNED	6/8/2021	4	164	41
PLANNED	6/8/2021	2	28	14
PLANNED	6/8/2021	6	84	14
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	12	108	9
PLANNED	6/8/2021	1	128	128
PLANNED	6/8/2021	3	30	10
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	2	14	7
PLANNED	6/8/2021	1	6	6
CUSTOMER REQUEST	6/8/2021	37	11,285	305
PLANNED	6/8/2021	4	260	65
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	7	210	30
PLANNED	6/8/2021	1	48	48
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	10	5
PLANNED	6/8/2021	1	66	66
PLANNED	6/8/2021	8	80	10
PLANNED	6/8/2021	29	2,523	87
PLANNED	6/8/2021	3	18	6
PLANNED	6/8/2021	44	5,984	136
PLANNED	6/8/2021	4	40	10
PLANNED	6/8/2021	1	210	210
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	9	72	8
PLANNED	6/8/2021	13	39	3
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	12	6
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	1	29	29
PLANNED	6/8/2021	2	2	1
PLANNED	6/8/2021	3	102	34
PLANNED	6/8/2021	28	1,568	56
PLANNED	6/8/2021	1	15	15
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	44	22
PLANNED	6/8/2021	10	1,650	165
PLANNED	6/8/2021	1	12	12
PLANNED	6/8/2021	4	360	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	2	18	9
PLANNED	6/8/2021	2	12	6
CUSTOMER REQUEST	6/8/2021	20	2,520	126
PLANNED	6/8/2021	4	748	187
PLANNED	6/8/2021	3	18	6
PLANNED	6/8/2021	10	80	8
PLANNED	6/8/2021	2	12	6
PLANNED	6/8/2021	1	219	219
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	1	149	149
PLANNED	6/8/2021	3	36	12
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	1	13	13
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	2	28	14
PLANNED	6/8/2021	3	69	23
PLANNED	6/8/2021	17	1,122	66
PLANNED	6/8/2021	2	24	12
PLANNED	6/8/2021	2	12	6
PLANNED	6/8/2021	11	99	9
PLANNED	6/8/2021	1	75	75
PLANNED	6/8/2021	6	174	29
PLANNED	6/8/2021	5	25	5
PLANNED	6/8/2021	3	36	12
PLANNED	6/8/2021	4	348	87
PLANNED	6/8/2021	5	230	46
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	1	57	57
PLANNED	6/8/2021	15	2,400	160
PLANNED	6/8/2021	2	20	10
PLANNED	6/8/2021	1	66	66
PLANNED	6/8/2021	3	15	5
PLANNED	6/8/2021	15	105	7
PLANNED	6/8/2021	2	22	11
PLANNED	6/8/2021	4	1,268	317
PLANNED	6/8/2021	2	92	46
PLANNED	6/8/2021	3	21	7
PLANNED	6/8/2021	6	96	16
PLANNED	6/8/2021	7	56	8
PLANNED	6/8/2021	7	420	60
PLANNED	6/8/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	2	318	159
PLANNED	6/8/2021	2	14	7
CUSTOMER REQUEST	6/8/2021	1	168	168
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	1	92	92
PLANNED	6/8/2021	1	68	68
PLANNED	6/8/2021	2	168	84
PLANNED	6/8/2021	2	540	308
PLANNED	6/8/2021	4	132	33
PLANNED	6/8/2021	2	12	6
PLANNED	6/8/2021	3	261	87
PLANNED	6/8/2021	4	108	27
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	3	21	7
PLANNED	6/8/2021	1	103	103
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	1	13	13
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	2	228	114
PLANNED	6/8/2021	2	150	75
PLANNED	6/8/2021	2	20	10
PLANNED	6/8/2021	1	12	12
PLANNED	6/8/2021	5	90	18
PLANNED	6/8/2021	2	6	3
PLANNED	6/8/2021	2	26	13
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	3	75	25
PLANNED	6/8/2021	2	14	7
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	1	105	105
PLANNED	6/8/2021	2	196	98
PLANNED	6/8/2021	29	1,885	65
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	1	91	91
PLANNED	6/8/2021	1	13	13
PLANNED	6/8/2021	1	1	1
PLANNED	6/8/2021	6	144	24
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	4	140	35
PLANNED	6/8/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	16	8
PLANNED	6/8/2021	1	13	13
PLANNED	6/8/2021	4	40	10
PLANNED	6/8/2021	1	52	52
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	18	9
PLANNED	6/8/2021	2	152	76
PLANNED	6/8/2021	2	16	8
PLANNED	6/8/2021	7	238	34
PLANNED	6/8/2021	1	11	11
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	22	11
PLANNED	6/8/2021	1	14	14
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	52	13,208	254
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	2	212	106
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	4	40	10
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	4	92	23
PLANNED	6/8/2021	4	192	48
PLANNED	6/8/2021	5	230	46
PLANNED	6/8/2021	13	208	16
PLANNED	6/8/2021	3	57	19
PLANNED	6/8/2021	2	152	76
PLANNED	6/8/2021	4	376	94
PLANNED	6/8/2021	6	906	151
PLANNED	6/8/2021	59	14,514	246
PLANNED	6/8/2021	1	8	8
PLANNED	6/8/2021	3	21	7
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	7	1,029	147
PLANNED	6/8/2021	4	32	8
PLANNED	6/8/2021	6	342	57
PLANNED	6/8/2021	8	1,600	200

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	3	540	180
PLANNED	6/8/2021	2	160	80
PLANNED	6/8/2021	14	196	14
PLANNED	6/8/2021	2	22	11
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	326	163
PLANNED	6/8/2021	1	84	84
PLANNED	6/8/2021	1	11	11
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	2	30	15
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	5	745	149
PLANNED	6/8/2021	9	108	12
PLANNED	6/8/2021	2	14	7
PLANNED	6/8/2021	2	12	6
PLANNED	6/8/2021	1	17	17
PLANNED	6/8/2021	7	133	19
PLANNED	6/8/2021	1	11	11
PLANNED	6/8/2021	1	9	9
PLANNED	6/8/2021	1	21	21
PLANNED	6/8/2021	2	14	7
PLANNED	6/8/2021	7	490	70
PLANNED	6/8/2021	5	50	10
PLANNED	6/8/2021	5	50	10
PLANNED	6/8/2021	1	6	6
PLANNED	6/8/2021	1	12	12
PLANNED	6/8/2021	1	9	9
CUSTOMER REQUEST	6/8/2021	1	144	144
PLANNED	6/8/2021	4	20	5
PLANNED	6/8/2021	5	55	11
PLANNED	6/8/2021	2	18	9
PLANNED	6/8/2021	10	25	16
PLANNED	6/8/2021	2	52	26
PLANNED	6/8/2021	2	20	10
PLANNED	6/8/2021	2	10	5
PLANNED	6/8/2021	1	21	21
PLANNED	6/8/2021	2	70	35
PLANNED	6/8/2021	2	16	8
PLANNED	6/8/2021	2	254	127
PLANNED	6/8/2021	12	168	14
PLANNED	6/8/2021	4	660	165

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	4	20	5
PLANNED	6/8/2021	2	14	7
PLANNED	6/8/2021	2	118	59
PLANNED	6/8/2021	10	680	68
PLANNED	6/8/2021	6	72	12
PLANNED	6/8/2021	2	24	12
PLANNED	6/8/2021	5	150	30
CUSTOMER REQUEST	6/8/2021	6	12	2
PLANNED	6/8/2021	11	253	23
PLANNED	6/8/2021	3	78	26
PLANNED	6/8/2021	2	42	21
PLANNED	6/8/2021	6	84	14
PLANNED	6/8/2021	2	18	9
PLANNED	6/8/2021	1	52	52
PLANNED	6/8/2021	1	63	63
CUSTOMER REQUEST	6/8/2021	4	52	13
PLANNED	6/8/2021	10	1,730	173
PLANNED	6/8/2021	3	15	5
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	4	80	20
PLANNED	6/8/2021	25	625	25
CUSTOMER REQUEST	6/8/2021	14	532	38
PLANNED	6/8/2021	1	7	7
PLANNED	6/8/2021	5	380	76
PLANNED	6/8/2021	8	232	29
PLANNED	6/8/2021	2	8	4
PLANNED	6/8/2021	2	10	5
PLANNED	6/8/2021	3	18	6
CUSTOMER REQUEST	6/8/2021	1	47	47
PLANNED	6/8/2021	5	70	14
PLANNED	6/8/2021	2	20	10
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	1	10	10
PLANNED	6/8/2021	2	10	5
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	1	5	5
PLANNED	6/8/2021	2	216	108
PLANNED	6/8/2021	2	93	73
PLANNED	6/8/2021	15	1,815	121
PLANNED	6/8/2021	8	2,664	333
PLANNED	6/8/2021	1	28	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/8/2021	1	140	140
CUSTOMER REQUEST	6/8/2021	1	65	65
PLANNED	6/9/2021	3	204	68
CUSTOMER REQUEST	6/9/2021	4	60	15
PLANNED	6/9/2021	2	380	190
PLANNED	6/9/2021	3	75	25
PLANNED	6/9/2021	4	760	190
PLANNED	6/9/2021	5	585	117
PLANNED	6/9/2021	1	74	74
PLANNED	6/9/2021	2	112	56
PLANNED	6/9/2021	3	468	156
PLANNED	6/9/2021	2	26	13
PLANNED	6/9/2021	3	27	9
PLANNED	6/9/2021	6	42	7
PLANNED	6/9/2021	8	1,240	155
PLANNED	6/9/2021	2	120	60
PLANNED	6/9/2021	2	268	134
PLANNED	6/9/2021	1	13	13
PLANNED	6/9/2021	14	1,834	131
PLANNED	6/9/2021	3	84	28
PLANNED	6/9/2021	12	744	62
PLANNED	6/9/2021	3	131	62
PLANNED	6/9/2021	12	780	65
PLANNED	6/9/2021	4	428	107
PLANNED	6/9/2021	8	472	59
PLANNED	6/9/2021	1	81	81
PLANNED	6/9/2021	2	46	23
PLANNED	6/9/2021	2	120	60
PLANNED	6/9/2021	1	97	97
PLANNED	6/9/2021	4	376	94
PLANNED	6/9/2021	3	264	88
PLANNED	6/9/2021	3	81	27
PLANNED	6/9/2021	1	12	12
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	4	96	24
PLANNED	6/9/2021	4	24	6
PLANNED	6/9/2021	13	377	29
PLANNED	6/9/2021	9	261	29
PLANNED	6/9/2021	2	242	121
PLANNED	6/9/2021	12	348	29
PLANNED	6/9/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	2	428	214
PLANNED	6/9/2021	2	176	88
PLANNED	6/9/2021	1	6	6
PLANNED	6/9/2021	1	14	14
PLANNED	6/9/2021	2	16	8
PLANNED	6/9/2021	11	363	33
PLANNED	6/9/2021	1	17	17
PLANNED	6/9/2021	1	7	7
PLANNED	6/9/2021	2	270	135
PLANNED	6/9/2021	4	536	134
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	29	2,813	97
PLANNED	6/9/2021	1	11	11
PLANNED	6/9/2021	1	71	71
PLANNED	6/9/2021	3	336	112
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	1	7	7
CUSTOMER REQUEST	6/9/2021	5	175	35
PLANNED	6/9/2021	3	96	32
CUSTOMER REQUEST	6/9/2021	4	322	313
PLANNED	6/9/2021	3	323	139
PLANNED	6/9/2021	4	20	5
PLANNED	6/9/2021	2	232	116
PLANNED	6/9/2021	2	14	7
PLANNED	6/9/2021	1	114	114
PLANNED	6/9/2021	4	668	167
PLANNED	6/9/2021	7	56	8
PLANNED	6/9/2021	5	90	18
PLANNED	6/9/2021	7	1,393	199
PLANNED	6/9/2021	1	51	51
CUSTOMER REQUEST	6/9/2021	3	861	287
PLANNED	6/9/2021	2	69	43
PLANNED	6/9/2021	1	10	10
PLANNED	6/9/2021	1	39	39
PLANNED	6/9/2021	1	6	6
CUSTOMER REQUEST	6/9/2021	9	2,250	250
PLANNED	6/9/2021	7	455	65
PLANNED	6/9/2021	1	132	132
PLANNED	6/9/2021	1	30	30
PLANNED	6/9/2021	1	18	18
PLANNED	6/9/2021	1	245	245

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	1	54	54
CUSTOMER REQUEST	6/9/2021	21	147	7
PLANNED	6/9/2021	3	81	27
PLANNED	6/9/2021	1	427	427
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	4	672	168
PLANNED	6/9/2021	2	18	9
PLANNED	6/9/2021	8	728	91
PLANNED	6/9/2021	1	79	79
PLANNED	6/9/2021	3	222	74
PLANNED	6/9/2021	27	3,429	127
PLANNED	6/9/2021	2	34	17
PLANNED	6/9/2021	1	64	64
CUSTOMER REQUEST	6/9/2021	9	18	2
PLANNED	6/9/2021	7	63	9
PLANNED	6/9/2021	9	126	14
PLANNED	6/9/2021	9	540	60
PLANNED	6/9/2021	1	74	74
PLANNED	6/9/2021	2	20	10
PLANNED	6/9/2021	2	20	10
CUSTOMER REQUEST	6/9/2021	13	572	44
PLANNED	6/9/2021	2	16	8
PLANNED	6/9/2021	3	138	46
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	2	16	8
PLANNED	6/9/2021	10	140	14
PLANNED	6/9/2021	2	34	17
PLANNED	6/9/2021	6	48	8
PLANNED	6/9/2021	35	875	25
PLANNED	6/9/2021	3	60	20
PLANNED	6/9/2021	19	475	25
PLANNED	6/9/2021	1	157	157
PLANNED	6/9/2021	1	17	17
PLANNED	6/9/2021	1	184	184
PLANNED	6/9/2021	1	107	107
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	3	240	80
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	8	64	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	9	450	50
PLANNED	6/9/2021	3	90	30
PLANNED	6/9/2021	6	60	10
PLANNED	6/9/2021	2	14	7
PLANNED	6/9/2021	4	760	190
PLANNED	6/9/2021	2	20	10
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	8	456	57
PLANNED	6/9/2021	4	36	9
PLANNED	6/9/2021	11	506	46
PLANNED	6/9/2021	36	5,076	141
PLANNED	6/9/2021	5	850	170
PLANNED	6/9/2021	2	111	70
PLANNED	6/9/2021	1	7	7
CUSTOMER REQUEST	6/9/2021	20	4,300	215
PLANNED	6/9/2021	1	6	6
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	2	138	69
PLANNED	6/9/2021	4	388	97
PLANNED	6/9/2021	25	1,275	51
PLANNED	6/9/2021	2	18	9
PLANNED	6/9/2021	2	248	124
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	1	15	15
PLANNED	6/9/2021	1	6	6
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	3	78	26
PLANNED	6/9/2021	2	410	205
PLANNED	6/9/2021	3	12	4
PLANNED	6/9/2021	2	116	58
PLANNED	6/9/2021	1	244	244
PLANNED	6/9/2021	18	2,070	115
PLANNED	6/9/2021	2	14	7
PLANNED	6/9/2021	3	18	6
PLANNED	6/9/2021	15	675	45
PLANNED	6/9/2021	13	325	25
PLANNED	6/9/2021	2	84	42
PLANNED	6/9/2021	1	11	11
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	2	342	171
PLANNED	6/9/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	12	12	1
PLANNED	6/9/2021	1	18	18
PLANNED	6/9/2021	2	10	5
PLANNED	6/9/2021	9	450	50
PLANNED	6/9/2021	1	6	6
PLANNED	6/9/2021	1	7	7
CUSTOMER REQUEST	6/9/2021	7	35	5
PLANNED	6/9/2021	1	101	101
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	1	96	96
PLANNED	6/9/2021	1	7	7
PLANNED	6/9/2021	2	14	7
PLANNED	6/9/2021	1	10	10
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	1	7	7
PLANNED	6/9/2021	2	14	7
PLANNED	6/9/2021	1	13	13
PLANNED	6/9/2021	2	140	70
PLANNED	6/9/2021	8	224	28
PLANNED	6/9/2021	3	54	18
PLANNED	6/9/2021	3	615	205
CUSTOMER REQUEST	6/9/2021	5	75	15
PLANNED	6/9/2021	6	252	42
PLANNED	6/9/2021	4	32	8
PLANNED	6/9/2021	16	1,360	85
PLANNED	6/9/2021	26	2,444	94
PLANNED	6/9/2021	3	381	127
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	3	189	63
PLANNED	6/9/2021	2	126	63
PLANNED	6/9/2021	3	36	12
PLANNED	6/9/2021	1	61	61
PLANNED	6/9/2021	5	95	19
PLANNED	6/9/2021	1	76	76
PLANNED	6/9/2021	1	14	14
PLANNED	6/9/2021	1	33	33
PLANNED	6/9/2021	29	1,943	67
PLANNED	6/9/2021	1	234	234
PLANNED	6/9/2021	2	34	17
PLANNED	6/9/2021	32	192	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	1	82	82
PLANNED	6/9/2021	7	252	36
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	4	84	21
PLANNED	6/9/2021	1	83	83
PLANNED	6/9/2021	3	357	119
PLANNED	6/9/2021	7	252	36
CUSTOMER REQUEST	6/9/2021	1	355	355
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	10	1,520	152
PLANNED	6/9/2021	6	234	39
PLANNED	6/9/2021	1	70	70
PLANNED	6/9/2021	1	50	50
PLANNED	6/9/2021	3	150	50
PLANNED	6/9/2021	1	9	9
CUSTOMER REQUEST	6/9/2021	8	296	37
PLANNED	6/9/2021	1	4	4
PLANNED	6/9/2021	4	116	29
PLANNED	6/9/2021	1	87	87
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	3	321	107
PLANNED	6/9/2021	1	7	7
PLANNED	6/9/2021	2	98	49
PLANNED	6/9/2021	2	24	12
PLANNED	6/9/2021	2	304	152
PLANNED	6/9/2021	2	10	5
PLANNED	6/9/2021	19	19	1
PLANNED	6/9/2021	1	8	8
PLANNED	6/9/2021	6	234	42
PLANNED	6/9/2021	3	219	73
PLANNED	6/9/2021	1	5	5
PLANNED	6/9/2021	4	28	7
PLANNED	6/9/2021	7	364	52
PLANNED	6/9/2021	3	15	5
PLANNED	6/9/2021	12	936	78
PLANNED	6/9/2021	1	9	9
PLANNED	6/9/2021	4	708	177
PLANNED	6/9/2021	3	270	90
PLANNED	6/9/2021	1	11	11
PLANNED	6/9/2021	3	72	24
PLANNED	6/9/2021	5	480	96

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/9/2021	2	110	55
PLANNED	6/9/2021	3	51	17
CUSTOMER REQUEST	6/9/2021	1	70	70
CUSTOMER REQUEST	6/9/2021	1	98	98
PLANNED	6/9/2021	1	14	14
PLANNED	6/9/2021	6	132	22
PLANNED	6/9/2021	1	108	108
CUSTOMER REQUEST	6/9/2021	5	430	86
PLANNED	6/9/2021	4	56	14
PLANNED	6/9/2021	4	68	17
PLANNED	6/9/2021	7	119	17
PLANNED	6/9/2021	3	138	46
PLANNED	6/9/2021	2	72	36
PLANNED	6/9/2021	9	2,034	226
PLANNED	6/9/2021	2	918	459
PLANNED	6/9/2021	3	864	288
PLANNED	6/9/2021	2	452	226
PLANNED	6/9/2021	3	1,101	367
PLANNED	6/9/2021	41	2,665	65
PLANNED	6/9/2021	2	2,924	1,462
PLANNED	6/10/2021	1	51	51
PLANNED	6/10/2021	1	70	70
PLANNED	6/10/2021	15	2,355	157
PLANNED	6/10/2021	27	2,133	79
PLANNED	6/10/2021	4	144	36
PLANNED	6/10/2021	1	79	79
PLANNED	6/10/2021	13	1,105	85
PLANNED	6/10/2021	4	236	59
PLANNED	6/10/2021	4	196	49
PLANNED	6/10/2021	5	85	17
PLANNED	6/10/2021	1	84	84
PLANNED	6/10/2021	2	202	101
PLANNED	6/10/2021	9	738	82
PLANNED	6/10/2021	9	342	38
PLANNED	6/10/2021	17	1,071	63
PLANNED	6/10/2021	3	108	39
PLANNED	6/10/2021	1	54	54
PLANNED	6/10/2021	2	106	53
PLANNED	6/10/2021	3	66	22
PLANNED	6/10/2021	6	1,470	245
PLANNED	6/10/2021	2	36	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/10/2021	2	26	13
PLANNED	6/10/2021	1	9	9
PLANNED	6/10/2021	4	286	78
PLANNED	6/10/2021	2	132	66
PLANNED	6/10/2021	7	371	53
PLANNED	6/10/2021	7	364	52
PLANNED	6/10/2021	1	67	67
PLANNED	6/10/2021	11	99	9
PLANNED	6/10/2021	1	119	119
PLANNED	6/10/2021	2	150	75
PLANNED	6/10/2021	4	352	88
PLANNED	6/10/2021	1	115	115
PLANNED	6/10/2021	3	324	108
PLANNED	6/10/2021	5	400	80
PLANNED	6/10/2021	1	9	9
PLANNED	6/10/2021	2	168	84
PLANNED	6/10/2021	2	38	19
PLANNED	6/10/2021	1	10	10
PLANNED	6/10/2021	2	28	14
PLANNED	6/10/2021	1	123	123
PLANNED	6/10/2021	4	48	12
PLANNED	6/10/2021	1	81	81
PLANNED	6/10/2021	2	12	6
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	3	162	54
PLANNED	6/10/2021	13	1,768	136
PLANNED	6/10/2021	10	1,720	204
PLANNED	6/10/2021	2	396	198
PLANNED	6/10/2021	2	134	67
PLANNED	6/10/2021	2	28	14
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	2	20	10
PLANNED	6/10/2021	3	30	10
PLANNED	6/10/2021	1	123	123
PLANNED	6/10/2021	1	219	219
PLANNED	6/10/2021	1	65	65
PLANNED	6/10/2021	3	39	13
PLANNED	6/10/2021	2	18	9
PLANNED	6/10/2021	3	180	60
PLANNED	6/10/2021	2	128	64
PLANNED	6/10/2021	1	176	176

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	6/10/2021	8	48	6
PLANNED	6/10/2021	4	336	84
PLANNED	6/10/2021	2	74	37
PLANNED	6/10/2021	2	24	12
PLANNED	6/10/2021	7	56	8
PLANNED	6/10/2021	4	60	15
PLANNED	6/10/2021	6	102	17
PLANNED	6/10/2021	8	1,512	189
PLANNED	6/10/2021	4	72	18
PLANNED	6/10/2021	2	22	11
PLANNED	6/10/2021	1	53	53
PLANNED	6/10/2021	1	12	12
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	12	1,116	93
PLANNED	6/10/2021	2	264	132
PLANNED	6/10/2021	5	130	26
PLANNED	6/10/2021	3	63	21
PLANNED	6/10/2021	3	198	66
CUSTOMER REQUEST	6/10/2021	16	1,216	76
PLANNED	6/10/2021	3	69	23
PLANNED	6/10/2021	8	720	90
PLANNED	6/10/2021	1	27	27
PLANNED	6/10/2021	1	222	222
PLANNED	6/10/2021	118	22,774	193
PLANNED	6/10/2021	10	430	43
PLANNED	6/10/2021	1	302	302
PLANNED	6/10/2021	1	303	303
PLANNED	6/10/2021	1	9	9
PLANNED	6/10/2021	3	75	25
PLANNED	6/10/2021	4	236	59
PLANNED	6/10/2021	2	42	21
PLANNED	6/10/2021	3	630	210
PLANNED	6/10/2021	2	14	7
PLANNED	6/10/2021	1	42	42
PLANNED	6/10/2021	1	7	7
PLANNED	6/10/2021	2	92	46
PLANNED	6/10/2021	3	111	37
PLANNED	6/10/2021	19	3,572	188
PLANNED	6/10/2021	1	54	54
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	115	4,025	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/10/2021	1	12	12
PLANNED	6/10/2021	1	344	344
PLANNED	6/10/2021	3	24	8
PLANNED	6/10/2021	5	75	15
PLANNED	6/10/2021	5	100	20
PLANNED	6/10/2021	1	50	50
PLANNED	6/10/2021	2	18	9
PLANNED	6/10/2021	2	28	14
PLANNED	6/10/2021	2	18	9
PLANNED	6/10/2021	16	1,848	168
PLANNED	6/10/2021	1	76	76
PLANNED	6/10/2021	2	409	220
PLANNED	6/10/2021	1	12	12
PLANNED	6/10/2021	1	32	32
PLANNED	6/10/2021	2	72	36
PLANNED	6/10/2021	10	520	52
PLANNED	6/10/2021	2	32	16
PLANNED	6/10/2021	11	572	52
PLANNED	6/10/2021	3	21	7
PLANNED	6/10/2021	4	72	18
PLANNED	6/10/2021	27	1,103	141
PLANNED	6/10/2021	10	1,210	121
PLANNED	6/10/2021	2	142	71
PLANNED	6/10/2021	1	13	13
PLANNED	6/10/2021	1	12	12
PLANNED	6/10/2021	3	81	27
PLANNED	6/10/2021	30	2,840	114
PLANNED	6/10/2021	15	1,005	67
PLANNED	6/10/2021	1	44	44
PLANNED	6/10/2021	5	500	100
PLANNED	6/10/2021	3	30	10
PLANNED	6/10/2021	3	306	102
PLANNED	6/10/2021	1	9	9
PLANNED	6/10/2021	1	14	14
PLANNED	6/10/2021	2	208	104
PLANNED	6/10/2021	3	468	156
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	2	452	226
PLANNED	6/10/2021	8	1,800	225
PLANNED	6/10/2021	1	143	143
PLANNED	6/10/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/10/2021	2	6	3
PLANNED	6/10/2021	3	54	18
PLANNED	6/10/2021	2	348	174
PLANNED	6/10/2021	4	216	54
PLANNED	6/10/2021	2	262	131
PLANNED	6/10/2021	1	227	227
PLANNED	6/10/2021	4	108	27
PLANNED	6/10/2021	1	10	10
CUSTOMER REQUEST	6/10/2021	2	140	70
PLANNED	6/10/2021	1	46	46
PLANNED	6/10/2021	2	6	3
PLANNED	6/10/2021	8	312	39
PLANNED	6/10/2021	2	26	13
PLANNED	6/10/2021	4	444	111
PLANNED	6/10/2021	2	70	35
PLANNED	6/10/2021	4	628	157
PLANNED	6/10/2021	2	40	20
PLANNED	6/10/2021	6	252	42
PLANNED	6/10/2021	4	592	148
PLANNED	6/10/2021	2	236	118
PLANNED	6/10/2021	7	735	105
PLANNED	6/10/2021	1	11	11
PLANNED	6/10/2021	3	15	5
PLANNED	6/10/2021	2	146	73
PLANNED	6/10/2021	1	285	285
CUSTOMER REQUEST	6/10/2021	1	303	303
PLANNED	6/10/2021	2	202	101
PLANNED	6/10/2021	1	6	6
PLANNED	6/10/2021	1	8	8
PLANNED	6/10/2021	1	54	54
PLANNED	6/10/2021	16	3,152	197
PLANNED	6/10/2021	1	15	15
PLANNED	6/10/2021	1	15	15
PLANNED	6/10/2021	23	3,690	200
PLANNED	6/10/2021	2	12	6
PLANNED	6/10/2021	1	30	30
PLANNED	6/10/2021	2	14	7
CUSTOMER REQUEST	6/10/2021	1	311	311
PLANNED	6/10/2021	1	95	95
PLANNED	6/10/2021	12	264	22
PLANNED	6/10/2021	2	22	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/10/2021	2	40	20
PLANNED	6/10/2021	2	90	45
PLANNED	6/10/2021	1	5	5
PLANNED	6/10/2021	6	504	84
PLANNED	6/10/2021	1	9	9
PLANNED	6/10/2021	6	882	147
PLANNED	6/10/2021	3	33	11
PLANNED	6/10/2021	1	91	91
PLANNED	6/10/2021	2	160	80
PLANNED	6/10/2021	2	16	8
PLANNED	6/10/2021	5	310	62
PLANNED	6/10/2021	10	140	14
PLANNED	6/10/2021	3	24	8
PLANNED	6/10/2021	3	15	5
PLANNED	6/10/2021	1	10	10
PLANNED	6/10/2021	2	26	13
PLANNED	6/10/2021	1	53	53
PLANNED	6/10/2021	1	7	7
PLANNED	6/10/2021	2	12	6
PLANNED	6/10/2021	3	18	6
PLANNED	6/10/2021	1	62	62
CUSTOMER REQUEST	6/10/2021	1	372	372
PLANNED	6/10/2021	1	47	47
PLANNED	6/10/2021	1	29	29
PLANNED	6/10/2021	3	213	71
PLANNED	6/10/2021	2	152	76
PLANNED	6/10/2021	3	891	297
PLANNED	6/10/2021	2	4	2
PLANNED	6/10/2021	6	522	87
PLANNED	6/10/2021	1	153	153
PLANNED	6/10/2021	5	1,365	273
PLANNED	6/10/2021	3	138	46
PLANNED	6/10/2021	8	816	102
PLANNED	6/10/2021	1	58	58
PLANNED	6/11/2021	20	3,440	172
PLANNED	6/11/2021	3	261	87
CUSTOMER REQUEST	6/11/2021	8	136	17
PLANNED	6/11/2021	2	30	15
PLANNED	6/11/2021	1	846	846
PLANNED	6/11/2021	8	1,136	142
PLANNED	6/11/2021	10	1,220	122

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/11/2021	1	42	42
PLANNED	6/11/2021	1	55	55
PLANNED	6/11/2021	4	216	54
PLANNED	6/11/2021	2	28	14
PLANNED	6/11/2021	3	150	50
PLANNED	6/11/2021	1	10	10
PLANNED	6/11/2021	3	300	100
PLANNED	6/11/2021	36	2,124	59
PLANNED	6/11/2021	1	113	113
PLANNED	6/11/2021	1	12	12
PLANNED	6/11/2021	1	172	172
PLANNED	6/11/2021	1	172	172
PLANNED	6/11/2021	1	243	243
PLANNED	6/11/2021	2	36	18
PLANNED	6/11/2021	1	13	13
PLANNED	6/11/2021	1	96	96
CUSTOMER REQUEST	6/11/2021	2	488	244
PLANNED	6/11/2021	1	56	56
PLANNED	6/11/2021	4	352	88
PLANNED	6/11/2021	1	89	89
PLANNED	6/11/2021	2	46	23
CUSTOMER REQUEST	6/11/2021	1	151	151
PLANNED	6/11/2021	9	1,143	127
PLANNED	6/11/2021	14	364	26
PLANNED	6/11/2021	1	105	105
PLANNED	6/11/2021	1	18	18
PLANNED	6/11/2021	3	150	50
PLANNED	6/11/2021	6	432	72
PLANNED	6/11/2021	1	164	164
PLANNED	6/11/2021	7	133	19
PLANNED	6/11/2021	1	58	58
PLANNED	6/11/2021	1	121	121
PLANNED	6/11/2021	1	25	25
PLANNED	6/11/2021	4	52	13
PLANNED	6/11/2021	5	181	109
CUSTOMER REQUEST	6/11/2021	75	13,425	179
PLANNED	6/11/2021	5	164	64
PLANNED	6/11/2021	1	19	19
PLANNED	6/11/2021	3	126	42
PLANNED	6/11/2021	13	637	49
PLANNED	6/11/2021	5	225	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/11/2021	2	338	169
PLANNED	6/11/2021	10	1,450	145
PLANNED	6/11/2021	1	52	52
PLANNED	6/11/2021	18	2,844	158
PLANNED	6/11/2021	14	2,128	206
PLANNED	6/11/2021	7	119	17
PLANNED	6/11/2021	1	85	85
PLANNED	6/11/2021	5	1,125	225
PLANNED	6/11/2021	2	16	8
PLANNED	6/11/2021	3	165	55
PLANNED	6/11/2021	1	12	12
PLANNED	6/11/2021	8	1,496	187
PLANNED	6/11/2021	1	14	14
PLANNED	6/11/2021	14	1,428	102
PLANNED	6/11/2021	8	1,352	169
PLANNED	6/11/2021	4	28	7
PLANNED	6/11/2021	3	519	173
PLANNED	6/11/2021	10	2,130	213
PLANNED	6/11/2021	143	5,434	38
PLANNED	6/11/2021	3	24	8
PLANNED	6/11/2021	1	8	8
PLANNED	6/11/2021	1	14	14
PLANNED	6/11/2021	4	372	93
PLANNED	6/11/2021	6	714	119
PLANNED	6/11/2021	4	488	122
PLANNED	6/11/2021	14	910	65
PLANNED	6/11/2021	1	7	7
PLANNED	6/11/2021	1	18	18
PLANNED	6/11/2021	11	132	12
PLANNED	6/11/2021	2	162	81
PLANNED	6/11/2021	3	81	27
CUSTOMER REQUEST	6/11/2021	5	145	29
CUSTOMER REQUEST	6/11/2021	4	164	41
CUSTOMER REQUEST	6/11/2021	3	123	41
PLANNED	6/11/2021	5	50	10
PLANNED	6/11/2021	10	340	34
PLANNED	6/11/2021	5	260	52
PLANNED	6/11/2021	16	2,240	140
PLANNED	6/11/2021	3	372	124
PLANNED	6/11/2021	1	47	47
PLANNED	6/11/2021	1	119	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/11/2021	3	138	46
PLANNED	6/11/2021	1	17	17
PLANNED	6/11/2021	2	78	39
PLANNED	6/11/2021	2	78	39
PLANNED	6/11/2021	2	38	19
PLANNED	6/11/2021	7	21	3
PLANNED	6/11/2021	8	80	10
PLANNED	6/11/2021	2	228	114
PLANNED	6/11/2021	7	77	11
PLANNED	6/11/2021	1	33	33
CUSTOMER REQUEST	6/11/2021	1	208	208
PLANNED	6/11/2021	6	108	18
PLANNED	6/11/2021	1	54	54
PLANNED	6/12/2021	1	17	17
PLANNED	6/12/2021	3	324	108
PLANNED	6/12/2021	1	158	158
PLANNED	6/12/2021	2	126	63
PLANNED	6/12/2021	1	392	392
PLANNED	6/12/2021	1	21	21
PLANNED	6/12/2021	3	756	252
CUSTOMER REQUEST	6/12/2021	1	302	302
PLANNED	6/12/2021	1	287	287
PLANNED	6/12/2021	3	339	113
PLANNED	6/12/2021	1	222	222
PLANNED	6/12/2021	1	95	95
PLANNED	6/12/2021	3	285	95
CUSTOMER REQUEST	6/12/2021	1	551	551
PLANNED	6/12/2021	5	765	153
PLANNED	6/12/2021	8	48	6
PLANNED	6/12/2021	9	882	98
PLANNED	6/12/2021	8	72	9
PLANNED	6/12/2021	3	348	116
PLANNED	6/12/2021	4	36	9
PLANNED	6/12/2021	10	780	78
PLANNED	6/12/2021	9	333	37
PLANNED	6/12/2021	6	438	73
PLANNED	6/12/2021	2	220	110
PLANNED	6/12/2021	3	183	61
PLANNED	6/13/2021	2	148	74
PLANNED	6/13/2021	1	65	65
PLANNED	6/13/2021	2	374	187

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/13/2021	1	80	80
PLANNED	6/13/2021	14	1,232	88
PLANNED	6/13/2021	6	750	125
PLANNED	6/13/2021	2	438	219
PLANNED	6/13/2021	5	690	138
PLANNED	6/13/2021	7	616	88
PLANNED	6/13/2021	10	1,725	269
PLANNED	6/13/2021	1	48	48
PLANNED	6/13/2021	5	190	38
PLANNED	6/13/2021	1	238	238
PLANNED	6/13/2021	12	1,152	96
PLANNED	6/13/2021	2	12	6
PLANNED	6/13/2021	4	948	237
PLANNED	6/13/2021	8	520	65
PLANNED	6/13/2021	3	492	164
PLANNED	6/13/2021	12	408	34
PLANNED	6/14/2021	3	213	71
PLANNED	6/14/2021	1	115	115
PLANNED	6/14/2021	2	384	197
PLANNED	6/14/2021	3	207	69
PLANNED	6/14/2021	1	12	12
PLANNED	6/14/2021	10	130	13
PLANNED	6/14/2021	10	420	42
PLANNED	6/14/2021	4	120	30
PLANNED	6/14/2021	3	246	90
PLANNED	6/14/2021	10	80	8
PLANNED	6/14/2021	2	74	40
PLANNED	6/14/2021	4	324	126
PLANNED	6/14/2021	3	294	98
PLANNED	6/14/2021	6	12	2
PLANNED	6/14/2021	12	24	2
CUSTOMER REQUEST	6/14/2021	1	24	24
CUSTOMER REQUEST	6/14/2021	1	205	205
CUSTOMER REQUEST	6/14/2021	5	435	87
PLANNED	6/14/2021	1	15	15
PLANNED	6/14/2021	2	74	37
PLANNED	6/14/2021	1	18	18
PLANNED	6/14/2021	6	90	15
PLANNED	6/14/2021	1	14	14
PLANNED	6/14/2021	6	510	85
PLANNED	6/14/2021	7	42	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/14/2021	10	1,320	132
PLANNED	6/14/2021	5	295	59
PLANNED	6/14/2021	8	280	35
PLANNED	6/14/2021	1	347	347
PLANNED	6/14/2021	4	264	66
PLANNED	6/14/2021	2	18	9
PLANNED	6/14/2021	1	11	11
PLANNED	6/14/2021	1	53	53
PLANNED	6/14/2021	2	24	12
PLANNED	6/14/2021	5	65	13
CUSTOMER REQUEST	6/14/2021	37	1,184	32
PLANNED	6/14/2021	2	24	12
CUSTOMER REQUEST	6/14/2021	1	139	139
PLANNED	6/14/2021	1	66	66
PLANNED	6/14/2021	3	18	6
PLANNED	6/14/2021	45	4,950	110
PLANNED	6/14/2021	4	60	15
PLANNED	6/14/2021	2	38	19
PLANNED	6/14/2021	4	124	31
PLANNED	6/14/2021	3	51	17
CUSTOMER REQUEST	6/14/2021	21	4,578	218
PLANNED	6/14/2021	4	28	7
PLANNED	6/14/2021	3	45	15
PLANNED	6/14/2021	3	102	34
PLANNED	6/14/2021	4	392	98
PLANNED	6/14/2021	5	415	83
PLANNED	6/14/2021	2	162	81
PLANNED	6/14/2021	2	36	18
PLANNED	6/14/2021	13	143	11
PLANNED	6/14/2021	4	28	7
PLANNED	6/14/2021	25	5,250	210
PLANNED	6/14/2021	11	990	90
PLANNED	6/14/2021	14	1,624	116
PLANNED	6/14/2021	3	30	10
PLANNED	6/14/2021	1	224	224
PLANNED	6/14/2021	1	224	224
PLANNED	6/14/2021	54	15,498	287
PLANNED	6/14/2021	1	224	224
PLANNED	6/14/2021	6	678	113
PLANNED	6/14/2021	1	9	9
PLANNED	6/14/2021	2	159	97

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	6/14/2021	2	14	7
PLANNED	6/14/2021	1	10	10
PLANNED	6/14/2021	4	324	81
PLANNED	6/14/2021	4	24	6
PLANNED	6/14/2021	2	32	16
PLANNED	6/14/2021	8	128	16
PLANNED	6/14/2021	4	320	80
PLANNED	6/14/2021	9	306	34
PLANNED	6/14/2021	2	22	11
CUSTOMER REQUEST	6/14/2021	6	84	14
PLANNED	6/14/2021	8	232	29
PLANNED	6/14/2021	4	164	41
PLANNED	6/14/2021	1	72	72
PLANNED	6/14/2021	1	7	7
PLANNED	6/14/2021	3	18	6
CUSTOMER REQUEST	6/14/2021	2	46	23
PLANNED	6/14/2021	2	26	13
PLANNED	6/14/2021	1	9	9
PLANNED	6/14/2021	5	50	10
PLANNED	6/14/2021	4	52	13
PLANNED	6/14/2021	3	143	59
PLANNED	6/14/2021	1	8	8
PLANNED	6/14/2021	2	12	6
PLANNED	6/14/2021	2	22	11
PLANNED	6/14/2021	1	5	5
PLANNED	6/14/2021	1	53	53
PLANNED	6/14/2021	3	36	12
PLANNED	6/14/2021	1	8	8
PLANNED	6/14/2021	3	15	5
PLANNED	6/14/2021	1	7	7
PLANNED	6/14/2021	1	14	14
PLANNED	6/14/2021	14	966	69
PLANNED	6/14/2021	6	36	6
PLANNED	6/14/2021	14	1,218	87
PLANNED	6/14/2021	29	2,378	82
PLANNED	6/14/2021	3	156	52
PLANNED	6/14/2021	9	423	47
PLANNED	6/14/2021	1	6	6
PLANNED	6/14/2021	3	84	28
CUSTOMER REQUEST	6/14/2021	1	65	65
PLANNED	6/14/2021	1	24	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/14/2021	3	21	7
PLANNED	6/14/2021	3	72	24
PLANNED	6/14/2021	3	36	12
PLANNED	6/14/2021	1	9	9
PLANNED	6/14/2021	2	14	7
PLANNED	6/14/2021	4	52	13
PLANNED	6/14/2021	3	36	12
PLANNED	6/14/2021	4	80	20
PLANNED	6/14/2021	1	29	29
PLANNED	6/14/2021	2	22	11
PLANNED	6/14/2021	1	13	13
PLANNED	6/14/2021	1	49	49
PLANNED	6/14/2021	1	134	134
PLANNED	6/14/2021	4	112	28
PLANNED	6/14/2021	6	36	6
PLANNED	6/14/2021	2	12	6
PLANNED	6/14/2021	1	13	13
PLANNED	6/14/2021	2	248	124
PLANNED	6/14/2021	2	94	47
PLANNED	6/14/2021	1	23	23
CUSTOMER REQUEST	6/14/2021	1	184	184
PLANNED	6/14/2021	2	46	23
PLANNED	6/14/2021	4	24	6
PLANNED	6/14/2021	7	56	8
PLANNED	6/14/2021	3	111	37
PLANNED	6/14/2021	4	24	6
PLANNED	6/14/2021	7	49	7
PLANNED	6/14/2021	3	207	69
PLANNED	6/14/2021	1	60	60
PLANNED	6/14/2021	1	9	9
PLANNED	6/14/2021	1	12	12
PLANNED	6/14/2021	2	18	9
PLANNED	6/14/2021	2	18	9
PLANNED	6/14/2021	2	249	148
PLANNED	6/14/2021	10	640	64
PLANNED	6/14/2021	1	15	15
PLANNED	6/14/2021	4	120	30
PLANNED	6/14/2021	3	33	11
PLANNED	6/14/2021	1	64	64
PLANNED	6/14/2021	1	63	63
PLANNED	6/14/2021	2	136	68

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/14/2021	6	42	7
PLANNED	6/14/2021	3	78	26
PLANNED	6/14/2021	6	60	10
PLANNED	6/14/2021	2	195	101
PLANNED	6/14/2021	4	380	95
PLANNED	6/14/2021	3	18	6
PLANNED	6/14/2021	10	970	97
PLANNED	6/14/2021	2	66	33
PLANNED	6/14/2021	3	15	5
PLANNED	6/14/2021	5	30	6
PLANNED	6/14/2021	9	630	70
PLANNED	6/14/2021	3	60	20
PLANNED	6/14/2021	1	22	22
PLANNED	6/14/2021	2	28	14
PLANNED	6/14/2021	4	56	14
PLANNED	6/14/2021	7	189	27
PLANNED	6/14/2021	2	14	7
PLANNED	6/14/2021	8	40	5
PLANNED	6/14/2021	1	8	8
PLANNED	6/14/2021	3	30	10
PLANNED	6/14/2021	1	14	14
PLANNED	6/14/2021	2	40	20
PLANNED	6/14/2021	5	25	5
PLANNED	6/14/2021	1	13	13
PLANNED	6/14/2021	8	32	4
PLANNED	6/14/2021	5	30	6
PLANNED	6/14/2021	2	12	6
PLANNED	6/14/2021	5	405	81
CUSTOMER REQUEST	6/14/2021	7	133	19
PLANNED	6/14/2021	6	24	4
PLANNED	6/14/2021	1	11	11
CUSTOMER REQUEST	6/14/2021	1	90	90
PLANNED	6/14/2021	1	19	19
PLANNED	6/14/2021	2	18	9
PLANNED	6/14/2021	2	10	5
PLANNED	6/14/2021	5	235	47
PLANNED	6/14/2021	15	4,155	277
PLANNED	6/14/2021	1	16	16
PLANNED	6/14/2021	1	146	146
PLANNED	6/15/2021	1	45	45
PLANNED	6/15/2021	1	49	49

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	18	3,492	194
PLANNED	6/15/2021	1	281	281
PLANNED	6/15/2021	1	281	281
PLANNED	6/15/2021	1	643	643
PLANNED	6/15/2021	1	82	82
PLANNED	6/15/2021	1	39	39
PLANNED	6/15/2021	4	40	10
PLANNED	6/15/2021	5	325	65
PLANNED	6/15/2021	3	327	109
PLANNED	6/15/2021	7	203	29
PLANNED	6/15/2021	4	80	20
PLANNED	6/15/2021	3	90	30
PLANNED	6/15/2021	12	348	29
PLANNED	6/15/2021	1	15	15
PLANNED	6/15/2021	7	819	117
PLANNED	6/15/2021	4	176	44
PLANNED	6/15/2021	5	110	22
PLANNED	6/15/2021	2	170	85
PLANNED	6/15/2021	2	66	33
PLANNED	6/15/2021	2	75	45
CUSTOMER REQUEST	6/15/2021	2	2	1,479
PLANNED	6/15/2021	3	222	74
CUSTOMER REQUEST	6/15/2021	1	1	1,476
PLANNED	6/15/2021	2	128	64
PLANNED	6/15/2021	3	24	8
PLANNED	6/15/2021	2	236	118
PLANNED	6/15/2021	4	36	9
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	1	161	161
PLANNED	6/15/2021	1	68	68
CUSTOMER REQUEST	6/15/2021	22	814	37
PLANNED	6/15/2021	5	110	22
PLANNED	6/15/2021	2	18	9
PLANNED	6/15/2021	1	7	7
PLANNED	6/15/2021	1	14	14
PLANNED	6/15/2021	3	585	195
PLANNED	6/15/2021	5	175	35
PLANNED	6/15/2021	6	1,038	173
PLANNED	6/15/2021	2	22	11
PLANNED	6/15/2021	3	180	60
CUSTOMER REQUEST	6/15/2021	23	2,277	99

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	1	34	34
PLANNED	6/15/2021	7	350	50
CUSTOMER REQUEST	6/15/2021	21	2,058	98
PLANNED	6/15/2021	6	48	8
PLANNED	6/15/2021	9	144	16
PLANNED	6/15/2021	3	33	11
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	4	72	18
PLANNED	6/15/2021	8	128	16
PLANNED	6/15/2021	1	21	21
PLANNED	6/15/2021	1	11	11
PLANNED	6/15/2021	2	192	96
CUSTOMER REQUEST	6/15/2021	1	86	86
PLANNED	6/15/2021	3	336	112
PLANNED	6/15/2021	4	128	32
PLANNED	6/15/2021	1	11	11
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	1	8	8
PLANNED	6/15/2021	3	36	12
PLANNED	6/15/2021	6	308	104
PLANNED	6/15/2021	1	147	147
PLANNED	6/15/2021	2	18	9
PLANNED	6/15/2021	2	24	12
PLANNED	6/15/2021	2	18	9
PLANNED	6/15/2021	4	84	21
PLANNED	6/15/2021	3	18	6
PLANNED	6/15/2021	2	14	7
PLANNED	6/15/2021	2	12	6
PLANNED	6/15/2021	27	3,753	139
PLANNED	6/15/2021	2	166	83
PLANNED	6/15/2021	1	146	146
PLANNED	6/15/2021	6	120	20
PLANNED	6/15/2021	2	38	19
PLANNED	6/15/2021	1	328	328
PLANNED	6/15/2021	4	32	8
PLANNED	6/15/2021	2	28	14
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	7	77	11
PLANNED	6/15/2021	14	1,610	115
PLANNED	6/15/2021	11	1,210	110
PLANNED	6/15/2021	14	1,624	116

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	3	96	32
PLANNED	6/15/2021	8	48	6
PLANNED	6/15/2021	1	46	46
PLANNED	6/15/2021	4	420	105
PLANNED	6/15/2021	10	1,690	169
PLANNED	6/15/2021	4	520	130
PLANNED	6/15/2021	8	232	29
PLANNED	6/15/2021	1	55	55
CUSTOMER REQUEST	6/15/2021	4	100	25
PLANNED	6/15/2021	4	48	12
PLANNED	6/15/2021	10	1,360	136
PLANNED	6/15/2021	10	1,000	100
PLANNED	6/15/2021	10	1,000	100
PLANNED	6/15/2021	4	40	10
PLANNED	6/15/2021	1	6	6
PLANNED	6/15/2021	3	42	14
PLANNED	6/15/2021	2	20	10
PLANNED	6/15/2021	3	498	166
PLANNED	6/15/2021	12	1,596	133
PLANNED	6/15/2021	6	420	70
PLANNED	6/15/2021	2	96	48
PLANNED	6/15/2021	1	5	5
PLANNED	6/15/2021	2	86	43
PLANNED	6/15/2021	2	1,018	509
PLANNED	6/15/2021	9	765	85
PLANNED	6/15/2021	2	1,016	508
PLANNED	6/15/2021	17	1,088	64
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	1	114	114
PLANNED	6/15/2021	2	18	9
PLANNED	6/15/2021	2	12	6
PLANNED	6/15/2021	1	16	16
PLANNED	6/15/2021	1	15	15
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	6	48	8
PLANNED	6/15/2021	4	468	117
PLANNED	6/15/2021	1	304	304
PLANNED	6/15/2021	2	94	47
PLANNED	6/15/2021	4	516	129
PLANNED	6/15/2021	16	2,144	134

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	56	7,504	134
PLANNED	6/15/2021	2	108	54
PLANNED	6/15/2021	5	30	6
PLANNED	6/15/2021	3	51	17
PLANNED	6/15/2021	5	120	24
PLANNED	6/15/2021	2	16	8
PLANNED	6/15/2021	3	48	16
PLANNED	6/15/2021	9	585	65
CUSTOMER REQUEST	6/15/2021	6	1,158	193
PLANNED	6/15/2021	8	1,776	222
PLANNED	6/15/2021	8	1,776	222
PLANNED	6/15/2021	1	14	14
PLANNED	6/15/2021	3	201	67
PLANNED	6/15/2021	6	102	17
PLANNED	6/15/2021	3	18	6
PLANNED	6/15/2021	4	1,144	286
PLANNED	6/15/2021	7	91	13
PLANNED	6/15/2021	7	56	8
PLANNED	6/15/2021	7	133	19
PLANNED	6/15/2021	2	34	17
PLANNED	6/15/2021	7	49	7
CUSTOMER REQUEST	6/15/2021	1	416	416
PLANNED	6/15/2021	11	1,199	109
PLANNED	6/15/2021	1	8	8
PLANNED	6/15/2021	5	595	119
PLANNED	6/15/2021	9	54	6
PLANNED	6/15/2021	4	28	7
PLANNED	6/15/2021	5	165	33
PLANNED	6/15/2021	4	40	10
PLANNED	6/15/2021	2	14	7
PLANNED	6/15/2021	2	16	8
PLANNED	6/15/2021	3	87	29
PLANNED	6/15/2021	5	650	130
PLANNED	6/15/2021	1	14	14
PLANNED	6/15/2021	3	198	66
PLANNED	6/15/2021	5	955	191
PLANNED	6/15/2021	6	126	21
PLANNED	6/15/2021	2	18	9
PLANNED	6/15/2021	2	22	11
PLANNED	6/15/2021	2	124	62
PLANNED	6/15/2021	2	40	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	9	126	14
PLANNED	6/15/2021	2	22	11
PLANNED	6/15/2021	9	261	29
PLANNED	6/15/2021	1	153	153
CUSTOMER REQUEST	6/15/2021	6	786	131
PLANNED	6/15/2021	8	80	10
PLANNED	6/15/2021	4	36	9
PLANNED	6/15/2021	1	6	6
PLANNED	6/15/2021	2	26	13
PLANNED	6/15/2021	6	180	30
PLANNED	6/15/2021	1	8	8
PLANNED	6/15/2021	6	132	22
PLANNED	6/15/2021	5	65	13
PLANNED	6/15/2021	2	16	8
PLANNED	6/15/2021	6	240	40
PLANNED	6/15/2021	3	63	21
PLANNED	6/15/2021	2	166	83
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	6	930	155
PLANNED	6/15/2021	1	12	12
PLANNED	6/15/2021	2	246	123
CUSTOMER REQUEST	6/15/2021	4	132	33
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	1	9	9
PLANNED	6/15/2021	2	100	50
PLANNED	6/15/2021	1	11	11
PLANNED	6/15/2021	1	12	12
CUSTOMER REQUEST	6/15/2021	1	418	418
PLANNED	6/15/2021	8	152	19
PLANNED	6/15/2021	5	45	9
PLANNED	6/15/2021	4	56	14
PLANNED	6/15/2021	3	18	6
PLANNED	6/15/2021	1	10	10
PLANNED	6/15/2021	6	204	34
PLANNED	6/15/2021	2	26	13
PLANNED	6/15/2021	4	420	105
PLANNED	6/15/2021	1	8	8
PLANNED	6/15/2021	8	40	5
PLANNED	6/15/2021	8	48	6
PLANNED	6/15/2021	6	732	122

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	7	28	4
PLANNED	6/15/2021	1	23	23
PLANNED	6/15/2021	6	54	9
PLANNED	6/15/2021	6	102	17
PLANNED	6/15/2021	1	5	5
PLANNED	6/15/2021	1	8	8
CUSTOMER REQUEST	6/15/2021	1	23	23
PLANNED	6/15/2021	4	56	14
PLANNED	6/15/2021	1	15	15
PLANNED	6/15/2021	9	117	13
PLANNED	6/15/2021	7	49	7
PLANNED	6/15/2021	2	14	7
PLANNED	6/15/2021	4	764	191
PLANNED	6/15/2021	3	30	10
PLANNED	6/15/2021	1	8	8
PLANNED	6/15/2021	1	13	13
PLANNED	6/15/2021	3	21	7
CUSTOMER REQUEST	6/15/2021	6	18	3
PLANNED	6/15/2021	3	12	4
PLANNED	6/15/2021	5	35	7
PLANNED	6/15/2021	4	36	9
PLANNED	6/15/2021	3	12	4
PLANNED	6/15/2021	1	11	11
PLANNED	6/15/2021	5	180	36
PLANNED	6/15/2021	2	212	106
PLANNED	6/15/2021	3	318	106
PLANNED	6/15/2021	1	6	6
PLANNED	6/15/2021	3	30	10
PLANNED	6/15/2021	5	10	2
PLANNED	6/15/2021	1	4	4
PLANNED	6/15/2021	3	45	15
PLANNED	6/15/2021	11	272	72
PLANNED	6/15/2021	3	117	39
PLANNED	6/15/2021	2	62	31
PLANNED	6/15/2021	4	112	28
PLANNED	6/15/2021	12	348	29
PLANNED	6/15/2021	6	144	24
PLANNED	6/15/2021	7	140	20
PLANNED	6/15/2021	7	119	17
PLANNED	6/15/2021	3	48	16
PLANNED	6/15/2021	4	88	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/15/2021	7	21	3
PLANNED	6/15/2021	3	36	12
PLANNED	6/15/2021	3	33	11
PLANNED	6/15/2021	1	49	49
PLANNED	6/15/2021	6	84	14
PLANNED	6/15/2021	3	21	7
PLANNED	6/15/2021	122	4,270	35
PLANNED	6/15/2021	2	136	68
PLANNED	6/15/2021	1	66	66
PLANNED	6/15/2021	8	528	66
PLANNED	6/15/2021	2	164	82
PLANNED	6/16/2021	2	14	7
PLANNED	6/16/2021	1	163	163
PLANNED	6/16/2021	1	168	168
PLANNED	6/16/2021	6	132	22
PLANNED	6/16/2021	2	204	102
PLANNED	6/16/2021	1	37	37
CUSTOMER REQUEST	6/16/2021	1	164	164
PLANNED	6/16/2021	4	332	83
PLANNED	6/16/2021	2	150	75
CUSTOMER REQUEST	6/16/2021	6	2,484	414
PLANNED	6/16/2021	4	36	9
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	3	21	7
PLANNED	6/16/2021	3	51	17
PLANNED	6/16/2021	2	56	28
PLANNED	6/16/2021	3	327	109
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	5	120	24
PLANNED	6/16/2021	2	268	134
PLANNED	6/16/2021	2	34	17
PLANNED	6/16/2021	2	50	25
PLANNED	6/16/2021	2	38	19
PLANNED	6/16/2021	10	190	19
PLANNED	6/16/2021	4	28	7
PLANNED	6/16/2021	2	205	104
PLANNED	6/16/2021	4	208	52
PLANNED	6/16/2021	3	636	212
PLANNED	6/16/2021	3	81	27
CUSTOMER REQUEST	6/16/2021	11	297	27
PLANNED	6/16/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	4	104	26
PLANNED	6/16/2021	2	56	28
PLANNED	6/16/2021	4	76	19
PLANNED	6/16/2021	10	960	96
PLANNED	6/16/2021	1	145	145
PLANNED	6/16/2021	5	345	69
PLANNED	6/16/2021	3	95	38
PLANNED	6/16/2021	1	245	245
PLANNED	6/16/2021	3	87	29
PLANNED	6/16/2021	1	51	51
PLANNED	6/16/2021	13	1,274	98
PLANNED	6/16/2021	2	166	83
PLANNED	6/16/2021	4	64	16
PLANNED	6/16/2021	5	150	30
PLANNED	6/16/2021	1	11	11
PLANNED	6/16/2021	7	357	51
PLANNED	6/16/2021	1	24	24
PLANNED	6/16/2021	1	53	53
PLANNED	6/16/2021	8	56	7
PLANNED	6/16/2021	6	1,794	299
PLANNED	6/16/2021	4	28	7
PLANNED	6/16/2021	2	18	9
PLANNED	6/16/2021	2	52	26
PLANNED	6/16/2021	2	28	14
PLANNED	6/16/2021	1	21	21
PLANNED	6/16/2021	2	28	14
PLANNED	6/16/2021	2	64	32
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	4	60	15
PLANNED	6/16/2021	1	43	43
PLANNED	6/16/2021	15	2,070	138
PLANNED	6/16/2021	17	5,389	317
PLANNED	6/16/2021	1	63	63
PLANNED	6/16/2021	3	480	160
PLANNED	6/16/2021	9	846	94
PLANNED	6/16/2021	2	530	265
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	3	60	20
PLANNED	6/16/2021	1	127	127
PLANNED	6/16/2021	2	58	29
PLANNED	6/16/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	2	14	7
PLANNED	6/16/2021	7	1,008	144
PLANNED	6/16/2021	3	48	16
PLANNED	6/16/2021	7	770	110
PLANNED	6/16/2021	5	45	9
PLANNED	6/16/2021	4	28	7
PLANNED	6/16/2021	3	18	6
PLANNED	6/16/2021	5	1,100	220
PLANNED	6/16/2021	38	10,070	265
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	2	238	119
PLANNED	6/16/2021	2	56	28
PLANNED	6/16/2021	5	425	85
PLANNED	6/16/2021	2	238	119
PLANNED	6/16/2021	16	3,856	241
PLANNED	6/16/2021	2	54	27
PLANNED	6/16/2021	7	1,680	240
PLANNED	6/16/2021	36	8,604	239
PLANNED	6/16/2021	3	72	24
PLANNED	6/16/2021	3	114	38
PLANNED	6/16/2021	2	84	42
PLANNED	6/16/2021	3	27	9
PLANNED	6/16/2021	4	168	42
PLANNED	6/16/2021	12	972	81
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	1	63	63
PLANNED	6/16/2021	8	864	108
PLANNED	6/16/2021	1	96	96
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	9	306	34
PLANNED	6/16/2021	2	128	64
PLANNED	6/16/2021	4	12	3
PLANNED	6/16/2021	5	1,330	266
PLANNED	6/16/2021	3	249	83
PLANNED	6/16/2021	1	117	117
PLANNED	6/16/2021	2	16	8
PLANNED	6/16/2021	1	64	64
PLANNED	6/16/2021	2	30	15
PLANNED	6/16/2021	5	75	15
PLANNED	6/16/2021	6	228	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	2	168	84
PLANNED	6/16/2021	1	138	138
PLANNED	6/16/2021	1	42	42
PLANNED	6/16/2021	2	12	6
PLANNED	6/16/2021	3	324	108
PLANNED	6/16/2021	25	225	9
PLANNED	6/16/2021	8	864	108
PLANNED	6/16/2021	4	36	9
PLANNED	6/16/2021	4	44	11
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	2	70	35
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	1	5	5
PLANNED	6/16/2021	1	36	36
PLANNED	6/16/2021	1	5	5
PLANNED	6/16/2021	1	10	10
PLANNED	6/16/2021	4	528	197
PLANNED	6/16/2021	5	25	5
PLANNED	6/16/2021	2	12	6
PLANNED	6/16/2021	3	39	13
PLANNED	6/16/2021	2	12	6
PLANNED	6/16/2021	4	648	162
PLANNED	6/16/2021	1	50	50
PLANNED	6/16/2021	4	92	23
PLANNED	6/16/2021	3	27	9
PLANNED	6/16/2021	1	13	13
PLANNED	6/16/2021	51	6,222	122
PLANNED	6/16/2021	2	116	58
PLANNED	6/16/2021	11	1,331	121
PLANNED	6/16/2021	2	20	10
PLANNED	6/16/2021	1	9	9
PLANNED	6/16/2021	4	76	19
PLANNED	6/16/2021	4	120	30
PLANNED	6/16/2021	2	82	41
PLANNED	6/16/2021	1	8	8
CUSTOMER REQUEST	6/16/2021	9	288	32
PLANNED	6/16/2021	72	288	4
PLANNED	6/16/2021	4	88	22
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	16	1,936	121

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	4	60	15
CUSTOMER REQUEST	6/16/2021	8	32	4
PLANNED	6/16/2021	2	16	8
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	1	31	31
CUSTOMER REQUEST	6/16/2021	1	75	75
PLANNED	6/16/2021	4	96	24
PLANNED	6/16/2021	5	680	136
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	2	14	7
PLANNED	6/16/2021	6	78	13
PLANNED	6/16/2021	4	44	11
CUSTOMER REQUEST	6/16/2021	18	810	45
PLANNED	6/16/2021	3	69	23
PLANNED	6/16/2021	1	89	89
PLANNED	6/16/2021	7	644	92
PLANNED	6/16/2021	3	267	89
PLANNED	6/16/2021	5	25	5
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	3	309	103
PLANNED	6/16/2021	138	9,660	70
PLANNED	6/16/2021	3	336	112
PLANNED	6/16/2021	4	112	28
PLANNED	6/16/2021	4	28	7
PLANNED	6/16/2021	2	42	21
PLANNED	6/16/2021	2	96	48
PLANNED	6/16/2021	6	1,092	182
PLANNED	6/16/2021	4	64	16
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	1	124	124
PLANNED	6/16/2021	1	66	66
PLANNED	6/16/2021	3	15	5
PLANNED	6/16/2021	1	9	9
CUSTOMER REQUEST	6/16/2021	12	72	6
PLANNED	6/16/2021	3	87	29
PLANNED	6/16/2021	4	124	31
PLANNED	6/16/2021	2	30	15
PLANNED	6/16/2021	3	24	8
PLANNED	6/16/2021	4	68	17
PLANNED	6/16/2021	4	120	30
PLANNED	6/16/2021	2	123	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	1	70	70
PLANNED	6/16/2021	2	28	14
PLANNED	6/16/2021	3	42	14
PLANNED	6/16/2021	2	304	152
PLANNED	6/16/2021	21	2,268	108
PLANNED	6/16/2021	2	238	119
PLANNED	6/16/2021	2	28	14
PLANNED	6/16/2021	6	36	6
PLANNED	6/16/2021	2	66	33
PLANNED	6/16/2021	3	255	85
PLANNED	6/16/2021	6	1,164	194
PLANNED	6/16/2021	9	45	5
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	7	1,358	194
PLANNED	6/16/2021	2	10	5
PLANNED	6/16/2021	2	42	21
PLANNED	6/16/2021	7	336	48
PLANNED	6/16/2021	5	245	49
PLANNED	6/16/2021	1	27	27
PLANNED	6/16/2021	8	480	60
CUSTOMER REQUEST	6/16/2021	44	5,148	117
PLANNED	6/16/2021	1	5	5
PLANNED	6/16/2021	3	21	7
PLANNED	6/16/2021	5	50	10
PLANNED	6/16/2021	2	14	7
PLANNED	6/16/2021	2	16	8
PLANNED	6/16/2021	3	24	8
PLANNED	6/16/2021	2	8	4
PLANNED	6/16/2021	2	150	75
PLANNED	6/16/2021	3	228	76
PLANNED	6/16/2021	3	15	5
PLANNED	6/16/2021	2	8	4
PLANNED	6/16/2021	2	14	7
PLANNED	6/16/2021	2	18	9
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	4	136	34
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	4	64	16
PLANNED	6/16/2021	25	1,425	57
PLANNED	6/16/2021	7	42	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/16/2021	3	177	59
PLANNED	6/16/2021	1	8	8
PLANNED	6/16/2021	1	7	7
PLANNED	6/16/2021	1	4	4
CUSTOMER REQUEST	6/16/2021	8	360	45
PLANNED	6/16/2021	2	20	10
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	1	32	32
PLANNED	6/16/2021	1	55	55
PLANNED	6/16/2021	5	35	7
CUSTOMER REQUEST	6/16/2021	5	25	5
PLANNED	6/16/2021	7	504	72
PLANNED	6/16/2021	2	58	29
PLANNED	6/16/2021	5	150	30
PLANNED	6/16/2021	1	6	6
PLANNED	6/16/2021	1	46	46
PLANNED	6/16/2021	1	60	60
PLANNED	6/16/2021	7	70	10
PLANNED	6/16/2021	3	33	11
PLANNED	6/16/2021	2	512	256
PLANNED	6/16/2021	6	432	72
PLANNED	6/16/2021	1	43	43
PLANNED	6/16/2021	22	968	44
PLANNED	6/16/2021	12	156	13
PLANNED	6/16/2021	1	276	276
PLANNED	6/16/2021	1	108	108
PLANNED	6/16/2021	3	213	71
CUSTOMER REQUEST	6/16/2021	42	1,512	36
PLANNED	6/16/2021	1	69	69
PLANNED	6/17/2021	1	81	81
PLANNED	6/17/2021	2	104	52
PLANNED	6/17/2021	3	153	51
PLANNED	6/17/2021	3	135	45
PLANNED	6/17/2021	7	567	81
PLANNED	6/17/2021	5	50	10
PLANNED	6/17/2021	4	76	19
PLANNED	6/17/2021	1	7	7
PLANNED	6/17/2021	7	217	31
PLANNED	6/17/2021	2	54	27
PLANNED	6/17/2021	3	94	37
PLANNED	6/17/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/17/2021	5	60	12
PLANNED	6/17/2021	3	209	104
PLANNED	6/17/2021	3	87	29
PLANNED	6/17/2021	3	45	15
PLANNED	6/17/2021	4	258	91
PLANNED	6/17/2021	2	16	8
PLANNED	6/17/2021	2	4	2
PLANNED	6/17/2021	1	7	7
PLANNED	6/17/2021	5	10	2
PLANNED	6/17/2021	1	21	21
PLANNED	6/17/2021	1	16	16
PLANNED	6/17/2021	3	42	14
PLANNED	6/17/2021	1	78	78
PLANNED	6/17/2021	8	1,864	233
PLANNED	6/17/2021	2	82	41
PLANNED	6/17/2021	14	602	43
PLANNED	6/17/2021	2	230	115
PLANNED	6/17/2021	5	215	43
PLANNED	6/17/2021	18	774	43
PLANNED	6/17/2021	18	774	43
PLANNED	6/17/2021	1	14	14
PLANNED	6/17/2021	11	473	43
PLANNED	6/17/2021	1	6	6
PLANNED	6/17/2021	3	627	209
PLANNED	6/17/2021	18	1,854	103
PLANNED	6/17/2021	8	1,568	196
PLANNED	6/17/2021	2	248	124
PLANNED	6/17/2021	8	72	9
PLANNED	6/17/2021	8	1,568	196
PLANNED	6/17/2021	4	356	93
PLANNED	6/17/2021	2	50	25
PLANNED	6/17/2021	10	2,950	295
PLANNED	6/17/2021	5	20	4
PLANNED	6/17/2021	3	69	23
CUSTOMER REQUEST	6/17/2021	18	144	8
PLANNED	6/17/2021	4	56	14
PLANNED	6/17/2021	10	270	27
PLANNED	6/17/2021	9	99	11
PLANNED	6/17/2021	1	10	10
PLANNED	6/17/2021	1	7	7
PLANNED	6/17/2021	8	128	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	6/17/2021	7	28	4
PLANNED	6/17/2021	8	88	11
PLANNED	6/17/2021	13	676	52
PLANNED	6/17/2021	18	2,898	161
PLANNED	6/17/2021	3	51	17
PLANNED	6/17/2021	8	168	21
PLANNED	6/17/2021	1	9	9
PLANNED	6/17/2021	1	72	72
PLANNED	6/17/2021	4	468	117
PLANNED	6/17/2021	13	1,482	114
PLANNED	6/17/2021	1	11	11
PLANNED	6/17/2021	17	340	20
CUSTOMER REQUEST	6/17/2021	1	234	234
PLANNED	6/17/2021	3	45	15
PLANNED	6/17/2021	2	14	7
PLANNED	6/17/2021	2	354	177
CUSTOMER REQUEST	6/17/2021	5	235	47
PLANNED	6/17/2021	6	504	84
CUSTOMER REQUEST	6/17/2021	1	362	362
PLANNED	6/17/2021	5	95	19
PLANNED	6/17/2021	3	27	9
PLANNED	6/17/2021	4	460	115
PLANNED	6/17/2021	1	12	12
PLANNED	6/17/2021	7	112	16
CUSTOMER REQUEST	6/17/2021	5	25	5
PLANNED	6/17/2021	4	212	53
PLANNED	6/17/2021	8	848	106
PLANNED	6/17/2021	5	530	106
PLANNED	6/17/2021	1	47	47
PLANNED	6/17/2021	1	6	6
PLANNED	6/17/2021	5	510	102
PLANNED	6/17/2021	9	279	31
PLANNED	6/17/2021	2	14	7
PLANNED	6/17/2021	3	132	44
PLANNED	6/17/2021	1	7	7
PLANNED	6/17/2021	4	40	10
PLANNED	6/17/2021	2	16	8
PLANNED	6/17/2021	7	119	17
PLANNED	6/17/2021	5	290	58
PLANNED	6/17/2021	6	36	6
PLANNED	6/17/2021	3	432	144

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/17/2021	1	10	10
CUSTOMER REQUEST	6/17/2021	1	129	129
PLANNED	6/17/2021	1	133	133
PLANNED	6/17/2021	124	28,396	229
PLANNED	6/17/2021	4	136	34
PLANNED	6/17/2021	2	70	35
PLANNED	6/17/2021	3	105	35
PLANNED	6/17/2021	2	14	7
PLANNED	6/17/2021	1	9	9
PLANNED	6/17/2021	3	231	77
PLANNED	6/17/2021	13	1,573	121
PLANNED	6/17/2021	1	118	118
PLANNED	6/17/2021	3	72	24
PLANNED	6/17/2021	2	16	8
PLANNED	6/17/2021	4	24	6
PLANNED	6/17/2021	2	10	5
PLANNED	6/17/2021	2	6	3
PLANNED	6/17/2021	2	18	9
PLANNED	6/17/2021	2	22	11
PLANNED	6/17/2021	7	1,099	157
PLANNED	6/17/2021	2	20	10
PLANNED	6/17/2021	4	96	24
PLANNED	6/17/2021	1	11	11
PLANNED	6/17/2021	14	280	20
PLANNED	6/17/2021	6	84	14
PLANNED	6/17/2021	26	467	148
PLANNED	6/17/2021	1	127	127
PLANNED	6/17/2021	1	126	126
PLANNED	6/17/2021	1	110	110
PLANNED	6/17/2021	3	24	8
PLANNED	6/17/2021	2	84	42
CUSTOMER REQUEST	6/17/2021	1	125	125
PLANNED	6/17/2021	3	271	109
PLANNED	6/17/2021	1	8	8
PLANNED	6/17/2021	12	228	19
PLANNED	6/17/2021	7	35	5
CUSTOMER REQUEST	6/17/2021	81	9,153	113
PLANNED	6/17/2021	1	20	20
PLANNED	6/17/2021	2	156	78
PLANNED	6/17/2021	1	18	18
PLANNED	6/17/2021	2	82	41

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/17/2021	1	80	80
PLANNED	6/17/2021	8	184	23
PLANNED	6/17/2021	1	9	9
PLANNED	6/17/2021	4	60	15
PLANNED	6/17/2021	1	6	6
PLANNED	6/17/2021	6	870	145
PLANNED	6/17/2021	6	468	78
PLANNED	6/17/2021	3	51	17
PLANNED	6/17/2021	1	156	156
PLANNED	6/17/2021	17	1,870	110
PLANNED	6/17/2021	5	30	6
PLANNED	6/17/2021	1	19	19
PLANNED	6/17/2021	1	10	10
PLANNED	6/17/2021	3	24	8
PLANNED	6/17/2021	15	7,905	527
PLANNED	6/17/2021	2	12	6
PLANNED	6/17/2021	1	215	215
CUSTOMER REQUEST	6/17/2021	11	187	17
PLANNED	6/17/2021	7	609	87
PLANNED	6/17/2021	1	79	79
PLANNED	6/17/2021	1	104	104
PLANNED	6/17/2021	1	4	4
PLANNED	6/17/2021	5	45	9
PLANNED	6/17/2021	9	630	70
PLANNED	6/17/2021	10	120	12
PLANNED	6/17/2021	2	54	27
PLANNED	6/17/2021	2	22	11
PLANNED	6/17/2021	3	27	9
PLANNED	6/17/2021	4	700	175
PLANNED	6/17/2021	8	256	137
CUSTOMER REQUEST	6/17/2021	6	78	13
PLANNED	6/17/2021	11	264	24
PLANNED	6/17/2021	2	116	58
PLANNED	6/17/2021	1	10	10
PLANNED	6/17/2021	1	44	44
PLANNED	6/17/2021	8	184	23
PLANNED	6/17/2021	1	43	43
PLANNED	6/17/2021	17	1,972	116
PLANNED	6/17/2021	12	180	15
PLANNED	6/17/2021	1	16	16
CUSTOMER REQUEST	6/17/2021	8	1,184	148

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/17/2021	3	27	9
PLANNED	6/17/2021	1	33	33
PLANNED	6/17/2021	1	148	148
PLANNED	6/17/2021	16	528	123
PLANNED	6/17/2021	4	56	14
PLANNED	6/17/2021	4	84	21
PLANNED	6/17/2021	2	72	36
PLANNED	6/17/2021	8	1,144	143
PLANNED	6/17/2021	6	114	19
PLANNED	6/17/2021	2	12	6
PLANNED	6/17/2021	3	54	18
PLANNED	6/17/2021	5	80	16
PLANNED	6/17/2021	4	44	11
PLANNED	6/17/2021	1	111	111
PLANNED	6/17/2021	2	12	6
PLANNED	6/17/2021	5	35	7
PLANNED	6/17/2021	2	144	72
PLANNED	6/17/2021	2	12	6
PLANNED	6/17/2021	2	68	34
PLANNED	6/17/2021	2	142	71
PLANNED	6/17/2021	1	14	14
PLANNED	6/17/2021	2	12	6
PLANNED	6/17/2021	1	45	45
PLANNED	6/17/2021	1	7	7
PLANNED	6/17/2021	3	126	42
PLANNED	6/17/2021	3	21	7
CUSTOMER REQUEST	6/17/2021	26	624	24
PLANNED	6/17/2021	6	246	41
PLANNED	6/17/2021	13	741	57
PLANNED	6/17/2021	12	648	54
PLANNED	6/17/2021	4	56	14
PLANNED	6/17/2021	1	275	275
PLANNED	6/17/2021	2	88	44
PLANNED	6/17/2021	8	1,552	194
PLANNED	6/17/2021	2	46	23
PLANNED	6/17/2021	2	214	107
PLANNED	6/17/2021	1	80	80
PLANNED	6/17/2021	9	711	79
PLANNED	6/17/2021	1	77	77
PLANNED	6/17/2021	11	1,474	134
PLANNED	6/17/2021	8	1,064	133

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/17/2021	1	21	21
PLANNED	6/17/2021	1	97	97
PLANNED	6/17/2021	7	581	83
PLANNED	6/18/2021	2	200	100
PLANNED	6/18/2021	1	58	58
PLANNED	6/18/2021	3	624	208
PLANNED	6/18/2021	2	432	216
PLANNED	6/18/2021	2	356	178
PLANNED	6/18/2021	1	86	86
PLANNED	6/18/2021	3	258	86
PLANNED	6/18/2021	1	5	5
PLANNED	6/18/2021	3	243	81
PLANNED	6/18/2021	5	75	15
PLANNED	6/18/2021	5	35	7
PLANNED	6/18/2021	2	16	8
PLANNED	6/18/2021	4	44	11
PLANNED	6/18/2021	4	104	26
PLANNED	6/18/2021	2	212	108
PLANNED	6/18/2021	1	44	44
PLANNED	6/18/2021	1	25	25
PLANNED	6/18/2021	1	7	7
PLANNED	6/18/2021	1	73	73
PLANNED	6/18/2021	14	1,232	88
PLANNED	6/18/2021	3	48	16
PLANNED	6/18/2021	15	480	32
PLANNED	6/18/2021	2	8	4
PLANNED	6/18/2021	7	406	58
PLANNED	6/18/2021	1	8	8
PLANNED	6/18/2021	9	396	44
PLANNED	6/18/2021	1	50	50
PLANNED	6/18/2021	1	41	41
PLANNED	6/18/2021	24	6,000	331
PLANNED	6/18/2021	4	88	22
PLANNED	6/18/2021	15	135	9
PLANNED	6/18/2021	1	48	48
PLANNED	6/18/2021	1	5	5
PLANNED	6/18/2021	4	355	129
PLANNED	6/18/2021	3	231	77
PLANNED	6/18/2021	1	56	56
PLANNED	6/18/2021	6	426	71
PLANNED	6/18/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/18/2021	8	952	119
PLANNED	6/18/2021	3	18	6
PLANNED	6/18/2021	21	2,352	112
PLANNED	6/18/2021	5	1,135	227
PLANNED	6/18/2021	2	8	4
PLANNED	6/18/2021	4	164	41
PLANNED	6/18/2021	2	16	8
PLANNED	6/18/2021	2	40	20
PLANNED	6/18/2021	2	10	5
PLANNED	6/18/2021	3	45	15
PLANNED	6/18/2021	6	1,434	239
PLANNED	6/18/2021	9	252	28
PLANNED	6/18/2021	11	1,617	147
PLANNED	6/18/2021	5	30	6
PLANNED	6/18/2021	4	268	67
PLANNED	6/18/2021	4	288	72
PLANNED	6/18/2021	2	14	7
PLANNED	6/18/2021	5	810	162
PLANNED	6/18/2021	4	1,144	286
PLANNED	6/18/2021	3	264	88
PLANNED	6/18/2021	4	200	50
PLANNED	6/18/2021	1	51	51
PLANNED	6/18/2021	1	3	3
PLANNED	6/18/2021	28	3,332	119
PLANNED	6/18/2021	12	192	16
PLANNED	6/18/2021	1	3	3
PLANNED	6/18/2021	2	18	9
PLANNED	6/18/2021	3	24	8
PLANNED	6/18/2021	10	550	55
PLANNED	6/18/2021	2	126	63
PLANNED	6/18/2021	9	540	60
PLANNED	6/18/2021	1	6	6
PLANNED	6/18/2021	6	750	125
PLANNED	6/18/2021	4	96	24
PLANNED	6/18/2021	4	1,104	276
PLANNED	6/18/2021	1	8	8
PLANNED	6/18/2021	18	288	16
PLANNED	6/18/2021	4	84	21
PLANNED	6/18/2021	1	105	105
PLANNED	6/18/2021	1	102	102
PLANNED	6/18/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/18/2021	4	24	6
PLANNED	6/18/2021	4	204	51
PLANNED	6/18/2021	2	32	16
PLANNED	6/18/2021	5	1,040	208
PLANNED	6/18/2021	13	637	49
PLANNED	6/18/2021	8	88	11
PLANNED	6/18/2021	2	10	5
PLANNED	6/18/2021	5	425	85
PLANNED	6/18/2021	2	420	210
PLANNED	6/18/2021	6	774	129
PLANNED	6/18/2021	4	448	112
PLANNED	6/18/2021	3	27	9
PLANNED	6/18/2021	2	12	6
PLANNED	6/18/2021	8	160	20
CUSTOMER REQUEST	6/18/2021	7	119	17
PLANNED	6/18/2021	2	10	5
PLANNED	6/18/2021	2	8	4
PLANNED	6/18/2021	1	6	6
PLANNED	6/18/2021	4	668	167
PLANNED	6/18/2021	4	148	37
CUSTOMER REQUEST	6/18/2021	1	1,259	1,259
PLANNED	6/18/2021	16	2,752	172
PLANNED	6/18/2021	2	10	5
CUSTOMER REQUEST	6/18/2021	6	24	4
PLANNED	6/18/2021	2	16	8
CUSTOMER REQUEST	6/18/2021	9	1,692	188
PLANNED	6/18/2021	8	600	75
PLANNED	6/18/2021	2	10	5
PLANNED	6/18/2021	1	61	61
PLANNED	6/18/2021	2	36	18
PLANNED	6/18/2021	3	348	116
CUSTOMER REQUEST	6/18/2021	4	36	9
PLANNED	6/18/2021	4	204	51
PLANNED	6/18/2021	1	80	80
PLANNED	6/18/2021	6	162	27
PLANNED	6/18/2021	19	969	51
PLANNED	6/18/2021	17	3,264	192
PLANNED	6/18/2021	3	36	12
PLANNED	6/18/2021	6	270	45
PLANNED	6/18/2021	1	53	53
PLANNED	6/18/2021	9	189	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/18/2021	3	102	34
PLANNED	6/18/2021	2	24	12
PLANNED	6/18/2021	1	93	93
PLANNED	6/18/2021	11	561	51
PLANNED	6/18/2021	4	280	70
PLANNED	6/18/2021	2	26	13
PLANNED	6/18/2021	4	148	37
PLANNED	6/18/2021	1	119	119
PLANNED	6/18/2021	8	576	72
CUSTOMER REQUEST	6/18/2021	7	441	63
PLANNED	6/18/2021	1	15	15
PLANNED	6/18/2021	2	166	83
PLANNED	6/18/2021	10	430	43
PLANNED	6/18/2021	1	101	101
PLANNED	6/18/2021	3	336	112
PLANNED	6/18/2021	17	544	32
PLANNED	6/18/2021	3	135	45
PLANNED	6/18/2021	17	1,275	75
PLANNED	6/18/2021	3	42	14
PLANNED	6/18/2021	1	12	12
PLANNED	6/18/2021	1	13	13
CUSTOMER REQUEST	6/18/2021	32	256	8
PLANNED	6/18/2021	10	1,520	152
PLANNED	6/18/2021	4	288	72
PLANNED	6/18/2021	1	161	161
PLANNED	6/19/2021	1	138	138
PLANNED	6/19/2021	2	250	125
PLANNED	6/19/2021	2	804	402
PLANNED	6/19/2021	4	304	76
PLANNED	6/19/2021	5	385	77
PLANNED	6/19/2021	8	1,296	162
PLANNED	6/19/2021	1	34	34
PLANNED	6/19/2021	1	149	149
PLANNED	6/19/2021	1	195	195
PLANNED	6/19/2021	7	217	31
PLANNED	6/19/2021	2	18	9
PLANNED	6/19/2021	2	288	144
CUSTOMER REQUEST	6/19/2021	139	1,668	12
PLANNED	6/19/2021	2	186	93
PLANNED	6/19/2021	2	96	48
PLANNED	6/19/2021	5	405	81

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/20/2021	1	24	24
PLANNED	6/20/2021	2	670	335
PLANNED	6/20/2021	1	127	127
CUSTOMER REQUEST	6/20/2021	1	124	124
PLANNED	6/21/2021	4	272	68
PLANNED	6/21/2021	2	138	69
PLANNED	6/21/2021	3	222	74
PLANNED	6/21/2021	1	7	7
PLANNED	6/21/2021	2	244	122
PLANNED	6/21/2021	3	33	11
PLANNED	6/21/2021	2	130	72
PLANNED	6/21/2021	5	105	21
PLANNED	6/21/2021	3	177	59
PLANNED	6/21/2021	2	210	105
PLANNED	6/21/2021	3	249	83
PLANNED	6/21/2021	2	62	31
PLANNED	6/21/2021	2	90	45
PLANNED	6/21/2021	2	116	58
PLANNED	6/21/2021	3	284	116
PLANNED	6/21/2021	4	48	12
PLANNED	6/21/2021	6	966	161
PLANNED	6/21/2021	2	38	19
PLANNED	6/21/2021	3	51	17
PLANNED	6/21/2021	1	44	44
PLANNED	6/21/2021	6	150	25
PLANNED	6/21/2021	1	11	11
PLANNED	6/21/2021	2	196	98
PLANNED	6/21/2021	10	1,890	189
CUSTOMER REQUEST	6/21/2021	1	3	3
PLANNED	6/21/2021	7	1,372	196
PLANNED	6/21/2021	4	44	11
PLANNED	6/21/2021	5	650	130
PLANNED	6/21/2021	2	16	8
PLANNED	6/21/2021	3	231	77
CUSTOMER REQUEST	6/21/2021	171	27,531	161
PLANNED	6/21/2021	1	55	55
PLANNED	6/21/2021	1	15	15
CUSTOMER REQUEST	6/21/2021	2	42	21
PLANNED	6/21/2021	5	205	41
PLANNED	6/21/2021	1	7	7
PLANNED	6/21/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	6/21/2021	1	259	259
PLANNED	6/21/2021	2	182	91
PLANNED	6/21/2021	1	56	56
CUSTOMER REQUEST	6/21/2021	21	6,762	322
PLANNED	6/21/2021	2	16	8
PLANNED	6/21/2021	1	8	8
PLANNED	6/21/2021	7	648	132
PLANNED	6/21/2021	1	11	11
PLANNED	6/21/2021	2	166	83
PLANNED	6/21/2021	1	139	139
PLANNED	6/21/2021	2	22	11
PLANNED	6/21/2021	13	455	35
PLANNED	6/21/2021	10	5,040	504
PLANNED	6/21/2021	1	7	7
PLANNED	6/21/2021	8	144	18
PLANNED	6/21/2021	1	113	113
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	3	45	15
PLANNED	6/21/2021	3	30	10
PLANNED	6/21/2021	4	36	9
PLANNED	6/21/2021	3	255	85
PLANNED	6/21/2021	2	20	10
PLANNED	6/21/2021	2	16	8
PLANNED	6/21/2021	2	12	6
PLANNED	6/21/2021	9	1,224	136
PLANNED	6/21/2021	6	360	60
PLANNED	6/21/2021	5	913	213
PLANNED	6/21/2021	3	54	18
PLANNED	6/21/2021	14	140	10
PLANNED	6/21/2021	16	3,680	230
PLANNED	6/21/2021	1	7	7
PLANNED	6/21/2021	3	24	8
PLANNED	6/21/2021	2	10	5
PLANNED	6/21/2021	12	108	9
PLANNED	6/21/2021	4	192	48
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	2	22	11
PLANNED	6/21/2021	2	28	14
PLANNED	6/21/2021	1	9	9
PLANNED	6/21/2021	5	160	32
PLANNED	6/21/2021	3	84	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/21/2021	3	27	9
PLANNED	6/21/2021	1	5	5
PLANNED	6/21/2021	2	296	148
PLANNED	6/21/2021	3	195	65
PLANNED	6/21/2021	8	984	176
PLANNED	6/21/2021	1	43	43
PLANNED	6/21/2021	1	36	36
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	3	15	5
PLANNED	6/21/2021	1	35	35
PLANNED	6/21/2021	3	114	38
PLANNED	6/21/2021	1	91	91
PLANNED	6/21/2021	4	612	153
PLANNED	6/21/2021	6	1,500	250
PLANNED	6/21/2021	2	246	123
PLANNED	6/21/2021	8	920	115
PLANNED	6/21/2021	3	51	17
PLANNED	6/21/2021	1	8	8
PLANNED	6/21/2021	2	20	10
PLANNED	6/21/2021	3	24	8
PLANNED	6/21/2021	1	11	11
PLANNED	6/21/2021	2	18	9
PLANNED	6/21/2021	2	24	12
PLANNED	6/21/2021	2	206	103
PLANNED	6/21/2021	4	48	12
PLANNED	6/21/2021	3	15	5
PLANNED	6/21/2021	4	336	84
PLANNED	6/21/2021	1	5	5
PLANNED	6/21/2021	3	141	47
PLANNED	6/21/2021	2	26	13
PLANNED	6/21/2021	43	1,032	24
PLANNED	6/21/2021	9	171	19
PLANNED	6/21/2021	2	14	7
PLANNED	6/21/2021	80	15,760	197
CUSTOMER REQUEST	6/21/2021	6	120	20
PLANNED	6/21/2021	3	15	5
PLANNED	6/21/2021	5	55	11
PLANNED	6/21/2021	1	25	25
PLANNED	6/21/2021	3	24	8
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/21/2021	8	1,000	125
PLANNED	6/21/2021	3	345	115
PLANNED	6/21/2021	4	48	12
CUSTOMER REQUEST	6/21/2021	21	882	42
PLANNED	6/21/2021	3	480	160
PLANNED	6/21/2021	1	183	183
PLANNED	6/21/2021	1	16	16
PLANNED	6/21/2021	2	24	12
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	1	55	55
PLANNED	6/21/2021	1	79	79
PLANNED	6/21/2021	1	10	10
PLANNED	6/21/2021	8	200	25
PLANNED	6/21/2021	2	20	10
PLANNED	6/21/2021	1	3	3
PLANNED	6/21/2021	35	350	10
PLANNED	6/21/2021	8	664	83
PLANNED	6/21/2021	4	44	11
PLANNED	6/21/2021	11	132	12
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	11	242	22
PLANNED	6/21/2021	3	21	7
PLANNED	6/21/2021	7	28	4
PLANNED	6/21/2021	2	12	6
PLANNED	6/21/2021	8	200	25
PLANNED	6/21/2021	1	163	163
PLANNED	6/21/2021	2	228	114
PLANNED	6/21/2021	4	32	8
PLANNED	6/21/2021	2	154	77
PLANNED	6/21/2021	4	44	11
PLANNED	6/21/2021	2	12	6
PLANNED	6/21/2021	1	51	51
PLANNED	6/21/2021	4	32	8
PLANNED	6/21/2021	3	51	17
PLANNED	6/21/2021	6	66	11
PLANNED	6/21/2021	1	6	6
PLANNED	6/21/2021	9	1,791	199
PLANNED	6/21/2021	1	10	10
PLANNED	6/21/2021	1	63	63
PLANNED	6/21/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/21/2021	4	36	9
PLANNED	6/21/2021	36	1,332	37
PLANNED	6/21/2021	1	68	68
PLANNED	6/21/2021	1	11	11
PLANNED	6/21/2021	2	8	4
CUSTOMER REQUEST	6/21/2021	1	304	304
PLANNED	6/21/2021	2	14	7
PLANNED	6/21/2021	2	110	55
PLANNED	6/21/2021	4	56	14
PLANNED	6/21/2021	1	96	96
PLANNED	6/21/2021	5	380	76
PLANNED	6/21/2021	1	71	71
PLANNED	6/21/2021	2	18	9
PLANNED	6/21/2021	2	30	15
PLANNED	6/21/2021	1	19	19
PLANNED	6/21/2021	1	28	28
PLANNED	6/21/2021	5	30	6
PLANNED	6/21/2021	1	7	7
PLANNED	6/21/2021	3	39	13
PLANNED	6/21/2021	1	20	20
PLANNED	6/21/2021	3	18	6
PLANNED	6/21/2021	5	35	7
PLANNED	6/21/2021	3	288	96
PLANNED	6/21/2021	3	147	49
PLANNED	6/21/2021	3	21	7
PLANNED	6/21/2021	3	255	85
PLANNED	6/21/2021	1	77	77
PLANNED	6/21/2021	4	52	13
PLANNED	6/21/2021	3	30	10
PLANNED	6/21/2021	10	570	57
PLANNED	6/21/2021	1	9	9
PLANNED	6/21/2021	2	92	46
PLANNED	6/21/2021	3	114	38
PLANNED	6/21/2021	20	1,200	87
PLANNED	6/21/2021	1	36	36
PLANNED	6/21/2021	1	73	73
PLANNED	6/21/2021	3	93	31
PLANNED	6/21/2021	8	136	28
PLANNED	6/21/2021	4	80	20
PLANNED	6/21/2021	6	132	22
CUSTOMER REQUEST	6/21/2021	3	21	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/21/2021	4	48	12
CUSTOMER REQUEST	6/21/2021	4	64	16
PLANNED	6/21/2021	8	32	4
CUSTOMER REQUEST	6/21/2021	1	432	432
PLANNED	6/21/2021	17	153	9
CUSTOMER REQUEST	6/22/2021	166	1,120	478
PLANNED	6/22/2021	3	363	121
PLANNED	6/22/2021	1	28	28
PLANNED	6/22/2021	3	303	101
PLANNED	6/22/2021	2	30	15
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	2	226	113
PLANNED	6/22/2021	3	24	8
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	2	136	68
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	1	88	88
PLANNED	6/22/2021	1	52	52
PLANNED	6/22/2021	4	164	41
PLANNED	6/22/2021	3	21	7
PLANNED	6/22/2021	7	2,086	298
PLANNED	6/22/2021	3	24	8
PLANNED	6/22/2021	1	10	10
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	4	256	64
PLANNED	6/22/2021	1	8	8
PLANNED	6/22/2021	4	120	30
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	2	24	12
PLANNED	6/22/2021	3	9	3
PLANNED	6/22/2021	2	128	64
PLANNED	6/22/2021	2	18	9
PLANNED	6/22/2021	1	10	10
PLANNED	6/22/2021	3	57	19
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	1	9	9
PLANNED	6/22/2021	3	33	11
CUSTOMER REQUEST	6/22/2021	5	60	12
PLANNED	6/22/2021	9	279	31
PLANNED	6/22/2021	1	4	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	18	2,556	142
CUSTOMER REQUEST	6/22/2021	2	42	21
PLANNED	6/22/2021	13	1,742	134
PLANNED	6/22/2021	3	15	5
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	1	90	90
PLANNED	6/22/2021	1	5	5
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	4	20	5
PLANNED	6/22/2021	1	89	89
PLANNED	6/22/2021	7	651	93
PLANNED	6/22/2021	1	85	85
CUSTOMER REQUEST	6/22/2021	9	45	5
PLANNED	6/22/2021	1	4	4
PLANNED	6/22/2021	3	18	6
PLANNED	6/22/2021	1	11	11
PLANNED	6/22/2021	1	123	123
PLANNED	6/22/2021	1	10	10
PLANNED	6/22/2021	7	21	3
PLANNED	6/22/2021	1	18	18
PLANNED	6/22/2021	2	10	5
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	3	21	7
PLANNED	6/22/2021	1	257	257
PLANNED	6/22/2021	1	420	420
PLANNED	6/22/2021	8	1,056	132
PLANNED	6/22/2021	8	72	9
PLANNED	6/22/2021	3	18	6
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	10	1,190	119
PLANNED	6/22/2021	1	119	119
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	7	476	68
PLANNED	6/22/2021	4	352	88
PLANNED	6/22/2021	4	24	6
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	2	130	65
PLANNED	6/22/2021	2	28	14
PLANNED	6/22/2021	11	4,846	464
PLANNED	6/22/2021	1	67	67
PLANNED	6/22/2021	1	65	65

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	1	65	65
PLANNED	6/22/2021	1	65	65
PLANNED	6/22/2021	1	10	10
PLANNED	6/22/2021	2	18	9
PLANNED	6/22/2021	6	384	64
PLANNED	6/22/2021	2	20	10
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	3	21	7
PLANNED	6/22/2021	3	39	13
PLANNED	6/22/2021	3	18	6
PLANNED	6/22/2021	1	37	37
PLANNED	6/22/2021	1	3	3
PLANNED	6/22/2021	1	15	15
PLANNED	6/22/2021	3	15	5
PLANNED	6/22/2021	7	525	75
PLANNED	6/22/2021	3	78	26
PLANNED	6/22/2021	3	243	81
PLANNED	6/22/2021	9	243	27
PLANNED	6/22/2021	1	288	288
PLANNED	6/22/2021	1	5	5
PLANNED	6/22/2021	1	28	28
PLANNED	6/22/2021	1	148	148
PLANNED	6/22/2021	1	13	13
PLANNED	6/22/2021	2	128	64
PLANNED	6/22/2021	1	8	8
PLANNED	6/22/2021	1	8	8
PLANNED	6/22/2021	6	678	113
PLANNED	6/22/2021	3	15	5
PLANNED	6/22/2021	2	26	13
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	2	3,010	1,505
PLANNED	6/22/2021	11	1,732	178
PLANNED	6/22/2021	1	98	98
PLANNED	6/22/2021	2	28	14
PLANNED	6/22/2021	4	288	72
PLANNED	6/22/2021	24	528	22
PLANNED	6/22/2021	27	1,026	38
PLANNED	6/22/2021	2	8	4
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	2	108	54
PLANNED	6/22/2021	2	278	139

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	9	639	71
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	1	229	229
PLANNED	6/22/2021	1	252	252
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	1	538	538
PLANNED	6/22/2021	1	26	26
PLANNED	6/22/2021	3	48	16
PLANNED	6/22/2021	1	306	306
PLANNED	6/22/2021	2	14	7
CUSTOMER REQUEST	6/22/2021	7	168	24
PLANNED	6/22/2021	1	8	8
PLANNED	6/22/2021	5	190	38
PLANNED	6/22/2021	4	704	176
PLANNED	6/22/2021	3	195	65
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	4	72	18
PLANNED	6/22/2021	1	9	9
PLANNED	6/22/2021	2	10	5
PLANNED	6/22/2021	2	10	5
PLANNED	6/22/2021	1	10	10
PLANNED	6/22/2021	2	20	10
PLANNED	6/22/2021	5	165	33
PLANNED	6/22/2021	1	16	16
CUSTOMER REQUEST	6/22/2021	1	948	948
PLANNED	6/22/2021	10	1,450	145
PLANNED	6/22/2021	5	120	24
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	15	1,800	120
PLANNED	6/22/2021	3	15	5
PLANNED	6/22/2021	1	6	6
PLANNED	6/22/2021	14	490	35
PLANNED	6/22/2021	1	49	49
PLANNED	6/22/2021	1	2	2
PLANNED	6/22/2021	2	22	11
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	4	32	8
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	2	168	84
PLANNED	6/22/2021	3	24	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	6	42	7
PLANNED	6/22/2021	4	60	15
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	2	44	22
PLANNED	6/22/2021	4	20	5
PLANNED	6/22/2021	19	570	30
PLANNED	6/22/2021	5	40	8
PLANNED	6/22/2021	1	6	6
CUSTOMER REQUEST	6/22/2021	2	18	9
PLANNED	6/22/2021	1	12	12
PLANNED	6/22/2021	2	26	13
PLANNED	6/22/2021	16	1,520	95
PLANNED	6/22/2021	16	656	41
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	3	1,080	360
PLANNED	6/22/2021	2	684	342
PLANNED	6/22/2021	1	19	19
PLANNED	6/22/2021	5	110	22
PLANNED	6/22/2021	2	24	12
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	1	24	24
CUSTOMER REQUEST	6/22/2021	9	27	3
PLANNED	6/22/2021	7	77	11
PLANNED	6/22/2021	2	118	59
PLANNED	6/22/2021	7	77	11
PLANNED	6/22/2021	1	184	184
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	9	54	6
PLANNED	6/22/2021	1	12	12
PLANNED	6/22/2021	1	8	8
PLANNED	6/22/2021	3	24	8
CUSTOMER REQUEST	6/22/2021	1	37	37
PLANNED	6/22/2021	2	200	100
PLANNED	6/22/2021	2	240	120
CUSTOMER REQUEST	6/22/2021	12	540	45
PLANNED	6/22/2021	2	14	7
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	3	21	7
PLANNED	6/22/2021	7	938	134
PLANNED	6/22/2021	2	344	172

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	3	99	33
PLANNED	6/22/2021	11	539	49
PLANNED	6/22/2021	1	48	48
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	2	16	8
PLANNED	6/22/2021	2	18	9
PLANNED	6/22/2021	1	9	9
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	2	12	6
CUSTOMER REQUEST	6/22/2021	60	420	7
PLANNED	6/22/2021	1	39	39
PLANNED	6/22/2021	2	20	10
PLANNED	6/22/2021	5	75	15
PLANNED	6/22/2021	1	7	7
PLANNED	6/22/2021	3	30	10
PLANNED	6/22/2021	1	47	47
PLANNED	6/22/2021	7	875	125
PLANNED	6/22/2021	5	35	7
PLANNED	6/22/2021	2	12	6
PLANNED	6/22/2021	4	40	10
PLANNED	6/22/2021	3	30	10
PLANNED	6/22/2021	2	38	19
PLANNED	6/22/2021	5	415	83
PLANNED	6/22/2021	7	147	21
PLANNED	6/22/2021	2	80	40
PLANNED	6/22/2021	4	180	45
PLANNED	6/22/2021	11	561	51
PLANNED	6/22/2021	14	182	13
PLANNED	6/22/2021	1	11	11
PLANNED	6/22/2021	23	1,886	82
PLANNED	6/22/2021	12	108	9
PLANNED	6/22/2021	1	2	2
PLANNED	6/22/2021	3	18	6
PLANNED	6/22/2021	2	100	50
CUSTOMER REQUEST	6/22/2021	1	36	36
PLANNED	6/22/2021	5	20	4
PLANNED	6/22/2021	6	276	46
PLANNED	6/22/2021	11	264	24
PLANNED	6/22/2021	3	18	6
CUSTOMER REQUEST	6/22/2021	8	80	10
PLANNED	6/22/2021	1	366	366

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/22/2021	12	924	77
PLANNED	6/22/2021	9	882	98
PLANNED	6/23/2021	1	318	318
PLANNED	6/23/2021	2	44	22
PLANNED	6/23/2021	3	309	103
PLANNED	6/23/2021	3	387	129
PLANNED	6/23/2021	8	336	42
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	1	5	5
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	4	24	6
PLANNED	6/23/2021	1	7	7
PLANNED	6/23/2021	8	136	17
PLANNED	6/23/2021	2	14	7
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	2	300	150
PLANNED	6/23/2021	1	7	7
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	1	9	9
PLANNED	6/23/2021	2	84	42
PLANNED	6/23/2021	3	24	8
CUSTOMER REQUEST	6/23/2021	388	103,596	267
PLANNED	6/23/2021	2	298	149
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	2	252	126
PLANNED	6/23/2021	1	5	5
PLANNED	6/23/2021	15	135	9
PLANNED	6/23/2021	7	84	12
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	7	70	10
PLANNED	6/23/2021	3	9	3
PLANNED	6/23/2021	2	272	136
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	3	141	47
PLANNED	6/23/2021	1	11	11
PLANNED	6/23/2021	2	22	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	2	28	14
PLANNED	6/23/2021	1	7	7
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	4	328	82
PLANNED	6/23/2021	8	984	123
PLANNED	6/23/2021	1	112	112
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	2	12	6
CUSTOMER REQUEST	6/23/2021	1	233	233
PLANNED	6/23/2021	4	32	8
PLANNED	6/23/2021	2	46	23
PLANNED	6/23/2021	12	984	214
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	4	16	4
PLANNED	6/23/2021	16	592	37
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	11	132	12
PLANNED	6/23/2021	8	1,992	249
PLANNED	6/23/2021	6	1,344	224
PLANNED	6/23/2021	3	525	175
PLANNED	6/23/2021	2	120	60
PLANNED	6/23/2021	2	18	9
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	4	108	27
PLANNED	6/23/2021	2	150	75
PLANNED	6/23/2021	2	176	88
PLANNED	6/23/2021	8	1,080	135
PLANNED	6/23/2021	2	24	12
CUSTOMER REQUEST	6/23/2021	6	864	144
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	1	4	4
PLANNED	6/23/2021	2	12	6
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	4	44	11
PLANNED	6/23/2021	2	10	5
CUSTOMER REQUEST	6/23/2021	147	1,394	1,248
PLANNED	6/23/2021	1	6	6
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	1	18	18
PLANNED	6/23/2021	3	27	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	1	119	119
PLANNED	6/23/2021	7	210	30
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	1	134	134
PLANNED	6/23/2021	9	99	11
PLANNED	6/23/2021	9	765	85
PLANNED	6/23/2021	1	3	3
PLANNED	6/23/2021	2	36	18
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	4	36	9
PLANNED	6/23/2021	1	8	8
PLANNED	6/23/2021	5	35	7
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	1	69	69
PLANNED	6/23/2021	4	40	10
PLANNED	6/23/2021	2	14	7
PLANNED	6/23/2021	1	212	212
PLANNED	6/23/2021	2	20	10
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	1	3	3
PLANNED	6/23/2021	1	7	7
PLANNED	6/23/2021	3	30	10
PLANNED	6/23/2021	7	1,204	172
PLANNED	6/23/2021	6	858	143
PLANNED	6/23/2021	2	12	6
PLANNED	6/23/2021	1	74	74
PLANNED	6/23/2021	2	22	11
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	3	33	11
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	1	3	3
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	3	147	49
PLANNED	6/23/2021	21	2,247	107
PLANNED	6/23/2021	1	6	6
PLANNED	6/23/2021	1	6	6
PLANNED	6/23/2021	9	171	19
PLANNED	6/23/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	1	31	31
PLANNED	6/23/2021	1	6	6
PLANNED	6/23/2021	8	248	31
PLANNED	6/23/2021	10	1,690	169
PLANNED	6/23/2021	7	1,176	168
PLANNED	6/23/2021	6	1,038	173
PLANNED	6/23/2021	12	564	47
PLANNED	6/23/2021	1	150	150
PLANNED	6/23/2021	4	32	8
PLANNED	6/23/2021	5	395	79
PLANNED	6/23/2021	2	12	6
PLANNED	6/23/2021	4	764	191
PLANNED	6/23/2021	4	32	8
PLANNED	6/23/2021	9	36	4
PLANNED	6/23/2021	4	20	5
PLANNED	6/23/2021	4	272	68
PLANNED	6/23/2021	4	60	15
PLANNED	6/23/2021	3	24	8
PLANNED	6/23/2021	14	2,422	173
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	3	24	8
PLANNED	6/23/2021	1	61	61
PLANNED	6/23/2021	4	24	6
PLANNED	6/23/2021	5	185	37
PLANNED	6/23/2021	1	73	73
PLANNED	6/23/2021	3	27	9
PLANNED	6/23/2021	2	24	12
PLANNED	6/23/2021	4	60	15
PLANNED	6/23/2021	2	30	15
PLANNED	6/23/2021	3	405	135
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	1	36	36
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	4	20	5
PLANNED	6/23/2021	7	182	26
PLANNED	6/23/2021	19	133	7
PLANNED	6/23/2021	3	24	8
PLANNED	6/23/2021	1	44	44
PLANNED	6/23/2021	2	20	10
PLANNED	6/23/2021	4	220	55
PLANNED	6/23/2021	1	45	45

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	3	90	30
PLANNED	6/23/2021	3	84	28
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	4	96	24
PLANNED	6/23/2021	4	80	20
PLANNED	6/23/2021	3	51	23
PLANNED	6/23/2021	3	33	11
PLANNED	6/23/2021	2	16	8
PLANNED	6/23/2021	3	348	116
PLANNED	6/23/2021	4	120	30
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	10	650	65
PLANNED	6/23/2021	4	12	3
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	3	15	5
PLANNED	6/23/2021	5	30	6
PLANNED	6/23/2021	2	12	6
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	11	2,585	235
PLANNED	6/23/2021	3	12	4
PLANNED	6/23/2021	1	54	54
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	2	12	6
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	12	936	78
PLANNED	6/23/2021	15	855	57
PLANNED	6/23/2021	5	30	6
PLANNED	6/23/2021	8	1,328	166
PLANNED	6/23/2021	4	748	187
PLANNED	6/23/2021	4	688	172
PLANNED	6/23/2021	10	130	13
PLANNED	6/23/2021	4	20	5
PLANNED	6/23/2021	2	6	3
PLANNED	6/23/2021	4	16	4
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	2	6	3
PLANNED	6/23/2021	2	8	4
PLANNED	6/23/2021	1	5	5
PLANNED	6/23/2021	9	2,295	274
PLANNED	6/23/2021	6	30	5
PLANNED	6/23/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	2	196	98
PLANNED	6/23/2021	1	6	6
PLANNED	6/23/2021	2	86	43
PLANNED	6/23/2021	10	440	44
PLANNED	6/23/2021	4	76	19
PLANNED	6/23/2021	3	2,037	679
PLANNED	6/23/2021	1	55	55
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	6	474	79
PLANNED	6/23/2021	8	216	27
PLANNED	6/23/2021	2	26	13
PLANNED	6/23/2021	6	378	63
PLANNED	6/23/2021	4	28	7
PLANNED	6/23/2021	1	133	133
PLANNED	6/23/2021	5	50	10
PLANNED	6/23/2021	2	100	50
PLANNED	6/23/2021	3	117	39
PLANNED	6/23/2021	5	30	6
PLANNED	6/23/2021	6	372	62
PLANNED	6/23/2021	4	212	53
PLANNED	6/23/2021	3	27	9
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	1	139	139
PLANNED	6/23/2021	6	40	10
PLANNED	6/23/2021	1	13	13
PLANNED	6/23/2021	4	24	6
PLANNED	6/23/2021	1	84	84
PLANNED	6/23/2021	4	68	17
PLANNED	6/23/2021	2	66	33
PLANNED	6/23/2021	2	134	67
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	6	132	22
PLANNED	6/23/2021	7	42	6
PLANNED	6/23/2021	3	21	7
PLANNED	6/23/2021	3	102	34
PLANNED	6/23/2021	8	88	11
PLANNED	6/23/2021	6	84	14
PLANNED	6/23/2021	1	33	33
PLANNED	6/23/2021	3	18	6
PLANNED	6/23/2021	3	138	46
PLANNED	6/23/2021	5	70	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/23/2021	2	118	59
PLANNED	6/23/2021	1	92	92
PLANNED	6/23/2021	8	248	31
PLANNED	6/23/2021	4	148	37
PLANNED	6/23/2021	5	1,660	332
PLANNED	6/23/2021	2	48	24
PLANNED	6/23/2021	2	318	159
PLANNED	6/23/2021	9	828	92
PLANNED	6/23/2021	4	184	46
PLANNED	6/23/2021	1	111	111
CUSTOMER REQUEST	6/24/2021	5	1,370	274
PLANNED	6/24/2021	8	728	91
PLANNED	6/24/2021	1	74	74
CUSTOMER REQUEST	6/24/2021	1,387	366,769	1,246
CUSTOMER REQUEST	6/24/2021	589	42,499	838
PLANNED	6/24/2021	1	35	35
PLANNED	6/24/2021	3	207	69
PLANNED	6/24/2021	2	256	128
PLANNED	6/24/2021	1	96	96
PLANNED	6/24/2021	2	290	145
PLANNED	6/24/2021	1	13	13
PLANNED	6/24/2021	2	2	1
PLANNED	6/24/2021	2	16	8
PLANNED	6/24/2021	1	15	15
PLANNED	6/24/2021	2	24	12
PLANNED	6/24/2021	1	9	9
PLANNED	6/24/2021	1	164	164
PLANNED	6/24/2021	1	4	4
PLANNED	6/24/2021	7	546	78
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	2	12	6
PLANNED	6/24/2021	7	553	79
PLANNED	6/24/2021	2	20	10
PLANNED	6/24/2021	3	24	8
PLANNED	6/24/2021	2	12	6
PLANNED	6/24/2021	2	18	9
PLANNED	6/24/2021	1	147	147
PLANNED	6/24/2021	4	60	15
PLANNED	6/24/2021	2	18	9
PLANNED	6/24/2021	2	188	94

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/24/2021	2	256	128
PLANNED	6/24/2021	2	224	112
PLANNED	6/24/2021	5	55	11
PLANNED	6/24/2021	8	872	109
PLANNED	6/24/2021	1	37	37
PLANNED	6/24/2021	5	120	24
PLANNED	6/24/2021	5	945	189
PLANNED	6/24/2021	5	45	9
PLANNED	6/24/2021	2	222	111
PLANNED	6/24/2021	1	8	8
PLANNED	6/24/2021	2	132	66
PLANNED	6/24/2021	2	198	99
PLANNED	6/24/2021	1	167	167
PLANNED	6/24/2021	3	21	7
PLANNED	6/24/2021	8	936	117
CUSTOMER REQUEST	6/24/2021	1	135	135
PLANNED	6/24/2021	2	30	15
PLANNED	6/24/2021	4	104	26
PLANNED	6/24/2021	3	561	187
PLANNED	6/24/2021	3	18	6
CUSTOMER REQUEST	6/24/2021	1	90	90
PLANNED	6/24/2021	4	684	171
PLANNED	6/24/2021	3	24	8
PLANNED	6/24/2021	3	12	4
PLANNED	6/24/2021	1	38	38
PLANNED	6/24/2021	1	87	87
PLANNED	6/24/2021	8	240	30
PLANNED	6/24/2021	6	198	33
PLANNED	6/24/2021	1	46	46
PLANNED	6/24/2021	3	60	20
PLANNED	6/24/2021	2	32	16
PLANNED	6/24/2021	1	8	8
PLANNED	6/24/2021	2	30	15
PLANNED	6/24/2021	2	210	105
PLANNED	6/24/2021	1	136	136
PLANNED	6/24/2021	8	1,200	150
PLANNED	6/24/2021	5	840	168
PLANNED	6/24/2021	1	13	13
PLANNED	6/24/2021	9	567	63
PLANNED	6/24/2021	1	289	289
PLANNED	6/24/2021	13	221	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/24/2021	56	2,240	40
PLANNED	6/24/2021	6	42	7
PLANNED	6/24/2021	6	318	53
PLANNED	6/24/2021	3	24	8
PLANNED	6/24/2021	4	24	6
PLANNED	6/24/2021	7	378	54
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	7	1,988	284
CUSTOMER REQUEST	6/24/2021	7	490	70
PLANNED	6/24/2021	2	168	84
PLANNED	6/24/2021	4	120	30
PLANNED	6/24/2021	6	864	144
PLANNED	6/24/2021	15	1,140	76
PLANNED	6/24/2021	85	11,645	137
PLANNED	6/24/2021	4	32	8
PLANNED	6/24/2021	2	14	7
PLANNED	6/24/2021	1	7	7
PLANNED	6/24/2021	5	42	10
PLANNED	6/24/2021	1	11	11
PLANNED	6/24/2021	7	175	25
PLANNED	6/24/2021	1	7	7
PLANNED	6/24/2021	21	693	33
PLANNED	6/24/2021	1	65	65
PLANNED	6/24/2021	1	4	4
CUSTOMER REQUEST	6/24/2021	13	78	6
PLANNED	6/24/2021	2	42	21
PLANNED	6/24/2021	14	1,450	245
PLANNED	6/24/2021	1	108	108
PLANNED	6/24/2021	7	588	84
PLANNED	6/24/2021	6	36	6
PLANNED	6/24/2021	11	88	8
PLANNED	6/24/2021	5	380	76
PLANNED	6/24/2021	2	184	92
PLANNED	6/24/2021	1	159	159
CUSTOMER REQUEST	6/24/2021	10	50	5
PLANNED	6/24/2021	1	3	3
PLANNED	6/24/2021	2	140	70
PLANNED	6/24/2021	2	288	144
PLANNED	6/24/2021	11	2,871	261
PLANNED	6/24/2021	1	7	7
PLANNED	6/24/2021	6	72	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/24/2021	1	17	17
PLANNED	6/24/2021	1	13	13
PLANNED	6/24/2021	2	18	9
CUSTOMER REQUEST	6/24/2021	63	1,890	30
PLANNED	6/24/2021	1	8	8
PLANNED	6/24/2021	9	837	93
PLANNED	6/24/2021	7	686	98
PLANNED	6/24/2021	1	5	5
PLANNED	6/24/2021	5	90	18
PLANNED	6/24/2021	4	628	157
PLANNED	6/24/2021	5	325	65
PLANNED	6/24/2021	7	168	24
PLANNED	6/24/2021	6	180	30
PLANNED	6/24/2021	6	66	11
PLANNED	6/24/2021	7	119	17
PLANNED	6/24/2021	7	168	24
PLANNED	6/24/2021	2	20	10
PLANNED	6/24/2021	1	8	8
PLANNED	6/24/2021	1	7	7
PLANNED	6/24/2021	1	147	147
PLANNED	6/24/2021	4	232	58
PLANNED	6/24/2021	2	20	10
PLANNED	6/24/2021	5	421	146
PLANNED	6/24/2021	3	39	13
PLANNED	6/24/2021	45	1,035	23
PLANNED	6/24/2021	2	12	6
PLANNED	6/24/2021	12	528	44
PLANNED	6/24/2021	1	3	3
PLANNED	6/24/2021	7	1,043	149
PLANNED	6/24/2021	1	6	6
PLANNED	6/24/2021	2	8	4
PLANNED	6/24/2021	2	8	4
PLANNED	6/24/2021	2	14	7
PLANNED	6/24/2021	8	64	8
PLANNED	6/24/2021	5	475	95
PLANNED	6/24/2021	1	29	29
PLANNED	6/24/2021	7	1,113	159
PLANNED	6/24/2021	8	1,068	172
PLANNED	6/24/2021	1	10	10
PLANNED	6/24/2021	4	1,088	272
PLANNED	6/24/2021	5	1,130	226

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/24/2021	4	940	235
PLANNED	6/24/2021	9	567	63
PLANNED	6/24/2021	12	756	63
PLANNED	6/24/2021	9	567	63
PLANNED	6/24/2021	2	276	138
PLANNED	6/24/2021	9	756	84
PLANNED	6/24/2021	3	219	73
PLANNED	6/24/2021	3	30	10
PLANNED	6/24/2021	4	116	29
PLANNED	6/24/2021	7	175	25
PLANNED	6/24/2021	10	430	43
PLANNED	6/24/2021	8	64	8
PLANNED	6/24/2021	4	120	30
PLANNED	6/24/2021	2	14	7
PLANNED	6/24/2021	11	638	58
PLANNED	6/24/2021	2	120	60
PLANNED	6/24/2021	5	35	7
PLANNED	6/24/2021	2	36	18
PLANNED	6/24/2021	5	75	15
PLANNED	6/24/2021	10	70	7
PLANNED	6/24/2021	9	198	22
PLANNED	6/24/2021	17	136	8
PLANNED	6/24/2021	5	560	112
PLANNED	6/24/2021	4	60	15
PLANNED	6/24/2021	8	130	46
PLANNED	6/24/2021	4	68	17
CUSTOMER REQUEST	6/24/2021	2	124	62
PLANNED	6/24/2021	2	42	21
PLANNED	6/24/2021	2	235	134
PLANNED	6/24/2021	11	1,210	110
PLANNED	6/24/2021	7	728	104
PLANNED	6/24/2021	2	96	48
PLANNED	6/24/2021	2	18	9
PLANNED	6/24/2021	1	46	46
PLANNED	6/24/2021	7	637	91
PLANNED	6/24/2021	1	10	10
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	2	30	15
PLANNED	6/24/2021	1	7	7
PLANNED	6/24/2021	4	52	13
PLANNED	6/24/2021	1	16	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	4	92	23
PLANNED	6/24/2021	3	285	95
PLANNED	6/24/2021	5	30	6
PLANNED	6/24/2021	3	30	10
PLANNED	6/24/2021	2	144	72
PLANNED	6/24/2021	4	172	43
PLANNED	6/24/2021	3	123	41
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	1	75	75
PLANNED	6/24/2021	62	6,076	98
PLANNED	6/24/2021	3	15	5
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	6	18	3
PLANNED	6/24/2021	4	48	12
PLANNED	6/24/2021	4	28	7
PLANNED	6/24/2021	4	32	8
CUSTOMER REQUEST	6/24/2021	1	354	354
PLANNED	6/24/2021	10	490	49
PLANNED	6/24/2021	4	76	19
PLANNED	6/24/2021	5	70	14
PLANNED	6/24/2021	10	670	67
PLANNED	6/24/2021	1	32	32
PLANNED	6/24/2021	4	40	10
PLANNED	6/24/2021	1	6	6
PLANNED	6/24/2021	3	36	12
PLANNED	6/24/2021	1	8	8
PLANNED	6/24/2021	2	78	39
PLANNED	6/24/2021	1	5	5
PLANNED	6/24/2021	1	6	6
PLANNED	6/24/2021	3	138	46
CUSTOMER REQUEST	6/24/2021	1	19	19
PLANNED	6/24/2021	14	980	70
CUSTOMER REQUEST	6/24/2021	23	391	17
PLANNED	6/24/2021	6	900	150
PLANNED	6/24/2021	6	504	84
PLANNED	6/24/2021	1	85	85
PLANNED	6/24/2021	18	3,618	201
PLANNED	6/24/2021	8	1,608	201
PLANNED	6/25/2021	4	32	8
PLANNED	6/25/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/25/2021	6	594	99
PLANNED	6/25/2021	15	1,005	67
PLANNED	6/25/2021	11	242	22
PLANNED	6/25/2021	4	452	113
PLANNED	6/25/2021	3	288	96
PLANNED	6/25/2021	8	728	91
PLANNED	6/25/2021	5	765	153
PLANNED	6/25/2021	1	10	10
PLANNED	6/25/2021	2	326	163
PLANNED	6/25/2021	3	39	13
PLANNED	6/25/2021	6	48	8
PLANNED	6/25/2021	3	72	24
PLANNED	6/25/2021	16	2,160	135
PLANNED	6/25/2021	6	60	10
PLANNED	6/25/2021	2	58	29
PLANNED	6/25/2021	2	136	68
PLANNED	6/25/2021	6	126	21
PLANNED	6/25/2021	2	24	12
PLANNED	6/25/2021	3	138	46
PLANNED	6/25/2021	2	92	46
CUSTOMER REQUEST	6/25/2021	13	39	3
PLANNED	6/25/2021	1	28	28
PLANNED	6/25/2021	90	18,500	450
PLANNED	6/25/2021	1	8	8
PLANNED	6/25/2021	1	260	260
PLANNED	6/25/2021	6	72	12
PLANNED	6/25/2021	3	21	7
PLANNED	6/25/2021	5	205	41
PLANNED	6/25/2021	1	57	57
PLANNED	6/25/2021	5	505	101
CUSTOMER REQUEST	6/25/2021	171	28,215	165
PLANNED	6/25/2021	1	10	10
PLANNED	6/25/2021	3	429	143
PLANNED	6/25/2021	10	940	94
PLANNED	6/25/2021	12	1,344	112
PLANNED	6/25/2021	2	444	222
PLANNED	6/25/2021	2	48	24
PLANNED	6/25/2021	1	12	12
PLANNED	6/25/2021	5	845	169
PLANNED	6/25/2021	1	9	9
PLANNED	6/25/2021	3	216	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/25/2021	8	1,344	168
CUSTOMER REQUEST	6/25/2021	8	96	12
PLANNED	6/25/2021	15	480	32
PLANNED	6/25/2021	1	25	25
PLANNED	6/25/2021	8	104	13
PLANNED	6/25/2021	9	648	72
PLANNED	6/25/2021	2	248	124
CUSTOMER REQUEST	6/25/2021	11	165	15
PLANNED	6/25/2021	12	1,812	151
PLANNED	6/25/2021	1	8	8
PLANNED	6/25/2021	16	2,832	177
PLANNED	6/25/2021	14	1,722	123
PLANNED	6/25/2021	2	16	8
PLANNED	6/25/2021	1	77	77
PLANNED	6/25/2021	1	26	26
CUSTOMER REQUEST	6/25/2021	5	20	4
PLANNED	6/25/2021	1	292	292
PLANNED	6/25/2021	71	20,590	290
PLANNED	6/25/2021	2	228	114
PLANNED	6/25/2021	10	1,130	113
PLANNED	6/25/2021	2	228	114
PLANNED	6/25/2021	8	16	2
PLANNED	6/25/2021	1	7	7
PLANNED	6/25/2021	1	19	19
PLANNED	6/25/2021	5	260	52
PLANNED	6/25/2021	5	275	55
PLANNED	6/25/2021	5	15	3
PLANNED	6/25/2021	4	84	21
PLANNED	6/25/2021	5	185	37
PLANNED	6/25/2021	15	840	56
PLANNED	6/25/2021	4	72	18
PLANNED	6/25/2021	1	7	7
PLANNED	6/25/2021	6	78	13
PLANNED	6/25/2021	3	42	14
PLANNED	6/25/2021	11	187	17
PLANNED	6/25/2021	3	30	10
PLANNED	6/25/2021	1	120	120
PLANNED	6/25/2021	5	70	14
PLANNED	6/25/2021	1	55	55
PLANNED	6/25/2021	4	100	25
PLANNED	6/25/2021	4	48	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/25/2021	2	42	21
PLANNED	6/25/2021	1	6	6
PLANNED	6/25/2021	1	32	32
PLANNED	6/25/2021	5	45	9
PLANNED	6/25/2021	6	468	78
PLANNED	6/25/2021	2	26	13
PLANNED	6/25/2021	3	9	3
PLANNED	6/25/2021	4	68	17
PLANNED	6/25/2021	3	36	12
PLANNED	6/25/2021	6	114	19
CUSTOMER REQUEST	6/25/2021	1	43	43
PLANNED	6/25/2021	5	115	23
PLANNED	6/25/2021	7	315	45
PLANNED	6/25/2021	41	369	9
PLANNED	6/25/2021	1	87	87
PLANNED	6/25/2021	2	164	82
PLANNED	6/25/2021	4	640	160
CUSTOMER REQUEST	6/25/2021	1	410	410
CUSTOMER REQUEST	6/25/2021	13	39	3
PLANNED	6/25/2021	3	30	10
CUSTOMER REQUEST	6/25/2021	492	10,824	22
PLANNED	6/26/2021	11	715	65
PLANNED	6/26/2021	2	130	65
PLANNED	6/26/2021	6	336	56
PLANNED	6/26/2021	1	61	61
PLANNED	6/26/2021	1	155	155
PLANNED	6/26/2021	3	27	9
PLANNED	6/26/2021	1	35	35
PLANNED	6/26/2021	1	270	270
PLANNED	6/26/2021	8	3,144	393
PLANNED	6/26/2021	3	165	55
PLANNED	6/26/2021	2	62	31
PLANNED	6/26/2021	15	2,145	143
CUSTOMER REQUEST	6/26/2021	7	28	4
PLANNED	6/26/2021	2	32	16
PLANNED	6/26/2021	14	924	66
PLANNED	6/26/2021	1	107	107
PLANNED	6/26/2021	2	154	77
PLANNED	6/26/2021	6	54	9
PLANNED	6/27/2021	9	837	93
PLANNED	6/27/2021	5	225	45

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/27/2021	2	76	38
PLANNED	6/27/2021	5	600	120
PLANNED	6/27/2021	2	348	174
PLANNED	6/27/2021	2	64	32
PLANNED	6/27/2021	5	1,240	248
PLANNED	6/27/2021	28	12,460	445
PLANNED	6/27/2021	4	616	154
PLANNED	6/27/2021	2	316	158
PLANNED	6/27/2021	8	536	67
PLANNED	6/27/2021	2	342	171
PLANNED	6/27/2021	1	172	172
PLANNED	6/27/2021	1	21	21
PLANNED	6/27/2021	2	324	162
PLANNED	6/27/2021	1	19	19
PLANNED	6/27/2021	2	42	21
PLANNED	6/27/2021	3	231	77
CUSTOMER REQUEST	6/27/2021	1	31	31
PLANNED	6/27/2021	3	213	71
PLANNED	6/27/2021	1	360	360
PLANNED	6/28/2021	7	686	98
PLANNED	6/28/2021	2	136	68
PLANNED	6/28/2021	4	408	102
PLANNED	6/28/2021	6	90	15
PLANNED	6/28/2021	4	104	26
PLANNED	6/28/2021	4	32	8
PLANNED	6/28/2021	4	8	2
PLANNED	6/28/2021	2	302	151
PLANNED	6/28/2021	10	100	10
PLANNED	6/28/2021	3	249	83
PLANNED	6/28/2021	2	130	65
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	3	27	9
PLANNED	6/28/2021	3	36	12
PLANNED	6/28/2021	2	24	12
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	7	49	7
PLANNED	6/28/2021	1	19	19
PLANNED	6/28/2021	5	680	136
PLANNED	6/28/2021	3	378	126
PLANNED	6/28/2021	18	3,654	203
PLANNED	6/28/2021	2	30	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	3	192	64
PLANNED	6/28/2021	8	407	78
PLANNED	6/28/2021	9	153	17
PLANNED	6/28/2021	5	537	110
PLANNED	6/28/2021	2	228	114
PLANNED	6/28/2021	3	33	11
PLANNED	6/28/2021	8	240	30
PLANNED	6/28/2021	4	8	2
PLANNED	6/28/2021	1	96	96
PLANNED	6/28/2021	3	30	10
PLANNED	6/28/2021	1	140	140
PLANNED	6/28/2021	4	1,000	250
PLANNED	6/28/2021	2	118	59
PLANNED	6/28/2021	9	612	68
PLANNED	6/28/2021	1	1	1
PLANNED	6/28/2021	8	48	6
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	3	81	27
PLANNED	6/28/2021	2	224	112
PLANNED	6/28/2021	6	648	108
PLANNED	6/28/2021	1	68	68
PLANNED	6/28/2021	2	218	109
PLANNED	6/28/2021	2	158	79
PLANNED	6/28/2021	2	10	5
PLANNED	6/28/2021	4	460	115
PLANNED	6/28/2021	1	12	12
PLANNED	6/28/2021	2	448	224
PLANNED	6/28/2021	2	10	5
PLANNED	6/28/2021	1	7	7
PLANNED	6/28/2021	9	99	11
PLANNED	6/28/2021	3	33	11
PLANNED	6/28/2021	4	48	12
PLANNED	6/28/2021	5	35	7
PLANNED	6/28/2021	3	51	17
PLANNED	6/28/2021	3	636	212
PLANNED	6/28/2021	2	24	12
PLANNED	6/28/2021	22	7,971	408
PLANNED	6/28/2021	1	250	250
PLANNED	6/28/2021	2	14	7
PLANNED	6/28/2021	2	508	254
PLANNED	6/28/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	1	25	25
PLANNED	6/28/2021	1	64	64
PLANNED	6/28/2021	3	129	43
PLANNED	6/28/2021	5	40	8
PLANNED	6/28/2021	10	890	89
PLANNED	6/28/2021	4	44	11
PLANNED	6/28/2021	2	14	7
PLANNED	6/28/2021	1	4	4
PLANNED	6/28/2021	2	8	4
PLANNED	6/28/2021	1	7	7
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	8	336	42
PLANNED	6/28/2021	1	210	210
PLANNED	6/28/2021	4	684	171
PLANNED	6/28/2021	16	1,136	71
PLANNED	6/28/2021	2	554	277
PLANNED	6/28/2021	3	30	10
PLANNED	6/28/2021	2	14	7
PLANNED	6/28/2021	2	18	9
PLANNED	6/28/2021	5	815	163
PLANNED	6/28/2021	2	134	67
PLANNED	6/28/2021	3	45	15
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	3	21	7
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	4	188	47
PLANNED	6/28/2021	2	22	11
PLANNED	6/28/2021	2	16	8
PLANNED	6/28/2021	4	60	15
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	1	18	18
PLANNED	6/28/2021	3	33	11
PLANNED	6/28/2021	3	21	7
PLANNED	6/28/2021	4	32	8
PLANNED	6/28/2021	2	16	8
PLANNED	6/28/2021	1	10	10
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	5	30	6
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	4	68	17
PLANNED	6/28/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	2	82	41
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	3	45	15
PLANNED	6/28/2021	17	221	13
PLANNED	6/28/2021	8	1,944	243
PLANNED	6/28/2021	4	956	246
PLANNED	6/28/2021	4	948	237
PLANNED	6/28/2021	2	286	143
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	2	10	5
PLANNED	6/28/2021	2	176	88
PLANNED	6/28/2021	2	66	33
PLANNED	6/28/2021	1	126	126
PLANNED	6/28/2021	1	58	58
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	17	3,808	224
PLANNED	6/28/2021	1	189	189
PLANNED	6/28/2021	2	14	7
PLANNED	6/28/2021	3	777	259
PLANNED	6/28/2021	3	63	21
PLANNED	6/28/2021	3	15	5
PLANNED	6/28/2021	2	10	5
PLANNED	6/28/2021	3	15	5
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	4	16	4
PLANNED	6/28/2021	3	21	7
PLANNED	6/28/2021	46	1,426	31
PLANNED	6/28/2021	4	56	14
PLANNED	6/28/2021	4	20	5
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	1	8	8
CUSTOMER REQUEST	6/28/2021	5	385	77
PLANNED	6/28/2021	3	54	18
PLANNED	6/28/2021	1	19	19
PLANNED	6/28/2021	1	5	5
PLANNED	6/28/2021	3	114	38
CUSTOMER REQUEST	6/28/2021	1,814	56,211	48
PLANNED	6/28/2021	3	48	16
PLANNED	6/28/2021	5	85	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	33	5,049	153
PLANNED	6/28/2021	1	4	4
PLANNED	6/28/2021	3	27	9
PLANNED	6/28/2021	3	48	16
PLANNED	6/28/2021	4	132	33
PLANNED	6/28/2021	6	105	70
PLANNED	6/28/2021	2	118	59
CUSTOMER REQUEST	6/28/2021	2	84	42
PLANNED	6/28/2021	1	175	175
PLANNED	6/28/2021	9	36	4
PLANNED	6/28/2021	2	4	2
PLANNED	6/28/2021	1	24	24
PLANNED	6/28/2021	4	220	55
PLANNED	6/28/2021	4	28	7
PLANNED	6/28/2021	1	11	11
PLANNED	6/28/2021	1	55	55
PLANNED	6/28/2021	4	32	8
PLANNED	6/28/2021	3	30	10
PLANNED	6/28/2021	4	36	9
PLANNED	6/28/2021	2	228	114
PLANNED	6/28/2021	3	24	8
CUSTOMER REQUEST	6/28/2021	1	91	91
PLANNED	6/28/2021	9	684	76
PLANNED	6/28/2021	4	76	19
PLANNED	6/28/2021	3	27	9
PLANNED	6/28/2021	1	108	108
PLANNED	6/28/2021	1	5	5
PLANNED	6/28/2021	2	20	10
PLANNED	6/28/2021	1	12	12
PLANNED	6/28/2021	2	18	9
PLANNED	6/28/2021	2	22	11
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	1	43	43
PLANNED	6/28/2021	4	4	1
PLANNED	6/28/2021	4	24	6
PLANNED	6/28/2021	1	5	5
CUSTOMER REQUEST	6/28/2021	1	478	478
PLANNED	6/28/2021	1	32	32
PLANNED	6/28/2021	2	294	147
PLANNED	6/28/2021	2	18	9
PLANNED	6/28/2021	2	34	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	8	582	179
PLANNED	6/28/2021	1	9	9
PLANNED	6/28/2021	1	7	7
PLANNED	6/28/2021	28	2,072	74
PLANNED	6/28/2021	2	62	31
CUSTOMER REQUEST	6/28/2021	222	15,096	68
PLANNED	6/28/2021	3	18	6
PLANNED	6/28/2021	3	87	29
PLANNED	6/28/2021	2	108	54
PLANNED	6/28/2021	1	64	64
PLANNED	6/28/2021	1	5	5
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	2	2	1
PLANNED	6/28/2021	4	24	6
PLANNED	6/28/2021	2	119	62
PLANNED	6/28/2021	1	26	26
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	1	9	9
PLANNED	6/28/2021	5	85	17
PLANNED	6/28/2021	8	168	21
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	1	60	60
PLANNED	6/28/2021	2	18	9
PLANNED	6/28/2021	3	24	8
PLANNED	6/28/2021	2	146	73
PLANNED	6/28/2021	4	52	13
PLANNED	6/28/2021	1	21	21
PLANNED	6/28/2021	2	70	35
PLANNED	6/28/2021	2	48	24
PLANNED	6/28/2021	6	42	7
PLANNED	6/28/2021	1	11	11
PLANNED	6/28/2021	6	228	38
PLANNED	6/28/2021	8	136	17
PLANNED	6/28/2021	2	12	6
PLANNED	6/28/2021	1	28	28
PLANNED	6/28/2021	1	6	6
PLANNED	6/28/2021	3	54	18
PLANNED	6/28/2021	36	360	10
PLANNED	6/28/2021	3	21	7
PLANNED	6/28/2021	2	10	5
PLANNED	6/28/2021	3	18	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/28/2021	3	12	4
PLANNED	6/28/2021	4	260	65
PLANNED	6/28/2021	3	48	16
PLANNED	6/28/2021	5	85	17
PLANNED	6/28/2021	1	186	186
PLANNED	6/28/2021	16	1,552	97
PLANNED	6/28/2021	1	152	152
PLANNED	6/28/2021	2	60	30
PLANNED	6/28/2021	1	65	65
PLANNED	6/28/2021	1	206	206
PLANNED	6/29/2021	1	82	82
PLANNED	6/29/2021	8	16	2
PLANNED	6/29/2021	1	183	183
PLANNED	6/29/2021	11	363	33
PLANNED	6/29/2021	1	87	87
PLANNED	6/29/2021	13	312	24
PLANNED	6/29/2021	2	202	101
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	3	171	57
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	1	90	90
PLANNED	6/29/2021	4	24	6
PLANNED	6/29/2021	2	176	88
PLANNED	6/29/2021	9	153	17
PLANNED	6/29/2021	4	324	81
PLANNED	6/29/2021	1	240	240
PLANNED	6/29/2021	3	21	7
PLANNED	6/29/2021	2	12	6
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	1	9	9
PLANNED	6/29/2021	4	32	8
PLANNED	6/29/2021	4	36	9
PLANNED	6/29/2021	5	35	7
PLANNED	6/29/2021	4	40	10
PLANNED	6/29/2021	6	498	83
PLANNED	6/29/2021	1	164	164
PLANNED	6/29/2021	11	682	62
PLANNED	6/29/2021	8	1,192	149
PLANNED	6/29/2021	1	8	8
PLANNED	6/29/2021	7	1,029	147
PLANNED	6/29/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	4	324	100
PLANNED	6/29/2021	3	30	10
PLANNED	6/29/2021	2	22	11
PLANNED	6/29/2021	6	1,290	215
PLANNED	6/29/2021	1	233	233
PLANNED	6/29/2021	6	66	11
PLANNED	6/29/2021	4	40	10
PLANNED	6/29/2021	6	372	62
PLANNED	6/29/2021	1	46	46
PLANNED	6/29/2021	5	265	53
PLANNED	6/29/2021	2	126	63
PLANNED	6/29/2021	3	30	10
PLANNED	6/29/2021	28	8,204	293
PLANNED	6/29/2021	2	80	40
PLANNED	6/29/2021	2	30	15
PLANNED	6/29/2021	6	54	9
PLANNED	6/29/2021	3	6	2
PLANNED	6/29/2021	3	42	14
PLANNED	6/29/2021	4	68	17
PLANNED	6/29/2021	2	12	6
PLANNED	6/29/2021	14	924	66
PLANNED	6/29/2021	4	1,300	325
PLANNED	6/29/2021	15	840	56
PLANNED	6/29/2021	1	11	11
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	8	144	18
PLANNED	6/29/2021	2	28	14
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	8	88	11
PLANNED	6/29/2021	2	26	13
CUSTOMER REQUEST	6/29/2021	49	294	6
PLANNED	6/29/2021	4	25	7
PLANNED	6/29/2021	1	11	11
PLANNED	6/29/2021	7	28	4
PLANNED	6/29/2021	1	16	16
PLANNED	6/29/2021	11	1,320	120
PLANNED	6/29/2021	7	56	8
PLANNED	6/29/2021	1	3	3
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	1	191	191
PLANNED	6/29/2021	7	70	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	3	276	92
PLANNED	6/29/2021	7	749	107
PLANNED	6/29/2021	11	2,233	203
PLANNED	6/29/2021	6	30	5
PLANNED	6/29/2021	2	88	44
PLANNED	6/29/2021	4	16	4
PLANNED	6/29/2021	1	34	34
PLANNED	6/29/2021	5	265	53
PLANNED	6/29/2021	3	27	9
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	2	36	18
PLANNED	6/29/2021	4	24	6
PLANNED	6/29/2021	16	784	49
PLANNED	6/29/2021	3	57	19
PLANNED	6/29/2021	10	1,350	135
PLANNED	6/29/2021	9	810	90
PLANNED	6/29/2021	1	39	39
PLANNED	6/29/2021	1	98	98
PLANNED	6/29/2021	9	99	11
PLANNED	6/29/2021	2	52	26
PLANNED	6/29/2021	6	612	102
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	2	12	6
PLANNED	6/29/2021	6	96	16
PLANNED	6/29/2021	1	6	6
PLANNED	6/29/2021	3	669	223
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	4	20	5
PLANNED	6/29/2021	10	10	1
PLANNED	6/29/2021	9	2,844	316
PLANNED	6/29/2021	10	500	50
PLANNED	6/29/2021	1	11	11
PLANNED	6/29/2021	7	609	87
PLANNED	6/29/2021	3	411	137
PLANNED	6/29/2021	1	21	21
PLANNED	6/29/2021	10	890	89
PLANNED	6/29/2021	3	21	7
PLANNED	6/29/2021	11	704	64
PLANNED	6/29/2021	7	4,123	589
PLANNED	6/29/2021	24	72	3
PLANNED	6/29/2021	1	385	385

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	3	156	52
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	4	20	5
CUSTOMER REQUEST	6/29/2021	9	369	41
PLANNED	6/29/2021	2	102	51
PLANNED	6/29/2021	1	9	9
PLANNED	6/29/2021	5	240	48
PLANNED	6/29/2021	2	86	43
PLANNED	6/29/2021	62	5,766	93
PLANNED	6/29/2021	2	10	5
PLANNED	6/29/2021	1	284	284
PLANNED	6/29/2021	4	52	13
PLANNED	6/29/2021	1	6	6
PLANNED	6/29/2021	4	16	4
PLANNED	6/29/2021	2	184	92
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	2	66	33
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	1	62	62
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	2	44	22
PLANNED	6/29/2021	7	42	6
PLANNED	6/29/2021	1	14	14
PLANNED	6/29/2021	10	100	10
PLANNED	6/29/2021	1	34	34
PLANNED	6/29/2021	3	84	28
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	2	20	10
PLANNED	6/29/2021	2	88	44
PLANNED	6/29/2021	6	666	111
CUSTOMER REQUEST	6/29/2021	13	169	13
PLANNED	6/29/2021	3	51	17
PLANNED	6/29/2021	9	81	9
CUSTOMER REQUEST	6/29/2021	8	216	27
PLANNED	6/29/2021	3	30	10
PLANNED	6/29/2021	8	1,864	233
PLANNED	6/29/2021	1	10	10
PLANNED	6/29/2021	17	2,617	169
PLANNED	6/29/2021	1	80	80
PLANNED	6/29/2021	6	240	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	7	518	74
PLANNED	6/29/2021	3	27	9
PLANNED	6/29/2021	4	32	8
PLANNED	6/29/2021	5	25	5
PLANNED	6/29/2021	1	21	21
PLANNED	6/29/2021	3	30	10
PLANNED	6/29/2021	1	14	14
PLANNED	6/29/2021	3	21	7
PLANNED	6/29/2021	2	24	12
PLANNED	6/29/2021	3	39	13
PLANNED	6/29/2021	1	8	8
PLANNED	6/29/2021	2	298	149
PLANNED	6/29/2021	5	35	7
PLANNED	6/29/2021	3	24	8
PLANNED	6/29/2021	11	946	86
PLANNED	6/29/2021	6	96	16
PLANNED	6/29/2021	3	12	4
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	2	82	41
PLANNED	6/29/2021	4	56	14
PLANNED	6/29/2021	3	417	139
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	3	15	5
PLANNED	6/29/2021	12	504	42
PLANNED	6/29/2021	4	36	9
PLANNED	6/29/2021	2	10	5
PLANNED	6/29/2021	11	165	15
PLANNED	6/29/2021	2	158	79
PLANNED	6/29/2021	5	25	5
PLANNED	6/29/2021	4	380	95
PLANNED	6/29/2021	4	200	50
PLANNED	6/29/2021	3	51	17
PLANNED	6/29/2021	1	28	28
PLANNED	6/29/2021	2	42	21
PLANNED	6/29/2021	6	720	120
PLANNED	6/29/2021	4	28	7
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	2	8	4
PLANNED	6/29/2021	16	1,600	100
PLANNED	6/29/2021	9	990	110
PLANNED	6/29/2021	5	60	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	6	120	20
PLANNED	6/29/2021	3	168	56
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	4	20	5
PLANNED	6/29/2021	5	180	36
PLANNED	6/29/2021	1	32	32
PLANNED	6/29/2021	4	24	6
PLANNED	6/29/2021	12	240	20
PLANNED	6/29/2021	3	45	15
PLANNED	6/29/2021	3	21	7
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	6	78	13
PLANNED	6/29/2021	2	10	5
PLANNED	6/29/2021	3	33	11
PLANNED	6/29/2021	4	164	41
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	9	63	7
PLANNED	6/29/2021	1	9	9
PLANNED	6/29/2021	3	159	53
PLANNED	6/29/2021	3	9	3
PLANNED	6/29/2021	1	8	8
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	8	496	62
PLANNED	6/29/2021	3	66	22
PLANNED	6/29/2021	3	267	89
PLANNED	6/29/2021	3	42	14
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	4	24	6
PLANNED	6/29/2021	1	13	13
PLANNED	6/29/2021	2	150	75
PLANNED	6/29/2021	4	12	3
PLANNED	6/29/2021	7	70	10
PLANNED	6/29/2021	3	30	10
CUSTOMER REQUEST	6/29/2021	1	62	62
PLANNED	6/29/2021	4	24	6
PLANNED	6/29/2021	2	12	6
PLANNED	6/29/2021	1	6	6
PLANNED	6/29/2021	4	60	15
PLANNED	6/29/2021	4	36	9
PLANNED	6/29/2021	7	301	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	4	28	7
PLANNED	6/29/2021	3	24	8
PLANNED	6/29/2021	2	24	12
PLANNED	6/29/2021	4	28	7
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	1	8	8
PLANNED	6/29/2021	6	192	32
PLANNED	6/29/2021	4	36	9
PLANNED	6/29/2021	1	59	59
PLANNED	6/29/2021	3	66	22
PLANNED	6/29/2021	7	294	42
PLANNED	6/29/2021	2	14	7
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	3	21	7
PLANNED	6/29/2021	2	10	5
PLANNED	6/29/2021	3	24	8
PLANNED	6/29/2021	3	3	1
PLANNED	6/29/2021	4	32	8
PLANNED	6/29/2021	2	4	2
PLANNED	6/29/2021	3	114	38
PLANNED	6/29/2021	4	52	13
PLANNED	6/29/2021	5	45	9
PLANNED	6/29/2021	2	18	9
PLANNED	6/29/2021	3	63	21
PLANNED	6/29/2021	2	12	6
PLANNED	6/29/2021	2	8	4
PLANNED	6/29/2021	10	710	71
PLANNED	6/29/2021	7	14	2
PLANNED	6/29/2021	3	39	13
PLANNED	6/29/2021	11	77	7
PLANNED	6/29/2021	2	92	46
PLANNED	6/29/2021	4	292	73
PLANNED	6/29/2021	3	57	19
PLANNED	6/29/2021	3	54	18
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	1	5	5
PLANNED	6/29/2021	1	7	7
PLANNED	6/29/2021	3	252	84
PLANNED	6/29/2021	6	36	6
PLANNED	6/29/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/29/2021	1	4	4
PLANNED	6/29/2021	8	592	74
PLANNED	6/29/2021	1	7	7
PLANNED	6/29/2021	2	16	8
PLANNED	6/29/2021	1	2	2
PLANNED	6/29/2021	4	32	8
PLANNED	6/29/2021	4	44	11
PLANNED	6/29/2021	3	18	6
PLANNED	6/29/2021	3	81	27
PLANNED	6/29/2021	1	176	176
PLANNED	6/29/2021	1	58	58
PLANNED	6/29/2021	1	116	116
PLANNED	6/30/2021	3	477	159
PLANNED	6/30/2021	5	830	166
PLANNED	6/30/2021	4	244	61
PLANNED	6/30/2021	21	4,158	198
PLANNED	6/30/2021	1	74	74
PLANNED	6/30/2021	2	324	162
PLANNED	6/30/2021	1	145	145
PLANNED	6/30/2021	5	45	9
PLANNED	6/30/2021	4	16	4
PLANNED	6/30/2021	6	78	13
PLANNED	6/30/2021	3	381	127
PLANNED	6/30/2021	4	32	8
PLANNED	6/30/2021	2	326	163
PLANNED	6/30/2021	2	104	52
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	2	198	99
PLANNED	6/30/2021	3	33	11
PLANNED	6/30/2021	5	20	4
PLANNED	6/30/2021	3	276	92
PLANNED	6/30/2021	2	6	3
PLANNED	6/30/2021	2	118	59
PLANNED	6/30/2021	6	600	100
PLANNED	6/30/2021	2	628	314
PLANNED	6/30/2021	3	12	4
PLANNED	6/30/2021	8	400	50
PLANNED	6/30/2021	5	30	6
PLANNED	6/30/2021	2	22	11
PLANNED	6/30/2021	3	462	154
PLANNED	6/30/2021	2	398	199

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	1	79	79
PLANNED	6/30/2021	1	150	150
PLANNED	6/30/2021	3	21	7
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	2	16	8
PLANNED	6/30/2021	3	333	111
PLANNED	6/30/2021	2	252	126
PLANNED	6/30/2021	2	222	111
PLANNED	6/30/2021	1	8	8
PLANNED	6/30/2021	6	186	31
PLANNED	6/30/2021	2	252	126
PLANNED	6/30/2021	2	358	179
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	1	11	11
PLANNED	6/30/2021	2	42	21
PLANNED	6/30/2021	2	20	10
PLANNED	6/30/2021	3	12	4
PLANNED	6/30/2021	8	1,448	181
PLANNED	6/30/2021	2	496	248
PLANNED	6/30/2021	4	324	81
PLANNED	6/30/2021	1	142	142
PLANNED	6/30/2021	1	16	16
PLANNED	6/30/2021	6	378	63
PLANNED	6/30/2021	2	94	47
PLANNED	6/30/2021	2	6	3
PLANNED	6/30/2021	1	8	8
PLANNED	6/30/2021	2	8	4
PLANNED	6/30/2021	4	1,264	316
PLANNED	6/30/2021	3	9	3
PLANNED	6/30/2021	2	498	249
PLANNED	6/30/2021	13	663	51
PLANNED	6/30/2021	1	8	8
PLANNED	6/30/2021	2	38	19
PLANNED	6/30/2021	13	4,069	313
PLANNED	6/30/2021	2	6	3
PLANNED	6/30/2021	4	44	11
CUSTOMER REQUEST	6/30/2021	13	130	10
PLANNED	6/30/2021	1	9	9
PLANNED	6/30/2021	1	3	3
PLANNED	6/30/2021	4	200	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	3	9	3
PLANNED	6/30/2021	1	334	334
PLANNED	6/30/2021	2	10	5
PLANNED	6/30/2021	14	1,568	112
PLANNED	6/30/2021	3	360	120
CUSTOMER REQUEST	6/30/2021	1	641	641
PLANNED	6/30/2021	1	19	19
PLANNED	6/30/2021	12	120	10
PLANNED	6/30/2021	4	20	5
PLANNED	6/30/2021	1	11	11
PLANNED	6/30/2021	6	876	146
PLANNED	6/30/2021	6	36	6
PLANNED	6/30/2021	7	595	85
PLANNED	6/30/2021	6	678	113
PLANNED	6/30/2021	1	6	6
PLANNED	6/30/2021	1	16	16
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	13	858	66
PLANNED	6/30/2021	2	18	9
PLANNED	6/30/2021	3	234	78
PLANNED	6/30/2021	8	56	7
PLANNED	6/30/2021	3	333	111
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	2	562	281
PLANNED	6/30/2021	2	14	7
PLANNED	6/30/2021	1	25	25
PLANNED	6/30/2021	6	792	132
PLANNED	6/30/2021	3	102	34
PLANNED	6/30/2021	5	15	3
PLANNED	6/30/2021	2	24	12
PLANNED	6/30/2021	7	182	26
PLANNED	6/30/2021	2	40	20
PLANNED	6/30/2021	4	16	4
PLANNED	6/30/2021	3	48	16
PLANNED	6/30/2021	6	78	13
PLANNED	6/30/2021	2	890	445
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	1	6	6
PLANNED	6/30/2021	1	19	19
PLANNED	6/30/2021	2	14	7
PLANNED	6/30/2021	12	924	77

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	2	278	139
PLANNED	6/30/2021	3	21	7
PLANNED	6/30/2021	2	10	5
PLANNED	6/30/2021	3	12	4
PLANNED	6/30/2021	4	168	42
PLANNED	6/30/2021	1	9	9
PLANNED	6/30/2021	1	67	67
PLANNED	6/30/2021	3	531	177
PLANNED	6/30/2021	10	620	62
PLANNED	6/30/2021	5	415	83
PLANNED	6/30/2021	1	76	76
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	21	84	4
PLANNED	6/30/2021	5	55	11
PLANNED	6/30/2021	7	1,414	202
PLANNED	6/30/2021	1	147	147
PLANNED	6/30/2021	5	25	5
PLANNED	6/30/2021	3	106	61
CUSTOMER REQUEST	6/30/2021	4	36	9
PLANNED	6/30/2021	3	120	40
PLANNED	6/30/2021	4	144	36
PLANNED	6/30/2021	2	106	53
PLANNED	6/30/2021	2	138	69
PLANNED	6/30/2021	4	28	7
PLANNED	6/30/2021	3	396	132
CUSTOMER REQUEST	6/30/2021	8	48	6
PLANNED	6/30/2021	2	30	15
PLANNED	6/30/2021	3	36	12
PLANNED	6/30/2021	3	9	3
PLANNED	6/30/2021	3	222	74
PLANNED	6/30/2021	3	219	73
PLANNED	6/30/2021	4	64	16
PLANNED	6/30/2021	4	88	22
PLANNED	6/30/2021	2	10	5
PLANNED	6/30/2021	1	253	253
PLANNED	6/30/2021	1	7	7
PLANNED	6/30/2021	8	672	84
PLANNED	6/30/2021	4	40	10
PLANNED	6/30/2021	6	594	99
PLANNED	6/30/2021	4	68	17
PLANNED	6/30/2021	4	204	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	2	30	15
PLANNED	6/30/2021	12	1,440	120
PLANNED	6/30/2021	17	1,071	63
PLANNED	6/30/2021	3	360	120
PLANNED	6/30/2021	3	21	7
PLANNED	6/30/2021	4	92	23
PLANNED	6/30/2021	1	30	30
PLANNED	6/30/2021	2	4	2
PLANNED	6/30/2021	2	44	22
PLANNED	6/30/2021	1	186	186
PLANNED	6/30/2021	4	60	15
PLANNED	6/30/2021	6	714	119
PLANNED	6/30/2021	4	20	5
PLANNED	6/30/2021	3	21	7
PLANNED	6/30/2021	3	39	13
PLANNED	6/30/2021	5	845	169
PLANNED	6/30/2021	15	4,380	292
PLANNED	6/30/2021	4	298	102
PLANNED	6/30/2021	4	20	5
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	3	123	41
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	10	2,330	233
PLANNED	6/30/2021	3	207	69
PLANNED	6/30/2021	13	793	61
PLANNED	6/30/2021	1	112	112
PLANNED	6/30/2021	5	1,220	244
PLANNED	6/30/2021	1	14	14
PLANNED	6/30/2021	3	21	7
PLANNED	6/30/2021	2	10	5
PLANNED	6/30/2021	5	75	15
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	2	66	33
PLANNED	6/30/2021	4	24	6
PLANNED	6/30/2021	2	104	52
PLANNED	6/30/2021	4	48	12
PLANNED	6/30/2021	7	497	71
PLANNED	6/30/2021	1	47	47
PLANNED	6/30/2021	1	6	6
PLANNED	6/30/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	2	36	18
PLANNED	6/30/2021	8	168	21
PLANNED	6/30/2021	4	36	9
PLANNED	6/30/2021	1	24	24
PLANNED	6/30/2021	5	60	12
PLANNED	6/30/2021	7	1,092	156
PLANNED	6/30/2021	2	316	158
PLANNED	6/30/2021	2	12	6
PLANNED	6/30/2021	3	474	158
PLANNED	6/30/2021	2	178	89
PLANNED	6/30/2021	3	18	6
CUSTOMER REQUEST	6/30/2021	1	81	81
PLANNED	6/30/2021	1	10	10
PLANNED	6/30/2021	4	20	5
PLANNED	6/30/2021	1	35	35
PLANNED	6/30/2021	1	74	74
PLANNED	6/30/2021	2	16	8
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	3	42	14
CUSTOMER REQUEST	6/30/2021	1	101	101
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	4	24	6
PLANNED	6/30/2021	4	28	7
PLANNED	6/30/2021	1	15	15
PLANNED	6/30/2021	4	64	16
PLANNED	6/30/2021	5	180	36
PLANNED	6/30/2021	2	26	13
PLANNED	6/30/2021	4	52	13
PLANNED	6/30/2021	3	18	6
PLANNED	6/30/2021	2	90	45
PLANNED	6/30/2021	1	4	4
PLANNED	6/30/2021	2	16	8
PLANNED	6/30/2021	1	8	8
PLANNED	6/30/2021	1	5	5
PLANNED	6/30/2021	2	14	7
PLANNED	6/30/2021	1	7	7
PLANNED	6/30/2021	6	474	79
PLANNED	6/30/2021	2	116	58
PLANNED	6/30/2021	5	60	12
PLANNED	6/30/2021	5	105	21
PLANNED	6/30/2021	8	32	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	1	5	5
PLANNED	6/30/2021	9	45	5
PLANNED	6/30/2021	2	124	62
PLANNED	6/30/2021	8	80	10
PLANNED	6/30/2021	6	84	14
PLANNED	6/30/2021	1	105	105
PLANNED	6/30/2021	7	56	8
CUSTOMER REQUEST	6/30/2021	4	80	20
PLANNED	6/30/2021	3	27	9
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	4	28	7
PLANNED	6/30/2021	1	71	71
PLANNED	6/30/2021	1	71	71
PLANNED	6/30/2021	11	143	13
PLANNED	6/30/2021	5	30	6
PLANNED	6/30/2021	13	65	5
PLANNED	6/30/2021	1	64	64
PLANNED	6/30/2021	2	36	18
PLANNED	6/30/2021	5	50	10
PLANNED	6/30/2021	3	48	16
PLANNED	6/30/2021	1	56	56
PLANNED	6/30/2021	1	90	90
PLANNED	6/30/2021	2	80	40
PLANNED	6/30/2021	6	846	141
PLANNED	6/30/2021	5	85	17
PLANNED	6/30/2021	6	168	28
PLANNED	6/30/2021	4	148	37
PLANNED	6/30/2021	4	116	29
PLANNED	6/30/2021	3	207	69
PLANNED	6/30/2021	10	60	6
PLANNED	6/30/2021	3	57	19
PLANNED	6/30/2021	13	169	13
PLANNED	6/30/2021	1	172	172
PLANNED	6/30/2021	4	184	46
PLANNED	6/30/2021	2	16	8
PLANNED	6/30/2021	3	159	53
PLANNED	6/30/2021	4	172	43
PLANNED	6/30/2021	6	204	34
PLANNED	6/30/2021	5	275	55
PLANNED	6/30/2021	3	15	5
PLANNED	6/30/2021	2	8	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	6/30/2021	4	16	4
PLANNED	6/30/2021	3	33	11
CUSTOMER REQUEST	6/30/2021	8	408	51
PLANNED	6/30/2021	2	292	146
PLANNED	6/30/2021	3	69	23
PLANNED	6/30/2021	1	80	80
PLANNED	6/30/2021	3	72	24
PLANNED	6/30/2021	1	11	11
PLANNED	6/30/2021	1	12	12
PLANNED	6/30/2021	4	44	11
PLANNED	6/30/2021	4	48	12
PLANNED	6/30/2021	4	308	77
PLANNED	6/30/2021	1	116	116
PLANNED	6/30/2021	2	280	140
PLANNED	6/30/2021	6	228	38
PLANNED	6/30/2021	1	30	30
PLANNED	6/30/2021	1	75	75
PLANNED	7/1/2021	3	357	119
PLANNED	7/1/2021	1	180	180
CUSTOMER REQUEST	7/1/2021	1	906	906
PLANNED	7/1/2021	1	60	60
PLANNED	7/1/2021	2	156	78
PLANNED	7/1/2021	1	36	36
PLANNED	7/1/2021	3	144	48
PLANNED	7/1/2021	1	114	114
CUSTOMER REQUEST	7/1/2021	1	136	136
PLANNED	7/1/2021	1	24	24
PLANNED	7/1/2021	4	32	8
PLANNED	7/1/2021	10	440	44
PLANNED	7/1/2021	4	304	76
PLANNED	7/1/2021	23	391	17
PLANNED	7/1/2021	2	12	6
PLANNED	7/1/2021	4	24	6
PLANNED	7/1/2021	6	282	47
PLANNED	7/1/2021	2	10	5
PLANNED	7/1/2021	3	266	108
PLANNED	7/1/2021	1	13	13
PLANNED	7/1/2021	2	202	101
PLANNED	7/1/2021	1	43	43
PLANNED	7/1/2021	6	390	124
PLANNED	7/1/2021	2	140	70

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/1/2021	1	12	12
PLANNED	7/1/2021	2	14	7
PLANNED	7/1/2021	4	452	113
PLANNED	7/1/2021	1	183	183
PLANNED	7/1/2021	2	26	13
PLANNED	7/1/2021	1	49	49
PLANNED	7/1/2021	2	48	24
PLANNED	7/1/2021	1	10	10
PLANNED	7/1/2021	2	428	214
PLANNED	7/1/2021	1	208	208
PLANNED	7/1/2021	2	116	58
PLANNED	7/1/2021	4	708	177
CUSTOMER REQUEST	7/1/2021	37	333	9
CUSTOMER REQUEST	7/1/2021	4	248	62
PLANNED	7/1/2021	2	414	207
PLANNED	7/1/2021	4	32	8
PLANNED	7/1/2021	2	224	112
CUSTOMER REQUEST	7/1/2021	124	26,412	213
PLANNED	7/1/2021	7	49	7
PLANNED	7/1/2021	1	7	7
PLANNED	7/1/2021	4	60	15
PLANNED	7/1/2021	2	292	146
PLANNED	7/1/2021	2	36	18
PLANNED	7/1/2021	3	24	8
PLANNED	7/1/2021	2	158	79
PLANNED	7/1/2021	5	400	80
PLANNED	7/1/2021	3	240	80
PLANNED	7/1/2021	10	600	60
PLANNED	7/1/2021	18	216	12
PLANNED	7/1/2021	3	18	6
PLANNED	7/1/2021	5	495	99
CUSTOMER REQUEST	7/1/2021	3	75	25
PLANNED	7/1/2021	8	688	86
PLANNED	7/1/2021	3	633	211
PLANNED	7/1/2021	1	7	7
PLANNED	7/1/2021	1	69	69
PLANNED	7/1/2021	15	660	44
PLANNED	7/1/2021	1	88	88
PLANNED	7/1/2021	4	44	11
PLANNED	7/1/2021	1	64	64
PLANNED	7/1/2021	8	704	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/1/2021	3	207	69
PLANNED	7/1/2021	3	111	37
PLANNED	7/1/2021	1	69	69
PLANNED	7/1/2021	6	798	133
PLANNED	7/1/2021	2	126	63
CUSTOMER REQUEST	7/1/2021	2	34	17
PLANNED	7/1/2021	4	24	6
PLANNED	7/1/2021	5	328	92
PLANNED	7/1/2021	1	53	53
PLANNED	7/1/2021	2	60	30
PLANNED	7/1/2021	2	86	43
PLANNED	7/1/2021	2	76	38
PLANNED	7/1/2021	2	267	137
PLANNED	7/1/2021	7	546	78
CUSTOMER REQUEST	7/1/2021	4	60	15
PLANNED	7/1/2021	4	272	68
PLANNED	7/1/2021	2	110	55
PLANNED	7/1/2021	2	300	150
PLANNED	7/1/2021	2	190	95
CUSTOMER REQUEST	7/1/2021	8	64	8
PLANNED	7/1/2021	9	666	74
PLANNED	7/1/2021	3	171	57
PLANNED	7/1/2021	8	280	35
PLANNED	7/1/2021	6	120	20
PLANNED	7/1/2021	1	52	52
PLANNED	7/1/2021	1	82	82
PLANNED	7/1/2021	4	52	13
PLANNED	7/1/2021	5	50	10
PLANNED	7/1/2021	10	1,650	165
PLANNED	7/1/2021	4	964	241
CUSTOMER REQUEST	7/1/2021	10	170	17
PLANNED	7/1/2021	8	64	8
PLANNED	7/1/2021	4	60	15
PLANNED	7/1/2021	13	910	70
PLANNED	7/1/2021	3	33	11
PLANNED	7/1/2021	3	30	10
PLANNED	7/1/2021	2	22	11
PLANNED	7/1/2021	2	24	12
PLANNED	7/1/2021	2	60	30
PLANNED	7/1/2021	6	648	108
PLANNED	7/1/2021	6	552	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/1/2021	5	490	98
PLANNED	7/1/2021	3	54	18
PLANNED	7/1/2021	4	132	33
PLANNED	7/1/2021	4	71	35
PLANNED	7/1/2021	12	840	70
PLANNED	7/1/2021	1	94	94
PLANNED	7/1/2021	2	10	5
CUSTOMER REQUEST	7/1/2021	9	792	88
CUSTOMER REQUEST	7/1/2021	2	116	58
PLANNED	7/1/2021	5	805	169
PLANNED	7/1/2021	6	192	32
PLANNED	7/1/2021	9	351	39
PLANNED	7/1/2021	3	60	20
PLANNED	7/1/2021	2	18	9
PLANNED	7/1/2021	1	188	188
PLANNED	7/1/2021	2	156	78
PLANNED	7/1/2021	2	256	128
PLANNED	7/1/2021	2	194	97
PLANNED	7/1/2021	3	171	57
PLANNED	7/1/2021	1	11	11
PLANNED	7/1/2021	8	376	47
PLANNED	7/1/2021	3	120	40
PLANNED	7/1/2021	3	21	7
PLANNED	7/1/2021	3	450	150
PLANNED	7/1/2021	2	246	123
PLANNED	7/1/2021	8	1,976	247
PLANNED	7/1/2021	1	27	27
PLANNED	7/1/2021	2	12	6
PLANNED	7/1/2021	2	42	21
PLANNED	7/1/2021	5	500	100
PLANNED	7/1/2021	3	30	10
PLANNED	7/1/2021	5	470	94
PLANNED	7/1/2021	6	588	98
PLANNED	7/1/2021	2	106	53
PLANNED	7/1/2021	3	18	6
PLANNED	7/1/2021	2	14	7
PLANNED	7/1/2021	25	1,322	98
PLANNED	7/1/2021	2	16	8
PLANNED	7/1/2021	3	33	11
PLANNED	7/1/2021	1	23	23
CUSTOMER REQUEST	7/1/2021	6	240	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/1/2021	3	27	9
PLANNED	7/1/2021	2	34	17
PLANNED	7/1/2021	1	45	45
PLANNED	7/1/2021	2	68	34
PLANNED	7/1/2021	9	540	60
PLANNED	7/1/2021	1	64	64
PLANNED	7/1/2021	1	21	21
PLANNED	7/1/2021	4	400	100
PLANNED	7/1/2021	3	45	15
PLANNED	7/1/2021	2	20	10
PLANNED	7/1/2021	11	286	26
PLANNED	7/1/2021	11	286	26
PLANNED	7/1/2021	7	245	35
PLANNED	7/1/2021	8	32	4
PLANNED	7/1/2021	2	98	49
PLANNED	7/1/2021	3	24	8
PLANNED	7/1/2021	2	160	80
PLANNED	7/1/2021	8	88	11
PLANNED	7/1/2021	1	18	18
PLANNED	7/1/2021	4	24	6
PLANNED	7/1/2021	73	146	2
PLANNED	7/1/2021	1	51	51
PLANNED	7/1/2021	1	56	56
PLANNED	7/1/2021	2	132	66
PLANNED	7/1/2021	1	127	127
PLANNED	7/1/2021	2	130	65
PLANNED	7/1/2021	2	264	132
PLANNED	7/2/2021	7	385	55
PLANNED	7/2/2021	1	126	126
PLANNED	7/2/2021	1	124	124
PLANNED	7/2/2021	5	565	113
PLANNED	7/2/2021	1	175	175
PLANNED	7/2/2021	21	2,898	138
PLANNED	7/2/2021	6	432	72
PLANNED	7/2/2021	2	180	90
PLANNED	7/2/2021	2	264	132
PLANNED	7/2/2021	2	108	54
PLANNED	7/2/2021	1	241	241
PLANNED	7/2/2021	2	118	59
PLANNED	7/2/2021	3	339	113
PLANNED	7/2/2021	2	280	140

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/2/2021	4	20	5
PLANNED	7/2/2021	1	41	41
PLANNED	7/2/2021	4	28	7
PLANNED	7/2/2021	4	60	15
PLANNED	7/2/2021	4	156	39
PLANNED	7/2/2021	2	20	10
PLANNED	7/2/2021	7	77	11
PLANNED	7/2/2021	4	24	6
PLANNED	7/2/2021	3	114	38
PLANNED	7/2/2021	12	156	13
PLANNED	7/2/2021	13	143	11
PLANNED	7/2/2021	11	3,322	302
PLANNED	7/2/2021	2	106	53
CUSTOMER REQUEST	7/2/2021	32	6,432	201
PLANNED	7/2/2021	3	315	105
PLANNED	7/2/2021	1	166	166
PLANNED	7/2/2021	3	267	89
PLANNED	7/2/2021	2	584	292
PLANNED	7/2/2021	8	264	33
PLANNED	7/2/2021	8	552	69
PLANNED	7/2/2021	4	248	62
PLANNED	7/2/2021	8	288	36
PLANNED	7/2/2021	8	704	88
PLANNED	7/2/2021	6	558	93
PLANNED	7/2/2021	2	236	118
PLANNED	7/2/2021	5	390	78
PLANNED	7/2/2021	98	6,664	68
CUSTOMER REQUEST	7/2/2021	10	890	89
PLANNED	7/2/2021	3	276	92
PLANNED	7/2/2021	11	979	89
CUSTOMER REQUEST	7/2/2021	8	464	58
PLANNED	7/2/2021	2	282	141
PLANNED	7/2/2021	2	604	302
PLANNED	7/2/2021	8	238	35
CUSTOMER REQUEST	7/2/2021	8	216	27
PLANNED	7/2/2021	8	320	40
PLANNED	7/2/2021	9	162	18
PLANNED	7/2/2021	6	186	31
PLANNED	7/2/2021	8	864	108
CUSTOMER REQUEST	7/2/2021	4	1,460	365
PLANNED	7/2/2021	6	390	65

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	7/2/2021	4	60	15
CUSTOMER REQUEST	7/2/2021	14	1,092	78
CUSTOMER REQUEST	7/2/2021	2	160	80
PLANNED	7/2/2021	1	34	34
PLANNED	7/2/2021	6	324	54
PLANNED	7/2/2021	1	101	101
PLANNED	7/2/2021	7	630	90
PLANNED	7/2/2021	2	180	90
PLANNED	7/2/2021	6	36	6
PLANNED	7/2/2021	1	58	58
CUSTOMER REQUEST	7/2/2021	1	63	63
PLANNED	7/2/2021	4	280	70
PLANNED	7/2/2021	4	520	130
PLANNED	7/2/2021	3	54	18
PLANNED	7/2/2021	3	645	215
PLANNED	7/2/2021	1	14	14
PLANNED	7/2/2021	4	268	67
PLANNED	7/2/2021	1	63	63
PLANNED	7/2/2021	2	202	101
PLANNED	7/2/2021	8	480	60
PLANNED	7/2/2021	11	649	59
PLANNED	7/2/2021	8	96	12
PLANNED	7/2/2021	4	348	87
PLANNED	7/2/2021	7	1,085	155
PLANNED	7/2/2021	8	8	1
PLANNED	7/2/2021	3	123	41
PLANNED	7/2/2021	1	109	109
PLANNED	7/2/2021	1	72	72
PLANNED	7/2/2021	1	143	143
CUSTOMER REQUEST	7/2/2021	1	2,472	2,472
PLANNED	7/2/2021	9	1,305	145
PLANNED	7/2/2021	3	303	101
PLANNED	7/3/2021	2	140	70
CUSTOMER REQUEST	7/3/2021	5	1,810	362
PLANNED	7/3/2021	2	272	136
PLANNED	7/3/2021	1	99	99
PLANNED	7/3/2021	1	207	207
PLANNED	7/3/2021	6	108	18
PLANNED	7/3/2021	2	128	64
PLANNED	7/3/2021	10	2,980	298
PLANNED	7/3/2021	1	14	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/3/2021	3	306	102
PLANNED	7/3/2021	2	86	43
PLANNED	7/3/2021	4	192	48
CUSTOMER REQUEST	7/4/2021	2,970	190,190	101
CUSTOMER REQUEST	7/4/2021	1	276	276
PLANNED	7/4/2021	2	280	140
PLANNED	7/4/2021	5	1,670	334
PLANNED	7/4/2021	1	194	194
PLANNED	7/4/2021	8	1,512	189
PLANNED	7/4/2021	7	1,610	230
PLANNED	7/4/2021	3	186	62
PLANNED	7/4/2021	35	665	19
PLANNED	7/7/2021	4	388	97
PLANNED	7/7/2021	22	1,430	65
PLANNED	7/8/2021	11	1,507	137
PLANNED	7/8/2021	14	1,862	133
PLANNED	7/8/2021	6	882	147
PLANNED	7/8/2021	1	55	55
PLANNED	7/8/2021	4	564	141
PLANNED	7/8/2021	1	120	120
PLANNED	7/8/2021	2	176	88
PLANNED	7/8/2021	11	2,057	187
PLANNED	7/8/2021	11	2,057	187
PLANNED	7/8/2021	20	2,860	143
PLANNED	7/8/2021	6	312	52
PLANNED	7/8/2021	4	580	145
PLANNED	7/8/2021	1	58	58
PLANNED	7/8/2021	2	178	99
PLANNED	7/8/2021	2	85	45
PLANNED	7/8/2021	3	201	71
PLANNED	7/8/2021	1	16	16
PLANNED	7/8/2021	2	99	56
PLANNED	7/8/2021	5	220	44
PLANNED	7/8/2021	1	22	22
PLANNED	7/8/2021	1	24	24
CUSTOMER REQUEST	7/8/2021	1	37	37
PLANNED	7/8/2021	2	18	9
CUSTOMER REQUEST	7/8/2021	37	481	13
CUSTOMER REQUEST	7/8/2021	2	262	131
PLANNED	7/8/2021	1	65	65
PLANNED	7/8/2021	33	3,597	109

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/8/2021	2	236	118
PLANNED	7/8/2021	17	2,227	131
PLANNED	7/8/2021	9	423	47
PLANNED	7/8/2021	2	366	183
PLANNED	7/8/2021	1	66	66
PLANNED	7/8/2021	7	658	94
PLANNED	7/8/2021	8	464	58
PLANNED	7/8/2021	6	48	8
PLANNED	7/8/2021	3	267	89
PLANNED	7/8/2021	1	87	87
PLANNED	7/8/2021	2	312	156
PLANNED	7/8/2021	2	18	9
PLANNED	7/8/2021	3	375	125
CUSTOMER REQUEST	7/8/2021	2	10	5
PLANNED	7/8/2021	61	5,368	88
CUSTOMER REQUEST	7/8/2021	6	48	8
PLANNED	7/8/2021	10	940	94
PLANNED	7/8/2021	2	222	111
PLANNED	7/8/2021	44	8,624	196
PLANNED	7/8/2021	15	1,095	73
PLANNED	7/8/2021	6	576	96
PLANNED	7/8/2021	10	170	17
PLANNED	7/8/2021	1	56	56
PLANNED	7/8/2021	2	108	54
PLANNED	7/8/2021	5	1,775	355
PLANNED	7/8/2021	34	1,156	34
PLANNED	7/8/2021	3	48	16
PLANNED	7/8/2021	1	17	17
PLANNED	7/8/2021	3	141	47
PLANNED	7/8/2021	2	158	79
PLANNED	7/8/2021	2	50	25
PLANNED	7/8/2021	2	144	72
PLANNED	7/8/2021	2	6	3
PLANNED	7/8/2021	10	150	15
PLANNED	7/8/2021	1	35	35
PLANNED	7/8/2021	10	120	12
PLANNED	7/8/2021	1	139	139
PLANNED	7/8/2021	5	530	106
PLANNED	7/8/2021	1	105	105
PLANNED	7/8/2021	7	483	69
PLANNED	7/8/2021	2	185	97

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/8/2021	2	540	270
PLANNED	7/8/2021	3	489	163
PLANNED	7/8/2021	3	567	189
PLANNED	7/8/2021	9	405	45
PLANNED	7/8/2021	4	68	17
PLANNED	7/8/2021	3	42	14
PLANNED	7/8/2021	1	10	10
PLANNED	7/8/2021	1	116	116
PLANNED	7/8/2021	2	70	40
PLANNED	7/8/2021	3	39	13
PLANNED	7/8/2021	1	100	100
PLANNED	7/8/2021	2	142	71
PLANNED	7/8/2021	2	236	118
PLANNED	7/8/2021	6	378	63
PLANNED	7/8/2021	5	490	98
PLANNED	7/8/2021	5	75	15
PLANNED	7/8/2021	14	1,386	99
PLANNED	7/8/2021	18	2,394	133
PLANNED	7/8/2021	1	42	42
PLANNED	7/8/2021	1	32	32
CUSTOMER REQUEST	7/8/2021	1	219	219
PLANNED	7/8/2021	1	3	3
PLANNED	7/8/2021	1	16	16
PLANNED	7/8/2021	1	184	184
PLANNED	7/8/2021	3	123	41
PLANNED	7/8/2021	2	112	78
CUSTOMER REQUEST	7/8/2021	46	1,380	30
CUSTOMER REQUEST	7/8/2021	1	78	78
PLANNED	7/8/2021	6	12	2
PLANNED	7/8/2021	1	252	252
PLANNED	7/8/2021	2	418	209
PLANNED	7/8/2021	8	1,352	169
PLANNED	7/8/2021	7	1,197	171
PLANNED	7/9/2021	2	372	186
PLANNED	7/9/2021	1	101	101
PLANNED	7/9/2021	3	399	133
PLANNED	7/9/2021	1	93	93
PLANNED	7/9/2021	2	88	44
PLANNED	7/9/2021	2	390	195
PLANNED	7/9/2021	1	72	72
PLANNED	7/9/2021	1	76	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/9/2021	2	120	60
PLANNED	7/9/2021	4	422	193
PLANNED	7/9/2021	2	148	74
PLANNED	7/9/2021	3	238	95
PLANNED	7/9/2021	1	294	294
PLANNED	7/9/2021	3	183	61
PLANNED	7/9/2021	1	259	259
PLANNED	7/9/2021	2	480	240
PLANNED	7/9/2021	10	20	2
CUSTOMER REQUEST	7/9/2021	6	18	3
PLANNED	7/9/2021	3	447	149
PLANNED	7/9/2021	1	46	46
PLANNED	7/9/2021	2	266	133
PLANNED	7/9/2021	12	1,284	107
PLANNED	7/9/2021	2	238	119
PLANNED	7/9/2021	17	153	9
CUSTOMER REQUEST	7/9/2021	30	7,890	263
PLANNED	7/9/2021	1	161	161
PLANNED	7/9/2021	9	36	4
PLANNED	7/9/2021	2	172	86
PLANNED	7/9/2021	6	246	41
PLANNED	7/9/2021	4	88	22
PLANNED	7/9/2021	1	163	163
PLANNED	7/9/2021	6	426	71
PLANNED	7/9/2021	3	162	54
PLANNED	7/9/2021	34	1,564	46
PLANNED	7/9/2021	3	276	92
PLANNED	7/9/2021	7	1,309	187
CUSTOMER REQUEST	7/9/2021	110	2,860	26
PLANNED	7/9/2021	1	127	127
PLANNED	7/9/2021	4	288	72
PLANNED	7/9/2021	2	76	38
PLANNED	7/9/2021	1	18	18
PLANNED	7/9/2021	7	308	44
PLANNED	7/9/2021	7	357	51
PLANNED	7/9/2021	8	512	64
PLANNED	7/9/2021	1	104	104
PLANNED	7/9/2021	4	140	35
PLANNED	7/9/2021	8	136	17
CUSTOMER REQUEST	7/9/2021	5	205	41
CUSTOMER REQUEST	7/9/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/9/2021	9	171	19
CUSTOMER REQUEST	7/9/2021	1	235	235
PLANNED	7/9/2021	7	182	26
PLANNED	7/9/2021	2	126	63
PLANNED	7/9/2021	6	294	49
PLANNED	7/9/2021	7	399	57
PLANNED	7/9/2021	13	910	70
PLANNED	7/9/2021	1	53	53
CUSTOMER REQUEST	7/9/2021	2	26	13
PLANNED	7/9/2021	7	427	61
PLANNED	7/9/2021	12	396	33
PLANNED	7/9/2021	40	8,251	223
PLANNED	7/9/2021	5	100	20
PLANNED	7/9/2021	5	25	5
PLANNED	7/9/2021	3	108	36
PLANNED	7/9/2021	6	294	49
PLANNED	7/9/2021	2	90	45
PLANNED	7/9/2021	2	110	55
PLANNED	7/9/2021	1	29	29
PLANNED	7/9/2021	8	1,256	157
CUSTOMER REQUEST	7/9/2021	16	688	43
PLANNED	7/9/2021	3	99	33
PLANNED	7/9/2021	6	276	46
PLANNED	7/9/2021	2	42	21
PLANNED	7/9/2021	3	183	61
PLANNED	7/9/2021	1	47	47
PLANNED	7/9/2021	8	584	73
PLANNED	7/9/2021	2	154	77
CUSTOMER REQUEST	7/9/2021	8	16	2
PLANNED	7/9/2021	2	434	217
CUSTOMER REQUEST	7/9/2021	16	16	1
CUSTOMER REQUEST	7/9/2021	36	2,124	59
PLANNED	7/10/2021	4	84	21
PLANNED	7/10/2021	4	472	118
PLANNED	7/10/2021	1	168	168
PLANNED	7/10/2021	1	441	441
PLANNED	7/10/2021	1	89	89
PLANNED	7/10/2021	1	158	158
PLANNED	7/10/2021	1	67	67
PLANNED	7/10/2021	1	116	116
PLANNED	7/10/2021	18	468	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/10/2021	6	477	139
PLANNED	7/10/2021	1	158	158
PLANNED	7/10/2021	2	208	104
PLANNED	7/10/2021	1	60	60
PLANNED	7/10/2021	23	644	28
PLANNED	7/11/2021	1	109	109
PLANNED	7/11/2021	1	91	91
PLANNED	7/11/2021	1	597	597
PLANNED	7/11/2021	1	59	59
PLANNED	7/11/2021	2	24	12
PLANNED	7/11/2021	2	52	26
PLANNED	7/11/2021	5	55	11
PLANNED	7/11/2021	5	1,240	248
PLANNED	7/11/2021	1	239	239
PLANNED	7/11/2021	5	770	154
PLANNED	7/11/2021	9	1,584	176
PLANNED	7/11/2021	2	166	83
PLANNED	7/11/2021	2	158	79
PLANNED	7/11/2021	2	92	46
PLANNED	7/11/2021	3	117	39
PLANNED	7/11/2021	1	321	321
CUSTOMER REQUEST	7/11/2021	2,556	59,706	26
PLANNED	7/11/2021	2	36	18
PLANNED	7/12/2021	1	351	351
PLANNED	7/12/2021	1	277	277
PLANNED	7/12/2021	1	144	144
CUSTOMER REQUEST	7/12/2021	44	4,620	105
PLANNED	7/12/2021	2	160	107
PLANNED	7/12/2021	10	1,150	115
PLANNED	7/12/2021	5	515	103
PLANNED	7/12/2021	2	64	32
PLANNED	7/12/2021	1	55	55
PLANNED	7/12/2021	1	20	20
PLANNED	7/12/2021	1	62	62
PLANNED	7/12/2021	2	562	281
PLANNED	7/12/2021	6	288	48
PLANNED	7/12/2021	12	144	12
PLANNED	7/12/2021	2	52	26
CUSTOMER REQUEST	7/12/2021	12	492	41
PLANNED	7/12/2021	11	2,497	227
PLANNED	7/12/2021	4	1,136	284

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/12/2021	1	33	33
PLANNED	7/12/2021	6	2,586	431
PLANNED	7/12/2021	1	24	24
CUSTOMER REQUEST	7/12/2021	28	5,656	202
PLANNED	7/12/2021	5	25	5
PLANNED	7/12/2021	8	1,224	153
PLANNED	7/12/2021	4	568	142
PLANNED	7/12/2021	1	360	360
PLANNED	7/12/2021	3	321	107
CUSTOMER REQUEST	7/12/2021	4	84	21
CUSTOMER REQUEST	7/12/2021	1	287	287
CUSTOMER REQUEST	7/12/2021	2	422	211
PLANNED	7/12/2021	1	64	64
PLANNED	7/12/2021	1	60	60
PLANNED	7/12/2021	1	23	23
PLANNED	7/12/2021	2	330	165
PLANNED	7/12/2021	1	26	26
CUSTOMER REQUEST	7/12/2021	1	18	18
PLANNED	7/12/2021	2	148	74
PLANNED	7/12/2021	4	348	87
PLANNED	7/12/2021	2	46	23
PLANNED	7/12/2021	2	46	23
PLANNED	7/12/2021	1	51	51
CUSTOMER REQUEST	7/12/2021	18	432	24
PLANNED	7/12/2021	2	296	148
PLANNED	7/12/2021	12	1,020	85
PLANNED	7/12/2021	2	176	88
PLANNED	7/12/2021	6	2,046	341
PLANNED	7/12/2021	2	73	47
PLANNED	7/12/2021	1	21	21
PLANNED	7/12/2021	2	100	50
PLANNED	7/12/2021	1	115	115
PLANNED	7/12/2021	2	152	76
PLANNED	7/12/2021	12	2,400	200
PLANNED	7/12/2021	2	490	245
CUSTOMER REQUEST	7/12/2021	6	390	65
PLANNED	7/12/2021	6	342	57
PLANNED	7/12/2021	1	175	175
PLANNED	7/12/2021	3	207	69
PLANNED	7/12/2021	10	1,290	129
PLANNED	7/12/2021	1	59	59

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/12/2021	8	496	62
CUSTOMER REQUEST	7/12/2021	7	455	65
CUSTOMER REQUEST	7/12/2021	3	762	254
PLANNED	7/12/2021	9	873	97
PLANNED	7/12/2021	5	365	73
CUSTOMER REQUEST	7/12/2021	2	40	20
PLANNED	7/12/2021	2	26	13
PLANNED	7/12/2021	6	24	4
PLANNED	7/12/2021	1	39	39
PLANNED	7/12/2021	2	72	36
PLANNED	7/12/2021	2	300	150
PLANNED	7/12/2021	1	24	24
PLANNED	7/12/2021	3	90	30
PLANNED	7/12/2021	1	64	64
PLANNED	7/12/2021	1	53	53
PLANNED	7/12/2021	4	148	37
CUSTOMER REQUEST	7/12/2021	1	1	1
PLANNED	7/12/2021	2	62	33
PLANNED	7/12/2021	2	184	92
PLANNED	7/12/2021	10	680	68
CUSTOMER REQUEST	7/12/2021	4	36	9
PLANNED	7/12/2021	1	109	109
CUSTOMER REQUEST	7/12/2021	61	14,884	244
CUSTOMER REQUEST	7/12/2021	1	108	108
PLANNED	7/12/2021	1	79	79
PLANNED	7/12/2021	8	128	16
PLANNED	7/12/2021	2	90	45
CUSTOMER REQUEST	7/12/2021	1,501	18,012	12
PLANNED	7/12/2021	13	1,222	94
PLANNED	7/12/2021	8	1,820	268
PLANNED	7/12/2021	1	122	122
PLANNED	7/12/2021	5	190	38
PLANNED	7/13/2021	1	141	141
CUSTOMER REQUEST	7/13/2021	1	1,157	1,157
PLANNED	7/13/2021	1	56	56
PLANNED	7/13/2021	3	498	166
PLANNED	7/13/2021	3	295	169
PLANNED	7/13/2021	2	82	41
PLANNED	7/13/2021	2	110	55
PLANNED	7/13/2021	1	66	66
PLANNED	7/13/2021	4	116	29

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/13/2021	4	100	25
PLANNED	7/13/2021	1	45	45
PLANNED	7/13/2021	1	55	55
PLANNED	7/13/2021	2	266	133
PLANNED	7/13/2021	3	276	92
PLANNED	7/13/2021	4	768	192
PLANNED	7/13/2021	2	216	108
PLANNED	7/13/2021	12	2,160	180
PLANNED	7/13/2021	6	1,002	167
PLANNED	7/13/2021	4	608	152
PLANNED	7/13/2021	2	237	165
PLANNED	7/13/2021	5	45	9
PLANNED	7/13/2021	7	49	7
PLANNED	7/13/2021	3	555	185
PLANNED	7/13/2021	2	32	16
PLANNED	7/13/2021	22	10,164	462
PLANNED	7/13/2021	2	54	27
CUSTOMER REQUEST	7/13/2021	34	11,230	355
PLANNED	7/13/2021	3	606	202
PLANNED	7/13/2021	36	5,040	140
PLANNED	7/13/2021	3	165	55
PLANNED	7/13/2021	4	208	52
PLANNED	7/13/2021	4	320	80
PLANNED	7/13/2021	5	100	20
PLANNED	7/13/2021	1	102	102
PLANNED	7/13/2021	2	152	76
PLANNED	7/13/2021	8	1,872	234
PLANNED	7/13/2021	6	1,020	170
CUSTOMER REQUEST	7/13/2021	1	249	249
PLANNED	7/13/2021	1	39	39
PLANNED	7/13/2021	2	294	147
PLANNED	7/13/2021	1	56	56
PLANNED	7/13/2021	3	90	30
PLANNED	7/13/2021	4	204	51
PLANNED	7/13/2021	4	84	21
PLANNED	7/13/2021	18	5,904	328
PLANNED	7/13/2021	2	128	64
PLANNED	7/13/2021	9	2,232	248
PLANNED	7/13/2021	4	628	157
PLANNED	7/13/2021	6	498	83
PLANNED	7/13/2021	14	490	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/13/2021	1	206	206
PLANNED	7/13/2021	10	1,687	209
PLANNED	7/13/2021	5	865	173
PLANNED	7/13/2021	2	66	33
PLANNED	7/13/2021	9	189	21
PLANNED	7/13/2021	1	139	139
PLANNED	7/13/2021	31	3,348	108
PLANNED	7/13/2021	4	296	74
PLANNED	7/13/2021	5	255	51
PLANNED	7/13/2021	4	96	24
PLANNED	7/13/2021	1	222	222
PLANNED	7/13/2021	6	816	136
PLANNED	7/13/2021	2	42	21
PLANNED	7/13/2021	2	140	70
PLANNED	7/13/2021	6	996	166
PLANNED	7/13/2021	12	780	65
CUSTOMER REQUEST	7/13/2021	12	48	4
PLANNED	7/13/2021	3	156	52
PLANNED	7/13/2021	2	70	35
PLANNED	7/13/2021	11	682	62
PLANNED	7/13/2021	1	173	173
PLANNED	7/13/2021	1	40	40
PLANNED	7/13/2021	2	76	38
PLANNED	7/13/2021	2	60	30
PLANNED	7/13/2021	1	157	157
PLANNED	7/13/2021	24	2,640	110
PLANNED	7/13/2021	6	312	52
PLANNED	7/13/2021	1	33	33
PLANNED	7/13/2021	13	1,144	88
PLANNED	7/13/2021	3	72	24
PLANNED	7/13/2021	27	1,242	46
PLANNED	7/13/2021	12	36	3
PLANNED	7/13/2021	10	620	62
PLANNED	7/13/2021	3	108	36
PLANNED	7/13/2021	51	1,632	32
PLANNED	7/13/2021	6	150	25
PLANNED	7/13/2021	1	49	49
PLANNED	7/13/2021	6	42	7
PLANNED	7/13/2021	1	92	92
PLANNED	7/13/2021	2	122	61
PLANNED	7/13/2021	8	40	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/13/2021	2	48	24
PLANNED	7/13/2021	2	146	73
PLANNED	7/13/2021	8	680	85
PLANNED	7/13/2021	2	222	111
PLANNED	7/13/2021	11	693	63
PLANNED	7/13/2021	2	224	112
PLANNED	7/13/2021	2	98	49
PLANNED	7/13/2021	1	71	71
PLANNED	7/13/2021	28	2,548	91
PLANNED	7/13/2021	5	110	22
PLANNED	7/13/2021	5	245	49
PLANNED	7/13/2021	8	384	48
PLANNED	7/13/2021	8	48	6
PLANNED	7/13/2021	2	76	38
PLANNED	7/13/2021	1	56	56
PLANNED	7/13/2021	1	168	168
PLANNED	7/13/2021	1	25	25
PLANNED	7/13/2021	2	104	52
PLANNED	7/13/2021	9	369	41
PLANNED	7/13/2021	8	256	32
PLANNED	7/13/2021	2	304	152
PLANNED	7/13/2021	2	34	17
CUSTOMER REQUEST	7/13/2021	1	238	238
CUSTOMER REQUEST	7/13/2021	1	68	68
PLANNED	7/13/2021	1	28	28
CUSTOMER REQUEST	7/13/2021	1	218	218
CUSTOMER REQUEST	7/13/2021	1	81	81
PLANNED	7/13/2021	2	326	163
PLANNED	7/13/2021	1	47	47
PLANNED	7/13/2021	6	468	78
PLANNED	7/13/2021	2	26	13
PLANNED	7/13/2021	1	107	107
PLANNED	7/13/2021	24	120	5
PLANNED	7/13/2021	10	760	76
PLANNED	7/13/2021	2	432	216
PLANNED	7/13/2021	4	208	52
PLANNED	7/13/2021	4	428	107
PLANNED	7/14/2021	7	1,869	267
PLANNED	7/14/2021	12	936	78
PLANNED	7/14/2021	3	471	157
PLANNED	7/14/2021	1	84	84

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/14/2021	6	396	66
PLANNED	7/14/2021	2	86	43
PLANNED	7/14/2021	5	300	60
PLANNED	7/14/2021	2	174	87
PLANNED	7/14/2021	1	68	68
PLANNED	7/14/2021	3	433	289
PLANNED	7/14/2021	9	1,845	205
CUSTOMER REQUEST	7/14/2021	1	243	243
CUSTOMER REQUEST	7/14/2021	32	5,440	170
PLANNED	7/14/2021	1	38	38
PLANNED	7/14/2021	1	258	258
PLANNED	7/14/2021	56	7,112	127
PLANNED	7/14/2021	7	1,022	176
PLANNED	7/14/2021	3	60	20
PLANNED	7/14/2021	1	411	411
PLANNED	7/14/2021	6	450	75
PLANNED	7/14/2021	5	210	42
PLANNED	7/14/2021	15	435	29
PLANNED	7/14/2021	5	285	57
PLANNED	7/14/2021	5	435	87
PLANNED	7/14/2021	7	602	86
PLANNED	7/14/2021	6	426	71
PLANNED	7/14/2021	2	98	49
PLANNED	7/14/2021	3	357	119
PLANNED	7/14/2021	3	69	23
PLANNED	7/14/2021	4	300	75
PLANNED	7/14/2021	2	140	70
PLANNED	7/14/2021	4	88	22
PLANNED	7/14/2021	6	102	17
PLANNED	7/14/2021	12	96	8
PLANNED	7/14/2021	11	99	9
PLANNED	7/14/2021	22	4,268	194
PLANNED	7/14/2021	7	42	6
CUSTOMER REQUEST	7/14/2021	1	148	148
PLANNED	7/14/2021	1	120	120
PLANNED	7/14/2021	3	66	22
PLANNED	7/14/2021	1	22	22
PLANNED	7/14/2021	29	1,566	54
CUSTOMER REQUEST	7/14/2021	5	125	25
PLANNED	7/14/2021	2	42	21
PLANNED	7/14/2021	3	537	179

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/14/2021	2	236	118
PLANNED	7/14/2021	1	157	157
PLANNED	7/14/2021	2	80	40
PLANNED	7/14/2021	2	250	125
PLANNED	7/14/2021	2	34	17
PLANNED	7/14/2021	1	66	66
PLANNED	7/14/2021	1	321	321
PLANNED	7/14/2021	1	50	50
PLANNED	7/14/2021	2	96	48
PLANNED	7/14/2021	10	40	4
PLANNED	7/14/2021	8	1,528	191
PLANNED	7/14/2021	2	78	39
PLANNED	7/14/2021	3	225	75
PLANNED	7/14/2021	9	273	75
PLANNED	7/14/2021	5	30	6
CUSTOMER REQUEST	7/14/2021	4	100	25
CUSTOMER REQUEST	7/14/2021	32	2,880	90
PLANNED	7/14/2021	4	92	23
PLANNED	7/14/2021	5	1,178	242
PLANNED	7/14/2021	3	129	43
PLANNED	7/14/2021	4	52	13
PLANNED	7/14/2021	2	198	99
PLANNED	7/14/2021	20	3,340	167
PLANNED	7/14/2021	5	185	37
PLANNED	7/14/2021	5	30	6
PLANNED	7/14/2021	2	194	97
PLANNED	7/14/2021	1	5	5
PLANNED	7/14/2021	3	453	151
PLANNED	7/14/2021	18	1,008	56
PLANNED	7/14/2021	5	85	17
PLANNED	7/14/2021	4	284	71
PLANNED	7/14/2021	2	358	179
PLANNED	7/14/2021	11	220	20
PLANNED	7/14/2021	4	148	37
PLANNED	7/14/2021	3	18	6
PLANNED	7/14/2021	4	152	38
PLANNED	7/14/2021	3	66	22
PLANNED	7/14/2021	2	66	33
PLANNED	7/14/2021	8	40	5
PLANNED	7/14/2021	3	18	6
PLANNED	7/14/2021	9	72	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/14/2021	2	36	18
PLANNED	7/14/2021	4	276	69
PLANNED	7/14/2021	5	105	21
CUSTOMER REQUEST	7/14/2021	2	14	7
PLANNED	7/14/2021	1	7	7
PLANNED	7/14/2021	2	476	238
PLANNED	7/14/2021	1	54	54
PLANNED	7/14/2021	4	64	16
PLANNED	7/14/2021	3	270	90
PLANNED	7/14/2021	4	152	38
PLANNED	7/14/2021	7	98	14
PLANNED	7/14/2021	1	72	72
PLANNED	7/14/2021	1	19	19
PLANNED	7/14/2021	10	60	6
PLANNED	7/14/2021	11	154	14
PLANNED	7/14/2021	6	288	48
PLANNED	7/14/2021	6	222	37
PLANNED	7/14/2021	4	96	24
PLANNED	7/14/2021	5	225	45
PLANNED	7/14/2021	4	104	26
PLANNED	7/14/2021	4	136	34
PLANNED	7/14/2021	8	80	10
PLANNED	7/14/2021	1	18	18
PLANNED	7/14/2021	2	240	120
PLANNED	7/14/2021	4	452	113
PLANNED	7/14/2021	2	114	57
PLANNED	7/14/2021	1	24	24
PLANNED	7/14/2021	3	93	31
PLANNED	7/14/2021	2	44	22
PLANNED	7/14/2021	1	88	88
PLANNED	7/14/2021	1	13	13
PLANNED	7/14/2021	1	47	47
PLANNED	7/14/2021	2	234	117
PLANNED	7/14/2021	8	176	22
PLANNED	7/14/2021	1	70	70
PLANNED	7/14/2021	4	452	113
PLANNED	7/14/2021	8	304	69
PLANNED	7/14/2021	1	109	109
CUSTOMER REQUEST	7/14/2021	1	172	172
CUSTOMER REQUEST	7/14/2021	1	57	57
PLANNED	7/14/2021	1	71	71

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	7/14/2021	1	139	139
PLANNED	7/14/2021	1	111	111
CUSTOMER REQUEST	7/14/2021	1	139	139
PLANNED	7/14/2021	1	116	116
PLANNED	7/14/2021	8	584	73
PLANNED	7/14/2021	1	272	272
CUSTOMER REQUEST	7/15/2021	20	6,360	318
PLANNED	7/15/2021	2	326	163
PLANNED	7/15/2021	55	22,275	405
PLANNED	7/15/2021	1	125	125
PLANNED	7/15/2021	1	115	115
PLANNED	7/15/2021	1	71	71
PLANNED	7/15/2021	1	48	48
PLANNED	7/15/2021	5	750	150
PLANNED	7/15/2021	1	54	54
PLANNED	7/15/2021	5	570	146
PLANNED	7/15/2021	1	27	27
PLANNED	7/15/2021	1	87	87
PLANNED	7/15/2021	15	1,140	76
PLANNED	7/15/2021	7	770	110
PLANNED	7/15/2021	4	600	192
PLANNED	7/15/2021	5	370	74
PLANNED	7/15/2021	1	36	36
PLANNED	7/15/2021	2	251	174
PLANNED	7/15/2021	8	952	119
PLANNED	7/15/2021	5	190	38
PLANNED	7/15/2021	1	66	66
PLANNED	7/15/2021	4	700	175
PLANNED	7/15/2021	8	408	51
PLANNED	7/15/2021	2	292	146
PLANNED	7/15/2021	5	350	70
PLANNED	7/15/2021	8	1,544	193
PLANNED	7/15/2021	1	139	139
PLANNED	7/15/2021	2	166	83
PLANNED	7/15/2021	2	46	23
PLANNED	7/15/2021	2	180	90
PLANNED	7/15/2021	1	38	38
PLANNED	7/15/2021	3	180	60
CUSTOMER REQUEST	7/15/2021	23	138	6
PLANNED	7/15/2021	1	138	138
PLANNED	7/15/2021	8	2,168	271

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/15/2021	17	2,686	158
PLANNED	7/15/2021	8	3,728	466
PLANNED	7/15/2021	4	332	83
PLANNED	7/15/2021	2	54	27
PLANNED	7/15/2021	12	2,208	184
PLANNED	7/15/2021	8	1,144	143
PLANNED	7/15/2021	2	254	127
PLANNED	7/15/2021	1	35	35
PLANNED	7/15/2021	48	2,136	187
PLANNED	7/15/2021	7	665	95
PLANNED	7/15/2021	1	118	118
PLANNED	7/15/2021	6	396	66
PLANNED	7/15/2021	8	512	64
PLANNED	7/15/2021	8	264	33
PLANNED	7/15/2021	1	89	89
PLANNED	7/15/2021	6	732	122
CUSTOMER REQUEST	7/15/2021	10	700	70
CUSTOMER REQUEST	7/15/2021	857	1,714	2
PLANNED	7/15/2021	4	264	66
PLANNED	7/15/2021	3	333	111
PLANNED	7/15/2021	4	424	106
PLANNED	7/15/2021	11	968	88
PLANNED	7/15/2021	5	530	106
PLANNED	7/15/2021	2	296	148
PLANNED	7/15/2021	2	162	81
CUSTOMER REQUEST	7/15/2021	8	160	20
PLANNED	7/15/2021	3	198	66
PLANNED	7/15/2021	2	14	7
PLANNED	7/15/2021	1	41	41
PLANNED	7/15/2021	7	147	21
PLANNED	7/15/2021	49	1,764	36
PLANNED	7/15/2021	3	177	59
PLANNED	7/15/2021	5	1,410	350
PLANNED	7/15/2021	7	63	9
PLANNED	7/15/2021	1	39	39
PLANNED	7/15/2021	2	76	38
PLANNED	7/15/2021	2	72	36
PLANNED	7/15/2021	3	225	75
PLANNED	7/15/2021	11	99	9
PLANNED	7/15/2021	1	30	30
PLANNED	7/15/2021	1	76	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/15/2021	4	680	170
PLANNED	7/15/2021	9	1,008	112
PLANNED	7/15/2021	15	1,855	441
PLANNED	7/15/2021	6	1,136	233
PLANNED	7/15/2021	6	330	55
PLANNED	7/15/2021	1	15	15
PLANNED	7/15/2021	15	1,545	103
PLANNED	7/15/2021	4	204	51
PLANNED	7/15/2021	4	164	41
PLANNED	7/15/2021	4	64	16
CUSTOMER REQUEST	7/15/2021	4	248	62
PLANNED	7/15/2021	1	70	70
PLANNED	7/15/2021	7	1,344	192
PLANNED	7/15/2021	4	188	47
PLANNED	7/15/2021	3	219	73
PLANNED	7/15/2021	2	42	21
PLANNED	7/15/2021	2	40	20
PLANNED	7/15/2021	1	17	17
CUSTOMER REQUEST	7/15/2021	15	1,260	84
CUSTOMER REQUEST	7/15/2021	1	366	366
PLANNED	7/15/2021	6	24	4
PLANNED	7/15/2021	4	632	158
PLANNED	7/15/2021	2	148	74
PLANNED	7/15/2021	2	150	75
PLANNED	7/15/2021	51	7,191	141
PLANNED	7/15/2021	3	84	28
PLANNED	7/15/2021	4	72	18
PLANNED	7/15/2021	2	76	38
PLANNED	7/15/2021	4	4	1
PLANNED	7/15/2021	5	500	100
PLANNED	7/15/2021	8	360	45
PLANNED	7/15/2021	4	564	141
PLANNED	7/15/2021	5	465	93
PLANNED	7/15/2021	3	342	114
PLANNED	7/15/2021	2	70	35
PLANNED	7/15/2021	2	74	37
PLANNED	7/15/2021	2	10	5
PLANNED	7/15/2021	8	96	12
PLANNED	7/15/2021	20	3,320	166
PLANNED	7/15/2021	1	58	58
PLANNED	7/15/2021	1	32	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/15/2021	6	324	54
PLANNED	7/15/2021	30	1,200	40
CUSTOMER REQUEST	7/15/2021	1	63	63
PLANNED	7/15/2021	1	101	101
PLANNED	7/15/2021	13	2,483	191
PLANNED	7/16/2021	1	94	94
PLANNED	7/16/2021	1	97	97
PLANNED	7/16/2021	2	196	98
PLANNED	7/16/2021	1	122	122
PLANNED	7/16/2021	1	78	78
PLANNED	7/16/2021	1	45	45
PLANNED	7/16/2021	1	768	768
PLANNED	7/16/2021	5	439	131
PLANNED	7/16/2021	2	303	165
PLANNED	7/16/2021	150	54,150	361
PLANNED	7/16/2021	7	42	6
PLANNED	7/16/2021	6	1,074	179
PLANNED	7/16/2021	1	198	198
PLANNED	7/16/2021	1	278	278
PLANNED	7/16/2021	1	213	213
CUSTOMER REQUEST	7/16/2021	35	7,862	325
PLANNED	7/16/2021	1	116	116
PLANNED	7/16/2021	17	952	56
PLANNED	7/16/2021	11	1,584	144
PLANNED	7/16/2021	13	1,963	151
PLANNED	7/16/2021	2	130	65
PLANNED	7/16/2021	2	118	59
PLANNED	7/16/2021	4	72	18
PLANNED	7/16/2021	1	85	85
PLANNED	7/16/2021	4	648	162
PLANNED	7/16/2021	2	90	45
PLANNED	7/16/2021	8	208	26
PLANNED	7/16/2021	11	88	8
PLANNED	7/16/2021	1	69	69
PLANNED	7/16/2021	8	2,048	256
PLANNED	7/16/2021	3	231	77
PLANNED	7/16/2021	7	168	24
PLANNED	7/16/2021	9	234	26
PLANNED	7/16/2021	1	231	231
PLANNED	7/16/2021	6	1,362	227
PLANNED	7/16/2021	1	40	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/16/2021	2	66	33
PLANNED	7/16/2021	1	34	34
PLANNED	7/16/2021	5	210	42
PLANNED	7/16/2021	2	32	16
PLANNED	7/16/2021	4	84	21
PLANNED	7/16/2021	11	154	14
PLANNED	7/16/2021	7	98	14
PLANNED	7/16/2021	2	188	94
PLANNED	7/16/2021	6	1,212	202
PLANNED	7/16/2021	2	90	45
PLANNED	7/16/2021	4	68	17
PLANNED	7/16/2021	6	114	19
PLANNED	7/16/2021	5	55	11
PLANNED	7/16/2021	32	1,696	53
PLANNED	7/16/2021	5	445	89
PLANNED	7/16/2021	8	136	17
PLANNED	7/16/2021	56	7,056	126
PLANNED	7/16/2021	8	1,064	133
PLANNED	7/16/2021	4	268	67
PLANNED	7/16/2021	8	584	73
PLANNED	7/16/2021	5	50	10
PLANNED	7/16/2021	1	36	36
PLANNED	7/16/2021	1	94	94
PLANNED	7/16/2021	4	200	50
PLANNED	7/16/2021	6	12	2
PLANNED	7/16/2021	8	216	27
PLANNED	7/16/2021	4	200	50
PLANNED	7/16/2021	17	2,397	159
PLANNED	7/16/2021	3	114	38
PLANNED	7/16/2021	1	44	44
PLANNED	7/16/2021	2	144	72
CUSTOMER REQUEST	7/16/2021	1	205	205
PLANNED	7/16/2021	8	112	14
CUSTOMER REQUEST	7/16/2021	1	255	255
PLANNED	7/16/2021	8	144	18
PLANNED	7/16/2021	1	47	47
PLANNED	7/16/2021	11	407	37
PLANNED	7/16/2021	13	130	10
PLANNED	7/17/2021	8	16	2
PLANNED	7/17/2021	6	336	56
PLANNED	7/17/2021	4	436	109

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/17/2021	9	540	60
PLANNED	7/17/2021	1	154	154
PLANNED	7/17/2021	11	418	38
PLANNED	7/17/2021	1	114	114
PLANNED	7/17/2021	6	456	76
PLANNED	7/17/2021	2	356	178
PLANNED	7/17/2021	1	50	50
PLANNED	7/17/2021	8	1,224	153
PLANNED	7/17/2021	4	380	95
PLANNED	7/17/2021	2	156	78
PLANNED	7/17/2021	3	135	45
PLANNED	7/17/2021	1	204	204
PLANNED	7/17/2021	2	88	44
PLANNED	7/17/2021	2	144	72
CUSTOMER REQUEST	7/17/2021	1	109	109
PLANNED	7/17/2021	3	570	190
PLANNED	7/17/2021	3	96	32
CUSTOMER REQUEST	7/17/2021	1	67	67
PLANNED	7/17/2021	1	93	93
PLANNED	7/18/2021	1	370	370
PLANNED	7/18/2021	1	50	50
PLANNED	7/18/2021	1	328	328
PLANNED	7/18/2021	4	756	189
PLANNED	7/18/2021	1	111	111
CUSTOMER REQUEST	7/18/2021	1	355	355
PLANNED	7/18/2021	11	407	37
PLANNED	7/18/2021	5	50	10
PLANNED	7/18/2021	2	134	67
CUSTOMER REQUEST	7/18/2021	1	494	494
PLANNED	7/18/2021	1	232	232
PLANNED	7/18/2021	1	47	47
PLANNED	7/18/2021	1	55	55
PLANNED	7/18/2021	5	440	88
CUSTOMER REQUEST	7/18/2021	1	294	294
CUSTOMER REQUEST	7/18/2021	1	282	282
CUSTOMER REQUEST	7/18/2021	1	124	124
PLANNED	7/19/2021	6	540	90
PLANNED	7/19/2021	1	134	134
CUSTOMER REQUEST	7/19/2021	1	293	293
PLANNED	7/19/2021	7	70	10
CUSTOMER REQUEST	7/19/2021	19	95	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/19/2021	1	23	23
PLANNED	7/19/2021	2	218	109
PLANNED	7/19/2021	1	9	9
PLANNED	7/19/2021	3	276	92
PLANNED	7/19/2021	7	105	15
PLANNED	7/19/2021	1	339	339
PLANNED	7/19/2021	3	150	50
PLANNED	7/19/2021	3	195	65
CUSTOMER REQUEST	7/19/2021	148	3,700	25
PLANNED	7/19/2021	5	580	116
PLANNED	7/19/2021	4	104	26
PLANNED	7/19/2021	2	452	226
PLANNED	7/19/2021	1	12	12
PLANNED	7/19/2021	3	129	43
PLANNED	7/19/2021	1	191	191
PLANNED	7/19/2021	1	356	356
PLANNED	7/19/2021	34	170	5
PLANNED	7/19/2021	10	80	8
PLANNED	7/19/2021	9	747	83
PLANNED	7/19/2021	10	470	47
PLANNED	7/19/2021	31	806	26
PLANNED	7/19/2021	75	14,625	195
PLANNED	7/19/2021	2	168	84
PLANNED	7/19/2021	2	130	65
PLANNED	7/19/2021	3	192	64
PLANNED	7/19/2021	1	179	179
PLANNED	7/19/2021	3	33	11
PLANNED	7/19/2021	3	33	11
PLANNED	7/19/2021	2	22	11
PLANNED	7/19/2021	1	51	51
PLANNED	7/19/2021	5	40	8
PLANNED	7/19/2021	3	198	66
PLANNED	7/19/2021	1	157	157
PLANNED	7/19/2021	7	287	41
PLANNED	7/19/2021	4	68	17
PLANNED	7/19/2021	5	105	21
PLANNED	7/19/2021	12	1,872	156
PLANNED	7/19/2021	2	86	43
PLANNED	7/19/2021	1	47	47
PLANNED	7/19/2021	3	531	177
PLANNED	7/19/2021	8	1,672	209

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/19/2021	3	72	24
PLANNED	7/19/2021	4	60	15
PLANNED	7/19/2021	9	252	28
PLANNED	7/19/2021	1	27	27
PLANNED	7/19/2021	5	30	6
PLANNED	7/19/2021	2	146	73
PLANNED	7/19/2021	6	1,602	267
PLANNED	7/19/2021	9	153	17
PLANNED	7/19/2021	13	104	8
PLANNED	7/19/2021	5	945	189
PLANNED	7/19/2021	3	39	13
PLANNED	7/19/2021	2	12	6
PLANNED	7/19/2021	2	56	28
PLANNED	7/19/2021	2	164	82
PLANNED	7/19/2021	3	438	146
PLANNED	7/19/2021	1	46	46
PLANNED	7/19/2021	56	2,912	52
PLANNED	7/19/2021	1	147	147
PLANNED	7/19/2021	1	14	14
PLANNED	7/19/2021	2	294	147
PLANNED	7/19/2021	2	104	52
PLANNED	7/19/2021	4	216	54
PLANNED	7/19/2021	2	42	21
PLANNED	7/19/2021	2	78	39
PLANNED	7/19/2021	2	44	22
PLANNED	7/19/2021	10	220	22
PLANNED	7/19/2021	1	38	38
PLANNED	7/19/2021	1	21	21
PLANNED	7/19/2021	3	24	8
PLANNED	7/19/2021	1	22	22
PLANNED	7/19/2021	2	38	19
PLANNED	7/19/2021	2	52	26
PLANNED	7/19/2021	3	15	5
PLANNED	7/19/2021	1	188	188
PLANNED	7/19/2021	5	25	5
PLANNED	7/19/2021	6	114	19
PLANNED	7/19/2021	8	1,072	134
PLANNED	7/19/2021	4	268	67
PLANNED	7/19/2021	9	189	21
PLANNED	7/19/2021	2	26	13
PLANNED	7/19/2021	11	198	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/19/2021	4	196	49
PLANNED	7/19/2021	2	60	30
PLANNED	7/19/2021	1	24	24
PLANNED	7/19/2021	8	96	12
PLANNED	7/19/2021	12	156	13
PLANNED	7/19/2021	4	52	13
PLANNED	7/19/2021	6	240	40
PLANNED	7/19/2021	4	728	182
PLANNED	7/19/2021	2	50	25
PLANNED	7/19/2021	1	37	37
PLANNED	7/19/2021	3	36	12
PLANNED	7/19/2021	1	24	24
PLANNED	7/19/2021	4	60	15
PLANNED	7/19/2021	3	18	6
PLANNED	7/19/2021	8	1,744	218
PLANNED	7/19/2021	4	88	22
PLANNED	7/19/2021	2	118	59
PLANNED	7/19/2021	4	140	35
PLANNED	7/19/2021	3	30	10
PLANNED	7/19/2021	1	35	35
CUSTOMER REQUEST	7/19/2021	8	144	18
PLANNED	7/19/2021	8	1,424	178
PLANNED	7/19/2021	1	74	74
PLANNED	7/19/2021	1	50	50
PLANNED	7/19/2021	5	95	19
CUSTOMER REQUEST	7/19/2021	1	215	215
CUSTOMER REQUEST	7/19/2021	1	278	278
CUSTOMER REQUEST	7/19/2021	1	284	284
PLANNED	7/19/2021	12	1,668	139
PLANNED	7/19/2021	10	410	41
PLANNED	7/19/2021	1	60	60
PLANNED	7/19/2021	2	58	29
PLANNED	7/19/2021	28	2,604	93
PLANNED	7/19/2021	7	560	80
CUSTOMER REQUEST	7/19/2021	1,814	67,118	37
PLANNED	7/19/2021	1	247	247
PLANNED	7/19/2021	2	536	268
PLANNED	7/19/2021	2	130	65
PLANNED	7/19/2021	1	181	181
PLANNED	7/20/2021	4	4	1
PLANNED	7/20/2021	12	300	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/20/2021	3	567	189
PLANNED	7/20/2021	2	154	77
PLANNED	7/20/2021	2	194	97
PLANNED	7/20/2021	3	348	116
PLANNED	7/20/2021	2	62	31
PLANNED	7/20/2021	4	68	17
CUSTOMER REQUEST	7/20/2021	22	1,100	50
PLANNED	7/20/2021	3	60	20
PLANNED	7/20/2021	1	201	201
CUSTOMER REQUEST	7/20/2021	31	3,069	99
PLANNED	7/20/2021	4	56	14
PLANNED	7/20/2021	2	40	20
PLANNED	7/20/2021	8	296	37
PLANNED	7/20/2021	6	534	89
PLANNED	7/20/2021	7	147	21
PLANNED	7/20/2021	11	143	13
PLANNED	7/20/2021	4	80	20
CUSTOMER REQUEST	7/20/2021	1	32	32
PLANNED	7/20/2021	2	640	320
PLANNED	7/20/2021	3	30	10
PLANNED	7/20/2021	21	2,814	134
PLANNED	7/20/2021	3	267	89
CUSTOMER REQUEST	7/20/2021	85	38,845	457
PLANNED	7/20/2021	2	46	23
PLANNED	7/20/2021	3	69	23
PLANNED	7/20/2021	1	128	128
PLANNED	7/20/2021	3	123	41
PLANNED	7/20/2021	4	508	127
PLANNED	7/20/2021	4	88	22
PLANNED	7/20/2021	2	8	4
PLANNED	7/20/2021	3	12	4
PLANNED	7/20/2021	2	14	7
PLANNED	7/20/2021	1	9	9
PLANNED	7/20/2021	3	36	12
PLANNED	7/20/2021	10	820	82
PLANNED	7/20/2021	2	314	157
PLANNED	7/20/2021	4	84	21
PLANNED	7/20/2021	4	232	58
PLANNED	7/20/2021	4	412	103
PLANNED	7/20/2021	7	1,008	144
PLANNED	7/20/2021	8	2,088	261

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/20/2021	6	1,452	242
PLANNED	7/20/2021	8	1,776	222
PLANNED	7/20/2021	6	1,392	232
PLANNED	7/20/2021	2	58	29
PLANNED	7/20/2021	7	525	75
PLANNED	7/20/2021	3	87	29
PLANNED	7/20/2021	4	12	3
PLANNED	7/20/2021	2	408	204
PLANNED	7/20/2021	78	26,442	339
PLANNED	7/20/2021	2	86	43
PLANNED	7/20/2021	3	66	22
PLANNED	7/20/2021	5	10	2
PLANNED	7/20/2021	7	784	112
PLANNED	7/20/2021	4	72	18
PLANNED	7/20/2021	7	798	114
PLANNED	7/20/2021	2	74	37
PLANNED	7/20/2021	1	122	122
PLANNED	7/20/2021	6	438	73
PLANNED	7/20/2021	4	80	20
PLANNED	7/20/2021	3	312	104
PLANNED	7/20/2021	5	410	82
PLANNED	7/20/2021	1	90	90
PLANNED	7/20/2021	2	196	98
PLANNED	7/20/2021	5	125	25
PLANNED	7/20/2021	6	108	18
PLANNED	7/20/2021	1	99	99
PLANNED	7/20/2021	3	60	20
PLANNED	7/20/2021	8	120	15
PLANNED	7/20/2021	7	455	65
CUSTOMER REQUEST	7/20/2021	9	198	22
PLANNED	7/20/2021	2	24	12
PLANNED	7/20/2021	10	2,470	247
PLANNED	7/20/2021	4	304	76
PLANNED	7/20/2021	4	248	62
PLANNED	7/20/2021	2	16	8
PLANNED	7/20/2021	5	20	4
PLANNED	7/20/2021	49	3,332	68
PLANNED	7/20/2021	6	84	14
PLANNED	7/20/2021	4	464	116
PLANNED	7/20/2021	2	572	286
PLANNED	7/20/2021	73	219	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/20/2021	60	5,220	87
PLANNED	7/20/2021	3	156	52
PLANNED	7/20/2021	4	96	24
PLANNED	7/20/2021	8	248	31
PLANNED	7/20/2021	6	18	3
PLANNED	7/20/2021	3	27	9
PLANNED	7/20/2021	4	16	4
PLANNED	7/20/2021	3	30	10
PLANNED	7/20/2021	1	4	4
PLANNED	7/20/2021	2	10	5
PLANNED	7/20/2021	4	136	34
PLANNED	7/20/2021	1	17	17
PLANNED	7/20/2021	4	1,208	302
PLANNED	7/20/2021	4	96	24
PLANNED	7/20/2021	1	124	124
PLANNED	7/20/2021	3	27	9
PLANNED	7/20/2021	8	672	84
PLANNED	7/20/2021	1	27	27
PLANNED	7/20/2021	8	944	118
PLANNED	7/20/2021	4	372	93
PLANNED	7/20/2021	3	84	28
PLANNED	7/20/2021	6	282	47
PLANNED	7/20/2021	3	75	25
PLANNED	7/20/2021	1	9	9
PLANNED	7/20/2021	10	150	15
CUSTOMER REQUEST	7/20/2021	18	13,176	732
PLANNED	7/20/2021	8	72	9
PLANNED	7/20/2021	12	852	71
PLANNED	7/20/2021	1	10	10
PLANNED	7/20/2021	2	112	56
PLANNED	7/20/2021	1	100	100
PLANNED	7/20/2021	1	7	7
PLANNED	7/20/2021	2	288	144
PLANNED	7/20/2021	2	202	101
CUSTOMER REQUEST	7/20/2021	3	531	177
PLANNED	7/20/2021	6	138	23
CUSTOMER REQUEST	7/20/2021	1	113	113
PLANNED	7/20/2021	4	376	94
PLANNED	7/20/2021	2	56	28
PLANNED	7/20/2021	13	871	67
PLANNED	7/20/2021	3	909	303

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	7/20/2021	1	91	91
PLANNED	7/20/2021	1	396	396
PLANNED	7/20/2021	1	93	93
PLANNED	7/20/2021	7	168	24
CUSTOMER REQUEST	7/20/2021	1	41	41
PLANNED	7/20/2021	16	1,328	83
PLANNED	7/20/2021	10	1,010	101
PLANNED	7/21/2021	3	186	62
PLANNED	7/21/2021	1	104	104
PLANNED	7/21/2021	1	34	34
PLANNED	7/21/2021	4	380	95
PLANNED	7/21/2021	1	200	200
PLANNED	7/21/2021	4	320	80
PLANNED	7/21/2021	3	63	21
CUSTOMER REQUEST	7/21/2021	17	12,988	764
PLANNED	7/21/2021	4	124	31
PLANNED	7/21/2021	12	3,012	251
PLANNED	7/21/2021	4	280	70
PLANNED	7/21/2021	2	98	49
PLANNED	7/21/2021	3	291	97
PLANNED	7/21/2021	2	100	50
PLANNED	7/21/2021	2	4	2
PLANNED	7/21/2021	3	483	161
PLANNED	7/21/2021	1	8	8
PLANNED	7/21/2021	1	24	24
PLANNED	7/21/2021	52	5,772	111
PLANNED	7/21/2021	1	90	90
PLANNED	7/21/2021	1	140	140
PLANNED	7/21/2021	6	1,608	268
PLANNED	7/21/2021	2	788	394
PLANNED	7/21/2021	8	408	51
PLANNED	7/21/2021	10	490	49
PLANNED	7/21/2021	4	68	17
PLANNED	7/21/2021	3	111	37
PLANNED	7/21/2021	5	115	23
PLANNED	7/21/2021	78	25,896	332
PLANNED	7/21/2021	1	69	69
PLANNED	7/21/2021	2	82	41
PLANNED	7/21/2021	3	243	81
CUSTOMER REQUEST	7/21/2021	85	31,450	370
PLANNED	7/21/2021	2	566	283

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/21/2021	2	124	62
PLANNED	7/21/2021	10	2,290	229
CUSTOMER REQUEST	7/21/2021	2	356	178
PLANNED	7/21/2021	11	462	42
PLANNED	7/21/2021	8	896	112
PLANNED	7/21/2021	12	912	76
PLANNED	7/21/2021	4	68	17
PLANNED	7/21/2021	3	75	25
PLANNED	7/21/2021	3	21	7
PLANNED	7/21/2021	1	24	24
PLANNED	7/21/2021	1	11	11
PLANNED	7/21/2021	3	24	8
PLANNED	7/21/2021	1	349	349
PLANNED	7/21/2021	3	243	81
PLANNED	7/21/2021	3	27	9
PLANNED	7/21/2021	4	40	10
PLANNED	7/21/2021	3	360	120
PLANNED	7/21/2021	1	234	234
PLANNED	7/21/2021	2	12	6
PLANNED	7/21/2021	22	7,326	333
PLANNED	7/21/2021	4	772	193
PLANNED	7/21/2021	4	144	36
PLANNED	7/21/2021	1	86	86
PLANNED	7/21/2021	7	339	231
PLANNED	7/21/2021	2	196	98
PLANNED	7/21/2021	2	62	31
PLANNED	7/21/2021	8	280	35
PLANNED	7/21/2021	4	680	170
PLANNED	7/21/2021	2	156	78
PLANNED	7/21/2021	4	84	21
PLANNED	7/21/2021	3	15	5
CUSTOMER REQUEST	7/21/2021	8	48	6
PLANNED	7/21/2021	53	3,922	74
PLANNED	7/21/2021	13	338	26
PLANNED	7/21/2021	1	335	335
PLANNED	7/21/2021	1	5	5
PLANNED	7/21/2021	2	68	34
PLANNED	7/21/2021	14	1,876	134
PLANNED	7/21/2021	13	1,651	127
PLANNED	7/21/2021	2	66	33
CUSTOMER REQUEST	7/21/2021	32	16,992	531

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/21/2021	2	22	11
PLANNED	7/21/2021	2	82	41
CUSTOMER REQUEST	7/21/2021	2	76	38
PLANNED	7/21/2021	1	7	7
PLANNED	7/21/2021	4	176	44
PLANNED	7/21/2021	4	364	91
PLANNED	7/21/2021	3	117	39
PLANNED	7/21/2021	4	198	171
PLANNED	7/21/2021	2	14	7
PLANNED	7/21/2021	4	116	29
PLANNED	7/21/2021	8	264	33
PLANNED	7/21/2021	11	781	71
PLANNED	7/21/2021	3	165	55
PLANNED	7/21/2021	4	124	31
PLANNED	7/21/2021	2	40	20
PLANNED	7/21/2021	1	73	73
PLANNED	7/21/2021	4	100	25
PLANNED	7/21/2021	3	324	108
PLANNED	7/21/2021	1	158	158
PLANNED	7/21/2021	14	420	30
PLANNED	7/21/2021	3	102	34
PLANNED	7/21/2021	2	16	8
PLANNED	7/21/2021	1	12	12
PLANNED	7/21/2021	2	18	9
PLANNED	7/21/2021	5	40	8
PLANNED	7/21/2021	1	11	11
PLANNED	7/21/2021	2	196	98
PLANNED	7/21/2021	5	25	5
CUSTOMER REQUEST	7/21/2021	11	33	3
PLANNED	7/21/2021	3	273	91
CUSTOMER REQUEST	7/21/2021	2	138	69
PLANNED	7/21/2021	1	22	22
CUSTOMER REQUEST	7/21/2021	4	156	39
PLANNED	7/21/2021	4	64	16
PLANNED	7/21/2021	4	68	17
PLANNED	7/21/2021	4	200	50
PLANNED	7/21/2021	6	732	122
PLANNED	7/21/2021	10	320	32
PLANNED	7/21/2021	1	93	93
PLANNED	7/21/2021	3	261	87
PLANNED	7/21/2021	17	4,335	255

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/21/2021	2	36	18
PLANNED	7/21/2021	3	225	75
PLANNED	7/21/2021	9	1,485	165
PLANNED	7/21/2021	1	49	49
PLANNED	7/21/2021	10	160	16
CUSTOMER REQUEST	7/21/2021	311	24,569	79
CUSTOMER REQUEST	7/21/2021	1	179	179
PLANNED	7/21/2021	1	138	138
PLANNED	7/21/2021	5	410	82
PLANNED	7/21/2021	1	179	179
PLANNED	7/21/2021	1	165	165
PLANNED	7/21/2021	9	1,026	114
PLANNED	7/21/2021	3	588	196
PLANNED	7/22/2021	2	80	40
PLANNED	7/22/2021	3	27	9
PLANNED	7/22/2021	1	21	21
PLANNED	7/22/2021	4	16	4
PLANNED	7/22/2021	3	15	5
PLANNED	7/22/2021	2	8	4
PLANNED	7/22/2021	5	20	4
PLANNED	7/22/2021	2	8	4
PLANNED	7/22/2021	2	192	96
PLANNED	7/22/2021	3	264	88
PLANNED	7/22/2021	1	5	5
PLANNED	7/22/2021	6	34	13
PLANNED	7/22/2021	4	44	11
PLANNED	7/22/2021	4	32	8
PLANNED	7/22/2021	3	15	5
PLANNED	7/22/2021	4	16	4
PLANNED	7/22/2021	2	200	100
PLANNED	7/22/2021	4	104	26
PLANNED	7/22/2021	3	843	281
PLANNED	7/22/2021	1	103	103
PLANNED	7/22/2021	7	1,071	153
PLANNED	7/22/2021	2	442	221
PLANNED	7/22/2021	5	55	11
PLANNED	7/22/2021	4	120	30
PLANNED	7/22/2021	2	8	4
PLANNED	7/22/2021	6	900	150
PLANNED	7/22/2021	3	54	18
PLANNED	7/22/2021	3	24	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/22/2021	1	9	9
PLANNED	7/22/2021	4	20	5
PLANNED	7/22/2021	1	93	93
PLANNED	7/22/2021	4	268	133
PLANNED	7/22/2021	2	48	24
PLANNED	7/22/2021	2	40	20
PLANNED	7/22/2021	2	222	111
PLANNED	7/22/2021	4	24	6
PLANNED	7/22/2021	1	18	18
PLANNED	7/22/2021	4	631	229
PLANNED	7/22/2021	9	864	96
PLANNED	7/22/2021	1	25	25
PLANNED	7/22/2021	3	462	154
PLANNED	7/22/2021	4	56	14
CUSTOMER REQUEST	7/22/2021	14	42	3
PLANNED	7/22/2021	39	4,290	110
PLANNED	7/22/2021	35	3,605	103
PLANNED	7/22/2021	6	894	149
PLANNED	7/22/2021	2	108	54
PLANNED	7/22/2021	23	2,254	98
PLANNED	7/22/2021	19	1,843	97
PLANNED	7/22/2021	8	328	41
PLANNED	7/22/2021	2	154	77
PLANNED	7/22/2021	1	7	7
PLANNED	7/22/2021	3	60	20
PLANNED	7/22/2021	5	70	14
PLANNED	7/22/2021	7	91	13
PLANNED	7/22/2021	2	260	130
PLANNED	7/22/2021	4	20	5
PLANNED	7/22/2021	4	936	234
PLANNED	7/22/2021	2	204	102
PLANNED	7/22/2021	6	468	78
PLANNED	7/22/2021	10	180	18
PLANNED	7/22/2021	1	124	124
PLANNED	7/22/2021	5	45	9
PLANNED	7/22/2021	2	76	38
PLANNED	7/22/2021	7	217	31
CUSTOMER REQUEST	7/22/2021	2	586	293
PLANNED	7/22/2021	3	21	7
PLANNED	7/22/2021	1	151	151
PLANNED	7/22/2021	22	1,188	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	7/22/2021	1	91	91
PLANNED	7/22/2021	4	216	54
PLANNED	7/22/2021	4	140	35
PLANNED	7/22/2021	2	158	79
PLANNED	7/22/2021	9	585	65
PLANNED	7/22/2021	1	9	9
PLANNED	7/22/2021	4	20	5
PLANNED	7/22/2021	7	126	18
PLANNED	7/22/2021	6	336	56
PLANNED	7/22/2021	3	147	49
PLANNED	7/22/2021	5	35	7
PLANNED	7/22/2021	3	9	3
PLANNED	7/22/2021	4	100	25
PLANNED	7/22/2021	2	8	4
PLANNED	7/22/2021	3	12	4
PLANNED	7/22/2021	4	16	4
PLANNED	7/22/2021	4	20	5
PLANNED	7/22/2021	3	36	12
PLANNED	7/22/2021	1	41	41
PLANNED	7/22/2021	1	63	63
PLANNED	7/22/2021	3	57	19
PLANNED	7/22/2021	10	30	3
PLANNED	7/22/2021	5	275	55
PLANNED	7/22/2021	4	144	36
PLANNED	7/22/2021	4	20	5
PLANNED	7/22/2021	2	26	13
PLANNED	7/22/2021	2	26	13
PLANNED	7/22/2021	3	663	221
PLANNED	7/22/2021	1	7	7
PLANNED	7/22/2021	1	5	5
PLANNED	7/22/2021	1	460	460
PLANNED	7/22/2021	6	174	29
PLANNED	7/22/2021	4	548	137
PLANNED	7/22/2021	2	14	7
PLANNED	7/22/2021	2	578	289
PLANNED	7/22/2021	1	145	145
PLANNED	7/22/2021	1	10	10
PLANNED	7/22/2021	3	285	95
PLANNED	7/22/2021	6	30	5
PLANNED	7/22/2021	1	118	118
PLANNED	7/22/2021	5	90	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/22/2021	12	276	23
PLANNED	7/22/2021	5	70	14
PLANNED	7/22/2021	10	50	5
PLANNED	7/22/2021	2	308	154
PLANNED	7/22/2021	3	411	137
PLANNED	7/22/2021	3	327	109
PLANNED	7/22/2021	5	40	8
PLANNED	7/22/2021	2	14	7
PLANNED	7/22/2021	4	116	29
CUSTOMER REQUEST	7/22/2021	11	1,606	146
PLANNED	7/22/2021	1	15	15
PLANNED	7/22/2021	4	24	6
PLANNED	7/22/2021	2	324	162
PLANNED	7/22/2021	2	260	130
PLANNED	7/22/2021	1	6	6
PLANNED	7/22/2021	11	110	10
PLANNED	7/22/2021	2	14	7
PLANNED	7/22/2021	6	84	14
PLANNED	7/22/2021	3	75	25
PLANNED	7/22/2021	11	88	8
PLANNED	7/22/2021	1	5	5
PLANNED	7/22/2021	8	104	13
PLANNED	7/22/2021	4	44	11
PLANNED	7/22/2021	1	57	57
PLANNED	7/22/2021	4	76	19
PLANNED	7/22/2021	8	264	33
PLANNED	7/22/2021	6	42	7
PLANNED	7/22/2021	3	18	6
PLANNED	7/22/2021	1	89	89
PLANNED	7/22/2021	1	20	20
PLANNED	7/22/2021	9	63	7
PLANNED	7/22/2021	4	196	49
PLANNED	7/22/2021	1	10	10
PLANNED	7/22/2021	1	112	112
PLANNED	7/22/2021	4	116	29
PLANNED	7/22/2021	7	35	5
PLANNED	7/22/2021	3	27	9
PLANNED	7/22/2021	13	286	22
PLANNED	7/22/2021	5	95	23
PLANNED	7/22/2021	2	182	91
PLANNED	7/22/2021	6	156	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/22/2021	30	2,010	67
PLANNED	7/22/2021	3	66	22
PLANNED	7/22/2021	4	76	19
PLANNED	7/22/2021	2	14	7
PLANNED	7/22/2021	2	256	128
PLANNED	7/22/2021	3	18	6
PLANNED	7/22/2021	4	388	97
PLANNED	7/22/2021	1	18	18
PLANNED	7/22/2021	3	423	141
PLANNED	7/22/2021	6	30	5
PLANNED	7/22/2021	6	234	39
PLANNED	7/22/2021	1	108	108
PLANNED	7/22/2021	1	3	3
PLANNED	7/22/2021	7	406	58
PLANNED	7/22/2021	2	26	13
PLANNED	7/22/2021	4	52	13
PLANNED	7/22/2021	3	18	6
PLANNED	7/22/2021	2	78	39
PLANNED	7/22/2021	5	315	63
PLANNED	7/22/2021	3	18	6
PLANNED	7/22/2021	18	378	21
PLANNED	7/22/2021	9	27	3
PLANNED	7/22/2021	8	208	26
PLANNED	7/22/2021	2	38	19
PLANNED	7/22/2021	1	6	6
PLANNED	7/22/2021	6	108	18
PLANNED	7/22/2021	4	40	10
PLANNED	7/22/2021	3	330	110
PLANNED	7/22/2021	4	60	15
PLANNED	7/22/2021	2	102	51
PLANNED	7/22/2021	1	373	373
PLANNED	7/22/2021	2	148	74
PLANNED	7/22/2021	5	160	32
CUSTOMER REQUEST	7/22/2021	1	130	130
PLANNED	7/22/2021	5	1,065	213
PLANNED	7/22/2021	5	1,590	318
PLANNED	7/22/2021	6	216	36
PLANNED	7/22/2021	4	628	157
PLANNED	7/22/2021	15	2,400	160
PLANNED	7/22/2021	1	70	70
PLANNED	7/23/2021	4	632	158

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/23/2021	1	163	163
PLANNED	7/23/2021	3	792	264
PLANNED	7/23/2021	9	909	101
PLANNED	7/23/2021	4	380	95
PLANNED	7/23/2021	3	66	22
PLANNED	7/23/2021	4	492	123
PLANNED	7/23/2021	4	72	18
PLANNED	7/23/2021	7	539	77
PLANNED	7/23/2021	6	126	21
PLANNED	7/23/2021	1	183	183
PLANNED	7/23/2021	6	174	29
PLANNED	7/23/2021	10	290	29
PLANNED	7/23/2021	3	213	71
PLANNED	7/23/2021	4	80	20
PLANNED	7/23/2021	2	10	5
PLANNED	7/23/2021	1	12	12
PLANNED	7/23/2021	1	11	11
PLANNED	7/23/2021	2	20	10
PLANNED	7/23/2021	3	21	7
PLANNED	7/23/2021	2	432	216
PLANNED	7/23/2021	4	116	29
PLANNED	7/23/2021	8	600	75
PLANNED	7/23/2021	3	102	34
CUSTOMER REQUEST	7/23/2021	1	98	98
PLANNED	7/23/2021	1	264	264
PLANNED	7/23/2021	3	336	112
PLANNED	7/23/2021	8	760	95
PLANNED	7/23/2021	2	14	7
PLANNED	7/23/2021	5	410	82
PLANNED	7/23/2021	4	20	5
CUSTOMER REQUEST	7/23/2021	11	220	20
PLANNED	7/23/2021	2	66	33
CUSTOMER REQUEST	7/23/2021	1	48	48
PLANNED	7/23/2021	4	240	60
PLANNED	7/23/2021	11	935	85
PLANNED	7/23/2021	8	816	102
PLANNED	7/23/2021	6	84	14
PLANNED	7/23/2021	6	1,038	173
PLANNED	7/23/2021	8	112	14
PLANNED	7/23/2021	2	314	157
PLANNED	7/23/2021	49	7,252	148

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/23/2021	5	215	43
PLANNED	7/23/2021	2	48	24
PLANNED	7/23/2021	10	60	6
PLANNED	7/23/2021	11	154	14
PLANNED	7/23/2021	1	2	2
PLANNED	7/23/2021	2	38	19
PLANNED	7/23/2021	3	36	12
PLANNED	7/23/2021	6	102	17
CUSTOMER REQUEST	7/23/2021	1	235	235
PLANNED	7/23/2021	4	32	8
PLANNED	7/23/2021	4	412	103
PLANNED	7/23/2021	2	102	51
PLANNED	7/23/2021	5	80	16
PLANNED	7/23/2021	1	71	71
PLANNED	7/23/2021	1	55	55
PLANNED	7/23/2021	2	44	22
PLANNED	7/23/2021	4	20	5
PLANNED	7/23/2021	3	42	14
PLANNED	7/23/2021	1	252	252
PLANNED	7/23/2021	3	18	6
PLANNED	7/23/2021	1	7	7
PLANNED	7/23/2021	9	54	6
PLANNED	7/23/2021	4	56	14
PLANNED	7/23/2021	3	111	37
PLANNED	7/23/2021	4	56	14
PLANNED	7/23/2021	2	86	43
PLANNED	7/23/2021	8	648	81
PLANNED	7/23/2021	4	216	54
PLANNED	7/23/2021	3	120	40
PLANNED	7/23/2021	11	253	23
PLANNED	7/23/2021	10	1,430	143
PLANNED	7/23/2021	9	45	5
PLANNED	7/23/2021	5	85	17
PLANNED	7/23/2021	1	2	2
PLANNED	7/23/2021	8	264	33
PLANNED	7/23/2021	3	153	51
PLANNED	7/23/2021	3	12	4
CUSTOMER REQUEST	7/23/2021	23	391	17
PLANNED	7/23/2021	4	92	23
PLANNED	7/23/2021	8	96	12
PLANNED	7/23/2021	1	84	84

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/23/2021	1	86	86
PLANNED	7/23/2021	9	63	7
PLANNED	7/23/2021	8	120	15
PLANNED	7/23/2021	4	132	33
PLANNED	7/23/2021	4	156	39
PLANNED	7/23/2021	6	180	30
PLANNED	7/23/2021	2	192	96
PLANNED	7/23/2021	9	405	45
CUSTOMER REQUEST	7/23/2021	1	37	37
PLANNED	7/23/2021	4	112	28
PLANNED	7/23/2021	12	108	9
PLANNED	7/23/2021	6	1,284	214
PLANNED	7/23/2021	1	176	176
CUSTOMER REQUEST	7/23/2021	1,664	101,504	61
PLANNED	7/23/2021	1	59	59
PLANNED	7/24/2021	1	24	24
PLANNED	7/24/2021	2	74	37
PLANNED	7/24/2021	5	460	92
PLANNED	7/24/2021	6	60	10
PLANNED	7/24/2021	2	16	8
PLANNED	7/24/2021	1	3	3
PLANNED	7/24/2021	1	23	23
PLANNED	7/24/2021	33	4,290	130
CUSTOMER REQUEST	7/24/2021	1	218	218
PLANNED	7/25/2021	9	225	25
PLANNED	7/25/2021	4	496	124
PLANNED	7/25/2021	1	272	272
PLANNED	7/25/2021	6	822	137
PLANNED	7/25/2021	1	244	244
CUSTOMER REQUEST	7/25/2021	145	23,402	206
PLANNED	7/25/2021	4	284	71
PLANNED	7/25/2021	3	303	101
PLANNED	7/25/2021	1	57	57
PLANNED	7/25/2021	7	588	84
PLANNED	7/25/2021	7	903	129
PLANNED	7/25/2021	1	53	53
CUSTOMER REQUEST	7/25/2021	1	50	50
PLANNED	7/25/2021	1	72	72
PLANNED	7/25/2021	3	54	18
PLANNED	7/25/2021	1	198	198
PLANNED	7/26/2021	4	40	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/26/2021	1	8	8
PLANNED	7/26/2021	3	18	6
PLANNED	7/26/2021	1	12	12
PLANNED	7/26/2021	2	18	9
PLANNED	7/26/2021	1	9	9
PLANNED	7/26/2021	2	14	7
PLANNED	7/26/2021	3	24	8
PLANNED	7/26/2021	3	168	56
CUSTOMER REQUEST	7/26/2021	1	214	214
PLANNED	7/26/2021	1	8	8
PLANNED	7/26/2021	6	384	64
PLANNED	7/26/2021	3	21	7
PLANNED	7/26/2021	2	22	11
PLANNED	7/26/2021	4	432	108
PLANNED	7/26/2021	2	16	8
PLANNED	7/26/2021	1	62	62
PLANNED	7/26/2021	2	246	123
PLANNED	7/26/2021	4	56	14
PLANNED	7/26/2021	3	273	91
PLANNED	7/26/2021	2	32	16
PLANNED	7/26/2021	1	8	8
PLANNED	7/26/2021	2	12	6
PLANNED	7/26/2021	1	5	5
PLANNED	7/26/2021	2	16	8
PLANNED	7/26/2021	3	12	4
PLANNED	7/26/2021	5	70	14
PLANNED	7/26/2021	3	21	7
PLANNED	7/26/2021	2	272	136
PLANNED	7/26/2021	3	21	7
PLANNED	7/26/2021	4	56	14
PLANNED	7/26/2021	8	792	99
PLANNED	7/26/2021	12	2,964	247
PLANNED	7/26/2021	6	546	91
PLANNED	7/26/2021	2	16	8
PLANNED	7/26/2021	4	20	5
PLANNED	7/26/2021	3	120	40
PLANNED	7/26/2021	2	148	74
PLANNED	7/26/2021	9	3,042	338
PLANNED	7/26/2021	8	392	49
PLANNED	7/26/2021	12	4,020	335
PLANNED	7/26/2021	5	295	83

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/26/2021	1	6	6
PLANNED	7/26/2021	1	22	22
PLANNED	7/26/2021	8	112	14
PLANNED	7/26/2021	9	3,042	338
PLANNED	7/26/2021	9	3,042	338
PLANNED	7/26/2021	3	18	6
PLANNED	7/26/2021	5	155	31
PLANNED	7/26/2021	8	136	17
PLANNED	7/26/2021	3	15	5
PLANNED	7/26/2021	8	1,120	140
PLANNED	7/26/2021	3	558	186
PLANNED	7/26/2021	9	468	52
PLANNED	7/26/2021	4	280	70
PLANNED	7/26/2021	1	76	76
PLANNED	7/26/2021	1	12	12
PLANNED	7/26/2021	5	500	100
PLANNED	7/26/2021	4	16	4
PLANNED	7/26/2021	4	540	135
PLANNED	7/26/2021	10	1,000	100
CUSTOMER REQUEST	7/26/2021	1	334	334
PLANNED	7/26/2021	2	16	8
CUSTOMER REQUEST	7/26/2021	9	198	22
PLANNED	7/26/2021	1	144	144
PLANNED	7/26/2021	4	60	15
PLANNED	7/26/2021	1	140	140
PLANNED	7/26/2021	3	15	5
PLANNED	7/26/2021	4	52	13
PLANNED	7/26/2021	3	18	6
PLANNED	7/26/2021	1	6	6
PLANNED	7/26/2021	3	36	12
PLANNED	7/26/2021	2	20	10
PLANNED	7/26/2021	3	30	10
PLANNED	7/26/2021	2	462	231
PLANNED	7/26/2021	1	7	7
PLANNED	7/26/2021	2	80	40
PLANNED	7/26/2021	6	510	85
PLANNED	7/26/2021	4	16	4
PLANNED	7/26/2021	2	30	15
PLANNED	7/26/2021	2	22	11
PLANNED	7/26/2021	8	537	103
PLANNED	7/26/2021	16	1,344	84

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/26/2021	3	396	132
PLANNED	7/26/2021	4	72	18
PLANNED	7/26/2021	12	360	30
PLANNED	7/26/2021	4	52	13
PLANNED	7/26/2021	3	39	13
PLANNED	7/26/2021	1	196	196
PLANNED	7/26/2021	1	56	56
PLANNED	7/26/2021	8	536	67
PLANNED	7/26/2021	3	294	98
PLANNED	7/26/2021	4	40	10
PLANNED	7/26/2021	4	388	97
PLANNED	7/26/2021	2	96	48
PLANNED	7/26/2021	4	88	22
PLANNED	7/26/2021	2	242	121
PLANNED	7/26/2021	8	1,000	125
PLANNED	7/26/2021	4	132	33
PLANNED	7/26/2021	4	96	24
PLANNED	7/26/2021	2	88	44
PLANNED	7/26/2021	1	65	65
PLANNED	7/26/2021	2	30	15
PLANNED	7/26/2021	3	45	15
PLANNED	7/26/2021	4	24	6
PLANNED	7/26/2021	263	23,144	88
PLANNED	7/26/2021	6	444	74
PLANNED	7/26/2021	5	165	33
CUSTOMER REQUEST	7/26/2021	5	3,660	732
PLANNED	7/26/2021	1	6	6
PLANNED	7/26/2021	3	27	9
PLANNED	7/26/2021	4	160	40
PLANNED	7/26/2021	3	18	6
PLANNED	7/26/2021	1	10	10
PLANNED	7/26/2021	1	41	41
PLANNED	7/26/2021	4	28	7
PLANNED	7/26/2021	3	24	8
PLANNED	7/26/2021	1	9	9
PLANNED	7/26/2021	3	33	11
PLANNED	7/26/2021	1	8	8
PLANNED	7/26/2021	12	192	16
PLANNED	7/26/2021	6	18	3
PLANNED	7/26/2021	8	32	4
PLANNED	7/26/2021	3	168	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/26/2021	4	24	6
PLANNED	7/26/2021	1	7	7
PLANNED	7/26/2021	2	20	10
PLANNED	7/26/2021	3	36	12
PLANNED	7/26/2021	4	72	18
PLANNED	7/26/2021	1	6	6
PLANNED	7/26/2021	1	24	24
PLANNED	7/26/2021	3	51	17
PLANNED	7/26/2021	4	40	10
PLANNED	7/26/2021	2	18	9
PLANNED	7/26/2021	2	8	4
PLANNED	7/26/2021	15	45	3
PLANNED	7/26/2021	1	9	9
PLANNED	7/26/2021	8	328	41
PLANNED	7/26/2021	4	64	16
PLANNED	7/26/2021	5	565	113
PLANNED	7/26/2021	2	30	15
PLANNED	7/26/2021	2	8	4
PLANNED	7/26/2021	1	8	8
PLANNED	7/26/2021	2	160	80
PLANNED	7/26/2021	4	20	5
PLANNED	7/26/2021	2	48	24
PLANNED	7/26/2021	3	456	152
PLANNED	7/26/2021	4	136	34
PLANNED	7/26/2021	4	20	5
PLANNED	7/26/2021	3	219	73
PLANNED	7/26/2021	1	5	5
PLANNED	7/26/2021	3	81	27
PLANNED	7/26/2021	1	7	7
PLANNED	7/26/2021	4	28	7
PLANNED	7/26/2021	3	15	5
PLANNED	7/26/2021	6	1,014	169
PLANNED	7/26/2021	63	1,386	22
PLANNED	7/26/2021	9	360	40
PLANNED	7/26/2021	5	420	84
PLANNED	7/26/2021	10	840	84
PLANNED	7/26/2021	3	15	5
PLANNED	7/26/2021	3	2,055	685
PLANNED	7/26/2021	3	63	21
PLANNED	7/26/2021	3	30	10
PLANNED	7/26/2021	8	848	106

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/26/2021	7	224	32
PLANNED	7/26/2021	1	26	26
PLANNED	7/26/2021	3	327	109
CUSTOMER REQUEST	7/26/2021	1	66	66
PLANNED	7/26/2021	49	3,185	65
PLANNED	7/26/2021	4	68	17
PLANNED	7/26/2021	2	102	51
PLANNED	7/26/2021	2	204	102
PLANNED	7/27/2021	2	170	85
PLANNED	7/27/2021	1	130	130
PLANNED	7/27/2021	5	895	179
PLANNED	7/27/2021	5	305	61
CUSTOMER REQUEST	7/27/2021	506	32,384	64
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	3	12	4
PLANNED	7/27/2021	4	20	5
PLANNED	7/27/2021	4	132	33
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	2	8	4
PLANNED	7/27/2021	4	24	6
PLANNED	7/27/2021	4	28	7
PLANNED	7/27/2021	10	310	31
PLANNED	7/27/2021	3	21	7
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	1	222	222
PLANNED	7/27/2021	1	6	6
PLANNED	7/27/2021	4	20	5
CUSTOMER REQUEST	7/27/2021	533	27,270	60
PLANNED	7/27/2021	1	142	142
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	2	14	7
PLANNED	7/27/2021	1	7	7
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	1	9	9
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	3	48	16
PLANNED	7/27/2021	1	24	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/27/2021	7	84	12
PLANNED	7/27/2021	1	11	11
PLANNED	7/27/2021	5	975	195
PLANNED	7/27/2021	2	34	17
CUSTOMER REQUEST	7/27/2021	1	246	246
PLANNED	7/27/2021	3	261	87
CUSTOMER REQUEST	7/27/2021	1	245	245
PLANNED	7/27/2021	3	9	3
PLANNED	7/27/2021	4	148	37
PLANNED	7/27/2021	8	464	58
PLANNED	7/27/2021	2	880	440
PLANNED	7/27/2021	12	2,748	229
PLANNED	7/27/2021	8	1,336	167
PLANNED	7/27/2021	12	2,748	229
PLANNED	7/27/2021	1	79	79
PLANNED	7/27/2021	1	9	9
PLANNED	7/27/2021	4	276	69
PLANNED	7/27/2021	4	282	77
PLANNED	7/27/2021	1	6	6
CUSTOMER REQUEST	7/27/2021	6	558	458
PLANNED	7/27/2021	6	624	104
PLANNED	7/27/2021	4	56	14
PLANNED	7/27/2021	10	2,787	429
PLANNED	7/27/2021	8	1,480	185
PLANNED	7/27/2021	1	9	9
PLANNED	7/27/2021	1	65	65
PLANNED	7/27/2021	4	1,192	298
PLANNED	7/27/2021	1	4	4
PLANNED	7/27/2021	5	465	93
PLANNED	7/27/2021	7	1,456	208
PLANNED	7/27/2021	8	936	117
PLANNED	7/27/2021	23	2,806	122
PLANNED	7/27/2021	1	6	6
PLANNED	7/27/2021	16	2,064	129
PLANNED	7/27/2021	2	18	9
PLANNED	7/27/2021	4	20	5
PLANNED	7/27/2021	3	21	7
PLANNED	7/27/2021	4	20	5
PLANNED	7/27/2021	2	12	6
PLANNED	7/27/2021	2	18	9
PLANNED	7/27/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/27/2021	2	20	10
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	8	936	117
PLANNED	7/27/2021	3	45	15
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	1	139	139
PLANNED	7/27/2021	2	12	6
PLANNED	7/27/2021	6	168	28
PLANNED	7/27/2021	7	777	111
PLANNED	7/27/2021	1	143	143
PLANNED	7/27/2021	9	1,521	169
PLANNED	7/27/2021	7	98	14
PLANNED	7/27/2021	1	323	323
PLANNED	7/27/2021	2	18	9
PLANNED	7/27/2021	3	27	9
PLANNED	7/27/2021	8	912	114
PLANNED	7/27/2021	8	912	114
PLANNED	7/27/2021	3	441	147
PLANNED	7/27/2021	7	966	138
PLANNED	7/27/2021	4	512	128
PLANNED	7/27/2021	2	238	119
PLANNED	7/27/2021	8	128	16
PLANNED	7/27/2021	2	26	13
PLANNED	7/27/2021	6	858	143
PLANNED	7/27/2021	1	8	8
PLANNED	7/27/2021	2	46	23
PLANNED	7/27/2021	7	371	53
PLANNED	7/27/2021	4	600	150
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	5	35	7
PLANNED	7/27/2021	3	27	9
PLANNED	7/27/2021	1	51	51
PLANNED	7/27/2021	1	11	11
PLANNED	7/27/2021	46	6,808	148
PLANNED	7/27/2021	9	1,197	133
PLANNED	7/27/2021	1	7	7
PLANNED	7/27/2021	26	4,420	170
PLANNED	7/27/2021	2	370	185
PLANNED	7/27/2021	1	29	29
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	5	25	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/27/2021	1	19	19
PLANNED	7/27/2021	8	1,600	200
CUSTOMER REQUEST	7/27/2021	2	42	21
PLANNED	7/27/2021	5	885	177
PLANNED	7/27/2021	6	30	5
PLANNED	7/27/2021	3	18	6
PLANNED	7/27/2021	4	284	71
PLANNED	7/27/2021	1	5	5
PLANNED	7/27/2021	1	42	42
PLANNED	7/27/2021	4	20	5
PLANNED	7/27/2021	1	13	13
CUSTOMER REQUEST	7/27/2021	1	64	64
PLANNED	7/27/2021	7	896	128
PLANNED	7/27/2021	1	7	7
PLANNED	7/27/2021	2	26	13
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	5	25	5
PLANNED	7/27/2021	3	15	5
PLANNED	7/27/2021	9	837	93
PLANNED	7/27/2021	2	22	11
PLANNED	7/27/2021	4	20	5
PLANNED	7/27/2021	6	510	85
CUSTOMER REQUEST	7/27/2021	1	310	310
PLANNED	7/27/2021	1	51	51
PLANNED	7/27/2021	4	60	15
PLANNED	7/27/2021	8	936	117
PLANNED	7/27/2021	2	12	6
PLANNED	7/27/2021	7	1,008	144
PLANNED	7/27/2021	7	42	6
PLANNED	7/27/2021	1	46	46
PLANNED	7/27/2021	2	22	11
PLANNED	7/27/2021	3	30	10
PLANNED	7/27/2021	4	264	66
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	1	8	8
PLANNED	7/27/2021	3	30	10
PLANNED	7/27/2021	2	44	22
PLANNED	7/27/2021	11	121	11
PLANNED	7/27/2021	2	12	6
PLANNED	7/27/2021	1	10	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/27/2021	12	1,332	111
PLANNED	7/27/2021	10	950	95
PLANNED	7/27/2021	7	154	22
PLANNED	7/27/2021	4	488	122
PLANNED	7/27/2021	8	1,056	132
PLANNED	7/27/2021	2	102	51
PLANNED	7/27/2021	1	7	7
PLANNED	7/27/2021	2	120	60
PLANNED	7/27/2021	2	22	11
PLANNED	7/27/2021	1	98	98
PLANNED	7/27/2021	1	312	312
PLANNED	7/27/2021	4	228	57
PLANNED	7/27/2021	2	20	10
PLANNED	7/27/2021	1	14	14
PLANNED	7/27/2021	1	7	7
PLANNED	7/27/2021	1	45	45
PLANNED	7/27/2021	2	28	14
PLANNED	7/27/2021	2	236	118
PLANNED	7/27/2021	3	27	9
PLANNED	7/27/2021	3	18	6
PLANNED	7/27/2021	3	363	121
PLANNED	7/27/2021	1	40	40
PLANNED	7/27/2021	12	192	16
PLANNED	7/27/2021	2	26	13
PLANNED	7/27/2021	3	36	12
PLANNED	7/27/2021	1	11	11
PLANNED	7/27/2021	1	59	59
PLANNED	7/27/2021	2	258	129
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	1	6	6
PLANNED	7/27/2021	8	976	122
PLANNED	7/27/2021	2	10	5
PLANNED	7/27/2021	9	963	107
PLANNED	7/27/2021	2	190	95
PLANNED	7/27/2021	2	152	76
PLANNED	7/27/2021	6	558	93
CUSTOMER REQUEST	7/27/2021	12	444	37
PLANNED	7/27/2021	6	264	44
PLANNED	7/27/2021	2	166	83
PLANNED	7/27/2021	2	66	33
PLANNED	7/27/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/27/2021	3	264	88
PLANNED	7/27/2021	8	232	29
PLANNED	7/27/2021	5	175	35
PLANNED	7/27/2021	2	254	127
PLANNED	7/27/2021	5	130	26
PLANNED	7/27/2021	7	168	24
CUSTOMER REQUEST	7/27/2021	1	234	234
PLANNED	7/27/2021	1	63	63
PLANNED	7/27/2021	8	408	51
PLANNED	7/27/2021	1	342	342
PLANNED	7/28/2021	8	482	76
PLANNED	7/28/2021	7	294	42
PLANNED	7/28/2021	7	455	65
PLANNED	7/28/2021	3	309	103
PLANNED	7/28/2021	1	175	175
PLANNED	7/28/2021	4	60	15
PLANNED	7/28/2021	35	6,090	174
PLANNED	7/28/2021	1	319	319
PLANNED	7/28/2021	9	2,241	249
PLANNED	7/28/2021	1	91	91
PLANNED	7/28/2021	2	62	31
PLANNED	7/28/2021	3	15	5
PLANNED	7/28/2021	1	59	59
PLANNED	7/28/2021	4	536	134
PLANNED	7/28/2021	2	12	6
PLANNED	7/28/2021	2	252	126
PLANNED	7/28/2021	2	10	5
CUSTOMER REQUEST	7/28/2021	1	412	412
PLANNED	7/28/2021	2	72	36
PLANNED	7/28/2021	3	60	20
PLANNED	7/28/2021	2	452	226
PLANNED	7/28/2021	2	6	3
PLANNED	7/28/2021	2	48	24
CUSTOMER REQUEST	7/28/2021	105	11,550	110
PLANNED	7/28/2021	2	36	18
PLANNED	7/28/2021	4	68	17
PLANNED	7/28/2021	1	44	44
PLANNED	7/28/2021	4	16	4
PLANNED	7/28/2021	3	24	8
PLANNED	7/28/2021	1	17	17
PLANNED	7/28/2021	2	24	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/28/2021	3	21	7
PLANNED	7/28/2021	3	24	8
PLANNED	7/28/2021	7	259	37
PLANNED	7/28/2021	3	24	8
CUSTOMER REQUEST	7/28/2021	59	5,074	86
PLANNED	7/28/2021	3	15	5
PLANNED	7/28/2021	1	127	127
PLANNED	7/28/2021	3	9	3
PLANNED	7/28/2021	1	171	171
PLANNED	7/28/2021	1	10	10
PLANNED	7/28/2021	12	1,056	88
PLANNED	7/28/2021	2	6	3
PLANNED	7/28/2021	4	656	164
PLANNED	7/28/2021	3	30	10
PLANNED	7/28/2021	1	124	124
PLANNED	7/28/2021	2	14	7
PLANNED	7/28/2021	1	5	5
PLANNED	7/28/2021	1	166	166
PLANNED	7/28/2021	2	330	165
PLANNED	7/28/2021	28	196	7
PLANNED	7/28/2021	4	8	2
PLANNED	7/28/2021	77	6,622	86
PLANNED	7/28/2021	6	480	80
PLANNED	7/28/2021	6	834	139
PLANNED	7/28/2021	3	12	4
PLANNED	7/28/2021	17	3,757	221
PLANNED	7/28/2021	33	6,039	183
PLANNED	7/28/2021	2	10	5
PLANNED	7/28/2021	3	522	174
PLANNED	7/28/2021	4	60	15
PLANNED	7/28/2021	2	24	12
PLANNED	7/28/2021	3	33	11
PLANNED	7/28/2021	7	413	59
PLANNED	7/28/2021	1	134	134
PLANNED	7/28/2021	4	24	6
PLANNED	7/28/2021	7	49	7
PLANNED	7/28/2021	22	2,706	123
PLANNED	7/28/2021	2	142	71
PLANNED	7/28/2021	3	312	104
PLANNED	7/28/2021	2	28	14
PLANNED	7/28/2021	16	3,024	189

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/28/2021	2	44	22
PLANNED	7/28/2021	1	41	41
PLANNED	7/28/2021	1	10	10
PLANNED	7/28/2021	7	812	116
PLANNED	7/28/2021	5	145	29
PLANNED	7/28/2021	3	33	11
PLANNED	7/28/2021	2	262	131
CUSTOMER REQUEST	7/28/2021	1	44	44
PLANNED	7/28/2021	8	472	59
PLANNED	7/28/2021	3	171	57
PLANNED	7/28/2021	9	513	57
PLANNED	7/28/2021	1	69	69
PLANNED	7/28/2021	4	228	57
PLANNED	7/28/2021	1	4	4
PLANNED	7/28/2021	14	2,352	168
PLANNED	7/28/2021	9	522	58
PLANNED	7/28/2021	4	164	41
PLANNED	7/28/2021	3	90	30
PLANNED	7/28/2021	2	12	6
PLANNED	7/28/2021	7	560	80
PLANNED	7/28/2021	4	292	73
PLANNED	7/28/2021	2	332	166
PLANNED	7/28/2021	1	6	6
PLANNED	7/28/2021	2	26	13
PLANNED	7/28/2021	26	858	33
PLANNED	7/28/2021	2	24	12
PLANNED	7/28/2021	4	328	82
PLANNED	7/28/2021	1	5	5
PLANNED	7/28/2021	1	44	44
PLANNED	7/28/2021	1	3	3
PLANNED	7/28/2021	4	24	6
PLANNED	7/28/2021	1	91	91
PLANNED	7/28/2021	5	35	7
PLANNED	7/28/2021	2	10	5
PLANNED	7/28/2021	1	16	16
PLANNED	7/28/2021	1	6	6
PLANNED	7/28/2021	2	10	5
PLANNED	7/28/2021	1	22	22
PLANNED	7/28/2021	1	11	11
PLANNED	7/28/2021	3	114	38
PLANNED	7/28/2021	1	48	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/28/2021	4	24	6
PLANNED	7/28/2021	2	34	17
PLANNED	7/28/2021	4	24	6
PLANNED	7/28/2021	1	8	8
PLANNED	7/28/2021	4	20	5
PLANNED	7/28/2021	1	19	19
PLANNED	7/28/2021	5	54	34
PLANNED	7/28/2021	4	480	120
PLANNED	7/28/2021	2	90	45
PLANNED	7/28/2021	2	10	5
PLANNED	7/28/2021	6	438	73
PLANNED	7/28/2021	3	123	41
PLANNED	7/28/2021	4	116	29
PLANNED	7/28/2021	5	205	41
PLANNED	7/28/2021	2	10	5
PLANNED	7/28/2021	4	400	100
PLANNED	7/28/2021	4	340	85
PLANNED	7/28/2021	11	1,023	93
PLANNED	7/28/2021	1	4	4
PLANNED	7/28/2021	2	26	13
PLANNED	7/28/2021	1	5	5
PLANNED	7/28/2021	10	410	41
PLANNED	7/28/2021	2	8	4
PLANNED	7/28/2021	4	212	53
PLANNED	7/28/2021	2	20	10
PLANNED	7/28/2021	3	27	9
PLANNED	7/28/2021	3	39	13
CUSTOMER REQUEST	7/28/2021	6	780	130
PLANNED	7/28/2021	5	135	27
PLANNED	7/28/2021	2	12	6
PLANNED	7/28/2021	4	36	9
PLANNED	7/28/2021	13	819	63
PLANNED	7/28/2021	4	56	14
PLANNED	7/28/2021	3	84	28
PLANNED	7/28/2021	3	93	31
PLANNED	7/28/2021	3	144	48
PLANNED	7/28/2021	2	432	216
PLANNED	7/28/2021	2	132	66
PLANNED	7/28/2021	2	90	45
PLANNED	7/28/2021	3	18	6
PLANNED	7/28/2021	3	114	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/28/2021	2	134	67
PLANNED	7/28/2021	3	69	23
PLANNED	7/28/2021	6	192	32
PLANNED	7/28/2021	3	369	123
PLANNED	7/28/2021	1	14	14
PLANNED	7/28/2021	5	140	28
CUSTOMER REQUEST	7/28/2021	1	211	211
CUSTOMER REQUEST	7/28/2021	1	168	168
PLANNED	7/28/2021	3	39	13
PLANNED	7/28/2021	8	512	64
PLANNED	7/28/2021	4	256	64
PLANNED	7/28/2021	4	256	64
PLANNED	7/28/2021	5	320	64
PLANNED	7/28/2021	8	512	64
CUSTOMER REQUEST	7/28/2021	1,112	11,856	174
PLANNED	7/28/2021	1	14	14
PLANNED	7/28/2021	1	59	59
PLANNED	7/28/2021	7	588	84
PLANNED	7/28/2021	6	306	51
PLANNED	7/28/2021	14	2,240	160
PLANNED	7/28/2021	7	1,008	144
PLANNED	7/28/2021	1	252	252
PLANNED	7/29/2021	1	61	61
PLANNED	7/29/2021	3	414	138
PLANNED	7/29/2021	1	16	16
CUSTOMER REQUEST	7/29/2021	1	139	139
PLANNED	7/29/2021	16	144	65
PLANNED	7/29/2021	4	24	6
PLANNED	7/29/2021	4	124	31
PLANNED	7/29/2021	3	12	4
PLANNED	7/29/2021	78	7,098	91
PLANNED	7/29/2021	2	8	4
CUSTOMER REQUEST	7/29/2021	1	115	115
PLANNED	7/29/2021	10	1,830	183
PLANNED	7/29/2021	4	40	10
PLANNED	7/29/2021	2	110	55
PLANNED	7/29/2021	3	18	6
PLANNED	7/29/2021	1	58	58
PLANNED	7/29/2021	2	10	5
PLANNED	7/29/2021	7	646	118
PLANNED	7/29/2021	1	73	73

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/29/2021	1	108	108
PLANNED	7/29/2021	1	235	235
PLANNED	7/29/2021	2	16	8
PLANNED	7/29/2021	4	56	14
PLANNED	7/29/2021	7	91	13
PLANNED	7/29/2021	3	36	12
PLANNED	7/29/2021	1	91	91
PLANNED	7/29/2021	5	855	171
PLANNED	7/29/2021	2	224	112
PLANNED	7/29/2021	3	918	306
PLANNED	7/29/2021	16	3,344	209
PLANNED	7/29/2021	8	1,680	210
PLANNED	7/29/2021	1	223	223
PLANNED	7/29/2021	17	3,519	207
PLANNED	7/29/2021	2	16	8
PLANNED	7/29/2021	2	86	43
PLANNED	7/29/2021	7	693	99
PLANNED	7/29/2021	1	130	130
PLANNED	7/29/2021	5	405	81
PLANNED	7/29/2021	8	712	89
PLANNED	7/29/2021	1	201	201
PLANNED	7/29/2021	3	18	6
PLANNED	7/29/2021	11	726	66
PLANNED	7/29/2021	2	286	143
PLANNED	7/29/2021	8	456	57
CUSTOMER REQUEST	7/29/2021	1	85	85
CUSTOMER REQUEST	7/29/2021	8	136	17
PLANNED	7/29/2021	5	125	25
PLANNED	7/29/2021	1	92	92
PLANNED	7/29/2021	8	272	34
PLANNED	7/29/2021	8	216	27
PLANNED	7/29/2021	8	560	70
PLANNED	7/29/2021	4	672	168
PLANNED	7/29/2021	4	428	107
PLANNED	7/29/2021	3	93	31
PLANNED	7/29/2021	1	22	22
PLANNED	7/29/2021	2	12	6
PLANNED	7/29/2021	2	234	117
CUSTOMER REQUEST	7/29/2021	7	504	72
PLANNED	7/29/2021	9	1,845	205
PLANNED	7/29/2021	2	106	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/29/2021	2	24	12
PLANNED	7/29/2021	3	96	32
PLANNED	7/29/2021	2	106	53
PLANNED	7/29/2021	1	16	16
PLANNED	7/29/2021	1	53	53
PLANNED	7/29/2021	2	124	62
PLANNED	7/29/2021	2	110	55
PLANNED	7/29/2021	15	2,685	179
PLANNED	7/29/2021	12	2,952	246
PLANNED	7/29/2021	10	160	16
PLANNED	7/29/2021	12	1,104	92
PLANNED	7/29/2021	7	1,561	223
PLANNED	7/29/2021	3	69	23
PLANNED	7/29/2021	1	65	65
PLANNED	7/29/2021	2	12	6
PLANNED	7/29/2021	4	20	5
PLANNED	7/29/2021	3	12	4
PLANNED	7/29/2021	3	30	10
PLANNED	7/29/2021	1	15	15
PLANNED	7/29/2021	1	7	7
PLANNED	7/29/2021	1	63	63
PLANNED	7/29/2021	19	3,268	172
PLANNED	7/29/2021	4	224	56
PLANNED	7/29/2021	9	333	37
PLANNED	7/29/2021	8	1,000	168
PLANNED	7/29/2021	6	30	5
PLANNED	7/29/2021	2	164	82
PLANNED	7/29/2021	1	14	14
PLANNED	7/29/2021	13	767	59
PLANNED	7/29/2021	2	50	25
PLANNED	7/29/2021	1	643	643
PLANNED	7/29/2021	3	24	8
PLANNED	7/29/2021	1	15	15
PLANNED	7/29/2021	2	144	72
PLANNED	7/29/2021	2	852	426
PLANNED	7/29/2021	3	21	7
PLANNED	7/29/2021	3	18	6
PLANNED	7/29/2021	3	15	5
PLANNED	7/29/2021	2	156	78
PLANNED	7/29/2021	5	295	59
PLANNED	7/29/2021	61	6,527	107

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/29/2021	4	44	11
PLANNED	7/29/2021	1	4	4
PLANNED	7/29/2021	1	101	101
PLANNED	7/29/2021	3	234	78
PLANNED	7/29/2021	1	11	11
PLANNED	7/29/2021	4	90	33
PLANNED	7/29/2021	3	99	33
CUSTOMER REQUEST	7/29/2021	7	56	8
PLANNED	7/29/2021	3	72	24
CUSTOMER REQUEST	7/29/2021	8	48	6
PLANNED	7/29/2021	1	55	55
PLANNED	7/29/2021	4	24	6
PLANNED	7/29/2021	12	1,584	132
PLANNED	7/29/2021	4	32	8
PLANNED	7/29/2021	6	234	39
CUSTOMER REQUEST	7/29/2021	1	337	337
PLANNED	7/29/2021	2	84	42
PLANNED	7/29/2021	10	240	24
PLANNED	7/29/2021	10	240	24
PLANNED	7/29/2021	6	210	35
PLANNED	7/29/2021	9	252	28
PLANNED	7/29/2021	5	120	24
PLANNED	7/29/2021	61	427	7
PLANNED	7/29/2021	12	24	2
CUSTOMER REQUEST	7/29/2021	1	151	151
PLANNED	7/29/2021	3	18	6
PLANNED	7/29/2021	1	6	6
PLANNED	7/29/2021	1	7	7
PLANNED	7/29/2021	1	4	4
PLANNED	7/29/2021	1	68	68
PLANNED	7/29/2021	2	44	22
PLANNED	7/29/2021	2	26	13
PLANNED	7/29/2021	2	8	4
PLANNED	7/29/2021	3	72	24
PLANNED	7/29/2021	3	309	103
PLANNED	7/29/2021	1	68	68
PLANNED	7/29/2021	2	98	49
PLANNED	7/29/2021	10	1,750	175
PLANNED	7/29/2021	4	740	185
PLANNED	7/29/2021	3	24	8
PLANNED	7/29/2021	4	36	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/29/2021	3	168	56
PLANNED	7/29/2021	1	136	136
PLANNED	7/29/2021	4	28	7
PLANNED	7/29/2021	173	12,456	72
PLANNED	7/29/2021	2	34	17
PLANNED	7/29/2021	1	17	17
PLANNED	7/29/2021	1	109	109
PLANNED	7/29/2021	2	196	98
PLANNED	7/29/2021	1	85	85
PLANNED	7/29/2021	2	22	11
PLANNED	7/29/2021	1	97	97
PLANNED	7/29/2021	2	264	132
PLANNED	7/29/2021	2	18	9
PLANNED	7/29/2021	1	82	82
PLANNED	7/29/2021	19	855	45
PLANNED	7/29/2021	9	369	41
PLANNED	7/29/2021	3	27	9
PLANNED	7/29/2021	8	776	97
PLANNED	7/29/2021	3	303	101
PLANNED	7/29/2021	1	15	15
PLANNED	7/29/2021	2	70	35
PLANNED	7/29/2021	1	82	82
PLANNED	7/29/2021	2	80	40
PLANNED	7/29/2021	3	195	65
PLANNED	7/29/2021	1	82	82
PLANNED	7/29/2021	12	468	39
PLANNED	7/29/2021	2	82	41
PLANNED	7/29/2021	43	1,806	42
PLANNED	7/29/2021	3	267	89
PLANNED	7/29/2021	3	159	53
PLANNED	7/29/2021	3	294	98
PLANNED	7/29/2021	1	5	5
PLANNED	7/29/2021	1	68	68
CUSTOMER REQUEST	7/29/2021	7	259	37
PLANNED	7/29/2021	4	340	85
PLANNED	7/29/2021	8	192	24
PLANNED	7/29/2021	5	115	23
PLANNED	7/29/2021	1	335	335
PLANNED	7/29/2021	1	31	31
CUSTOMER REQUEST	7/29/2021	1,802	18,526	17
PLANNED	7/29/2021	12	756	63

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/29/2021	7	966	138
PLANNED	7/29/2021	8	1,384	173
PLANNED	7/29/2021	1	141	141
PLANNED	7/29/2021	12	2,952	246
CUSTOMER REQUEST	7/29/2021	1	56	56
PLANNED	7/30/2021	4	252	63
CUSTOMER REQUEST	7/30/2021	963	26,734	30
PLANNED	7/30/2021	8	1,432	179
CUSTOMER REQUEST	7/30/2021	5	205	41
PLANNED	7/30/2021	9	783	87
PLANNED	7/30/2021	8	680	136
PLANNED	7/30/2021	2	4	2
PLANNED	7/30/2021	1	231	231
PLANNED	7/30/2021	4	116	29
PLANNED	7/30/2021	2	30	15
PLANNED	7/30/2021	1	6	6
PLANNED	7/30/2021	4	112	28
PLANNED	7/30/2021	1	8	8
PLANNED	7/30/2021	4	36	9
PLANNED	7/30/2021	1	72	72
PLANNED	7/30/2021	1	16	16
PLANNED	7/30/2021	4	728	182
CUSTOMER REQUEST	7/30/2021	1	95	95
PLANNED	7/30/2021	4	64	16
PLANNED	7/30/2021	4	348	87
PLANNED	7/30/2021	6	1,152	192
PLANNED	7/30/2021	4	36	9
PLANNED	7/30/2021	2	10	5
PLANNED	7/30/2021	8	1,136	142
PLANNED	7/30/2021	2	294	147
PLANNED	7/30/2021	49	6,811	139
PLANNED	7/30/2021	2	102	51
PLANNED	7/30/2021	3	15	5
PLANNED	7/30/2021	3	138	46
PLANNED	7/30/2021	1	145	145
PLANNED	7/30/2021	2	16	8
PLANNED	7/30/2021	2	114	57
PLANNED	7/30/2021	1	5	5
PLANNED	7/30/2021	1	202	202
PLANNED	7/30/2021	1	46	46
PLANNED	7/30/2021	4	160	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/30/2021	16	2,304	144
PLANNED	7/30/2021	4	72	18
PLANNED	7/30/2021	3	120	40
PLANNED	7/30/2021	7	392	56
PLANNED	7/30/2021	6	36	6
PLANNED	7/30/2021	1	267	267
PLANNED	7/30/2021	35	5,845	167
PLANNED	7/30/2021	4	480	120
PLANNED	7/30/2021	2	30	15
PLANNED	7/30/2021	2	16	8
PLANNED	7/30/2021	2	20	10
PLANNED	7/30/2021	1	16	16
PLANNED	7/30/2021	21	1,359	119
PLANNED	7/30/2021	3	498	166
PLANNED	7/30/2021	1	72	72
PLANNED	7/30/2021	4	268	67
PLANNED	7/30/2021	1	13	13
PLANNED	7/30/2021	1	99	99
PLANNED	7/30/2021	1	154	154
PLANNED	7/30/2021	5	110	22
PLANNED	7/30/2021	8	1,040	130
PLANNED	7/30/2021	2	14	7
PLANNED	7/30/2021	1	59	59
PLANNED	7/30/2021	3	21	7
PLANNED	7/30/2021	2	14	7
PLANNED	7/30/2021	1	11	11
PLANNED	7/30/2021	2	320	160
PLANNED	7/30/2021	5	255	51
PLANNED	7/30/2021	1	40	40
PLANNED	7/30/2021	3	21	7
CUSTOMER REQUEST	7/30/2021	1	72	72
PLANNED	7/30/2021	12	338	59
PLANNED	7/30/2021	2	32	16
PLANNED	7/30/2021	57	1,881	33
PLANNED	7/30/2021	6	1,800	300
PLANNED	7/30/2021	2	308	154
PLANNED	7/30/2021	4	644	161
PLANNED	7/30/2021	9	387	43
PLANNED	7/30/2021	9	396	44
PLANNED	7/30/2021	5	120	24
PLANNED	7/30/2021	5	140	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/30/2021	3	276	92
PLANNED	7/30/2021	2	40	20
CUSTOMER REQUEST	7/30/2021	31	1,519	49
PLANNED	7/30/2021	8	176	22
PLANNED	7/30/2021	2	126	63
CUSTOMER REQUEST	7/30/2021	6	378	358
PLANNED	7/30/2021	1	16	16
PLANNED	7/30/2021	8	440	55
PLANNED	7/30/2021	6	606	101
PLANNED	7/30/2021	6	252	42
PLANNED	7/30/2021	5	205	41
PLANNED	7/30/2021	12	60	5
PLANNED	7/30/2021	9	2,178	242
PLANNED	7/30/2021	3	102	34
PLANNED	7/30/2021	2	44	22
PLANNED	7/30/2021	2	180	90
PLANNED	7/30/2021	11	671	61
PLANNED	7/30/2021	1	78	78
PLANNED	7/30/2021	2	12	6
PLANNED	7/30/2021	6	175	55
PLANNED	7/30/2021	2	46	23
PLANNED	7/30/2021	1	143	143
PLANNED	7/30/2021	9	135	15
PLANNED	7/30/2021	4	20	5
PLANNED	7/30/2021	1	58	58
PLANNED	7/30/2021	4	96	24
PLANNED	7/30/2021	2	38	19
PLANNED	7/30/2021	1	59	59
PLANNED	7/30/2021	8	288	36
PLANNED	7/30/2021	8	448	56
PLANNED	7/30/2021	1	92	92
PLANNED	7/30/2021	2	92	46
PLANNED	7/30/2021	1	18	18
PLANNED	7/30/2021	6	1,014	169
PLANNED	7/30/2021	8	40	5
PLANNED	7/30/2021	4	44	11
PLANNED	7/30/2021	2	52	26
PLANNED	7/30/2021	31	3,038	98
PLANNED	7/30/2021	12	1,356	113
PLANNED	7/30/2021	1	84	84
PLANNED	7/30/2021	12	1,368	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	7/30/2021	8	104	13
PLANNED	7/30/2021	1	70	70
PLANNED	7/30/2021	8	208	26
PLANNED	7/30/2021	25	325	13
PLANNED	7/30/2021	1	18	18
PLANNED	7/30/2021	11	616	56
PLANNED	7/30/2021	1	40	40
PLANNED	7/30/2021	5	760	152
CUSTOMER REQUEST	7/30/2021	1	175	175
CUSTOMER REQUEST	7/30/2021	1	151	151
PLANNED	7/30/2021	1	97	97
CUSTOMER REQUEST	7/30/2021	1	142	142
PLANNED	7/30/2021	1	148	148
CUSTOMER REQUEST	7/31/2021	605	18,150	30
CUSTOMER REQUEST	7/31/2021	1	35	35
PLANNED	7/31/2021	1	264	264
CUSTOMER REQUEST	7/31/2021	3	753	251
PLANNED	7/31/2021	48	4,582	285
PLANNED	7/31/2021	1	121	121
CUSTOMER REQUEST	7/31/2021	2	238	119
PLANNED	7/31/2021	4	168	42
PLANNED	7/31/2021	1	5	5
PLANNED	7/31/2021	2	498	249
PLANNED	7/31/2021	3	195	65
PLANNED	7/31/2021	3	105	35
PLANNED	7/31/2021	1	42	42
PLANNED	7/31/2021	2	96	48
PLANNED	7/31/2021	2	56	28
PLANNED	7/31/2021	1	15	15
PLANNED	7/31/2021	12	312	26
PLANNED	7/31/2021	8	576	72
PLANNED	8/1/2021	8	2,132	348
PLANNED	8/1/2021	3	330	199
PLANNED	8/1/2021	1	47	47
PLANNED	8/1/2021	1	143	143
PLANNED	8/1/2021	1	225	225
PLANNED	8/1/2021	5	135	27
PLANNED	8/1/2021	12	1,308	109
PLANNED	8/1/2021	12	852	71
PLANNED	8/1/2021	1	116	116
PLANNED	8/1/2021	2	364	182

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/1/2021	1	89	89
PLANNED	8/1/2021	2	200	100
PLANNED	8/1/2021	9	126	14
CUSTOMER REQUEST	8/1/2021	8	2,472	309
PLANNED	8/1/2021	8	1,152	144
PLANNED	8/2/2021	3	432	144
PLANNED	8/2/2021	1	34	34
PLANNED	8/2/2021	10	680	68
PLANNED	8/2/2021	3	123	41
PLANNED	8/2/2021	4	116	29
PLANNED	8/2/2021	8	880	110
PLANNED	8/2/2021	5	340	68
PLANNED	8/2/2021	3	18	6
PLANNED	8/2/2021	6	456	76
PLANNED	8/2/2021	2	48	24
PLANNED	8/2/2021	3	15	5
PLANNED	8/2/2021	1	23	23
PLANNED	8/2/2021	8	792	99
PLANNED	8/2/2021	9	576	64
PLANNED	8/2/2021	5	105	21
PLANNED	8/2/2021	4	408	102
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	1	86	86
PLANNED	8/2/2021	8	88	11
PLANNED	8/2/2021	9	693	77
PLANNED	8/2/2021	4	16	4
PLANNED	8/2/2021	3	12	4
PLANNED	8/2/2021	3	51	17
PLANNED	8/2/2021	1	8	8
PLANNED	8/2/2021	1	5	5
PLANNED	8/2/2021	1	148	148
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	4	92	23
PLANNED	8/2/2021	3	18	6
CUSTOMER REQUEST	8/2/2021	1	129	129
PLANNED	8/2/2021	6	114	19
PLANNED	8/2/2021	3	582	194
PLANNED	8/2/2021	1	22	22
PLANNED	8/2/2021	3	105	35
PLANNED	8/2/2021	3	72	24
PLANNED	8/2/2021	3	3	1

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/2/2021	32	7,968	249
PLANNED	8/2/2021	4	36	9
PLANNED	8/2/2021	7	665	95
PLANNED	8/2/2021	1	230	230
PLANNED	8/2/2021	2	252	126
PLANNED	8/2/2021	1	5	5
PLANNED	8/2/2021	2	10	5
PLANNED	8/2/2021	3	12	4
PLANNED	8/2/2021	4	28	7
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	2	86	43
PLANNED	8/2/2021	3	39	13
PLANNED	8/2/2021	2	228	114
PLANNED	8/2/2021	1	60	60
PLANNED	8/2/2021	5	115	23
PLANNED	8/2/2021	3	309	103
PLANNED	8/2/2021	10	840	84
PLANNED	8/2/2021	12	864	72
PLANNED	8/2/2021	10	670	67
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	3	27	9
PLANNED	8/2/2021	2	14	7
PLANNED	8/2/2021	4	260	65
PLANNED	8/2/2021	2	156	78
PLANNED	8/2/2021	1	12	12
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	4	84	21
PLANNED	8/2/2021	8	736	92
PLANNED	8/2/2021	4	20	5
PLANNED	8/2/2021	5	1,335	267
PLANNED	8/2/2021	4	56	14
PLANNED	8/2/2021	1	13	13
PLANNED	8/2/2021	2	256	128
PLANNED	8/2/2021	5	125	25
PLANNED	8/2/2021	1	259	259
PLANNED	8/2/2021	5	440	88
PLANNED	8/2/2021	2	14	7
PLANNED	8/2/2021	4	24	6
PLANNED	8/2/2021	2	36	18
PLANNED	8/2/2021	6	36	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/2/2021	1	66	66
PLANNED	8/2/2021	4	32	8
PLANNED	8/2/2021	2	134	67
PLANNED	8/2/2021	1	76	76
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	1	68	68
PLANNED	8/2/2021	2	26	13
PLANNED	8/2/2021	2	348	174
PLANNED	8/2/2021	2	16	8
PLANNED	8/2/2021	2	58	29
PLANNED	8/2/2021	4	24	6
PLANNED	8/2/2021	1	17	17
PLANNED	8/2/2021	3	423	141
PLANNED	8/2/2021	2	22	11
PLANNED	8/2/2021	3	15	5
PLANNED	8/2/2021	2	14	7
PLANNED	8/2/2021	4	68	17
PLANNED	8/2/2021	4	704	176
PLANNED	8/2/2021	3	15	5
PLANNED	8/2/2021	3	12	4
PLANNED	8/2/2021	10	30	3
PLANNED	8/2/2021	4	44	11
PLANNED	8/2/2021	3	186	62
PLANNED	8/2/2021	9	693	77
PLANNED	8/2/2021	1	6	6
PLANNED	8/2/2021	3	483	161
PLANNED	8/2/2021	2	18	9
PLANNED	8/2/2021	2	16	8
PLANNED	8/2/2021	2	60	30
PLANNED	8/2/2021	1	13	13
PLANNED	8/2/2021	3	18	6
PLANNED	8/2/2021	5	30	6
PLANNED	8/2/2021	4	28	7
PLANNED	8/2/2021	3	18	6
PLANNED	8/2/2021	1	11	11
PLANNED	8/2/2021	3	24	8
PLANNED	8/2/2021	3	18	6
PLANNED	8/2/2021	2	92	46
PLANNED	8/2/2021	5	30	6
PLANNED	8/2/2021	3	15	5
PLANNED	8/2/2021	4	544	136

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/2/2021	5	170	34
PLANNED	8/2/2021	1	100	100
PLANNED	8/2/2021	1	8	8
PLANNED	8/2/2021	3	93	31
PLANNED	8/2/2021	13	936	72
PLANNED	8/2/2021	8	1,232	154
PLANNED	8/2/2021	2	24	12
PLANNED	8/2/2021	2	158	79
PLANNED	8/2/2021	1	5	5
PLANNED	8/2/2021	12	1,788	149
PLANNED	8/2/2021	1	16	16
PLANNED	8/2/2021	16	176	11
PLANNED	8/2/2021	2	14	7
CUSTOMER REQUEST	8/2/2021	1	253	253
PLANNED	8/2/2021	3	51	17
PLANNED	8/2/2021	44	1,056	24
PLANNED	8/2/2021	3	69	23
PLANNED	8/2/2021	4	140	35
PLANNED	8/2/2021	4	680	170
PLANNED	8/2/2021	2	20	10
PLANNED	8/2/2021	2	302	151
PLANNED	8/2/2021	1	147	147
PLANNED	8/2/2021	2	90	45
PLANNED	8/2/2021	1	6	6
PLANNED	8/2/2021	10	1,030	103
PLANNED	8/2/2021	1	14	14
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	2	16	8
PLANNED	8/2/2021	1	6	6
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	2	14	7
PLANNED	8/2/2021	2	96	48
PLANNED	8/2/2021	2	16	8
PLANNED	8/2/2021	2	156	78
PLANNED	8/2/2021	11	418	38
PLANNED	8/2/2021	2	490	245
PLANNED	8/2/2021	1	91	91
PLANNED	8/2/2021	4	52	13
PLANNED	8/2/2021	1	10	10
PLANNED	8/2/2021	1	18	18
PLANNED	8/2/2021	3	21	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/2/2021	3	327	109
PLANNED	8/2/2021	1	61	61
PLANNED	8/2/2021	1	7	7
PLANNED	8/2/2021	1	36	36
PLANNED	8/2/2021	10	10	1
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	3	270	90
PLANNED	8/2/2021	6	282	47
PLANNED	8/2/2021	4	88	22
PLANNED	8/2/2021	3	12	4
PLANNED	8/2/2021	4	80	20
PLANNED	8/2/2021	3	24	8
PLANNED	8/2/2021	3	36	12
PLANNED	8/2/2021	2	8	4
PLANNED	8/2/2021	4	88	22
PLANNED	8/2/2021	2	12	6
PLANNED	8/2/2021	1	25	25
PLANNED	8/2/2021	2	96	48
PLANNED	8/2/2021	1	26	26
PLANNED	8/2/2021	3	21	7
PLANNED	8/2/2021	2	20	10
PLANNED	8/2/2021	2	270	135
PLANNED	8/2/2021	3	417	139
PLANNED	8/2/2021	3	3	1
PLANNED	8/2/2021	5	145	29
PLANNED	8/2/2021	4	48	12
CUSTOMER REQUEST	8/2/2021	1	120	120
CUSTOMER REQUEST	8/2/2021	1	251	251
PLANNED	8/2/2021	7	1,540	220
PLANNED	8/2/2021	1	22	22
PLANNED	8/2/2021	1	69	69
PLANNED	8/2/2021	11	836	76
PLANNED	8/2/2021	2	68	34
PLANNED	8/2/2021	15	30	2
PLANNED	8/2/2021	17	51	3
PLANNED	8/2/2021	3	105	35
PLANNED	8/2/2021	18	414	23
PLANNED	8/2/2021	1	54	54
PLANNED	8/2/2021	1	21	21
PLANNED	8/2/2021	1	44	44
PLANNED	8/2/2021	1	40	40

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/2/2021	4	584	146
PLANNED	8/2/2021	1	289	289
PLANNED	8/3/2021	19	2,641	139
PLANNED	8/3/2021	1	75	75
CUSTOMER REQUEST	8/3/2021	36	25,560	710
PLANNED	8/3/2021	4	288	72
PLANNED	8/3/2021	3	21	7
PLANNED	8/3/2021	4	28	7
PLANNED	8/3/2021	1	5	5
PLANNED	8/3/2021	2	20	10
PLANNED	8/3/2021	6	462	77
PLANNED	8/3/2021	6	24	4
PLANNED	8/3/2021	3	21	7
PLANNED	8/3/2021	4	156	39
PLANNED	8/3/2021	6	557	340
PLANNED	8/3/2021	3	117	39
PLANNED	8/3/2021	34	4,182	123
PLANNED	8/3/2021	5	35	7
PLANNED	8/3/2021	4	20	5
PLANNED	8/3/2021	5	35	7
PLANNED	8/3/2021	5	30	6
PLANNED	8/3/2021	3	18	6
PLANNED	8/3/2021	8	512	64
PLANNED	8/3/2021	1	34	34
PLANNED	8/3/2021	8	536	67
PLANNED	8/3/2021	5	670	134
PLANNED	8/3/2021	29	1,624	56
PLANNED	8/3/2021	4	44	11
PLANNED	8/3/2021	3	942	314
PLANNED	8/3/2021	6	1,014	169
PLANNED	8/3/2021	1	11	11
PLANNED	8/3/2021	7	154	22
PLANNED	8/3/2021	1	12	12
PLANNED	8/3/2021	4	96	24
PLANNED	8/3/2021	2	82	41
PLANNED	8/3/2021	1	60	60
CUSTOMER REQUEST	8/3/2021	1	197	197
PLANNED	8/3/2021	1	119	119
PLANNED	8/3/2021	32	480	15
PLANNED	8/3/2021	5	155	31
PLANNED	8/3/2021	1	264	264

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/3/2021	2	304	152
PLANNED	8/3/2021	1	304	304
PLANNED	8/3/2021	2	8	4
PLANNED	8/3/2021	1	67	67
PLANNED	8/3/2021	8	384	48
PLANNED	8/3/2021	4	1,144	286
PLANNED	8/3/2021	2	464	232
PLANNED	8/3/2021	26	2,244	121
PLANNED	8/3/2021	1	5	5
PLANNED	8/3/2021	6	648	108
PLANNED	8/3/2021	2	119	64
PLANNED	8/3/2021	3	510	170
PLANNED	8/3/2021	3	291	97
PLANNED	8/3/2021	8	625	140
PLANNED	8/3/2021	5	465	93
PLANNED	8/3/2021	1	15	15
PLANNED	8/3/2021	4	80	20
PLANNED	8/3/2021	1	8	8
PLANNED	8/3/2021	1	6	6
PLANNED	8/3/2021	10	670	67
PLANNED	8/3/2021	13	39	3
PLANNED	8/3/2021	2	56	28
PLANNED	8/3/2021	2	130	65
PLANNED	8/3/2021	2	110	56
PLANNED	8/3/2021	2	75	46
PLANNED	8/3/2021	5	755	151
PLANNED	8/3/2021	4	76	19
PLANNED	8/3/2021	4	168	42
PLANNED	8/3/2021	1	40	40
PLANNED	8/3/2021	32	1,760	55
PLANNED	8/3/2021	7	854	122
PLANNED	8/3/2021	6	486	81
PLANNED	8/3/2021	8	976	122
PLANNED	8/3/2021	3	90	30
PLANNED	8/3/2021	1	10	10
PLANNED	8/3/2021	1	34	34
PLANNED	8/3/2021	81	7,857	97
PLANNED	8/3/2021	8	80	10
PLANNED	8/3/2021	7	343	49
PLANNED	8/3/2021	8	160	20
PLANNED	8/3/2021	26	2,236	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/3/2021	25	7,275	291
PLANNED	8/3/2021	4	64	16
PLANNED	8/3/2021	28	2,408	86
PLANNED	8/3/2021	8	680	85
PLANNED	8/3/2021	1	111	111
PLANNED	8/3/2021	23	1,978	86
PLANNED	8/3/2021	24	2,064	86
PLANNED	8/3/2021	24	2,064	86
PLANNED	8/3/2021	25	2,175	87
PLANNED	8/3/2021	1	186	186
PLANNED	8/3/2021	1	69	69
PLANNED	8/3/2021	2	125	70
PLANNED	8/3/2021	12	132	11
PLANNED	8/3/2021	1	5	5
PLANNED	8/3/2021	4	60	15
PLANNED	8/3/2021	9	675	75
PLANNED	8/3/2021	2	316	158
PLANNED	8/3/2021	2	78	39
PLANNED	8/3/2021	2	102	51
PLANNED	8/3/2021	4	380	95
PLANNED	8/3/2021	12	2,162	193
PLANNED	8/3/2021	2	124	62
PLANNED	8/3/2021	10	340	34
PLANNED	8/3/2021	2	104	52
PLANNED	8/3/2021	5	165	33
PLANNED	8/3/2021	1	278	278
PLANNED	8/3/2021	6	234	39
PLANNED	8/3/2021	1	23	23
PLANNED	8/3/2021	7	91	13
PLANNED	8/3/2021	9	1,170	130
PLANNED	8/3/2021	8	696	87
PLANNED	8/3/2021	1	275	275
PLANNED	8/3/2021	2	136	68
PLANNED	8/3/2021	8	280	35
PLANNED	8/3/2021	5	70	14
PLANNED	8/3/2021	1	8	8
PLANNED	8/3/2021	1	11	11
PLANNED	8/3/2021	4	64	16
PLANNED	8/3/2021	4	84	21
PLANNED	8/3/2021	17	680	40
PLANNED	8/3/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/3/2021	138	32,154	233
PLANNED	8/3/2021	1	50	50
PLANNED	8/3/2021	1	17	17
PLANNED	8/3/2021	1	9	9
PLANNED	8/3/2021	4	28	7
PLANNED	8/3/2021	4	68	17
PLANNED	8/3/2021	8	320	40
PLANNED	8/3/2021	5	165	33
PLANNED	8/3/2021	5	110	22
PLANNED	8/3/2021	1	8	8
CUSTOMER REQUEST	8/3/2021	1	347	347
PLANNED	8/3/2021	8	624	78
PLANNED	8/3/2021	4	72	18
PLANNED	8/3/2021	6	234	39
PLANNED	8/3/2021	10	480	48
PLANNED	8/3/2021	1	20	20
PLANNED	8/3/2021	1	6	6
PLANNED	8/3/2021	9	18	2
CUSTOMER REQUEST	8/3/2021	1	105	105
CUSTOMER REQUEST	8/3/2021	6	30	5
PLANNED	8/3/2021	1	5	5
PLANNED	8/3/2021	41	2,173	53
PLANNED	8/3/2021	2	34	17
PLANNED	8/3/2021	1	99	99
PLANNED	8/3/2021	2	62	31
CUSTOMER REQUEST	8/3/2021	1	33	33
CUSTOMER REQUEST	8/3/2021	1	156	156
CUSTOMER REQUEST	8/3/2021	69	3,657	53
PLANNED	8/3/2021	1	180	180
CUSTOMER REQUEST	8/3/2021	1,049	134,004	145
CUSTOMER REQUEST	8/3/2021	3	87	29
PLANNED	8/3/2021	9	4,275	475
PLANNED	8/3/2021	6	3,492	582
CUSTOMER REQUEST	8/4/2021	4	444	111
PLANNED	8/4/2021	10	470	47
PLANNED	8/4/2021	4	104	26
PLANNED	8/4/2021	5	165	33
PLANNED	8/4/2021	7	168	24
PLANNED	8/4/2021	2	8	4
PLANNED	8/4/2021	5	175	35
PLANNED	8/4/2021	4	112	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/4/2021	9	531	59
PLANNED	8/4/2021	7	266	38
PLANNED	8/4/2021	5	100	20
PLANNED	8/4/2021	2	8	4
PLANNED	8/4/2021	1	89	89
PLANNED	8/4/2021	5	535	107
PLANNED	8/4/2021	3	185	67
PLANNED	8/4/2021	4	20	5
PLANNED	8/4/2021	1	180	180
PLANNED	8/4/2021	4	328	82
PLANNED	8/4/2021	4	24	6
PLANNED	8/4/2021	1	171	171
PLANNED	8/4/2021	7	1,554	222
PLANNED	8/4/2021	3	24	8
PLANNED	8/4/2021	4	36	9
PLANNED	8/4/2021	3	18	6
PLANNED	8/4/2021	6	36	6
PLANNED	8/4/2021	15	1,395	93
PLANNED	8/4/2021	10	900	90
PLANNED	8/4/2021	16	160	10
PLANNED	8/4/2021	5	620	124
PLANNED	8/4/2021	5	560	112
PLANNED	8/4/2021	2	30	15
PLANNED	8/4/2021	2	22	11
PLANNED	8/4/2021	1	135	135
PLANNED	8/4/2021	6	492	82
PLANNED	8/4/2021	1	21	21
PLANNED	8/4/2021	2	8	4
PLANNED	8/4/2021	13	247	19
PLANNED	8/4/2021	1	48	48
PLANNED	8/4/2021	4	280	70
PLANNED	8/4/2021	42	862	92
PLANNED	8/4/2021	6	48	8
PLANNED	8/4/2021	2	118	59
PLANNED	8/4/2021	1	253	253
PLANNED	8/4/2021	4	64	16
PLANNED	8/4/2021	5	5	1
PLANNED	8/4/2021	2	10	5
PLANNED	8/4/2021	1	25	25
PLANNED	8/4/2021	2	100	50
PLANNED	8/4/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/4/2021	2	22	11
PLANNED	8/4/2021	1	8	8
PLANNED	8/4/2021	4	92	23
PLANNED	8/4/2021	2	14	7
PLANNED	8/4/2021	4	148	37
PLANNED	8/4/2021	2	64	32
PLANNED	8/4/2021	1	5	5
PLANNED	8/4/2021	4	44	11
PLANNED	8/4/2021	9	423	47
PLANNED	8/4/2021	3	15	5
PLANNED	8/4/2021	9	270	30
PLANNED	8/4/2021	6	534	89
PLANNED	8/4/2021	4	352	88
PLANNED	8/4/2021	8	8	1
PLANNED	8/4/2021	6	546	91
PLANNED	8/4/2021	6	54	9
PLANNED	8/4/2021	2	54	27
PLANNED	8/4/2021	2	46	23
CUSTOMER REQUEST	8/4/2021	13	1,444	236
PLANNED	8/4/2021	19	532	28
PLANNED	8/4/2021	3	153	51
PLANNED	8/4/2021	2	26	13
PLANNED	8/4/2021	3	42	14
PLANNED	8/4/2021	2	8	4
PLANNED	8/4/2021	4	104	26
PLANNED	8/4/2021	1	4	4
PLANNED	8/4/2021	1	5	5
PLANNED	8/4/2021	5	120	24
PLANNED	8/4/2021	6	66	11
PLANNED	8/4/2021	2	18	9
PLANNED	8/4/2021	6	42	7
PLANNED	8/4/2021	3	24	8
PLANNED	8/4/2021	2	30	15
PLANNED	8/4/2021	2	14	7
PLANNED	8/4/2021	2	12	6
PLANNED	8/4/2021	10	480	48
PLANNED	8/4/2021	2	6	3
PLANNED	8/4/2021	2	272	136
PLANNED	8/4/2021	8	872	109
PLANNED	8/4/2021	1	5	5
PLANNED	8/4/2021	5	85	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/4/2021	4	60	15
PLANNED	8/4/2021	1	61	61
PLANNED	8/4/2021	1	4	4
PLANNED	8/4/2021	3	87	29
PLANNED	8/4/2021	1	7	7
PLANNED	8/4/2021	3	117	39
PLANNED	8/4/2021	3	12	4
PLANNED	8/4/2021	3	36	12
PLANNED	8/4/2021	2	66	33
PLANNED	8/4/2021	2	74	37
PLANNED	8/4/2021	1	8	8
PLANNED	8/4/2021	2	12	6
PLANNED	8/4/2021	2	10	5
PLANNED	8/4/2021	1	27	27
PLANNED	8/4/2021	2	14	7
PLANNED	8/4/2021	2	14	7
PLANNED	8/4/2021	3	21	7
PLANNED	8/4/2021	2	6	3
PLANNED	8/4/2021	52	3,679	79
PLANNED	8/4/2021	3	30	10
PLANNED	8/4/2021	4	48	12
PLANNED	8/4/2021	3	45	15
PLANNED	8/4/2021	3	33	11
PLANNED	8/4/2021	4	92	23
PLANNED	8/4/2021	5	20	4
PLANNED	8/4/2021	4	36	9
PLANNED	8/4/2021	3	18	6
PLANNED	8/4/2021	2	12	6
PLANNED	8/4/2021	2	50	25
CUSTOMER REQUEST	8/4/2021	1	169	169
PLANNED	8/4/2021	3	45	15
PLANNED	8/4/2021	18	396	22
PLANNED	8/4/2021	4	100	25
PLANNED	8/4/2021	9	72	8
PLANNED	8/4/2021	1	36	36
PLANNED	8/4/2021	2	22	11
PLANNED	8/4/2021	12	204	17
PLANNED	8/4/2021	7	105	15
PLANNED	8/4/2021	3	27	9
PLANNED	8/4/2021	5	55	11
PLANNED	8/4/2021	1	164	164

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	8/4/2021	1	120	120
PLANNED	8/4/2021	2	208	104
PLANNED	8/4/2021	5	395	79
CUSTOMER REQUEST	8/4/2021	8	304	38
PLANNED	8/4/2021	11	660	60
PLANNED	8/4/2021	4	172	43
PLANNED	8/4/2021	6	30	5
PLANNED	8/4/2021	1	189	189
PLANNED	8/4/2021	12	185	53
PLANNED	8/4/2021	15	555	37
PLANNED	8/4/2021	35	350	10
PLANNED	8/4/2021	2	154	77
PLANNED	8/4/2021	2	210	105
PLANNED	8/4/2021	1	70	70
CUSTOMER REQUEST	8/4/2021	1	181	181
PLANNED	8/4/2021	4	740	185
PLANNED	8/4/2021	11	407	37
PLANNED	8/4/2021	1	39	39
PLANNED	8/4/2021	3	687	229
PLANNED	8/4/2021	1	222	222
PLANNED	8/5/2021	5	410	82
PLANNED	8/5/2021	203	28,420	140
PLANNED	8/5/2021	4	52	13
PLANNED	8/5/2021	5	190	38
PLANNED	8/5/2021	3	231	77
PLANNED	8/5/2021	9	612	68
PLANNED	8/5/2021	1	9	9
PLANNED	8/5/2021	2	64	32
PLANNED	8/5/2021	6	715	170
PLANNED	8/5/2021	2	12	6
PLANNED	8/5/2021	3	33	11
PLANNED	8/5/2021	1	5	5
PLANNED	8/5/2021	3	18	6
PLANNED	8/5/2021	10	1,220	122
PLANNED	8/5/2021	2	10	5
PLANNED	8/5/2021	1	44	44
PLANNED	8/5/2021	2	188	94
PLANNED	8/5/2021	3	56	23
PLANNED	8/5/2021	1	233	233
CUSTOMER REQUEST	8/5/2021	4	92	23
PLANNED	8/5/2021	2	10	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/5/2021	3	261	87
PLANNED	8/5/2021	2	220	110
CUSTOMER REQUEST	8/5/2021	6	36	6
PLANNED	8/5/2021	2	102	51
PLANNED	8/5/2021	4	92	23
CUSTOMER REQUEST	8/5/2021	12	9,672	806
PLANNED	8/5/2021	6	810	135
PLANNED	8/5/2021	1	4	4
PLANNED	8/5/2021	3	60	20
PLANNED	8/5/2021	2	123	75
PLANNED	8/5/2021	1	7	7
PLANNED	8/5/2021	2	12	6
PLANNED	8/5/2021	54	14,958	277
PLANNED	8/5/2021	8	1,784	223
PLANNED	8/5/2021	15	2,025	135
PLANNED	8/5/2021	2	110	55
PLANNED	8/5/2021	23	3,588	156
PLANNED	8/5/2021	6	138	23
PLANNED	8/5/2021	1	176	176
PLANNED	8/5/2021	1	98	98
PLANNED	8/5/2021	1	4	4
PLANNED	8/5/2021	2	430	215
PLANNED	8/5/2021	2	12	6
PLANNED	8/5/2021	3	30	10
PLANNED	8/5/2021	1	73	73
CUSTOMER REQUEST	8/5/2021	1	9	9
PLANNED	8/5/2021	2	20	10
PLANNED	8/5/2021	5	140	28
PLANNED	8/5/2021	2	8	4
PLANNED	8/5/2021	3	375	125
PLANNED	8/5/2021	6	294	49
PLANNED	8/5/2021	7	385	55
PLANNED	8/5/2021	2	251	164
PLANNED	8/5/2021	6	1,314	219
PLANNED	8/5/2021	8	232	29
PLANNED	8/5/2021	2	18	9
PLANNED	8/5/2021	2	10	5
PLANNED	8/5/2021	4	144	36
PLANNED	8/5/2021	12	648	54
PLANNED	8/5/2021	2	236	118
PLANNED	8/5/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/5/2021	6	30	5
PLANNED	8/5/2021	3	126	42
PLANNED	8/5/2021	15	2,550	170
PLANNED	8/5/2021	2	10	5
PLANNED	8/5/2021	1	90	90
CUSTOMER REQUEST	8/5/2021	31	34,490	1,820
PLANNED	8/5/2021	1	170	170
PLANNED	8/5/2021	2	278	139
PLANNED	8/5/2021	3	45	15
PLANNED	8/5/2021	4	116	29
PLANNED	8/5/2021	1	4	4
PLANNED	8/5/2021	2	160	80
PLANNED	8/5/2021	2	14	7
PLANNED	8/5/2021	4	16	4
PLANNED	8/5/2021	6	42	7
CUSTOMER REQUEST	8/5/2021	4	368	92
PLANNED	8/5/2021	1	19	19
PLANNED	8/5/2021	4	1,124	281
PLANNED	8/5/2021	1	107	107
PLANNED	8/5/2021	2	12	6
PLANNED	8/5/2021	3	57	19
PLANNED	8/5/2021	8	376	47
PLANNED	8/5/2021	2	16	8
PLANNED	8/5/2021	5	815	163
PLANNED	8/5/2021	7	1,092	156
PLANNED	8/5/2021	6	906	151
PLANNED	8/5/2021	3	222	74
PLANNED	8/5/2021	9	1,314	146
PLANNED	8/5/2021	1	4	4
PLANNED	8/5/2021	1	162	162
PLANNED	8/5/2021	3	24	8
PLANNED	8/5/2021	4	80	20
PLANNED	8/5/2021	7	238	34
PLANNED	8/5/2021	6	288	48
PLANNED	8/5/2021	4	384	96
PLANNED	8/5/2021	13	4,914	378
PLANNED	8/5/2021	2	174	87
PLANNED	8/5/2021	3	15	5
PLANNED	8/5/2021	8	1,336	167
PLANNED	8/5/2021	12	12	1
PLANNED	8/5/2021	3	39	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/5/2021	33	8,019	243
CUSTOMER REQUEST	8/5/2021	6	42	7
PLANNED	8/5/2021	7	1,498	214
PLANNED	8/5/2021	4	396	99
PLANNED	8/5/2021	16	432	27
PLANNED	8/5/2021	2	24	12
PLANNED	8/5/2021	1	4	4
CUSTOMER REQUEST	8/5/2021	2	22	11
PLANNED	8/5/2021	6	42	7
PLANNED	8/5/2021	3	12	4
PLANNED	8/5/2021	21	105	5
PLANNED	8/5/2021	1	18	18
PLANNED	8/5/2021	2	10	5
PLANNED	8/5/2021	2	34	17
PLANNED	8/5/2021	3	33	11
PLANNED	8/5/2021	16	80	5
PLANNED	8/5/2021	2	10	5
PLANNED	8/5/2021	3	693	231
PLANNED	8/5/2021	6	222	37
PLANNED	8/5/2021	8	80	10
PLANNED	8/5/2021	1	66	66
PLANNED	8/5/2021	4	1,268	317
PLANNED	8/5/2021	2	20	10
PLANNED	8/5/2021	16	3,824	239
PLANNED	8/5/2021	2	150	75
PLANNED	8/5/2021	1	106	106
PLANNED	8/5/2021	3	39	13
PLANNED	8/5/2021	5	135	27
PLANNED	8/5/2021	2	30	15
PLANNED	8/5/2021	25	2,250	90
PLANNED	8/5/2021	9	387	43
PLANNED	8/5/2021	5	850	170
PLANNED	8/5/2021	2	240	120
PLANNED	8/5/2021	3	873	291
PLANNED	8/5/2021	1	32	32
PLANNED	8/5/2021	3	36	12
PLANNED	8/5/2021	3	69	23
PLANNED	8/5/2021	1	28	28
PLANNED	8/5/2021	3	60	24
PLANNED	8/5/2021	2	180	90
PLANNED	8/5/2021	10	220	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/5/2021	4	316	79
PLANNED	8/5/2021	4	68	17
PLANNED	8/5/2021	3	42	14
PLANNED	8/5/2021	5	70	14
PLANNED	8/5/2021	1	70	70
PLANNED	8/5/2021	2	106	53
PLANNED	8/5/2021	9	162	18
PLANNED	8/5/2021	2	2	1
PLANNED	8/5/2021	3	48	16
PLANNED	8/5/2021	3	201	67
PLANNED	8/5/2021	12	1,476	123
PLANNED	8/5/2021	4	164	41
CUSTOMER REQUEST	8/5/2021	1	236	236
PLANNED	8/5/2021	2	276	138
PLANNED	8/5/2021	9	1,422	158
PLANNED	8/5/2021	1	69	69
PLANNED	8/5/2021	3	204	68
PLANNED	8/5/2021	11	220	20
PLANNED	8/5/2021	3	159	53
PLANNED	8/5/2021	4	88	22
PLANNED	8/5/2021	18	126	7
PLANNED	8/5/2021	12	1,416	118
PLANNED	8/5/2021	7	35	5
PLANNED	8/5/2021	2	204	102
PLANNED	8/5/2021	4	28	7
PLANNED	8/5/2021	1	23	23
PLANNED	8/5/2021	4	28	7
PLANNED	8/5/2021	5	550	110
PLANNED	8/5/2021	2	394	197
PLANNED	8/5/2021	1	52	52
PLANNED	8/5/2021	3	39	13
PLANNED	8/5/2021	2	182	91
PLANNED	8/5/2021	1	80	80
PLANNED	8/5/2021	5	180	36
CUSTOMER REQUEST	8/5/2021	15	315	21
CUSTOMER REQUEST	8/5/2021	1	301	301
PLANNED	8/5/2021	8	88	11
PLANNED	8/5/2021	13	3,536	272
PLANNED	8/5/2021	1	367	367
CUSTOMER REQUEST	8/5/2021	1	839	839
PLANNED	8/5/2021	9	252	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/5/2021	1	292	292
PLANNED	8/5/2021	3	81	27
PLANNED	8/5/2021	5	1,505	301
PLANNED	8/6/2021	25	2,350	94
PLANNED	8/6/2021	5	680	136
PLANNED	8/6/2021	11	891	81
PLANNED	8/6/2021	3	168	56
PLANNED	8/6/2021	1	52	52
PLANNED	8/6/2021	27	2,835	105
PLANNED	8/6/2021	8	1,408	176
PLANNED	8/6/2021	3	24	8
PLANNED	8/6/2021	2	8	4
PLANNED	8/6/2021	1	7	7
PLANNED	8/6/2021	2	14	7
PLANNED	8/6/2021	2	12	6
PLANNED	8/6/2021	4	100	25
PLANNED	8/6/2021	1	4	4
PLANNED	8/6/2021	1	154	154
PLANNED	8/6/2021	4	1,160	290
PLANNED	8/6/2021	1	7	7
PLANNED	8/6/2021	3	33	11
PLANNED	8/6/2021	2	176	88
PLANNED	8/6/2021	2	120	60
PLANNED	8/6/2021	1	5	5
PLANNED	8/6/2021	4	432	108
PLANNED	8/6/2021	5	245	49
PLANNED	8/6/2021	3	258	86
PLANNED	8/6/2021	4	292	73
PLANNED	8/6/2021	6	702	117
CUSTOMER REQUEST	8/6/2021	1	100	100
PLANNED	8/6/2021	2	16	8
PLANNED	8/6/2021	13	6,552	504
PLANNED	8/6/2021	33	7,029	213
PLANNED	8/6/2021	30	5,670	189
PLANNED	8/6/2021	1	6	6
PLANNED	8/6/2021	5	370	74
CUSTOMER REQUEST	8/6/2021	1	37	37
PLANNED	8/6/2021	4	340	85
PLANNED	8/6/2021	2	600	300
PLANNED	8/6/2021	1	21	21
PLANNED	8/6/2021	1	4	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/6/2021	1	24	24
PLANNED	8/6/2021	19	5,073	267
PLANNED	8/6/2021	5	180	36
PLANNED	8/6/2021	1	271	271
PLANNED	8/6/2021	3	57	19
PLANNED	8/6/2021	2	356	178
PLANNED	8/6/2021	1	94	94
PLANNED	8/6/2021	1	4	4
PLANNED	8/6/2021	6	576	96
PLANNED	8/6/2021	2	168	84
PLANNED	8/6/2021	4	256	64
PLANNED	8/6/2021	5	175	35
PLANNED	8/6/2021	1	12	12
PLANNED	8/6/2021	6	906	151
PLANNED	8/6/2021	2	26	13
PLANNED	8/6/2021	1	64	64
PLANNED	8/6/2021	3	258	86
PLANNED	8/6/2021	5	705	141
PLANNED	8/6/2021	2	162	81
PLANNED	8/6/2021	1	5	5
PLANNED	8/6/2021	8	2,640	330
PLANNED	8/6/2021	1	6	6
PLANNED	8/6/2021	5	30	6
PLANNED	8/6/2021	2	12	6
PLANNED	8/6/2021	1	160	160
PLANNED	8/6/2021	3	15	5
PLANNED	8/6/2021	2	8	4
PLANNED	8/6/2021	3	180	60
CUSTOMER REQUEST	8/6/2021	3	12	4
PLANNED	8/6/2021	2	70	35
PLANNED	8/6/2021	3	18	6
PLANNED	8/6/2021	2	298	149
PLANNED	8/6/2021	1	74	74
PLANNED	8/6/2021	5	30	6
PLANNED	8/6/2021	1	231	231
PLANNED	8/6/2021	1	183	183
PLANNED	8/6/2021	4	36	9
PLANNED	8/6/2021	3	180	60
PLANNED	8/6/2021	7	91	13
PLANNED	8/6/2021	2	24	12
PLANNED	8/6/2021	4	128	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/6/2021	11	1,221	111
PLANNED	8/6/2021	1	7	7
PLANNED	8/6/2021	2	340	170
PLANNED	8/6/2021	2	526	263
PLANNED	8/6/2021	26	416	16
PLANNED	8/6/2021	2	90	45
PLANNED	8/6/2021	2	24	12
PLANNED	8/6/2021	4	44	11
PLANNED	8/6/2021	33	5,115	155
PLANNED	8/6/2021	2	10	5
PLANNED	8/6/2021	4	24	6
PLANNED	8/6/2021	1	92	92
PLANNED	8/6/2021	3	345	115
PLANNED	8/6/2021	2	12	6
PLANNED	8/6/2021	1	77	77
PLANNED	8/6/2021	1	5	5
PLANNED	8/6/2021	2	76	38
PLANNED	8/6/2021	9	576	64
PLANNED	8/6/2021	58	2,204	38
PLANNED	8/6/2021	8	320	40
PLANNED	8/6/2021	9	1,350	150
PLANNED	8/6/2021	3	36	12
PLANNED	8/6/2021	4	76	19
PLANNED	8/6/2021	12	504	42
PLANNED	8/6/2021	6	1,650	404
PLANNED	8/6/2021	3	3	1
PLANNED	8/6/2021	3	21	7
PLANNED	8/6/2021	246	738	3
PLANNED	8/6/2021	8	1,688	211
PLANNED	8/6/2021	8	1,064	222
PLANNED	8/6/2021	2	12	6
PLANNED	8/6/2021	2	76	38
PLANNED	8/6/2021	9	167	73
PLANNED	8/6/2021	3	30	10
PLANNED	8/6/2021	23	667	29
PLANNED	8/6/2021	3	171	57
PLANNED	8/6/2021	3	96	32
PLANNED	8/6/2021	1	4	4
PLANNED	8/6/2021	1	37	37
PLANNED	8/6/2021	3	36	12
PLANNED	8/6/2021	3	144	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/6/2021	3	24	8
PLANNED	8/6/2021	6	162	27
PLANNED	8/6/2021	1	51	51
PLANNED	8/6/2021	3	36	12
PLANNED	8/6/2021	6	36	6
PLANNED	8/6/2021	10	40	4
PLANNED	8/6/2021	1	72	72
PLANNED	8/6/2021	3	30	10
PLANNED	8/6/2021	1	40	40
PLANNED	8/6/2021	2	28	14
PLANNED	8/6/2021	12	144	12
PLANNED	8/6/2021	4	636	159
PLANNED	8/6/2021	3	96	32
PLANNED	8/6/2021	10	1,590	159
PLANNED	8/7/2021	1	228	228
PLANNED	8/7/2021	1	43	43
PLANNED	8/7/2021	1	43	43
PLANNED	8/7/2021	1	137	137
CUSTOMER REQUEST	8/7/2021	1,265	109,054	149
PLANNED	8/7/2021	2	222	111
PLANNED	8/7/2021	7	770	110
PLANNED	8/7/2021	5	390	78
PLANNED	8/7/2021	4	344	86
PLANNED	8/7/2021	1	156	156
PLANNED	8/7/2021	1	7	7
PLANNED	8/7/2021	1	85	85
PLANNED	8/7/2021	2	212	106
PLANNED	8/7/2021	1	43	43
PLANNED	8/7/2021	8	200	25
PLANNED	8/7/2021	3	450	150
PLANNED	8/7/2021	12	1,440	120
PLANNED	8/7/2021	2	186	93
PLANNED	8/7/2021	1	392	392
PLANNED	8/7/2021	1	384	384
PLANNED	8/7/2021	1	357	357
PLANNED	8/8/2021	2	254	127
PLANNED	8/8/2021	3	417	139
PLANNED	8/8/2021	2	170	85
PLANNED	8/8/2021	2	156	78
PLANNED	8/8/2021	1	288	288
PLANNED	8/8/2021	2	600	300

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	8/8/2021	1	1,476	1,476
PLANNED	8/8/2021	12	1,428	119
PLANNED	8/8/2021	1	78	78
PLANNED	8/8/2021	1	97	97
PLANNED	8/8/2021	1	230	230
PLANNED	8/8/2021	4	920	230
PLANNED	8/8/2021	2	212	106
PLANNED	8/8/2021	2	192	96
PLANNED	8/8/2021	3	63	21
PLANNED	8/8/2021	3	417	139
PLANNED	8/8/2021	3	69	23
PLANNED	8/8/2021	1	5	5
PLANNED	8/8/2021	3	72	24
PLANNED	8/8/2021	4	1,516	379
PLANNED	8/9/2021	1	219	219
CUSTOMER REQUEST	8/9/2021	32	2,272	71
PLANNED	8/9/2021	1	155	155
PLANNED	8/9/2021	4	268	67
PLANNED	8/9/2021	3	339	113
PLANNED	8/9/2021	1	73	73
PLANNED	8/9/2021	3	222	74
PLANNED	8/9/2021	1	46	46
PLANNED	8/9/2021	2	46	23
PLANNED	8/9/2021	2	30	15
PLANNED	8/9/2021	6	30	5
PLANNED	8/9/2021	8	48	6
PLANNED	8/9/2021	6	2,526	421
PLANNED	8/9/2021	2	140	70
PLANNED	8/9/2021	5	330	66
PLANNED	8/9/2021	3	201	67
PLANNED	8/9/2021	3	396	132
PLANNED	8/9/2021	2	298	149
PLANNED	8/9/2021	3	924	308
PLANNED	8/9/2021	1	10	10
PLANNED	8/9/2021	3	57	19
PLANNED	8/9/2021	2	260	130
PLANNED	8/9/2021	4	704	176
PLANNED	8/9/2021	2	50	25
PLANNED	8/9/2021	2	352	176
PLANNED	8/9/2021	4	12	3
PLANNED	8/9/2021	11	330	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/9/2021	19	7,942	418
PLANNED	8/9/2021	2	12	6
PLANNED	8/9/2021	3	18	6
PLANNED	8/9/2021	1	5	5
PLANNED	8/9/2021	3	21	7
PLANNED	8/9/2021	3	15	5
PLANNED	8/9/2021	1	96	96
PLANNED	8/9/2021	6	762	127
PLANNED	8/9/2021	31	1,829	59
PLANNED	8/9/2021	4	652	163
PLANNED	8/9/2021	4	508	127
PLANNED	8/9/2021	2	128	64
PLANNED	8/9/2021	6	246	41
CUSTOMER REQUEST	8/9/2021	1	2	2
PLANNED	8/9/2021	1	119	119
PLANNED	8/9/2021	2	234	117
PLANNED	8/9/2021	4	16	4
PLANNED	8/9/2021	2	24	12
PLANNED	8/9/2021	1	6	6
PLANNED	8/9/2021	1	12	12
PLANNED	8/9/2021	12	216	18
PLANNED	8/9/2021	8	104	13
PLANNED	8/9/2021	1	76	76
PLANNED	8/9/2021	1	63	63
PLANNED	8/9/2021	13	1,027	79
PLANNED	8/9/2021	4	60	15
PLANNED	8/9/2021	2	18	9
PLANNED	8/9/2021	5	750	150
PLANNED	8/9/2021	3	27	9
PLANNED	8/9/2021	7	42	6
PLANNED	8/9/2021	1	8	8
PLANNED	8/9/2021	10	370	37
PLANNED	8/9/2021	2	184	92
PLANNED	8/9/2021	1	99	99
PLANNED	8/9/2021	4	84	21
PLANNED	8/9/2021	7	63	9
PLANNED	8/9/2021	4	56	14
PLANNED	8/9/2021	1	347	347
PLANNED	8/9/2021	5	200	40
PLANNED	8/9/2021	13	377	29
PLANNED	8/9/2021	4	20	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/9/2021	1	307	307
PLANNED	8/9/2021	7	497	71
PLANNED	8/9/2021	2	10	5
PLANNED	8/9/2021	1	6	6
PLANNED	8/9/2021	3	21	7
PLANNED	8/9/2021	1	25	25
PLANNED	8/9/2021	3	18	6
PLANNED	8/9/2021	2	12	6
PLANNED	8/9/2021	26	650	25
PLANNED	8/9/2021	3	60	20
PLANNED	8/9/2021	4	392	98
PLANNED	8/9/2021	1	8	8
PLANNED	8/9/2021	13	52	4
PLANNED	8/9/2021	3	150	50
PLANNED	8/9/2021	2	18	9
PLANNED	8/9/2021	10	1,420	142
PLANNED	8/9/2021	4	48	12
PLANNED	8/9/2021	3	135	45
PLANNED	8/9/2021	1	41	41
PLANNED	8/9/2021	3	48	16
PLANNED	8/9/2021	4	172	43
PLANNED	8/9/2021	3	27	9
PLANNED	8/9/2021	10	2,870	287
PLANNED	8/9/2021	7	231	33
PLANNED	8/9/2021	2	22	11
PLANNED	8/9/2021	4	44	11
PLANNED	8/9/2021	17	901	53
PLANNED	8/9/2021	4	116	29
PLANNED	8/9/2021	3	57	19
PLANNED	8/9/2021	11	110	10
PLANNED	8/9/2021	8	104	13
PLANNED	8/9/2021	5	75	15
PLANNED	8/9/2021	8	144	18
PLANNED	8/9/2021	7	84	12
PLANNED	8/9/2021	24	48	2
PLANNED	8/9/2021	6	54	9
PLANNED	8/9/2021	4	292	73
PLANNED	8/9/2021	13	2,093	161
PLANNED	8/9/2021	3	162	54
PLANNED	8/9/2021	2	14	7
PLANNED	8/9/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/9/2021	5	30	6
PLANNED	8/9/2021	6	36	6
PLANNED	8/9/2021	1	36	36
PLANNED	8/9/2021	1	6	6
PLANNED	8/9/2021	4	48	12
PLANNED	8/9/2021	2	90	45
PLANNED	8/9/2021	2	18	9
PLANNED	8/9/2021	1	114	114
PLANNED	8/9/2021	6	234	39
PLANNED	8/9/2021	5	50	10
PLANNED	8/9/2021	4	100	25
PLANNED	8/9/2021	1	8	8
PLANNED	8/9/2021	1	9	9
PLANNED	8/9/2021	1	12	12
PLANNED	8/9/2021	5	370	74
PLANNED	8/9/2021	3	294	98
PLANNED	8/9/2021	1	9	9
PLANNED	8/9/2021	1	94	94
PLANNED	8/9/2021	4	272	68
PLANNED	8/9/2021	1	9	9
PLANNED	8/9/2021	3	213	71
PLANNED	8/9/2021	7	2,191	313
PLANNED	8/9/2021	4	140	35
PLANNED	8/9/2021	4	468	117
PLANNED	8/9/2021	5	60	12
PLANNED	8/9/2021	4	124	31
PLANNED	8/9/2021	2	84	42
PLANNED	8/9/2021	5	1,050	210
PLANNED	8/9/2021	3	255	85
PLANNED	8/9/2021	7	875	125
PLANNED	8/9/2021	2	232	116
PLANNED	8/9/2021	3	165	55
PLANNED	8/9/2021	6	348	58
PLANNED	8/9/2021	2	118	59
PLANNED	8/9/2021	1	238	238
PLANNED	8/9/2021	13	2,093	161
PLANNED	8/9/2021	1	143	143
PLANNED	8/9/2021	3	282	94
PLANNED	8/9/2021	2	714	357
PLANNED	8/9/2021	2	200	100
PLANNED	8/9/2021	4	168	42

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/9/2021	8	728	91
PLANNED	8/9/2021	4	200	50
PLANNED	8/9/2021	2	58	29
PLANNED	8/9/2021	1	69	69
PLANNED	8/9/2021	9	126	29
PLANNED	8/9/2021	2	111	82
PLANNED	8/9/2021	2	86	43
PLANNED	8/9/2021	2	106	53
PLANNED	8/9/2021	6	732	122
PLANNED	8/9/2021	7	1,162	166
CUSTOMER REQUEST	8/9/2021	1	159	159
CUSTOMER REQUEST	8/9/2021	1	144	144
PLANNED	8/9/2021	4	116	29
PLANNED	8/9/2021	2	210	105
PLANNED	8/10/2021	3	555	185
PLANNED	8/10/2021	1	123	123
PLANNED	8/10/2021	5	660	132
PLANNED	8/10/2021	3	522	174
PLANNED	8/10/2021	4	96	24
PLANNED	8/10/2021	3	96	32
PLANNED	8/10/2021	2	118	59
PLANNED	8/10/2021	3	33	11
PLANNED	8/10/2021	2	320	160
PLANNED	8/10/2021	6	54	9
PLANNED	8/10/2021	3	30	10
PLANNED	8/10/2021	6	132	22
PLANNED	8/10/2021	1	17	17
PLANNED	8/10/2021	1	40	40
PLANNED	8/10/2021	21	1,176	56
PLANNED	8/10/2021	1	109	109
PLANNED	8/10/2021	4	300	75
PLANNED	8/10/2021	6	438	73
PLANNED	8/10/2021	2	202	101
PLANNED	8/10/2021	1	299	299
PLANNED	8/10/2021	1	138	138
PLANNED	8/10/2021	6	150	25
PLANNED	8/10/2021	4	68	17
PLANNED	8/10/2021	3	33	11
PLANNED	8/10/2021	1	23	23
PLANNED	8/10/2021	11	88	8
PLANNED	8/10/2021	4	32	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/10/2021	2	22	11
PLANNED	8/10/2021	2	158	79
PLANNED	8/10/2021	12	120	10
PLANNED	8/10/2021	2	64	32
CUSTOMER REQUEST	8/10/2021	8	88	11
PLANNED	8/10/2021	2	12	6
PLANNED	8/10/2021	5	465	93
PLANNED	8/10/2021	3	360	120
CUSTOMER REQUEST	8/10/2021	22	8,668	394
PLANNED	8/10/2021	8	248	31
PLANNED	8/10/2021	2	52	26
PLANNED	8/10/2021	4	92	23
PLANNED	8/10/2021	2	18	9
PLANNED	8/10/2021	4	236	59
PLANNED	8/10/2021	1	8	8
PLANNED	8/10/2021	28	2,688	96
PLANNED	8/10/2021	3	582	194
CUSTOMER REQUEST	8/10/2021	5	285	57
PLANNED	8/10/2021	6	1,326	221
PLANNED	8/10/2021	5	1,070	214
PLANNED	8/10/2021	4	20	5
PLANNED	8/10/2021	1	193	193
PLANNED	8/10/2021	7	721	103
PLANNED	8/10/2021	3	15	5
PLANNED	8/10/2021	3	276	92
PLANNED	8/10/2021	12	888	74
PLANNED	8/10/2021	2	248	124
PLANNED	8/10/2021	8	1,248	156
PLANNED	8/10/2021	5	875	175
PLANNED	8/10/2021	2	156	78
PLANNED	8/10/2021	2	34	17
PLANNED	8/10/2021	4	24	6
PLANNED	8/10/2021	3	339	113
PLANNED	8/10/2021	8	872	109
PLANNED	8/10/2021	10	3,170	317
PLANNED	8/10/2021	3	495	165
PLANNED	8/10/2021	2	110	55
PLANNED	8/10/2021	9	612	68
PLANNED	8/10/2021	1	198	198
PLANNED	8/10/2021	1	66	66
PLANNED	8/10/2021	4	296	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/10/2021	4	100	25
PLANNED	8/10/2021	7	119	17
PLANNED	8/10/2021	7	119	17
PLANNED	8/10/2021	11	3,729	339
PLANNED	8/10/2021	7	553	79
PLANNED	8/10/2021	2	52	26
PLANNED	8/10/2021	4	296	74
PLANNED	8/10/2021	1	83	83
PLANNED	8/10/2021	1	358	358
PLANNED	8/10/2021	2	434	217
PLANNED	8/10/2021	2	294	147
PLANNED	8/10/2021	3	81	27
PLANNED	8/10/2021	3	18	6
PLANNED	8/10/2021	4	40	10
PLANNED	8/10/2021	3	243	81
PLANNED	8/10/2021	31	1,550	50
PLANNED	8/10/2021	5	310	62
PLANNED	8/10/2021	1	62	62
PLANNED	8/10/2021	1	153	153
PLANNED	8/10/2021	3	429	143
PLANNED	8/10/2021	2	24	12
PLANNED	8/10/2021	8	456	57
PLANNED	8/10/2021	2	12	6
PLANNED	8/10/2021	1	112	112
PLANNED	8/10/2021	10	400	40
PLANNED	8/10/2021	3	21	7
PLANNED	8/10/2021	3	27	9
PLANNED	8/10/2021	38	1,862	49
PLANNED	8/10/2021	3	21	7
PLANNED	8/10/2021	4	48	12
PLANNED	8/10/2021	2	18	9
PLANNED	8/10/2021	5	160	32
PLANNED	8/10/2021	2	166	83
PLANNED	8/10/2021	28	3,192	114
PLANNED	8/10/2021	32	2,016	63
PLANNED	8/10/2021	8	1,888	236
PLANNED	8/10/2021	7	1,687	241
PLANNED	8/10/2021	4	100	25
PLANNED	8/10/2021	7	917	131
PLANNED	8/10/2021	4	120	30
PLANNED	8/10/2021	1	16	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/10/2021	1	11	11
PLANNED	8/10/2021	16	2,544	159
PLANNED	8/10/2021	4	1,064	266
PLANNED	8/10/2021	3	90	30
PLANNED	8/10/2021	4	88	22
PLANNED	8/10/2021	6	90	15
PLANNED	8/10/2021	15	705	47
PLANNED	8/10/2021	3	210	70
PLANNED	8/10/2021	2	38	19
PLANNED	8/10/2021	9	603	67
PLANNED	8/10/2021	3	60	20
PLANNED	8/10/2021	4	264	66
PLANNED	8/10/2021	4	24	6
PLANNED	8/10/2021	4	56	14
PLANNED	8/10/2021	3	237	79
PLANNED	8/10/2021	8	64	8
PLANNED	8/10/2021	2	28	14
PLANNED	8/10/2021	1	10	10
PLANNED	8/10/2021	3	75	25
PLANNED	8/10/2021	3	87	29
PLANNED	8/10/2021	2	16	8
PLANNED	8/10/2021	3	54	18
PLANNED	8/10/2021	3	51	17
PLANNED	8/10/2021	10	760	76
PLANNED	8/10/2021	11	121	11
PLANNED	8/10/2021	9	684	76
PLANNED	8/10/2021	1	10	10
PLANNED	8/10/2021	4	32	8
PLANNED	8/10/2021	8	48	6
PLANNED	8/10/2021	5	55	11
PLANNED	8/10/2021	1	78	78
PLANNED	8/10/2021	4	44	11
PLANNED	8/10/2021	3	24	8
PLANNED	8/10/2021	30	2,430	81
PLANNED	8/10/2021	2	66	33
PLANNED	8/10/2021	5	190	38
PLANNED	8/10/2021	8	256	32
PLANNED	8/10/2021	2	74	37
PLANNED	8/10/2021	1	2	2
PLANNED	8/10/2021	3	96	32
PLANNED	8/10/2021	2	434	217

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/10/2021	17	1,020	60
PLANNED	8/10/2021	4	252	63
PLANNED	8/10/2021	3	558	186
PLANNED	8/10/2021	5	15	3
PLANNED	8/10/2021	8	112	14
PLANNED	8/10/2021	3	255	85
PLANNED	8/10/2021	1	81	81
PLANNED	8/10/2021	3	6	2
PLANNED	8/10/2021	2	14	7
PLANNED	8/10/2021	1	22	22
PLANNED	8/10/2021	4	36	9
PLANNED	8/10/2021	1	7	7
PLANNED	8/10/2021	2	12	6
PLANNED	8/10/2021	2	224	112
PLANNED	8/10/2021	2	134	67
PLANNED	8/10/2021	4	156	39
CUSTOMER REQUEST	8/10/2021	1	132	132
PLANNED	8/10/2021	1	87	87
PLANNED	8/10/2021	6	984	164
PLANNED	8/10/2021	1	35	35
PLANNED	8/10/2021	2	160	80
PLANNED	8/10/2021	1	61	61
PLANNED	8/10/2021	10	30	3
PLANNED	8/10/2021	1	93	93
PLANNED	8/10/2021	3	357	119
PLANNED	8/10/2021	34	1,700	50
PLANNED	8/10/2021	3	363	121
PLANNED	8/10/2021	9	1,674	186
PLANNED	8/10/2021	1	131	131
PLANNED	8/11/2021	4	36	9
PLANNED	8/11/2021	3	753	251
PLANNED	8/11/2021	4	204	51
PLANNED	8/11/2021	2	10	5
PLANNED	8/11/2021	1	231	231
PLANNED	8/11/2021	1	168	168
PLANNED	8/11/2021	6	1,590	265
PLANNED	8/11/2021	3	702	234
PLANNED	8/11/2021	1	38	38
PLANNED	8/11/2021	2	121	120
PLANNED	8/11/2021	2	8	4
PLANNED	8/11/2021	1	159	159

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/11/2021	9	252	28
PLANNED	8/11/2021	1	43	43
PLANNED	8/11/2021	4	16	4
PLANNED	8/11/2021	2	10	5
PLANNED	8/11/2021	4	20	5
PLANNED	8/11/2021	1	87	87
PLANNED	8/11/2021	2	68	34
CUSTOMER REQUEST	8/11/2021	3	12	4
PLANNED	8/11/2021	2	92	46
PLANNED	8/11/2021	3	15	5
PLANNED	8/11/2021	106	19,716	186
PLANNED	8/11/2021	19	3,040	160
PLANNED	8/11/2021	1	246	246
PLANNED	8/11/2021	2	128	64
PLANNED	8/11/2021	1	5	5
PLANNED	8/11/2021	7	896	128
PLANNED	8/11/2021	9	198	22
PLANNED	8/11/2021	12	792	66
PLANNED	8/11/2021	1	5	5
PLANNED	8/11/2021	1	81	81
PLANNED	8/11/2021	4	116	29
PLANNED	8/11/2021	3	15	5
PLANNED	8/11/2021	2	64	32
PLANNED	8/11/2021	1	169	169
PLANNED	8/11/2021	1	57	57
CUSTOMER REQUEST	8/11/2021	1	234	234
CUSTOMER REQUEST	8/11/2021	22	5,060	230
CUSTOMER REQUEST	8/11/2021	9	126	14
PLANNED	8/11/2021	5	290	58
PLANNED	8/11/2021	1	58	58
PLANNED	8/11/2021	2	8	4
CUSTOMER REQUEST	8/11/2021	8	40	5
PLANNED	8/11/2021	2	22	11
PLANNED	8/11/2021	2	314	157
PLANNED	8/11/2021	4	24	6
PLANNED	8/11/2021	6	120	20
PLANNED	8/11/2021	2	171	170
PLANNED	8/11/2021	2	12	6
PLANNED	8/11/2021	1	16	16
PLANNED	8/11/2021	4	72	18
PLANNED	8/11/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/11/2021	2	20	10
PLANNED	8/11/2021	2	20	10
PLANNED	8/11/2021	4	306	79
PLANNED	8/11/2021	6	180	30
PLANNED	8/11/2021	3	42	14
PLANNED	8/11/2021	5	70	14
PLANNED	8/11/2021	4	36	9
PLANNED	8/11/2021	6	948	158
PLANNED	8/11/2021	2	412	206
PLANNED	8/11/2021	8	1,984	248
CUSTOMER REQUEST	8/11/2021	1	117	117
PLANNED	8/11/2021	2	16	8
PLANNED	8/11/2021	4	348	87
CUSTOMER REQUEST	8/11/2021	4	492	123
PLANNED	8/11/2021	1	94	94
CUSTOMER REQUEST	8/11/2021	5	332	280
PLANNED	8/11/2021	3	24	8
PLANNED	8/11/2021	2	50	25
PLANNED	8/11/2021	2	272	136
PLANNED	8/11/2021	2	586	293
PLANNED	8/11/2021	2	10	5
PLANNED	8/11/2021	3	66	22
PLANNED	8/11/2021	4	516	129
PLANNED	8/11/2021	3	60	20
PLANNED	8/11/2021	1	137	137
PLANNED	8/11/2021	4	288	72
PLANNED	8/11/2021	6	288	48
PLANNED	8/11/2021	2	56	28
PLANNED	8/11/2021	8	176	22
PLANNED	8/11/2021	1	4	4
PLANNED	8/11/2021	1	6	6
PLANNED	8/11/2021	2	16	8
PLANNED	8/11/2021	5	55	11
PLANNED	8/11/2021	5	750	150
PLANNED	8/11/2021	3	279	93
PLANNED	8/11/2021	3	123	41
PLANNED	8/11/2021	3	423	141
PLANNED	8/11/2021	4	76	19
PLANNED	8/11/2021	5	505	101
CUSTOMER REQUEST	8/11/2021	3	93	31
PLANNED	8/11/2021	3	522	174

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/11/2021	1	59	59
PLANNED	8/11/2021	9	360	40
PLANNED	8/11/2021	2	104	52
PLANNED	8/11/2021	6	324	54
PLANNED	8/11/2021	4	32	8
PLANNED	8/11/2021	1	17	17
PLANNED	8/11/2021	2	136	68
PLANNED	8/11/2021	4	88	22
PLANNED	8/11/2021	3	507	169
PLANNED	8/11/2021	4	80	20
PLANNED	8/11/2021	1	38	38
PLANNED	8/11/2021	2	166	83
PLANNED	8/11/2021	3	111	37
PLANNED	8/11/2021	4	132	33
CUSTOMER REQUEST	8/11/2021	8	64	8
CUSTOMER REQUEST	8/11/2021	3	24	8
PLANNED	8/11/2021	64	5,376	84
PLANNED	8/11/2021	3	33	11
PLANNED	8/11/2021	14	1,890	135
PLANNED	8/11/2021	4	44	11
PLANNED	8/11/2021	2	120	60
PLANNED	8/11/2021	2	10	5
PLANNED	8/11/2021	2	14	7
PLANNED	8/11/2021	3	24	8
PLANNED	8/11/2021	6	354	59
PLANNED	8/11/2021	4	612	153
PLANNED	8/11/2021	2	58	29
PLANNED	8/11/2021	4	80	20
PLANNED	8/11/2021	2	362	181
PLANNED	8/11/2021	2	128	64
PLANNED	8/11/2021	4	384	96
PLANNED	8/11/2021	6	766	205
PLANNED	8/11/2021	4	76	19
PLANNED	8/11/2021	2	202	101
PLANNED	8/11/2021	5	290	58
PLANNED	8/11/2021	4	484	121
PLANNED	8/11/2021	8	904	113
PLANNED	8/11/2021	3	150	50
PLANNED	8/11/2021	6	144	24
PLANNED	8/11/2021	3	366	122
CUSTOMER REQUEST	8/11/2021	3	54	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/11/2021	5	200	41
CUSTOMER REQUEST	8/11/2021	13	78	6
PLANNED	8/11/2021	4	40	10
PLANNED	8/11/2021	2	22	11
PLANNED	8/11/2021	4	20	5
PLANNED	8/11/2021	2	16	8
PLANNED	8/11/2021	3	24	8
PLANNED	8/11/2021	1	6	6
PLANNED	8/11/2021	4	24	6
CUSTOMER REQUEST	8/11/2021	2	52	26
PLANNED	8/11/2021	1	119	119
PLANNED	8/11/2021	2	20	10
PLANNED	8/11/2021	3	3	1
PLANNED	8/11/2021	3	270	90
PLANNED	8/11/2021	1	56	56
PLANNED	8/11/2021	2	36	18
PLANNED	8/11/2021	1	14	14
PLANNED	8/11/2021	2	188	94
PLANNED	8/11/2021	11	484	44
PLANNED	8/11/2021	130	3,380	26
CUSTOMER REQUEST	8/11/2021	1	142	142
PLANNED	8/11/2021	3	21	7
PLANNED	8/11/2021	4	24	6
PLANNED	8/11/2021	1	32	32
PLANNED	8/11/2021	2	180	90
PLANNED	8/11/2021	2	138	69
PLANNED	8/11/2021	3	15	5
PLANNED	8/11/2021	5	495	99
PLANNED	8/11/2021	6	108	18
PLANNED	8/11/2021	1	13	13
PLANNED	8/11/2021	3	915	305
PLANNED	8/11/2021	3	114	38
PLANNED	8/11/2021	8	328	41
CUSTOMER REQUEST	8/11/2021	1	109	109
CUSTOMER REQUEST	8/11/2021	1	111	111
CUSTOMER REQUEST	8/11/2021	9	54	6
CUSTOMER REQUEST	8/11/2021	8	152	19
PLANNED	8/11/2021	1	115	115
PLANNED	8/11/2021	10	2,390	239
CUSTOMER REQUEST	8/11/2021	898	56,574	63
PLANNED	8/11/2021	3	594	198

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/11/2021	4	408	102
PLANNED	8/11/2021	2	178	89
CUSTOMER REQUEST	8/11/2021	898	13,470	15
PLANNED	8/12/2021	1	191	191
CUSTOMER REQUEST	8/12/2021	5	795	159
PLANNED	8/12/2021	1	71	71
PLANNED	8/12/2021	4	24	6
PLANNED	8/12/2021	13	1,235	95
PLANNED	8/12/2021	27	2,160	80
PLANNED	8/12/2021	10	710	71
CUSTOMER REQUEST	8/12/2021	1	5	5
PLANNED	8/12/2021	1	124	124
PLANNED	8/12/2021	7	196	28
PLANNED	8/12/2021	3	681	227
PLANNED	8/12/2021	1	73	73
PLANNED	8/12/2021	3	147	49
PLANNED	8/12/2021	1	3	3
PLANNED	8/12/2021	8	112	14
PLANNED	8/12/2021	1	88	88
PLANNED	8/12/2021	2	214	107
PLANNED	8/12/2021	1	123	123
PLANNED	8/12/2021	2	12	6
PLANNED	8/12/2021	2	20	10
PLANNED	8/12/2021	1	19	19
PLANNED	8/12/2021	4	136	34
PLANNED	8/12/2021	1	4	4
PLANNED	8/12/2021	1	19	19
PLANNED	8/12/2021	2	156	78
PLANNED	8/12/2021	2	310	155
PLANNED	8/12/2021	1	224	224
PLANNED	8/12/2021	12	2,316	193
PLANNED	8/12/2021	14	2,548	182
PLANNED	8/12/2021	9	1,530	170
PLANNED	8/12/2021	11	1,859	169
PLANNED	8/12/2021	11	1,870	170
PLANNED	8/12/2021	12	2,028	169
PLANNED	8/12/2021	2	292	146
PLANNED	8/12/2021	10	1,700	170
PLANNED	8/12/2021	5	80	16
PLANNED	8/12/2021	10	1,690	169
PLANNED	8/12/2021	4	528	132

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/12/2021	4	144	36
PLANNED	8/12/2021	10	1,700	170
PLANNED	8/12/2021	12	2,040	170
PLANNED	8/12/2021	10	1,700	170
PLANNED	8/12/2021	12	2,256	188
PLANNED	8/12/2021	4	366	158
PLANNED	8/12/2021	3	39	13
PLANNED	8/12/2021	11	1,881	171
PLANNED	8/12/2021	3	39	13
PLANNED	8/12/2021	2	12	6
PLANNED	8/12/2021	1	49	49
CUSTOMER REQUEST	8/12/2021	26	9,282	357
PLANNED	8/12/2021	1	221	221
PLANNED	8/12/2021	4	468	117
PLANNED	8/12/2021	7	182	26
PLANNED	8/12/2021	2	276	138
PLANNED	8/12/2021	5	45	9
PLANNED	8/12/2021	2	46	23
PLANNED	8/12/2021	1	47	47
PLANNED	8/12/2021	14	1,470	105
PLANNED	8/12/2021	3	9	3
PLANNED	8/12/2021	5	720	144
PLANNED	8/12/2021	5	1,620	324
PLANNED	8/12/2021	4	96	24
PLANNED	8/12/2021	2	364	182
PLANNED	8/12/2021	1	4	4
PLANNED	8/12/2021	3	225	75
PLANNED	8/12/2021	3	522	174
PLANNED	8/12/2021	4	540	135
PLANNED	8/12/2021	2	32	16
PLANNED	8/12/2021	2	22	11
PLANNED	8/12/2021	2	96	48
PLANNED	8/12/2021	2	222	111
PLANNED	8/12/2021	2	272	136
PLANNED	8/12/2021	5	30	6
PLANNED	8/12/2021	19	1,805	95
PLANNED	8/12/2021	9	171	19
PLANNED	8/12/2021	2	130	65
PLANNED	8/12/2021	9	297	33
PLANNED	8/12/2021	4	652	163
PLANNED	8/12/2021	8	1,232	154

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/12/2021	7	70	10
PLANNED	8/12/2021	5	460	92
PLANNED	8/12/2021	7	42	6
PLANNED	8/12/2021	1	168	168
CUSTOMER REQUEST	8/12/2021	1	85	85
PLANNED	8/12/2021	1	55	55
PLANNED	8/12/2021	3	69	23
PLANNED	8/12/2021	3	267	89
PLANNED	8/12/2021	1	69	69
PLANNED	8/12/2021	5	65	13
PLANNED	8/12/2021	1	5	5
PLANNED	8/12/2021	3	291	97
PLANNED	8/12/2021	1	27	27
PLANNED	8/12/2021	4	204	51
PLANNED	8/12/2021	3	45	15
PLANNED	8/12/2021	3	348	116
PLANNED	8/12/2021	1	131	131
PLANNED	8/12/2021	1	30	30
PLANNED	8/12/2021	7	749	107
PLANNED	8/12/2021	1	5	5
PLANNED	8/12/2021	4	64	16
PLANNED	8/12/2021	4	80	20
PLANNED	8/12/2021	4	88	22
PLANNED	8/12/2021	3	318	106
PLANNED	8/12/2021	1	178	178
PLANNED	8/12/2021	3	180	60
PLANNED	8/12/2021	25	125	5
PLANNED	8/12/2021	4	816	204
PLANNED	8/12/2021	8	768	96
PLANNED	8/12/2021	11	561	51
PLANNED	8/12/2021	3	12	4
PLANNED	8/12/2021	5	90	18
PLANNED	8/12/2021	4	84	21
PLANNED	8/12/2021	4	68	17
PLANNED	8/12/2021	4	64	16
PLANNED	8/12/2021	2	114	58
PLANNED	8/12/2021	4	112	28
PLANNED	8/12/2021	3	99	33
PLANNED	8/12/2021	1	14	14
PLANNED	8/12/2021	3	369	123
PLANNED	8/12/2021	3	12	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/12/2021	1	104	104
PLANNED	8/12/2021	1	69	69
PLANNED	8/12/2021	2	216	108
PLANNED	8/12/2021	5	370	74
PLANNED	8/12/2021	12	2,712	226
PLANNED	8/12/2021	49	4,263	87
PLANNED	8/12/2021	8	1,960	325
PLANNED	8/12/2021	2	10	5
PLANNED	8/12/2021	1	49	49
PLANNED	8/12/2021	2	12	6
PLANNED	8/12/2021	1	49	49
PLANNED	8/12/2021	1	40	40
PLANNED	8/12/2021	2	14	7
PLANNED	8/12/2021	7	84	12
PLANNED	8/12/2021	7	742	106
PLANNED	8/12/2021	9	954	106
PLANNED	8/12/2021	11	1,166	106
PLANNED	8/12/2021	11	3,454	314
PLANNED	8/12/2021	5	1,645	329
PLANNED	8/12/2021	1	9	9
PLANNED	8/12/2021	4	180	45
PLANNED	8/12/2021	3	69	23
CUSTOMER REQUEST	8/12/2021	2	408	204
PLANNED	8/12/2021	1	9	9
PLANNED	8/12/2021	8	240	30
CUSTOMER REQUEST	8/12/2021	1	179	179
PLANNED	8/12/2021	3	51	17
PLANNED	8/12/2021	4	104	26
PLANNED	8/12/2021	4	128	32
PLANNED	8/12/2021	4	192	48
PLANNED	8/12/2021	1	8	8
PLANNED	8/12/2021	3	240	80
PLANNED	8/12/2021	2	18	9
PLANNED	8/12/2021	1	88	88
PLANNED	8/12/2021	1	150	150
PLANNED	8/12/2021	2	68	34
PLANNED	8/12/2021	3	291	97
PLANNED	8/12/2021	2	16	8
PLANNED	8/12/2021	2	120	60
PLANNED	8/12/2021	1	78	78
PLANNED	8/12/2021	1	76	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/12/2021	15	1,335	89
PLANNED	8/12/2021	22	1,958	89
PLANNED	8/12/2021	20	1,800	90
PLANNED	8/12/2021	21	1,869	89
PLANNED	8/12/2021	19	1,862	98
PLANNED	8/12/2021	24	2,808	117
PLANNED	8/12/2021	3	276	92
PLANNED	8/12/2021	4	32	8
PLANNED	8/12/2021	4	28	7
PLANNED	8/12/2021	5	105	21
PLANNED	8/12/2021	1	6	6
PLANNED	8/12/2021	3	141	47
PLANNED	8/12/2021	4	200	50
PLANNED	8/12/2021	4	296	74
PLANNED	8/12/2021	10	180	18
PLANNED	8/12/2021	5	10	2
PLANNED	8/12/2021	13	741	57
PLANNED	8/12/2021	3	234	78
PLANNED	8/12/2021	1	46	46
PLANNED	8/12/2021	1	134	134
PLANNED	8/12/2021	1	130	130
PLANNED	8/12/2021	10	80	8
PLANNED	8/12/2021	6	1,194	199
PLANNED	8/12/2021	12	1,044	87
PLANNED	8/12/2021	1	52	52
PLANNED	8/12/2021	3	87	29
PLANNED	8/12/2021	8	360	45
PLANNED	8/12/2021	3	252	84
PLANNED	8/12/2021	1	136	136
PLANNED	8/12/2021	8	167	54
PLANNED	8/12/2021	2	94	47
PLANNED	8/12/2021	1	26	26
PLANNED	8/12/2021	1	100	100
PLANNED	8/12/2021	6	66	11
PLANNED	8/12/2021	3	60	20
PLANNED	8/12/2021	2	200	100
PLANNED	8/12/2021	1	62	62
PLANNED	8/12/2021	7	413	59
PLANNED	8/12/2021	2	184	92
PLANNED	8/12/2021	3	123	41
PLANNED	8/12/2021	1	47	47

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/12/2021	1	69	69
CUSTOMER REQUEST	8/12/2021	1	34	34
PLANNED	8/12/2021	10	850	85
PLANNED	8/12/2021	2	450	225
PLANNED	8/12/2021	2	188	94
PLANNED	8/12/2021	5	535	107
PLANNED	8/13/2021	4	208	52
CUSTOMER REQUEST	8/13/2021	1	271	271
PLANNED	8/13/2021	1	55	55
PLANNED	8/13/2021	1	93	93
PLANNED	8/13/2021	22	396	18
PLANNED	8/13/2021	9	837	93
PLANNED	8/13/2021	1	61	61
PLANNED	8/14/2021	1	47	47
PLANNED	8/14/2021	5	135	27
PLANNED	8/15/2021	3	696	232
PLANNED	8/16/2021	3	153	51
PLANNED	8/16/2021	1	33	33
PLANNED	8/16/2021	1	57	57
CUSTOMER REQUEST	8/16/2021	2	344	172
PLANNED	8/16/2021	1	126	126
PLANNED	8/16/2021	4	72	18
CUSTOMER REQUEST	8/16/2021	2	28	14
PLANNED	8/16/2021	4	184	46
PLANNED	8/16/2021	1	7	7
PLANNED	8/16/2021	9	657	73
PLANNED	8/16/2021	1	67	67
PLANNED	8/16/2021	2	198	99
PLANNED	8/16/2021	4	36	9
PLANNED	8/16/2021	2	222	111
PLANNED	8/16/2021	1	55	55
PLANNED	8/16/2021	1	110	110
PLANNED	8/16/2021	3	12	4
PLANNED	8/16/2021	3	234	78
CUSTOMER REQUEST	8/16/2021	5	330	66
CUSTOMER REQUEST	8/16/2021	4	520	130
PLANNED	8/16/2021	4	188	47
PLANNED	8/16/2021	1	26	26
PLANNED	8/16/2021	1	26	26
PLANNED	8/16/2021	1	25	25
PLANNED	8/16/2021	3	285	95

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/16/2021	1	31	31
PLANNED	8/17/2021	1	216	216
CUSTOMER REQUEST	8/17/2021	6	102	17
PLANNED	8/17/2021	2	424	212
PLANNED	8/17/2021	1	44	44
PLANNED	8/17/2021	1	58	58
PLANNED	8/17/2021	1	48	48
PLANNED	8/17/2021	11	671	61
PLANNED	8/17/2021	6	318	53
PLANNED	8/17/2021	1	51	51
PLANNED	8/17/2021	7	413	59
PLANNED	8/17/2021	4	108	27
PLANNED	8/17/2021	12	960	80
PLANNED	8/17/2021	3	24	8
PLANNED	8/17/2021	5	995	199
PLANNED	8/17/2021	3	27	9
PLANNED	8/17/2021	1	155	155
PLANNED	8/17/2021	2	46	23
PLANNED	8/17/2021	2	26	13
PLANNED	8/17/2021	1	15	15
PLANNED	8/17/2021	1	9	9
PLANNED	8/17/2021	13	5,330	410
PLANNED	8/17/2021	1	99	99
PLANNED	8/17/2021	3	84	28
PLANNED	8/17/2021	4	28	7
PLANNED	8/17/2021	4	540	135
PLANNED	8/17/2021	4	52	13
PLANNED	8/17/2021	6	18	3
PLANNED	8/17/2021	5	350	70
PLANNED	8/17/2021	5	675	135
PLANNED	8/17/2021	3	303	101
PLANNED	8/17/2021	4	36	9
PLANNED	8/17/2021	5	80	16
PLANNED	8/17/2021	6	96	16
PLANNED	8/17/2021	1	19	19
PLANNED	8/17/2021	8	768	96
PLANNED	8/17/2021	5	505	101
PLANNED	8/17/2021	4	372	93
PLANNED	8/17/2021	6	1,926	321
PLANNED	8/17/2021	1	76	76
PLANNED	8/17/2021	1	81	81

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/17/2021	3	30	10
PLANNED	8/17/2021	15	3,210	214
CUSTOMER REQUEST	8/17/2021	24	1,920	80
PLANNED	8/17/2021	2	10	5
PLANNED	8/17/2021	1	79	79
CUSTOMER REQUEST	8/17/2021	1	138	138
PLANNED	8/17/2021	3	27	9
PLANNED	8/17/2021	2	46	23
PLANNED	8/17/2021	2	20	10
PLANNED	8/17/2021	3	18	6
PLANNED	8/17/2021	1	107	107
PLANNED	8/17/2021	2	254	127
PLANNED	8/17/2021	10	430	43
PLANNED	8/17/2021	2	92	46
PLANNED	8/17/2021	4	20	5
PLANNED	8/17/2021	5	625	125
PLANNED	8/17/2021	2	142	71
PLANNED	8/17/2021	1	14	14
PLANNED	8/17/2021	2	22	11
PLANNED	8/17/2021	2	16	8
PLANNED	8/17/2021	1	81	81
PLANNED	8/17/2021	3	24	8
PLANNED	8/17/2021	1	123	123
PLANNED	8/17/2021	4	148	37
PLANNED	8/17/2021	3	30	10
PLANNED	8/17/2021	1	86	86
PLANNED	8/17/2021	1	5	5
PLANNED	8/17/2021	5	835	167
PLANNED	8/17/2021	2	20	10
PLANNED	8/17/2021	1	17	17
CUSTOMER REQUEST	8/17/2021	1	43	43
PLANNED	8/17/2021	3	105	35
PLANNED	8/17/2021	3	24	8
PLANNED	8/17/2021	3	174	86
PLANNED	8/17/2021	2	16	8
PLANNED	8/17/2021	1	46	46
PLANNED	8/17/2021	1	100	100
PLANNED	8/17/2021	3	24	8
PLANNED	8/17/2021	3	30	10
PLANNED	8/17/2021	3	27	9
PLANNED	8/17/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/17/2021	1	11	11
PLANNED	8/17/2021	1	22	22
PLANNED	8/17/2021	5	55	11
PLANNED	8/17/2021	2	28	14
CUSTOMER REQUEST	8/17/2021	8	104	13
PLANNED	8/17/2021	6	150	25
PLANNED	8/17/2021	6	48	8
PLANNED	8/17/2021	6	282	47
PLANNED	8/17/2021	9	441	49
PLANNED	8/17/2021	1	97	97
PLANNED	8/17/2021	3	27	9
PLANNED	8/17/2021	2	44	22
PLANNED	8/17/2021	2	116	58
PLANNED	8/17/2021	6	60	10
PLANNED	8/17/2021	1	8	8
PLANNED	8/17/2021	7	392	56
PLANNED	8/17/2021	2	22	11
PLANNED	8/17/2021	2	32	16
PLANNED	8/17/2021	1	11	11
PLANNED	8/17/2021	4	148	37
PLANNED	8/17/2021	3	42	14
PLANNED	8/17/2021	1	62	62
PLANNED	8/17/2021	2	112	56
CUSTOMER REQUEST	8/17/2021	1	81	81
CUSTOMER REQUEST	8/17/2021	1	235	235
PLANNED	8/17/2021	8	288	36
CUSTOMER REQUEST	8/17/2021	1	135	135
PLANNED	8/17/2021	6	120	20
PLANNED	8/17/2021	1	164	164
PLANNED	8/17/2021	26	1,430	55
CUSTOMER REQUEST	8/17/2021	1	115	115
PLANNED	8/17/2021	1	25	25
PLANNED	8/18/2021	6	204	34
PLANNED	8/18/2021	1	32	32
PLANNED	8/18/2021	1	72	72
PLANNED	8/18/2021	1	95	95
PLANNED	8/18/2021	1	89	89
PLANNED	8/18/2021	8	1,432	179
PLANNED	8/18/2021	14	2,492	178
PLANNED	8/18/2021	2	48	24
PLANNED	8/18/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/18/2021	3	42	14
PLANNED	8/18/2021	7	567	81
PLANNED	8/18/2021	3	39	13
PLANNED	8/18/2021	6	678	113
PLANNED	8/18/2021	1	17	17
PLANNED	8/18/2021	1	157	157
PLANNED	8/18/2021	3	228	76
PLANNED	8/18/2021	3	27	9
PLANNED	8/18/2021	3	63	21
PLANNED	8/18/2021	2	148	74
PLANNED	8/18/2021	1	15	15
PLANNED	8/18/2021	7	511	73
PLANNED	8/18/2021	4	48	12
PLANNED	8/18/2021	4	520	130
CUSTOMER REQUEST	8/18/2021	13	5,161	397
PLANNED	8/18/2021	3	1,155	385
CUSTOMER REQUEST	8/18/2021	6	24	4
PLANNED	8/18/2021	24	1,440	60
PLANNED	8/18/2021	2	10	5
PLANNED	8/18/2021	8	392	49
PLANNED	8/18/2021	1	19	19
PLANNED	8/18/2021	2	14	7
PLANNED	8/18/2021	2	318	159
PLANNED	8/18/2021	8	224	28
PLANNED	8/18/2021	7	1,127	161
PLANNED	8/18/2021	1	7	7
PLANNED	8/18/2021	2	8	4
PLANNED	8/18/2021	3	36	12
PLANNED	8/18/2021	4	52	13
PLANNED	8/18/2021	2	56	28
PLANNED	8/18/2021	7	301	43
PLANNED	8/18/2021	16	2,192	137
PLANNED	8/18/2021	8	168	21
PLANNED	8/18/2021	1	39	39
PLANNED	8/18/2021	1	130	130
PLANNED	8/18/2021	4	20	5
PLANNED	8/18/2021	2	12	6
PLANNED	8/18/2021	2	126	63
PLANNED	8/18/2021	10	860	86
PLANNED	8/18/2021	1	89	89
PLANNED	8/18/2021	6	1,218	203

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/18/2021	1	247	247
PLANNED	8/18/2021	2	274	137
PLANNED	8/18/2021	2	54	27
PLANNED	8/18/2021	10	1,100	110
PLANNED	8/18/2021	8	696	87
PLANNED	8/18/2021	2	12	6
PLANNED	8/18/2021	2	200	100
PLANNED	8/18/2021	7	637	91
PLANNED	8/18/2021	4	235	91
PLANNED	8/18/2021	4	12	3
PLANNED	8/18/2021	10	910	91
PLANNED	8/18/2021	1	8	8
PLANNED	8/18/2021	24	2,136	89
PLANNED	8/18/2021	11	55	5
CUSTOMER REQUEST	8/18/2021	3	57	19
PLANNED	8/18/2021	2	24	12
PLANNED	8/18/2021	1	45	45
PLANNED	8/18/2021	1	27	27
PLANNED	8/18/2021	14	1,694	121
PLANNED	8/18/2021	3	33	11
PLANNED	8/18/2021	5	260	52
PLANNED	8/18/2021	1	12	12
PLANNED	8/18/2021	2	284	142
PLANNED	8/18/2021	3	246	82
PLANNED	8/18/2021	22	3,080	140
PLANNED	8/18/2021	3	21	7
PLANNED	8/18/2021	1	26	26
PLANNED	8/18/2021	1	17	17
PLANNED	8/18/2021	1	10	10
PLANNED	8/18/2021	10	220	22
PLANNED	8/18/2021	1	129	129
PLANNED	8/18/2021	1	6	6
CUSTOMER REQUEST	8/18/2021	113	1,130	10
PLANNED	8/18/2021	4	12	3
PLANNED	8/18/2021	1	66	66
PLANNED	8/18/2021	1	97	97
PLANNED	8/18/2021	1	7	7
PLANNED	8/18/2021	1	5	5
PLANNED	8/18/2021	3	102	34
PLANNED	8/18/2021	7	266	38
PLANNED	8/18/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/18/2021	7	284	88
PLANNED	8/18/2021	3	57	19
PLANNED	8/18/2021	1	6	6
PLANNED	8/18/2021	3	33	11
PLANNED	8/18/2021	5	25	5
PLANNED	8/18/2021	4	264	66
PLANNED	8/18/2021	9	324	36
PLANNED	8/18/2021	6	1,506	251
PLANNED	8/18/2021	3	72	24
PLANNED	8/18/2021	2	18	9
PLANNED	8/18/2021	1	186	186
PLANNED	8/18/2021	4	20	5
PLANNED	8/18/2021	3	30	10
PLANNED	8/18/2021	2	14	7
PLANNED	8/18/2021	1	5	5
PLANNED	8/18/2021	1	7	7
PLANNED	8/18/2021	8	304	38
PLANNED	8/18/2021	3	18	6
PLANNED	8/18/2021	2	28	14
PLANNED	8/18/2021	1	16	16
PLANNED	8/18/2021	2	284	142
PLANNED	8/18/2021	1	7	7
PLANNED	8/18/2021	1	24	24
PLANNED	8/18/2021	8	344	43
PLANNED	8/18/2021	1	72	72
PLANNED	8/18/2021	3	24	8
PLANNED	8/18/2021	6	420	70
PLANNED	8/18/2021	1	157	157
PLANNED	8/18/2021	5	625	125
PLANNED	8/18/2021	1	5	5
PLANNED	8/18/2021	4	600	150
PLANNED	8/18/2021	2	78	39
PLANNED	8/18/2021	2	64	32
PLANNED	8/18/2021	6	546	91
PLANNED	8/18/2021	7	91	13
PLANNED	8/18/2021	10	10	1
PLANNED	8/18/2021	2	20	10
PLANNED	8/18/2021	11	77	7
PLANNED	8/18/2021	22	528	24
PLANNED	8/18/2021	7	63	9
PLANNED	8/18/2021	9	1,116	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/18/2021	2	120	60
PLANNED	8/18/2021	12	60	5
PLANNED	8/18/2021	2	90	45
PLANNED	8/18/2021	1	115	115
PLANNED	8/18/2021	15	75	5
PLANNED	8/18/2021	2	170	85
PLANNED	8/18/2021	3	192	64
CUSTOMER REQUEST	8/18/2021	6	24	4
PLANNED	8/18/2021	5	340	68
PLANNED	8/18/2021	3	108	36
PLANNED	8/18/2021	5	140	28
PLANNED	8/18/2021	11	649	59
PLANNED	8/18/2021	1	63	63
PLANNED	8/18/2021	1	36	36
PLANNED	8/18/2021	7	154	22
CUSTOMER REQUEST	8/18/2021	23	552	24
PLANNED	8/18/2021	3	354	118
CUSTOMER REQUEST	8/18/2021	6	948	158
PLANNED	8/18/2021	4	324	81
PLANNED	8/18/2021	2	150	75
PLANNED	8/18/2021	4	460	115
CUSTOMER REQUEST	8/18/2021	1	196	196
PLANNED	8/18/2021	5	100	20
PLANNED	8/18/2021	1	401	401
PLANNED	8/18/2021	1	249	249
PLANNED	8/18/2021	2	188	94
PLANNED	8/18/2021	1	106	106
CUSTOMER REQUEST	8/18/2021	1	291	291
CUSTOMER REQUEST	8/19/2021	1	284	284
PLANNED	8/19/2021	4	340	85
PLANNED	8/19/2021	3	219	73
PLANNED	8/19/2021	1	23	23
PLANNED	8/19/2021	7	560	80
PLANNED	8/19/2021	1	73	73
PLANNED	8/19/2021	4	762	223
PLANNED	8/19/2021	3	15	5
PLANNED	8/19/2021	2	260	130
PLANNED	8/19/2021	4	36	9
PLANNED	8/19/2021	3	18	6
PLANNED	8/19/2021	3	27	9
PLANNED	8/19/2021	4	32	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/19/2021	3	27	9
PLANNED	8/19/2021	1	35	35
PLANNED	8/19/2021	4	80	20
PLANNED	8/19/2021	1	55	55
PLANNED	8/19/2021	2	97	70
PLANNED	8/19/2021	3	621	207
CUSTOMER REQUEST	8/19/2021	2	542	271
PLANNED	8/19/2021	2	8	4
PLANNED	8/19/2021	16	768	48
PLANNED	8/19/2021	3	348	116
PLANNED	8/19/2021	31	3,689	119
PLANNED	8/19/2021	7	798	114
PLANNED	8/19/2021	34	13,396	394
PLANNED	8/19/2021	2	40	20
PLANNED	8/19/2021	3	291	97
PLANNED	8/19/2021	2	10	5
PLANNED	8/19/2021	28	3,864	138
PLANNED	8/19/2021	5	620	124
PLANNED	8/19/2021	2	20	10
PLANNED	8/19/2021	13	26	2
PLANNED	8/19/2021	3	15	5
PLANNED	8/19/2021	4	264	66
PLANNED	8/19/2021	13	1,547	119
PLANNED	8/19/2021	6	1,194	199
PLANNED	8/19/2021	13	104	8
PLANNED	8/19/2021	13	91	7
PLANNED	8/19/2021	7	245	35
PLANNED	8/19/2021	1	174	174
PLANNED	8/19/2021	4	48	12
PLANNED	8/19/2021	2	58	29
PLANNED	8/19/2021	2	128	64
PLANNED	8/19/2021	4	68	17
PLANNED	8/19/2021	1	96	96
PLANNED	8/19/2021	13	65	5
PLANNED	8/19/2021	3	15	5
PLANNED	8/19/2021	2	78	39
PLANNED	8/19/2021	1	10	10
PLANNED	8/19/2021	1	51	51
PLANNED	8/19/2021	3	18	6
PLANNED	8/19/2021	2	14	7
PLANNED	8/19/2021	12	3,060	255

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/19/2021	3	21	7
PLANNED	8/19/2021	5	1,535	307
PLANNED	8/19/2021	1	5	5
CUSTOMER REQUEST	8/19/2021	3	24	8
PLANNED	8/19/2021	4	608	152
PLANNED	8/19/2021	1	21	21
PLANNED	8/19/2021	3	72	24
PLANNED	8/19/2021	1	14	14
PLANNED	8/19/2021	4	60	15
PLANNED	8/19/2021	3	528	176
PLANNED	8/19/2021	2	30	15
PLANNED	8/19/2021	1	43	43
PLANNED	8/19/2021	2	42	21
PLANNED	8/19/2021	4	899	273
PLANNED	8/19/2021	10	80	8
PLANNED	8/19/2021	1	3	3
PLANNED	8/19/2021	6	120	20
PLANNED	8/19/2021	27	6,291	233
PLANNED	8/19/2021	4	444	111
PLANNED	8/19/2021	2	12	6
PLANNED	8/19/2021	1	52	52
PLANNED	8/19/2021	1	47	47
PLANNED	8/19/2021	7	70	10
PLANNED	8/19/2021	1	207	207
PLANNED	8/19/2021	4	20	5
PLANNED	8/19/2021	5	325	65
PLANNED	8/19/2021	10	70	7
PLANNED	8/19/2021	11	1,551	141
PLANNED	8/19/2021	3	18	6
PLANNED	8/19/2021	1	206	206
PLANNED	8/19/2021	1	51	51
PLANNED	8/19/2021	7	616	88
PLANNED	8/19/2021	4	364	91
PLANNED	8/19/2021	1	3	3
PLANNED	8/19/2021	3	120	40
PLANNED	8/19/2021	3	33	11
CUSTOMER REQUEST	8/19/2021	9	522	58
PLANNED	8/19/2021	4	1,068	267
PLANNED	8/19/2021	3	51	17
PLANNED	8/19/2021	2	122	61
PLANNED	8/19/2021	3	27	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/19/2021	10	1,900	190
PLANNED	8/19/2021	3	18	6
PLANNED	8/19/2021	1	17	17
PLANNED	8/19/2021	1	170	170
PLANNED	8/19/2021	3	33	11
PLANNED	8/19/2021	6	138	23
PLANNED	8/19/2021	7	98	14
PLANNED	8/19/2021	1	69	69
PLANNED	8/19/2021	8	984	123
PLANNED	8/19/2021	2	10	5
PLANNED	8/19/2021	2	26	13
PLANNED	8/19/2021	3	69	23
PLANNED	8/19/2021	2	10	5
PLANNED	8/19/2021	3	21	7
PLANNED	8/19/2021	1	153	153
PLANNED	8/19/2021	3	21	7
PLANNED	8/19/2021	4	396	99
PLANNED	8/19/2021	14	56	4
PLANNED	8/19/2021	3	18	6
PLANNED	8/19/2021	4	16	4
PLANNED	8/19/2021	1	131	131
PLANNED	8/19/2021	3	108	36
PLANNED	8/19/2021	2	182	91
PLANNED	8/19/2021	1	139	139
CUSTOMER REQUEST	8/19/2021	6	1,050	175
PLANNED	8/19/2021	1	5	5
PLANNED	8/19/2021	2	20	10
PLANNED	8/19/2021	6	876	198
PLANNED	8/19/2021	2	28	14
PLANNED	8/19/2021	3	51	17
PLANNED	8/19/2021	14	770	55
CUSTOMER REQUEST	8/19/2021	5	80	16
PLANNED	8/19/2021	7	588	84
PLANNED	8/19/2021	3	93	31
PLANNED	8/19/2021	9	72	8
PLANNED	8/19/2021	2	16	8
PLANNED	8/19/2021	10	480	48
CUSTOMER REQUEST	8/19/2021	8	64	8
PLANNED	8/19/2021	2	84	42
PLANNED	8/19/2021	2	22	11
PLANNED	8/19/2021	4	52	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/19/2021	4	260	65
CUSTOMER REQUEST	8/19/2021	1	120	120
PLANNED	8/19/2021	32	128	4
PLANNED	8/19/2021	3	381	127
PLANNED	8/19/2021	3	6	2
PLANNED	8/19/2021	7	392	56
PLANNED	8/19/2021	16	1,488	93
PLANNED	8/19/2021	4	44	11
PLANNED	8/19/2021	1	121	121
PLANNED	8/19/2021	2	44	22
PLANNED	8/19/2021	8	725	125
PLANNED	8/19/2021	10	1,002	137
PLANNED	8/19/2021	1	51	51
PLANNED	8/19/2021	2	54	27
PLANNED	8/19/2021	4	52	13
PLANNED	8/19/2021	1	46	46
PLANNED	8/19/2021	1	32	32
PLANNED	8/19/2021	7	77	11
PLANNED	8/19/2021	2	90	45
PLANNED	8/19/2021	1	32	32
PLANNED	8/19/2021	1	116	116
PLANNED	8/19/2021	2	266	133
PLANNED	8/19/2021	2	160	80
PLANNED	8/19/2021	4	792	198
PLANNED	8/19/2021	44	3,388	77
PLANNED	8/19/2021	1	17	17
PLANNED	8/19/2021	1	27	27
PLANNED	8/19/2021	2	28	14
PLANNED	8/19/2021	5	715	143
PLANNED	8/19/2021	4	140	35
PLANNED	8/19/2021	4	272	68
PLANNED	8/19/2021	7	126	18
PLANNED	8/19/2021	3	540	180
PLANNED	8/19/2021	6	186	31
PLANNED	8/19/2021	1	115	115
PLANNED	8/19/2021	12	1,836	153
PLANNED	8/19/2021	8	32	4
PLANNED	8/19/2021	3	471	157
PLANNED	8/19/2021	9	81	9
PLANNED	8/19/2021	6	582	97
CUSTOMER REQUEST	8/19/2021	1	87	87

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/19/2021	1	161	161
PLANNED	8/19/2021	1	24	24
PLANNED	8/19/2021	3	354	118
PLANNED	8/19/2021	1	62	62
PLANNED	8/19/2021	2	4	2
PLANNED	8/19/2021	10	940	94
PLANNED	8/19/2021	8	200	25
CUSTOMER REQUEST	8/19/2021	1	162	162
PLANNED	8/19/2021	8	144	18
PLANNED	8/19/2021	10	180	18
PLANNED	8/19/2021	6	108	18
CUSTOMER REQUEST	8/19/2021	20	260	13
PLANNED	8/19/2021	6	582	97
CUSTOMER REQUEST	8/19/2021	1	42	42
PLANNED	8/19/2021	3	741	247
PLANNED	8/19/2021	1	66	66
PLANNED	8/19/2021	9	270	30
PLANNED	8/19/2021	7	469	67
PLANNED	8/19/2021	17	731	43
PLANNED	8/19/2021	1	70	70
PLANNED	8/19/2021	2	100	50
CUSTOMER REQUEST	8/19/2021	1	51	51
PLANNED	8/19/2021	1	104	104
CUSTOMER REQUEST	8/19/2021	1	686	686
PLANNED	8/19/2021	4	1,472	368
PLANNED	8/19/2021	11	4,213	383
PLANNED	8/19/2021	1	77	77
PLANNED	8/19/2021	3	183	61
PLANNED	8/19/2021	1	363	363
PLANNED	8/19/2021	10	2,630	263
PLANNED	8/19/2021	6	816	136
PLANNED	8/20/2021	1	61	61
PLANNED	8/20/2021	1	98	98
PLANNED	8/20/2021	4	480	120
PLANNED	8/20/2021	1	47	47
PLANNED	8/20/2021	3	225	75
PLANNED	8/20/2021	3	258	127
PLANNED	8/20/2021	2	132	66
PLANNED	8/20/2021	10	540	54
PLANNED	8/20/2021	1	160	160
PLANNED	8/20/2021	1	108	108

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/20/2021	3	57	19
PLANNED	8/20/2021	5	55	11
PLANNED	8/20/2021	3	93	31
PLANNED	8/20/2021	4	2,380	595
PLANNED	8/20/2021	3	39	13
PLANNED	8/20/2021	6	96	16
PLANNED	8/20/2021	1	215	215
PLANNED	8/20/2021	4	424	106
PLANNED	8/20/2021	8	1,264	158
PLANNED	8/20/2021	2	32	16
PLANNED	8/20/2021	18	5,400	300
PLANNED	8/20/2021	1	23	23
PLANNED	8/20/2021	33	7,491	227
PLANNED	8/20/2021	11	2,002	182
PLANNED	8/20/2021	2	126	63
PLANNED	8/20/2021	49	6,321	129
PLANNED	8/20/2021	8	432	54
PLANNED	8/20/2021	2	214	107
PLANNED	8/20/2021	10	20	2
PLANNED	8/20/2021	17	595	35
PLANNED	8/20/2021	8	464	58
PLANNED	8/20/2021	3	159	53
PLANNED	8/20/2021	1	10	10
PLANNED	8/20/2021	3	36	12
PLANNED	8/20/2021	2	188	94
PLANNED	8/20/2021	2	66	33
PLANNED	8/20/2021	5	300	60
PLANNED	8/20/2021	2	194	97
PLANNED	8/20/2021	1	34	34
PLANNED	8/20/2021	10	980	98
PLANNED	8/20/2021	10	1,020	102
PLANNED	8/20/2021	9	1,089	121
PLANNED	8/20/2021	11	1,045	95
PLANNED	8/20/2021	2	24	12
PLANNED	8/20/2021	16	1,488	93
PLANNED	8/20/2021	4	88	22
PLANNED	8/20/2021	3	312	104
PLANNED	8/20/2021	1	288	288
PLANNED	8/20/2021	12	2,592	216
PLANNED	8/20/2021	2	56	28
PLANNED	8/20/2021	1	69	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/20/2021	11	319	29
PLANNED	8/20/2021	1	37	37
PLANNED	8/20/2021	1	75	75
PLANNED	8/20/2021	37	2,479	67
CUSTOMER REQUEST	8/20/2021	20	2,060	103
PLANNED	8/20/2021	2	235	154
PLANNED	8/20/2021	7	798	114
CUSTOMER REQUEST	8/20/2021	1	143	143
PLANNED	8/20/2021	1	57	57
CUSTOMER REQUEST	8/20/2021	4	44	11
PLANNED	8/20/2021	1	105	105
CUSTOMER REQUEST	8/20/2021	4	480	120
PLANNED	8/20/2021	6	428	130
PLANNED	8/20/2021	6	54	9
PLANNED	8/20/2021	1	27	27
PLANNED	8/20/2021	4	268	67
PLANNED	8/20/2021	13	1,131	87
PLANNED	8/20/2021	7	161	23
PLANNED	8/20/2021	4	100	25
PLANNED	8/20/2021	5	600	120
PLANNED	8/20/2021	8	712	89
PLANNED	8/20/2021	1	171	171
PLANNED	8/20/2021	1	53	53
PLANNED	8/20/2021	2	324	162
CUSTOMER REQUEST	8/20/2021	1	65	65
CUSTOMER REQUEST	8/20/2021	1	248	248
PLANNED	8/20/2021	1	277	277
PLANNED	8/20/2021	1	25	25
PLANNED	8/20/2021	1	153	153
CUSTOMER REQUEST	8/20/2021	13	1,976	152
PLANNED	8/21/2021	1	117	117
PLANNED	8/21/2021	14	952	68
PLANNED	8/21/2021	7	700	100
PLANNED	8/21/2021	35	3,430	98
PLANNED	8/21/2021	5	265	53
PLANNED	8/21/2021	16	992	62
PLANNED	8/21/2021	1	170	170
PLANNED	8/21/2021	1	186	186
PLANNED	8/21/2021	10	98	53
PLANNED	8/21/2021	1	141	141
PLANNED	8/21/2021	2	508	254

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/21/2021	4	360	90
PLANNED	8/21/2021	3	117	39
PLANNED	8/21/2021	1	107	107
PLANNED	8/21/2021	1	133	133
CUSTOMER REQUEST	8/21/2021	1	995	995
PLANNED	8/22/2021	9	450	50
PLANNED	8/22/2021	8	520	65
PLANNED	8/22/2021	3	477	159
PLANNED	8/22/2021	1	432	432
PLANNED	8/22/2021	9	567	63
PLANNED	8/22/2021	10	1,430	143
PLANNED	8/22/2021	1	108	108
PLANNED	8/22/2021	1	94	94
PLANNED	8/22/2021	1	200	200
PLANNED	8/22/2021	1	25	25
PLANNED	8/22/2021	4	144	36
PLANNED	8/22/2021	3	138	46
PLANNED	8/22/2021	1	219	219
PLANNED	8/22/2021	1	279	279
PLANNED	8/22/2021	12	516	43
PLANNED	8/22/2021	1	106	106
PLANNED	8/22/2021	1	105	105
PLANNED	8/22/2021	5	95	19
PLANNED	8/22/2021	4	900	225
PLANNED	8/22/2021	2	146	73
CUSTOMER REQUEST	8/22/2021	39	27,222	698
PLANNED	8/23/2021	1	159	159
CUSTOMER REQUEST	8/23/2021	3	48	16
PLANNED	8/23/2021	1	238	238
PLANNED	8/23/2021	5	685	137
PLANNED	8/23/2021	6	810	135
PLANNED	8/23/2021	4	536	134
PLANNED	8/23/2021	6	60	10
PLANNED	8/23/2021	2	181	122
PLANNED	8/23/2021	1	33	33
PLANNED	8/23/2021	1	60	60
PLANNED	8/23/2021	1	207	207
PLANNED	8/23/2021	46	2,678	73
PLANNED	8/23/2021	3	216	72
CUSTOMER REQUEST	8/23/2021	11	6,446	586
CUSTOMER REQUEST	8/23/2021	13	4,953	381

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/23/2021	3	207	104
PLANNED	8/23/2021	9	1,899	211
PLANNED	8/23/2021	6	600	100
PLANNED	8/23/2021	2	624	312
PLANNED	8/23/2021	16	240	15
PLANNED	8/23/2021	2	120	60
CUSTOMER REQUEST	8/23/2021	3	1,599	533
PLANNED	8/23/2021	6	1,944	324
PLANNED	8/23/2021	1	405	405
PLANNED	8/23/2021	78	12,948	166
CUSTOMER REQUEST	8/23/2021	7	581	83
PLANNED	8/23/2021	2	96	48
PLANNED	8/23/2021	3	168	56
PLANNED	8/23/2021	7	1,008	144
PLANNED	8/23/2021	7	1,337	191
PLANNED	8/23/2021	16	3,472	217
PLANNED	8/23/2021	159	8,904	56
PLANNED	8/23/2021	1	24	24
PLANNED	8/23/2021	2	32	16
PLANNED	8/23/2021	11	946	86
PLANNED	8/23/2021	2	50	25
PLANNED	8/23/2021	6	234	39
PLANNED	8/23/2021	7	98	14
PLANNED	8/23/2021	24	48	2
PLANNED	8/23/2021	8	1,000	125
PLANNED	8/23/2021	8	944	118
PLANNED	8/23/2021	3	162	54
CUSTOMER REQUEST	8/23/2021	1	125	125
PLANNED	8/23/2021	4	1,088	272
PLANNED	8/23/2021	8	48	6
PLANNED	8/23/2021	2	148	74
PLANNED	8/23/2021	2	166	118
PLANNED	8/23/2021	1	43	43
PLANNED	8/23/2021	6	330	55
CUSTOMER REQUEST	8/23/2021	1	446	446
PLANNED	8/23/2021	1	166	166
PLANNED	8/23/2021	3	231	77
PLANNED	8/23/2021	5	75	15
PLANNED	8/23/2021	5	145	29
PLANNED	8/23/2021	8	216	27
PLANNED	8/23/2021	3	261	87

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/23/2021	4	348	87
PLANNED	8/23/2021	1	89	89
PLANNED	8/23/2021	1	51	51
PLANNED	8/23/2021	1	104	104
PLANNED	8/23/2021	1	84	84
PLANNED	8/23/2021	6	126	21
CUSTOMER REQUEST	8/23/2021	1	297	297
PLANNED	8/23/2021	3	33	13
PLANNED	8/23/2021	3	102	34
PLANNED	8/23/2021	16	32	2
PLANNED	8/23/2021	5	740	148
PLANNED	8/23/2021	7	133	19
PLANNED	8/24/2021	1	45	45
PLANNED	8/24/2021	16	928	58
PLANNED	8/24/2021	4	356	89
PLANNED	8/24/2021	1	228	228
PLANNED	8/24/2021	3	165	55
PLANNED	8/24/2021	2	144	72
PLANNED	8/24/2021	6	900	150
PLANNED	8/24/2021	1	114	114
CUSTOMER REQUEST	8/24/2021	1	36	36
PLANNED	8/24/2021	2	294	147
PLANNED	8/24/2021	1	303	303
PLANNED	8/24/2021	4	204	51
PLANNED	8/24/2021	18	1,044	58
PLANNED	8/24/2021	10	2,340	234
PLANNED	8/24/2021	1	101	101
PLANNED	8/24/2021	8	176	22
PLANNED	8/24/2021	6	114	19
PLANNED	8/24/2021	2	162	81
CUSTOMER REQUEST	8/24/2021	1	94	94
PLANNED	8/24/2021	1	19	19
PLANNED	8/24/2021	3	192	64
PLANNED	8/24/2021	1	110	110
PLANNED	8/24/2021	2	174	87
PLANNED	8/24/2021	1	194	194
PLANNED	8/24/2021	3	1,590	530
PLANNED	8/24/2021	2	158	79
PLANNED	8/24/2021	1	398	398
PLANNED	8/24/2021	6	240	40
PLANNED	8/24/2021	2	810	405

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/24/2021	56	2,968	53
CUSTOMER REQUEST	8/24/2021	1	17	17
PLANNED	8/24/2021	5	70	14
PLANNED	8/24/2021	1	47	47
PLANNED	8/24/2021	85	6,460	76
PLANNED	8/24/2021	4	292	73
PLANNED	8/24/2021	5	640	128
PLANNED	8/24/2021	3	192	64
PLANNED	8/24/2021	1	278	278
PLANNED	8/24/2021	2	176	94
PLANNED	8/24/2021	41	2,501	61
PLANNED	8/24/2021	2	50	25
PLANNED	8/24/2021	2	22	11
PLANNED	8/24/2021	5	40	8
PLANNED	8/24/2021	9	360	40
PLANNED	8/24/2021	34	510	15
PLANNED	8/24/2021	1	9	9
PLANNED	8/24/2021	26	6,786	261
PLANNED	8/24/2021	5	645	129
PLANNED	8/24/2021	2	52	26
PLANNED	8/24/2021	1	101	101
PLANNED	8/24/2021	6	498	83
PLANNED	8/24/2021	3	784	312
PLANNED	8/24/2021	5	350	70
PLANNED	8/24/2021	2	368	184
PLANNED	8/24/2021	16	1,072	67
PLANNED	8/24/2021	20	1,860	93
PLANNED	8/24/2021	1	316	316
PLANNED	8/24/2021	3	375	125
PLANNED	8/24/2021	1	176	176
PLANNED	8/24/2021	2	124	62
PLANNED	8/24/2021	6	222	37
PLANNED	8/24/2021	1	63	63
PLANNED	8/24/2021	4	84	21
PLANNED	8/24/2021	2	10	5
PLANNED	8/24/2021	3	276	92
PLANNED	8/24/2021	13	247	19
PLANNED	8/24/2021	6	528	88
PLANNED	8/24/2021	8	32	4
PLANNED	8/24/2021	2	60	30
PLANNED	8/24/2021	1	21	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/24/2021	7	910	130
PLANNED	8/24/2021	12	552	46
PLANNED	8/24/2021	3	408	136
PLANNED	8/24/2021	8	2,080	260
PLANNED	8/24/2021	1	248	248
PLANNED	8/24/2021	2	174	87
PLANNED	8/24/2021	18	1,368	76
PLANNED	8/24/2021	4	332	83
PLANNED	8/24/2021	4	316	79
PLANNED	8/24/2021	4	416	104
PLANNED	8/24/2021	3	117	39
PLANNED	8/24/2021	1	45	45
PLANNED	8/24/2021	2	130	65
PLANNED	8/24/2021	1	94	94
PLANNED	8/24/2021	1	88	88
PLANNED	8/24/2021	8	376	47
CUSTOMER REQUEST	8/24/2021	5	80	16
PLANNED	8/24/2021	5	380	76
PLANNED	8/24/2021	2	246	123
PLANNED	8/24/2021	14	630	45
PLANNED	8/24/2021	17	1,649	97
PLANNED	8/24/2021	34	578	17
PLANNED	8/24/2021	1	19	19
PLANNED	8/24/2021	2	64	32
PLANNED	8/24/2021	1	46	46
CUSTOMER REQUEST	8/24/2021	364	1,216	214
PLANNED	8/24/2021	4	32	8
PLANNED	8/24/2021	4	552	138
PLANNED	8/24/2021	1	21	21
PLANNED	8/24/2021	5	55	11
PLANNED	8/24/2021	2	312	156
PLANNED	8/24/2021	1	209	209
PLANNED	8/24/2021	5	590	118
PLANNED	8/25/2021	1	134	134
PLANNED	8/25/2021	2	220	110
PLANNED	8/25/2021	2	140	70
PLANNED	8/25/2021	8	1,232	154
PLANNED	8/25/2021	2	118	59
PLANNED	8/25/2021	1	171	171
PLANNED	8/25/2021	1	59	59
PLANNED	8/25/2021	1	17	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/25/2021	1	59	59
PLANNED	8/25/2021	14	1,652	118
PLANNED	8/25/2021	2	190	95
PLANNED	8/25/2021	1	151	151
PLANNED	8/25/2021	1	114	114
PLANNED	8/25/2021	18	1,314	73
PLANNED	8/25/2021	1	241	241
PLANNED	8/25/2021	15	90	6
PLANNED	8/25/2021	10	1,370	137
PLANNED	8/25/2021	1	52	52
CUSTOMER REQUEST	8/25/2021	4	539	521
PLANNED	8/25/2021	6	804	134
PLANNED	8/25/2021	3	69	23
PLANNED	8/25/2021	6	516	86
PLANNED	8/25/2021	16	1,296	81
PLANNED	8/25/2021	4	344	86
PLANNED	8/25/2021	3	336	112
PLANNED	8/25/2021	2	84	42
PLANNED	8/25/2021	1	149	149
PLANNED	8/25/2021	45	8,690	209
PLANNED	8/25/2021	3	325	132
PLANNED	8/25/2021	3	132	44
PLANNED	8/25/2021	4	316	79
PLANNED	8/25/2021	1	53	53
PLANNED	8/25/2021	8	1,952	244
PLANNED	8/25/2021	4	1,309	565
PLANNED	8/25/2021	3	162	54
PLANNED	8/25/2021	7	455	65
PLANNED	8/25/2021	4	168	42
PLANNED	8/25/2021	1	43	43
PLANNED	8/25/2021	2	116	58
PLANNED	8/25/2021	8	852	192
PLANNED	8/25/2021	7	2,254	322
PLANNED	8/25/2021	4	144	36
PLANNED	8/25/2021	2	372	186
PLANNED	8/25/2021	19	3,230	170
PLANNED	8/25/2021	2	124	62
PLANNED	8/25/2021	4	208	52
PLANNED	8/25/2021	4	280	134
PLANNED	8/25/2021	4	68	17
PLANNED	8/25/2021	6	780	130

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/25/2021	3	99	33
PLANNED	8/25/2021	1	66	66
PLANNED	8/25/2021	2	116	58
PLANNED	8/25/2021	1	219	219
PLANNED	8/25/2021	4	876	219
PLANNED	8/25/2021	3	684	228
PLANNED	8/25/2021	2	456	228
PLANNED	8/25/2021	2	456	228
PLANNED	8/25/2021	1	228	228
PLANNED	8/25/2021	2	456	228
PLANNED	8/25/2021	1	228	228
PLANNED	8/25/2021	4	880	220
PLANNED	8/25/2021	1	219	219
PLANNED	8/25/2021	2	456	228
PLANNED	8/25/2021	3	657	219
PLANNED	8/25/2021	4	1,264	316
PLANNED	8/25/2021	12	720	60
PLANNED	8/25/2021	14	392	28
PLANNED	8/25/2021	5	210	42
PLANNED	8/25/2021	5	220	44
PLANNED	8/25/2021	2	126	63
PLANNED	8/25/2021	1	62	62
PLANNED	8/25/2021	1	27	27
PLANNED	8/25/2021	8	720	90
PLANNED	8/25/2021	1	96	96
PLANNED	8/25/2021	1	298	298
PLANNED	8/25/2021	14	1,580	226
PLANNED	8/25/2021	5	245	49
PLANNED	8/25/2021	2	170	85
PLANNED	8/25/2021	1	24	24
PLANNED	8/25/2021	4	976	244
PLANNED	8/25/2021	8	392	49
PLANNED	8/25/2021	1	69	69
PLANNED	8/25/2021	11	2,332	212
PLANNED	8/25/2021	6	252	42
PLANNED	8/25/2021	3	924	308
PLANNED	8/25/2021	4	544	136
PLANNED	8/25/2021	5	615	123
PLANNED	8/25/2021	7	882	126
PLANNED	8/25/2021	2	262	131
PLANNED	8/25/2021	4	840	210

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/25/2021	1	17	17
PLANNED	8/25/2021	8	256	32
PLANNED	8/25/2021	8	1,016	127
PLANNED	8/25/2021	4	68	17
PLANNED	8/25/2021	4	132	33
CUSTOMER REQUEST	8/25/2021	5	130	26
PLANNED	8/25/2021	5	450	90
PLANNED	8/25/2021	5	695	139
PLANNED	8/25/2021	1	70	70
PLANNED	8/25/2021	2	310	155
PLANNED	8/25/2021	9	171	19
CUSTOMER REQUEST	8/25/2021	1	10	10
PLANNED	8/25/2021	8	368	46
PLANNED	8/25/2021	8	336	42
PLANNED	8/25/2021	9	36	4
PLANNED	8/25/2021	4	220	55
PLANNED	8/25/2021	2	164	82
CUSTOMER REQUEST	8/25/2021	1	91	91
PLANNED	8/25/2021	9	963	107
CUSTOMER REQUEST	8/25/2021	1	232	232
PLANNED	8/25/2021	4	552	138
PLANNED	8/25/2021	2	254	127
CUSTOMER REQUEST	8/25/2021	1	102	102
PLANNED	8/25/2021	3	6	2
PLANNED	8/25/2021	13	1,274	98
PLANNED	8/25/2021	13	52	4
PLANNED	8/25/2021	11	385	35
PLANNED	8/25/2021	5	1,120	224
PLANNED	8/25/2021	4	444	111
PLANNED	8/25/2021	3	267	89
PLANNED	8/25/2021	3	84	28
PLANNED	8/25/2021	1	44	44
PLANNED	8/25/2021	1	81	81
PLANNED	8/25/2021	7	532	76
PLANNED	8/25/2021	1	17	17
PLANNED	8/25/2021	9	612	68
PLANNED	8/25/2021	2	182	91
PLANNED	8/25/2021	3	9	3
PLANNED	8/25/2021	7	413	59
PLANNED	8/25/2021	7	371	53
PLANNED	8/25/2021	4	20	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/25/2021	4	484	121
PLANNED	8/25/2021	1	24	24
PLANNED	8/25/2021	7	140	20
PLANNED	8/25/2021	1	18	18
PLANNED	8/25/2021	1	152	152
PLANNED	8/25/2021	1	38	38
CUSTOMER REQUEST	8/25/2021	21	8,001	381
PLANNED	8/25/2021	7	2,100	300
PLANNED	8/25/2021	15	1,770	118
PLANNED	8/26/2021	4	596	149
PLANNED	8/26/2021	2	154	77
PLANNED	8/26/2021	4	332	83
PLANNED	8/26/2021	14	924	66
PLANNED	8/26/2021	2	118	59
PLANNED	8/26/2021	1	58	58
PLANNED	8/26/2021	2	102	51
PLANNED	8/26/2021	15	1,860	124
PLANNED	8/26/2021	12	60	5
PLANNED	8/26/2021	16	16	1
PLANNED	8/26/2021	2	236	118
PLANNED	8/26/2021	2	154	77
PLANNED	8/26/2021	3	426	142
PLANNED	8/26/2021	5	725	145
PLANNED	8/26/2021	2	50	25
PLANNED	8/26/2021	4	528	132
PLANNED	8/26/2021	24	5,208	217
PLANNED	8/26/2021	10	260	26
PLANNED	8/26/2021	34	510	15
PLANNED	8/26/2021	7	532	76
PLANNED	8/26/2021	6	84	14
PLANNED	8/26/2021	8	48	6
PLANNED	8/26/2021	5	155	31
PLANNED	8/26/2021	5	240	48
PLANNED	8/26/2021	2	16	8
PLANNED	8/26/2021	10	720	72
PLANNED	8/26/2021	12	996	83
PLANNED	8/26/2021	14	1,162	83
PLANNED	8/26/2021	1	20	20
PLANNED	8/26/2021	2	148	74
PLANNED	8/26/2021	6	966	161
PLANNED	8/26/2021	3	186	62

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/26/2021	2	1,032	516
PLANNED	8/26/2021	1	146	146
PLANNED	8/26/2021	8	136	17
PLANNED	8/26/2021	2	136	68
PLANNED	8/26/2021	3	309	103
PLANNED	8/26/2021	2	234	117
PLANNED	8/26/2021	5	460	92
PLANNED	8/26/2021	3	36	12
PLANNED	8/26/2021	1	29	29
PLANNED	8/26/2021	10	320	32
PLANNED	8/26/2021	5	250	50
PLANNED	8/26/2021	2	408	204
PLANNED	8/26/2021	1	58	58
PLANNED	8/26/2021	8	240	30
PLANNED	8/26/2021	2	174	87
PLANNED	8/26/2021	4	312	78
PLANNED	8/26/2021	8	632	79
PLANNED	8/26/2021	2	188	94
PLANNED	8/26/2021	3	36	12
PLANNED	8/26/2021	2	54	27
PLANNED	8/26/2021	1	78	78
PLANNED	8/26/2021	24	1,296	54
PLANNED	8/26/2021	1	154	154
PLANNED	8/26/2021	17	408	24
PLANNED	8/26/2021	4	88	22
PLANNED	8/26/2021	1	184	184
CUSTOMER REQUEST	8/26/2021	7	1,211	173
PLANNED	8/26/2021	2	122	61
PLANNED	8/26/2021	22	2,134	97
PLANNED	8/26/2021	5	205	41
PLANNED	8/26/2021	2	90	45
PLANNED	8/26/2021	14	1,666	119
PLANNED	8/26/2021	4	160	40
PLANNED	8/26/2021	2	62	31
PLANNED	8/26/2021	1	108	108
PLANNED	8/26/2021	3	310	107
PLANNED	8/26/2021	1	9	9
PLANNED	8/26/2021	1	136	136
PLANNED	8/26/2021	1	38	38
PLANNED	8/26/2021	2	60	30
PLANNED	8/26/2021	3	264	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/26/2021	1	191	191
PLANNED	8/26/2021	10	20	2
PLANNED	8/26/2021	4	240	60
PLANNED	8/26/2021	2	148	74
PLANNED	8/26/2021	2	136	68
PLANNED	8/26/2021	1	32	32
PLANNED	8/26/2021	4	104	26
PLANNED	8/26/2021	3	285	95
PLANNED	8/26/2021	1	68	68
PLANNED	8/26/2021	1	64	64
PLANNED	8/26/2021	3	237	79
PLANNED	8/26/2021	24	1,488	62
PLANNED	8/26/2021	12	1,236	103
PLANNED	8/26/2021	1	73	73
PLANNED	8/26/2021	1	205	205
PLANNED	8/26/2021	2	348	174
PLANNED	8/26/2021	1	190	190
PLANNED	8/26/2021	1	130	130
PLANNED	8/26/2021	16	1,632	102
PLANNED	8/26/2021	5	1,005	201
PLANNED	8/26/2021	2	810	405
PLANNED	8/27/2021	4	676	169
PLANNED	8/27/2021	1	46	46
PLANNED	8/27/2021	1	123	123
PLANNED	8/27/2021	1	97	97
PLANNED	8/27/2021	2	264	132
PLANNED	8/27/2021	3	219	73
PLANNED	8/27/2021	1	214	214
PLANNED	8/27/2021	27	1,431	53
PLANNED	8/27/2021	6	1,206	201
PLANNED	8/27/2021	3	696	232
CUSTOMER REQUEST	8/27/2021	14	784	56
CUSTOMER REQUEST	8/27/2021	12	288	24
PLANNED	8/27/2021	4	672	168
PLANNED	8/27/2021	6	804	134
PLANNED	8/27/2021	3	453	151
PLANNED	8/27/2021	3	690	230
PLANNED	8/27/2021	2	48	24
PLANNED	8/27/2021	8	832	104
PLANNED	8/27/2021	7	728	104
PLANNED	8/27/2021	12	1,656	138

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/27/2021	57	2,109	37
PLANNED	8/27/2021	68	2,924	43
PLANNED	8/27/2021	5	755	151
PLANNED	8/27/2021	4	44	11
CUSTOMER REQUEST	8/27/2021	25	2,225	89
PLANNED	8/27/2021	1	136	136
PLANNED	8/27/2021	4	176	44
PLANNED	8/27/2021	1	116	116
PLANNED	8/27/2021	26	1,586	61
CUSTOMER REQUEST	8/27/2021	1	14	14
PLANNED	8/27/2021	4	484	121
PLANNED	8/27/2021	13	481	37
PLANNED	8/27/2021	1	296	296
PLANNED	8/27/2021	2	158	79
PLANNED	8/27/2021	8	840	105
PLANNED	8/27/2021	4	492	123
PLANNED	8/27/2021	3	282	94
PLANNED	8/27/2021	1	12	12
PLANNED	8/27/2021	7	1,176	168
PLANNED	8/27/2021	32	10,048	314
PLANNED	8/27/2021	4	108	27
PLANNED	8/27/2021	18	468	26
PLANNED	8/27/2021	12	1,788	149
PLANNED	8/27/2021	11	1,639	149
PLANNED	8/27/2021	13	1,950	150
PLANNED	8/27/2021	8	1,000	125
PLANNED	8/27/2021	7	147	21
PLANNED	8/27/2021	4	480	120
PLANNED	8/27/2021	10	600	60
PLANNED	8/27/2021	1	6	6
PLANNED	8/27/2021	3	783	261
PLANNED	8/28/2021	3	345	115
PLANNED	8/28/2021	1	57	57
PLANNED	8/28/2021	1	277	277
PLANNED	8/28/2021	14	1,088	207
PLANNED	8/28/2021	1	193	193
PLANNED	8/28/2021	1	339	339
PLANNED	8/28/2021	2	30	15
PLANNED	8/29/2021	13	2,132	164
PLANNED	8/29/2021	2	262	131
PLANNED	8/29/2021	1	232	232

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/29/2021	1	150	150
PLANNED	8/29/2021	5	85	17
PLANNED	8/29/2021	12	48	4
PLANNED	8/29/2021	10	110	11
PLANNED	8/29/2021	2	12	6
PLANNED	8/29/2021	2	82	41
PLANNED	8/29/2021	2	234	117
PLANNED	8/30/2021	13	3,406	262
PLANNED	8/30/2021	1	24	24
PLANNED	8/30/2021	3	424	266
PLANNED	8/30/2021	2	148	74
PLANNED	8/30/2021	2	134	67
PLANNED	8/30/2021	2	258	129
CUSTOMER REQUEST	8/30/2021	14	2,254	161
PLANNED	8/30/2021	10	180	18
PLANNED	8/30/2021	3	114	38
PLANNED	8/30/2021	13	624	48
PLANNED	8/30/2021	2	268	134
CUSTOMER REQUEST	8/30/2021	38	12,274	323
PLANNED	8/30/2021	6	2,214	369
PLANNED	8/30/2021	11	979	89
PLANNED	8/30/2021	1	182	182
PLANNED	8/30/2021	7	21	3
PLANNED	8/30/2021	6	240	40
PLANNED	8/30/2021	4	64	16
PLANNED	8/30/2021	14	616	44
PLANNED	8/30/2021	12	252	21
PLANNED	8/30/2021	6	60	10
PLANNED	8/30/2021	3	90	30
PLANNED	8/30/2021	2	212	106
PLANNED	8/30/2021	25	1,525	61
CUSTOMER REQUEST	8/30/2021	8	232	29
PLANNED	8/30/2021	1	16	16
PLANNED	8/30/2021	32	3,968	124
PLANNED	8/30/2021	4	284	71
PLANNED	8/30/2021	115	4,255	37
PLANNED	8/30/2021	5	25	5
PLANNED	8/30/2021	2	428	214
CUSTOMER REQUEST	8/30/2021	1	333	333
PLANNED	8/30/2021	3	132	44
PLANNED	8/30/2021	4	360	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/30/2021	2	158	79
PLANNED	8/30/2021	36	2,952	82
PLANNED	8/30/2021	3	93	31
PLANNED	8/30/2021	1	30	30
PLANNED	8/30/2021	3	156	52
PLANNED	8/30/2021	1	31	31
PLANNED	8/30/2021	7	518	74
CUSTOMER REQUEST	8/30/2021	1	1,465	1,465
PLANNED	8/30/2021	3	30	10
PLANNED	8/30/2021	7	378	54
PLANNED	8/30/2021	1	24	24
CUSTOMER REQUEST	8/30/2021	1	89	89
PLANNED	8/30/2021	25	1,750	70
PLANNED	8/30/2021	5	175	35
PLANNED	8/30/2021	4	204	51
PLANNED	8/30/2021	9	63	7
PLANNED	8/30/2021	3	84	28
CUSTOMER REQUEST	8/30/2021	8	24	3
PLANNED	8/30/2021	2	114	57
PLANNED	8/30/2021	9	549	61
PLANNED	8/30/2021	8	184	23
CUSTOMER REQUEST	8/30/2021	1	85	85
CUSTOMER REQUEST	8/30/2021	1	68	68
PLANNED	8/30/2021	2	70	35
PLANNED	8/30/2021	1	12	12
CUSTOMER REQUEST	8/30/2021	1	60	60
PLANNED	8/30/2021	1	72	72
PLANNED	8/30/2021	1	132	132
PLANNED	8/30/2021	1	135	135
CUSTOMER REQUEST	8/30/2021	2	1,286	643
PLANNED	8/31/2021	4	220	55
PLANNED	8/31/2021	1	215	215
PLANNED	8/31/2021	3	252	84
PLANNED	8/31/2021	2	88	44
CUSTOMER REQUEST	8/31/2021	18	2,838	463
PLANNED	8/31/2021	4	200	50
PLANNED	8/31/2021	2	156	78
PLANNED	8/31/2021	16	432	27
PLANNED	8/31/2021	3	207	69
PLANNED	8/31/2021	7	588	84
PLANNED	8/31/2021	3	384	128

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/31/2021	3	588	196
PLANNED	8/31/2021	2	224	112
PLANNED	8/31/2021	4	428	145
PLANNED	8/31/2021	1	296	296
PLANNED	8/31/2021	18	36	2
PLANNED	8/31/2021	18	288	16
PLANNED	8/31/2021	3	21	7
PLANNED	8/31/2021	2	374	187
PLANNED	8/31/2021	5	235	47
PLANNED	8/31/2021	5	504	153
PLANNED	8/31/2021	1	85	85
PLANNED	8/31/2021	1	85	85
PLANNED	8/31/2021	25	8,675	347
PLANNED	8/31/2021	2	199	105
PLANNED	8/31/2021	2	354	177
PLANNED	8/31/2021	2	536	268
PLANNED	8/31/2021	3	414	138
PLANNED	8/31/2021	8	1,384	173
PLANNED	8/31/2021	4	44	11
PLANNED	8/31/2021	8	264	33
PLANNED	8/31/2021	12	2,688	224
PLANNED	8/31/2021	1	56	56
PLANNED	8/31/2021	4	165	123
CUSTOMER REQUEST	8/31/2021	9	63	7
PLANNED	8/31/2021	9	1,872	208
PLANNED	8/31/2021	3	357	119
PLANNED	8/31/2021	5	560	112
PLANNED	8/31/2021	3	561	205
PLANNED	8/31/2021	20	1,880	94
PLANNED	8/31/2021	3	417	139
PLANNED	8/31/2021	1	41	41
PLANNED	8/31/2021	3	717	239
PLANNED	8/31/2021	1	154	154
PLANNED	8/31/2021	7	700	100
PLANNED	8/31/2021	9	657	73
PLANNED	8/31/2021	8	600	75
PLANNED	8/31/2021	8	560	70
PLANNED	8/31/2021	38	3,970	110
PLANNED	8/31/2021	5	265	53
PLANNED	8/31/2021	4	768	192
PLANNED	8/31/2021	5	980	196

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/31/2021	6	1,128	188
PLANNED	8/31/2021	6	49	9
PLANNED	8/31/2021	1	71	71
PLANNED	8/31/2021	2	116	58
PLANNED	8/31/2021	4	332	83
PLANNED	8/31/2021	6	408	68
PLANNED	8/31/2021	3	51	17
PLANNED	8/31/2021	1	109	109
PLANNED	8/31/2021	4	308	77
PLANNED	8/31/2021	1	88	88
PLANNED	8/31/2021	8	1,448	181
PLANNED	8/31/2021	7	847	121
PLANNED	8/31/2021	5	600	120
PLANNED	8/31/2021	8	56	7
PLANNED	8/31/2021	2	218	109
PLANNED	8/31/2021	2	398	199
CUSTOMER REQUEST	8/31/2021	9	2,025	225
PLANNED	8/31/2021	1	22	22
PLANNED	8/31/2021	6	318	53
PLANNED	8/31/2021	2	222	111
PLANNED	8/31/2021	10	850	85
PLANNED	8/31/2021	4	280	70
CUSTOMER REQUEST	8/31/2021	1	35	35
PLANNED	8/31/2021	1	11	11
PLANNED	8/31/2021	14	616	44
PLANNED	8/31/2021	6	162	27
PLANNED	8/31/2021	5	25	5
PLANNED	8/31/2021	1	131	131
PLANNED	8/31/2021	4	16	4
PLANNED	8/31/2021	4	160	40
PLANNED	8/31/2021	2	66	33
PLANNED	8/31/2021	2	44	22
PLANNED	8/31/2021	1	9	9
PLANNED	8/31/2021	1	26	26
CUSTOMER REQUEST	8/31/2021	1	102	102
PLANNED	8/31/2021	6	36	6
PLANNED	8/31/2021	1	37	37
PLANNED	8/31/2021	1	179	179
CUSTOMER REQUEST	8/31/2021	1	768	768
PLANNED	8/31/2021	19	2,014	106
PLANNED	8/31/2021	9	657	73

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	8/31/2021	1	56	56
PLANNED	9/2/2021	1	51	51
CUSTOMER REQUEST	9/2/2021	7	161	23
CUSTOMER REQUEST	9/2/2021	7	35	5
PLANNED	9/2/2021	6	366	61
PLANNED	9/2/2021	4	148	37
CUSTOMER REQUEST	9/2/2021	3	12	4
PLANNED	9/2/2021	23	1,794	78
PLANNED	9/2/2021	28	3,892	139
CUSTOMER REQUEST	9/2/2021	5	15	3
PLANNED	9/2/2021	1	75	75
PLANNED	9/2/2021	6	390	65
PLANNED	9/2/2021	6	384	64
PLANNED	9/2/2021	5	155	31
PLANNED	9/2/2021	19	1,083	57
PLANNED	9/2/2021	4	68	17
CUSTOMER REQUEST	9/2/2021	13	1,196	92
PLANNED	9/2/2021	1	37	37
CUSTOMER REQUEST	9/2/2021	2	14	7
PLANNED	9/2/2021	4	132	33
CUSTOMER REQUEST	9/2/2021	5	20	4
PLANNED	9/2/2021	2	288	144
PLANNED	9/3/2021	6	1,218	203
PLANNED	9/3/2021	1	117	117
CUSTOMER REQUEST	9/3/2021	1	114	114
PLANNED	9/3/2021	5	165	33
PLANNED	9/3/2021	3	831	277
PLANNED	9/3/2021	37	8,695	235
PLANNED	9/3/2021	33	3,267	99
PLANNED	9/3/2021	5	490	98
PLANNED	9/3/2021	5	95	19
PLANNED	9/3/2021	1	103	103
PLANNED	9/3/2021	1	15	15
PLANNED	9/3/2021	2	368	184
PLANNED	9/3/2021	7	77	11
PLANNED	9/3/2021	5	955	191
PLANNED	9/3/2021	7	798	114
PLANNED	9/3/2021	4	672	168
PLANNED	9/3/2021	1	195	195
PLANNED	9/3/2021	1	132	132
PLANNED	9/3/2021	6	306	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/3/2021	3	153	51
CUSTOMER REQUEST	9/3/2021	3	906	302
PLANNED	9/3/2021	1	43	43
CUSTOMER REQUEST	9/3/2021	1	68	68
PLANNED	9/3/2021	77	3,080	40
PLANNED	9/3/2021	27	2,646	98
PLANNED	9/3/2021	11	4,400	400
PLANNED	9/3/2021	7	2,786	398
PLANNED	9/3/2021	12	384	32
PLANNED	9/3/2021	1	238	238
PLANNED	9/3/2021	1	6	6
PLANNED	9/3/2021	10	1,220	122
PLANNED	9/3/2021	10	440	44
PLANNED	9/3/2021	7	651	93
PLANNED	9/3/2021	1	329	329
PLANNED	9/3/2021	5	215	43
PLANNED	9/3/2021	2	58	29
PLANNED	9/3/2021	2	130	65
CUSTOMER REQUEST	9/3/2021	4	36	9
PLANNED	9/3/2021	2	42	21
CUSTOMER REQUEST	9/3/2021	2	28	14
PLANNED	9/3/2021	2	104	52
PLANNED	9/3/2021	15	1,320	88
PLANNED	9/3/2021	12	2,916	243
PLANNED	9/3/2021	11	2,662	242
PLANNED	9/3/2021	11	2,662	242
PLANNED	9/3/2021	12	732	61
PLANNED	9/3/2021	1	249	249
PLANNED	9/3/2021	12	228	19
PLANNED	9/3/2021	9	270	30
PLANNED	9/3/2021	3	207	69
PLANNED	9/3/2021	7	42	6
PLANNED	9/3/2021	4	80	20
PLANNED	9/3/2021	2	302	151
PLANNED	9/3/2021	1	7	7
CUSTOMER REQUEST	9/3/2021	1	136	136
PLANNED	9/3/2021	8	568	71
CUSTOMER REQUEST	9/3/2021	1	587	587
CUSTOMER REQUEST	9/3/2021	1	266	266
PLANNED	9/3/2021	10	1,760	176
PLANNED	9/3/2021	1	241	241

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/3/2021	1	105	105
PLANNED	9/4/2021	4	868	217
PLANNED	9/4/2021	1	91	91
PLANNED	9/4/2021	1	191	191
PLANNED	9/4/2021	1	379	379
CUSTOMER REQUEST	9/4/2021	1	287	287
PLANNED	9/4/2021	3	102	34
PLANNED	9/4/2021	1	249	249
PLANNED	9/4/2021	1	116	116
PLANNED	9/4/2021	1	259	259
PLANNED	9/4/2021	7	105	15
PLANNED	9/4/2021	2	186	93
PLANNED	9/4/2021	1	49	49
PLANNED	9/4/2021	1	58	58
CUSTOMER REQUEST	9/4/2021	30	3,270	109
PLANNED	9/4/2021	1	32	32
PLANNED	9/4/2021	8	1,576	197
PLANNED	9/4/2021	3	330	110
PLANNED	9/5/2021	1	247	247
CUSTOMER REQUEST	9/5/2021	1,097	25,231	23
PLANNED	9/5/2021	1	168	168
PLANNED	9/5/2021	1	248	248
PLANNED	9/5/2021	3	495	165
PLANNED	9/5/2021	10	220	22
PLANNED	9/5/2021	6	450	75
PLANNED	9/5/2021	1	85	85
CUSTOMER REQUEST	9/5/2021	1	132	132
PLANNED	9/5/2021	3	219	73
PLANNED	9/5/2021	7	252	36
PLANNED	9/5/2021	7	119	17
PLANNED	9/6/2021	21	4,221	201
CUSTOMER REQUEST	9/6/2021	7	70	10
PLANNED	9/6/2021	5	70	14
PLANNED	9/6/2021	3	45	15
PLANNED	9/6/2021	3	36	12
PLANNED	9/6/2021	3	95	46
CUSTOMER REQUEST	9/6/2021	1	195	195
PLANNED	9/6/2021	25	2,350	94
PLANNED	9/7/2021	44	8,712	198
PLANNED	9/7/2021	1	104	104
PLANNED	9/7/2021	2	136	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/7/2021	13	1,079	83
PLANNED	9/7/2021	1	51	51
PLANNED	9/7/2021	5	75	15
PLANNED	9/7/2021	1	98	98
PLANNED	9/7/2021	3	217	82
PLANNED	9/7/2021	3	425	208
PLANNED	9/7/2021	4	72	18
PLANNED	9/7/2021	5	245	49
CUSTOMER REQUEST	9/7/2021	26	338	13
PLANNED	9/7/2021	2	234	117
PLANNED	9/7/2021	2	186	93
PLANNED	9/7/2021	3	69	23
PLANNED	9/7/2021	2	562	281
PLANNED	9/7/2021	9	2,484	276
PLANNED	9/7/2021	1	67	67
PLANNED	9/7/2021	2	18	9
PLANNED	9/7/2021	2	272	136
PLANNED	9/7/2021	11	55	5
PLANNED	9/7/2021	4	44	11
PLANNED	9/7/2021	2	166	83
PLANNED	9/7/2021	5	59	13
PLANNED	9/7/2021	2	40	20
PLANNED	9/7/2021	2	156	78
PLANNED	9/7/2021	10	990	99
PLANNED	9/7/2021	2	104	52
PLANNED	9/7/2021	10	160	16
PLANNED	9/7/2021	29	4,031	139
PLANNED	9/7/2021	3	51	17
PLANNED	9/7/2021	3	459	153
PLANNED	9/7/2021	3	561	187
PLANNED	9/7/2021	10	350	35
PLANNED	9/7/2021	2	44	22
PLANNED	9/7/2021	1	138	138
PLANNED	9/7/2021	8	160	20
PLANNED	9/7/2021	4	60	15
PLANNED	9/7/2021	6	66	11
PLANNED	9/7/2021	85	9,010	106
PLANNED	9/7/2021	6	294	49
PLANNED	9/7/2021	1	43	43
PLANNED	9/7/2021	3	87	29
PLANNED	9/7/2021	4	48	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/7/2021	19	1,045	55
PLANNED	9/7/2021	3	21	7
PLANNED	9/7/2021	4	416	104
PLANNED	9/7/2021	6	612	102
PLANNED	9/7/2021	10	300	30
PLANNED	9/7/2021	5	240	48
PLANNED	9/7/2021	4	56	14
PLANNED	9/7/2021	8	16	2
PLANNED	9/7/2021	4	336	84
PLANNED	9/7/2021	2	282	141
PLANNED	9/7/2021	3	73	51
PLANNED	9/7/2021	2	174	87
PLANNED	9/7/2021	5	150	30
PLANNED	9/7/2021	4	116	29
PLANNED	9/7/2021	20	320	16
PLANNED	9/7/2021	9	522	58
PLANNED	9/7/2021	8	320	40
PLANNED	9/7/2021	3	141	47
PLANNED	9/7/2021	1	20	20
PLANNED	9/7/2021	2	228	114
PLANNED	9/7/2021	3	207	69
PLANNED	9/7/2021	2	94	47
PLANNED	9/7/2021	8	64	8
PLANNED	9/7/2021	4	120	30
PLANNED	9/7/2021	4	152	38
PLANNED	9/7/2021	13	1,131	87
PLANNED	9/7/2021	1	90	90
PLANNED	9/7/2021	1	361	361
PLANNED	9/7/2021	1	115	115
PLANNED	9/7/2021	1	157	157
PLANNED	9/8/2021	6	612	102
PLANNED	9/8/2021	1	85	85
PLANNED	9/8/2021	2	292	146
CUSTOMER REQUEST	9/8/2021	1	90	90
PLANNED	9/8/2021	16	2,512	157
PLANNED	9/8/2021	6	2,928	488
CUSTOMER REQUEST	9/8/2021	1	59	59
PLANNED	9/8/2021	2	222	111
PLANNED	9/8/2021	7	637	91
PLANNED	9/8/2021	1	72	72
PLANNED	9/8/2021	8	1,208	151

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/8/2021	7	693	99
PLANNED	9/8/2021	9	1,350	150
PLANNED	9/8/2021	8	1,200	150
PLANNED	9/8/2021	2	216	108
PLANNED	9/8/2021	6	894	149
PLANNED	9/8/2021	1	23	23
CUSTOMER REQUEST	9/8/2021	6	210	35
PLANNED	9/8/2021	2	152	76
PLANNED	9/8/2021	6	246	41
PLANNED	9/8/2021	2	314	157
PLANNED	9/8/2021	5	170	34
PLANNED	9/8/2021	6	60	10
PLANNED	9/8/2021	23	4,715	205
PLANNED	9/8/2021	1	177	177
PLANNED	9/8/2021	9	1,890	210
PLANNED	9/8/2021	4	612	153
PLANNED	9/8/2021	8	2,680	335
PLANNED	9/8/2021	11	2,717	247
PLANNED	9/8/2021	13	325	25
PLANNED	9/8/2021	2	768	384
PLANNED	9/8/2021	7	728	104
PLANNED	9/8/2021	15	1,215	81
PLANNED	9/8/2021	107	17,334	162
PLANNED	9/8/2021	72	16,992	236
PLANNED	9/8/2021	11	352	32
PLANNED	9/8/2021	2	328	164
CUSTOMER REQUEST	9/8/2021	3	39	13
CUSTOMER REQUEST	9/8/2021	3	69	23
PLANNED	9/8/2021	2	924	462
PLANNED	9/8/2021	26	1,846	71
PLANNED	9/8/2021	8	528	66
PLANNED	9/8/2021	1	49	49
PLANNED	9/8/2021	6	546	91
PLANNED	9/8/2021	8	296	37
PLANNED	9/8/2021	7	357	51
PLANNED	9/8/2021	39	2,496	64
PLANNED	9/8/2021	2	20	10
PLANNED	9/8/2021	78	6,474	83
PLANNED	9/8/2021	7	469	67
PLANNED	9/8/2021	6	204	34
PLANNED	9/8/2021	8	536	67

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/8/2021	27	2,781	103
PLANNED	9/8/2021	1	114	114
CUSTOMER REQUEST	9/8/2021	13	819	63
PLANNED	9/8/2021	15	1,230	82
PLANNED	9/8/2021	1	182	182
PLANNED	9/9/2021	2	116	58
PLANNED	9/9/2021	4	180	45
PLANNED	9/9/2021	5	530	106
PLANNED	9/9/2021	1	133	133
PLANNED	9/9/2021	7	189	27
PLANNED	9/9/2021	4	248	62
PLANNED	9/9/2021	5	250	50
PLANNED	9/9/2021	9	405	45
PLANNED	9/9/2021	9	414	46
PLANNED	9/9/2021	7	322	46
PLANNED	9/9/2021	3	639	213
PLANNED	9/9/2021	36	900	25
CUSTOMER REQUEST	9/9/2021	91	17,654	194
PLANNED	9/9/2021	27	3,483	129
PLANNED	9/9/2021	54	594	11
PLANNED	9/9/2021	6	498	83
PLANNED	9/9/2021	4	276	69
PLANNED	9/9/2021	8	376	47
PLANNED	9/9/2021	5	185	37
PLANNED	9/9/2021	5	220	44
CUSTOMER REQUEST	9/9/2021	1	153	153
PLANNED	9/9/2021	7	2,646	378
PLANNED	9/9/2021	2	196	98
PLANNED	9/9/2021	1	252	252
PLANNED	9/9/2021	9	1,710	190
PLANNED	9/9/2021	63	6,111	97
CUSTOMER REQUEST	9/9/2021	150	15,750	105
PLANNED	9/9/2021	11	825	75
PLANNED	9/9/2021	1	36	36
PLANNED	9/9/2021	1	39	39
PLANNED	9/9/2021	1	52	52
PLANNED	9/9/2021	2	104	52
PLANNED	9/9/2021	13	572	44
PLANNED	9/9/2021	4	300	75
PLANNED	9/9/2021	7	574	82
PLANNED	9/9/2021	106	848	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/9/2021	3	970	372
PLANNED	9/9/2021	10	1,410	141
PLANNED	9/9/2021	4	204	51
PLANNED	9/9/2021	2	214	107
CUSTOMER REQUEST	9/9/2021	1	136	136
PLANNED	9/9/2021	5	505	101
PLANNED	9/9/2021	11	1,331	121
PLANNED	9/9/2021	1	150	150
PLANNED	9/9/2021	2	448	224
PLANNED	9/10/2021	3	228	76
PLANNED	9/10/2021	1	183	183
PLANNED	9/10/2021	6	1,068	178
PLANNED	9/10/2021	19	1,292	68
PLANNED	9/10/2021	12	912	76
PLANNED	9/10/2021	5	230	46
PLANNED	9/10/2021	7	203	29
PLANNED	9/10/2021	8	1,068	198
PLANNED	9/10/2021	2	298	149
PLANNED	9/10/2021	1	94	94
PLANNED	9/10/2021	1	31	31
CUSTOMER REQUEST	9/10/2021	11	2,739	249
PLANNED	9/10/2021	4	16	4
PLANNED	9/10/2021	12	1,224	102
PLANNED	9/10/2021	10	680	68
PLANNED	9/10/2021	2	372	186
PLANNED	9/10/2021	2	270	135
PLANNED	9/10/2021	3	312	104
PLANNED	9/10/2021	4	84	21
CUSTOMER REQUEST	9/10/2021	99	27,324	276
PLANNED	9/10/2021	9	342	38
CUSTOMER REQUEST	9/10/2021	35	175	5
PLANNED	9/10/2021	5	370	74
CUSTOMER REQUEST	9/10/2021	11	726	66
PLANNED	9/10/2021	1	14	14
PLANNED	9/10/2021	10	990	99
PLANNED	9/10/2021	2	64	32
PLANNED	9/10/2021	1	1	1
PLANNED	9/10/2021	3	570	190
PLANNED	9/10/2021	4	788	197
PLANNED	9/10/2021	11	561	51
PLANNED	9/10/2021	8	144	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/10/2021	4	72	18
PLANNED	9/10/2021	7	119	17
PLANNED	9/10/2021	3	183	61
PLANNED	9/10/2021	7	140	20
PLANNED	9/10/2021	2	56	28
PLANNED	9/10/2021	48	2,880	60
PLANNED	9/10/2021	1	84	84
PLANNED	9/10/2021	2	28	14
PLANNED	9/10/2021	4	224	56
PLANNED	9/10/2021	4	552	138
CUSTOMER REQUEST	9/10/2021	1	225	225
CUSTOMER REQUEST	9/10/2021	1	60	60
PLANNED	9/10/2021	2	66	33
PLANNED	9/10/2021	14	2,632	188
PLANNED	9/10/2021	23	2,691	117
PLANNED	9/10/2021	10	310	31
PLANNED	9/11/2021	2	684	342
PLANNED	9/11/2021	11	4,664	424
PLANNED	9/11/2021	2	220	110
PLANNED	9/11/2021	17	1,224	72
PLANNED	9/11/2021	17	1,360	80
CUSTOMER REQUEST	9/11/2021	1	84	84
PLANNED	9/12/2021	2	202	101
PLANNED	9/12/2021	2	660	330
PLANNED	9/12/2021	1	13	13
PLANNED	9/12/2021	3	927	309
PLANNED	9/12/2021	4	120	30
PLANNED	9/12/2021	8	104	13
PLANNED	9/13/2021	47	3,431	73
PLANNED	9/13/2021	13	962	74
PLANNED	9/13/2021	25	1,850	74
PLANNED	9/13/2021	2	83	46
PLANNED	9/13/2021	12	432	36
PLANNED	9/13/2021	8	432	54
PLANNED	9/13/2021	3	873	291
PLANNED	9/13/2021	6	506	152
CUSTOMER REQUEST	9/13/2021	2	42	21
PLANNED	9/13/2021	6	1,128	188
PLANNED	9/13/2021	1	62	62
PLANNED	9/13/2021	2	340	170
PLANNED	9/13/2021	7	1,981	283

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/13/2021	4	452	113
CUSTOMER REQUEST	9/13/2021	21	4,347	207
CUSTOMER REQUEST	9/13/2021	2	50	25
PLANNED	9/13/2021	5	260	52
PLANNED	9/13/2021	29	6,989	241
PLANNED	9/13/2021	2	92	46
PLANNED	9/13/2021	1	40	40
PLANNED	9/13/2021	13	52	4
CUSTOMER REQUEST	9/13/2021	7	280	40
PLANNED	9/13/2021	4	420	105
CUSTOMER REQUEST	9/13/2021	1	136	136
PLANNED	9/13/2021	2	224	112
PLANNED	9/13/2021	4	8	2
PLANNED	9/13/2021	16	1,184	74
PLANNED	9/13/2021	2	74	37
PLANNED	9/13/2021	3	216	72
PLANNED	9/13/2021	6	270	45
PLANNED	9/13/2021	11	704	64
PLANNED	9/13/2021	7	161	23
PLANNED	9/13/2021	2	392	196
PLANNED	9/13/2021	12	228	19
PLANNED	9/13/2021	8	288	36
PLANNED	9/13/2021	1	22	22
PLANNED	9/13/2021	3	228	76
PLANNED	9/13/2021	3	96	32
PLANNED	9/13/2021	7	1,330	190
PLANNED	9/13/2021	7	441	63
PLANNED	9/13/2021	7	875	125
PLANNED	9/13/2021	12	84	7
CUSTOMER REQUEST	9/13/2021	2	46	23
PLANNED	9/13/2021	9	441	49
PLANNED	9/13/2021	2	134	67
PLANNED	9/13/2021	6	252	42
PLANNED	9/13/2021	1	40	40
PLANNED	9/13/2021	6	174	29
PLANNED	9/13/2021	4	592	148
CUSTOMER REQUEST	9/13/2021	1	118	118
PLANNED	9/13/2021	1	19	19
CUSTOMER REQUEST	9/13/2021	7	42	6
PLANNED	9/13/2021	1	229	229
PLANNED	9/13/2021	2	100	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/13/2021	33	1,089	33
PLANNED	9/13/2021	16	336	21
PLANNED	9/13/2021	3	72	24
PLANNED	9/13/2021	10	720	72
PLANNED	9/13/2021	1	43	43
CUSTOMER REQUEST	9/13/2021	1	618	618
PLANNED	9/13/2021	4	616	154
PLANNED	9/13/2021	1	287	287
PLANNED	9/14/2021	1	265	265
PLANNED	9/14/2021	1	49	49
PLANNED	9/14/2021	1	152	152
PLANNED	9/14/2021	18	180	10
CUSTOMER REQUEST	9/14/2021	1	349	349
PLANNED	9/14/2021	3	450	150
PLANNED	9/14/2021	3	204	68
PLANNED	9/14/2021	1	53	53
PLANNED	9/14/2021	1	23	23
PLANNED	9/14/2021	1	49	49
CUSTOMER REQUEST	9/14/2021	1,042	7,778	15
CUSTOMER REQUEST	9/14/2021	5	1,276	318
PLANNED	9/14/2021	26	769	569
PLANNED	9/14/2021	7	168	24
PLANNED	9/14/2021	1	150	150
PLANNED	9/14/2021	3	246	102
PLANNED	9/14/2021	2	136	68
PLANNED	9/14/2021	7	448	64
PLANNED	9/14/2021	1	24	24
PLANNED	9/14/2021	2	134	67
PLANNED	9/14/2021	2	400	200
PLANNED	9/14/2021	12	60	5
PLANNED	9/14/2021	39	4,524	116
PLANNED	9/14/2021	23	3,772	164
PLANNED	9/14/2021	3	345	115
PLANNED	9/14/2021	1	46	46
PLANNED	9/14/2021	1	82	82
PLANNED	9/14/2021	2	300	150
PLANNED	9/14/2021	5	195	39
PLANNED	9/14/2021	128	3,840	30
PLANNED	9/14/2021	15	480	32
PLANNED	9/14/2021	8	472	59
PLANNED	9/14/2021	14	42	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/14/2021	4	304	92
CUSTOMER REQUEST	9/14/2021	6	644	306
PLANNED	9/14/2021	7	189	27
PLANNED	9/14/2021	7	2,058	294
PLANNED	9/14/2021	41	11,275	275
PLANNED	9/14/2021	1	11	11
PLANNED	9/14/2021	10	1,210	121
PLANNED	9/14/2021	1	34	34
PLANNED	9/14/2021	10	499	67
PLANNED	9/14/2021	1	100	100
PLANNED	9/14/2021	7	245	59
PLANNED	9/14/2021	1	190	190
PLANNED	9/14/2021	5	145	29
PLANNED	9/14/2021	12	1,416	118
PLANNED	9/14/2021	1	10	10
PLANNED	9/14/2021	11	1,298	118
PLANNED	9/14/2021	5	505	101
PLANNED	9/14/2021	2	596	298
PLANNED	9/14/2021	4	84	21
PLANNED	9/14/2021	3	531	177
PLANNED	9/14/2021	3	492	164
PLANNED	9/14/2021	9	117	13
PLANNED	9/14/2021	2	382	199
PLANNED	9/14/2021	1	103	103
PLANNED	9/14/2021	10	1,000	100
PLANNED	9/14/2021	8	816	102
PLANNED	9/14/2021	3	495	165
PLANNED	9/14/2021	1	101	101
CUSTOMER REQUEST	9/14/2021	1	2	2
PLANNED	9/14/2021	6	204	34
PLANNED	9/14/2021	4	100	25
PLANNED	9/14/2021	8	64	8
PLANNED	9/14/2021	31	9,703	313
PLANNED	9/14/2021	11	847	77
PLANNED	9/14/2021	4	348	87
PLANNED	9/14/2021	7	56	8
PLANNED	9/14/2021	1	56	56
PLANNED	9/14/2021	1	15	15
PLANNED	9/14/2021	9	702	78
PLANNED	9/14/2021	5	315	63
PLANNED	9/14/2021	2	176	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/14/2021	2	16	8
PLANNED	9/14/2021	4	232	58
PLANNED	9/14/2021	8	24	3
CUSTOMER REQUEST	9/14/2021	1	178	178
CUSTOMER REQUEST	9/14/2021	2	102	51
PLANNED	9/14/2021	1	163	163
PLANNED	9/14/2021	8	32	4
PLANNED	9/14/2021	6	144	24
PLANNED	9/14/2021	5	10	2
PLANNED	9/14/2021	1	50	50
PLANNED	9/14/2021	38	3,154	83
PLANNED	9/14/2021	2	10	5
PLANNED	9/14/2021	8	256	32
PLANNED	9/14/2021	1	120	120
PLANNED	9/14/2021	1	105	105
PLANNED	9/14/2021	7	35	5
PLANNED	9/14/2021	3	213	71
PLANNED	9/14/2021	1	43	43
CUSTOMER REQUEST	9/14/2021	1	110	110
CUSTOMER REQUEST	9/14/2021	1	192	192
PLANNED	9/15/2021	6	1,374	229
PLANNED	9/15/2021	1	176	176
PLANNED	9/15/2021	1	650	650
PLANNED	9/15/2021	5	795	159
PLANNED	9/15/2021	2	72	36
PLANNED	9/15/2021	1	8	8
CUSTOMER REQUEST	9/15/2021	12	1,620	135
PLANNED	9/15/2021	1	72	72
CUSTOMER REQUEST	9/15/2021	6	214	204
PLANNED	9/15/2021	8	824	103
CUSTOMER REQUEST	9/15/2021	2	20	10
PLANNED	9/15/2021	2	188	94
PLANNED	9/15/2021	8	368	46
PLANNED	9/15/2021	10	470	47
PLANNED	9/15/2021	2	214	107
PLANNED	9/15/2021	2	78	39
PLANNED	9/15/2021	2	74	37
PLANNED	9/15/2021	10	370	37
PLANNED	9/15/2021	24	2,088	87
PLANNED	9/15/2021	4	400	100
PLANNED	9/15/2021	6	555	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/15/2021	6	42	7
CUSTOMER REQUEST	9/15/2021	1	18	18
PLANNED	9/15/2021	11	33	3
CUSTOMER REQUEST	9/15/2021	4	16	4
CUSTOMER REQUEST	9/15/2021	2	92	46
PLANNED	9/15/2021	2	38	19
PLANNED	9/15/2021	1	105	105
PLANNED	9/15/2021	7	329	47
PLANNED	9/15/2021	12	2,124	177
PLANNED	9/15/2021	11	1,804	164
PLANNED	9/15/2021	5	15	3
PLANNED	9/15/2021	4	440	110
CUSTOMER REQUEST	9/15/2021	1	219	219
PLANNED	9/15/2021	6	732	122
PLANNED	9/15/2021	7	1,540	220
PLANNED	9/15/2021	7	973	139
PLANNED	9/15/2021	29	1,160	40
PLANNED	9/15/2021	1	44	44
PLANNED	9/15/2021	2	320	160
PLANNED	9/15/2021	18	3,024	168
PLANNED	9/15/2021	6	960	160
PLANNED	9/15/2021	21	3,339	159
PLANNED	9/15/2021	1	203	203
PLANNED	9/15/2021	4	208	52
CUSTOMER REQUEST	9/15/2021	5	130	26
PLANNED	9/15/2021	14	476	34
PLANNED	9/15/2021	2	294	147
PLANNED	9/15/2021	6	312	52
PLANNED	9/15/2021	1	144	144
PLANNED	9/15/2021	4	124	31
PLANNED	9/15/2021	2	176	88
PLANNED	9/15/2021	1	43	43
PLANNED	9/15/2021	21	1,050	50
CUSTOMER REQUEST	9/15/2021	6	6	1
PLANNED	9/15/2021	2	84	42
PLANNED	9/15/2021	2	36	18
PLANNED	9/15/2021	10	1,460	146
PLANNED	9/15/2021	12	1,752	146
PLANNED	9/15/2021	5	735	147
PLANNED	9/15/2021	2	294	147
PLANNED	9/15/2021	4	164	41

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/15/2021	2	190	95
PLANNED	9/15/2021	4	188	47
PLANNED	9/15/2021	4	232	58
PLANNED	9/15/2021	1	120	120
PLANNED	9/15/2021	2	248	124
PLANNED	9/15/2021	11	451	41
PLANNED	9/15/2021	2	36	18
CUSTOMER REQUEST	9/15/2021	1	98	98
PLANNED	9/15/2021	10	330	33
PLANNED	9/15/2021	1	13	13
PLANNED	9/15/2021	8	320	40
PLANNED	9/15/2021	11	990	90
PLANNED	9/15/2021	7	567	81
PLANNED	9/15/2021	1	69	69
PLANNED	9/15/2021	1	31	31
PLANNED	9/15/2021	12	384	32
PLANNED	9/15/2021	1	170	170
CUSTOMER REQUEST	9/15/2021	1	732	732
PLANNED	9/15/2021	21	84	4
CUSTOMER REQUEST	9/15/2021	1	89	89
CUSTOMER REQUEST	9/15/2021	1	256	256
PLANNED	9/15/2021	3	333	111
PLANNED	9/15/2021	6	1,338	223
CUSTOMER REQUEST	9/15/2021	1	510	510
PLANNED	9/15/2021	3	135	45
PLANNED	9/15/2021	2	186	93
PLANNED	9/16/2021	2	140	70
PLANNED	9/16/2021	18	900	50
PLANNED	9/16/2021	8	496	62
PLANNED	9/16/2021	13	806	62
PLANNED	9/16/2021	9	558	62
PLANNED	9/16/2021	1	37	37
PLANNED	9/16/2021	7	798	114
PLANNED	9/16/2021	3	330	110
PLANNED	9/16/2021	1	41	41
PLANNED	9/16/2021	1	183	183
PLANNED	9/16/2021	2	123	65
PLANNED	9/16/2021	6	150	25
PLANNED	9/16/2021	6	540	116
PLANNED	9/16/2021	8	104	13
PLANNED	9/16/2021	1	51	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/16/2021	31	2,635	85
PLANNED	9/16/2021	1	95	95
PLANNED	9/16/2021	1	176	176
PLANNED	9/16/2021	8	312	39
PLANNED	9/16/2021	1	157	157
PLANNED	9/16/2021	10	680	328
PLANNED	9/16/2021	3	258	86
PLANNED	9/16/2021	2	206	103
CUSTOMER REQUEST	9/16/2021	275	16,500	60
PLANNED	9/16/2021	20	140	7
PLANNED	9/16/2021	8	56	7
CUSTOMER REQUEST	9/16/2021	1	647	647
PLANNED	9/16/2021	10	980	98
PLANNED	9/16/2021	8	1,560	195
PLANNED	9/16/2021	2	10	5
PLANNED	9/16/2021	4	256	64
PLANNED	9/16/2021	1	71	71
PLANNED	9/16/2021	2	95	54
PLANNED	9/16/2021	10	260	26
PLANNED	9/16/2021	7	376	100
PLANNED	9/16/2021	2	404	202
PLANNED	9/16/2021	17	34	2
PLANNED	9/16/2021	6	666	111
PLANNED	9/16/2021	1	97	97
PLANNED	9/16/2021	6	666	111
CUSTOMER REQUEST	9/16/2021	4	356	89
PLANNED	9/16/2021	4	140	35
PLANNED	9/16/2021	6	156	39
PLANNED	9/16/2021	91	7,462	82
PLANNED	9/16/2021	15	90	6
PLANNED	9/16/2021	2	50	25
CUSTOMER REQUEST	9/16/2021	72	2,736	38
PLANNED	9/16/2021	1	51	51
PLANNED	9/16/2021	6	156	26
PLANNED	9/16/2021	4	368	92
PLANNED	9/16/2021	2	40	20
PLANNED	9/16/2021	1	37	37
PLANNED	9/16/2021	6	150	25
PLANNED	9/16/2021	4	212	53
CUSTOMER REQUEST	9/16/2021	3	90	30
PLANNED	9/16/2021	4	156	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/16/2021	62	3,906	63
PLANNED	9/16/2021	5	200	40
PLANNED	9/16/2021	1	103	103
CUSTOMER REQUEST	9/16/2021	5	95	19
PLANNED	9/16/2021	6	699	124
PLANNED	9/16/2021	3	90	30
PLANNED	9/16/2021	1	93	93
PLANNED	9/16/2021	6	186	31
PLANNED	9/16/2021	13	1,183	91
PLANNED	9/16/2021	1	101	101
PLANNED	9/16/2021	15	2,715	181
PLANNED	9/16/2021	8	56	7
PLANNED	9/16/2021	34	6,154	181
PLANNED	9/16/2021	26	1,482	57
PLANNED	9/16/2021	1	41	41
PLANNED	9/16/2021	5	510	102
PLANNED	9/16/2021	3	120	40
PLANNED	9/16/2021	43	2,408	56
CUSTOMER REQUEST	9/16/2021	1	298	298
PLANNED	9/16/2021	6	6	1
PLANNED	9/16/2021	1	11	11
PLANNED	9/16/2021	1	78	78
PLANNED	9/16/2021	1	27	27
CUSTOMER REQUEST	9/16/2021	1	221	221
PLANNED	9/16/2021	25	675	27
PLANNED	9/16/2021	9	873	97
PLANNED	9/16/2021	8	1,280	160
PLANNED	9/16/2021	4	528	132
PLANNED	9/16/2021	1	250	250
PLANNED	9/17/2021	1	423	423
PLANNED	9/17/2021	1	114	114
PLANNED	9/17/2021	10	900	90
PLANNED	9/17/2021	1	24	24
PLANNED	9/17/2021	2	97	64
PLANNED	9/17/2021	1	92	92
PLANNED	9/17/2021	5	450	90
PLANNED	9/17/2021	2	330	165
PLANNED	9/17/2021	2	183	107
CUSTOMER REQUEST	9/17/2021	622	11,196	18
PLANNED	9/17/2021	13	598	46
PLANNED	9/17/2021	6	420	70

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/17/2021	1	153	153
PLANNED	9/17/2021	2	70	35
PLANNED	9/17/2021	4	368	92
PLANNED	9/17/2021	1	37	37
PLANNED	9/17/2021	8	480	60
PLANNED	9/17/2021	1	62	62
PLANNED	9/17/2021	5	915	183
PLANNED	9/17/2021	1	119	119
PLANNED	9/17/2021	7	1,540	220
PLANNED	9/17/2021	2	76	38
PLANNED	9/17/2021	2	6	3
PLANNED	9/17/2021	5	810	162
PLANNED	9/17/2021	8	416	52
PLANNED	9/17/2021	5	390	78
PLANNED	9/17/2021	1	189	189
PLANNED	9/17/2021	8	656	82
PLANNED	9/17/2021	14	1,582	113
PLANNED	9/17/2021	8	640	80
PLANNED	9/17/2021	8	592	74
PLANNED	9/17/2021	3	696	232
PLANNED	9/17/2021	1	67	67
PLANNED	9/17/2021	3	60	20
PLANNED	9/17/2021	8	568	71
PLANNED	9/17/2021	2	396	198
PLANNED	9/17/2021	1	60	60
PLANNED	9/17/2021	4	40	10
PLANNED	9/17/2021	12	960	80
PLANNED	9/17/2021	2	306	153
PLANNED	9/17/2021	11	1,650	150
PLANNED	9/17/2021	1	22	22
PLANNED	9/17/2021	2	256	128
PLANNED	9/17/2021	5	751	368
PLANNED	9/17/2021	4	68	17
PLANNED	9/17/2021	3	174	58
PLANNED	9/17/2021	2	96	48
PLANNED	9/17/2021	17	697	41
PLANNED	9/17/2021	3	141	47
PLANNED	9/17/2021	23	56	12
PLANNED	9/17/2021	1	55	55
PLANNED	9/17/2021	16	3,888	243
PLANNED	9/17/2021	29	7,047	243

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/17/2021	29	7,018	242
PLANNED	9/17/2021	27	1,487	59
PLANNED	9/17/2021	5	130	26
PLANNED	9/17/2021	2	54	27
PLANNED	9/17/2021	95	1,615	17
PLANNED	9/17/2021	9	216	24
PLANNED	9/17/2021	28	1,260	45
PLANNED	9/17/2021	3	93	31
CUSTOMER REQUEST	9/17/2021	1	159	159
PLANNED	9/17/2021	4	44	11
CUSTOMER REQUEST	9/17/2021	1	101	101
PLANNED	9/17/2021	1	85	85
PLANNED	9/17/2021	1	20	20
CUSTOMER REQUEST	9/18/2021	1	3	3
PLANNED	9/18/2021	5	385	77
PLANNED	9/18/2021	1	54	54
PLANNED	9/18/2021	1	182	182
PLANNED	9/18/2021	1	213	213
PLANNED	9/18/2021	2	106	53
PLANNED	9/18/2021	32	11,680	365
PLANNED	9/18/2021	1	70	70
PLANNED	9/18/2021	1	191	191
PLANNED	9/18/2021	33	2,970	90
PLANNED	9/18/2021	33	2,937	89
PLANNED	9/18/2021	8	623	161
PLANNED	9/18/2021	2	294	147
CUSTOMER REQUEST	9/18/2021	1	80	80
PLANNED	9/18/2021	1	14	14
PLANNED	9/18/2021	1	60	60
PLANNED	9/18/2021	16	1,232	77
PLANNED	9/18/2021	2	32	16
PLANNED	9/18/2021	1	104	104
CUSTOMER REQUEST	9/18/2021	1	190	190
PLANNED	9/18/2021	1	145	145
PLANNED	9/19/2021	1	58	58
PLANNED	9/19/2021	6	126	21
PLANNED	9/19/2021	32	6,368	199
PLANNED	9/19/2021	16	1,212	231
PLANNED	9/19/2021	21	11,109	529
PLANNED	9/19/2021	1	114	114
PLANNED	9/19/2021	3	228	76

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/19/2021	1	65	65
CUSTOMER REQUEST	9/20/2021	29	10,208	352
PLANNED	9/20/2021	1	274	274
PLANNED	9/20/2021	1	140	140
PLANNED	9/20/2021	1	32	32
PLANNED	9/20/2021	1	96	96
PLANNED	9/20/2021	1	36	36
PLANNED	9/20/2021	6	270	45
PLANNED	9/20/2021	2	250	125
PLANNED	9/20/2021	2	416	208
PLANNED	9/20/2021	1	140	140
PLANNED	9/20/2021	1	324	324
PLANNED	9/20/2021	13	2,015	155
PLANNED	9/20/2021	7	420	60
CUSTOMER REQUEST	9/20/2021	5	95	19
PLANNED	9/20/2021	3	300	100
PLANNED	9/20/2021	5	340	68
CUSTOMER REQUEST	9/20/2021	1	70	70
PLANNED	9/20/2021	2	62	31
PLANNED	9/20/2021	91	637	7
PLANNED	9/20/2021	68	68	1
PLANNED	9/20/2021	2	64	32
CUSTOMER REQUEST	9/20/2021	12	108	9
CUSTOMER REQUEST	9/20/2021	5	125	25
PLANNED	9/20/2021	17	2,091	123
PLANNED	9/20/2021	52	7,436	143
PLANNED	9/20/2021	6	2,430	405
PLANNED	9/20/2021	6	12	2
CUSTOMER REQUEST	9/20/2021	1	239	239
PLANNED	9/20/2021	3	193	70
PLANNED	9/20/2021	1	145	145
PLANNED	9/20/2021	2	176	88
PLANNED	9/20/2021	68	2,040	30
PLANNED	9/20/2021	5	375	75
PLANNED	9/20/2021	9	234	26
PLANNED	9/20/2021	37	5,920	160
PLANNED	9/20/2021	4	16	4
PLANNED	9/20/2021	1	82	82
CUSTOMER REQUEST	9/20/2021	54	15,822	293
PLANNED	9/20/2021	1	79	79
PLANNED	9/20/2021	5	575	115

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/20/2021	10	2,400	240
PLANNED	9/20/2021	24	2,556	244
PLANNED	9/20/2021	2	30	15
PLANNED	9/20/2021	2	20	10
PLANNED	9/20/2021	4	516	129
PLANNED	9/20/2021	7	1,015	145
PLANNED	9/20/2021	7	406	58
PLANNED	9/20/2021	15	15	1
CUSTOMER REQUEST	9/20/2021	1	74	74
PLANNED	9/20/2021	66	2,178	33
PLANNED	9/20/2021	3	45	15
PLANNED	9/20/2021	9	162	18
PLANNED	9/20/2021	7	14	2
PLANNED	9/20/2021	2	24	12
PLANNED	9/20/2021	2	276	138
PLANNED	9/20/2021	7	378	54
PLANNED	9/20/2021	32	288	9
PLANNED	9/20/2021	4	424	106
CUSTOMER REQUEST	9/20/2021	7	322	46
PLANNED	9/20/2021	12	228	19
PLANNED	9/20/2021	3	66	22
PLANNED	9/20/2021	2	102	51
PLANNED	9/20/2021	7	1,288	184
PLANNED	9/20/2021	1	15	15
PLANNED	9/20/2021	61	732	12
PLANNED	9/20/2021	5	375	75
PLANNED	9/20/2021	60	3,600	60
PLANNED	9/20/2021	63	1,206	142
PLANNED	9/20/2021	1	142	142
PLANNED	9/20/2021	6	870	145
PLANNED	9/20/2021	2	92	46
PLANNED	9/20/2021	13	1,625	125
PLANNED	9/20/2021	6	876	146
PLANNED	9/20/2021	7	1,554	222
PLANNED	9/20/2021	4	300	75
PLANNED	9/20/2021	9	171	19
PLANNED	9/20/2021	1	163	163
PLANNED	9/20/2021	79	316	4
PLANNED	9/20/2021	3	134	60
PLANNED	9/20/2021	60	3,300	55
PLANNED	9/20/2021	1	23	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/20/2021	2	168	84
PLANNED	9/20/2021	12	960	80
PLANNED	9/20/2021	1	2	2
PLANNED	9/20/2021	7	105	15
PLANNED	9/20/2021	2	68	34
PLANNED	9/20/2021	4	268	67
PLANNED	9/20/2021	2	56	28
PLANNED	9/20/2021	5	210	42
PLANNED	9/20/2021	7	28	4
PLANNED	9/20/2021	1	41	41
PLANNED	9/20/2021	1	70	70
PLANNED	9/20/2021	1	50	50
CUSTOMER REQUEST	9/20/2021	1	355	355
PLANNED	9/20/2021	8	344	43
PLANNED	9/20/2021	2	54	27
PLANNED	9/20/2021	2	92	46
CUSTOMER REQUEST	9/20/2021	1	179	179
PLANNED	9/20/2021	3	90	30
PLANNED	9/20/2021	1	65	65
PLANNED	9/20/2021	5	390	78
PLANNED	9/20/2021	3	39	13
PLANNED	9/20/2021	5	1,295	259
CUSTOMER REQUEST	9/20/2021	1	87	87
PLANNED	9/20/2021	1	97	97
PLANNED	9/21/2021	1	1,223	1,223
PLANNED	9/21/2021	83	21,829	263
PLANNED	9/21/2021	97	25,511	263
PLANNED	9/21/2021	3	789	263
PLANNED	9/21/2021	4	392	98
PLANNED	9/21/2021	2	132	66
PLANNED	9/21/2021	11	1,507	137
PLANNED	9/21/2021	42	5,754	137
PLANNED	9/21/2021	1	81	81
PLANNED	9/21/2021	6	1,112	336
PLANNED	9/21/2021	2	160	80
PLANNED	9/21/2021	22	1,672	76
PLANNED	9/21/2021	8	776	97
PLANNED	9/21/2021	17	119	7
PLANNED	9/21/2021	3	48	16
PLANNED	9/21/2021	4	340	85
CUSTOMER REQUEST	9/21/2021	2	68	34

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/21/2021	10	50	5
PLANNED	9/21/2021	39	3,588	92
PLANNED	9/21/2021	6	270	45
PLANNED	9/21/2021	2	100	50
PLANNED	9/21/2021	2	22	11
PLANNED	9/21/2021	5	1,895	379
PLANNED	9/21/2021	4	460	115
PLANNED	9/21/2021	1	56	56
PLANNED	9/21/2021	8	8	1
PLANNED	9/21/2021	1	28	28
CUSTOMER REQUEST	9/21/2021	11	99	9
CUSTOMER REQUEST	9/21/2021	4	164	41
PLANNED	9/21/2021	9	684	76
CUSTOMER REQUEST	9/21/2021	20	1,800	90
PLANNED	9/21/2021	1	52	52
PLANNED	9/21/2021	1	120	120
PLANNED	9/21/2021	7	1,505	215
PLANNED	9/21/2021	4	72	18
PLANNED	9/21/2021	1	33	33
PLANNED	9/21/2021	4	220	55
PLANNED	9/21/2021	2	176	88
PLANNED	9/21/2021	1	415	415
PLANNED	9/21/2021	2	84	42
PLANNED	9/21/2021	7	749	107
CUSTOMER REQUEST	9/21/2021	2	56	28
PLANNED	9/21/2021	1	53	53
PLANNED	9/21/2021	13	3,614	278
PLANNED	9/21/2021	9	855	95
PLANNED	9/21/2021	8	239	64
PLANNED	9/21/2021	1	29	29
PLANNED	9/21/2021	4	320	80
PLANNED	9/21/2021	4	144	36
PLANNED	9/21/2021	2	44	22
PLANNED	9/21/2021	9	27	3
PLANNED	9/21/2021	4	144	36
PLANNED	9/21/2021	4	44	11
PLANNED	9/21/2021	25	1,550	62
PLANNED	9/21/2021	13	52	4
CUSTOMER REQUEST	9/21/2021	1	85	85
PLANNED	9/21/2021	1	63	63
PLANNED	9/21/2021	5	575	115

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/21/2021	18	252	14
PLANNED	9/21/2021	1	35	35
PLANNED	9/21/2021	2	60	30
PLANNED	9/21/2021	4	232	58
PLANNED	9/21/2021	6	177	77
PLANNED	9/21/2021	3	90	30
PLANNED	9/21/2021	5	775	155
PLANNED	9/21/2021	7	316	64
PLANNED	9/21/2021	4	296	74
CUSTOMER REQUEST	9/21/2021	3	69	23
PLANNED	9/21/2021	23	1,932	84
PLANNED	9/21/2021	13	533	41
PLANNED	9/21/2021	22	6,864	312
PLANNED	9/21/2021	1	35	35
PLANNED	9/21/2021	12	24	2
PLANNED	9/21/2021	2	24	12
PLANNED	9/21/2021	3	273	91
PLANNED	9/21/2021	4	372	93
PLANNED	9/21/2021	7	707	101
PLANNED	9/21/2021	17	357	21
PLANNED	9/21/2021	2	106	53
PLANNED	9/21/2021	4	284	71
PLANNED	9/21/2021	9	45	5
PLANNED	9/21/2021	3	24	8
PLANNED	9/21/2021	5	70	14
PLANNED	9/21/2021	9	540	60
PLANNED	9/21/2021	4	848	212
PLANNED	9/21/2021	10	460	46
PLANNED	9/21/2021	4	88	22
PLANNED	9/21/2021	57	4,674	82
PLANNED	9/21/2021	4	504	126
PLANNED	9/21/2021	5	125	25
CUSTOMER REQUEST	9/21/2021	7	1,246	178
PLANNED	9/21/2021	8	64	8
PLANNED	9/21/2021	7	847	121
PLANNED	9/21/2021	10	370	37
PLANNED	9/21/2021	8	104	13
PLANNED	9/21/2021	1	82	82
PLANNED	9/21/2021	1	9	9
CUSTOMER REQUEST	9/21/2021	1	447	447
CUSTOMER REQUEST	9/21/2021	1	415	415

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	9/21/2021	1	52	52
PLANNED	9/21/2021	29	2,581	89
CUSTOMER REQUEST	9/22/2021	1	95	95
PLANNED	9/22/2021	1	142	142
PLANNED	9/22/2021	4	172	59
PLANNED	9/22/2021	3	75	25
CUSTOMER REQUEST	9/22/2021	6	714	119
PLANNED	9/22/2021	12	1,308	109
CUSTOMER REQUEST	9/22/2021	113	23,052	204
PLANNED	9/22/2021	4	1,068	267
PLANNED	9/22/2021	7	238	34
CUSTOMER REQUEST	9/22/2021	4	24	6
PLANNED	9/22/2021	6	648	108
PLANNED	9/22/2021	5	555	111
PLANNED	9/22/2021	2	306	153
PLANNED	9/22/2021	1	145	145
PLANNED	9/22/2021	4	504	126
PLANNED	9/22/2021	5	920	184
PLANNED	9/22/2021	2	368	184
PLANNED	9/22/2021	4	740	185
PLANNED	9/22/2021	5	920	184
PLANNED	9/22/2021	1	184	184
PLANNED	9/22/2021	11	583	53
PLANNED	9/22/2021	8	888	111
PLANNED	9/22/2021	2	214	107
PLANNED	9/22/2021	12	480	40
PLANNED	9/22/2021	2	4	2
PLANNED	9/22/2021	1	263	263
PLANNED	9/22/2021	3	69	23
PLANNED	9/22/2021	12	984	82
PLANNED	9/22/2021	11	627	57
PLANNED	9/22/2021	2	338	169
PLANNED	9/22/2021	1	106	106
PLANNED	9/22/2021	3	213	71
PLANNED	9/22/2021	8	896	112
PLANNED	9/22/2021	2	204	102
PLANNED	9/22/2021	27	2,646	98
PLANNED	9/22/2021	4	358	117
PLANNED	9/22/2021	2	24	12
PLANNED	9/22/2021	8	240	30
PLANNED	9/22/2021	6	798	133

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/22/2021	16	48	3
PLANNED	9/22/2021	5	320	64
PLANNED	9/22/2021	8	24	3
PLANNED	9/22/2021	2	314	157
PLANNED	9/22/2021	1	21	21
PLANNED	9/22/2021	2	50	25
PLANNED	9/22/2021	3	258	86
PLANNED	9/22/2021	6	456	76
PLANNED	9/22/2021	24	936	39
PLANNED	9/22/2021	2	240	120
PLANNED	9/22/2021	2	14	7
PLANNED	9/22/2021	3	417	139
PLANNED	9/22/2021	9	504	56
PLANNED	9/22/2021	2	78	39
PLANNED	9/22/2021	7	70	10
PLANNED	9/22/2021	5	30	6
PLANNED	9/22/2021	6	420	70
PLANNED	9/22/2021	6	54	9
PLANNED	9/22/2021	7	574	82
PLANNED	9/22/2021	1	15	15
PLANNED	9/22/2021	2	158	79
PLANNED	9/22/2021	2	160	80
PLANNED	9/22/2021	2	16	8
PLANNED	9/22/2021	3	63	21
PLANNED	9/22/2021	13	520	40
PLANNED	9/22/2021	5	905	181
PLANNED	9/22/2021	7	161	23
PLANNED	9/22/2021	12	1,152	96
PLANNED	9/22/2021	5	275	55
PLANNED	9/22/2021	6	498	83
CUSTOMER REQUEST	9/22/2021	6	336	56
PLANNED	9/22/2021	1	48	48
PLANNED	9/22/2021	3	186	62
PLANNED	9/22/2021	1	82	82
PLANNED	9/22/2021	12	156	13
CUSTOMER REQUEST	9/22/2021	19	76	4
PLANNED	9/22/2021	3	27	9
PLANNED	9/22/2021	5	585	117
PLANNED	9/22/2021	3	6	2
PLANNED	9/22/2021	3	42	14
PLANNED	9/22/2021	7	483	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/22/2021	2	22	11
PLANNED	9/22/2021	3	33	11
PLANNED	9/22/2021	6	510	85
PLANNED	9/22/2021	6	174	29
PLANNED	9/22/2021	2	92	46
PLANNED	9/22/2021	1	7	7
PLANNED	9/22/2021	9	261	29
PLANNED	9/22/2021	3	24	8
PLANNED	9/22/2021	3	27	9
PLANNED	9/22/2021	2	54	27
CUSTOMER REQUEST	9/22/2021	1	94	94
PLANNED	9/22/2021	2	10	5
PLANNED	9/22/2021	3	24	8
PLANNED	9/22/2021	2	20	10
PLANNED	9/22/2021	3	24	8
PLANNED	9/22/2021	4	36	9
PLANNED	9/22/2021	3	33	11
PLANNED	9/22/2021	3	21	7
PLANNED	9/22/2021	4	24	6
PLANNED	9/22/2021	1	4	4
PLANNED	9/22/2021	3	18	6
PLANNED	9/22/2021	3	21	7
PLANNED	9/22/2021	3	18	6
PLANNED	9/22/2021	3	111	37
CUSTOMER REQUEST	9/22/2021	1	173	173
PLANNED	9/22/2021	3	105	35
PLANNED	9/22/2021	1	61	61
PLANNED	9/22/2021	1	130	130
PLANNED	9/22/2021	1	57	57
PLANNED	9/22/2021	3	486	162
PLANNED	9/23/2021	3	468	156
PLANNED	9/23/2021	3	264	88
PLANNED	9/23/2021	2	172	86
PLANNED	9/23/2021	1	243	243
PLANNED	9/23/2021	19	969	51
PLANNED	9/23/2021	1	36	36
PLANNED	9/23/2021	1	222	222
PLANNED	9/23/2021	2	250	125
PLANNED	9/23/2021	8	1,192	149
PLANNED	9/23/2021	6	684	114
PLANNED	9/23/2021	4	1,996	499

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/23/2021	3	51	17
PLANNED	9/23/2021	1	139	139
PLANNED	9/23/2021	4	420	105
PLANNED	9/23/2021	3	198	66
PLANNED	9/23/2021	3	399	133
PLANNED	9/23/2021	1	306	306
PLANNED	9/23/2021	1	16	16
PLANNED	9/23/2021	1	209	209
PLANNED	9/23/2021	2	88	44
PLANNED	9/23/2021	3	939	313
PLANNED	9/23/2021	26	8,034	309
PLANNED	9/23/2021	26	8,034	309
PLANNED	9/23/2021	27	8,343	309
PLANNED	9/23/2021	28	8,652	309
PLANNED	9/23/2021	6	384	64
PLANNED	9/23/2021	3	99	33
PLANNED	9/23/2021	1	9	9
CUSTOMER REQUEST	9/23/2021	1	354	354
CUSTOMER REQUEST	9/23/2021	1	138	138
PLANNED	9/23/2021	7	1,638	234
CUSTOMER REQUEST	9/23/2021	6	24	4
PLANNED	9/23/2021	1	29	29
PLANNED	9/23/2021	12	360	30
CUSTOMER REQUEST	9/23/2021	13	169	13
CUSTOMER REQUEST	9/23/2021	6	24	4
PLANNED	9/23/2021	7	77	11
PLANNED	9/23/2021	5	40	8
PLANNED	9/23/2021	6	630	105
PLANNED	9/23/2021	1	2	2
PLANNED	9/23/2021	3	726	242
PLANNED	9/23/2021	2	302	151
CUSTOMER REQUEST	9/23/2021	1	138	138
PLANNED	9/23/2021	5	805	161
PLANNED	9/23/2021	3	36	12
PLANNED	9/23/2021	2	186	93
PLANNED	9/23/2021	3	225	75
PLANNED	9/23/2021	1	126	126
PLANNED	9/23/2021	1	267	267
PLANNED	9/23/2021	7	294	42
PLANNED	9/23/2021	2	252	126
PLANNED	9/23/2021	1	15	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/23/2021	4	312	78
PLANNED	9/23/2021	9	783	87
PLANNED	9/23/2021	8	1,040	130
CUSTOMER REQUEST	9/23/2021	14	998	379
PLANNED	9/23/2021	3	393	131
PLANNED	9/23/2021	1	101	101
PLANNED	9/23/2021	14	490	35
PLANNED	9/23/2021	4	208	52
PLANNED	9/23/2021	2	28	14
PLANNED	9/23/2021	1	52	52
PLANNED	9/23/2021	2	44	22
PLANNED	9/23/2021	5	470	94
PLANNED	9/23/2021	7	35	5
PLANNED	9/23/2021	2	244	122
PLANNED	9/23/2021	1	107	107
PLANNED	9/23/2021	8	1,040	130
PLANNED	9/23/2021	20	2,480	124
PLANNED	9/23/2021	1	27	27
PLANNED	9/23/2021	1	8	8
PLANNED	9/23/2021	6	210	55
PLANNED	9/23/2021	4	544	136
PLANNED	9/23/2021	3	405	135
PLANNED	9/23/2021	46	6,072	132
PLANNED	9/23/2021	4	816	204
PLANNED	9/23/2021	1	18	18
PLANNED	9/23/2021	2	44	22
CUSTOMER REQUEST	9/23/2021	2	350	175
CUSTOMER REQUEST	9/23/2021	1	43	43
CUSTOMER REQUEST	9/23/2021	1	240	240
PLANNED	9/23/2021	6	372	62
PLANNED	9/23/2021	5	195	39
PLANNED	9/23/2021	1	9	9
PLANNED	9/23/2021	10	1,040	104
PLANNED	9/23/2021	7	952	136
PLANNED	9/23/2021	7	322	46
PLANNED	9/23/2021	1	16	16
PLANNED	9/23/2021	4	108	27
PLANNED	9/23/2021	4	68	17
PLANNED	9/23/2021	20	1,960	98
PLANNED	9/23/2021	11	616	56
PLANNED	9/23/2021	1	48	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/23/2021	11	132	12
PLANNED	9/23/2021	40	2,960	74
PLANNED	9/23/2021	2	94	47
PLANNED	9/23/2021	1	94	94
PLANNED	9/23/2021	3	264	88
PLANNED	9/23/2021	3	174	58
PLANNED	9/23/2021	2	16	8
PLANNED	9/23/2021	1	54	54
PLANNED	9/23/2021	3	1,149	383
PLANNED	9/23/2021	2	26	13
PLANNED	9/23/2021	1	173	173
PLANNED	9/23/2021	6	1,176	196
PLANNED	9/23/2021	1	11	11
PLANNED	9/23/2021	8	904	113
PLANNED	9/23/2021	1	19	19
PLANNED	9/23/2021	8	688	86
PLANNED	9/23/2021	3	24	8
PLANNED	9/23/2021	2	204	102
PLANNED	9/23/2021	3	153	51
PLANNED	9/23/2021	2	20	10
PLANNED	9/23/2021	1	10	10
PLANNED	9/23/2021	1	53	53
PLANNED	9/23/2021	8	528	66
PLANNED	9/23/2021	1	11	11
PLANNED	9/23/2021	6	138	23
PLANNED	9/23/2021	2	158	79
CUSTOMER REQUEST	9/23/2021	2	30	15
PLANNED	9/23/2021	3	351	117
CUSTOMER REQUEST	9/23/2021	3	81	27
PLANNED	9/23/2021	2	230	115
PLANNED	9/23/2021	4	76	19
PLANNED	9/23/2021	2	76	38
PLANNED	9/23/2021	3	12	4
CUSTOMER REQUEST	9/23/2021	1	355	355
PLANNED	9/23/2021	5	365	73
PLANNED	9/23/2021	1	5	5
PLANNED	9/23/2021	4	272	68
PLANNED	9/23/2021	2	228	114
PLANNED	9/23/2021	3	24	8
PLANNED	9/23/2021	4	176	44
PLANNED	9/23/2021	10	350	35

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/23/2021	9	1,377	153
PLANNED	9/23/2021	1	137	137
PLANNED	9/23/2021	9	45	5
PLANNED	9/23/2021	3	66	22
PLANNED	9/23/2021	5	565	113
CUSTOMER REQUEST	9/23/2021	1	402	402
PLANNED	9/23/2021	3	18	6
PLANNED	9/23/2021	1	32	32
PLANNED	9/23/2021	14	280	20
PLANNED	9/23/2021	2	30	15
PLANNED	9/23/2021	1	11	11
PLANNED	9/23/2021	1	13	13
CUSTOMER REQUEST	9/23/2021	1	259	259
PLANNED	9/23/2021	5	355	71
PLANNED	9/23/2021	1	21	21
PLANNED	9/23/2021	1	10	10
CUSTOMER REQUEST	9/23/2021	3	33	11
PLANNED	9/23/2021	1	5	5
PLANNED	9/23/2021	2	14	7
PLANNED	9/23/2021	1	53	53
PLANNED	9/23/2021	1	181	181
PLANNED	9/23/2021	4	316	79
PLANNED	9/23/2021	1	9	9
PLANNED	9/23/2021	3	27	9
PLANNED	9/23/2021	1	129	129
CUSTOMER REQUEST	9/23/2021	1	136	136
PLANNED	9/23/2021	14	322	23
CUSTOMER REQUEST	9/23/2021	3	63	21
PLANNED	9/23/2021	1	146	146
CUSTOMER REQUEST	9/23/2021	1	162	162
PLANNED	9/23/2021	12	3,396	283
PLANNED	9/23/2021	19	4,902	258
PLANNED	9/23/2021	2	624	312
PLANNED	9/23/2021	2	536	268
PLANNED	9/23/2021	21	4,347	207
PLANNED	9/23/2021	6	1,974	329
PLANNED	9/23/2021	1	273	273
PLANNED	9/23/2021	2	190	95
PLANNED	9/23/2021	1	93	93
PLANNED	9/23/2021	1	94	94
PLANNED	9/23/2021	1	93	93

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/23/2021	8	1,616	202
PLANNED	9/23/2021	2	28	14
PLANNED	9/23/2021	1	140	140
PLANNED	9/23/2021	1	83	83
PLANNED	9/24/2021	1	173	173
PLANNED	9/24/2021	1	718	718
PLANNED	9/24/2021	15	4,215	281
PLANNED	9/24/2021	14	3,010	215
PLANNED	9/24/2021	13	416	32
PLANNED	9/24/2021	1	80	80
PLANNED	9/24/2021	2	150	75
PLANNED	9/24/2021	2	328	164
PLANNED	9/24/2021	2	314	157
PLANNED	9/24/2021	1	97	97
PLANNED	9/24/2021	4	140	35
PLANNED	9/24/2021	6	324	54
PLANNED	9/24/2021	1	8	8
PLANNED	9/24/2021	1	212	212
PLANNED	9/24/2021	5	375	75
PLANNED	9/24/2021	2	18	9
PLANNED	9/24/2021	4	64	16
PLANNED	9/24/2021	20	2,220	111
PLANNED	9/24/2021	2	98	49
PLANNED	9/24/2021	1	259	259
PLANNED	9/24/2021	1	6	6
PLANNED	9/24/2021	8	1,440	180
PLANNED	9/24/2021	10	730	73
CUSTOMER REQUEST	9/24/2021	2	480	240
PLANNED	9/24/2021	2	16	8
PLANNED	9/24/2021	1	7	7
PLANNED	9/24/2021	1	213	213
PLANNED	9/24/2021	37	6,475	175
PLANNED	9/24/2021	3	321	107
PLANNED	9/24/2021	1	178	178
PLANNED	9/24/2021	2	204	102
PLANNED	9/24/2021	2	190	95
PLANNED	9/24/2021	1	83	83
PLANNED	9/24/2021	7	238	34
PLANNED	9/24/2021	1	8	8
PLANNED	9/24/2021	5	390	78
PLANNED	9/24/2021	4	176	44

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/24/2021	1	182	182
PLANNED	9/24/2021	24	1,872	78
PLANNED	9/24/2021	1	8	8
PLANNED	9/24/2021	1	144	144
PLANNED	9/24/2021	6	252	42
PLANNED	9/24/2021	1	339	339
PLANNED	9/24/2021	4	340	85
PLANNED	9/24/2021	6	1,056	176
PLANNED	9/24/2021	8	232	29
PLANNED	9/24/2021	20	1,240	62
PLANNED	9/24/2021	4	356	89
PLANNED	9/24/2021	2	40	20
PLANNED	9/24/2021	3	21	7
PLANNED	9/24/2021	4	180	45
PLANNED	9/24/2021	8	576	72
PLANNED	9/24/2021	5	350	70
PLANNED	9/24/2021	6	822	137
PLANNED	9/24/2021	3	27	9
PLANNED	9/24/2021	1	78	78
PLANNED	9/24/2021	1	13	13
PLANNED	9/24/2021	1	174	174
PLANNED	9/24/2021	1	6	6
PLANNED	9/24/2021	4	444	111
PLANNED	9/24/2021	2	210	105
PLANNED	9/24/2021	3	177	59
CUSTOMER REQUEST	9/24/2021	35	1,540	44
PLANNED	9/24/2021	1	8	8
PLANNED	9/24/2021	1	221	221
PLANNED	9/24/2021	1	10	10
PLANNED	9/24/2021	4	460	115
PLANNED	9/24/2021	1	85	85
PLANNED	9/24/2021	2	164	82
PLANNED	9/24/2021	11	495	45
PLANNED	9/24/2021	8	80	10
PLANNED	9/24/2021	1	8	8
PLANNED	9/24/2021	4	140	35
PLANNED	9/24/2021	1	13	13
PLANNED	9/24/2021	6	84	14
PLANNED	9/24/2021	2	4	2
PLANNED	9/24/2021	2	20	10
PLANNED	9/24/2021	1	140	140

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/24/2021	9	729	81
PLANNED	9/24/2021	1	6	6
PLANNED	9/24/2021	2	326	163
PLANNED	9/24/2021	1	99	99
PLANNED	9/24/2021	2	12	6
CUSTOMER REQUEST	9/24/2021	10	60	6
PLANNED	9/24/2021	1	80	80
PLANNED	9/24/2021	2	70	35
PLANNED	9/24/2021	1	9	9
PLANNED	9/24/2021	4	160	40
PLANNED	9/24/2021	1	5	5
PLANNED	9/24/2021	4	48	12
PLANNED	9/24/2021	5	55	11
PLANNED	9/24/2021	4	108	27
PLANNED	9/24/2021	1	12	12
PLANNED	9/24/2021	1	63	63
PLANNED	9/24/2021	1	33	33
CUSTOMER REQUEST	9/24/2021	1	278	278
CUSTOMER REQUEST	9/24/2021	1	139	139
PLANNED	9/24/2021	4	16	4
PLANNED	9/24/2021	7	245	35
PLANNED	9/24/2021	8	144	18
PLANNED	9/24/2021	2	472	236
PLANNED	9/25/2021	5	570	114
PLANNED	9/25/2021	2	304	152
PLANNED	9/25/2021	1	25	25
PLANNED	9/25/2021	1	54	54
PLANNED	9/25/2021	2	30	15
PLANNED	9/25/2021	3	96	32
PLANNED	9/25/2021	4	16	4
PLANNED	9/25/2021	1	184	184
PLANNED	9/25/2021	2	1,132	566
PLANNED	9/25/2021	2	306	153
PLANNED	9/25/2021	2	262	131
PLANNED	9/25/2021	8	560	70
PLANNED	9/25/2021	2	236	118
CUSTOMER REQUEST	9/25/2021	11	1,243	113
PLANNED	9/25/2021	2	48	24
PLANNED	9/25/2021	2	560	280
PLANNED	9/25/2021	6	96	16
PLANNED	9/25/2021	3	213	71

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/25/2021	1	81	81
PLANNED	9/25/2021	10	560	56
PLANNED	9/25/2021	1	171	171
PLANNED	9/25/2021	1	387	387
PLANNED	9/26/2021	14	770	55
PLANNED	9/26/2021	2	156	78
PLANNED	9/26/2021	2	510	255
CUSTOMER REQUEST	9/26/2021	27	7,614	282
PLANNED	9/26/2021	2	32	16
PLANNED	9/26/2021	1	88	88
PLANNED	9/26/2021	5	955	191
PLANNED	9/26/2021	7	1,190	170
PLANNED	9/26/2021	3	48	16
PLANNED	9/26/2021	1	219	219
PLANNED	9/26/2021	1	126	126
PLANNED	9/26/2021	14	182	13
PLANNED	9/26/2021	1	66	66
PLANNED	9/27/2021	1	396	396
PLANNED	9/27/2021	1	83	83
PLANNED	9/27/2021	2	144	72
PLANNED	9/27/2021	8	232	29
CUSTOMER REQUEST	9/27/2021	80	8,480	106
PLANNED	9/27/2021	3	156	52
PLANNED	9/27/2021	2	146	73
PLANNED	9/27/2021	6	810	135
PLANNED	9/27/2021	2	182	91
PLANNED	9/27/2021	13	390	30
PLANNED	9/27/2021	7	588	84
PLANNED	9/27/2021	1	32	32
PLANNED	9/27/2021	6	138	23
PLANNED	9/27/2021	1	57	57
PLANNED	9/27/2021	1	133	133
PLANNED	9/27/2021	9	630	70
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	3	21	7
PLANNED	9/27/2021	2	24	12
PLANNED	9/27/2021	1	14	14
PLANNED	9/27/2021	1	8	8
PLANNED	9/27/2021	1	159	159
PLANNED	9/27/2021	5	105	21
PLANNED	9/27/2021	9	1,116	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	1	53	53
PLANNED	9/27/2021	4	660	165
PLANNED	9/27/2021	4	44	11
PLANNED	9/27/2021	2	64	32
PLANNED	9/27/2021	4	72	18
PLANNED	9/27/2021	6	150	25
PLANNED	9/27/2021	4	56	14
PLANNED	9/27/2021	1	58	58
PLANNED	9/27/2021	8	432	54
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	4	428	107
PLANNED	9/27/2021	5	345	69
PLANNED	9/27/2021	4	20	5
PLANNED	9/27/2021	3	21	7
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	6	738	123
PLANNED	9/27/2021	1	32	32
PLANNED	9/27/2021	10	440	44
PLANNED	9/27/2021	2	20	10
PLANNED	9/27/2021	3	36	12
PLANNED	9/27/2021	2	28	14
PLANNED	9/27/2021	2	160	80
PLANNED	9/27/2021	1	11	11
PLANNED	9/27/2021	2	122	61
PLANNED	9/27/2021	2	42	21
PLANNED	9/27/2021	2	264	132
PLANNED	9/27/2021	4	32	8
PLANNED	9/27/2021	5	35	7
PLANNED	9/27/2021	3	165	55
PLANNED	9/27/2021	2	570	285
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	1	6	6
CUSTOMER REQUEST	9/27/2021	1	215	215
PLANNED	9/27/2021	8	312	39
PLANNED	9/27/2021	1	9	9
PLANNED	9/27/2021	2	12	6
PLANNED	9/27/2021	3	96	32
PLANNED	9/27/2021	5	125	25
PLANNED	9/27/2021	5	900	180
PLANNED	9/27/2021	2	16	8
PLANNED	9/27/2021	4	812	203

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	1	47	47
PLANNED	9/27/2021	9	837	93
PLANNED	9/27/2021	3	18	6
PLANNED	9/27/2021	9	540	60
PLANNED	9/27/2021	2	72	36
PLANNED	9/27/2021	7	1,379	197
PLANNED	9/27/2021	11	2,376	216
PLANNED	9/27/2021	4	24	6
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	1	89	89
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	1	8	8
PLANNED	9/27/2021	1	9	9
PLANNED	9/27/2021	5	890	178
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	10	120	12
PLANNED	9/27/2021	14	462	33
PLANNED	9/27/2021	1	93	93
PLANNED	9/27/2021	10	830	83
PLANNED	9/27/2021	8	616	77
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	3	24	8
PLANNED	9/27/2021	8	192	24
PLANNED	9/27/2021	59	413	7
PLANNED	9/27/2021	1	141	141
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	2	20	10
PLANNED	9/27/2021	1	65	65
PLANNED	9/27/2021	2	10	5
PLANNED	9/27/2021	4	24	6
CUSTOMER REQUEST	9/27/2021	40	5,520	138
PLANNED	9/27/2021	3	42	14
PLANNED	9/27/2021	2	8	4
PLANNED	9/27/2021	2	84	42
CUSTOMER REQUEST	9/27/2021	9	612	68
PLANNED	9/27/2021	5	130	26
PLANNED	9/27/2021	2	12	6
PLANNED	9/27/2021	1	5	5
PLANNED	9/27/2021	8	310	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	3	63	21
PLANNED	9/27/2021	4	368	92
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	2	44	22
PLANNED	9/27/2021	1	24	24
PLANNED	9/27/2021	4	124	31
PLANNED	9/27/2021	4	48	12
PLANNED	9/27/2021	4	64	16
PLANNED	9/27/2021	10	80	8
PLANNED	9/27/2021	8	688	86
PLANNED	9/27/2021	3	51	17
PLANNED	9/27/2021	3	30	10
PLANNED	9/27/2021	2	158	79
PLANNED	9/27/2021	4	76	19
PLANNED	9/27/2021	3	105	35
PLANNED	9/27/2021	2	20	10
PLANNED	9/27/2021	1	105	105
PLANNED	9/27/2021	3	54	18
PLANNED	9/27/2021	2	30	15
PLANNED	9/27/2021	5	30	6
PLANNED	9/27/2021	2	288	144
PLANNED	9/27/2021	3	90	30
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	3	63	21
PLANNED	9/27/2021	4	16	4
PLANNED	9/27/2021	1	8	8
PLANNED	9/27/2021	1	183	183
PLANNED	9/27/2021	3	18	6
PLANNED	9/27/2021	3	12	4
PLANNED	9/27/2021	4	104	26
PLANNED	9/27/2021	4	152	38
PLANNED	9/27/2021	1	52	52
PLANNED	9/27/2021	2	14	7
PLANNED	9/27/2021	1	8	8
PLANNED	9/27/2021	3	18	6
PLANNED	9/27/2021	1	166	166
PLANNED	9/27/2021	2	20	10
PLANNED	9/27/2021	2	356	178
PLANNED	9/27/2021	1	8	8
PLANNED	9/27/2021	7	448	64
PLANNED	9/27/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	1	90	90
PLANNED	9/27/2021	1	9	9
PLANNED	9/27/2021	3	147	49
PLANNED	9/27/2021	4	444	111
PLANNED	9/27/2021	2	14	7
PLANNED	9/27/2021	3	24	8
PLANNED	9/27/2021	3	21	7
PLANNED	9/27/2021	1	122	122
PLANNED	9/27/2021	1	12	12
PLANNED	9/27/2021	1	119	119
PLANNED	9/27/2021	5	35	7
PLANNED	9/27/2021	2	10	5
PLANNED	9/27/2021	3	12	4
PLANNED	9/27/2021	3	12	4
PLANNED	9/27/2021	5	25	5
PLANNED	9/27/2021	3	33	11
PLANNED	9/27/2021	2	8	4
PLANNED	9/27/2021	2	8	4
PLANNED	9/27/2021	4	44	11
PLANNED	9/27/2021	7	259	37
PLANNED	9/27/2021	3	27	9
PLANNED	9/27/2021	2	12	6
PLANNED	9/27/2021	4	40	10
PLANNED	9/27/2021	5	270	54
PLANNED	9/27/2021	5	230	46
PLANNED	9/27/2021	1	89	89
PLANNED	9/27/2021	33	264	8
PLANNED	9/27/2021	4	272	68
PLANNED	9/27/2021	1	12	12
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	1	51	51
PLANNED	9/27/2021	2	12	6
PLANNED	9/27/2021	1	4	4
PLANNED	9/27/2021	3	15	5
PLANNED	9/27/2021	1	4	4
PLANNED	9/27/2021	7	350	50
PLANNED	9/27/2021	1	5	5
PLANNED	9/27/2021	2	22	11
PLANNED	9/27/2021	1	113	113
PLANNED	9/27/2021	10	750	75
PLANNED	9/27/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	4	28	7
PLANNED	9/27/2021	2	14	7
PLANNED	9/27/2021	2	18	9
PLANNED	9/27/2021	3	168	56
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	9	72	8
PLANNED	9/27/2021	2	20	10
PLANNED	9/27/2021	3	96	32
PLANNED	9/27/2021	5	45	9
PLANNED	9/27/2021	1	51	51
PLANNED	9/27/2021	2	48	24
PLANNED	9/27/2021	5	25	5
PLANNED	9/27/2021	3	12	4
PLANNED	9/27/2021	14	1,484	106
PLANNED	9/27/2021	3	18	6
PLANNED	9/27/2021	12	1,368	114
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	2	189	109
PLANNED	9/27/2021	3	12	4
PLANNED	9/27/2021	5	660	132
PLANNED	9/27/2021	6	60	10
PLANNED	9/27/2021	8	176	22
PLANNED	9/27/2021	3	72	24
PLANNED	9/27/2021	3	36	12
PLANNED	9/27/2021	1	41	41
PLANNED	9/27/2021	1	40	40
PLANNED	9/27/2021	2	18	9
PLANNED	9/27/2021	2	172	86
CUSTOMER REQUEST	9/27/2021	1	231	231
PLANNED	9/27/2021	3	27	9
PLANNED	9/27/2021	1	9	9
PLANNED	9/27/2021	4	32	8
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	4	28	7
PLANNED	9/27/2021	3	24	8
PLANNED	9/27/2021	4	20	5
PLANNED	9/27/2021	4	16	4
PLANNED	9/27/2021	1	6	6
PLANNED	9/27/2021	4	16	4
PLANNED	9/27/2021	3	24	8
PLANNED	9/27/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/27/2021	6	84	14
PLANNED	9/27/2021	1	7	7
PLANNED	9/27/2021	3	21	7
PLANNED	9/27/2021	2	110	55
PLANNED	9/27/2021	1	10	10
PLANNED	9/27/2021	4	136	34
PLANNED	9/27/2021	3	18	6
PLANNED	9/27/2021	1	5	5
PLANNED	9/27/2021	3	21	7
PLANNED	9/27/2021	3	18	6
CUSTOMER REQUEST	9/27/2021	1	31	31
PLANNED	9/27/2021	1	262	262
PLANNED	9/27/2021	2	336	168
PLANNED	9/27/2021	2	682	341
PLANNED	9/27/2021	1	277	277
PLANNED	9/27/2021	2	528	264
PLANNED	9/28/2021	2	854	427
PLANNED	9/28/2021	5	440	88
PLANNED	9/28/2021	6	2,532	422
PLANNED	9/28/2021	7	14	2
PLANNED	9/28/2021	1	10	10
PLANNED	9/28/2021	1	41	41
PLANNED	9/28/2021	2	142	71
PLANNED	9/28/2021	4	24	6
PLANNED	9/28/2021	5	480	96
PLANNED	9/28/2021	7	644	92
PLANNED	9/28/2021	6	546	91
PLANNED	9/28/2021	1	10	10
PLANNED	9/28/2021	6	354	59
PLANNED	9/28/2021	7	168	24
PLANNED	9/28/2021	5	75	15
PLANNED	9/28/2021	4	160	40
PLANNED	9/28/2021	3	75	25
PLANNED	9/28/2021	6	1,038	173
PLANNED	9/28/2021	3	783	261
PLANNED	9/28/2021	5	35	7
PLANNED	9/28/2021	3	117	39
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	9	153	17
PLANNED	9/28/2021	5	405	81
PLANNED	9/28/2021	9	351	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	6	216	36
CUSTOMER REQUEST	9/28/2021	11	407	37
PLANNED	9/28/2021	4	44	11
PLANNED	9/28/2021	4	24	6
PLANNED	9/28/2021	9	792	88
PLANNED	9/28/2021	11	1,353	123
PLANNED	9/28/2021	1	10	10
PLANNED	9/28/2021	2	10	5
PLANNED	9/28/2021	18	1,440	80
PLANNED	9/28/2021	9	324	36
PLANNED	9/28/2021	5	25	5
PLANNED	9/28/2021	5	365	73
PLANNED	9/28/2021	1	10	10
PLANNED	9/28/2021	2	66	33
PLANNED	9/28/2021	2	12	6
PLANNED	9/28/2021	1	14	14
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	3	249	83
PLANNED	9/28/2021	4	32	8
PLANNED	9/28/2021	12	1,092	91
PLANNED	9/28/2021	5	455	91
PLANNED	9/28/2021	4	80	20
PLANNED	9/28/2021	4	68	17
PLANNED	9/28/2021	3	18	6
PLANNED	9/28/2021	1	7	7
PLANNED	9/28/2021	10	60	6
PLANNED	9/28/2021	2	12	6
PLANNED	9/28/2021	9	207	23
PLANNED	9/28/2021	11	99	9
PLANNED	9/28/2021	7	574	82
PLANNED	9/28/2021	2	222	111
PLANNED	9/28/2021	3	24	8
PLANNED	9/28/2021	5	345	69
PLANNED	9/28/2021	1	7	7
PLANNED	9/28/2021	18	1,350	75
PLANNED	9/28/2021	7	413	59
PLANNED	9/28/2021	4	92	23
PLANNED	9/28/2021	2	180	90
PLANNED	9/28/2021	9	81	9
PLANNED	9/28/2021	3	30	10
PLANNED	9/28/2021	4	68	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	5	140	28
PLANNED	9/28/2021	4	240	60
PLANNED	9/28/2021	2	22	11
PLANNED	9/28/2021	2	30	15
PLANNED	9/28/2021	2	24	12
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	2	22	11
PLANNED	9/28/2021	2	14	7
PLANNED	9/28/2021	1	17	17
PLANNED	9/28/2021	2	62	31
PLANNED	9/28/2021	9	855	95
PLANNED	9/28/2021	4	60	15
PLANNED	9/28/2021	3	24	8
PLANNED	9/28/2021	4	256	64
PLANNED	9/28/2021	4	40	10
PLANNED	9/28/2021	2	62	31
PLANNED	9/28/2021	2	24	12
PLANNED	9/28/2021	1	34	34
PLANNED	9/28/2021	1	7	7
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	1	105	105
PLANNED	9/28/2021	5	285	57
PLANNED	9/28/2021	11	550	50
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	2	10	5
PLANNED	9/28/2021	3	30	10
PLANNED	9/28/2021	10	690	69
PLANNED	9/28/2021	2	277	246
PLANNED	9/28/2021	1	55	55
PLANNED	9/28/2021	1	12	12
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	3	30	10
PLANNED	9/28/2021	7	455	65
PLANNED	9/28/2021	4	224	56
CUSTOMER REQUEST	9/28/2021	12	912	76
PLANNED	9/28/2021	3	63	21
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	4	60	15
PLANNED	9/28/2021	3	21	7
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	3	54	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	4	24	6
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	4	32	8
PLANNED	9/28/2021	5	780	156
PLANNED	9/28/2021	1	62	62
PLANNED	9/28/2021	3	57	19
PLANNED	9/28/2021	14	700	50
PLANNED	9/28/2021	1	17	17
CUSTOMER REQUEST	9/28/2021	34	442	13
PLANNED	9/28/2021	2	54	27
PLANNED	9/28/2021	1	20	20
PLANNED	9/28/2021	1	13	13
PLANNED	9/28/2021	2	16	8
PLANNED	9/28/2021	7	427	61
PLANNED	9/28/2021	3	255	85
PLANNED	9/28/2021	6	12	2
PLANNED	9/28/2021	2	366	183
PLANNED	9/28/2021	9	1,386	154
PLANNED	9/28/2021	9	513	57
PLANNED	9/28/2021	3	30	10
PLANNED	9/28/2021	4	964	241
PLANNED	9/28/2021	4	60	15
PLANNED	9/28/2021	6	2,310	385
PLANNED	9/28/2021	7	350	50
PLANNED	9/28/2021	3	60	20
PLANNED	9/28/2021	4	1,540	385
PLANNED	9/28/2021	6	84	14
PLANNED	9/28/2021	3	39	13
PLANNED	9/28/2021	2	56	28
PLANNED	9/28/2021	3	66	22
PLANNED	9/28/2021	6	894	149
PLANNED	9/28/2021	2	314	157
PLANNED	9/28/2021	7	266	38
PLANNED	9/28/2021	4	44	11
PLANNED	9/28/2021	2	32	16
PLANNED	9/28/2021	2	18	9
PLANNED	9/28/2021	7	476	68
PLANNED	9/28/2021	3	24	8
PLANNED	9/28/2021	2	232	116
PLANNED	9/28/2021	1	14	14
PLANNED	9/28/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	1	70	70
PLANNED	9/28/2021	3	81	27
PLANNED	9/28/2021	11	264	24
PLANNED	9/28/2021	3	24	8
PLANNED	9/28/2021	7	28	4
PLANNED	9/28/2021	2	60	30
PLANNED	9/28/2021	8	248	31
PLANNED	9/28/2021	4	32	8
PLANNED	9/28/2021	1	87	87
PLANNED	9/28/2021	2	76	38
PLANNED	9/28/2021	6	384	64
PLANNED	9/28/2021	2	100	50
PLANNED	9/28/2021	2	2	1
PLANNED	9/28/2021	2	12	6
PLANNED	9/28/2021	4	160	40
PLANNED	9/28/2021	3	48	16
PLANNED	9/28/2021	4	116	29
PLANNED	9/28/2021	10	280	28
PLANNED	9/28/2021	6	72	12
PLANNED	9/28/2021	5	35	7
PLANNED	9/28/2021	8	528	66
PLANNED	9/28/2021	1	5	5
PLANNED	9/28/2021	2	80	40
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	4	108	27
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	3	51	17
PLANNED	9/28/2021	5	770	154
PLANNED	9/28/2021	2	62	31
PLANNED	9/28/2021	3	282	94
PLANNED	9/28/2021	4	304	76
PLANNED	9/28/2021	2	50	25
PLANNED	9/28/2021	2	172	86
PLANNED	9/28/2021	7	84	12
PLANNED	9/28/2021	9	171	19
PLANNED	9/28/2021	1	10	10
PLANNED	9/28/2021	2	86	43
PLANNED	9/28/2021	2	16	8
PLANNED	9/28/2021	4	36	9
PLANNED	9/28/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	2	130	65
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	3	264	88
PLANNED	9/28/2021	6	96	16
PLANNED	9/28/2021	1	5	5
PLANNED	9/28/2021	6	30	5
PLANNED	9/28/2021	3	39	13
PLANNED	9/28/2021	1	11	11
PLANNED	9/28/2021	2	20	10
PLANNED	9/28/2021	2	22	11
PLANNED	9/28/2021	3	60	20
PLANNED	9/28/2021	10	330	33
PLANNED	9/28/2021	1	14	14
PLANNED	9/28/2021	4	44	11
PLANNED	9/28/2021	1	20	20
PLANNED	9/28/2021	7	147	21
PLANNED	9/28/2021	1	7	7
PLANNED	9/28/2021	4	88	22
PLANNED	9/28/2021	8	296	37
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	1	8	8
PLANNED	9/28/2021	7	518	74
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	4	44	11
PLANNED	9/28/2021	3	21	7
PLANNED	9/28/2021	3	18	6
PLANNED	9/28/2021	5	55	11
PLANNED	9/28/2021	3	66	22
PLANNED	9/28/2021	5	65	13
PLANNED	9/28/2021	2	14	7
PLANNED	9/28/2021	3	39	13
PLANNED	9/28/2021	2	22	11
PLANNED	9/28/2021	13	182	14
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	4	36	9
PLANNED	9/28/2021	1	5	5
PLANNED	9/28/2021	12	1,140	95
PLANNED	9/28/2021	4	24	6
PLANNED	9/28/2021	4	256	64
PLANNED	9/28/2021	5	345	69
PLANNED	9/28/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	2	12	6
PLANNED	9/28/2021	1	23	23
CUSTOMER REQUEST	9/28/2021	10	780	78
PLANNED	9/28/2021	12	240	20
PLANNED	9/28/2021	3	21	7
PLANNED	9/28/2021	3	21	7
PLANNED	9/28/2021	8	160	20
PLANNED	9/28/2021	2	12	6
PLANNED	9/28/2021	4	56	14
PLANNED	9/28/2021	5	25	5
PLANNED	9/28/2021	8	64	8
PLANNED	9/28/2021	1	13	13
PLANNED	9/28/2021	2	206	103
PLANNED	9/28/2021	1	13	13
PLANNED	9/28/2021	2	10	5
PLANNED	9/28/2021	3	15	5
PLANNED	9/28/2021	5	30	6
PLANNED	9/28/2021	7	105	15
PLANNED	9/28/2021	4	20	5
PLANNED	9/28/2021	3	18	6
PLANNED	9/28/2021	2	20	10
PLANNED	9/28/2021	39	2,964	76
PLANNED	9/28/2021	4	48	12
PLANNED	9/28/2021	2	116	58
PLANNED	9/28/2021	1	12	12
PLANNED	9/28/2021	1	12	12
PLANNED	9/28/2021	3	24	8
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	3	18	6
PLANNED	9/28/2021	1	6	6
PLANNED	9/28/2021	5	40	8
PLANNED	9/28/2021	1	11	11
PLANNED	9/28/2021	12	96	8
PLANNED	9/28/2021	4	32	8
PLANNED	9/28/2021	1	7	7
PLANNED	9/28/2021	2	26	13
PLANNED	9/28/2021	2	20	10
PLANNED	9/28/2021	3	51	17
PLANNED	9/28/2021	1	9	9
PLANNED	9/28/2021	1	15	15
CUSTOMER REQUEST	9/28/2021	1	41	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/28/2021	3	21	7
PLANNED	9/28/2021	1	43	43
PLANNED	9/28/2021	2	18	9
PLANNED	9/28/2021	1	17	17
CUSTOMER REQUEST	9/28/2021	1	343	343
CUSTOMER REQUEST	9/28/2021	1	728	728
PLANNED	9/28/2021	1	133	133
PLANNED	9/28/2021	1	107	107
PLANNED	9/28/2021	1	70	70
PLANNED	9/28/2021	1	242	242
PLANNED	9/28/2021	3	594	198
PLANNED	9/28/2021	3	342	114
PLANNED	9/28/2021	2	314	157
PLANNED	9/28/2021	1	185	185
PLANNED	9/29/2021	2	160	80
PLANNED	9/29/2021	1	80	80
PLANNED	9/29/2021	37	2,072	56
PLANNED	9/29/2021	2	58	34
PLANNED	9/29/2021	1	243	243
PLANNED	9/29/2021	1	70	70
PLANNED	9/29/2021	1	57	57
PLANNED	9/29/2021	2	176	88
PLANNED	9/29/2021	5	345	69
PLANNED	9/29/2021	3	33	11
PLANNED	9/29/2021	3	21	7
PLANNED	9/29/2021	6	114	19
PLANNED	9/29/2021	1	30	30
PLANNED	9/29/2021	2	16	8
PLANNED	9/29/2021	2	162	81
PLANNED	9/29/2021	6	318	53
PLANNED	9/29/2021	3	24	8
PLANNED	9/29/2021	4	44	11
PLANNED	9/29/2021	8	320	40
PLANNED	9/29/2021	4	24	6
PLANNED	9/29/2021	4	28	7
PLANNED	9/29/2021	1	6	6
PLANNED	9/29/2021	3	18	6
PLANNED	9/29/2021	3	21	7
PLANNED	9/29/2021	2	24	12
PLANNED	9/29/2021	2	496	248
PLANNED	9/29/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	2	110	55
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	2	14	7
PLANNED	9/29/2021	5	55	11
PLANNED	9/29/2021	1	63	63
PLANNED	9/29/2021	3	186	62
PLANNED	9/29/2021	5	190	38
PLANNED	9/29/2021	6	54	9
PLANNED	9/29/2021	2	38	19
PLANNED	9/29/2021	4	124	31
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	4	24	6
CUSTOMER REQUEST	9/29/2021	60	9,936	237
PLANNED	9/29/2021	14	2,144	156
PLANNED	9/29/2021	12	876	73
PLANNED	9/29/2021	1	14	14
PLANNED	9/29/2021	3	18	6
PLANNED	9/29/2021	1	6	6
PLANNED	9/29/2021	2	12	6
PLANNED	9/29/2021	1	4	4
PLANNED	9/29/2021	1	125	125
PLANNED	9/29/2021	6	540	90
PLANNED	9/29/2021	2	276	138
PLANNED	9/29/2021	6	480	80
PLANNED	9/29/2021	1	12	12
PLANNED	9/29/2021	9	999	111
PLANNED	9/29/2021	2	72	36
PLANNED	9/29/2021	1	10	10
PLANNED	9/29/2021	4	44	11
PLANNED	9/29/2021	22	4,796	218
PLANNED	9/29/2021	1	86	86
PLANNED	9/29/2021	3	162	54
PLANNED	9/29/2021	3	54	18
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	14	478	167
PLANNED	9/29/2021	6	90	15
PLANNED	9/29/2021	3	24	8
PLANNED	9/29/2021	1	23	23
PLANNED	9/29/2021	2	272	136
PLANNED	9/29/2021	2	16	8
PLANNED	9/29/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	1	6	6
PLANNED	9/29/2021	5	460	92
PLANNED	9/29/2021	5	70	14
PLANNED	9/29/2021	1	16	16
PLANNED	9/29/2021	1	80	80
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	12	780	65
PLANNED	9/29/2021	4	328	82
PLANNED	9/29/2021	2	20	10
PLANNED	9/29/2021	1	10	10
PLANNED	9/29/2021	2	14	7
PLANNED	9/29/2021	2	18	9
PLANNED	9/29/2021	1	11	11
PLANNED	9/29/2021	3	27	9
PLANNED	9/29/2021	2	16	8
PLANNED	9/29/2021	3	21	7
PLANNED	9/29/2021	3	15	5
PLANNED	9/29/2021	6	42	7
PLANNED	9/29/2021	2	22	11
PLANNED	9/29/2021	1	49	49
PLANNED	9/29/2021	3	222	74
PLANNED	9/29/2021	7	70	10
PLANNED	9/29/2021	2	20	10
PLANNED	9/29/2021	8	88	11
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	4	304	76
PLANNED	9/29/2021	6	624	104
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	5	55	11
PLANNED	9/29/2021	7	371	53
PLANNED	9/29/2021	4	44	11
PLANNED	9/29/2021	4	24	6
PLANNED	9/29/2021	1	10	10
PLANNED	9/29/2021	2	46	23
PLANNED	9/29/2021	2	444	222
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	5	590	118
PLANNED	9/29/2021	2	46	23
PLANNED	9/29/2021	4	384	96
PLANNED	9/29/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	2	112	56
PLANNED	9/29/2021	1	10	10
PLANNED	9/29/2021	4	680	170
PLANNED	9/29/2021	2	48	24
PLANNED	9/29/2021	17	1,887	111
PLANNED	9/29/2021	2	130	65
PLANNED	9/29/2021	2	202	101
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	1	16	16
PLANNED	9/29/2021	7	714	102
PLANNED	9/29/2021	4	80	20
PLANNED	9/29/2021	2	18	9
PLANNED	9/29/2021	4	8	2
PLANNED	9/29/2021	3	39	13
PLANNED	9/29/2021	1	137	137
PLANNED	9/29/2021	2	136	68
PLANNED	9/29/2021	2	488	244
PLANNED	9/29/2021	1	15	15
PLANNED	9/29/2021	9	81	9
PLANNED	9/29/2021	2	12	6
PLANNED	9/29/2021	2	534	267
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	3	105	35
PLANNED	9/29/2021	6	984	164
PLANNED	9/29/2021	4	588	147
CUSTOMER REQUEST	9/29/2021	1	61	61
PLANNED	9/29/2021	1	8	8
CUSTOMER REQUEST	9/29/2021	2	22	11
CUSTOMER REQUEST	9/29/2021	3	21	7
PLANNED	9/29/2021	8	624	78
PLANNED	9/29/2021	1	72	72
PLANNED	9/29/2021	5	55	11
PLANNED	9/29/2021	9	171	19
PLANNED	9/29/2021	2	12	6
PLANNED	9/29/2021	2	26	13
PLANNED	9/29/2021	3	27	9
PLANNED	9/29/2021	3	525	175
CUSTOMER REQUEST	9/29/2021	1	349	349
PLANNED	9/29/2021	3	30	10
PLANNED	9/29/2021	42	2,856	68
PLANNED	9/29/2021	3	261	87

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	7	882	126
PLANNED	9/29/2021	2	34	17
PLANNED	9/29/2021	5	150	30
PLANNED	9/29/2021	2	254	127
PLANNED	9/29/2021	2	12	6
PLANNED	9/29/2021	1	8	8
PLANNED	9/29/2021	1	18	18
PLANNED	9/29/2021	2	288	144
PLANNED	9/29/2021	7	49	7
PLANNED	9/29/2021	2	134	67
CUSTOMER REQUEST	9/29/2021	1	74	74
PLANNED	9/29/2021	4	676	169
PLANNED	9/29/2021	3	90	30
PLANNED	9/29/2021	2	22	11
PLANNED	9/29/2021	11	957	87
PLANNED	9/29/2021	2	22	11
PLANNED	9/29/2021	3	315	105
PLANNED	9/29/2021	1	54	54
PLANNED	9/29/2021	1	17	17
PLANNED	9/29/2021	1	52	52
PLANNED	9/29/2021	8	584	73
PLANNED	9/29/2021	3	24	8
PLANNED	9/29/2021	2	20	10
PLANNED	9/29/2021	1	95	95
PLANNED	9/29/2021	4	276	69
PLANNED	9/29/2021	1	5	5
PLANNED	9/29/2021	1	93	93
PLANNED	9/29/2021	4	580	145
PLANNED	9/29/2021	6	450	75
PLANNED	9/29/2021	5	165	33
PLANNED	9/29/2021	1	7	7
PLANNED	9/29/2021	16	304	19
PLANNED	9/29/2021	2	22	11
PLANNED	9/29/2021	2	16	8
PLANNED	9/29/2021	2	14	7
PLANNED	9/29/2021	2	50	25
PLANNED	9/29/2021	1	10	10
PLANNED	9/29/2021	4	36	9
PLANNED	9/29/2021	8	224	28
PLANNED	9/29/2021	2	34	17
PLANNED	9/29/2021	1	32	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	2	26	13
PLANNED	9/29/2021	3	24	8
PLANNED	9/29/2021	3	21	7
PLANNED	9/29/2021	2	296	148
PLANNED	9/29/2021	2	42	21
PLANNED	9/29/2021	1	11	11
PLANNED	9/29/2021	2	186	93
PLANNED	9/29/2021	11	638	58
PLANNED	9/29/2021	9	63	7
PLANNED	9/29/2021	11	737	67
PLANNED	9/29/2021	3	15	5
PLANNED	9/29/2021	2	240	120
PLANNED	9/29/2021	2	22	11
PLANNED	9/29/2021	5	685	137
PLANNED	9/29/2021	4	72	18
PLANNED	9/29/2021	1	42	42
PLANNED	9/29/2021	2	72	36
PLANNED	9/29/2021	1	6	6
PLANNED	9/29/2021	4	148	37
CUSTOMER REQUEST	9/29/2021	1	299	299
PLANNED	9/29/2021	2	176	88
PLANNED	9/29/2021	2	200	100
PLANNED	9/29/2021	3	3	1
PLANNED	9/29/2021	1	5	5
PLANNED	9/29/2021	10	210	21
PLANNED	9/29/2021	6	336	56
PLANNED	9/29/2021	7	497	71
PLANNED	9/29/2021	5	1,435	287
PLANNED	9/29/2021	4	232	58
PLANNED	9/29/2021	3	48	16
PLANNED	9/29/2021	3	30	10
PLANNED	9/29/2021	2	186	93
PLANNED	9/29/2021	1	24	24
PLANNED	9/29/2021	1	30	30
PLANNED	9/29/2021	1	61	61
PLANNED	9/29/2021	1	56	56
PLANNED	9/29/2021	8	200	25
PLANNED	9/29/2021	3	186	62
PLANNED	9/29/2021	7	168	24
PLANNED	9/29/2021	2	8	4
PLANNED	9/29/2021	1	32	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/29/2021	1	31	31
PLANNED	9/29/2021	2	26	13
PLANNED	9/29/2021	2	34	17
CUSTOMER REQUEST	9/29/2021	1	297	297
PLANNED	9/29/2021	2	298	149
CUSTOMER REQUEST	9/29/2021	3	285	95
PLANNED	9/29/2021	1	95	95
PLANNED	9/29/2021	8	408	51
PLANNED	9/29/2021	5	585	117
PLANNED	9/30/2021	1	159	159
PLANNED	9/30/2021	13	1,027	79
CUSTOMER REQUEST	9/30/2021	2	316	158
PLANNED	9/30/2021	9	963	107
PLANNED	9/30/2021	2	190	95
PLANNED	9/30/2021	11	781	71
CUSTOMER REQUEST	9/30/2021	7	2,919	417
PLANNED	9/30/2021	1	80	80
CUSTOMER REQUEST	9/30/2021	1	32	32
PLANNED	9/30/2021	3	33	11
PLANNED	9/30/2021	4	592	148
PLANNED	9/30/2021	15	1,245	83
PLANNED	9/30/2021	10	930	93
PLANNED	9/30/2021	10	950	95
PLANNED	9/30/2021	12	1,344	112
PLANNED	9/30/2021	1	193	193
PLANNED	9/30/2021	1	49	49
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	2	124	77
PLANNED	9/30/2021	3	39	13
PLANNED	9/30/2021	1	153	153
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	2	168	84
PLANNED	9/30/2021	1	9	9
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	2	18	9
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	1	11	11
PLANNED	9/30/2021	4	256	64
PLANNED	9/30/2021	2	188	95
PLANNED	9/30/2021	1	124	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/30/2021	19	2,546	134
PLANNED	9/30/2021	2	126	63
PLANNED	9/30/2021	7	854	122
CUSTOMER REQUEST	9/30/2021	25	10,200	408
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	4	68	17
CUSTOMER REQUEST	9/30/2021	2	186	93
PLANNED	9/30/2021	2	24	12
PLANNED	9/30/2021	3	24	8
PLANNED	9/30/2021	1	6	6
CUSTOMER REQUEST	9/30/2021	26	10,244	394
PLANNED	9/30/2021	41	3,485	85
PLANNED	9/30/2021	4	124	31
PLANNED	9/30/2021	1	27	27
PLANNED	9/30/2021	4	500	125
PLANNED	9/30/2021	9	603	67
PLANNED	9/30/2021	6	502	477
PLANNED	9/30/2021	2	14	7
PLANNED	9/30/2021	2	48	24
PLANNED	9/30/2021	2	200	100
PLANNED	9/30/2021	2	194	97
PLANNED	9/30/2021	1	9	9
PLANNED	9/30/2021	3	285	95
PLANNED	9/30/2021	2	16	8
CUSTOMER REQUEST	9/30/2021	50	31,450	629
PLANNED	9/30/2021	2	328	164
PLANNED	9/30/2021	5	1,046	354
PLANNED	9/30/2021	18	234	13
PLANNED	9/30/2021	3	18	6
PLANNED	9/30/2021	1	10	10
PLANNED	9/30/2021	5	870	174
PLANNED	9/30/2021	1	9	9
PLANNED	9/30/2021	2	208	156
PLANNED	9/30/2021	19	2,337	123
PLANNED	9/30/2021	1	40	40
PLANNED	9/30/2021	4	436	109
PLANNED	9/30/2021	1	20	20
PLANNED	9/30/2021	8	152	19
PLANNED	9/30/2021	1	10	10
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	1	10	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/30/2021	2	18	9
PLANNED	9/30/2021	2	78	39
PLANNED	9/30/2021	1	41	41
PLANNED	9/30/2021	2	12	6
PLANNED	9/30/2021	2	298	149
PLANNED	9/30/2021	2	194	97
PLANNED	9/30/2021	1	8	8
PLANNED	9/30/2021	3	21	7
PLANNED	9/30/2021	2	14	7
PLANNED	9/30/2021	3	18	6
PLANNED	9/30/2021	2	16	8
PLANNED	9/30/2021	1	12	12
CUSTOMER REQUEST	9/30/2021	8	16	2
PLANNED	9/30/2021	10	180	18
PLANNED	9/30/2021	2	18	9
CUSTOMER REQUEST	9/30/2021	1	125	125
PLANNED	9/30/2021	4	300	75
PLANNED	9/30/2021	3	132	44
PLANNED	9/30/2021	3	249	83
PLANNED	9/30/2021	3	219	73
PLANNED	9/30/2021	3	42	14
PLANNED	9/30/2021	37	932	104
PLANNED	9/30/2021	4	84	21
PLANNED	9/30/2021	2	358	179
PLANNED	9/30/2021	1	251	251
PLANNED	9/30/2021	1	8	8
PLANNED	9/30/2021	2	272	136
PLANNED	9/30/2021	2	156	78
PLANNED	9/30/2021	1	8	8
PLANNED	9/30/2021	1	100	100
PLANNED	9/30/2021	1	63	63
PLANNED	9/30/2021	2	20	10
PLANNED	9/30/2021	3	237	79
PLANNED	9/30/2021	8	120	15
PLANNED	9/30/2021	2	64	32
PLANNED	9/30/2021	30	4,290	143
PLANNED	9/30/2021	7	308	44
PLANNED	9/30/2021	1	9	9
PLANNED	9/30/2021	1	5	5
PLANNED	9/30/2021	2	14	7
CUSTOMER REQUEST	9/30/2021	14	3,440	568

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/30/2021	3	42	14
PLANNED	9/30/2021	41	6,847	167
PLANNED	9/30/2021	41	11,480	280
PLANNED	9/30/2021	1	8	8
PLANNED	9/30/2021	1	11	11
PLANNED	9/30/2021	1	3	3
PLANNED	9/30/2021	1	131	131
PLANNED	9/30/2021	2	14	7
PLANNED	9/30/2021	1	9	9
PLANNED	9/30/2021	7	140	20
PLANNED	9/30/2021	4	64	16
CUSTOMER REQUEST	9/30/2021	2	92	46
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	1	66	66
PLANNED	9/30/2021	4	108	27
PLANNED	9/30/2021	2	14	7
PLANNED	9/30/2021	2	414	207
PLANNED	9/30/2021	36	576	16
PLANNED	9/30/2021	2	184	92
PLANNED	9/30/2021	7	420	60
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	9	45	5
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	1	137	137
PLANNED	9/30/2021	2	20	10
PLANNED	9/30/2021	1	10	10
PLANNED	9/30/2021	6	240	40
PLANNED	9/30/2021	2	190	95
PLANNED	9/30/2021	1	22	22
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	2	16	8
PLANNED	9/30/2021	12	168	14
PLANNED	9/30/2021	1	82	82
PLANNED	9/30/2021	2	26	13
PLANNED	9/30/2021	3	423	141
PLANNED	9/30/2021	1	10	10
PLANNED	9/30/2021	2	58	29
PLANNED	9/30/2021	1	86	86
PLANNED	9/30/2021	2	350	175
PLANNED	9/30/2021	4	128	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	9/30/2021	3	42	14
PLANNED	9/30/2021	2	70	35
PLANNED	9/30/2021	1	6	6
PLANNED	9/30/2021	2	16	8
PLANNED	9/30/2021	4	52	13
PLANNED	9/30/2021	2	80	40
PLANNED	9/30/2021	13	1,144	88
PLANNED	9/30/2021	1	67	67
PLANNED	9/30/2021	3	201	67
PLANNED	9/30/2021	4	136	34
PLANNED	9/30/2021	2	12	6
PLANNED	9/30/2021	1	104	104
PLANNED	9/30/2021	1	54	54
CUSTOMER REQUEST	9/30/2021	8	1,848	231
PLANNED	9/30/2021	1	7	7
PLANNED	9/30/2021	2	82	41
CUSTOMER REQUEST	9/30/2021	15	15	1
PLANNED	9/30/2021	8	64	8
CUSTOMER REQUEST	9/30/2021	11	11	1
PLANNED	9/30/2021	10	1,300	130
CUSTOMER REQUEST	9/30/2021	1	106	106
PLANNED	9/30/2021	6	690	115
PLANNED	9/30/2021	1	153	153
PLANNED	9/30/2021	1	58	58
PLANNED	9/30/2021	1	189	189
PLANNED	9/30/2021	1	141	141
PLANNED	9/30/2021	1	44	44
PLANNED	9/30/2021	9	3,861	429
PLANNED	9/30/2021	25	7,950	318
PLANNED	10/1/2021	4	432	108
PLANNED	10/1/2021	3	327	109
PLANNED	10/1/2021	4	484	121
PLANNED	10/1/2021	3	96	32
PLANNED	10/1/2021	7	420	91
PLANNED	10/1/2021	2	94	47
CUSTOMER REQUEST	10/1/2021	10	250	25
PLANNED	10/1/2021	2	30	15
PLANNED	10/1/2021	41	2,747	67
PLANNED	10/1/2021	1	103	103
PLANNED	10/1/2021	7	546	78
PLANNED	10/1/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/1/2021	14	742	53
PLANNED	10/1/2021	3	234	78
CUSTOMER REQUEST	10/1/2021	2	202	101
PLANNED	10/1/2021	1	10	10
PLANNED	10/1/2021	1	7	7
CUSTOMER REQUEST	10/1/2021	2	110	55
PLANNED	10/1/2021	1	9	9
PLANNED	10/1/2021	9	9	1
PLANNED	10/1/2021	1	8	8
PLANNED	10/1/2021	1	7	7
PLANNED	10/1/2021	2	12	6
PLANNED	10/1/2021	1	27	27
PLANNED	10/1/2021	19	1,976	104
PLANNED	10/1/2021	1	7	7
PLANNED	10/1/2021	3	302	138
PLANNED	10/1/2021	2	28	14
CUSTOMER REQUEST	10/1/2021	4	44	11
PLANNED	10/1/2021	2	186	93
CUSTOMER REQUEST	10/1/2021	7	273	39
PLANNED	10/1/2021	16	768	48
PLANNED	10/1/2021	12	2,268	189
PLANNED	10/1/2021	4	340	85
PLANNED	10/1/2021	1	130	130
PLANNED	10/1/2021	2	14	7
PLANNED	10/1/2021	10	1,620	162
PLANNED	10/1/2021	2	30	15
PLANNED	10/1/2021	3	93	31
PLANNED	10/1/2021	3	33	11
PLANNED	10/1/2021	1	13	13
PLANNED	10/1/2021	10	550	55
PLANNED	10/1/2021	1	88	88
PLANNED	10/1/2021	1	22	22
PLANNED	10/1/2021	22	2,156	98
PLANNED	10/1/2021	1	5	5
PLANNED	10/1/2021	1	13	13
PLANNED	10/1/2021	1	83	83
PLANNED	10/1/2021	5	545	109
PLANNED	10/1/2021	9	963	107
PLANNED	10/1/2021	2	26	13
CUSTOMER REQUEST	10/1/2021	1	198	198
PLANNED	10/1/2021	3	78	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/1/2021	7	434	62
PLANNED	10/1/2021	8	696	87
PLANNED	10/1/2021	1	23	23
PLANNED	10/1/2021	5	65	13
PLANNED	10/1/2021	1	33	33
PLANNED	10/1/2021	20	260	13
PLANNED	10/1/2021	9	630	70
PLANNED	10/1/2021	1	56	56
PLANNED	10/1/2021	3	45	15
PLANNED	10/1/2021	35	1,645	47
PLANNED	10/1/2021	35	1,645	47
PLANNED	10/1/2021	18	1,350	75
PLANNED	10/1/2021	33	2,013	61
PLANNED	10/1/2021	4	56	14
PLANNED	10/1/2021	25	625	25
CUSTOMER REQUEST	10/1/2021	8	232	29
PLANNED	10/1/2021	2	162	81
PLANNED	10/1/2021	4	60	15
PLANNED	10/1/2021	19	380	20
PLANNED	10/1/2021	1	151	151
PLANNED	10/1/2021	8	392	49
CUSTOMER REQUEST	10/1/2021	8	320	40
PLANNED	10/1/2021	3	39	13
CUSTOMER REQUEST	10/1/2021	1	19	19
PLANNED	10/1/2021	3	102	34
PLANNED	10/1/2021	3	72	24
PLANNED	10/1/2021	2	502	251
PLANNED	10/1/2021	3	81	27
PLANNED	10/1/2021	6	264	44
PLANNED	10/1/2021	7	756	108
CUSTOMER REQUEST	10/1/2021	7	644	92
CUSTOMER REQUEST	10/1/2021	19	190	10
PLANNED	10/1/2021	4	220	55
PLANNED	10/1/2021	7	3,003	429
PLANNED	10/1/2021	1	145	145
PLANNED	10/2/2021	8	184	23
PLANNED	10/2/2021	5	525	105
PLANNED	10/2/2021	1	84	84
PLANNED	10/2/2021	1	328	328
PLANNED	10/2/2021	1	70	70
PLANNED	10/2/2021	1	64	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/2/2021	1	247	247
PLANNED	10/2/2021	11	1,199	109
PLANNED	10/2/2021	11	825	75
PLANNED	10/2/2021	2	450	225
PLANNED	10/2/2021	2	196	98
PLANNED	10/2/2021	1	202	202
PLANNED	10/2/2021	9	9	1
PLANNED	10/2/2021	1	15	15
PLANNED	10/2/2021	1	116	116
PLANNED	10/2/2021	1	284	284
PLANNED	10/3/2021	12	2,472	206
CUSTOMER REQUEST	10/3/2021	2	336	168
PLANNED	10/3/2021	2	192	96
PLANNED	10/3/2021	2	12	6
PLANNED	10/3/2021	1	124	124
PLANNED	10/3/2021	1	143	143
PLANNED	10/3/2021	4	228	57
PLANNED	10/3/2021	1	46	46
CUSTOMER REQUEST	10/3/2021	1	154	154
PLANNED	10/3/2021	2	152	76
PLANNED	10/3/2021	2	220	110
CUSTOMER REQUEST	10/3/2021	786	13,362	17
PLANNED	10/3/2021	9	1,323	147
PLANNED	10/3/2021	20	3,840	192
PLANNED	10/3/2021	18	2,898	161
PLANNED	10/4/2021	1	9	9
PLANNED	10/4/2021	3	15	5
PLANNED	10/4/2021	5	150	30
PLANNED	10/4/2021	7	1,022	146
PLANNED	10/4/2021	4	436	109
PLANNED	10/4/2021	6	335	81
PLANNED	10/4/2021	1	89	89
PLANNED	10/4/2021	1	224	224
PLANNED	10/4/2021	3	148	60
PLANNED	10/4/2021	4	36	9
PLANNED	10/4/2021	4	44	11
PLANNED	10/4/2021	4	28	7
PLANNED	10/4/2021	2	12	6
PLANNED	10/4/2021	2	112	56
PLANNED	10/4/2021	2	316	158
PLANNED	10/4/2021	2	68	34

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/4/2021	2	2	1
PLANNED	10/4/2021	4	32	8
PLANNED	10/4/2021	11	407	37
PLANNED	10/4/2021	1	88	88
CUSTOMER REQUEST	10/4/2021	9	355	307
PLANNED	10/4/2021	2	36	18
PLANNED	10/4/2021	1	12	12
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	1	9	9
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	4	192	48
PLANNED	10/4/2021	2	156	78
PLANNED	10/4/2021	1	288	288
PLANNED	10/4/2021	7	791	113
CUSTOMER REQUEST	10/4/2021	5	290	58
PLANNED	10/4/2021	4	32	8
PLANNED	10/4/2021	4	40	10
PLANNED	10/4/2021	5	50	10
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	1	435	435
PLANNED	10/4/2021	2	32	16
PLANNED	10/4/2021	5	50	10
PLANNED	10/4/2021	16	336	21
PLANNED	10/4/2021	2	218	109
PLANNED	10/4/2021	2	212	106
PLANNED	10/4/2021	3	120	40
PLANNED	10/4/2021	3	36	12
PLANNED	10/4/2021	4	28	7
PLANNED	10/4/2021	1	20	20
PLANNED	10/4/2021	1	109	109
PLANNED	10/4/2021	4	20	5
PLANNED	10/4/2021	2	40	20
PLANNED	10/4/2021	3	51	17
PLANNED	10/4/2021	2	170	85
PLANNED	10/4/2021	4	712	178
PLANNED	10/4/2021	5	495	99
PLANNED	10/4/2021	6	1,344	224
PLANNED	10/4/2021	2	278	139
PLANNED	10/4/2021	3	30	10
PLANNED	10/4/2021	8	96	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/4/2021	4	330	154
PLANNED	10/4/2021	3	27	9
PLANNED	10/4/2021	2	34	17
PLANNED	10/4/2021	5	370	74
CUSTOMER REQUEST	10/4/2021	10	240	24
PLANNED	10/4/2021	3	27	9
PLANNED	10/4/2021	8	32	4
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	4	32	8
PLANNED	10/4/2021	3	18	6
PLANNED	10/4/2021	4	56	14
PLANNED	10/4/2021	7	938	224
PLANNED	10/4/2021	8	232	29
PLANNED	10/4/2021	1	232	232
PLANNED	10/4/2021	3	60	20
PLANNED	10/4/2021	1	57	57
PLANNED	10/4/2021	1	10	10
PLANNED	10/4/2021	12	5,916	493
PLANNED	10/4/2021	12	5,940	495
PLANNED	10/4/2021	1	75	75
PLANNED	10/4/2021	3	81	27
PLANNED	10/4/2021	3	33	11
PLANNED	10/4/2021	3	147	49
PLANNED	10/4/2021	2	34	17
PLANNED	10/4/2021	3	27	9
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	5	35	7
PLANNED	10/4/2021	3	321	107
PLANNED	10/4/2021	3	51	17
CUSTOMER REQUEST	10/4/2021	12	219	65
PLANNED	10/4/2021	1	406	406
PLANNED	10/4/2021	2	14	7
PLANNED	10/4/2021	5	30	6
PLANNED	10/4/2021	5	80	16
PLANNED	10/4/2021	6	132	22
PLANNED	10/4/2021	5	45	9
PLANNED	10/4/2021	2	18	9
PLANNED	10/4/2021	4	48	12
PLANNED	10/4/2021	3	33	11
PLANNED	10/4/2021	4	28	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/4/2021	5	35	7
PLANNED	10/4/2021	5	140	28
PLANNED	10/4/2021	2	66	33
PLANNED	10/4/2021	3	21	7
PLANNED	10/4/2021	2	10	5
PLANNED	10/4/2021	1	6	6
PLANNED	10/4/2021	1	9	9
PLANNED	10/4/2021	1	8	8
PLANNED	10/4/2021	2	38	19
PLANNED	10/4/2021	2	18	9
PLANNED	10/4/2021	4	540	135
PLANNED	10/4/2021	2	138	69
PLANNED	10/4/2021	1	112	112
PLANNED	10/4/2021	1	7	7
PLANNED	10/4/2021	6	90	15
PLANNED	10/4/2021	3	45	15
PLANNED	10/4/2021	1	19	19
PLANNED	10/4/2021	5	300	60
PLANNED	10/4/2021	4	140	35
PLANNED	10/4/2021	1	9	9
PLANNED	10/4/2021	2	106	53
PLANNED	10/4/2021	11	506	46
PLANNED	10/4/2021	2	28	14
PLANNED	10/4/2021	12	24	2
PLANNED	10/4/2021	3	21	7
PLANNED	10/4/2021	5	50	10
PLANNED	10/4/2021	4	288	72
PLANNED	10/4/2021	2	76	38
PLANNED	10/4/2021	2	32	16
PLANNED	10/4/2021	3	30	10
PLANNED	10/4/2021	3	282	94
PLANNED	10/4/2021	5	50	10
PLANNED	10/4/2021	2	92	46
PLANNED	10/4/2021	3	21	7
PLANNED	10/4/2021	2	14	7
PLANNED	10/4/2021	1	7	7
PLANNED	10/4/2021	2	14	7
PLANNED	10/4/2021	10	20	2
PLANNED	10/4/2021	2	220	110
PLANNED	10/4/2021	2	244	122
PLANNED	10/4/2021	3	18	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/4/2021	3	15	5
PLANNED	10/4/2021	5	40	8
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	1	25	25
PLANNED	10/4/2021	2	486	243
PLANNED	10/4/2021	1	89	89
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	4	24	6
PLANNED	10/4/2021	1	1	1
PLANNED	10/4/2021	3	18	6
PLANNED	10/4/2021	4	44	11
PLANNED	10/4/2021	6	234	39
PLANNED	10/4/2021	5	215	43
PLANNED	10/4/2021	4	92	23
PLANNED	10/4/2021	2	46	23
PLANNED	10/4/2021	13	156	12
PLANNED	10/4/2021	7	840	120
PLANNED	10/4/2021	1	73	73
PLANNED	10/4/2021	5	585	117
PLANNED	10/4/2021	3	24	8
PLANNED	10/4/2021	1	7	7
PLANNED	10/4/2021	3	30	10
PLANNED	10/4/2021	2	18	9
PLANNED	10/4/2021	1	42	42
PLANNED	10/4/2021	3	21	7
PLANNED	10/4/2021	6	60	10
PLANNED	10/4/2021	7	56	8
PLANNED	10/4/2021	15	255	17
PLANNED	10/4/2021	3	291	97
PLANNED	10/4/2021	2	14	7
PLANNED	10/4/2021	1	21	21
PLANNED	10/4/2021	1	7	7
PLANNED	10/4/2021	2	22	11
PLANNED	10/4/2021	6	186	31
PLANNED	10/4/2021	12	2,580	215
PLANNED	10/4/2021	3	48	16
PLANNED	10/4/2021	3	255	85
PLANNED	10/4/2021	11	44	4
PLANNED	10/4/2021	1	123	123
PLANNED	10/4/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/4/2021	4	36	9
PLANNED	10/4/2021	3	72	24
PLANNED	10/4/2021	1	253	253
PLANNED	10/4/2021	1	4	4
CUSTOMER REQUEST	10/4/2021	9	72	8
PLANNED	10/4/2021	3	498	166
PLANNED	10/4/2021	4	376	94
PLANNED	10/4/2021	4	76	19
PLANNED	10/4/2021	3	123	41
PLANNED	10/4/2021	3	21	7
PLANNED	10/4/2021	11	1,298	118
PLANNED	10/4/2021	4	416	104
PLANNED	10/4/2021	2	54	27
PLANNED	10/4/2021	2	16	8
PLANNED	10/4/2021	2	20	10
PLANNED	10/4/2021	3	30	10
PLANNED	10/4/2021	7	105	15
PLANNED	10/4/2021	3	18	6
PLANNED	10/4/2021	4	48	12
PLANNED	10/4/2021	5	435	87
PLANNED	10/4/2021	3	33	11
PLANNED	10/4/2021	6	84	14
PLANNED	10/4/2021	12	72	6
PLANNED	10/4/2021	6	24	4
PLANNED	10/4/2021	6	12	2
CUSTOMER REQUEST	10/4/2021	3,862	24,909	9
PLANNED	10/4/2021	5	40	8
PLANNED	10/4/2021	6	402	67
PLANNED	10/5/2021	9	2,133	237
PLANNED	10/5/2021	2	154	77
PLANNED	10/5/2021	1	146	146
PLANNED	10/5/2021	7	616	88
PLANNED	10/5/2021	6	354	59
PLANNED	10/5/2021	16	224	14
PLANNED	10/5/2021	5	35	7
PLANNED	10/5/2021	7	539	77
PLANNED	10/5/2021	3	192	64
PLANNED	10/5/2021	12	144	12
PLANNED	10/5/2021	6	564	94
PLANNED	10/5/2021	3	1,149	383
PLANNED	10/5/2021	2	96	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	4	1,532	383
PLANNED	10/5/2021	8	3,056	382
PLANNED	10/5/2021	4	1,532	383
PLANNED	10/5/2021	4	724	181
PLANNED	10/5/2021	1	39	39
PLANNED	10/5/2021	6	2,298	383
PLANNED	10/5/2021	2	52	26
PLANNED	10/5/2021	1	356	356
PLANNED	10/5/2021	3	30	10
PLANNED	10/5/2021	3	3	1
PLANNED	10/5/2021	2	334	167
PLANNED	10/5/2021	1	12	12
PLANNED	10/5/2021	8	584	73
PLANNED	10/5/2021	91	19,838	218
PLANNED	10/5/2021	1	113	113
PLANNED	10/5/2021	2	286	143
PLANNED	10/5/2021	1	143	143
PLANNED	10/5/2021	2	226	113
PLANNED	10/5/2021	3	612	204
PLANNED	10/5/2021	5	65	13
PLANNED	10/5/2021	4	28	7
PLANNED	10/5/2021	7	84	12
PLANNED	10/5/2021	2	12	6
PLANNED	10/5/2021	3	24	8
PLANNED	10/5/2021	17	170	10
PLANNED	10/5/2021	4	44	11
PLANNED	10/5/2021	7	91	13
PLANNED	10/5/2021	7	84	12
PLANNED	10/5/2021	9	81	9
PLANNED	10/5/2021	9	72	8
PLANNED	10/5/2021	7	56	8
PLANNED	10/5/2021	3	24	8
PLANNED	10/5/2021	4	136	34
PLANNED	10/5/2021	3	30	10
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	24	3,756	279
PLANNED	10/5/2021	4	28	7
PLANNED	10/5/2021	4	280	70
PLANNED	10/5/2021	1	12	12
PLANNED	10/5/2021	1	117	117
PLANNED	10/5/2021	2	82	41

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	8	600	75
PLANNED	10/5/2021	2	192	96
PLANNED	10/5/2021	1	116	116
PLANNED	10/5/2021	4	176	44
PLANNED	10/5/2021	3	147	49
CUSTOMER REQUEST	10/5/2021	7	235	100
PLANNED	10/5/2021	1	301	301
PLANNED	10/5/2021	2	140	70
PLANNED	10/5/2021	1	76	76
CUSTOMER REQUEST	10/5/2021	17	4,981	293
CUSTOMER REQUEST	10/5/2021	2	2	1
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	1	86	86
PLANNED	10/5/2021	4	120	30
PLANNED	10/5/2021	2	26	13
PLANNED	10/5/2021	3	81	27
PLANNED	10/5/2021	3	111	37
PLANNED	10/5/2021	2	48	24
PLANNED	10/5/2021	4	72	18
PLANNED	10/5/2021	3	36	12
PLANNED	10/5/2021	2	98	49
PLANNED	10/5/2021	2	18	9
PLANNED	10/5/2021	2	110	55
PLANNED	10/5/2021	27	118	66
PLANNED	10/5/2021	2	12	6
PLANNED	10/5/2021	8	664	83
PLANNED	10/5/2021	2	246	123
PLANNED	10/5/2021	2	12	6
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	6	228	38
PLANNED	10/5/2021	2	16	8
PLANNED	10/5/2021	190	190	1
PLANNED	10/5/2021	6	600	100
PLANNED	10/5/2021	2	234	117
PLANNED	10/5/2021	6	492	82
PLANNED	10/5/2021	6	492	82
PLANNED	10/5/2021	3	33	11
PLANNED	10/5/2021	9	981	109
PLANNED	10/5/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	2	14	7
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	11	957	87
PLANNED	10/5/2021	1	10	10
PLANNED	10/5/2021	4	56	14
PLANNED	10/5/2021	6	138	23
PLANNED	10/5/2021	20	2,080	104
PLANNED	10/5/2021	8	1,096	137
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	6	108	18
PLANNED	10/5/2021	1	85	85
PLANNED	10/5/2021	1	18	18
PLANNED	10/5/2021	9	702	78
PLANNED	10/5/2021	8	1,336	167
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	4	328	82
PLANNED	10/5/2021	5	545	109
PLANNED	10/5/2021	4	24	6
PLANNED	10/5/2021	4	568	142
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	1	70	70
CUSTOMER REQUEST	10/5/2021	10	100	10
PLANNED	10/5/2021	7	763	109
PLANNED	10/5/2021	4	36	9
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	2	18	9
PLANNED	10/5/2021	4	36	9
PLANNED	10/5/2021	3	24	8
PLANNED	10/5/2021	2	22	11
PLANNED	10/5/2021	2	26	13
PLANNED	10/5/2021	1	11	11
PLANNED	10/5/2021	2	8	4
PLANNED	10/5/2021	4	20	5
PLANNED	10/5/2021	3	21	7
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	3	21	7
PLANNED	10/5/2021	2	10	5
PLANNED	10/5/2021	3	504	168
PLANNED	10/5/2021	3	24	8
PLANNED	10/5/2021	3	21	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	2	20	10
PLANNED	10/5/2021	1	93	93
PLANNED	10/5/2021	6	474	79
PLANNED	10/5/2021	2	16	8
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	2	22	11
PLANNED	10/5/2021	3	30	10
PLANNED	10/5/2021	4	44	11
PLANNED	10/5/2021	2	16	8
PLANNED	10/5/2021	3	24	8
PLANNED	10/5/2021	4	32	8
PLANNED	10/5/2021	1	344	344
PLANNED	10/5/2021	2	102	51
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	1	6	6
CUSTOMER REQUEST	10/5/2021	1	467	467
PLANNED	10/5/2021	2	10	5
PLANNED	10/5/2021	1	17	17
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	2	48	24
PLANNED	10/5/2021	4	284	71
PLANNED	10/5/2021	2	14	7
PLANNED	10/5/2021	2	14	7
PLANNED	10/5/2021	2	202	101
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	1	4	4
PLANNED	10/5/2021	2	32	16
CUSTOMER REQUEST	10/5/2021	17	3,400	200
PLANNED	10/5/2021	16	4,256	266
CUSTOMER REQUEST	10/5/2021	7	686	98
PLANNED	10/5/2021	7	357	51
PLANNED	10/5/2021	2	22	11
PLANNED	10/5/2021	15	855	57
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	9	450	50
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	4	8	2
PLANNED	10/5/2021	2	172	86
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	2	180	90
PLANNED	10/5/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	4	1,176	294
PLANNED	10/5/2021	3	162	54
PLANNED	10/5/2021	5	120	24
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	4	268	67
PLANNED	10/5/2021	1	15	15
PLANNED	10/5/2021	1	11	11
PLANNED	10/5/2021	3	45	15
PLANNED	10/5/2021	7	147	21
PLANNED	10/5/2021	12	204	17
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	3	12	4
PLANNED	10/5/2021	1	4	4
PLANNED	10/5/2021	4	132	33
PLANNED	10/5/2021	3	51	17
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	9	171	19
PLANNED	10/5/2021	8	40	5
PLANNED	10/5/2021	4	48	12
PLANNED	10/5/2021	16	672	42
PLANNED	10/5/2021	4	36	9
PLANNED	10/5/2021	2	14	7
PLANNED	10/5/2021	4	36	9
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	1	11	11
CUSTOMER REQUEST	10/5/2021	9	5,274	586
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	1	20	20
PLANNED	10/5/2021	3	171	57
PLANNED	10/5/2021	3	36	12
PLANNED	10/5/2021	5	65	13
PLANNED	10/5/2021	11	33	3
PLANNED	10/5/2021	9	189	21
CUSTOMER REQUEST	10/5/2021	4	204	51
PLANNED	10/5/2021	8	168	21
PLANNED	10/5/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	9	216	24
PLANNED	10/5/2021	4	120	30
PLANNED	10/5/2021	20	1,500	75
PLANNED	10/5/2021	2	416	208
PLANNED	10/5/2021	7	168	24
PLANNED	10/5/2021	1	147	147
PLANNED	10/5/2021	2	20	10
PLANNED	10/5/2021	14	196	14
PLANNED	10/5/2021	11	198	18
PLANNED	10/5/2021	2	18	9
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	1	114	114
PLANNED	10/5/2021	14	168	12
PLANNED	10/5/2021	2	238	119
PLANNED	10/5/2021	10	380	38
PLANNED	10/5/2021	8	824	103
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	3	15	5
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	1	10	10
PLANNED	10/5/2021	1	3	3
PLANNED	10/5/2021	7	21	3
PLANNED	10/5/2021	1	32	32
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	1	7	7
CUSTOMER REQUEST	10/5/2021	1	29	29
PLANNED	10/5/2021	2	372	186
PLANNED	10/5/2021	1	11	11
PLANNED	10/5/2021	1	10	10
PLANNED	10/5/2021	20	1,180	59
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	2	16	8
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	10	30	3
PLANNED	10/5/2021	1	204	204
PLANNED	10/5/2021	16	256	16
PLANNED	10/5/2021	2	54	27
PLANNED	10/5/2021	1	155	155

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	3	144	48
PLANNED	10/5/2021	1	103	103
PLANNED	10/5/2021	1	14	14
PLANNED	10/5/2021	2	84	42
PLANNED	10/5/2021	2	32	16
PLANNED	10/5/2021	2	12	6
PLANNED	10/5/2021	3	15	5
PLANNED	10/5/2021	3	297	99
PLANNED	10/5/2021	3	30	10
PLANNED	10/5/2021	2	12	6
PLANNED	10/5/2021	1	56	56
PLANNED	10/5/2021	5	50	10
PLANNED	10/5/2021	1	3	3
PLANNED	10/5/2021	4	84	21
PLANNED	10/5/2021	1	10	10
PLANNED	10/5/2021	4	52	13
PLANNED	10/5/2021	2	10	5
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	1	9	9
PLANNED	10/5/2021	1	4	4
PLANNED	10/5/2021	2	32	16
PLANNED	10/5/2021	7	42	6
PLANNED	10/5/2021	1	22	22
PLANNED	10/5/2021	1	7	7
PLANNED	10/5/2021	1	8	8
PLANNED	10/5/2021	2	14	7
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	2	20	10
PLANNED	10/5/2021	9	576	64
PLANNED	10/5/2021	1	3	3
PLANNED	10/5/2021	1	5	5
PLANNED	10/5/2021	4	408	102
PLANNED	10/5/2021	2	10	5
PLANNED	10/5/2021	1	47	47
PLANNED	10/5/2021	1	10	10
PLANNED	10/5/2021	4	20	5
PLANNED	10/5/2021	8	32	4
PLANNED	10/5/2021	1	11	11
PLANNED	10/5/2021	4	68	17
PLANNED	10/5/2021	1	13	13
PLANNED	10/5/2021	1	5	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/5/2021	2	92	46
PLANNED	10/5/2021	1	4	4
PLANNED	10/5/2021	5	45	9
PLANNED	10/5/2021	11	121	11
PLANNED	10/5/2021	4	36	9
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	3	168	56
CUSTOMER REQUEST	10/5/2021	1	211	211
PLANNED	10/5/2021	2	16	8
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	4	116	29
PLANNED	10/5/2021	6	72	12
PLANNED	10/5/2021	1	6	6
PLANNED	10/5/2021	2	146	73
PLANNED	10/5/2021	2	220	110
PLANNED	10/5/2021	8	160	20
PLANNED	10/5/2021	1	48	48
PLANNED	10/5/2021	1	197	197
PLANNED	10/5/2021	1	141	141
PLANNED	10/5/2021	4	220	55
PLANNED	10/5/2021	1	124	124
PLANNED	10/5/2021	1	205	205
PLANNED	10/6/2021	1	45	45
PLANNED	10/6/2021	1	32	32
PLANNED	10/6/2021	1	32	32
PLANNED	10/6/2021	1	142	142
PLANNED	10/6/2021	1	117	117
PLANNED	10/6/2021	1	108	108
PLANNED	10/6/2021	1	169	169
PLANNED	10/6/2021	2	101	67
PLANNED	10/6/2021	2	170	85
PLANNED	10/6/2021	2	12	6
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	1	10	10
PLANNED	10/6/2021	2	16	8
PLANNED	10/6/2021	3	27	9
PLANNED	10/6/2021	4	64	16
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	2	22	11
PLANNED	10/6/2021	2	24	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	2	26	13
PLANNED	10/6/2021	3	468	156
CUSTOMER REQUEST	10/6/2021	2	86	43
PLANNED	10/6/2021	2	174	87
PLANNED	10/6/2021	7	49	7
PLANNED	10/6/2021	1	98	98
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	2	202	101
PLANNED	10/6/2021	4	20	5
PLANNED	10/6/2021	3	24	8
PLANNED	10/6/2021	1	12	12
PLANNED	10/6/2021	3	42	14
PLANNED	10/6/2021	4	60	15
PLANNED	10/6/2021	31	18,011	581
PLANNED	10/6/2021	2	400	200
PLANNED	10/6/2021	2	112	56
PLANNED	10/6/2021	3	87	29
PLANNED	10/6/2021	1	15	15
PLANNED	10/6/2021	3	21	7
PLANNED	10/6/2021	8	376	47
PLANNED	10/6/2021	10	760	76
PLANNED	10/6/2021	2	142	71
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	48	5,232	109
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	1	11	11
PLANNED	10/6/2021	1	7	7
CUSTOMER REQUEST	10/6/2021	1	264	264
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	6	120	20
PLANNED	10/6/2021	1	4	4
PLANNED	10/6/2021	12	156	13
PLANNED	10/6/2021	4	132	33
PLANNED	10/6/2021	2	98	49
PLANNED	10/6/2021	47	5,264	112

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	6	396	66
PLANNED	10/6/2021	2	208	104
PLANNED	10/6/2021	12	564	47
PLANNED	10/6/2021	10	470	47
PLANNED	10/6/2021	13	117	9
PLANNED	10/6/2021	2	94	47
PLANNED	10/6/2021	8	424	53
PLANNED	10/6/2021	6	312	52
CUSTOMER REQUEST	10/6/2021	51	11,475	225
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	3	606	202
PLANNED	10/6/2021	3	27	9
PLANNED	10/6/2021	6	60	10
PLANNED	10/6/2021	4	40	10
PLANNED	10/6/2021	1	45	45
PLANNED	10/6/2021	7	91	13
PLANNED	10/6/2021	10	510	51
PLANNED	10/6/2021	1	13	13
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	2	14	7
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	19	3,952	208
PLANNED	10/6/2021	1	10	10
PLANNED	10/6/2021	2	22	11
PLANNED	10/6/2021	3	732	244
PLANNED	10/6/2021	3	237	79
PLANNED	10/6/2021	1	34	34
PLANNED	10/6/2021	5	40	8
PLANNED	10/6/2021	3	15	5
PLANNED	10/6/2021	1	10	10
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	12	168	14
PLANNED	10/6/2021	2	8	4
PLANNED	10/6/2021	8	48	6
PLANNED	10/6/2021	3	12	4
PLANNED	10/6/2021	1	143	143
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	10	1,250	125

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	14	2,142	153
PLANNED	10/6/2021	2	642	321
CUSTOMER REQUEST	10/6/2021	1	42	42
PLANNED	10/6/2021	7	49	7
PLANNED	10/6/2021	3	18	6
PLANNED	10/6/2021	4	148	37
PLANNED	10/6/2021	6	12	2
PLANNED	10/6/2021	3	24	8
PLANNED	10/6/2021	2	256	128
PLANNED	10/6/2021	4	28	7
PLANNED	10/6/2021	19	171	9
PLANNED	10/6/2021	6	30	5
PLANNED	10/6/2021	5	245	49
PLANNED	10/6/2021	3	1,020	340
PLANNED	10/6/2021	3	24	8
PLANNED	10/6/2021	2	16	8
PLANNED	10/6/2021	4	52	13
PLANNED	10/6/2021	1	10	10
PLANNED	10/6/2021	4	28	7
CUSTOMER REQUEST	10/6/2021	9	18	2
PLANNED	10/6/2021	2	18	9
PLANNED	10/6/2021	32	992	31
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	7	658	94
PLANNED	10/6/2021	1	9	9
CUSTOMER REQUEST	10/6/2021	5	377	301
PLANNED	10/6/2021	4	24	6
PLANNED	10/6/2021	6	102	17
PLANNED	10/6/2021	2	270	135
PLANNED	10/6/2021	8	144	18
PLANNED	10/6/2021	3	63	21
PLANNED	10/6/2021	5	55	11
PLANNED	10/6/2021	2	52	26
PLANNED	10/6/2021	2	22	11
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	1	15	15
CUSTOMER REQUEST	10/6/2021	13	481	37
PLANNED	10/6/2021	3	18	6
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	2	14	7
PLANNED	10/6/2021	5	35	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	1	33	33
PLANNED	10/6/2021	8	40	5
PLANNED	10/6/2021	12	468	39
PLANNED	10/6/2021	11	198	18
PLANNED	10/6/2021	3	45	15
PLANNED	10/6/2021	2	12	6
PLANNED	10/6/2021	9	1,062	118
PLANNED	10/6/2021	4	296	74
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	25	300	12
PLANNED	10/6/2021	8	528	66
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	1	4	4
PLANNED	10/6/2021	2	12	6
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	8	1,856	232
PLANNED	10/6/2021	6	30	5
PLANNED	10/6/2021	11	1,816	192
PLANNED	10/6/2021	12	2,484	207
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	1	129	129
PLANNED	10/6/2021	22	132	6
PLANNED	10/6/2021	2	20	10
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	1	10	10
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	2	18	9
PLANNED	10/6/2021	1	57	57
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	14	224	16
PLANNED	10/6/2021	2	22	11
PLANNED	10/6/2021	5	145	29
PLANNED	10/6/2021	3	228	76
PLANNED	10/6/2021	4	348	87
PLANNED	10/6/2021	30	840	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	8	56	7
PLANNED	10/6/2021	15	3,300	220
PLANNED	10/6/2021	4	128	32
PLANNED	10/6/2021	5	85	17
PLANNED	10/6/2021	4	32	8
PLANNED	10/6/2021	2	18	9
PLANNED	10/6/2021	3	60	20
PLANNED	10/6/2021	69	14,904	216
PLANNED	10/6/2021	3	24	8
PLANNED	10/6/2021	26	3,770	145
PLANNED	10/6/2021	4	160	40
PLANNED	10/6/2021	1	5	5
PLANNED	10/6/2021	1	4	4
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	1	7	7
PLANNED	10/6/2021	2	32	16
PLANNED	10/6/2021	2	24	12
PLANNED	10/6/2021	2	254	127
PLANNED	10/6/2021	18	270	15
PLANNED	10/6/2021	1	9	9
PLANNED	10/6/2021	4	28	7
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	3	27	9
PLANNED	10/6/2021	3	279	93
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	5	105	21
PLANNED	10/6/2021	3	33	11
PLANNED	10/6/2021	3	39	13
PLANNED	10/6/2021	25	325	13
PLANNED	10/6/2021	4	84	21
PLANNED	10/6/2021	2	102	51
PLANNED	10/6/2021	1	8	8
PLANNED	10/6/2021	2	10	5
PLANNED	10/6/2021	7	574	82
PLANNED	10/6/2021	3	33	11
PLANNED	10/6/2021	14	196	14
PLANNED	10/6/2021	2	96	48
PLANNED	10/6/2021	1	3	3
PLANNED	10/6/2021	2	12	6
PLANNED	10/6/2021	4	108	27

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	6	36	6
PLANNED	10/6/2021	2	42	21
PLANNED	10/6/2021	1	78	78
PLANNED	10/6/2021	4	68	17
PLANNED	10/6/2021	1	71	71
PLANNED	10/6/2021	4	40	10
PLANNED	10/6/2021	6	36	6
PLANNED	10/6/2021	6	90	15
PLANNED	10/6/2021	4	104	26
PLANNED	10/6/2021	1	27	27
PLANNED	10/6/2021	3	24	8
PLANNED	10/6/2021	4	28	7
PLANNED	10/6/2021	6	108	18
PLANNED	10/6/2021	2	28	14
PLANNED	10/6/2021	8	600	75
PLANNED	10/6/2021	3	438	146
PLANNED	10/6/2021	3	39	13
PLANNED	10/6/2021	5	280	56
PLANNED	10/6/2021	17	170	10
PLANNED	10/6/2021	6	144	24
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	4	580	145
PLANNED	10/6/2021	4	79	28
PLANNED	10/6/2021	5	135	27
PLANNED	10/6/2021	2	100	50
PLANNED	10/6/2021	3	519	173
PLANNED	10/6/2021	1	23	23
PLANNED	10/6/2021	1	13	13
PLANNED	10/6/2021	2	60	30
PLANNED	10/6/2021	1	16	16
PLANNED	10/6/2021	1	79	79
PLANNED	10/6/2021	1	27	27
PLANNED	10/6/2021	1	6	6
PLANNED	10/6/2021	2	8	4
PLANNED	10/6/2021	3	78	26
PLANNED	10/6/2021	2	38	19
PLANNED	10/6/2021	2	8	4
PLANNED	10/6/2021	24	1,056	44
PLANNED	10/6/2021	8	1,056	132
PLANNED	10/6/2021	4	88	22
PLANNED	10/6/2021	1	15	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/6/2021	1	66	66
PLANNED	10/6/2021	2	40	20
PLANNED	10/6/2021	4	124	31
PLANNED	10/6/2021	4	184	46
PLANNED	10/6/2021	5	280	56
PLANNED	10/6/2021	2	164	82
PLANNED	10/6/2021	2	214	107
CUSTOMER REQUEST	10/6/2021	4	252	63
PLANNED	10/6/2021	2	392	196
PLANNED	10/6/2021	1	123	123
PLANNED	10/6/2021	2	220	110
PLANNED	10/6/2021	24	1,032	43
PLANNED	10/6/2021	2	378	189
PLANNED	10/6/2021	1	145	145
PLANNED	10/7/2021	3	729	243
PLANNED	10/7/2021	1	54	54
PLANNED	10/7/2021	6	654	109
PLANNED	10/7/2021	1	230	230
CUSTOMER REQUEST	10/7/2021	1	42	42
PLANNED	10/7/2021	1	86	86
PLANNED	10/7/2021	4	164	41
PLANNED	10/7/2021	4	219	96
PLANNED	10/7/2021	4	220	55
PLANNED	10/7/2021	1	70	70
PLANNED	10/7/2021	2	104	52
PLANNED	10/7/2021	1	48	48
PLANNED	10/7/2021	1	74	74
PLANNED	10/7/2021	1	142	142
PLANNED	10/7/2021	5	130	26
PLANNED	10/7/2021	2	20	10
PLANNED	10/7/2021	1	8	8
PLANNED	10/7/2021	1	6	6
PLANNED	10/7/2021	6	422	86
PLANNED	10/7/2021	22	2,640	120
PLANNED	10/7/2021	3	9	3
PLANNED	10/7/2021	13	1,560	120
PLANNED	10/7/2021	4	140	35
PLANNED	10/7/2021	3	57	19
PLANNED	10/7/2021	1	77	77
CUSTOMER REQUEST	10/7/2021	41	41	398
PLANNED	10/7/2021	8	256	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/7/2021	2	62	31
PLANNED	10/7/2021	2	144	72
PLANNED	10/7/2021	8	272	34
PLANNED	10/7/2021	5	40	8
PLANNED	10/7/2021	8	1,024	128
PLANNED	10/7/2021	3	177	59
PLANNED	10/7/2021	1	7	7
PLANNED	10/7/2021	8	304	38
CUSTOMER REQUEST	10/7/2021	2	494	259
PLANNED	10/7/2021	2	18	9
PLANNED	10/7/2021	1	6	6
PLANNED	10/7/2021	1	9	9
PLANNED	10/7/2021	1	11	11
PLANNED	10/7/2021	1	175	175
CUSTOMER REQUEST	10/7/2021	7	133	19
PLANNED	10/7/2021	1	288	288
PLANNED	10/7/2021	10	2,370	237
PLANNED	10/7/2021	10	2,440	244
PLANNED	10/7/2021	8	336	42
PLANNED	10/7/2021	8	144	18
PLANNED	10/7/2021	25	1,325	53
PLANNED	10/7/2021	4	96	24
PLANNED	10/7/2021	4	172	43
PLANNED	10/7/2021	9	504	56
PLANNED	10/7/2021	1	4	4
PLANNED	10/7/2021	4	56	14
PLANNED	10/7/2021	6	36	6
PLANNED	10/7/2021	5	221	49
PLANNED	10/7/2021	1	150	150
PLANNED	10/7/2021	1	5	5
PLANNED	10/7/2021	4	172	43
PLANNED	10/7/2021	9	747	83
PLANNED	10/7/2021	6	582	97
PLANNED	10/7/2021	3	42	14
PLANNED	10/7/2021	8	72	9
PLANNED	10/7/2021	1	13	13
PLANNED	10/7/2021	6	1,956	326
PLANNED	10/7/2021	2	22	11
PLANNED	10/7/2021	1	14	14
PLANNED	10/7/2021	3	30	10
PLANNED	10/7/2021	1	10	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/7/2021	6	486	81
PLANNED	10/7/2021	28	2,940	105
PLANNED	10/7/2021	2	70	35
PLANNED	10/7/2021	3	24	8
PLANNED	10/7/2021	12	264	22
PLANNED	10/7/2021	1	29	29
PLANNED	10/7/2021	3	369	123
PLANNED	10/7/2021	6	654	109
PLANNED	10/7/2021	3	1,704	568
CUSTOMER REQUEST	10/7/2021	1	688	688
PLANNED	10/7/2021	11	308	28
PLANNED	10/7/2021	1	69	69
PLANNED	10/7/2021	5	225	45
PLANNED	10/7/2021	6	516	86
PLANNED	10/7/2021	2	130	65
PLANNED	10/7/2021	4	120	30
PLANNED	10/7/2021	6	366	61
PLANNED	10/7/2021	6	324	54
PLANNED	10/7/2021	4	60	15
CUSTOMER REQUEST	10/7/2021	1	363	363
PLANNED	10/7/2021	4	56	14
PLANNED	10/7/2021	1	5	5
PLANNED	10/7/2021	2	60	30
PLANNED	10/7/2021	4	220	55
PLANNED	10/7/2021	5	40	8
PLANNED	10/7/2021	6	522	87
PLANNED	10/7/2021	4	72	18
PLANNED	10/7/2021	10	1,170	117
PLANNED	10/7/2021	11	1,001	91
CUSTOMER REQUEST	10/7/2021	33	264	8
PLANNED	10/7/2021	3	153	51
PLANNED	10/7/2021	6	84	14
PLANNED	10/7/2021	1	4	4
PLANNED	10/7/2021	1	6	6
PLANNED	10/7/2021	2	24	12
PLANNED	10/7/2021	2	18	9
PLANNED	10/7/2021	1	9	9
PLANNED	10/7/2021	1	8	8
PLANNED	10/7/2021	2	180	90
PLANNED	10/7/2021	5	60	12
PLANNED	10/7/2021	4	476	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/7/2021	2	132	66
PLANNED	10/7/2021	7	350	50
PLANNED	10/7/2021	6	474	79
PLANNED	10/7/2021	2	476	238
PLANNED	10/7/2021	1	352	352
PLANNED	10/7/2021	3	162	54
PLANNED	10/7/2021	3	15	5
PLANNED	10/7/2021	4	52	13
PLANNED	10/7/2021	9	504	56
PLANNED	10/7/2021	1	5	5
PLANNED	10/7/2021	8	528	66
PLANNED	10/7/2021	5	40	8
PLANNED	10/7/2021	2	28	14
PLANNED	10/7/2021	3	384	128
CUSTOMER REQUEST	10/7/2021	11	770	70
PLANNED	10/7/2021	1	6	6
PLANNED	10/7/2021	2	594	297
PLANNED	10/7/2021	5	45	9
PLANNED	10/7/2021	1	4	4
PLANNED	10/7/2021	7	714	102
PLANNED	10/7/2021	7	28	4
PLANNED	10/7/2021	5	60	12
PLANNED	10/7/2021	2	10	5
PLANNED	10/7/2021	2	22	11
PLANNED	10/7/2021	3	36	12
PLANNED	10/7/2021	2	282	141
PLANNED	10/7/2021	1	15	15
PLANNED	10/7/2021	2	46	23
PLANNED	10/7/2021	2	10	5
PLANNED	10/7/2021	1	3	3
PLANNED	10/7/2021	2	18	9
PLANNED	10/7/2021	8	1,040	130
PLANNED	10/7/2021	1	4	4
PLANNED	10/7/2021	5	50	10
PLANNED	10/7/2021	2	6	3
PLANNED	10/7/2021	5	65	13
PLANNED	10/7/2021	4	84	21
PLANNED	10/7/2021	8	1,200	150
PLANNED	10/7/2021	3	63	21
PLANNED	10/7/2021	2	14	7
PLANNED	10/7/2021	1	3	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/7/2021	9	360	40
PLANNED	10/7/2021	3	36	12
PLANNED	10/7/2021	2	16	8
PLANNED	10/7/2021	2	18	9
PLANNED	10/7/2021	1	4	4
PLANNED	10/7/2021	1	13	13
PLANNED	10/7/2021	1	10	10
PLANNED	10/7/2021	3	42	14
PLANNED	10/7/2021	2	16	8
PLANNED	10/7/2021	8	128	16
PLANNED	10/7/2021	6	102	17
PLANNED	10/7/2021	5	35	7
PLANNED	10/7/2021	8	128	16
CUSTOMER REQUEST	10/7/2021	8	768	96
PLANNED	10/7/2021	1	5	5
PLANNED	10/7/2021	3	24	8
PLANNED	10/7/2021	2	28	25
PLANNED	10/7/2021	2	68	34
PLANNED	10/7/2021	1	33	33
PLANNED	10/7/2021	1	24	24
PLANNED	10/7/2021	2	136	68
PLANNED	10/7/2021	2	106	53
PLANNED	10/7/2021	5	40	8
PLANNED	10/7/2021	4	24	6
PLANNED	10/7/2021	2	444	222
PLANNED	10/7/2021	1	112	112
PLANNED	10/7/2021	4	396	99
CUSTOMER REQUEST	10/7/2021	5	125	25
PLANNED	10/7/2021	2	120	60
PLANNED	10/7/2021	4	24	6
PLANNED	10/7/2021	4	56	14
CUSTOMER REQUEST	10/7/2021	2	40	20
PLANNED	10/7/2021	1	31	31
PLANNED	10/7/2021	6	648	108
PLANNED	10/7/2021	2	88	44
PLANNED	10/7/2021	5	165	33
PLANNED	10/7/2021	5	230	46
PLANNED	10/7/2021	15	2,115	141
PLANNED	10/7/2021	3	432	144
PLANNED	10/7/2021	4	220	55
PLANNED	10/7/2021	3	33	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/7/2021	1	9	9
PLANNED	10/7/2021	2	150	75
CUSTOMER REQUEST	10/7/2021	38	418	11
CUSTOMER REQUEST	10/7/2021	1	186	186
CUSTOMER REQUEST	10/7/2021	1	80	80
PLANNED	10/7/2021	4	356	89
PLANNED	10/7/2021	11	187	17
CUSTOMER REQUEST	10/7/2021	1	84	84
PLANNED	10/7/2021	1	351	351
CUSTOMER REQUEST	10/7/2021	1	122	122
PLANNED	10/7/2021	1	206	206
PLANNED	10/8/2021	1	87	87
PLANNED	10/8/2021	6	1,104	184
PLANNED	10/8/2021	6	480	80
PLANNED	10/8/2021	3	174	58
PLANNED	10/8/2021	4	244	61
PLANNED	10/8/2021	1	57	57
CUSTOMER REQUEST	10/8/2021	1	332	332
CUSTOMER REQUEST	10/8/2021	19	38,703	2,037
PLANNED	10/8/2021	1	198	198
PLANNED	10/8/2021	12	1,212	101
PLANNED	10/8/2021	2	96	48
PLANNED	10/8/2021	2	72	36
PLANNED	10/8/2021	2	16	8
PLANNED	10/8/2021	2	2	1
PLANNED	10/8/2021	2	12	6
PLANNED	10/8/2021	2	14	7
PLANNED	10/8/2021	1	9	9
PLANNED	10/8/2021	7	91	13
PLANNED	10/8/2021	1	93	93
PLANNED	10/8/2021	2	152	76
PLANNED	10/8/2021	4	72	18
PLANNED	10/8/2021	1	93	93
PLANNED	10/8/2021	1	93	93
PLANNED	10/8/2021	4	68	17
PLANNED	10/8/2021	2	68	34
PLANNED	10/8/2021	11	1,100	100
PLANNED	10/8/2021	2	18	9
CUSTOMER REQUEST	10/8/2021	8	24	3
PLANNED	10/8/2021	8	576	72
PLANNED	10/8/2021	4	180	45

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/8/2021	21	1,386	66
PLANNED	10/8/2021	27	139	15
PLANNED	10/8/2021	4	120	30
PLANNED	10/8/2021	5	1,485	297
PLANNED	10/8/2021	2	46	23
PLANNED	10/8/2021	11	1,166	106
PLANNED	10/8/2021	7	21	3
PLANNED	10/8/2021	27	2,106	78
PLANNED	10/8/2021	2	56	28
PLANNED	10/8/2021	11	176	16
PLANNED	10/8/2021	5	20	4
PLANNED	10/8/2021	3	6	2
CUSTOMER REQUEST	10/8/2021	1	7	7
PLANNED	10/8/2021	2	14	7
PLANNED	10/8/2021	1	7	7
PLANNED	10/8/2021	1	43	43
PLANNED	10/8/2021	1	5	5
PLANNED	10/8/2021	2	80	40
PLANNED	10/8/2021	3	1,173	391
PLANNED	10/8/2021	1	146	146
PLANNED	10/8/2021	2	84	42
PLANNED	10/8/2021	1	68	68
PLANNED	10/8/2021	4	496	124
PLANNED	10/8/2021	7	35	15
PLANNED	10/8/2021	4	304	76
PLANNED	10/8/2021	1	39	39
PLANNED	10/8/2021	6	624	104
PLANNED	10/8/2021	6	1,644	274
PLANNED	10/8/2021	3	57	19
PLANNED	10/8/2021	1	79	79
PLANNED	10/8/2021	4	100	25
PLANNED	10/8/2021	4	592	148
PLANNED	10/8/2021	8	96	12
PLANNED	10/8/2021	21	2,856	136
PLANNED	10/8/2021	13	1,755	135
PLANNED	10/8/2021	12	1,860	155
PLANNED	10/8/2021	3	168	56
PLANNED	10/8/2021	4	56	14
PLANNED	10/8/2021	5	60	12
PLANNED	10/8/2021	16	1,312	82
PLANNED	10/8/2021	3	213	71

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/8/2021	2	66	33
PLANNED	10/8/2021	6	1,464	244
CUSTOMER REQUEST	10/8/2021	17	170	10
PLANNED	10/8/2021	2	182	91
PLANNED	10/8/2021	4	548	137
PLANNED	10/8/2021	9	504	56
PLANNED	10/8/2021	2	64	32
PLANNED	10/8/2021	23	4,232	184
PLANNED	10/8/2021	2	78	39
PLANNED	10/8/2021	1	84	84
PLANNED	10/8/2021	2	370	185
PLANNED	10/8/2021	13	923	71
PLANNED	10/8/2021	3	75	25
PLANNED	10/8/2021	3	75	25
PLANNED	10/8/2021	8	1,360	170
PLANNED	10/8/2021	4	228	57
PLANNED	10/8/2021	3	129	43
PLANNED	10/8/2021	13	897	69
PLANNED	10/8/2021	9	576	64
PLANNED	10/8/2021	4	124	31
PLANNED	10/8/2021	21	3,864	184
PLANNED	10/8/2021	13	2,496	192
PLANNED	10/8/2021	13	2,392	184
PLANNED	10/8/2021	12	696	58
PLANNED	10/8/2021	1	39	39
PLANNED	10/8/2021	15	435	29
PLANNED	10/8/2021	7	98	14
PLANNED	10/8/2021	7	518	74
PLANNED	10/8/2021	3	1,029	343
PLANNED	10/9/2021	10	1,700	170
PLANNED	10/9/2021	2	260	130
PLANNED	10/9/2021	28	5,068	181
CUSTOMER REQUEST	10/9/2021	1	266	266
PLANNED	10/9/2021	9	900	100
PLANNED	10/9/2021	12	352	84
CUSTOMER REQUEST	10/9/2021	15	180	12
PLANNED	10/10/2021	5	630	126
CUSTOMER REQUEST	10/10/2021	1	169	169
PLANNED	10/10/2021	22	2,860	130
PLANNED	10/10/2021	14	1,638	117
PLANNED	10/10/2021	3	78	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/10/2021	5	500	100
PLANNED	10/10/2021	9	900	100
PLANNED	10/10/2021	4	392	98
PLANNED	10/10/2021	7	812	116
CUSTOMER REQUEST	10/10/2021	5	250	50
PLANNED	10/10/2021	1	67	67
PLANNED	10/11/2021	10	560	56
PLANNED	10/11/2021	1	253	253
PLANNED	10/11/2021	2	276	138
PLANNED	10/11/2021	2	510	255
PLANNED	10/11/2021	2	568	284
PLANNED	10/11/2021	1	186	186
PLANNED	10/11/2021	2	270	135
PLANNED	10/11/2021	1	104	104
PLANNED	10/11/2021	3	99	33
PLANNED	10/11/2021	3	24	8
PLANNED	10/11/2021	4	716	179
PLANNED	10/11/2021	3	18	6
PLANNED	10/11/2021	4	32	8
PLANNED	10/11/2021	2	20	10
CUSTOMER REQUEST	10/11/2021	7	3,171	453
PLANNED	10/11/2021	2	148	74
PLANNED	10/11/2021	4	324	81
PLANNED	10/11/2021	4	364	91
PLANNED	10/11/2021	4	24	6
PLANNED	10/11/2021	2	22	11
PLANNED	10/11/2021	11	396	36
PLANNED	10/11/2021	3	18	6
PLANNED	10/11/2021	2	8	4
PLANNED	10/11/2021	2	20	10
PLANNED	10/11/2021	9	1,395	155
PLANNED	10/11/2021	2	48	24
PLANNED	10/11/2021	1	63	63
PLANNED	10/11/2021	8	296	37
PLANNED	10/11/2021	1	467	467
PLANNED	10/11/2021	5	525	105
PLANNED	10/11/2021	4	28	7
PLANNED	10/11/2021	3	27	9
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	2	192	96
PLANNED	10/11/2021	2	362	181

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	7	336	48
PLANNED	10/11/2021	7	455	65
PLANNED	10/11/2021	8	96	12
PLANNED	10/11/2021	2	18	9
PLANNED	10/11/2021	3	39	13
PLANNED	10/11/2021	1	89	89
PLANNED	10/11/2021	1	90	90
PLANNED	10/11/2021	8	1,088	136
PLANNED	10/11/2021	2	178	89
PLANNED	10/11/2021	3	144	48
PLANNED	10/11/2021	3	114	38
PLANNED	10/11/2021	19	2,793	147
PLANNED	10/11/2021	19	2,489	131
PLANNED	10/11/2021	5	35	7
PLANNED	10/11/2021	4	668	167
PLANNED	10/11/2021	3	240	80
PLANNED	10/11/2021	5	635	127
PLANNED	10/11/2021	4	44	11
PLANNED	10/11/2021	3	36	12
PLANNED	10/11/2021	40	6,560	164
PLANNED	10/11/2021	3	1,077	359
PLANNED	10/11/2021	10	220	22
PLANNED	10/11/2021	4	84	21
PLANNED	10/11/2021	4	792	198
PLANNED	10/11/2021	3	51	17
PLANNED	10/11/2021	7	658	94
PLANNED	10/11/2021	4	24	6
PLANNED	10/11/2021	1	124	124
PLANNED	10/11/2021	4	108	27
PLANNED	10/11/2021	2	10	5
PLANNED	10/11/2021	4	20	5
PLANNED	10/11/2021	5	35	7
PLANNED	10/11/2021	4	20	5
PLANNED	10/11/2021	2	66	33
PLANNED	10/11/2021	3	3	1
PLANNED	10/11/2021	4	124	31
PLANNED	10/11/2021	1	12	12
PLANNED	10/11/2021	1	52	52
PLANNED	10/11/2021	2	20	10
PLANNED	10/11/2021	2	18	9
PLANNED	10/11/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	2	74	37
PLANNED	10/11/2021	13	1,170	90
PLANNED	10/11/2021	2	34	17
PLANNED	10/11/2021	4	184	46
PLANNED	10/11/2021	3	306	102
PLANNED	10/11/2021	1	81	81
PLANNED	10/11/2021	4	104	26
PLANNED	10/11/2021	2	278	139
PLANNED	10/11/2021	2	108	54
PLANNED	10/11/2021	3	36	12
PLANNED	10/11/2021	4	124	31
PLANNED	10/11/2021	4	484	121
PLANNED	10/11/2021	3	282	94
PLANNED	10/11/2021	1	14	14
PLANNED	10/11/2021	2	232	116
PLANNED	10/11/2021	1	300	300
PLANNED	10/11/2021	6	696	116
PLANNED	10/11/2021	4	104	26
CUSTOMER REQUEST	10/11/2021	4	56	14
PLANNED	10/11/2021	1	50	50
PLANNED	10/11/2021	4	740	185
PLANNED	10/11/2021	2	66	33
PLANNED	10/11/2021	16	1,120	70
PLANNED	10/11/2021	1	5	5
PLANNED	10/11/2021	7	686	98
PLANNED	10/11/2021	4	448	112
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	7	182	26
PLANNED	10/11/2021	2	190	95
PLANNED	10/11/2021	3	21	7
PLANNED	10/11/2021	2	2	1
PLANNED	10/11/2021	5	1,275	255
PLANNED	10/11/2021	2	110	55
PLANNED	10/11/2021	3	219	73
PLANNED	10/11/2021	3	189	63
PLANNED	10/11/2021	1	4	4
PLANNED	10/11/2021	1	117	117
PLANNED	10/11/2021	1	13	13
PLANNED	10/11/2021	1	85	85
PLANNED	10/11/2021	2	276	138
PLANNED	10/11/2021	1	17	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	1	7	7
PLANNED	10/11/2021	1	84	84
PLANNED	10/11/2021	2	28	14
PLANNED	10/11/2021	3	21	7
PLANNED	10/11/2021	1	272	272
PLANNED	10/11/2021	3	201	67
PLANNED	10/11/2021	3	123	41
PLANNED	10/11/2021	7	420	60
PLANNED	10/11/2021	3	63	21
PLANNED	10/11/2021	1	71	71
PLANNED	10/11/2021	1	48	48
PLANNED	10/11/2021	4	24	6
PLANNED	10/11/2021	10	200	20
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	7	910	130
PLANNED	10/11/2021	4	572	143
PLANNED	10/11/2021	7	903	129
PLANNED	10/11/2021	2	38	19
PLANNED	10/11/2021	4	136	34
PLANNED	10/11/2021	4	316	79
PLANNED	10/11/2021	4	40	10
PLANNED	10/11/2021	4	32	8
CUSTOMER REQUEST	10/11/2021	13	208	16
PLANNED	10/11/2021	3	60	20
PLANNED	10/11/2021	3	120	40
PLANNED	10/11/2021	5	940	188
PLANNED	10/11/2021	3	273	91
PLANNED	10/11/2021	4	396	99
PLANNED	10/11/2021	3	186	62
PLANNED	10/11/2021	8	512	64
PLANNED	10/11/2021	3	63	21
PLANNED	10/11/2021	4	116	29
PLANNED	10/11/2021	5	220	44
PLANNED	10/11/2021	1	61	61
PLANNED	10/11/2021	3	36	12
PLANNED	10/11/2021	14	280	20
PLANNED	10/11/2021	5	25	5
PLANNED	10/11/2021	3	12	4
PLANNED	10/11/2021	5	95	19
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	3	276	92

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	5	25	5
PLANNED	10/11/2021	2	10	5
PLANNED	10/11/2021	3	24	8
PLANNED	10/11/2021	4	88	22
PLANNED	10/11/2021	1	5	5
PLANNED	10/11/2021	4	20	5
PLANNED	10/11/2021	1	2	2
PLANNED	10/11/2021	4	492	123
PLANNED	10/11/2021	8	40	5
PLANNED	10/11/2021	5	610	122
PLANNED	10/11/2021	1	175	175
PLANNED	10/11/2021	1	12	12
PLANNED	10/11/2021	3	111	37
PLANNED	10/11/2021	1	60	60
PLANNED	10/11/2021	4	32	8
PLANNED	10/11/2021	3	21	7
PLANNED	10/11/2021	3	24	8
PLANNED	10/11/2021	2	68	34
PLANNED	10/11/2021	2	12	6
PLANNED	10/11/2021	5	135	27
PLANNED	10/11/2021	6	318	53
PLANNED	10/11/2021	2	126	63
PLANNED	10/11/2021	5	35	7
PLANNED	10/11/2021	4	108	27
PLANNED	10/11/2021	4	36	9
PLANNED	10/11/2021	4	32	8
PLANNED	10/11/2021	3	27	9
PLANNED	10/11/2021	12	144	12
PLANNED	10/11/2021	3	24	8
PLANNED	10/11/2021	2	8	4
PLANNED	10/11/2021	4	96	24
PLANNED	10/11/2021	2	14	7
PLANNED	10/11/2021	3	15	5
PLANNED	10/11/2021	2	38	19
PLANNED	10/11/2021	3	108	36
PLANNED	10/11/2021	5	165	33
PLANNED	10/11/2021	1	33	33
PLANNED	10/11/2021	1	32	32
PLANNED	10/11/2021	7	210	30
PLANNED	10/11/2021	3	78	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	2	20	10
PLANNED	10/11/2021	1	57	57
PLANNED	10/11/2021	3	78	26
PLANNED	10/11/2021	4	52	13
PLANNED	10/11/2021	3	27	9
PLANNED	10/11/2021	7	161	23
PLANNED	10/11/2021	3	18	6
PLANNED	10/11/2021	2	148	74
PLANNED	10/11/2021	1	71	71
PLANNED	10/11/2021	3	477	159
PLANNED	10/11/2021	5	285	57
PLANNED	10/11/2021	1	225	225
PLANNED	10/11/2021	7	280	40
PLANNED	10/11/2021	4	548	137
PLANNED	10/11/2021	6	858	143
PLANNED	10/11/2021	2	50	25
PLANNED	10/11/2021	4	60	15
PLANNED	10/11/2021	4	280	70
PLANNED	10/11/2021	7	77	11
PLANNED	10/11/2021	1	9	9
PLANNED	10/11/2021	3	36	12
PLANNED	10/11/2021	3	264	88
PLANNED	10/11/2021	2	24	12
PLANNED	10/11/2021	3	27	9
PLANNED	10/11/2021	4	324	81
PLANNED	10/11/2021	1	74	74
PLANNED	10/11/2021	4	144	36
PLANNED	10/11/2021	3	264	88
PLANNED	10/11/2021	13	637	49
PLANNED	10/11/2021	2	34	17
PLANNED	10/11/2021	3	63	21
PLANNED	10/11/2021	1	5	5
PLANNED	10/11/2021	3	39	13
PLANNED	10/11/2021	4	108	27
PLANNED	10/11/2021	4	44	11
PLANNED	10/11/2021	3	21	7
PLANNED	10/11/2021	2	66	33
PLANNED	10/11/2021	4	24	6
PLANNED	10/11/2021	2	18	9
PLANNED	10/11/2021	4	24	6
PLANNED	10/11/2021	6	468	78

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/11/2021	2	16	8
PLANNED	10/11/2021	7	756	108
PLANNED	10/11/2021	4	104	26
PLANNED	10/11/2021	3	24	8
PLANNED	10/11/2021	3	27	9
PLANNED	10/11/2021	9	387	43
PLANNED	10/11/2021	1	156	156
PLANNED	10/11/2021	3	87	29
PLANNED	10/11/2021	3	42	14
PLANNED	10/11/2021	3	33	11
PLANNED	10/11/2021	3	177	59
PLANNED	10/11/2021	1	19	19
PLANNED	10/11/2021	1	61	61
PLANNED	10/11/2021	3	99	33
PLANNED	10/11/2021	1	247	247
PLANNED	10/11/2021	3	54	18
PLANNED	10/11/2021	5	60	12
PLANNED	10/11/2021	4	216	54
CUSTOMER REQUEST	10/11/2021	1	91	91
CUSTOMER REQUEST	10/11/2021	3	24	8
PLANNED	10/11/2021	1	97	97
PLANNED	10/11/2021	1	100	100
PLANNED	10/11/2021	5	710	142
PLANNED	10/11/2021	3	363	121
PLANNED	10/11/2021	1	171	171
PLANNED	10/12/2021	3	396	132
PLANNED	10/12/2021	6	198	33
PLANNED	10/12/2021	5	265	53
PLANNED	10/12/2021	4	448	112
PLANNED	10/12/2021	4	580	145
PLANNED	10/12/2021	5	235	47
PLANNED	10/12/2021	2	14	7
PLANNED	10/12/2021	4	36	9
PLANNED	10/12/2021	4	36	9
PLANNED	10/12/2021	3	39	13
PLANNED	10/12/2021	6	48	8
PLANNED	10/12/2021	1	22	22
PLANNED	10/12/2021	4	86	29
PLANNED	10/12/2021	3	129	43
PLANNED	10/12/2021	6	840	140
PLANNED	10/12/2021	3	147	49

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	1	6	6
PLANNED	10/12/2021	1	112	112
PLANNED	10/12/2021	1	173	173
PLANNED	10/12/2021	7	154	22
PLANNED	10/12/2021	4	588	147
PLANNED	10/12/2021	2	296	148
PLANNED	10/12/2021	9	81	9
PLANNED	10/12/2021	2	296	148
PLANNED	10/12/2021	2	296	148
PLANNED	10/12/2021	4	592	148
PLANNED	10/12/2021	11	539	49
PLANNED	10/12/2021	5	710	142
PLANNED	10/12/2021	1	383	383
PLANNED	10/12/2021	3	24	8
PLANNED	10/12/2021	28	2,688	96
PLANNED	10/12/2021	2	10	5
PLANNED	10/12/2021	3	219	73
PLANNED	10/12/2021	4	28	7
PLANNED	10/12/2021	2	284	142
PLANNED	10/12/2021	3	33	11
PLANNED	10/12/2021	5	670	134
PLANNED	10/12/2021	8	320	40
PLANNED	10/12/2021	4	36	9
PLANNED	10/12/2021	2	14	7
PLANNED	10/12/2021	1	177	177
PLANNED	10/12/2021	1	177	177
PLANNED	10/12/2021	1	177	177
PLANNED	10/12/2021	1	177	177
PLANNED	10/12/2021	1	177	177
PLANNED	10/12/2021	6	1,572	262
PLANNED	10/12/2021	4	128	32
PLANNED	10/12/2021	3	549	183
PLANNED	10/12/2021	4	80	20
PLANNED	10/12/2021	8	144	18
PLANNED	10/12/2021	2	916	458
PLANNED	10/12/2021	4	600	150
PLANNED	10/12/2021	9	756	84
CUSTOMER REQUEST	10/12/2021	12	3,552	296
PLANNED	10/12/2021	7	805	115
PLANNED	10/12/2021	6	132	22
PLANNED	10/12/2021	5	10	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	9	360	40
PLANNED	10/12/2021	6	54	9
PLANNED	10/12/2021	3	27	9
PLANNED	10/12/2021	5	290	58
PLANNED	10/12/2021	3	87	29
PLANNED	10/12/2021	1	7	7
PLANNED	10/12/2021	3	3	1
PLANNED	10/12/2021	2	608	304
PLANNED	10/12/2021	6	606	101
PLANNED	10/12/2021	7	448	64
PLANNED	10/12/2021	3	720	240
PLANNED	10/12/2021	193	11,001	57
PLANNED	10/12/2021	3	483	161
PLANNED	10/12/2021	3	93	31
PLANNED	10/12/2021	21	441	21
PLANNED	10/12/2021	6	372	62
PLANNED	10/12/2021	2	414	207
PLANNED	10/12/2021	17	1,122	66
PLANNED	10/12/2021	4	64	16
PLANNED	10/12/2021	1	22	22
PLANNED	10/12/2021	14	2,562	183
PLANNED	10/12/2021	10	440	44
PLANNED	10/12/2021	6	252	42
PLANNED	10/12/2021	6	300	50
PLANNED	10/12/2021	2	542	271
PLANNED	10/12/2021	3	72	24
PLANNED	10/12/2021	10	600	60
PLANNED	10/12/2021	2	42	21
PLANNED	10/12/2021	3	18	6
PLANNED	10/12/2021	3	39	13
PLANNED	10/12/2021	4	260	65
PLANNED	10/12/2021	6	120	20
PLANNED	10/12/2021	12	144	12
PLANNED	10/12/2021	3	315	105
PLANNED	10/12/2021	7	539	77
PLANNED	10/12/2021	2	16	8
PLANNED	10/12/2021	5	40	8
PLANNED	10/12/2021	4	44	11
PLANNED	10/12/2021	8	40	5
PLANNED	10/12/2021	4	44	11
PLANNED	10/12/2021	1	28	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	4	112	28
PLANNED	10/12/2021	4	28	7
PLANNED	10/12/2021	8	1,616	202
PLANNED	10/12/2021	6	936	156
PLANNED	10/12/2021	3	315	105
PLANNED	10/12/2021	17	2,108	124
PLANNED	10/12/2021	4	60	15
PLANNED	10/12/2021	2	454	227
PLANNED	10/12/2021	3	33	11
PLANNED	10/12/2021	7	525	75
PLANNED	10/12/2021	7	602	86
PLANNED	10/12/2021	3	33	11
PLANNED	10/12/2021	3	30	10
PLANNED	10/12/2021	1	21	21
PLANNED	10/12/2021	5	85	17
PLANNED	10/12/2021	2	356	178
PLANNED	10/12/2021	2	80	40
PLANNED	10/12/2021	1	50	50
PLANNED	10/12/2021	10	340	34
PLANNED	10/12/2021	2	230	115
PLANNED	10/12/2021	1	9	9
PLANNED	10/12/2021	4	368	92
PLANNED	10/12/2021	1	191	191
PLANNED	10/12/2021	10	180	18
PLANNED	10/12/2021	2	1,022	511
PLANNED	10/12/2021	1	70	70
PLANNED	10/12/2021	195	7,605	39
PLANNED	10/12/2021	8	384	48
PLANNED	10/12/2021	6	102	17
PLANNED	10/12/2021	13	182	14
PLANNED	10/12/2021	2	200	100
PLANNED	10/12/2021	7	329	47
PLANNED	10/12/2021	3	21	7
PLANNED	10/12/2021	7	49	7
PLANNED	10/12/2021	4	79	25
PLANNED	10/12/2021	13	3,744	288
PLANNED	10/12/2021	1	27	27
PLANNED	10/12/2021	14	770	55
PLANNED	10/12/2021	2	76	38
PLANNED	10/12/2021	1	11	11
PLANNED	10/12/2021	27	486	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	35	1,820	52
PLANNED	10/12/2021	13	312	24
PLANNED	10/12/2021	1	115	115
PLANNED	10/12/2021	3	444	148
PLANNED	10/12/2021	1	147	147
PLANNED	10/12/2021	8	1,176	147
PLANNED	10/12/2021	9	72	8
PLANNED	10/12/2021	29	377	13
PLANNED	10/12/2021	5	35	7
PLANNED	10/12/2021	7	210	30
PLANNED	10/12/2021	4	20	5
PLANNED	10/12/2021	6	210	35
PLANNED	10/12/2021	8	360	45
PLANNED	10/12/2021	10	630	63
PLANNED	10/12/2021	12	876	73
PLANNED	10/12/2021	1	178	178
PLANNED	10/12/2021	17	1,105	65
PLANNED	10/12/2021	18	1,170	65
PLANNED	10/12/2021	14	910	65
PLANNED	10/12/2021	3	297	99
PLANNED	10/12/2021	4	40	10
PLANNED	10/12/2021	4	20	5
PLANNED	10/12/2021	2	20	10
PLANNED	10/12/2021	4	352	88
PLANNED	10/12/2021	3	306	102
PLANNED	10/12/2021	19	49	16
PLANNED	10/12/2021	1	50	50
PLANNED	10/12/2021	1	8	8
PLANNED	10/12/2021	7	1,036	148
PLANNED	10/12/2021	9	225	25
PLANNED	10/12/2021	1	5	5
PLANNED	10/12/2021	1	175	175
PLANNED	10/12/2021	2	270	135
PLANNED	10/12/2021	2	36	18
PLANNED	10/12/2021	2	34	17
PLANNED	10/12/2021	1	201	201
PLANNED	10/12/2021	1	4	4
PLANNED	10/12/2021	9	73	17
CUSTOMER REQUEST	10/12/2021	3	36	12
PLANNED	10/12/2021	7	42	6
PLANNED	10/12/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	10	600	60
PLANNED	10/12/2021	1	91	91
PLANNED	10/12/2021	1	91	91
PLANNED	10/12/2021	1	10	10
PLANNED	10/12/2021	1	91	91
PLANNED	10/12/2021	4	388	97
PLANNED	10/12/2021	2	194	97
PLANNED	10/12/2021	4	408	102
PLANNED	10/12/2021	1	97	97
PLANNED	10/12/2021	2	34	17
PLANNED	10/12/2021	2	192	96
PLANNED	10/12/2021	4	96	24
PLANNED	10/12/2021	3	99	33
PLANNED	10/12/2021	20	180	9
PLANNED	10/12/2021	5	265	53
PLANNED	10/12/2021	5	780	156
PLANNED	10/12/2021	1	5	5
PLANNED	10/12/2021	3	510	170
PLANNED	10/12/2021	15	135	9
PLANNED	10/12/2021	8	1,440	180
PLANNED	10/12/2021	10	230	23
PLANNED	10/12/2021	4	148	37
PLANNED	10/12/2021	1	8	8
PLANNED	10/12/2021	6	606	101
PLANNED	10/12/2021	11	770	70
PLANNED	10/12/2021	2	218	109
PLANNED	10/12/2021	18	162	9
PLANNED	10/12/2021	8	496	62
PLANNED	10/12/2021	11	165	15
PLANNED	10/12/2021	5	35	7
PLANNED	10/12/2021	6	36	6
PLANNED	10/12/2021	1	6	6
PLANNED	10/12/2021	13	117	9
PLANNED	10/12/2021	5	65	13
PLANNED	10/12/2021	4	384	96
PLANNED	10/12/2021	1	4	4
PLANNED	10/12/2021	3	120	40
PLANNED	10/12/2021	1	112	112
PLANNED	10/12/2021	1	5	5
PLANNED	10/12/2021	7	77	11
PLANNED	10/12/2021	6	630	105

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	5	285	57
PLANNED	10/12/2021	1	129	129
PLANNED	10/12/2021	8	208	26
PLANNED	10/12/2021	1	3	3
PLANNED	10/12/2021	11	2,574	234
PLANNED	10/12/2021	9	2,052	228
PLANNED	10/12/2021	11	2,893	263
PLANNED	10/12/2021	3	33	11
PLANNED	10/12/2021	5	175	35
PLANNED	10/12/2021	4	72	18
PLANNED	10/12/2021	21	273	13
PLANNED	10/12/2021	2	8	4
PLANNED	10/12/2021	2	16	8
PLANNED	10/12/2021	3	54	18
PLANNED	10/12/2021	1	33	33
PLANNED	10/12/2021	1	6	6
PLANNED	10/12/2021	3	27	9
PLANNED	10/12/2021	1	5	5
CUSTOMER REQUEST	10/12/2021	1	161	161
PLANNED	10/12/2021	1	7	7
PLANNED	10/12/2021	2	10	5
PLANNED	10/12/2021	2	10	5
PLANNED	10/12/2021	1	9	9
PLANNED	10/12/2021	1	5	5
PLANNED	10/12/2021	1	15	15
PLANNED	10/12/2021	2	16	8
PLANNED	10/12/2021	2	16	8
PLANNED	10/12/2021	1	5	5
PLANNED	10/12/2021	3	63	21
PLANNED	10/12/2021	3	198	66
PLANNED	10/12/2021	1	24	24
PLANNED	10/12/2021	12	408	34
PLANNED	10/12/2021	5	95	19
PLANNED	10/12/2021	4	24	6
PLANNED	10/12/2021	3	159	53
PLANNED	10/12/2021	2	10	5
PLANNED	10/12/2021	6	156	26
PLANNED	10/12/2021	2	12	6
PLANNED	10/12/2021	2	102	51
PLANNED	10/12/2021	3	15	5
PLANNED	10/12/2021	27	378	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/12/2021	1	199	199
PLANNED	10/12/2021	3	72	24
PLANNED	10/12/2021	2	16	8
PLANNED	10/12/2021	5	265	53
PLANNED	10/12/2021	2	22	11
PLANNED	10/12/2021	2	76	38
PLANNED	10/12/2021	2	154	77
PLANNED	10/12/2021	4	20	5
PLANNED	10/12/2021	2	20	10
PLANNED	10/12/2021	10	1,600	160
PLANNED	10/12/2021	7	63	9
PLANNED	10/12/2021	2	266	133
PLANNED	10/12/2021	2	10	5
PLANNED	10/12/2021	4	120	30
PLANNED	10/12/2021	4	160	40
PLANNED	10/12/2021	3	21	7
PLANNED	10/12/2021	3	30	10
PLANNED	10/12/2021	3	21	7
PLANNED	10/12/2021	3	42	14
PLANNED	10/12/2021	9	243	27
PLANNED	10/12/2021	1	81	81
PLANNED	10/12/2021	17	425	25
PLANNED	10/12/2021	1	140	140
PLANNED	10/12/2021	3	21	7
PLANNED	10/12/2021	4	52	13
PLANNED	10/12/2021	2	14	7
CUSTOMER REQUEST	10/12/2021	1	29	29
PLANNED	10/12/2021	2	32	16
PLANNED	10/12/2021	1	94	94
PLANNED	10/12/2021	1	129	129
PLANNED	10/12/2021	4	656	164
PLANNED	10/12/2021	1	151	151
CUSTOMER REQUEST	10/13/2021	203	61,733	325
CUSTOMER REQUEST	10/13/2021	4	476	119
PLANNED	10/13/2021	5	550	110
PLANNED	10/13/2021	1	103	103
PLANNED	10/13/2021	1	283	283
PLANNED	10/13/2021	2	122	61
PLANNED	10/13/2021	1	51	51
PLANNED	10/13/2021	27	2,160	80
PLANNED	10/13/2021	2	172	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/13/2021	2	250	125
PLANNED	10/13/2021	5	840	168
PLANNED	10/13/2021	5	55	11
PLANNED	10/13/2021	9	333	37
PLANNED	10/13/2021	6	534	89
PLANNED	10/13/2021	9	270	30
PLANNED	10/13/2021	1	220	220
PLANNED	10/13/2021	1	90	90
PLANNED	10/13/2021	2	8	4
PLANNED	10/13/2021	2	8	4
PLANNED	10/13/2021	2	178	89
PLANNED	10/13/2021	1	89	89
PLANNED	10/13/2021	11	66	6
PLANNED	10/13/2021	3	114	38
PLANNED	10/13/2021	1	136	136
PLANNED	10/13/2021	3	273	91
PLANNED	10/13/2021	2	20	10
PLANNED	10/13/2021	1	20	20
PLANNED	10/13/2021	2	180	90
PLANNED	10/13/2021	1	90	90
PLANNED	10/13/2021	1	89	89
PLANNED	10/13/2021	1	90	90
PLANNED	10/13/2021	1	89	89
PLANNED	10/13/2021	2	20	10
PLANNED	10/13/2021	1	89	89
PLANNED	10/13/2021	4	40	10
CUSTOMER REQUEST	10/13/2021	1	282	282
PLANNED	10/13/2021	11	88	8
PLANNED	10/13/2021	1	96	96
PLANNED	10/13/2021	4	128	32
PLANNED	10/13/2021	1	31	31
PLANNED	10/13/2021	3	357	119
PLANNED	10/13/2021	1	7	7
PLANNED	10/13/2021	11	154	14
PLANNED	10/13/2021	2	578	289
PLANNED	10/13/2021	3	210	70
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	8	152	19
PLANNED	10/13/2021	8	272	34
PLANNED	10/13/2021	1	75	75
PLANNED	10/13/2021	9	234	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/13/2021	10	1,100	110
PLANNED	10/13/2021	16	2,000	125
CUSTOMER REQUEST	10/13/2021	1	127	127
PLANNED	10/13/2021	2	178	89
PLANNED	10/13/2021	4	556	139
PLANNED	10/13/2021	4	692	212
PLANNED	10/13/2021	3	84	28
PLANNED	10/13/2021	3	516	172
PLANNED	10/13/2021	1	83	83
CUSTOMER REQUEST	10/13/2021	18	252	14
PLANNED	10/13/2021	1	7	7
PLANNED	10/13/2021	3	9	3
PLANNED	10/13/2021	14	1,890	135
PLANNED	10/13/2021	1	21	21
PLANNED	10/13/2021	4	48	12
PLANNED	10/13/2021	26	1,013	63
PLANNED	10/13/2021	2	400	200
PLANNED	10/13/2021	2	8	4
PLANNED	10/13/2021	1	24	24
PLANNED	10/13/2021	2	64	32
PLANNED	10/13/2021	6	30	5
PLANNED	10/13/2021	3	423	141
PLANNED	10/13/2021	6	24	4
PLANNED	10/13/2021	1	9	9
PLANNED	10/13/2021	3	276	92
PLANNED	10/13/2021	1	130	130
PLANNED	10/13/2021	1	130	130
PLANNED	10/13/2021	1	131	131
PLANNED	10/13/2021	3	393	131
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	1	131	131
PLANNED	10/13/2021	2	372	186
PLANNED	10/13/2021	7	21	3
PLANNED	10/13/2021	1	166	166
PLANNED	10/13/2021	5	180	36
PLANNED	10/13/2021	4	172	43
PLANNED	10/13/2021	5	60	12
PLANNED	10/13/2021	1	278	278
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	2	130	65
PLANNED	10/13/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/13/2021	2	8	4
PLANNED	10/13/2021	2	16	8
PLANNED	10/13/2021	1	71	71
PLANNED	10/13/2021	2	158	79
PLANNED	10/13/2021	2	14	7
PLANNED	10/13/2021	2	12	6
PLANNED	10/13/2021	6	186	56
PLANNED	10/13/2021	1	77	77
PLANNED	10/13/2021	1	10	10
PLANNED	10/13/2021	2	364	182
PLANNED	10/13/2021	2	192	96
PLANNED	10/13/2021	1	50	50
PLANNED	10/13/2021	1	4	4
PLANNED	10/13/2021	27	1,620	60
CUSTOMER REQUEST	10/13/2021	1	216	216
PLANNED	10/13/2021	1	165	165
PLANNED	10/13/2021	21	693	33
PLANNED	10/13/2021	3	12	4
PLANNED	10/13/2021	9	63	7
PLANNED	10/13/2021	2	50	25
PLANNED	10/13/2021	1	8	8
PLANNED	10/13/2021	13	2,873	221
PLANNED	10/13/2021	3	162	54
PLANNED	10/13/2021	1	3	3
PLANNED	10/13/2021	1	204	204
PLANNED	10/13/2021	3	33	11
PLANNED	10/13/2021	1	7	7
CUSTOMER REQUEST	10/13/2021	8	1,844	237
PLANNED	10/13/2021	1	12	12
CUSTOMER REQUEST	10/13/2021	73	32,923	451
PLANNED	10/13/2021	8	1,408	176
PLANNED	10/13/2021	32	160	5
PLANNED	10/13/2021	4	88	22
PLANNED	10/13/2021	1	298	298
PLANNED	10/13/2021	1	87	87
PLANNED	10/13/2021	4	248	62
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	4	336	84
PLANNED	10/13/2021	1	199	199
PLANNED	10/13/2021	2	184	92
PLANNED	10/13/2021	21	756	36

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/13/2021	1	184	184
PLANNED	10/13/2021	6	384	64
PLANNED	10/13/2021	1	8	8
PLANNED	10/13/2021	7	357	51
PLANNED	10/13/2021	1	9	9
PLANNED	10/13/2021	1	29	29
PLANNED	10/13/2021	1	19	19
PLANNED	10/13/2021	1	4	4
PLANNED	10/13/2021	1	7	7
PLANNED	10/13/2021	1	4	4
PLANNED	10/13/2021	10	590	59
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	2	236	118
PLANNED	10/13/2021	5	220	44
PLANNED	10/13/2021	8	568	71
PLANNED	10/13/2021	3	282	94
PLANNED	10/13/2021	2	194	97
PLANNED	10/13/2021	4	96	24
PLANNED	10/13/2021	1	8	8
PLANNED	10/13/2021	7	980	140
PLANNED	10/13/2021	10	1,340	134
PLANNED	10/13/2021	1	104	104
PLANNED	10/13/2021	7	378	54
PLANNED	10/13/2021	5	385	77
PLANNED	10/13/2021	9	360	40
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	1	140	140
CUSTOMER REQUEST	10/13/2021	2	108	54
PLANNED	10/13/2021	1	135	135
PLANNED	10/13/2021	1	140	140
PLANNED	10/13/2021	9	1,584	176
PLANNED	10/13/2021	2	278	139
PLANNED	10/13/2021	2	278	139
PLANNED	10/13/2021	1	26	26
PLANNED	10/13/2021	2	10	5
PLANNED	10/13/2021	2	166	83
PLANNED	10/13/2021	10	460	46
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	1	47	47
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	2	52	26

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	10/13/2021	4	104	26
PLANNED	10/13/2021	1	33	33
PLANNED	10/13/2021	2	18	9
PLANNED	10/13/2021	2	240	120
PLANNED	10/13/2021	1	7	7
PLANNED	10/13/2021	1	13	13
PLANNED	10/13/2021	5	855	171
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	3	18	6
PLANNED	10/13/2021	4	656	164
PLANNED	10/13/2021	4	168	42
PLANNED	10/13/2021	7	39	33
PLANNED	10/13/2021	2	320	160
PLANNED	10/13/2021	1	76	76
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	6	126	21
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	1	5	5
PLANNED	10/13/2021	15	375	25
PLANNED	10/13/2021	1	91	91
PLANNED	10/13/2021	2	6	3
PLANNED	10/13/2021	1	11	11
PLANNED	10/13/2021	2	14	7
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	22	3,300	150
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	1	70	70
PLANNED	10/13/2021	3	78	26
PLANNED	10/13/2021	1	6	6
PLANNED	10/13/2021	8	152	19
PLANNED	10/13/2021	4	380	95
PLANNED	10/13/2021	3	42	14
PLANNED	10/13/2021	4	168	42
PLANNED	10/13/2021	4	396	99
PLANNED	10/13/2021	4	376	94
PLANNED	10/13/2021	2	186	93
PLANNED	10/13/2021	2	96	48
PLANNED	10/13/2021	1	81	81
PLANNED	10/13/2021	2	10	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/13/2021	3	15	5
PLANNED	10/13/2021	2	12	6
PLANNED	10/13/2021	1	93	93
PLANNED	10/13/2021	1	4	4
PLANNED	10/13/2021	9	1,152	128
PLANNED	10/13/2021	10	1,380	138
PLANNED	10/13/2021	9	783	87
PLANNED	10/13/2021	1	95	95
PLANNED	10/13/2021	1	12	12
PLANNED	10/13/2021	1	121	121
PLANNED	10/13/2021	1	7	7
PLANNED	10/13/2021	13	935	79
PLANNED	10/13/2021	3	63	21
PLANNED	10/13/2021	2	92	46
PLANNED	10/13/2021	1	56	56
CUSTOMER REQUEST	10/13/2021	1	90	90
PLANNED	10/13/2021	4	140	35
CUSTOMER REQUEST	10/13/2021	1	101	101
CUSTOMER REQUEST	10/13/2021	1	77	77
PLANNED	10/13/2021	10	410	41
CUSTOMER REQUEST	10/13/2021	1	386	386
PLANNED	10/13/2021	21	1,071	51
PLANNED	10/13/2021	31	7,533	243
PLANNED	10/13/2021	3	681	227
PLANNED	10/13/2021	1	374	374
PLANNED	10/13/2021	4	36	9
PLANNED	10/13/2021	2	112	56
PLANNED	10/13/2021	1	55	55
PLANNED	10/13/2021	1	8	8
PLANNED	10/13/2021	3	237	79
PLANNED	10/13/2021	8	712	89
PLANNED	10/13/2021	7	623	89
PLANNED	10/13/2021	8	720	90
PLANNED	10/13/2021	1	168	168
PLANNED	10/13/2021	3	351	117
PLANNED	10/13/2021	1	352	352
PLANNED	10/14/2021	1	111	111
PLANNED	10/14/2021	1	134	134
PLANNED	10/14/2021	6	540	90
PLANNED	10/14/2021	1	90	90
PLANNED	10/14/2021	9	1,890	210

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/14/2021	10	320	32
PLANNED	10/14/2021	2	134	67
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	1	4	4
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	12	480	40
PLANNED	10/14/2021	2	26	13
PLANNED	10/14/2021	4	288	72
PLANNED	10/14/2021	14	462	33
PLANNED	10/14/2021	6	216	36
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	2	442	221
PLANNED	10/14/2021	1	8	8
CUSTOMER REQUEST	10/14/2021	1	9	9
CUSTOMER REQUEST	10/14/2021	2	12	6
CUSTOMER REQUEST	10/14/2021	1	9	9
CUSTOMER REQUEST	10/14/2021	1	12	12
PLANNED	10/14/2021	2	178	89
CUSTOMER REQUEST	10/14/2021	46	230	5
PLANNED	10/14/2021	13	3,484	268
PLANNED	10/14/2021	35	2,205	63
PLANNED	10/14/2021	1	275	275
PLANNED	10/14/2021	6	870	145
PLANNED	10/14/2021	1	25	25
PLANNED	10/14/2021	1	4	4
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	2	10	5
PLANNED	10/14/2021	2	14	7
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	1	4	4
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	2	76	38
PLANNED	10/14/2021	7	826	118
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	3	51	17
PLANNED	10/14/2021	1	9	9
PLANNED	10/14/2021	1	163	163
PLANNED	10/14/2021	133	3,192	24
PLANNED	10/14/2021	1	160	160
PLANNED	10/14/2021	8	440	55

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/14/2021	1	10	10
PLANNED	10/14/2021	1	275	275
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	8	472	59
PLANNED	10/14/2021	1	72	72
PLANNED	10/14/2021	2	126	63
PLANNED	10/14/2021	2	26	13
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	1	70	70
PLANNED	10/14/2021	2	168	84
PLANNED	10/14/2021	3	120	40
PLANNED	10/14/2021	4	180	45
PLANNED	10/14/2021	8	192	24
PLANNED	10/14/2021	3	423	141
PLANNED	10/14/2021	1	94	94
PLANNED	10/14/2021	3	30	10
PLANNED	10/14/2021	2	76	38
PLANNED	10/14/2021	2	8	4
PLANNED	10/14/2021	5	570	114
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	10	1,220	122
PLANNED	10/14/2021	8	864	108
PLANNED	10/14/2021	1	50	50
PLANNED	10/14/2021	9	9	1
PLANNED	10/14/2021	2	158	79
PLANNED	10/14/2021	2	22	11
PLANNED	10/14/2021	3	351	117
PLANNED	10/14/2021	15	555	37
PLANNED	10/14/2021	17	1,581	93
PLANNED	10/14/2021	3	18	6
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	2	12	6
CUSTOMER REQUEST	10/14/2021	1	246	246
PLANNED	10/14/2021	5	585	117
PLANNED	10/14/2021	4	168	42
PLANNED	10/14/2021	1	463	463
PLANNED	10/14/2021	3	45	15
PLANNED	10/14/2021	1	116	116
PLANNED	10/14/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/14/2021	3	93	31
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	4	1,092	273
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	1	4	4
PLANNED	10/14/2021	1	120	120
PLANNED	10/14/2021	2	12	6
PLANNED	10/14/2021	2	154	77
PLANNED	10/14/2021	4	128	32
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	1	10	10
PLANNED	10/14/2021	3	21	7
PLANNED	10/14/2021	1	56	56
PLANNED	10/14/2021	10	1,700	170
PLANNED	10/14/2021	1	7	7
CUSTOMER REQUEST	10/14/2021	1	589	589
PLANNED	10/14/2021	4	284	71
PLANNED	10/14/2021	3	588	196
PLANNED	10/14/2021	1	10	10
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	2	6	3
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	1	86	86
PLANNED	10/14/2021	4	448	112
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	5	410	82
PLANNED	10/14/2021	3	534	178
PLANNED	10/14/2021	1	4	4
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	2	18	9
PLANNED	10/14/2021	1	82	82
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	8	2,352	294
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	4	312	78
PLANNED	10/14/2021	2	474	237
PLANNED	10/14/2021	1	2	2
PLANNED	10/14/2021	2	28	14
PLANNED	10/14/2021	8	600	75
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	2	10	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	2	12	6
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	3	27	9
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	5	270	54
PLANNED	10/14/2021	4	888	222
PLANNED	10/14/2021	1	9	9
PLANNED	10/14/2021	3	222	74
PLANNED	10/14/2021	2	22	11
PLANNED	10/14/2021	1	9	9
PLANNED	10/14/2021	2	38	19
PLANNED	10/14/2021	2	258	129
PLANNED	10/14/2021	4	60	15
CUSTOMER REQUEST	10/14/2021	1	541	541
CUSTOMER REQUEST	10/14/2021	8	448	56
PLANNED	10/14/2021	9	369	42
PLANNED	10/14/2021	1	10	10
PLANNED	10/14/2021	3	141	47
PLANNED	10/14/2021	4	404	101
PLANNED	10/14/2021	6	498	83
PLANNED	10/14/2021	5	415	83
PLANNED	10/14/2021	5	610	122
PLANNED	10/14/2021	1	75	75
PLANNED	10/14/2021	8	208	26
PLANNED	10/14/2021	1	157	157
PLANNED	10/14/2021	5	320	64
CUSTOMER REQUEST	10/14/2021	2	280	140
PLANNED	10/14/2021	4	248	62
CUSTOMER REQUEST	10/14/2021	6	906	169
PLANNED	10/14/2021	3	39	13
PLANNED	10/14/2021	8	160	20
PLANNED	10/14/2021	2	152	76
PLANNED	10/14/2021	3	186	62
PLANNED	10/14/2021	1	5	5
PLANNED	10/14/2021	8	232	29
PLANNED	10/14/2021	3	111	37
PLANNED	10/14/2021	18	666	37
PLANNED	10/14/2021	1	6	6
CUSTOMER REQUEST	10/14/2021	2	70	35
PLANNED	10/14/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/14/2021	10	1,370	137
PLANNED	10/14/2021	4	508	127
PLANNED	10/14/2021	7	790	139
PLANNED	10/14/2021	2	100	50
PLANNED	10/14/2021	8	689	290
PLANNED	10/14/2021	1	99	99
PLANNED	10/14/2021	2	16	8
PLANNED	10/14/2021	1	8	8
PLANNED	10/14/2021	2	88	44
PLANNED	10/14/2021	4	144	36
PLANNED	10/14/2021	2	12	6
PLANNED	10/14/2021	1	73	73
PLANNED	10/14/2021	2	90	45
PLANNED	10/14/2021	2	14	7
PLANNED	10/14/2021	1	230	230
PLANNED	10/14/2021	2	420	210
PLANNED	10/14/2021	1	6	6
PLANNED	10/14/2021	11	385	35
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	9	198	22
PLANNED	10/14/2021	1	19	19
PLANNED	10/14/2021	3	159	53
PLANNED	10/14/2021	1	142	142
CUSTOMER REQUEST	10/14/2021	7	1,022	146
PLANNED	10/14/2021	1	7	7
PLANNED	10/14/2021	3	153	51
PLANNED	10/14/2021	2	94	47
PLANNED	10/14/2021	1	166	166
PLANNED	10/14/2021	1	105	105
PLANNED	10/14/2021	1	119	119
PLANNED	10/14/2021	2	234	117
PLANNED	10/14/2021	1	94	94
PLANNED	10/14/2021	14	3,906	279
PLANNED	10/14/2021	5	635	127
PLANNED	10/14/2021	2	260	130
PLANNED	10/14/2021	2	154	77
PLANNED	10/14/2021	4	496	124
PLANNED	10/14/2021	5	700	140
PLANNED	10/15/2021	3	108	36
PLANNED	10/15/2021	2	330	165
PLANNED	10/15/2021	2	3,062	1,531

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/15/2021	1	176	176
PLANNED	10/15/2021	1	121	121
PLANNED	10/15/2021	8	192	24
PLANNED	10/15/2021	10	80	8
PLANNED	10/15/2021	3	180	60
PLANNED	10/15/2021	2	148	74
PLANNED	10/15/2021	3	645	215
PLANNED	10/15/2021	3	66	22
PLANNED	10/15/2021	6	1,260	210
PLANNED	10/15/2021	6	1,296	216
CUSTOMER REQUEST	10/15/2021	14	98	7
CUSTOMER REQUEST	10/15/2021	8	96	12
PLANNED	10/15/2021	1	163	163
PLANNED	10/15/2021	1	210	210
PLANNED	10/15/2021	1	154	154
PLANNED	10/15/2021	2	36	18
PLANNED	10/15/2021	4	888	222
PLANNED	10/15/2021	2	2	1
PLANNED	10/15/2021	6	468	78
PLANNED	10/15/2021	10	2,100	210
PLANNED	10/15/2021	4	72	18
PLANNED	10/15/2021	4	760	190
CUSTOMER REQUEST	10/15/2021	1	189	189
PLANNED	10/15/2021	2	36	18
PLANNED	10/15/2021	3	42	14
PLANNED	10/15/2021	8	1,136	142
PLANNED	10/15/2021	4	156	39
PLANNED	10/15/2021	22	1,958	89
PLANNED	10/15/2021	3	57	19
PLANNED	10/15/2021	8	552	69
PLANNED	10/15/2021	3	45	15
PLANNED	10/15/2021	3	54	18
PLANNED	10/15/2021	1	128	128
PLANNED	10/15/2021	5	445	89
CUSTOMER REQUEST	10/15/2021	6	96	16
PLANNED	10/15/2021	4	616	154
PLANNED	10/15/2021	6	720	120
CUSTOMER REQUEST	10/15/2021	2	240	120
PLANNED	10/15/2021	8	432	54
PLANNED	10/15/2021	3	84	28
PLANNED	10/15/2021	6	36	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/15/2021	16	672	42
PLANNED	10/15/2021	4	700	175
CUSTOMER REQUEST	10/15/2021	3	60	20
PLANNED	10/15/2021	13	468	36
PLANNED	10/15/2021	9	280	77
PLANNED	10/15/2021	4	848	212
CUSTOMER REQUEST	10/15/2021	15	690	46
CUSTOMER REQUEST	10/15/2021	15	570	38
PLANNED	10/15/2021	4	424	106
PLANNED	10/15/2021	1	141	141
PLANNED	10/15/2021	1	44	44
CUSTOMER REQUEST	10/15/2021	12	36	3
PLANNED	10/15/2021	4	128	32
PLANNED	10/15/2021	4	500	125
PLANNED	10/15/2021	1	59	59
PLANNED	10/15/2021	1	26	26
PLANNED	10/15/2021	3	294	98
PLANNED	10/15/2021	10	350	35
PLANNED	10/15/2021	14	196	14
PLANNED	10/15/2021	5	140	28
PLANNED	10/15/2021	7	518	74
CUSTOMER REQUEST	10/15/2021	6	276	46
PLANNED	10/15/2021	11	110	10
PLANNED	10/15/2021	3	186	62
PLANNED	10/15/2021	8	528	66
CUSTOMER REQUEST	10/15/2021	1	59	59
PLANNED	10/15/2021	1	141	141
PLANNED	10/15/2021	19	3,078	162
CUSTOMER REQUEST	10/15/2021	1	317	317
CUSTOMER REQUEST	10/15/2021	51	1,734	34
PLANNED	10/15/2021	1	122	122
CUSTOMER REQUEST	10/16/2021	1	763	763
PLANNED	10/16/2021	24	2,568	107
PLANNED	10/16/2021	1	131	131
PLANNED	10/16/2021	1	154	154
PLANNED	10/16/2021	8	2,240	280
PLANNED	10/16/2021	2	36	18
PLANNED	10/16/2021	1	220	220
PLANNED	10/16/2021	4	104	26
PLANNED	10/16/2021	1	286	286
PLANNED	10/16/2021	4	596	149

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/16/2021	2	44	22
PLANNED	10/16/2021	2	262	131
PLANNED	10/16/2021	2	42	21
PLANNED	10/16/2021	1	21	21
PLANNED	10/16/2021	2	4	2
PLANNED	10/16/2021	4	328	82
PLANNED	10/16/2021	3	9	3
CUSTOMER REQUEST	10/16/2021	3	237	79
PLANNED	10/16/2021	2	254	127
PLANNED	10/16/2021	4	216	54
PLANNED	10/16/2021	3	27	9
PLANNED	10/17/2021	4	644	161
PLANNED	10/17/2021	3	399	133
PLANNED	10/17/2021	1	139	139
PLANNED	10/17/2021	9	2,079	231
CUSTOMER REQUEST	10/17/2021	204	11,832	58
PLANNED	10/17/2021	4	132	33
PLANNED	10/17/2021	3	864	288
PLANNED	10/17/2021	4	232	58
PLANNED	10/17/2021	6	714	119
PLANNED	10/17/2021	2	86	43
CUSTOMER REQUEST	10/17/2021	66	6,006	91
PLANNED	10/17/2021	4	92	23
PLANNED	10/17/2021	6	342	57
PLANNED	10/17/2021	4	60	15
PLANNED	10/17/2021	1	204	204
PLANNED	10/17/2021	1	211	211
CUSTOMER REQUEST	10/17/2021	1	117	117
PLANNED	10/18/2021	2	304	152
PLANNED	10/18/2021	10	1,550	155
PLANNED	10/18/2021	2	376	188
PLANNED	10/18/2021	6	348	58
PLANNED	10/18/2021	1	209	209
PLANNED	10/18/2021	2	170	85
PLANNED	10/18/2021	2	368	184
PLANNED	10/18/2021	2	290	145
PLANNED	10/18/2021	1	376	376
PLANNED	10/18/2021	1	80	80
PLANNED	10/18/2021	3	314	127
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	2	4	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	1	17	17
PLANNED	10/18/2021	4	48	12
PLANNED	10/18/2021	14	2,070	202
PLANNED	10/18/2021	4	120	30
PLANNED	10/18/2021	3	21	7
PLANNED	10/18/2021	3	27	9
PLANNED	10/18/2021	4	96	24
PLANNED	10/18/2021	2	18	9
PLANNED	10/18/2021	4	28	7
PLANNED	10/18/2021	40	1,760	44
PLANNED	10/18/2021	17	1,564	92
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	2	22	11
PLANNED	10/18/2021	1	9	9
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	2	10	5
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	4	28	7
PLANNED	10/18/2021	4	28	7
PLANNED	10/18/2021	3	30	10
PLANNED	10/18/2021	5	30	6
CUSTOMER REQUEST	10/18/2021	8	1,448	181
PLANNED	10/18/2021	3	30	10
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	3	114	38
PLANNED	10/18/2021	10	210	21
PLANNED	10/18/2021	2	6	3
PLANNED	10/18/2021	1	92	92
PLANNED	10/18/2021	10	600	60
PLANNED	10/18/2021	9	450	50
PLANNED	10/18/2021	7	476	68
PLANNED	10/18/2021	10	910	91
PLANNED	10/18/2021	10	900	90
PLANNED	10/18/2021	10	830	83
PLANNED	10/18/2021	10	800	80
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	4	96	24
PLANNED	10/18/2021	1	122	122

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	1	122	122
PLANNED	10/18/2021	1	122	122
PLANNED	10/18/2021	1	121	121
PLANNED	10/18/2021	2	244	122
PLANNED	10/18/2021	1	44	44
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	5	50	10
PLANNED	10/18/2021	11	935	85
PLANNED	10/18/2021	9	594	66
PLANNED	10/18/2021	6	318	53
PLANNED	10/18/2021	1	115	115
PLANNED	10/18/2021	2	230	115
PLANNED	10/18/2021	5	275	55
PLANNED	10/18/2021	1	115	115
PLANNED	10/18/2021	1	115	115
PLANNED	10/18/2021	3	342	114
PLANNED	10/18/2021	4	32	8
PLANNED	10/18/2021	1	17	17
PLANNED	10/18/2021	12	768	64
PLANNED	10/18/2021	18	1,728	96
PLANNED	10/18/2021	1	73	73
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	3	27	9
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	1	134	134
PLANNED	10/18/2021	4	124	31
PLANNED	10/18/2021	4	28	7
PLANNED	10/18/2021	3	30	10
PLANNED	10/18/2021	4	16	4
PLANNED	10/18/2021	2	14	7
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	2	238	119
PLANNED	10/18/2021	7	315	45
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	3	141	47
PLANNED	10/18/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	2	24	12
PLANNED	10/18/2021	1	15	15
PLANNED	10/18/2021	3	21	7
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	2	44	22
PLANNED	10/18/2021	2	256	128
PLANNED	10/18/2021	1	25	25
PLANNED	10/18/2021	8	72	9
PLANNED	10/18/2021	4	136	34
PLANNED	10/18/2021	4	32	8
PLANNED	10/18/2021	4	4	1
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	4	32	8
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	2	360	180
PLANNED	10/18/2021	3	24	8
PLANNED	10/18/2021	11	2,442	222
PLANNED	10/18/2021	1	15	15
PLANNED	10/18/2021	1	139	139
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	2	14	7
PLANNED	10/18/2021	17	476	93
PLANNED	10/18/2021	1	109	109
PLANNED	10/18/2021	34	5,202	153
PLANNED	10/18/2021	35	4,900	140
PLANNED	10/18/2021	18	2,304	128
PLANNED	10/18/2021	1	13	13
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	1	67	67
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	4	16	4
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	1	79	79
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	1	95	95
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	2	110	55
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	2	350	175
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	2	18	9
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	6	648	108
PLANNED	10/18/2021	1	69	69
PLANNED	10/18/2021	2	274	137
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	8	208	26
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	2	20	10
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	1	9	9
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	7	28	4
PLANNED	10/18/2021	1	29	29
PLANNED	10/18/2021	13	962	74
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	5	165	33
PLANNED	10/18/2021	2	24	12
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	1	70	70
PLANNED	10/18/2021	1	44	44
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	2	24	12
PLANNED	10/18/2021	5	125	25
PLANNED	10/18/2021	3	24	8
PLANNED	10/18/2021	2	40	20
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	5	285	57
PLANNED	10/18/2021	4	32	8
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	1	65	65
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	3	314	120
PLANNED	10/18/2021	14	168	12
PLANNED	10/18/2021	18	2,232	124
PLANNED	10/18/2021	15	1,725	115
PLANNED	10/18/2021	7	315	45
PLANNED	10/18/2021	9	396	44
PLANNED	10/18/2021	16	528	33
PLANNED	10/18/2021	1	99	99
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	3	12	4
PLANNED	10/18/2021	4	88	22
PLANNED	10/18/2021	4	32	8
PLANNED	10/18/2021	1	5	5
PLANNED	10/18/2021	4	56	14
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	3	27	9
PLANNED	10/18/2021	4	36	9
PLANNED	10/18/2021	2	22	11
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	3	12	4
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	3	81	27
PLANNED	10/18/2021	1	107	107
PLANNED	10/18/2021	1	8	8
PLANNED	10/18/2021	1	4	4
PLANNED	10/18/2021	4	312	78
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	1	164	164
PLANNED	10/18/2021	3	36	12
PLANNED	10/18/2021	4	28	7
PLANNED	10/18/2021	4	264	66
PLANNED	10/18/2021	2	60	30
PLANNED	10/18/2021	2	118	59
PLANNED	10/18/2021	1	59	59
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	2	12	6
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	2	12	6
PLANNED	10/18/2021	2	8	4
PLANNED	10/18/2021	1	7	7
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	5	35	7
PLANNED	10/18/2021	10	170	17
PLANNED	10/18/2021	2	10	5
PLANNED	10/18/2021	2	12	6
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	4	16	4
PLANNED	10/18/2021	3	18	6
PLANNED	10/18/2021	1	6	6
PLANNED	10/18/2021	3	459	153
PLANNED	10/18/2021	3	36	12
PLANNED	10/18/2021	2	28	14
PLANNED	10/18/2021	4	120	30
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	2	18	9
PLANNED	10/18/2021	4	40	10
PLANNED	10/18/2021	3	27	9
PLANNED	10/18/2021	17	187	11
PLANNED	10/18/2021	1	10	10
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	2	8	4
PLANNED	10/18/2021	2	16	8
PLANNED	10/18/2021	2	12	6
PLANNED	10/18/2021	2	10	5
PLANNED	10/18/2021	1	129	129
PLANNED	10/18/2021	1	15	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/18/2021	4	524	131
PLANNED	10/18/2021	2	150	75
PLANNED	10/18/2021	3	93	31
PLANNED	10/18/2021	2	64	32
PLANNED	10/18/2021	3	21	7
PLANNED	10/18/2021	4	20	5
CUSTOMER REQUEST	10/18/2021	1	229	229
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	3	9	3
PLANNED	10/18/2021	3	9	3
PLANNED	10/18/2021	2	8	4
PLANNED	10/18/2021	4	24	6
PLANNED	10/18/2021	3	33	11
PLANNED	10/18/2021	4	112	28
PLANNED	10/18/2021	1	13	13
PLANNED	10/18/2021	4	68	17
PLANNED	10/18/2021	2	18	9
PLANNED	10/18/2021	2	56	28
PLANNED	10/18/2021	2	40	20
CUSTOMER REQUEST	10/18/2021	1	818	818
PLANNED	10/18/2021	2	24	12
PLANNED	10/18/2021	15	285	19
PLANNED	10/18/2021	5	35	7
PLANNED	10/18/2021	3	51	17
PLANNED	10/18/2021	3	12	4
PLANNED	10/18/2021	4	20	5
PLANNED	10/18/2021	3	15	5
PLANNED	10/18/2021	1	105	105
PLANNED	10/18/2021	13	3,965	305
PLANNED	10/18/2021	10	1,980	198
CUSTOMER REQUEST	10/18/2021	1	746	746
PLANNED	10/18/2021	2	220	110
PLANNED	10/18/2021	2	272	136
PLANNED	10/18/2021	5	780	156
PLANNED	10/19/2021	6	1,164	194
PLANNED	10/19/2021	2	96	48
PLANNED	10/19/2021	10	1,000	100
PLANNED	10/19/2021	1	78	78
PLANNED	10/19/2021	1	75	75
CUSTOMER REQUEST	10/19/2021	1	876	876
PLANNED	10/19/2021	3	426	142

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	44	44
PLANNED	10/19/2021	3	248	111
PLANNED	10/19/2021	1	76	76
PLANNED	10/19/2021	1	118	118
PLANNED	10/19/2021	3	18	6
PLANNED	10/19/2021	1	36	36
PLANNED	10/19/2021	1	251	251
PLANNED	10/19/2021	1	132	132
PLANNED	10/19/2021	3	375	125
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	95	95
PLANNED	10/19/2021	2	188	94
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	5	998	215
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	82	82
PLANNED	10/19/2021	2	122	61
PLANNED	10/19/2021	1	81	81
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	2	30	15
PLANNED	10/19/2021	2	28	14
PLANNED	10/19/2021	10	210	21
PLANNED	10/19/2021	6	60	10
PLANNED	10/19/2021	2	22	11
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	3	51	17
PLANNED	10/19/2021	4	40	10
PLANNED	10/19/2021	4	316	79
PLANNED	10/19/2021	3	294	98
CUSTOMER REQUEST	10/19/2021	4	1,908	477
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	7	714	102
PLANNED	10/19/2021	2	10	5
PLANNED	10/19/2021	4	92	23
PLANNED	10/19/2021	4	28	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	4	16	4
PLANNED	10/19/2021	2	112	56
PLANNED	10/19/2021	4	288	72
PLANNED	10/19/2021	5	165	33
PLANNED	10/19/2021	2	12	6
PLANNED	10/19/2021	2	250	125
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	143	143
PLANNED	10/19/2021	1	143	143
PLANNED	10/19/2021	2	284	142
PLANNED	10/19/2021	6	978	163
PLANNED	10/19/2021	1	142	142
PLANNED	10/19/2021	1	12	12
PLANNED	10/19/2021	1	142	142
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	5	10	2
PLANNED	10/19/2021	1	11	11
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	5	580	116
PLANNED	10/19/2021	2	12	6
PLANNED	10/19/2021	4	20	5
PLANNED	10/19/2021	2	372	186
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	4	28	7
PLANNED	10/19/2021	12	2,124	177
PLANNED	10/19/2021	11	803	73
PLANNED	10/19/2021	15	2,715	181
PLANNED	10/19/2021	12	804	67
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	12	168	14
PLANNED	10/19/2021	2	20	10
PLANNED	10/19/2021	15	270	18
PLANNED	10/19/2021	1	13	13
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	180	180

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	1	71	71
PLANNED	10/19/2021	1	70	70
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	105	105
PLANNED	10/19/2021	1	104	104
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	104	104
PLANNED	10/19/2021	1	104	104
PLANNED	10/19/2021	2	218	109
PLANNED	10/19/2021	5	725	145
PLANNED	10/19/2021	10	790	275
PLANNED	10/19/2021	3	690	230
PLANNED	10/19/2021	13	182	14
PLANNED	10/19/2021	22	1,386	63
PLANNED	10/19/2021	7	1,232	176
PLANNED	10/19/2021	8	472	59
PLANNED	10/19/2021	4	24	6
PLANNED	10/19/2021	11	594	54
PLANNED	10/19/2021	6	24	4
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	3	186	62
PLANNED	10/19/2021	1	1	1
PLANNED	10/19/2021	3	171	57
PLANNED	10/19/2021	2	134	67
PLANNED	10/19/2021	6	150	25
PLANNED	10/19/2021	7	364	52
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	2	356	178
PLANNED	10/19/2021	1	84	84
PLANNED	10/19/2021	16	4,752	297
PLANNED	10/19/2021	1	193	193
PLANNED	10/19/2021	1	14	14
PLANNED	10/19/2021	9	1,485	165
PLANNED	10/19/2021	5	45	9
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	12	312	26
PLANNED	10/19/2021	7	1,491	213
PLANNED	10/19/2021	4	24	6
PLANNED	10/19/2021	15	990	66

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	10	240	24
PLANNED	10/19/2021	4	20	5
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	3	51	17
PLANNED	10/19/2021	3	21	7
PLANNED	10/19/2021	4	20	5
PLANNED	10/19/2021	4	40	10
PLANNED	10/19/2021	4	28	7
PLANNED	10/19/2021	22	352	16
PLANNED	10/19/2021	5	200	40
PLANNED	10/19/2021	2	128	64
PLANNED	10/19/2021	3	273	91
PLANNED	10/19/2021	2	218	109
PLANNED	10/19/2021	1	43	43
PLANNED	10/19/2021	4	184	46
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	13	403	31
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	3	24	8
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	110	110
PLANNED	10/19/2021	9	810	90
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	59	59
PLANNED	10/19/2021	1	13	13
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	78	78
PLANNED	10/19/2021	1	187	187
PLANNED	10/19/2021	3	15	5
PLANNED	10/19/2021	4	280	70
PLANNED	10/19/2021	1	12	12
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	64	64
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	6	6
CUSTOMER REQUEST	10/19/2021	10	390	39
PLANNED	10/19/2021	6	336	56
PLANNED	10/19/2021	2	138	69
PLANNED	10/19/2021	11	418	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	10/19/2021	2	526	263
PLANNED	10/19/2021	2	28	14
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	8	1,880	235
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	9	414	46
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	14	14
PLANNED	10/19/2021	4	120	30
PLANNED	10/19/2021	9	333	37
PLANNED	10/19/2021	5	30	6
PLANNED	10/19/2021	3	627	209
PLANNED	10/19/2021	4	60	15
PLANNED	10/19/2021	4	16	4
PLANNED	10/19/2021	10	290	29
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	2	20	10
PLANNED	10/19/2021	11	583	53
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	2	26	13
PLANNED	10/19/2021	2	196	98
PLANNED	10/19/2021	2	32	16
PLANNED	10/19/2021	1	18	18
PLANNED	10/19/2021	1	13	13
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	12	12
PLANNED	10/19/2021	1	20	20
PLANNED	10/19/2021	1	24	24
CUSTOMER REQUEST	10/19/2021	12	228	19
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	4	788	197
PLANNED	10/19/2021	4	124	31
PLANNED	10/19/2021	3	111	37
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	4	60	15
PLANNED	10/19/2021	1	63	63
PLANNED	10/19/2021	33	1,980	60
PLANNED	10/19/2021	32	1,728	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	1	35	35
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	49	49
PLANNED	10/19/2021	2	170	85
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	20	20
CUSTOMER REQUEST	10/19/2021	1	340	340
PLANNED	10/19/2021	2	36	18
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	2	8	4
PLANNED	10/19/2021	4	172	43
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	10	1,150	115
PLANNED	10/19/2021	4	276	69
PLANNED	10/19/2021	2	140	70
PLANNED	10/19/2021	6	30	5
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	4	268	67
PLANNED	10/19/2021	4	24	6
PLANNED	10/19/2021	4	48	12
PLANNED	10/19/2021	4	24	6
PLANNED	10/19/2021	3	234	78
PLANNED	10/19/2021	2	184	92
CUSTOMER REQUEST	10/19/2021	4	184	46
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	2	20	10
PLANNED	10/19/2021	2	20	10
PLANNED	10/19/2021	9	333	37
PLANNED	10/19/2021	2	130	65
PLANNED	10/19/2021	2	86	43
PLANNED	10/19/2021	4	172	43
PLANNED	10/19/2021	3	78	26
PLANNED	10/19/2021	3	15	5
PLANNED	10/19/2021	3	18	6
PLANNED	10/19/2021	2	180	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	11	374	34
PLANNED	10/19/2021	2	10	5
PLANNED	10/19/2021	3	18	6
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	3	15	5
PLANNED	10/19/2021	1	27	27
PLANNED	10/19/2021	1	54	54
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	1	188	188
PLANNED	10/19/2021	1	14	14
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	4	300	75
PLANNED	10/19/2021	1	4	4
PLANNED	10/19/2021	1	70	70
PLANNED	10/19/2021	10	380	38
PLANNED	10/19/2021	3	1,011	337
PLANNED	10/19/2021	2	36	18
PLANNED	10/19/2021	2	374	187
PLANNED	10/19/2021	6	306	51
PLANNED	10/19/2021	3	66	22
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	25	25
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	6	36	6
PLANNED	10/19/2021	2	24	12
PLANNED	10/19/2021	4	264	66
PLANNED	10/19/2021	1	14	14
PLANNED	10/19/2021	2	10	5
PLANNED	10/19/2021	1	5	5
PLANNED	10/19/2021	3	18	6
PLANNED	10/19/2021	8	320	40
PLANNED	10/19/2021	2	248	124
PLANNED	10/19/2021	9	387	43
PLANNED	10/19/2021	3	99	33
PLANNED	10/19/2021	2	268	134
PLANNED	10/19/2021	5	815	163

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	4	332	83
PLANNED	10/19/2021	1	48	48
PLANNED	10/19/2021	5	40	8
PLANNED	10/19/2021	3	21	7
PLANNED	10/19/2021	3	195	65
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	4	108	27
PLANNED	10/19/2021	4	28	7
PLANNED	10/19/2021	4	24	6
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	2	64	32
PLANNED	10/19/2021	2	92	46
PLANNED	10/19/2021	12	288	24
PLANNED	10/19/2021	3	216	72
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	2	36	18
PLANNED	10/19/2021	4	36	9
PLANNED	10/19/2021	5	40	8
PLANNED	10/19/2021	2	40	20
PLANNED	10/19/2021	2	288	144
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	7	413	59
PLANNED	10/19/2021	4	84	21
PLANNED	10/19/2021	1	18	18
PLANNED	10/19/2021	6	258	43
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	1	13	13
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	1	7	7
PLANNED	10/19/2021	1	9	9
PLANNED	10/19/2021	3	138	46
PLANNED	10/19/2021	6	426	71
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	4	152	38
PLANNED	10/19/2021	2	64	32
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	3	18	6
PLANNED	10/19/2021	3	21	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	1	57	57
PLANNED	10/19/2021	2	44	22
PLANNED	10/19/2021	2	64	32
PLANNED	10/19/2021	2	24	12
PLANNED	10/19/2021	2	14	7
PLANNED	10/19/2021	6	342	57
PLANNED	10/19/2021	2	292	146
PLANNED	10/19/2021	3	21	7
PLANNED	10/19/2021	1	82	82
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	1	36	36
PLANNED	10/19/2021	2	10	5
PLANNED	10/19/2021	2	18	9
PLANNED	10/19/2021	3	21	7
PLANNED	10/19/2021	1	89	89
PLANNED	10/19/2021	1	15	15
PLANNED	10/19/2021	3	30	10
PLANNED	10/19/2021	2	78	39
CUSTOMER REQUEST	10/19/2021	5	1,195	239
PLANNED	10/19/2021	1	71	71
PLANNED	10/19/2021	1	6	6
PLANNED	10/19/2021	2	16	8
PLANNED	10/19/2021	1	49	49
PLANNED	10/19/2021	1	10	10
PLANNED	10/19/2021	2	114	57
PLANNED	10/19/2021	3	39	13
PLANNED	10/19/2021	4	112	28
PLANNED	10/19/2021	4	32	8
PLANNED	10/19/2021	5	30	6
PLANNED	10/19/2021	1	8	8
PLANNED	10/19/2021	3	78	26
PLANNED	10/19/2021	3	78	26
PLANNED	10/19/2021	2	136	68
PLANNED	10/19/2021	12	1,308	109
PLANNED	10/19/2021	1	165	165
CUSTOMER REQUEST	10/20/2021	204	17,748	87
PLANNED	10/20/2021	1	116	116
CUSTOMER REQUEST	10/20/2021	9	1,278	142
PLANNED	10/20/2021	4	592	148
PLANNED	10/20/2021	1	50	50

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	15	165	11
PLANNED	10/20/2021	9	549	61
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	107	107
PLANNED	10/20/2021	2	276	138
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	9	414	46
PLANNED	10/20/2021	1	98	98
PLANNED	10/20/2021	1	98	98
PLANNED	10/20/2021	12	1,320	110
PLANNED	10/20/2021	1	15	15
PLANNED	10/20/2021	1	97	97
PLANNED	10/20/2021	1	98	98
PLANNED	10/20/2021	2	8	4
PLANNED	10/20/2021	11	1,111	101
PLANNED	10/20/2021	1	13	13
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	18	18
PLANNED	10/20/2021	3	24	8
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	1	86	86
PLANNED	10/20/2021	202	25,250	125
PLANNED	10/20/2021	2	176	88
PLANNED	10/20/2021	81	3,660	160
PLANNED	10/20/2021	51	301	151
PLANNED	10/20/2021	47	141	3
PLANNED	10/20/2021	5	525	105
PLANNED	10/20/2021	61	3,464	144
PLANNED	10/20/2021	9	783	87
PLANNED	10/20/2021	4	96	24
PLANNED	10/20/2021	1	52	52
PLANNED	10/20/2021	1	13	13
PLANNED	10/20/2021	1	135	135
PLANNED	10/20/2021	2	272	136
PLANNED	10/20/2021	1	209	209
PLANNED	10/20/2021	2	272	136
PLANNED	10/20/2021	2	270	135

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	5	245	49
PLANNED	10/20/2021	4	468	117
PLANNED	10/20/2021	5	585	117
PLANNED	10/20/2021	2	44	22
PLANNED	10/20/2021	2	310	155
PLANNED	10/20/2021	2	96	48
PLANNED	10/20/2021	1	68	68
PLANNED	10/20/2021	4	364	91
PLANNED	10/20/2021	1	98	98
PLANNED	10/20/2021	1	12	12
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	2	176	88
PLANNED	10/20/2021	3	54	18
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	6	528	88
PLANNED	10/20/2021	1	8	8
PLANNED	10/20/2021	1	92	92
PLANNED	10/20/2021	2	284	142
PLANNED	10/20/2021	2	286	143
PLANNED	10/20/2021	3	90	30
PLANNED	10/20/2021	2	66	33
PLANNED	10/20/2021	1	11	11
PLANNED	10/20/2021	11	374	34
PLANNED	10/20/2021	5	125	25
PLANNED	10/20/2021	10	230	23
PLANNED	10/20/2021	4	324	81
PLANNED	10/20/2021	6	357	110
PLANNED	10/20/2021	4	148	37
PLANNED	10/20/2021	2	18	9
PLANNED	10/20/2021	6	282	47
PLANNED	10/20/2021	8	328	41
PLANNED	10/20/2021	1	36	36
PLANNED	10/20/2021	8	464	58
PLANNED	10/20/2021	1	8	8
PLANNED	10/20/2021	11	2,684	244
CUSTOMER REQUEST	10/20/2021	1	59	59
PLANNED	10/20/2021	2	124	62
PLANNED	10/20/2021	1	35	35
PLANNED	10/20/2021	5	45	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	1	68	68
PLANNED	10/20/2021	1	11	11
PLANNED	10/20/2021	1	8	8
PLANNED	10/20/2021	29	3,277	113
PLANNED	10/20/2021	7	168	24
PLANNED	10/20/2021	4	84	21
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	6	618	103
PLANNED	10/20/2021	8	384	48
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	6	174	29
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	13	260	20
PLANNED	10/20/2021	3	360	120
CUSTOMER REQUEST	10/20/2021	2	696	353
PLANNED	10/20/2021	3	45	15
PLANNED	10/20/2021	5	125	25
PLANNED	10/20/2021	1	96	96
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	4	144	36
PLANNED	10/20/2021	6	354	59
PLANNED	10/20/2021	2	142	71
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	2	14	7
PLANNED	10/20/2021	2	10	5
PLANNED	10/20/2021	2	14	7
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	1	3	3
PLANNED	10/20/2021	3	24	8
PLANNED	10/20/2021	3	42	14
PLANNED	10/20/2021	8	304	38
PLANNED	10/20/2021	2	30	15
PLANNED	10/20/2021	1	13	13
PLANNED	10/20/2021	2	22	11
PLANNED	10/20/2021	2	30	15
PLANNED	10/20/2021	4	44	11
PLANNED	10/20/2021	4	216	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	3	132	44
PLANNED	10/20/2021	2	62	31
PLANNED	10/20/2021	3	51	17
PLANNED	10/20/2021	3	288	96
CUSTOMER REQUEST	10/20/2021	6	174	29
PLANNED	10/20/2021	2	22	11
PLANNED	10/20/2021	1	13	13
PLANNED	10/20/2021	10	390	39
PLANNED	10/20/2021	1	49	49
PLANNED	10/20/2021	6	462	77
PLANNED	10/20/2021	4	144	36
PLANNED	10/20/2021	1	282	282
PLANNED	10/20/2021	1	9	9
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	1	53	53
PLANNED	10/20/2021	1	97	97
PLANNED	10/20/2021	5	325	65
PLANNED	10/20/2021	5	295	59
PLANNED	10/20/2021	2	42	21
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	6	168	28
PLANNED	10/20/2021	1	11	11
PLANNED	10/20/2021	4	200	50
PLANNED	10/20/2021	3	336	112
PLANNED	10/20/2021	9	189	21
PLANNED	10/20/2021	10	370	37
PLANNED	10/20/2021	42	2,646	63
PLANNED	10/20/2021	2	306	153
PLANNED	10/20/2021	2	202	101
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	2	34	17
PLANNED	10/20/2021	1	10	10
PLANNED	10/20/2021	3	27	9
PLANNED	10/20/2021	1	10	10
PLANNED	10/20/2021	1	8	8
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	2	188	94
PLANNED	10/20/2021	3	411	137
PLANNED	10/20/2021	18	288	16
PLANNED	10/20/2021	2	36	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	4	588	147
PLANNED	10/20/2021	6	1,338	223
PLANNED	10/20/2021	7	826	118
PLANNED	10/20/2021	7	805	115
PLANNED	10/20/2021	2	126	63
PLANNED	10/20/2021	2	22	11
PLANNED	10/20/2021	4	96	24
PLANNED	10/20/2021	1	19	19
PLANNED	10/20/2021	8	56	7
PLANNED	10/20/2021	4	788	197
PLANNED	10/20/2021	3	135	45
PLANNED	10/20/2021	8	1,672	209
PLANNED	10/20/2021	8	984	123
PLANNED	10/20/2021	2	34	17
PLANNED	10/20/2021	7	203	29
PLANNED	10/20/2021	12	1,524	127
PLANNED	10/20/2021	1	11	11
PLANNED	10/20/2021	3	87	29
PLANNED	10/20/2021	12	144	12
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	2	306	153
PLANNED	10/20/2021	3	54	18
PLANNED	10/20/2021	1	4	4
PLANNED	10/20/2021	4	72	18
PLANNED	10/20/2021	1	12	12
PLANNED	10/20/2021	1	10	10
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	7	7
PLANNED	10/20/2021	1	11	11
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	19	475	25
PLANNED	10/20/2021	1	4	4
PLANNED	10/20/2021	3	180	60
PLANNED	10/20/2021	1	8	8
PLANNED	10/20/2021	1	15	15
PLANNED	10/20/2021	5	140	28
PLANNED	10/20/2021	13	559	43
PLANNED	10/20/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/20/2021	1	1	1
PLANNED	10/20/2021	1	22	22
PLANNED	10/20/2021	1	5	5
PLANNED	10/20/2021	1	6	6
PLANNED	10/20/2021	3	681	227
PLANNED	10/20/2021	3	351	117
PLANNED	10/20/2021	2	40	20
PLANNED	10/20/2021	2	94	47
PLANNED	10/20/2021	7	329	47
PLANNED	10/20/2021	8	128	16
PLANNED	10/20/2021	2	156	78
PLANNED	10/20/2021	1	48	48
PLANNED	10/20/2021	5	650	130
PLANNED	10/20/2021	1	66	66
PLANNED	10/20/2021	1	44	44
PLANNED	10/20/2021	1	124	124
CUSTOMER REQUEST	10/20/2021	1	387	387
PLANNED	10/20/2021	6	774	129
PLANNED	10/20/2021	3	210	70
PLANNED	10/20/2021	1	61	61
PLANNED	10/21/2021	1	162	162
PLANNED	10/21/2021	1	54	54
PLANNED	10/21/2021	4	396	99
PLANNED	10/21/2021	2	168	84
PLANNED	10/21/2021	6	474	79
PLANNED	10/21/2021	2	118	59
CUSTOMER REQUEST	10/21/2021	11	3,058	278
PLANNED	10/21/2021	1	190	190
PLANNED	10/21/2021	11	858	78
PLANNED	10/21/2021	4	104	26
PLANNED	10/21/2021	6	1,116	186
PLANNED	10/21/2021	7	133	19
PLANNED	10/21/2021	2	128	64
PLANNED	10/21/2021	7	616	88
PLANNED	10/21/2021	5	130	26
PLANNED	10/21/2021	1	8	8
PLANNED	10/21/2021	8	1,024	128
PLANNED	10/21/2021	23	1,955	85
PLANNED	10/21/2021	1	11	11
PLANNED	10/21/2021	2	74	37
PLANNED	10/21/2021	1	58	58

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/21/2021	3	138	46
PLANNED	10/21/2021	11	66	6
CUSTOMER REQUEST	10/21/2021	1	353	353
PLANNED	10/21/2021	2	20	10
PLANNED	10/21/2021	1	32	32
PLANNED	10/21/2021	8	416	52
PLANNED	10/21/2021	1	9	9
CUSTOMER REQUEST	10/21/2021	10	80	8
PLANNED	10/21/2021	5	435	87
CUSTOMER REQUEST	10/21/2021	12	216	18
PLANNED	10/21/2021	2	98	49
PLANNED	10/21/2021	5	170	34
PLANNED	10/21/2021	5	465	93
PLANNED	10/21/2021	32	6,304	197
CUSTOMER REQUEST	10/21/2021	6	36	6
PLANNED	10/21/2021	2	177	95
PLANNED	10/21/2021	1	34	34
PLANNED	10/21/2021	6	84	14
PLANNED	10/21/2021	1	5	5
PLANNED	10/21/2021	5	735	147
PLANNED	10/21/2021	42	8,988	214
PLANNED	10/21/2021	4	144	36
PLANNED	10/21/2021	12	72	6
PLANNED	10/21/2021	9	288	32
PLANNED	10/21/2021	1	34	34
PLANNED	10/21/2021	2	226	113
PLANNED	10/21/2021	12	1,212	101
PLANNED	10/21/2021	23	6,578	286
PLANNED	10/21/2021	6	522	87
PLANNED	10/21/2021	7	616	88
PLANNED	10/21/2021	1	316	316
PLANNED	10/21/2021	22	7,150	325
PLANNED	10/21/2021	5	660	132
PLANNED	10/21/2021	1	34	34
PLANNED	10/21/2021	1	168	168
CUSTOMER REQUEST	10/21/2021	46	27,186	591
PLANNED	10/21/2021	2	96	48
PLANNED	10/21/2021	1	124	124
PLANNED	10/21/2021	10	100	10
PLANNED	10/21/2021	6	150	25
PLANNED	10/21/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/21/2021	4	956	239
PLANNED	10/21/2021	6	114	19
PLANNED	10/21/2021	30	7,521	271
PLANNED	10/21/2021	6	132	22
CUSTOMER REQUEST	10/21/2021	1	101	101
PLANNED	10/21/2021	2	84	42
PLANNED	10/21/2021	10	370	37
PLANNED	10/21/2021	2	196	98
PLANNED	10/21/2021	1	165	165
PLANNED	10/21/2021	2	128	64
PLANNED	10/21/2021	1	6	6
PLANNED	10/21/2021	5	95	19
PLANNED	10/21/2021	1	25	25
PLANNED	10/21/2021	15	75	5
PLANNED	10/21/2021	4	272	68
PLANNED	10/21/2021	32	1,856	58
PLANNED	10/21/2021	33	1,947	59
PLANNED	10/21/2021	2	254	127
PLANNED	10/21/2021	5	1,647	331
PLANNED	10/21/2021	1	85	85
PLANNED	10/21/2021	1	14	14
PLANNED	10/21/2021	4	284	71
PLANNED	10/21/2021	41	3,772	92
PLANNED	10/21/2021	2	10	5
PLANNED	10/21/2021	6	786	131
PLANNED	10/21/2021	3	36	12
PLANNED	10/21/2021	6	486	81
PLANNED	10/21/2021	4	168	42
PLANNED	10/21/2021	6	288	48
PLANNED	10/21/2021	7	168	24
PLANNED	10/21/2021	1	170	170
PLANNED	10/21/2021	2	66	33
CUSTOMER REQUEST	10/21/2021	25	2,383	247
PLANNED	10/21/2021	8	624	78
PLANNED	10/21/2021	1	6	6
CUSTOMER REQUEST	10/21/2021	1	399	399
PLANNED	10/21/2021	3	147	49
PLANNED	10/21/2021	2	208	104
PLANNED	10/21/2021	4	388	97
PLANNED	10/21/2021	3	18	6
PLANNED	10/21/2021	1	48	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/21/2021	2	146	73
CUSTOMER REQUEST	10/21/2021	2	1,209	1,157
PLANNED	10/21/2021	2	500	250
PLANNED	10/21/2021	12	684	57
PLANNED	10/21/2021	6	624	129
PLANNED	10/21/2021	1	22	22
PLANNED	10/21/2021	4	124	31
PLANNED	10/21/2021	2	248	124
PLANNED	10/21/2021	1	18	18
PLANNED	10/21/2021	1	5	5
CUSTOMER REQUEST	10/21/2021	5	100	20
PLANNED	10/21/2021	11	286	26
PLANNED	10/21/2021	81	14,337	177
PLANNED	10/21/2021	6	396	66
PLANNED	10/21/2021	5	95	19
PLANNED	10/21/2021	8	640	80
CUSTOMER REQUEST	10/21/2021	3	51	17
PLANNED	10/21/2021	8	1,552	194
PLANNED	10/21/2021	1	7	7
PLANNED	10/21/2021	1	8	8
PLANNED	10/21/2021	4	96	24
PLANNED	10/21/2021	7	1,260	180
PLANNED	10/21/2021	1	7	7
PLANNED	10/21/2021	2	70	35
PLANNED	10/21/2021	1	16	16
PLANNED	10/21/2021	3	270	90
PLANNED	10/21/2021	5	320	86
PLANNED	10/21/2021	18	1,098	61
PLANNED	10/21/2021	3	39	13
PLANNED	10/21/2021	4	52	13
PLANNED	10/21/2021	1	6	6
PLANNED	10/21/2021	1	65	65
PLANNED	10/21/2021	3	60	20
PLANNED	10/21/2021	3	15	5
PLANNED	10/21/2021	2	24	12
PLANNED	10/21/2021	5	240	48
CUSTOMER REQUEST	10/21/2021	1	217	217
PLANNED	10/21/2021	1	19	19
PLANNED	10/21/2021	3	69	23
PLANNED	10/21/2021	17	748	44
PLANNED	10/21/2021	3	165	55

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/21/2021	7	175	25
PLANNED	10/21/2021	3	111	37
PLANNED	10/21/2021	1	21	21
PLANNED	10/21/2021	3	174	58
PLANNED	10/21/2021	8	448	56
PLANNED	10/21/2021	3	342	114
PLANNED	10/21/2021	3	414	138
PLANNED	10/21/2021	2	60	30
PLANNED	10/21/2021	1	68	68
PLANNED	10/21/2021	25	275	11
PLANNED	10/21/2021	3	66	22
PLANNED	10/21/2021	6	24	4
PLANNED	10/21/2021	11	176	16
PLANNED	10/21/2021	2	64	32
PLANNED	10/21/2021	3	267	89
PLANNED	10/21/2021	5	15	3
PLANNED	10/21/2021	2	94	47
PLANNED	10/21/2021	4	168	42
PLANNED	10/21/2021	2	172	86
CUSTOMER REQUEST	10/21/2021	9	63	7
PLANNED	10/21/2021	1	51	51
PLANNED	10/21/2021	4	1,508	377
PLANNED	10/21/2021	8	312	39
PLANNED	10/21/2021	5	65	13
PLANNED	10/21/2021	3	396	132
PLANNED	10/21/2021	6	300	50
PLANNED	10/21/2021	7	350	50
PLANNED	10/21/2021	1	206	206
PLANNED	10/21/2021	6	282	47
PLANNED	10/21/2021	1	39	39
PLANNED	10/22/2021	1	53	53
PLANNED	10/22/2021	7	700	100
PLANNED	10/22/2021	1	133	133
PLANNED	10/22/2021	2	88	44
PLANNED	10/22/2021	1	65	65
PLANNED	10/22/2021	3	21	7
PLANNED	10/22/2021	1	232	232
PLANNED	10/22/2021	7	672	96
PLANNED	10/22/2021	5	95	19
PLANNED	10/22/2021	1	174	174
PLANNED	10/22/2021	2	106	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/22/2021	7	154	22
CUSTOMER REQUEST	10/22/2021	6	270	45
PLANNED	10/22/2021	4	36	9
PLANNED	10/22/2021	3	222	74
PLANNED	10/22/2021	1	6	6
PLANNED	10/22/2021	8	1,160	145
PLANNED	10/22/2021	3	24	8
CUSTOMER REQUEST	10/22/2021	17	10,115	595
PLANNED	10/22/2021	1	173	173
PLANNED	10/22/2021	22	1,100	50
PLANNED	10/22/2021	2	4	2
PLANNED	10/22/2021	15	4,230	282
PLANNED	10/22/2021	3	183	61
PLANNED	10/22/2021	6	936	156
PLANNED	10/22/2021	8	1,336	167
PLANNED	10/22/2021	1	4	4
PLANNED	10/22/2021	1	59	59
PLANNED	10/22/2021	2	116	58
PLANNED	10/22/2021	4	636	159
PLANNED	10/22/2021	1	4	4
PLANNED	10/22/2021	7	644	92
PLANNED	10/22/2021	11	2,013	183
CUSTOMER REQUEST	10/22/2021	4	24	6
PLANNED	10/22/2021	1	4	4
PLANNED	10/22/2021	1	100	100
CUSTOMER REQUEST	10/22/2021	1	415	415
PLANNED	10/22/2021	3	33	11
PLANNED	10/22/2021	1	7	7
PLANNED	10/22/2021	1	26	26
PLANNED	10/22/2021	2	138	69
PLANNED	10/22/2021	10	730	73
PLANNED	10/22/2021	2	50	25
PLANNED	10/22/2021	5	275	85
PLANNED	10/22/2021	6	348	58
CUSTOMER REQUEST	10/22/2021	10	430	43
PLANNED	10/22/2021	1	5	5
PLANNED	10/22/2021	3	156	52
CUSTOMER REQUEST	10/22/2021	17	544	32
PLANNED	10/22/2021	4	56	14
PLANNED	10/22/2021	9	378	42
PLANNED	10/22/2021	1	382	382

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/22/2021	4	277	103
PLANNED	10/22/2021	1	24	24
PLANNED	10/22/2021	1	3	3
PLANNED	10/22/2021	15	5,119	345
PLANNED	10/22/2021	2	58	29
PLANNED	10/22/2021	1	4	4
PLANNED	10/22/2021	3	120	40
PLANNED	10/22/2021	1	40	40
PLANNED	10/22/2021	9	513	57
PLANNED	10/22/2021	4	52	13
PLANNED	10/22/2021	1	314	314
PLANNED	10/22/2021	5	340	68
PLANNED	10/22/2021	1	6	6
PLANNED	10/22/2021	3	81	27
PLANNED	10/22/2021	4	72	18
PLANNED	10/22/2021	2	82	41
PLANNED	10/22/2021	4	88	22
PLANNED	10/22/2021	2	10	5
PLANNED	10/22/2021	5	190	38
PLANNED	10/22/2021	3	30	10
CUSTOMER REQUEST	10/22/2021	1	217	217
PLANNED	10/22/2021	1	7	7
CUSTOMER REQUEST	10/22/2021	16	240	15
PLANNED	10/22/2021	7	1,099	157
PLANNED	10/22/2021	1	17	17
CUSTOMER REQUEST	10/22/2021	3	237	79
PLANNED	10/22/2021	6	354	59
PLANNED	10/22/2021	1	10	10
PLANNED	10/22/2021	1	24	24
PLANNED	10/22/2021	1	22	22
PLANNED	10/22/2021	6	282	47
PLANNED	10/22/2021	1	271	271
PLANNED	10/22/2021	4	72	18
PLANNED	10/22/2021	10	4,820	482
PLANNED	10/22/2021	11	5,324	484
PLANNED	10/22/2021	2	304	152
PLANNED	10/22/2021	1	7	7
PLANNED	10/22/2021	2	442	221
PLANNED	10/22/2021	9	405	45
PLANNED	10/22/2021	2	102	51
PLANNED	10/22/2021	5	490	98

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/22/2021	2	12	6
PLANNED	10/22/2021	4	36	9
PLANNED	10/22/2021	2	112	56
CUSTOMER REQUEST	10/22/2021	1	315	315
PLANNED	10/22/2021	5	365	73
PLANNED	10/22/2021	6	306	51
PLANNED	10/22/2021	6	234	39
PLANNED	10/22/2021	6	234	39
PLANNED	10/22/2021	1	13	13
PLANNED	10/22/2021	2	182	91
PLANNED	10/22/2021	1	175	175
CUSTOMER REQUEST	10/22/2021	109	7,412	68
PLANNED	10/22/2021	2	72	36
PLANNED	10/22/2021	3	111	37
PLANNED	10/22/2021	3	54	18
PLANNED	10/22/2021	30	1,710	57
PLANNED	10/22/2021	8	436	97
PLANNED	10/22/2021	9	405	45
PLANNED	10/22/2021	1	24	24
CUSTOMER REQUEST	10/22/2021	8	88	11
PLANNED	10/22/2021	1	16	16
PLANNED	10/22/2021	1	1	1
PLANNED	10/22/2021	5	225	45
PLANNED	10/22/2021	1	95	95
CUSTOMER REQUEST	10/22/2021	1	803	803
CUSTOMER REQUEST	10/22/2021	1	1,112	1,112
CUSTOMER REQUEST	10/22/2021	1	78	78
PLANNED	10/23/2021	3	114	38
PLANNED	10/23/2021	14	2,716	194
PLANNED	10/23/2021	1	202	202
CUSTOMER REQUEST	10/23/2021	198	3,762	19
PLANNED	10/23/2021	10	3,440	344
PLANNED	10/23/2021	3	1,557	519
PLANNED	10/23/2021	5	703	215
PLANNED	10/23/2021	4	96	24
PLANNED	10/23/2021	1	19	19
PLANNED	10/23/2021	3	39	13
PLANNED	10/23/2021	12	720	60
PLANNED	10/23/2021	11	2,541	231
PLANNED	10/23/2021	3	525	175
PLANNED	10/23/2021	1	18	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	10/23/2021	1	202	202
PLANNED	10/23/2021	20	1,484	157
PLANNED	10/23/2021	13	1,417	109
PLANNED	10/24/2021	4	872	218
PLANNED	10/24/2021	6	2,880	480
CUSTOMER REQUEST	10/24/2021	1	58	58
PLANNED	10/24/2021	9	1,431	159
PLANNED	10/24/2021	4	588	147
PLANNED	10/24/2021	1	241	241
PLANNED	10/24/2021	1	101	101
CUSTOMER REQUEST	10/24/2021	33	7,821	237
PLANNED	10/24/2021	7	658	94
PLANNED	10/24/2021	3	399	133
CUSTOMER REQUEST	10/24/2021	1	297	297
PLANNED	10/24/2021	10	1,550	155
PLANNED	10/24/2021	1	149	149
PLANNED	10/25/2021	1	314	314
PLANNED	10/25/2021	3	228	76
PLANNED	10/25/2021	2	186	130
PLANNED	10/25/2021	1	325	325
PLANNED	10/25/2021	5	615	123
PLANNED	10/25/2021	1	241	241
PLANNED	10/25/2021	2	154	77
PLANNED	10/25/2021	4	24	6
PLANNED	10/25/2021	4	84	21
PLANNED	10/25/2021	4	352	88
PLANNED	10/25/2021	2	390	195
PLANNED	10/25/2021	1	95	95
PLANNED	10/25/2021	1	95	95
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	1	94	94
PLANNED	10/25/2021	1	13	13
PLANNED	10/25/2021	2	232	231
PLANNED	10/25/2021	12	1,296	108
PLANNED	10/25/2021	12	1,284	107
PLANNED	10/25/2021	11	154	14
CUSTOMER REQUEST	10/25/2021	33	22,242	674
PLANNED	10/25/2021	8	856	107
PLANNED	10/25/2021	1	21	21
PLANNED	10/25/2021	3	27	9
PLANNED	10/25/2021	2	162	81

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	2	204	102
PLANNED	10/25/2021	4	204	51
PLANNED	10/25/2021	4	148	37
PLANNED	10/25/2021	1	67	67
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	66	66
PLANNED	10/25/2021	1	23	23
PLANNED	10/25/2021	10	100	10
PLANNED	10/25/2021	15	90	6
PLANNED	10/25/2021	2	16	8
CUSTOMER REQUEST	10/25/2021	7	2,128	304
PLANNED	10/25/2021	1	328	328
PLANNED	10/25/2021	2	60	30
PLANNED	10/25/2021	1	43	43
CUSTOMER REQUEST	10/25/2021	1	376	376
PLANNED	10/25/2021	5	90	18
PLANNED	10/25/2021	2	16	8
PLANNED	10/25/2021	5	225	45
PLANNED	10/25/2021	3	84	28
PLANNED	10/25/2021	1	24	24
PLANNED	10/25/2021	2	70	35
PLANNED	10/25/2021	4	220	55
PLANNED	10/25/2021	2	340	170
PLANNED	10/25/2021	6	468	78
PLANNED	10/25/2021	12	516	43
PLANNED	10/25/2021	2	230	115
PLANNED	10/25/2021	1	106	106
PLANNED	10/25/2021	3	117	39
PLANNED	10/25/2021	3	375	125
PLANNED	10/25/2021	1	62	62
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	1	233	233
PLANNED	10/25/2021	15	465	31
CUSTOMER REQUEST	10/25/2021	1	313	313
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	5	800	160
PLANNED	10/25/2021	3	84	28
PLANNED	10/25/2021	4	124	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	14	1,246	89
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	1	680	680
PLANNED	10/25/2021	1	75	75
PLANNED	10/25/2021	2	88	44
PLANNED	10/25/2021	1	21	21
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	46	46
PLANNED	10/25/2021	8	1,952	244
PLANNED	10/25/2021	1	136	136
PLANNED	10/25/2021	3	156	52
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	4	36	9
PLANNED	10/25/2021	3	135	45
PLANNED	10/25/2021	4	180	45
PLANNED	10/25/2021	4	40	10
PLANNED	10/25/2021	4	36	9
PLANNED	10/25/2021	1	8	8
PLANNED	10/25/2021	10	270	27
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	2	158	79
PLANNED	10/25/2021	2	158	79
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	1	5	5
PLANNED	10/25/2021	1	8	8
PLANNED	10/25/2021	11	2,959	269
PLANNED	10/25/2021	4	32	8
PLANNED	10/25/2021	2	298	149
PLANNED	10/25/2021	8	267	69
PLANNED	10/25/2021	3	81	27
PLANNED	10/25/2021	3	186	62
PLANNED	10/25/2021	1	4	4
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	1	8	8
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	1	68	68
PLANNED	10/25/2021	12	804	67
PLANNED	10/25/2021	1	30	30
PLANNED	10/25/2021	4	32	8
PLANNED	10/25/2021	2	8	4
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	3	81	27
PLANNED	10/25/2021	12	1,428	119
PLANNED	10/25/2021	2	116	58
PLANNED	10/25/2021	3	522	174
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	2	100	50
PLANNED	10/25/2021	1	51	51
PLANNED	10/25/2021	2	84	42
PLANNED	10/25/2021	2	122	61
PLANNED	10/25/2021	12	684	57
PLANNED	10/25/2021	9	540	60
PLANNED	10/25/2021	1	75	75
PLANNED	10/25/2021	8	176	22
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	8	8
PLANNED	10/25/2021	2	352	176
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	9	99	11
PLANNED	10/25/2021	9	648	72
PLANNED	10/25/2021	15	120	8
PLANNED	10/25/2021	1	9	9
PLANNED	10/25/2021	3	240	80
PLANNED	10/25/2021	15	390	26
PLANNED	10/25/2021	1	8	8
PLANNED	10/25/2021	3	30	10
PLANNED	10/25/2021	3	261	87
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	6	144	24
PLANNED	10/25/2021	4	40	10
PLANNED	10/25/2021	1	248	248
PLANNED	10/25/2021	5	1,590	318
PLANNED	10/25/2021	15	1,200	80
PLANNED	10/25/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	4	20	5
PLANNED	10/25/2021	2	18	9
PLANNED	10/25/2021	4	96	24
PLANNED	10/25/2021	5	325	65
PLANNED	10/25/2021	3	222	74
PLANNED	10/25/2021	3	48	16
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	2	44	22
PLANNED	10/25/2021	3	24	8
PLANNED	10/25/2021	2	20	10
PLANNED	10/25/2021	3	222	74
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	2	148	74
PLANNED	10/25/2021	1	74	74
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	3	120	40
PLANNED	10/25/2021	1	73	73
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	2	146	73
PLANNED	10/25/2021	1	13	13
PLANNED	10/25/2021	9	945	105
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	1	5	5
PLANNED	10/25/2021	1	5	5
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	1	10	10
PLANNED	10/25/2021	1	10	10
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	2	16	8
PLANNED	10/25/2021	2	206	103
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	11	572	52
PLANNED	10/25/2021	4	572	143
PLANNED	10/25/2021	2	134	67
PLANNED	10/25/2021	8	312	39
PLANNED	10/25/2021	9	468	52
PLANNED	10/25/2021	13	689	53
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	7	259	37
PLANNED	10/25/2021	1	58	58

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	2	278	139
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	5	115	23
PLANNED	10/25/2021	4	60	15
PLANNED	10/25/2021	2	8	4
PLANNED	10/25/2021	2	16	8
PLANNED	10/25/2021	3	18	6
PLANNED	10/25/2021	1	9	9
PLANNED	10/25/2021	6	570	95
PLANNED	10/25/2021	7	406	58
PLANNED	10/25/2021	3	177	59
PLANNED	10/25/2021	1	90	90
PLANNED	10/25/2021	1	44	44
PLANNED	10/25/2021	2	70	35
PLANNED	10/25/2021	4	248	62
PLANNED	10/25/2021	5	315	63
PLANNED	10/25/2021	2	48	24
PLANNED	10/25/2021	1	17	17
PLANNED	10/25/2021	3	84	28
PLANNED	10/25/2021	1	6	6
PLANNED	10/25/2021	3	15	5
PLANNED	10/25/2021	2	38	19
PLANNED	10/25/2021	3	24	8
PLANNED	10/25/2021	3	141	47
PLANNED	10/25/2021	3	117	39
PLANNED	10/25/2021	2	8	4
PLANNED	10/25/2021	2	58	29
PLANNED	10/25/2021	1	4	4
PLANNED	10/25/2021	1	79	79
PLANNED	10/25/2021	2	22	11
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	2	22	11
PLANNED	10/25/2021	1	79	79
PLANNED	10/25/2021	4	356	89
PLANNED	10/25/2021	1	102	102
PLANNED	10/25/2021	1	80	80
PLANNED	10/25/2021	3	27	9
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	2	134	67
PLANNED	10/25/2021	4	320	80
PLANNED	10/25/2021	3	69	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	2	122	61
CUSTOMER REQUEST	10/25/2021	1	164	164
PLANNED	10/25/2021	1	80	80
PLANNED	10/25/2021	4	32	8
PLANNED	10/25/2021	13	336	58
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	1	78	78
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	9	9
PLANNED	10/25/2021	6	1,080	180
PLANNED	10/25/2021	2	38	19
PLANNED	10/25/2021	2	40	20
PLANNED	10/25/2021	2	34	17
PLANNED	10/25/2021	5	1,775	355
PLANNED	10/25/2021	5	120	24
PLANNED	10/25/2021	1	4	4
PLANNED	10/25/2021	2	82	41
PLANNED	10/25/2021	12	1,284	107
PLANNED	10/25/2021	8	920	115
PLANNED	10/25/2021	4	616	154
PLANNED	10/25/2021	4	156	39
PLANNED	10/25/2021	2	126	63
PLANNED	10/25/2021	2	6	3
PLANNED	10/25/2021	2	12	6
PLANNED	10/25/2021	1	9	9
PLANNED	10/25/2021	3	12	4
PLANNED	10/25/2021	4	24	6
PLANNED	10/25/2021	1	56	56
PLANNED	10/25/2021	6	432	72
PLANNED	10/25/2021	2	110	55
PLANNED	10/25/2021	1	7	7
PLANNED	10/25/2021	1	29	29
PLANNED	10/25/2021	1	10	10
PLANNED	10/25/2021	2	34	17
PLANNED	10/25/2021	3	261	87
PLANNED	10/25/2021	1	104	104
PLANNED	10/25/2021	8	468	113
PLANNED	10/25/2021	5	440	88
PLANNED	10/25/2021	1	34	34
PLANNED	10/25/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/25/2021	4	292	73
PLANNED	10/25/2021	4	28	7
PLANNED	10/25/2021	3	15	5
PLANNED	10/25/2021	3	24	8
PLANNED	10/25/2021	1	9	9
PLANNED	10/25/2021	4	416	104
PLANNED	10/25/2021	3	15	5
PLANNED	10/25/2021	2	92	46
PLANNED	10/25/2021	3	18	6
PLANNED	10/25/2021	3	21	7
PLANNED	10/25/2021	4	20	5
PLANNED	10/25/2021	4	296	74
PLANNED	10/25/2021	4	1,472	368
PLANNED	10/25/2021	2	18	9
PLANNED	10/25/2021	6	162	27
PLANNED	10/25/2021	2	10	5
PLANNED	10/25/2021	3	15	5
CUSTOMER REQUEST	10/25/2021	1	106	106
CUSTOMER REQUEST	10/25/2021	1	76	76
PLANNED	10/25/2021	2	14	7
PLANNED	10/25/2021	3	81	27
PLANNED	10/25/2021	2	20	10
PLANNED	10/25/2021	4	32	8
PLANNED	10/25/2021	4	308	77
PLANNED	10/25/2021	1	93	93
PLANNED	10/25/2021	2	36	18
PLANNED	10/25/2021	4	16	4
PLANNED	10/25/2021	4	8	2
PLANNED	10/25/2021	4	148	37
PLANNED	10/25/2021	1	90	90
CUSTOMER REQUEST	10/25/2021	1	47	47
PLANNED	10/25/2021	5	95	19
PLANNED	10/25/2021	4	32	8
PLANNED	10/25/2021	3	15	5
PLANNED	10/25/2021	4	24	6
PLANNED	10/25/2021	8	768	96
PLANNED	10/25/2021	1	105	105
PLANNED	10/25/2021	6	1,152	192
PLANNED	10/25/2021	3	252	84
PLANNED	10/25/2021	1	91	91
PLANNED	10/25/2021	5	540	108

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	10/25/2021	557	8,912	16
CUSTOMER REQUEST	10/25/2021	1	643	643
PLANNED	10/26/2021	2	222	111
PLANNED	10/26/2021	1	251	251
CUSTOMER REQUEST	10/26/2021	8	48	6
PLANNED	10/26/2021	4	728	182
PLANNED	10/26/2021	5	135	27
PLANNED	10/26/2021	1	177	177
PLANNED	10/26/2021	12	684	57
PLANNED	10/26/2021	2	22	11
PLANNED	10/26/2021	4	420	105
PLANNED	10/26/2021	2	728	364
PLANNED	10/26/2021	1	75	75
PLANNED	10/26/2021	4	24	6
PLANNED	10/26/2021	2	176	88
PLANNED	10/26/2021	13	962	74
PLANNED	10/26/2021	4	244	61
PLANNED	10/26/2021	4	28	7
PLANNED	10/26/2021	7	91	13
PLANNED	10/26/2021	1	416	416
PLANNED	10/26/2021	3	270	90
PLANNED	10/26/2021	1	14	14
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	1	90	90
PLANNED	10/26/2021	1	91	91
PLANNED	10/26/2021	7	630	90
PLANNED	10/26/2021	3	51	17
PLANNED	10/26/2021	3	45	15
PLANNED	10/26/2021	4	32	8
PLANNED	10/26/2021	1	43	43
PLANNED	10/26/2021	5	645	129
PLANNED	10/26/2021	3	60	20
PLANNED	10/26/2021	6	498	83
PLANNED	10/26/2021	4	92	23
PLANNED	10/26/2021	3	21	7
PLANNED	10/26/2021	4	164	41
PLANNED	10/26/2021	4	76	19
PLANNED	10/26/2021	4	388	97
PLANNED	10/26/2021	4	1,224	306
PLANNED	10/26/2021	2	308	154
PLANNED	10/26/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	3	24	8
PLANNED	10/26/2021	1	122	122
PLANNED	10/26/2021	2	116	58
PLANNED	10/26/2021	2	20	10
PLANNED	10/26/2021	3	51	17
PLANNED	10/26/2021	3	12	4
PLANNED	10/26/2021	10	370	37
PLANNED	10/26/2021	1	52	52
PLANNED	10/26/2021	1	52	52
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	7	42	6
PLANNED	10/26/2021	1	50	50
PLANNED	10/26/2021	11	88	8
PLANNED	10/26/2021	6	180	30
PLANNED	10/26/2021	1	3	3
PLANNED	10/26/2021	3	39	13
CUSTOMER REQUEST	10/26/2021	10	560	56
PLANNED	10/26/2021	4	424	106
PLANNED	10/26/2021	20	3,460	173
PLANNED	10/26/2021	7	959	137
PLANNED	10/26/2021	8	792	99
PLANNED	10/26/2021	1	278	278
PLANNED	10/26/2021	5	815	163
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	5	155	31
PLANNED	10/26/2021	8	304	38
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	2	356	178
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	13	585	45
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	10	350	35
PLANNED	10/26/2021	4	48	12
PLANNED	10/26/2021	5	35	7
PLANNED	10/26/2021	8	168	21
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	8	72	9
PLANNED	10/26/2021	3	150	50
PLANNED	10/26/2021	3	30	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	3	279	93
PLANNED	10/26/2021	1	11	11
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	4	400	100
PLANNED	10/26/2021	8	472	59
PLANNED	10/26/2021	11	693	63
PLANNED	10/26/2021	7	406	58
PLANNED	10/26/2021	5	40	8
PLANNED	10/26/2021	12	780	65
PLANNED	10/26/2021	2	248	124
PLANNED	10/26/2021	3	33	11
PLANNED	10/26/2021	1	10	10
CUSTOMER REQUEST	10/26/2021	7	210	30
PLANNED	10/26/2021	4	76	19
PLANNED	10/26/2021	3	102	34
PLANNED	10/26/2021	2	66	33
PLANNED	10/26/2021	2	12	6
PLANNED	10/26/2021	1	63	63
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	2	10	5
PLANNED	10/26/2021	2	12	6
PLANNED	10/26/2021	3	27	9
PLANNED	10/26/2021	3	387	129
PLANNED	10/26/2021	1	65	65
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	3	192	64
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	7	637	91
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	3	348	116
PLANNED	10/26/2021	2	212	106
PLANNED	10/26/2021	34	4,352	128
PLANNED	10/26/2021	2	32	16
PLANNED	10/26/2021	4	744	186
PLANNED	10/26/2021	2	288	144
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	94	94
PLANNED	10/26/2021	4	88	22
PLANNED	10/26/2021	1	4	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	8	904	113
PLANNED	10/26/2021	32	6,528	204
CUSTOMER REQUEST	10/26/2021	6	750	125
PLANNED	10/26/2021	2	164	82
PLANNED	10/26/2021	2	20	10
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	4	44	11
PLANNED	10/26/2021	4	64	16
PLANNED	10/26/2021	1	91	91
PLANNED	10/26/2021	4	308	77
PLANNED	10/26/2021	7	371	53
PLANNED	10/26/2021	4	324	81
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	22	22
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	1	17	17
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	2	32	16
PLANNED	10/26/2021	7	182	26
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	3	39	13
PLANNED	10/26/2021	1	23	23
PLANNED	10/26/2021	4	156	39
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	6	1,284	214
PLANNED	10/26/2021	1	75	75
PLANNED	10/26/2021	1	81	81
PLANNED	10/26/2021	8	376	47
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	93	93
PLANNED	10/26/2021	4	24	6
PLANNED	10/26/2021	2	12	6
PLANNED	10/26/2021	2	120	60
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	1	63	63
PLANNED	10/26/2021	10	150	15
PLANNED	10/26/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	2	14	7
PLANNED	10/26/2021	10	800	80
PLANNED	10/26/2021	4	124	31
PLANNED	10/26/2021	1	393	393
PLANNED	10/26/2021	3	21	7
PLANNED	10/26/2021	1	95	95
PLANNED	10/26/2021	3	39	13
PLANNED	10/26/2021	1	95	95
PLANNED	10/26/2021	2	10	5
PLANNED	10/26/2021	2	188	94
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	2	14	7
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	15	375	25
PLANNED	10/26/2021	4	24	6
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	1	121	121
PLANNED	10/26/2021	3	279	93
PLANNED	10/26/2021	1	121	121
PLANNED	10/26/2021	3	15	5
PLANNED	10/26/2021	5	65	13
PLANNED	10/26/2021	4	24	6
PLANNED	10/26/2021	3	72	24
PLANNED	10/26/2021	6	126	21
PLANNED	10/26/2021	7	581	83
PLANNED	10/26/2021	2	12	6
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	4	608	152
PLANNED	10/26/2021	1	68	68
PLANNED	10/26/2021	2	14	7
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	16	16
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	3	228	76
PLANNED	10/26/2021	7	448	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	1	74	74
PLANNED	10/26/2021	2	148	74
PLANNED	10/26/2021	1	11	11
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	74	74
PLANNED	10/26/2021	6	258	43
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	4	60	15
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	12	672	56
PLANNED	10/26/2021	8	400	50
PLANNED	10/26/2021	4	44	11
PLANNED	10/26/2021	3	111	37
PLANNED	10/26/2021	4	4	1
PLANNED	10/26/2021	2	20	10
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	2	12	6
PLANNED	10/26/2021	3	318	106
PLANNED	10/26/2021	2	8	4
PLANNED	10/26/2021	3	78	26
PLANNED	10/26/2021	5	1,650	330
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	3	114	38
PLANNED	10/26/2021	2	38	19
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	4	392	98
PLANNED	10/26/2021	3	264	88
PLANNED	10/26/2021	3	240	80
PLANNED	10/26/2021	1	14	14
PLANNED	10/26/2021	2	28	14
PLANNED	10/26/2021	1	10	10
PLANNED	10/26/2021	3	303	101
PLANNED	10/26/2021	8	336	42
PLANNED	10/26/2021	9	297	33
CUSTOMER REQUEST	10/26/2021	2	90	45
PLANNED	10/26/2021	1	44	44
PLANNED	10/26/2021	1	8	8
PLANNED	10/26/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	3	222	74
PLANNED	10/26/2021	1	4	4
PLANNED	10/26/2021	7	119	17
PLANNED	10/26/2021	1	29	29
PLANNED	10/26/2021	1	85	85
PLANNED	10/26/2021	2	278	139
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	38	38
PLANNED	10/26/2021	5	210	42
PLANNED	10/26/2021	1	19	19
PLANNED	10/26/2021	9	135	15
PLANNED	10/26/2021	1	25	25
PLANNED	10/26/2021	1	14	14
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	2	10	5
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	60	60
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	46	46
PLANNED	10/26/2021	1	23	23
PLANNED	10/26/2021	16	912	57
PLANNED	10/26/2021	1	11	11
CUSTOMER REQUEST	10/26/2021	5	20	4
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	1	60	60
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	15	15
PLANNED	10/26/2021	12	1,236	103
PLANNED	10/26/2021	2	10	5
PLANNED	10/26/2021	14	364	26
PLANNED	10/26/2021	1	11	11
PLANNED	10/26/2021	4	512	128
PLANNED	10/26/2021	3	18	6
PLANNED	10/26/2021	1	12	12
PLANNED	10/26/2021	2	10	5
PLANNED	10/26/2021	7	658	94
PLANNED	10/26/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	4	64	16
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	3	108	36
PLANNED	10/26/2021	2	96	48
PLANNED	10/26/2021	2	16	8
PLANNED	10/26/2021	3	219	73
PLANNED	10/26/2021	4	336	84
PLANNED	10/26/2021	1	61	61
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	2	294	147
PLANNED	10/26/2021	1	77	77
PLANNED	10/26/2021	2	22	11
PLANNED	10/26/2021	8	136	17
PLANNED	10/26/2021	1	4	4
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	10	220	22
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	12	144	12
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	3	9	3
PLANNED	10/26/2021	2	230	115
PLANNED	10/26/2021	4	96	24
PLANNED	10/26/2021	2	40	20
CUSTOMER REQUEST	10/26/2021	5	180	36
PLANNED	10/26/2021	2	18	9
PLANNED	10/26/2021	1	20	20
PLANNED	10/26/2021	2	164	82
PLANNED	10/26/2021	3	12	4
PLANNED	10/26/2021	3	114	38
PLANNED	10/26/2021	8	696	87
PLANNED	10/26/2021	1	2	2
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	1	3	3
PLANNED	10/26/2021	2	96	48
PLANNED	10/26/2021	6	30	5
PLANNED	10/26/2021	2	6	3
PLANNED	10/26/2021	2	36	18
PLANNED	10/26/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/26/2021	1	117	117
PLANNED	10/26/2021	1	5	5
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	4	56	14
PLANNED	10/26/2021	16	272	17
PLANNED	10/26/2021	1	6	6
PLANNED	10/26/2021	24	600	25
PLANNED	10/26/2021	3	42	14
PLANNED	10/26/2021	5	70	14
PLANNED	10/26/2021	3	219	73
PLANNED	10/26/2021	10	170	17
PLANNED	10/26/2021	2	22	11
PLANNED	10/26/2021	2	54	27
PLANNED	10/26/2021	3	30	10
PLANNED	10/26/2021	1	48	48
PLANNED	10/26/2021	4	36	9
PLANNED	10/26/2021	4	80	20
PLANNED	10/26/2021	1	90	90
PLANNED	10/26/2021	1	7	7
PLANNED	10/26/2021	11	495	45
PLANNED	10/26/2021	10	220	22
PLANNED	10/26/2021	1	20	20
CUSTOMER REQUEST	10/26/2021	1	105	105
PLANNED	10/26/2021	12	372	31
PLANNED	10/26/2021	8	48	6
CUSTOMER REQUEST	10/26/2021	1	953	953
PLANNED	10/26/2021	2	100	50
PLANNED	10/26/2021	3	108	36
PLANNED	10/26/2021	6	210	35
PLANNED	10/26/2021	12	324	27
PLANNED	10/26/2021	3	459	153
PLANNED	10/26/2021	6	780	130
PLANNED	10/26/2021	2	410	205
PLANNED	10/26/2021	1	250	250
PLANNED	10/26/2021	1	74	74
PLANNED	10/26/2021	1	140	140
PLANNED	10/26/2021	32	768	24
PLANNED	10/26/2021	1	9	9
PLANNED	10/26/2021	1	130	130
PLANNED	10/26/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	10/26/2021	205	64,780	316
PLANNED	10/27/2021	1	67	67
PLANNED	10/27/2021	2	230	115
PLANNED	10/27/2021	3	372	124
PLANNED	10/27/2021	4	596	149
PLANNED	10/27/2021	4	192	48
PLANNED	10/27/2021	2	428	214
PLANNED	10/27/2021	1	65	65
PLANNED	10/27/2021	1	37	37
PLANNED	10/27/2021	1	77	77
PLANNED	10/27/2021	4	188	47
CUSTOMER REQUEST	10/27/2021	11	52	14
PLANNED	10/27/2021	3	123	41
PLANNED	10/27/2021	1	343	343
PLANNED	10/27/2021	1	117	117
PLANNED	10/27/2021	5	40	8
PLANNED	10/27/2021	2	28	14
PLANNED	10/27/2021	23	276	12
PLANNED	10/27/2021	4	64	16
PLANNED	10/27/2021	2	10	5
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	1	10	10
PLANNED	10/27/2021	1	10	10
PLANNED	10/27/2021	1	14	14
PLANNED	10/27/2021	1	79	79
PLANNED	10/27/2021	4	76	19
PLANNED	10/27/2021	3	264	88
PLANNED	10/27/2021	1	45	45
PLANNED	10/27/2021	4	40	10
PLANNED	10/27/2021	2	14	7
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	51	51
PLANNED	10/27/2021	2	10	5
PLANNED	10/27/2021	2	18	9
PLANNED	10/27/2021	3	60	20
PLANNED	10/27/2021	8	1,608	201
PLANNED	10/27/2021	8	432	54
PLANNED	10/27/2021	1	70	70
PLANNED	10/27/2021	2	16	8
PLANNED	10/27/2021	3	57	19

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	10	1,940	194
PLANNED	10/27/2021	8	944	118
PLANNED	10/27/2021	2	66	33
PLANNED	10/27/2021	1	120	120
CUSTOMER REQUEST	10/27/2021	6	72	12
PLANNED	10/27/2021	2	224	112
PLANNED	10/27/2021	2	698	349
PLANNED	10/27/2021	1	113	113
PLANNED	10/27/2021	11	884	140
PLANNED	10/27/2021	2	18	9
PLANNED	10/27/2021	2	366	183
PLANNED	10/27/2021	2	608	304
PLANNED	10/27/2021	2	6	3
PLANNED	10/27/2021	2	514	257
PLANNED	10/27/2021	5	165	33
PLANNED	10/27/2021	1	11	11
PLANNED	10/27/2021	5	340	68
PLANNED	10/27/2021	7	98	14
PLANNED	10/27/2021	2	174	87
PLANNED	10/27/2021	4	148	37
PLANNED	10/27/2021	3	15	5
PLANNED	10/27/2021	4	548	137
PLANNED	10/27/2021	2	28	14
PLANNED	10/27/2021	5	35	7
PLANNED	10/27/2021	3	21	7
PLANNED	10/27/2021	4	480	120
PLANNED	10/27/2021	9	378	42
PLANNED	10/27/2021	3	12	4
PLANNED	10/27/2021	3	81	27
PLANNED	10/27/2021	1	26	26
CUSTOMER REQUEST	10/27/2021	11	55	5
PLANNED	10/27/2021	4	12	3
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	3	606	202
CUSTOMER REQUEST	10/27/2021	104	34,944	336
PLANNED	10/27/2021	1	104	104
PLANNED	10/27/2021	3	36	12
PLANNED	10/27/2021	3	9	3
PLANNED	10/27/2021	1	22	22
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	2	528	264

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	4	8	2
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	363	363
PLANNED	10/27/2021	9	1,782	198
PLANNED	10/27/2021	2	6	3
PLANNED	10/27/2021	2	190	95
PLANNED	10/27/2021	4	52	13
PLANNED	10/27/2021	4	44	11
CUSTOMER REQUEST	10/27/2021	1	628	628
PLANNED	10/27/2021	1	11	11
PLANNED	10/27/2021	1	2	2
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	4	284	71
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	3	9	3
PLANNED	10/27/2021	11	1,518	138
PLANNED	10/27/2021	2	160	80
PLANNED	10/27/2021	1	195	195
PLANNED	10/27/2021	3	6	2
PLANNED	10/27/2021	12	4,764	397
PLANNED	10/27/2021	1	315	315
PLANNED	10/27/2021	2	16	8
PLANNED	10/27/2021	1	85	85
PLANNED	10/27/2021	2	12	6
PLANNED	10/27/2021	2	16	8
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	1	87	87
PLANNED	10/27/2021	2	198	99
PLANNED	10/27/2021	2	312	156
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	4	116	29
PLANNED	10/27/2021	3	39	13
PLANNED	10/27/2021	3	9	3
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	4	272	68
PLANNED	10/27/2021	14	546	39
PLANNED	10/27/2021	4	20	5
PLANNED	10/27/2021	4	268	67
PLANNED	10/27/2021	1	8	8
PLANNED	10/27/2021	3	222	74
PLANNED	10/27/2021	3	9	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	4	24	6
PLANNED	10/27/2021	4	32	8
PLANNED	10/27/2021	7	833	119
PLANNED	10/27/2021	1	2	2
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	10	860	86
CUSTOMER REQUEST	10/27/2021	9	648	72
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	2	470	235
PLANNED	10/27/2021	4	652	163
PLANNED	10/27/2021	6	324	54
PLANNED	10/27/2021	4	736	184
PLANNED	10/27/2021	3	15	5
CUSTOMER REQUEST	10/27/2021	3	9	3
CUSTOMER REQUEST	10/27/2021	3	300	100
PLANNED	10/27/2021	10	230	23
PLANNED	10/27/2021	6	306	51
CUSTOMER REQUEST	10/27/2021	2	198	99
PLANNED	10/27/2021	1	1	1
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	2	4	2
PLANNED	10/27/2021	4	198	189
PLANNED	10/27/2021	14	980	70
PLANNED	10/27/2021	3	639	213
CUSTOMER REQUEST	10/27/2021	8	456	57
PLANNED	10/27/2021	4	4	1
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	4	568	142
PLANNED	10/27/2021	1	10	10
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	2	4	2
PLANNED	10/27/2021	1	25	25
PLANNED	10/27/2021	6	24	4
PLANNED	10/27/2021	9	3,060	340
CUSTOMER REQUEST	10/27/2021	4	236	59
PLANNED	10/27/2021	5	210	42
PLANNED	10/27/2021	3	27	9
PLANNED	10/27/2021	1	38	38

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	2	18	9
PLANNED	10/27/2021	3	9	3
PLANNED	10/27/2021	5	140	28
PLANNED	10/27/2021	1	25	25
PLANNED	10/27/2021	2	316	158
PLANNED	10/27/2021	3	615	205
PLANNED	10/27/2021	2	6	3
PLANNED	10/27/2021	7	518	74
PLANNED	10/27/2021	6	708	118
PLANNED	10/27/2021	9	675	75
PLANNED	10/27/2021	6	924	154
PLANNED	10/27/2021	2	68	34
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	6	678	113
PLANNED	10/27/2021	9	1,602	178
PLANNED	10/27/2021	1	4	4
PLANNED	10/27/2021	3	24	8
PLANNED	10/27/2021	3	18	6
PLANNED	10/27/2021	4	8	2
PLANNED	10/27/2021	4	28	7
PLANNED	10/27/2021	4	544	136
PLANNED	10/27/2021	3	399	133
PLANNED	10/27/2021	1	10	10
PLANNED	10/27/2021	4	12	3
PLANNED	10/27/2021	4	148	37
PLANNED	10/27/2021	4	32	8
PLANNED	10/27/2021	3	12	4
PLANNED	10/27/2021	2	10	5
PLANNED	10/27/2021	5	360	72
PLANNED	10/27/2021	4	36	9
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	3	9	3
PLANNED	10/27/2021	2	8	4
PLANNED	10/27/2021	26	2,418	93
PLANNED	10/27/2021	1	291	291
PLANNED	10/27/2021	4	12	3
CUSTOMER REQUEST	10/27/2021	1	120	120
PLANNED	10/27/2021	1	4	4
PLANNED	10/27/2021	1	12	12
PLANNED	10/27/2021	1	14	14
PLANNED	10/27/2021	1	11	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	1	73	73
PLANNED	10/27/2021	1	86	86
PLANNED	10/27/2021	1	9	9
CUSTOMER REQUEST	10/27/2021	2	3,536	1,768
PLANNED	10/27/2021	165	5,445	33
PLANNED	10/27/2021	1	157	157
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	2	312	156
PLANNED	10/27/2021	1	156	156
PLANNED	10/27/2021	2	312	156
PLANNED	10/27/2021	2	32	16
PLANNED	10/27/2021	3	213	71
PLANNED	10/27/2021	4	248	62
CUSTOMER REQUEST	10/27/2021	1	115	115
PLANNED	10/27/2021	4	32	8
PLANNED	10/27/2021	3	213	71
PLANNED	10/27/2021	3	102	34
PLANNED	10/27/2021	1	21	21
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	204	204
PLANNED	10/27/2021	10	250	25
PLANNED	10/27/2021	3	201	67
PLANNED	10/27/2021	1	8	8
PLANNED	10/27/2021	2	232	116
PLANNED	10/27/2021	4	320	80
PLANNED	10/27/2021	6	162	27
PLANNED	10/27/2021	6	324	54
PLANNED	10/27/2021	1	10	10
PLANNED	10/27/2021	8	288	36
CUSTOMER REQUEST	10/27/2021	3	81	27
PLANNED	10/27/2021	3	24	8
PLANNED	10/27/2021	4	236	59
PLANNED	10/27/2021	1	20	20
PLANNED	10/27/2021	1	7	7
CUSTOMER REQUEST	10/27/2021	1	134	134
PLANNED	10/27/2021	1	11	11
CUSTOMER REQUEST	10/27/2021	104	11,544	111
PLANNED	10/27/2021	3	414	138
PLANNED	10/27/2021	7	574	82

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	1	115	115
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	2	14	7
PLANNED	10/27/2021	2	136	68
PLANNED	10/27/2021	1	72	72
PLANNED	10/27/2021	5	480	96
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	1	18	18
PLANNED	10/27/2021	1	63	63
PLANNED	10/27/2021	2	148	74
PLANNED	10/27/2021	1	9	9
PLANNED	10/27/2021	7	161	23
PLANNED	10/27/2021	2	12	6
PLANNED	10/27/2021	1	7	7
PLANNED	10/27/2021	1	8	8
PLANNED	10/27/2021	9	1,071	197
PLANNED	10/27/2021	3	261	87
PLANNED	10/27/2021	1	17	17
PLANNED	10/27/2021	2	228	114
PLANNED	10/27/2021	1	12	12
PLANNED	10/27/2021	7	497	71
PLANNED	10/27/2021	3	15	5
PLANNED	10/27/2021	4	16	4
PLANNED	10/27/2021	5	440	88
PLANNED	10/27/2021	4	20	5
PLANNED	10/27/2021	4	144	36
PLANNED	10/27/2021	3	18	6
PLANNED	10/27/2021	1	7	7
CUSTOMER REQUEST	10/27/2021	6	30	5
PLANNED	10/27/2021	2	388	194
PLANNED	10/27/2021	1	369	369
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	1	10	10
CUSTOMER REQUEST	10/27/2021	8	912	114
PLANNED	10/27/2021	10	150	15
PLANNED	10/27/2021	2	244	122
PLANNED	10/27/2021	4	108	27
PLANNED	10/27/2021	4	60	15
PLANNED	10/27/2021	3	132	44
PLANNED	10/27/2021	1	5	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/27/2021	11	660	60
PLANNED	10/27/2021	4	116	29
PLANNED	10/27/2021	1	16	16
PLANNED	10/27/2021	2	150	75
PLANNED	10/27/2021	1	36	36
PLANNED	10/27/2021	1	12	12
PLANNED	10/27/2021	2	144	72
PLANNED	10/27/2021	1	27	27
PLANNED	10/27/2021	1	6	6
PLANNED	10/27/2021	14	14	1
PLANNED	10/27/2021	9	225	25
PLANNED	10/27/2021	1	17	17
PLANNED	10/27/2021	1	5	5
PLANNED	10/27/2021	5	70	14
PLANNED	10/27/2021	2	188	94
PLANNED	10/27/2021	8	128	16
PLANNED	10/27/2021	1	158	158
PLANNED	10/27/2021	1	65	65
PLANNED	10/27/2021	4	100	25
PLANNED	10/27/2021	22	374	17
PLANNED	10/27/2021	1	105	105
PLANNED	10/27/2021	41	4,715	115
PLANNED	10/27/2021	68	18,632	274
PLANNED	10/27/2021	4	312	78
PLANNED	10/27/2021	3	186	62
PLANNED	10/27/2021	1	72	72
PLANNED	10/27/2021	2	328	164
PLANNED	10/27/2021	1	221	221
PLANNED	10/27/2021	10	1,240	124
PLANNED	10/27/2021	4	308	77
PLANNED	10/27/2021	2	102	51
PLANNED	10/27/2021	3	396	132
PLANNED	10/27/2021	1	53	53
PLANNED	10/27/2021	1	163	163
PLANNED	10/28/2021	1	39	39
PLANNED	10/28/2021	2	388	194
PLANNED	10/28/2021	1	45	45
PLANNED	10/28/2021	3	201	67
PLANNED	10/28/2021	2	304	152
PLANNED	10/28/2021	1	131	131
PLANNED	10/28/2021	3	342	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/28/2021	1	64	64
PLANNED	10/28/2021	2	144	72
PLANNED	10/28/2021	3	258	86
PLANNED	10/28/2021	11	1,507	137
PLANNED	10/28/2021	15	885	59
PLANNED	10/28/2021	9	54	6
PLANNED	10/28/2021	11	77	7
PLANNED	10/28/2021	2	168	84
PLANNED	10/28/2021	1	186	186
PLANNED	10/28/2021	9	225	25
PLANNED	10/28/2021	6	864	144
PLANNED	10/28/2021	9	954	106
PLANNED	10/28/2021	8	1,048	131
PLANNED	10/28/2021	13	390	30
PLANNED	10/28/2021	6	24	4
PLANNED	10/28/2021	2	60	30
PLANNED	10/28/2021	3	69	23
PLANNED	10/28/2021	6	816	240
PLANNED	10/28/2021	3	144	48
PLANNED	10/28/2021	3	69	23
PLANNED	10/28/2021	3	306	102
CUSTOMER REQUEST	10/28/2021	10	30	3
PLANNED	10/28/2021	2	538	269
CUSTOMER REQUEST	10/28/2021	1	9	9
PLANNED	10/28/2021	9	198	22
PLANNED	10/28/2021	8	272	34
CUSTOMER REQUEST	10/28/2021	11	187	17
PLANNED	10/28/2021	8	680	85
PLANNED	10/28/2021	2	56	28
PLANNED	10/28/2021	2	86	43
PLANNED	10/28/2021	3	636	212
PLANNED	10/28/2021	2	110	55
PLANNED	10/28/2021	4	80	20
PLANNED	10/28/2021	2	508	254
PLANNED	10/28/2021	2	140	70
PLANNED	10/28/2021	4	664	166
CUSTOMER REQUEST	10/28/2021	10	350	35
PLANNED	10/28/2021	5	75	15
PLANNED	10/28/2021	6	318	53
PLANNED	10/28/2021	2	382	191
PLANNED	10/28/2021	1	318	318

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/28/2021	3	45	15
PLANNED	10/28/2021	1	10	10
PLANNED	10/28/2021	8	2,136	267
PLANNED	10/28/2021	3	147	49
PLANNED	10/28/2021	4	620	155
PLANNED	10/28/2021	4	524	131
PLANNED	10/28/2021	6	144	24
PLANNED	10/28/2021	1	103	103
PLANNED	10/28/2021	6	708	118
PLANNED	10/28/2021	6	768	128
PLANNED	10/28/2021	10	510	51
PLANNED	10/28/2021	1	58	58
PLANNED	10/28/2021	13	221	17
PLANNED	10/28/2021	9	1,045	125
PLANNED	10/28/2021	10	880	88
PLANNED	10/28/2021	1	19	19
PLANNED	10/28/2021	1	57	57
PLANNED	10/28/2021	52	2,704	52
PLANNED	10/28/2021	2	30	15
PLANNED	10/28/2021	52	5,044	97
CUSTOMER REQUEST	10/28/2021	6	84	14
PLANNED	10/28/2021	21	1,680	80
PLANNED	10/28/2021	7	245	35
PLANNED	10/28/2021	6	426	71
PLANNED	10/28/2021	9	774	86
PLANNED	10/28/2021	1	26	26
PLANNED	10/28/2021	2	30	15
PLANNED	10/28/2021	6	396	66
PLANNED	10/28/2021	16	3,761	293
PLANNED	10/28/2021	8	200	25
CUSTOMER REQUEST	10/28/2021	1	281	281
PLANNED	10/28/2021	4	636	159
PLANNED	10/28/2021	4	448	112
PLANNED	10/28/2021	4	56	14
PLANNED	10/28/2021	1	14	14
PLANNED	10/28/2021	1	135	135
PLANNED	10/28/2021	1	28	28
PLANNED	10/28/2021	6	198	33
PLANNED	10/28/2021	3	102	34
PLANNED	10/28/2021	2	12	6
PLANNED	10/28/2021	2	22	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/28/2021	2	30	15
PLANNED	10/28/2021	6	114	19
PLANNED	10/28/2021	2	12	6
PLANNED	10/28/2021	15	1,575	105
CUSTOMER REQUEST	10/28/2021	9	207	23
PLANNED	10/28/2021	12	1,512	126
PLANNED	10/28/2021	8	688	86
PLANNED	10/28/2021	8	1,760	247
PLANNED	10/28/2021	1	8	8
PLANNED	10/28/2021	2	22	11
PLANNED	10/28/2021	18	198	11
CUSTOMER REQUEST	10/28/2021	9	63	7
PLANNED	10/28/2021	21	1,470	70
PLANNED	10/28/2021	4	368	92
PLANNED	10/28/2021	5	115	23
PLANNED	10/28/2021	1	25	25
PLANNED	10/28/2021	15	3,105	207
PLANNED	10/28/2021	6	756	126
PLANNED	10/28/2021	1	216	216
PLANNED	10/28/2021	4	168	42
PLANNED	10/28/2021	2	110	55
PLANNED	10/28/2021	3	99	33
PLANNED	10/28/2021	1	11	11
CUSTOMER REQUEST	10/28/2021	8	296	37
PLANNED	10/28/2021	2	338	169
CUSTOMER REQUEST	10/28/2021	17	4,165	245
PLANNED	10/28/2021	10	690	69
CUSTOMER REQUEST	10/28/2021	9	2,115	235
PLANNED	10/28/2021	6	234	39
PLANNED	10/28/2021	1	12	12
PLANNED	10/28/2021	3	243	81
PLANNED	10/28/2021	1	159	159
PLANNED	10/28/2021	1	15	15
PLANNED	10/28/2021	2	262	131
PLANNED	10/28/2021	4	848	212
PLANNED	10/28/2021	78	2,496	32
PLANNED	10/28/2021	8	624	78
PLANNED	10/28/2021	2	26	13
PLANNED	10/28/2021	4	232	58
PLANNED	10/28/2021	3	141	47
PLANNED	10/28/2021	28	1,428	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/28/2021	13	3,640	280
PLANNED	10/28/2021	1	33	33
PLANNED	10/28/2021	1	18	18
PLANNED	10/28/2021	1	255	255
PLANNED	10/28/2021	1	246	246
PLANNED	10/28/2021	1	132	132
PLANNED	10/29/2021	7	357	51
PLANNED	10/29/2021	1	99	99
PLANNED	10/29/2021	1	83	83
PLANNED	10/29/2021	1	87	87
PLANNED	10/29/2021	3	477	159
PLANNED	10/29/2021	2	224	112
PLANNED	10/29/2021	4	136	34
PLANNED	10/29/2021	2	106	53
PLANNED	10/29/2021	8	1,016	127
PLANNED	10/29/2021	16	1,312	82
PLANNED	10/29/2021	4	352	88
PLANNED	10/29/2021	10	570	57
PLANNED	10/29/2021	2	166	83
PLANNED	10/29/2021	6	582	97
PLANNED	10/29/2021	9	306	34
PLANNED	10/29/2021	3	282	94
PLANNED	10/29/2021	1	96	96
PLANNED	10/29/2021	4	52	13
CUSTOMER REQUEST	10/29/2021	2	236	118
PLANNED	10/29/2021	3	27	9
CUSTOMER REQUEST	10/29/2021	8	72	9
PLANNED	10/29/2021	2	72	36
PLANNED	10/29/2021	1	140	140
PLANNED	10/29/2021	1	61	61
PLANNED	10/29/2021	1	35	35
PLANNED	10/29/2021	2	144	72
PLANNED	10/29/2021	5	170	34
PLANNED	10/29/2021	4	212	53
PLANNED	10/29/2021	5	750	150
PLANNED	10/29/2021	3	48	16
PLANNED	10/29/2021	1	86	86
PLANNED	10/29/2021	11	33	3
PLANNED	10/29/2021	4	168	42
PLANNED	10/29/2021	1	9	9
PLANNED	10/29/2021	2	32	16

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/29/2021	1	76	76
PLANNED	10/29/2021	1	7	7
PLANNED	10/29/2021	1	19	19
PLANNED	10/29/2021	2	26	13
CUSTOMER REQUEST	10/29/2021	51	19,227	377
PLANNED	10/29/2021	28	3,612	129
PLANNED	10/29/2021	18	2,394	133
PLANNED	10/29/2021	4	232	58
PLANNED	10/29/2021	2	36	18
PLANNED	10/29/2021	3	45	15
PLANNED	10/29/2021	4	184	46
CUSTOMER REQUEST	10/29/2021	12	600	50
PLANNED	10/29/2021	3	336	112
PLANNED	10/29/2021	1	21	21
PLANNED	10/29/2021	3	459	153
PLANNED	10/29/2021	6	414	117
PLANNED	10/29/2021	1	8	8
PLANNED	10/29/2021	1	170	170
CUSTOMER REQUEST	10/29/2021	2	222	219
PLANNED	10/29/2021	5	870	174
PLANNED	10/29/2021	3	51	17
CUSTOMER REQUEST	10/29/2021	8	104	13
PLANNED	10/29/2021	1	21	21
PLANNED	10/29/2021	1	36	36
PLANNED	10/29/2021	15	4,320	288
PLANNED	10/29/2021	1	278	278
PLANNED	10/29/2021	1	54	54
PLANNED	10/29/2021	1	5	5
PLANNED	10/29/2021	3	307	145
PLANNED	10/29/2021	1	27	27
PLANNED	10/29/2021	1	10	10
PLANNED	10/29/2021	1	116	116
CUSTOMER REQUEST	10/29/2021	2	435	290
PLANNED	10/29/2021	1	5	5
PLANNED	10/29/2021	1	110	110
PLANNED	10/29/2021	2	14	7
PLANNED	10/29/2021	1	27	27
PLANNED	10/29/2021	2	155	140
PLANNED	10/29/2021	1	10	10
PLANNED	10/29/2021	2	88	44
PLANNED	10/29/2021	5	320	64

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/29/2021	1	17	17
PLANNED	10/29/2021	9	513	57
PLANNED	10/29/2021	2	14	7
PLANNED	10/29/2021	2	12	6
PLANNED	10/29/2021	7	602	86
PLANNED	10/29/2021	1	17	17
PLANNED	10/29/2021	1	83	83
CUSTOMER REQUEST	10/29/2021	2	8	4
PLANNED	10/29/2021	47	188	4
PLANNED	10/29/2021	2	140	70
PLANNED	10/29/2021	3	51	17
PLANNED	10/29/2021	15	465	31
PLANNED	10/29/2021	2	718	359
PLANNED	10/29/2021	3	1,068	356
CUSTOMER REQUEST	10/29/2021	1	37	37
PLANNED	10/29/2021	1	73	73
PLANNED	10/29/2021	3	492	164
PLANNED	10/29/2021	1	105	105
PLANNED	10/29/2021	7	980	140
CUSTOMER REQUEST	10/29/2021	1	210	210
PLANNED	10/29/2021	1	221	221
PLANNED	10/29/2021	3	654	218
PLANNED	10/30/2021	3	693	231
PLANNED	10/30/2021	1	31	31
PLANNED	10/30/2021	6	492	82
PLANNED	10/30/2021	19	1,254	66
PLANNED	10/30/2021	4	420	105
CUSTOMER REQUEST	10/30/2021	1	50	50
PLANNED	10/30/2021	1	337	337
PLANNED	10/30/2021	3	324	108
CUSTOMER REQUEST	10/30/2021	1	242	242
CUSTOMER REQUEST	10/30/2021	7	980	140
PLANNED	10/30/2021	5	586	206
PLANNED	10/30/2021	3	465	155
PLANNED	10/30/2021	8	1,280	160
PLANNED	10/30/2021	6	474	79
PLANNED	10/30/2021	1	12	12
PLANNED	10/30/2021	5	481	143
PLANNED	10/30/2021	2	160	80
PLANNED	10/30/2021	1	300	300
PLANNED	10/30/2021	1	100	100

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	10/30/2021	4	240	60
PLANNED	10/30/2021	1	64	64
PLANNED	10/30/2021	5	235	47
PLANNED	10/30/2021	2	164	82
PLANNED	10/30/2021	2	46	23
PLANNED	10/31/2021	1	76	76
PLANNED	10/31/2021	5	560	112
PLANNED	10/31/2021	17	6,256	368
PLANNED	10/31/2021	3	243	81
PLANNED	10/31/2021	6	48	8
PLANNED	10/31/2021	3	132	44
PLANNED	10/31/2021	1	51	51
PLANNED	10/31/2021	1	79	79
PLANNED	10/31/2021	2	98	49
PLANNED	10/31/2021	2	206	103
PLANNED	10/31/2021	3	600	200
PLANNED	10/31/2021	1	4	4
CUSTOMER REQUEST	11/1/2021	29	116	4
PLANNED	11/1/2021	4	288	72
CUSTOMER REQUEST	11/1/2021	5	35	7
PLANNED	11/1/2021	9	1,494	166
PLANNED	11/1/2021	3	147	49
PLANNED	11/1/2021	3	222	74
CUSTOMER REQUEST	11/1/2021	16	320	20
PLANNED	11/1/2021	2	264	132
CUSTOMER REQUEST	11/1/2021	12	156	13
PLANNED	11/1/2021	2	14	7
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	8	792	99
PLANNED	11/1/2021	6	486	81
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	8	72	9
PLANNED	11/1/2021	2	202	101
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	4	535	157
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	16	576	36
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	2	18	9
PLANNED	11/1/2021	3	36	12
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	4	28	7
PLANNED	11/1/2021	8	752	94
PLANNED	11/1/2021	3	558	186
PLANNED	11/1/2021	1	104	104
PLANNED	11/1/2021	1	14	14
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	1	14	14
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	1	8	8
CUSTOMER REQUEST	11/1/2021	28	2,464	88
PLANNED	11/1/2021	17	816	48
PLANNED	11/1/2021	4	44	11
PLANNED	11/1/2021	1	48	48
PLANNED	11/1/2021	1	20	20
CUSTOMER REQUEST	11/1/2021	6	30	5
PLANNED	11/1/2021	3	27	9
CUSTOMER REQUEST	11/1/2021	9	4,194	466
PLANNED	11/1/2021	2	530	265
CUSTOMER REQUEST	11/1/2021	8	1,328	166
PLANNED	11/1/2021	23	759	33
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	1	2	2
PLANNED	11/1/2021	2	6	3
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	1	116	116
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	1	107	107
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	2	120	60
PLANNED	11/1/2021	6	168	28
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	6	2,142	357
PLANNED	11/1/2021	43	8,600	200
PLANNED	11/1/2021	12	732	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/1/2021	8	40	5
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	1	169	169
PLANNED	11/1/2021	5	25	5
PLANNED	11/1/2021	1	44	44
PLANNED	11/1/2021	4	36	9
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	4	40	10
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	4	552	138
PLANNED	11/1/2021	2	14	7
CUSTOMER REQUEST	11/1/2021	8	168	21
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	34	2,006	59
CUSTOMER REQUEST	11/1/2021	8	584	73
PLANNED	11/1/2021	9	729	81
PLANNED	11/1/2021	6	1,254	209
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	14	1,414	101
PLANNED	11/1/2021	8	808	101
PLANNED	11/1/2021	1	141	141
CUSTOMER REQUEST	11/1/2021	1	15	15
CUSTOMER REQUEST	11/1/2021	14	28	2
CUSTOMER REQUEST	11/1/2021	12	192	16
PLANNED	11/1/2021	2	310	155
PLANNED	11/1/2021	3	510	170
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	3	42	14
CUSTOMER REQUEST	11/1/2021	12	48	4
PLANNED	11/1/2021	3	366	122
PLANNED	11/1/2021	1	73	73
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	3	234	78
PLANNED	11/1/2021	5	315	63
PLANNED	11/1/2021	2	22	11
PLANNED	11/1/2021	1	6	6
CUSTOMER REQUEST	11/1/2021	5	350	70
PLANNED	11/1/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	2	86	43
PLANNED	11/1/2021	12	120	10
PLANNED	11/1/2021	1	13	13
CUSTOMER REQUEST	11/1/2021	7	140	20
PLANNED	11/1/2021	1	3	3
PLANNED	11/1/2021	2	8	4
CUSTOMER REQUEST	11/1/2021	1	3	3
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	4	60	15
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	1	16	16
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	5	120	24
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	9	855	95
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	2	14	7
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	9	225	25
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	1	4	4
CUSTOMER REQUEST	11/1/2021	15	75	5
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	4	92	23
PLANNED	11/1/2021	2	6	3
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	1	17	17
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	7	763	109
CUSTOMER REQUEST	11/1/2021	12	660	55
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	3	591	197
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	2	86	43
PLANNED	11/1/2021	1	21	21
PLANNED	11/1/2021	19	399	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	7	280	40
PLANNED	11/1/2021	24	1,968	82
PLANNED	11/1/2021	5	455	91
PLANNED	11/1/2021	1	22	22
PLANNED	11/1/2021	15	1,474	191
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	1	16	16
PLANNED	11/1/2021	36	2,592	72
PLANNED	11/1/2021	19	1,938	102
PLANNED	11/1/2021	4	60	15
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	43	43
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	4	36	9
PLANNED	11/1/2021	5	25	5
PLANNED	11/1/2021	3	33	11
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	8	40	5
PLANNED	11/1/2021	6	126	21
PLANNED	11/1/2021	4	36	9
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	4	28	7
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	13	949	73
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	2	14	7
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	6	30	5
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	24	24
PLANNED	11/1/2021	2	24	12
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	6	1,428	238
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	2	22	11
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	2	14	7
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	2	220	110
PLANNED	11/1/2021	3	30	10
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	10	10
PLANNED	11/1/2021	40	3,000	75
PLANNED	11/1/2021	1	10	10
PLANNED	11/1/2021	7	49	7
PLANNED	11/1/2021	2	172	86
PLANNED	11/1/2021	2	26	13
PLANNED	11/1/2021	5	190	38
PLANNED	11/1/2021	4	256	64
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	5	545	109
PLANNED	11/1/2021	4	24	6
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	8	128	16
PLANNED	11/1/2021	1	70	70
PLANNED	11/1/2021	5	70	14
CUSTOMER REQUEST	11/1/2021	5	35	7
PLANNED	11/1/2021	16	1,088	68
PLANNED	11/1/2021	11	594	54
PLANNED	11/1/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	1	80	80
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	4	440	110
PLANNED	11/1/2021	2	74	37
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	2	14	7
PLANNED	11/1/2021	1	64	64
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	1	20	20
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	7	56	8
CUSTOMER REQUEST	11/1/2021	9	18	2
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	7	42	6
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	4	412	103
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	4	232	58
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	1	30	30
PLANNED	11/1/2021	7	210	30
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	9	198	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	3	624	208
PLANNED	11/1/2021	8	392	49
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	1	10	10
PLANNED	11/1/2021	3	63	21
PLANNED	11/1/2021	1	3	3
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	14	812	58
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	4	56	14
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	4	52	13
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	3	36	12
PLANNED	11/1/2021	2	6	3
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	2	242	121
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	4	24	6
PLANNED	11/1/2021	2	18	9
PLANNED	11/1/2021	1	15	15
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	2	78	39
PLANNED	11/1/2021	4	520	130
PLANNED	11/1/2021	4	24	6
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	1	4	4
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	5	820	164
PLANNED	11/1/2021	2	30	15
PLANNED	11/1/2021	3	282	94
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	4	12	3
PLANNED	11/1/2021	3	12	4
PLANNED	11/1/2021	1	87	87
PLANNED	11/1/2021	2	18	9
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	10	60	6
PLANNED	11/1/2021	3	642	214
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	13	767	59
PLANNED	11/1/2021	1	5	5
PLANNED	11/1/2021	2	42	21
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	6	186	31
PLANNED	11/1/2021	2	36	18
PLANNED	11/1/2021	15	135	9
PLANNED	11/1/2021	1	199	199
PLANNED	11/1/2021	10	90	9
PLANNED	11/1/2021	1	16	16
PLANNED	11/1/2021	11	99	9
PLANNED	11/1/2021	1	12	12
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	13	192	24
PLANNED	11/1/2021	3	24	8
PLANNED	11/1/2021	8	16	2
PLANNED	11/1/2021	3	39	13
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	1	19	19
PLANNED	11/1/2021	24	3,408	142
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	3	153	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	4	20	5
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	5	20	4
PLANNED	11/1/2021	2	8	4
PLANNED	11/1/2021	3	15	5
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	4	36	9
PLANNED	11/1/2021	2	30	15
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	1	9	9
PLANNED	11/1/2021	2	26	13
PLANNED	11/1/2021	10	500	50
PLANNED	11/1/2021	1	14	14
PLANNED	11/1/2021	4	124	31
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	3	36	12
PLANNED	11/1/2021	12	516	43
PLANNED	11/1/2021	5	65	13
PLANNED	11/1/2021	1	7	7
PLANNED	11/1/2021	3	36	12
PLANNED	11/1/2021	2	16	8
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	1	8	8
PLANNED	11/1/2021	9	162	18
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	1	11	11
PLANNED	11/1/2021	2	18	9
PLANNED	11/1/2021	2	10	5
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	3	21	7
PLANNED	11/1/2021	1	6	6
PLANNED	11/1/2021	3	18	6
PLANNED	11/1/2021	2	56	28
PLANNED	11/1/2021	28	1,092	39
PLANNED	11/1/2021	13	156	12
PLANNED	11/1/2021	5	85	17
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/1/2021	3	27	9
PLANNED	11/1/2021	3	30	10
PLANNED	11/1/2021	2	12	6
PLANNED	11/1/2021	1	35	35
PLANNED	11/1/2021	8	192	24
PLANNED	11/1/2021	8	128	16
PLANNED	11/1/2021	13	3,484	268
PLANNED	11/1/2021	5	955	191
PLANNED	11/1/2021	25	4,600	184
PLANNED	11/1/2021	1	65	65
CUSTOMER REQUEST	11/2/2021	1	226	226
PLANNED	11/2/2021	1	148	148
PLANNED	11/2/2021	1	107	107
PLANNED	11/2/2021	2	180	90
PLANNED	11/2/2021	25	1,275	51
PLANNED	11/2/2021	2	444	222
PLANNED	11/2/2021	1	225	225
PLANNED	11/2/2021	1	104	104
PLANNED	11/2/2021	2	356	178
PLANNED	11/2/2021	5	105	21
PLANNED	11/2/2021	2	160	80
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	5	590	118
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	2	176	88
PLANNED	11/2/2021	1	89	89
PLANNED	11/2/2021	2	8	4
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	42	2,268	54
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	5	20	4
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	2	80	41
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	13	13
PLANNED	11/2/2021	4	440	110
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	2	24	12
PLANNED	11/2/2021	2	104	53

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	3	42	14
PLANNED	11/2/2021	2	20	10
PLANNED	11/2/2021	4	36	9
PLANNED	11/2/2021	3	261	87
PLANNED	11/2/2021	12	960	80
PLANNED	11/2/2021	8	960	120
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	4	32	8
PLANNED	11/2/2021	2	16	8
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	3	30	10
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	12	12
PLANNED	11/2/2021	8	1,392	174
PLANNED	11/2/2021	6	900	150
CUSTOMER REQUEST	11/2/2021	1	74	75
PLANNED	11/2/2021	6	594	99
PLANNED	11/2/2021	4	616	154
PLANNED	11/2/2021	3	207	69
PLANNED	11/2/2021	9	747	83
PLANNED	11/2/2021	1	34	34
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	4	128	32
PLANNED	11/2/2021	8	320	40
PLANNED	11/2/2021	8	384	48
PLANNED	11/2/2021	2	500	250
PLANNED	11/2/2021	2	250	125
PLANNED	11/2/2021	14	728	52
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	1	65	65
PLANNED	11/2/2021	18	4,122	229
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	9	666	74
CUSTOMER REQUEST	11/2/2021	10	100	10
PLANNED	11/2/2021	5	215	43
PLANNED	11/2/2021	3	204	68
PLANNED	11/2/2021	5	430	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/2/2021	237	11,376	48
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	16	16
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	1	11	11
PLANNED	11/2/2021	2	16	8
PLANNED	11/2/2021	1	98	98
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	2	46	23
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	1	30	30
PLANNED	11/2/2021	7	735	105
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	2	130	65
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	22	11
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	96	9,216	96
CUSTOMER REQUEST	11/2/2021	112	276	165
PLANNED	11/2/2021	4	24	6
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	2	22	11
CUSTOMER REQUEST	11/2/2021	2	122	61
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	16	16
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	2	16	8
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	115	61
PLANNED	11/2/2021	2	368	184
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	3	39	13
PLANNED	11/2/2021	2	8	4
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	2	18	9
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	6	570	95
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	3	27	9
PLANNED	11/2/2021	3	27	9
PLANNED	11/2/2021	3	39	13
PLANNED	11/2/2021	2	26	13
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	5	60	12
PLANNED	11/2/2021	1	19	19
PLANNED	11/2/2021	8	320	40
PLANNED	11/2/2021	7	280	40
PLANNED	11/2/2021	4	168	42
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	14	14
CUSTOMER REQUEST	11/2/2021	30	2,690	92
PLANNED	11/2/2021	5	305	61
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	9	27	3
PLANNED	11/2/2021	5	250	50
PLANNED	11/2/2021	4	16	4
PLANNED	11/2/2021	6	450	75
PLANNED	11/2/2021	13	351	27
PLANNED	11/2/2021	17	3,604	212
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	3	9	3
PLANNED	11/2/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	35	35
PLANNED	11/2/2021	4	188	47
PLANNED	11/2/2021	2	34	17
PLANNED	11/2/2021	2	22	11
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	3	192	64
CUSTOMER REQUEST	11/2/2021	8	88	11
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	23	5,129	223
PLANNED	11/2/2021	7	749	107
PLANNED	11/2/2021	13	2,834	218
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	13	13
PLANNED	11/2/2021	2	20	10
PLANNED	11/2/2021	2	8	4
PLANNED	11/2/2021	4	456	114
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	8	552	69
PLANNED	11/2/2021	1	59	59
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	1	75	75
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	1	23	23
PLANNED	11/2/2021	1	178	178
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	18	9
PLANNED	11/2/2021	3	354	118
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	8	112	14
PLANNED	11/2/2021	8	312	39
PLANNED	11/2/2021	4	12	3
PLANNED	11/2/2021	4	20	5
PLANNED	11/2/2021	3	39	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	5	20	4
PLANNED	11/2/2021	10	2,680	268
PLANNED	11/2/2021	4	28	7
PLANNED	11/2/2021	1	51	51
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	3	9	3
PLANNED	11/2/2021	7	371	53
PLANNED	11/2/2021	4	36	9
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	2	264	132
PLANNED	11/2/2021	3	12	4
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	7	42	6
PLANNED	11/2/2021	1	10	10
CUSTOMER REQUEST	11/2/2021	9	36	4
PLANNED	11/2/2021	4	60	15
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	5	105	21
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	134	67
PLANNED	11/2/2021	5	105	21
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	38	19
PLANNED	11/2/2021	18	630	35
PLANNED	11/2/2021	4	12	3
PLANNED	11/2/2021	2	34	17
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	5	30	6
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	3	36	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	29	754	26
PLANNED	11/2/2021	1	3	3
PLANNED	11/2/2021	4	40	10
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	120	60
CUSTOMER REQUEST	11/2/2021	6	1,320	220
PLANNED	11/2/2021	11	2,189	199
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	22	22
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	4	16	4
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	4	12	3
PLANNED	11/2/2021	5	10	2
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	3	18	6
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	7	420	60
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	140	70
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	4	20	5
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	4	16	4
PLANNED	11/2/2021	1	3	3
PLANNED	11/2/2021	1	107	107
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	4	36	9
PLANNED	11/2/2021	2	19	13
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	11	110	10
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	22	176	8
PLANNED	11/2/2021	1	37	37
PLANNED	11/2/2021	8	112	14
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	72	72
PLANNED	11/2/2021	8	808	101
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	6	612	102
CUSTOMER REQUEST	11/2/2021	4	132	33
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	3	27	9
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	3	93	31
PLANNED	11/2/2021	3	168	56
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	10	100	10
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	3	3
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	4	24	6
PLANNED	11/2/2021	4	24	6
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	4	28	7
PLANNED	11/2/2021	1	11	11
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	4	4
CUSTOMER REQUEST	11/2/2021	1	53	53
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	6	300	50
PLANNED	11/2/2021	1	12	12
PLANNED	11/2/2021	4	36	9
PLANNED	11/2/2021	3	285	95
PLANNED	11/2/2021	3	18	6
PLANNED	11/2/2021	2	10	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	6	126	21
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	1	80	80
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	2	10	5
PLANNED	11/2/2021	1	3	3
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	3	36	12
PLANNED	11/2/2021	1	4	4
CUSTOMER REQUEST	11/2/2021	4	112	28
PLANNED	11/2/2021	2	64	32
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	13	1,807	139
PLANNED	11/2/2021	49	98	2
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	20	10
PLANNED	11/2/2021	2	82	41
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	119	119
PLANNED	11/2/2021	4	152	38
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	176	88
PLANNED	11/2/2021	7	119	17
PLANNED	11/2/2021	4	492	123
PLANNED	11/2/2021	3	276	92
PLANNED	11/2/2021	4	32	8
PLANNED	11/2/2021	5	25	5
PLANNED	11/2/2021	2	16	8
PLANNED	11/2/2021	29	261	9
PLANNED	11/2/2021	3	18	6
PLANNED	11/2/2021	4	32	8
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	4	880	220
PLANNED	11/2/2021	5	280	56
CUSTOMER REQUEST	11/2/2021	1	295	295

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	1	18	18
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	2	18	9
PLANNED	11/2/2021	2	18	9
PLANNED	11/2/2021	3	15	5
PLANNED	11/2/2021	1	4	4
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	12	312	26
PLANNED	11/2/2021	2	30	15
PLANNED	11/2/2021	12	528	44
PLANNED	11/2/2021	3	264	88
PLANNED	11/2/2021	47	893	19
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	8	56	7
PLANNED	11/2/2021	2	144	72
PLANNED	11/2/2021	4	12	3
PLANNED	11/2/2021	2	32	16
PLANNED	11/2/2021	3	171	57
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	2	12	6
PLANNED	11/2/2021	1	215	215
PLANNED	11/2/2021	2	8	4
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	5	5
PLANNED	11/2/2021	2	16	8
PLANNED	11/2/2021	3	21	7
PLANNED	11/2/2021	2	14	7
PLANNED	11/2/2021	2	666	333
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	10	110	11
PLANNED	11/2/2021	1	8	8
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	6	270	45
PLANNED	11/2/2021	1	9	9
PLANNED	11/2/2021	3	363	121
PLANNED	11/2/2021	3	1,179	393

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/2/2021	1	10	10
PLANNED	11/2/2021	9	27	3
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	1	13	13
PLANNED	11/2/2021	3	24	8
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	4	120	30
PLANNED	11/2/2021	2	32	16
CUSTOMER REQUEST	11/2/2021	15	90	6
PLANNED	11/2/2021	6	120	20
PLANNED	11/2/2021	1	7	7
PLANNED	11/2/2021	2	12	6
CUSTOMER REQUEST	11/2/2021	1	1,215	1,215
PLANNED	11/2/2021	10	510	51
PLANNED	11/2/2021	47	1,598	34
PLANNED	11/2/2021	5	35	7
PLANNED	11/2/2021	1	6	6
PLANNED	11/2/2021	7	133	19
PLANNED	11/2/2021	2	20	10
PLANNED	11/2/2021	2	84	42
PLANNED	11/2/2021	6	84	14
PLANNED	11/2/2021	4	64	16
PLANNED	11/2/2021	1	23	23
PLANNED	11/2/2021	11	374	34
PLANNED	11/2/2021	11	187	17
PLANNED	11/2/2021	2	142	71
PLANNED	11/2/2021	1	201	201
PLANNED	11/2/2021	1	172	172
PLANNED	11/2/2021	1	16	16
PLANNED	11/2/2021	2	286	143
PLANNED	11/2/2021	1	160	160
PLANNED	11/2/2021	3	429	143
PLANNED	11/2/2021	1	62	62
PLANNED	11/2/2021	15	5,175	345
PLANNED	11/2/2021	2	130	65
PLANNED	11/2/2021	1	446	446
PLANNED	11/2/2021	2	498	249
PLANNED	11/2/2021	7	1,743	249
PLANNED	11/2/2021	14	434	31
PLANNED	11/2/2021	1	78	78
PLANNED	11/3/2021	2	270	135

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	1	134	134
PLANNED	11/3/2021	24	1,440	60
PLANNED	11/3/2021	3	108	36
PLANNED	11/3/2021	1	52	52
PLANNED	11/3/2021	2	176	88
PLANNED	11/3/2021	7	1,162	166
PLANNED	11/3/2021	10	520	52
PLANNED	11/3/2021	1	9	9
PLANNED	11/3/2021	1	8	8
PLANNED	11/3/2021	2	104	52
PLANNED	11/3/2021	32	15,584	487
PLANNED	11/3/2021	2	16	8
PLANNED	11/3/2021	1	11	11
PLANNED	11/3/2021	1	5	5
CUSTOMER REQUEST	11/3/2021	10	2,330	233
PLANNED	11/3/2021	1	8	8
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	1	4	4
PLANNED	11/3/2021	7	1,547	221
PLANNED	11/3/2021	4	32	8
PLANNED	11/3/2021	8	496	62
PLANNED	11/3/2021	1	9	9
PLANNED	11/3/2021	3	207	69
PLANNED	11/3/2021	4	424	106
PLANNED	11/3/2021	3	24	8
PLANNED	11/3/2021	2	262	131
PLANNED	11/3/2021	1	4	4
PLANNED	11/3/2021	1	14	14
PLANNED	11/3/2021	10	1,240	124
PLANNED	11/3/2021	10	1,946	227
PLANNED	11/3/2021	3	21	7
CUSTOMER REQUEST	11/3/2021	2	702	351
PLANNED	11/3/2021	6	342	57
PLANNED	11/3/2021	2	438	219
PLANNED	11/3/2021	11	1,573	143
PLANNED	11/3/2021	8	1,256	157
PLANNED	11/3/2021	12	492	41
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	8	1,032	129
PLANNED	11/3/2021	5	75	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	1	198	198
PLANNED	11/3/2021	1	23	23
PLANNED	11/3/2021	35	4,200	120
PLANNED	11/3/2021	5	55	11
PLANNED	11/3/2021	22	2,464	112
PLANNED	11/3/2021	1	13	13
PLANNED	11/3/2021	1	5	5
PLANNED	11/3/2021	1	4	4
PLANNED	11/3/2021	6	492	82
PLANNED	11/3/2021	1	216	216
CUSTOMER REQUEST	11/3/2021	8	1,880	235
CUSTOMER REQUEST	11/3/2021	36	4,788	133
PLANNED	11/3/2021	8	296	37
PLANNED	11/3/2021	2	122	61
PLANNED	11/3/2021	2	8	4
PLANNED	11/3/2021	7	672	96
CUSTOMER REQUEST	11/3/2021	1	232	232
PLANNED	11/3/2021	7	798	114
PLANNED	11/3/2021	9	1,503	167
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	1	17	17
PLANNED	11/3/2021	1	13	13
PLANNED	11/3/2021	2	24	12
PLANNED	11/3/2021	1	11	11
PLANNED	11/3/2021	1	5	5
PLANNED	11/3/2021	2	118	59
PLANNED	11/3/2021	4	116	29
PLANNED	11/3/2021	16	2,000	125
CUSTOMER REQUEST	11/3/2021	1	71	71
PLANNED	11/3/2021	1	17	17
CUSTOMER REQUEST	11/3/2021	9	63	7
PLANNED	11/3/2021	1	720	720
PLANNED	11/3/2021	2	30	15
PLANNED	11/3/2021	1	5	5
PLANNED	11/3/2021	1	84	84
PLANNED	11/3/2021	5	620	124
PLANNED	11/3/2021	2	106	53
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	4	68	17
PLANNED	11/3/2021	10	200	20

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	2	10	5
PLANNED	11/3/2021	4	420	105
PLANNED	11/3/2021	2	272	136
PLANNED	11/3/2021	1	307	307
PLANNED	11/3/2021	1	152	152
PLANNED	11/3/2021	11	616	56
PLANNED	11/3/2021	1	4	4
PLANNED	11/3/2021	23	1,472	64
PLANNED	11/3/2021	2	260	130
PLANNED	11/3/2021	1	97	97
PLANNED	11/3/2021	1	10	10
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	2	10	5
PLANNED	11/3/2021	3	120	40
PLANNED	11/3/2021	10	530	53
PLANNED	11/3/2021	6	138	55
PLANNED	11/3/2021	1	3	3
CUSTOMER REQUEST	11/3/2021	1	23	23
PLANNED	11/3/2021	1	9	9
PLANNED	11/3/2021	2	14	7
PLANNED	11/3/2021	2	278	139
PLANNED	11/3/2021	105	1,260	12
PLANNED	11/3/2021	1	109	109
PLANNED	11/3/2021	5	340	68
PLANNED	11/3/2021	1	66	66
CUSTOMER REQUEST	11/3/2021	10	320	32
PLANNED	11/3/2021	4	100	25
PLANNED	11/3/2021	8	168	21
PLANNED	11/3/2021	1	5	5
CUSTOMER REQUEST	11/3/2021	2	352	176
PLANNED	11/3/2021	1	103	103
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	4	244	61
PLANNED	11/3/2021	10	120	12
PLANNED	11/3/2021	2	478	239
PLANNED	11/3/2021	1	13	13
PLANNED	11/3/2021	10	1,100	110
PLANNED	11/3/2021	7	441	63
PLANNED	11/3/2021	6	342	57
PLANNED	11/3/2021	6	324	54
PLANNED	11/3/2021	1	7	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	1	6	6
CUSTOMER REQUEST	11/3/2021	1	124	124
PLANNED	11/3/2021	2	264	132
PLANNED	11/3/2021	5	225	45
CUSTOMER REQUEST	11/3/2021	2	6	3
CUSTOMER REQUEST	11/3/2021	1	36	36
PLANNED	11/3/2021	3	381	127
PLANNED	11/3/2021	10	70	7
PLANNED	11/3/2021	2	40	20
PLANNED	11/3/2021	6	6	1
PLANNED	11/3/2021	2	10	5
PLANNED	11/3/2021	2	12	6
PLANNED	11/3/2021	1	8	8
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	1	12	12
PLANNED	11/3/2021	2	208	104
PLANNED	11/3/2021	14	2,982	213
PLANNED	11/3/2021	19	247	13
PLANNED	11/3/2021	2	68	34
PLANNED	11/3/2021	16	1,264	79
PLANNED	11/3/2021	10	240	24
PLANNED	11/3/2021	3	93	31
PLANNED	11/3/2021	2	8	4
PLANNED	11/3/2021	2	139	72
PLANNED	11/3/2021	1	11	11
PLANNED	11/3/2021	10	290	29
PLANNED	11/3/2021	8	32	4
PLANNED	11/3/2021	15	2,475	165
PLANNED	11/3/2021	10	250	25
CUSTOMER REQUEST	11/3/2021	3	30	10
PLANNED	11/3/2021	1	10	10
CUSTOMER REQUEST	11/3/2021	1	304	304
PLANNED	11/3/2021	1	16	16
PLANNED	11/3/2021	1	66	66
PLANNED	11/3/2021	1	112	112
PLANNED	11/3/2021	14	154	11
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	7	91	13
PLANNED	11/3/2021	2	14	7
PLANNED	11/3/2021	1	57	57

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	9	522	58
PLANNED	11/3/2021	15	450	30
PLANNED	11/3/2021	3	42	14
PLANNED	11/3/2021	1	13	13
PLANNED	11/3/2021	8	176	22
PLANNED	11/3/2021	4	448	112
PLANNED	11/3/2021	2	30	15
PLANNED	11/3/2021	1	146	146
PLANNED	11/3/2021	2	10	5
PLANNED	11/3/2021	1	6	6
PLANNED	11/3/2021	4	28	7
PLANNED	11/3/2021	2	20	10
PLANNED	11/3/2021	2	12	6
CUSTOMER REQUEST	11/3/2021	9	279	31
PLANNED	11/3/2021	2	64	32
PLANNED	11/3/2021	2	16	8
PLANNED	11/3/2021	2	364	182
PLANNED	11/3/2021	1	14	14
PLANNED	11/3/2021	6	906	151
PLANNED	11/3/2021	1	9	9
PLANNED	11/3/2021	1	85	85
PLANNED	11/3/2021	4	324	81
PLANNED	11/3/2021	2	70	35
PLANNED	11/3/2021	18	2,052	114
PLANNED	11/3/2021	1	147	147
PLANNED	11/3/2021	1	7	7
PLANNED	11/3/2021	1	43	43
PLANNED	11/3/2021	1	16	16
PLANNED	11/3/2021	2	16	8
PLANNED	11/3/2021	4	76	19
PLANNED	11/3/2021	1	9	9
PLANNED	11/3/2021	2	170	85
PLANNED	11/3/2021	5	165	33
PLANNED	11/3/2021	1	15	15
PLANNED	11/3/2021	5	545	109
CUSTOMER REQUEST	11/3/2021	2	18	9
CUSTOMER REQUEST	11/3/2021	1	3	3
PLANNED	11/3/2021	5	55	11
CUSTOMER REQUEST	11/3/2021	10	980	98
PLANNED	11/3/2021	2	8	4
PLANNED	11/3/2021	1	48	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/3/2021	2	54	27
CUSTOMER REQUEST	11/3/2021	1	392	392
PLANNED	11/3/2021	19	361	19
PLANNED	11/3/2021	1	133	133
PLANNED	11/3/2021	1	212	212
PLANNED	11/3/2021	5	2,035	407
PLANNED	11/3/2021	6	2,454	409
PLANNED	11/3/2021	3	9	3
PLANNED	11/3/2021	3	303	101
PLANNED	11/3/2021	5	835	167
PLANNED	11/3/2021	1	113	113
PLANNED	11/3/2021	1	76	76
PLANNED	11/3/2021	19	3,743	197
PLANNED	11/3/2021	3	459	153
CUSTOMER REQUEST	11/4/2021	279	17,019	61
PLANNED	11/4/2021	1	52	52
PLANNED	11/4/2021	18	3,816	212
CUSTOMER REQUEST	11/4/2021	1	1	1
PLANNED	11/4/2021	1	83	83
CUSTOMER REQUEST	11/4/2021	206	11,330	55
PLANNED	11/4/2021	8	728	91
CUSTOMER REQUEST	11/4/2021	1	102	102
PLANNED	11/4/2021	1	72	72
PLANNED	11/4/2021	1	263	263
PLANNED	11/4/2021	16	304	19
PLANNED	11/4/2021	15	2,895	193
PLANNED	11/4/2021	9	459	51
PLANNED	11/4/2021	7	161	23
PLANNED	11/4/2021	1	81	81
PLANNED	11/4/2021	20	680	34
PLANNED	11/4/2021	1	181	181
PLANNED	11/4/2021	8	1,326	201
PLANNED	11/4/2021	5	170	34
PLANNED	11/4/2021	28	5,124	183
PLANNED	11/4/2021	11	121	11
CUSTOMER REQUEST	11/4/2021	9	72	8
PLANNED	11/4/2021	4	380	95
PLANNED	11/4/2021	1	16	16
CUSTOMER REQUEST	11/4/2021	1	172	172
PLANNED	11/4/2021	8	360	45
PLANNED	11/4/2021	3	429	143

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/4/2021	4	120	30
PLANNED	11/4/2021	8	192	24
CUSTOMER REQUEST	11/4/2021	13	2,132	164
PLANNED	11/4/2021	1	48	48
PLANNED	11/4/2021	1	145	145
PLANNED	11/4/2021	1	23	23
PLANNED	11/4/2021	2	266	133
CUSTOMER REQUEST	11/4/2021	5	20	4
PLANNED	11/4/2021	2	132	66
PLANNED	11/4/2021	5	210	42
PLANNED	11/4/2021	5	515	103
PLANNED	11/4/2021	2	52	26
PLANNED	11/4/2021	1	131	131
PLANNED	11/4/2021	2	114	57
CUSTOMER REQUEST	11/4/2021	86	18,060	210
PLANNED	11/4/2021	7	511	73
PLANNED	11/4/2021	1	6	6
CUSTOMER REQUEST	11/4/2021	12	1,344	112
CUSTOMER REQUEST	11/4/2021	1	189	189
PLANNED	11/4/2021	28	4,200	150
PLANNED	11/4/2021	15	3,450	230
PLANNED	11/4/2021	1	12	12
PLANNED	11/4/2021	1	88	88
PLANNED	11/4/2021	4	568	142
PLANNED	11/4/2021	10	570	57
PLANNED	11/4/2021	109	18,203	167
PLANNED	11/4/2021	7	378	54
CUSTOMER REQUEST	11/4/2021	1	206	206
CUSTOMER REQUEST	11/4/2021	1	274	274
PLANNED	11/4/2021	1	35	35
PLANNED	11/4/2021	2	154	77
CUSTOMER REQUEST	11/4/2021	27	7,344	272
PLANNED	11/4/2021	8	2,728	341
PLANNED	11/4/2021	6	750	125
PLANNED	11/4/2021	1	5	5
PLANNED	11/4/2021	2	114	57
PLANNED	11/4/2021	8	176	22
PLANNED	11/4/2021	1	4	4
PLANNED	11/4/2021	4	296	74
PLANNED	11/4/2021	4	540	135
PLANNED	11/4/2021	7	581	83

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/4/2021	2	242	121
CUSTOMER REQUEST	11/4/2021	12	36	3
PLANNED	11/4/2021	2	244	122
PLANNED	11/4/2021	9	450	50
PLANNED	11/4/2021	20	3,480	174
PLANNED	11/4/2021	40	1,160	29
PLANNED	11/4/2021	8	472	59
PLANNED	11/4/2021	1	5	5
PLANNED	11/4/2021	2	10	5
PLANNED	11/4/2021	1	26	26
PLANNED	11/4/2021	6	144	24
PLANNED	11/4/2021	3	204	68
CUSTOMER REQUEST	11/4/2021	31	31	1
PLANNED	11/4/2021	2	148	74
PLANNED	11/4/2021	25	2,500	100
PLANNED	11/4/2021	12	468	39
PLANNED	11/4/2021	2	550	275
PLANNED	11/4/2021	6	1,002	167
PLANNED	11/4/2021	2	30	15
CUSTOMER REQUEST	11/4/2021	14	28	2
PLANNED	11/4/2021	1	86	86
PLANNED	11/4/2021	11	99	9
PLANNED	11/4/2021	12	252	21
PLANNED	11/4/2021	2	128	64
PLANNED	11/4/2021	13	130	10
PLANNED	11/4/2021	10	600	60
PLANNED	11/4/2021	2	68	34
PLANNED	11/4/2021	2	110	55
PLANNED	11/4/2021	1	68	68
PLANNED	11/4/2021	11	792	72
PLANNED	11/4/2021	7	112	16
PLANNED	11/4/2021	3	102	34
PLANNED	11/4/2021	1	60	60
CUSTOMER REQUEST	11/4/2021	10	90	9
PLANNED	11/4/2021	2	26	13
PLANNED	11/4/2021	1	25	25
PLANNED	11/4/2021	1	5	5
PLANNED	11/4/2021	2	270	135
PLANNED	11/4/2021	4	416	104
PLANNED	11/4/2021	12	2,064	172
PLANNED	11/4/2021	3	45	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/4/2021	11	330	30
PLANNED	11/4/2021	2	26	13
PLANNED	11/4/2021	3	132	44
PLANNED	11/4/2021	4	36	9
PLANNED	11/4/2021	4	332	83
PLANNED	11/4/2021	3	321	107
PLANNED	11/4/2021	2	28	14
PLANNED	11/4/2021	2	366	183
PLANNED	11/4/2021	4	300	75
PLANNED	11/4/2021	7	371	67
PLANNED	11/4/2021	2	108	54
PLANNED	11/4/2021	2	16	8
PLANNED	11/4/2021	2	54	27
PLANNED	11/4/2021	1	5	5
PLANNED	11/4/2021	9	270	30
CUSTOMER REQUEST	11/4/2021	5	20	4
PLANNED	11/4/2021	5	810	162
PLANNED	11/4/2021	2	12	6
PLANNED	11/4/2021	4	184	46
PLANNED	11/4/2021	5	520	104
PLANNED	11/4/2021	2	100	50
PLANNED	11/4/2021	2	12	6
PLANNED	11/4/2021	3	243	81
PLANNED	11/4/2021	2	32	16
PLANNED	11/4/2021	9	36	4
PLANNED	11/4/2021	1	6	6
PLANNED	11/4/2021	2	202	101
PLANNED	11/4/2021	2	10	5
PLANNED	11/4/2021	8	144	18
PLANNED	11/4/2021	2	22	11
PLANNED	11/4/2021	9	459	51
PLANNED	11/4/2021	1	101	101
PLANNED	11/4/2021	1	14	14
PLANNED	11/4/2021	2	112	56
PLANNED	11/4/2021	2	214	107
PLANNED	11/4/2021	4	172	43
PLANNED	11/4/2021	2	594	297
PLANNED	11/4/2021	3	126	42
PLANNED	11/4/2021	8	528	66
CUSTOMER REQUEST	11/4/2021	1	111	111
PLANNED	11/4/2021	1	8	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/4/2021	1	64	64
PLANNED	11/4/2021	3	267	89
PLANNED	11/4/2021	2	514	257
PLANNED	11/4/2021	2	180	90
PLANNED	11/4/2021	3	270	90
PLANNED	11/4/2021	12	2,952	246
PLANNED	11/4/2021	7	1,274	182
PLANNED	11/4/2021	6	1,032	172
PLANNED	11/4/2021	1	171	171
PLANNED	11/4/2021	2	252	126
PLANNED	11/5/2021	7	812	116
PLANNED	11/5/2021	1	70	70
CUSTOMER REQUEST	11/5/2021	1	334	334
PLANNED	11/5/2021	26	6,448	248
CUSTOMER REQUEST	11/5/2021	19	2,432	128
PLANNED	11/5/2021	1	7	7
PLANNED	11/5/2021	14	238	17
PLANNED	11/6/2021	2	370	185
PLANNED	11/6/2021	1	126	126
PLANNED	11/6/2021	1	157	157
PLANNED	11/6/2021	1	293	293
PLANNED	11/6/2021	2	250	125
PLANNED	11/6/2021	1	161	161
PLANNED	11/6/2021	2	248	124
PLANNED	11/6/2021	2	182	91
PLANNED	11/6/2021	7	175	25
PLANNED	11/6/2021	2	128	64
CUSTOMER REQUEST	11/6/2021	1	270	270
PLANNED	11/6/2021	1	99	99
CUSTOMER REQUEST	11/6/2021	1	37	37
PLANNED	11/6/2021	4	360	90
PLANNED	11/6/2021	4	52	13
PLANNED	11/6/2021	1	124	124
PLANNED	11/6/2021	1	47	47
PLANNED	11/6/2021	1	122	122
PLANNED	11/6/2021	3	84	28
CUSTOMER REQUEST	11/6/2021	36	3,564	99
PLANNED	11/7/2021	4	900	225
PLANNED	11/7/2021	1	106	106
PLANNED	11/7/2021	21	756	36
PLANNED	11/7/2021	1	29	29

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/7/2021	1	68	68
PLANNED	11/7/2021	3	516	172
PLANNED	11/7/2021	1	46	46
PLANNED	11/7/2021	14	1,456	104
CUSTOMER REQUEST	11/7/2021	8	2,240	280
PLANNED	11/7/2021	33	594	18
PLANNED	11/8/2021	9	3,600	400
PLANNED	11/8/2021	7	532	76
PLANNED	11/8/2021	7	616	88
PLANNED	11/8/2021	4	472	118
PLANNED	11/8/2021	2	282	141
PLANNED	11/8/2021	4	132	33
PLANNED	11/8/2021	4	132	33
PLANNED	11/8/2021	3	30	10
PLANNED	11/8/2021	7	217	31
PLANNED	11/8/2021	3	66	22
PLANNED	11/8/2021	3	468	156
PLANNED	11/8/2021	3	381	127
PLANNED	11/8/2021	2	12	6
CUSTOMER REQUEST	11/8/2021	1	248	248
PLANNED	11/8/2021	2	482	241
PLANNED	11/8/2021	1	15	15
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	3	9	3
PLANNED	11/8/2021	2	14	7
PLANNED	11/8/2021	2	24	12
PLANNED	11/8/2021	3	24	8
PLANNED	11/8/2021	6	366	61
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	3	21	7
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	1	6	6
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	3	66	22
PLANNED	11/8/2021	1	40	40
PLANNED	11/8/2021	3	66	22

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	3	33	11
PLANNED	11/8/2021	1	122	122
PLANNED	11/8/2021	4	284	71
PLANNED	11/8/2021	9	99	11
PLANNED	11/8/2021	1	18	18
PLANNED	11/8/2021	5	135	27
PLANNED	11/8/2021	2	14	7
PLANNED	11/8/2021	2	18	9
PLANNED	11/8/2021	2	24	12
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	1	8	8
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	4	28	7
PLANNED	11/8/2021	7	105	15
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	2	90	45
PLANNED	11/8/2021	1	17	17
PLANNED	11/8/2021	2	18	9
PLANNED	11/8/2021	1	11	11
PLANNED	11/8/2021	2	200	100
PLANNED	11/8/2021	1	100	100
PLANNED	11/8/2021	4	164	41
PLANNED	11/8/2021	1	8	8
PLANNED	11/8/2021	1	113	113
PLANNED	11/8/2021	11	1,870	170
PLANNED	11/8/2021	19	532	28
PLANNED	11/8/2021	12	1,404	117
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	1	6	6
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	19	1,311	69
PLANNED	11/8/2021	4	388	97
PLANNED	11/8/2021	6	198	33
PLANNED	11/8/2021	1	16	16
PLANNED	11/8/2021	2	14	7
PLANNED	11/8/2021	31	6,634	214
PLANNED	11/8/2021	3	366	122

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	1	72	72
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	3	42	14
CUSTOMER REQUEST	11/8/2021	2	3,510	1,763
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	6	470	121
PLANNED	11/8/2021	12	348	29
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	3	45	15
PLANNED	11/8/2021	5	20	4
PLANNED	11/8/2021	1	3	3
PLANNED	11/8/2021	2	24	12
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	14	756	54
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	4	36	9
PLANNED	11/8/2021	2	28	14
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	3	21	7
PLANNED	11/8/2021	7	735	105
PLANNED	11/8/2021	6	126	21
PLANNED	11/8/2021	3	336	112
PLANNED	11/8/2021	2	248	124
PLANNED	11/8/2021	1	124	124
PLANNED	11/8/2021	1	123	123
PLANNED	11/8/2021	2	248	124
PLANNED	11/8/2021	8	80	10
PLANNED	11/8/2021	1	21	21
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	1	23	23
PLANNED	11/8/2021	4	44	11
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	2	26	13
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	4	2,436	609
PLANNED	11/8/2021	1	13	13
PLANNED	11/8/2021	3	234	78
PLANNED	11/8/2021	4	16	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	3	42	14
PLANNED	11/8/2021	4	88	22
PLANNED	11/8/2021	3	24	8
PLANNED	11/8/2021	1	11	11
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	7	1,057	151
PLANNED	11/8/2021	5	245	49
PLANNED	11/8/2021	2	270	135
PLANNED	11/8/2021	7	602	86
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	3	399	133
PLANNED	11/8/2021	10	1,500	150
PLANNED	11/8/2021	1	4	4
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	2	22	11
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	3	9	3
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	22	11
PLANNED	11/8/2021	3	336	112
PLANNED	11/8/2021	6	2,148	358
PLANNED	11/8/2021	1	260	260
PLANNED	11/8/2021	1	3	3
PLANNED	11/8/2021	3	45	15
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	3	321	107
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	20	10
PLANNED	11/8/2021	2	6	3
PLANNED	11/8/2021	3	9	3
PLANNED	11/8/2021	1	16	16
PLANNED	11/8/2021	10	230	23
PLANNED	11/8/2021	3	39	13
PLANNED	11/8/2021	4	52	13
PLANNED	11/8/2021	4	76	19
PLANNED	11/8/2021	2	138	69
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	3	30	10
PLANNED	11/8/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	1	6	6
PLANNED	11/8/2021	2	134	67
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	34	17
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	2	26	13
PLANNED	11/8/2021	3	30	10
PLANNED	11/8/2021	4	468	117
PLANNED	11/8/2021	2	14	7
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	14	1,064	76
PLANNED	11/8/2021	15	945	63
PLANNED	11/8/2021	3	6	2
CUSTOMER REQUEST	11/8/2021	7	301	43
PLANNED	11/8/2021	5	350	70
PLANNED	11/8/2021	4	252	63
PLANNED	11/8/2021	2	20	10
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	4	12	3
PLANNED	11/8/2021	6	138	23
PLANNED	11/8/2021	3	6	2
PLANNED	11/8/2021	3	72	24
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	6	60	10
PLANNED	11/8/2021	1	26	26
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	8	808	101
PLANNED	11/8/2021	1	8	8
PLANNED	11/8/2021	1	12	12
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	4	8	2
PLANNED	11/8/2021	2	202	101
PLANNED	11/8/2021	3	12	4
PLANNED	11/8/2021	9	63	7
PLANNED	11/8/2021	1	4	4
PLANNED	11/8/2021	3	9	3
PLANNED	11/8/2021	1	4	4
PLANNED	11/8/2021	3	24	8
PLANNED	11/8/2021	1	41	41

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	4	52	13
PLANNED	11/8/2021	2	24	12
PLANNED	11/8/2021	2	16	8
PLANNED	11/8/2021	2	54	27
PLANNED	11/8/2021	2	28	14
PLANNED	11/8/2021	1	19	19
PLANNED	11/8/2021	1	10	10
PLANNED	11/8/2021	5	60	12
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	4	776	194
PLANNED	11/8/2021	1	3	3
PLANNED	11/8/2021	2	4	2
PLANNED	11/8/2021	4	12	3
PLANNED	11/8/2021	1	11	11
PLANNED	11/8/2021	1	138	138
PLANNED	11/8/2021	2	32	16
PLANNED	11/8/2021	1	15	15
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	1	138	138
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	6	132	22
PLANNED	11/8/2021	1	6	6
PLANNED	11/8/2021	3	9	3
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	3	33	11
PLANNED	11/8/2021	2	6	3
PLANNED	11/8/2021	2	100	50
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	3	12	4
PLANNED	11/8/2021	1	212	212
PLANNED	11/8/2021	2	238	119
PLANNED	11/8/2021	2	230	115
PLANNED	11/8/2021	1	9	9
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	11	1,727	157
PLANNED	11/8/2021	2	30	15
PLANNED	11/8/2021	12	336	28
PLANNED	11/8/2021	7	56	8
PLANNED	11/8/2021	1	23	23

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	3	12	4
PLANNED	11/8/2021	1	10	10
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	4	24	6
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	2	12	6
PLANNED	11/8/2021	5	50	10
PLANNED	11/8/2021	4	28	7
PLANNED	11/8/2021	5	20	4
PLANNED	11/8/2021	3	24	8
PLANNED	11/8/2021	40	1,600	40
PLANNED	11/8/2021	10	310	31
PLANNED	11/8/2021	1	6	6
PLANNED	11/8/2021	3	441	147
PLANNED	11/8/2021	12	324	27
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	1	189	189
PLANNED	11/8/2021	4	140	35
PLANNED	11/8/2021	2	28	14
PLANNED	11/8/2021	2	30	15
PLANNED	11/8/2021	2	22	11
PLANNED	11/8/2021	2	20	10
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	3	12	4
PLANNED	11/8/2021	6	24	4
PLANNED	11/8/2021	13	1,547	119
PLANNED	11/8/2021	4	116	29
PLANNED	11/8/2021	4	208	52
PLANNED	11/8/2021	1	5	5
PLANNED	11/8/2021	5	305	61
PLANNED	11/8/2021	2	16	8
PLANNED	11/8/2021	1	4	4
PLANNED	11/8/2021	15	600	40
PLANNED	11/8/2021	2	16	8
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	1	124	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	10	1,020	102
PLANNED	11/8/2021	5	30	6
PLANNED	11/8/2021	1	35	35
PLANNED	11/8/2021	1	12	12
PLANNED	11/8/2021	4	16	4
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	5	370	74
PLANNED	11/8/2021	1	37	37
PLANNED	11/8/2021	2	32	16
PLANNED	11/8/2021	1	24	24
PLANNED	11/8/2021	2	40	20
PLANNED	11/8/2021	10	280	28
PLANNED	11/8/2021	1	9	9
PLANNED	11/8/2021	3	18	6
PLANNED	11/8/2021	3	15	5
PLANNED	11/8/2021	2	34	17
PLANNED	11/8/2021	2	16	8
PLANNED	11/8/2021	1	70	70
PLANNED	11/8/2021	2	96	48
PLANNED	11/8/2021	1	8	8
PLANNED	11/8/2021	3	231	77
PLANNED	11/8/2021	3	81	27
PLANNED	11/8/2021	5	205	41
PLANNED	11/8/2021	4	124	31
PLANNED	11/8/2021	1	13	13
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	4	20	5
PLANNED	11/8/2021	3	6	2
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	4	304	76
PLANNED	11/8/2021	4	396	99
PLANNED	11/8/2021	4	324	81
PLANNED	11/8/2021	6	120	20
PLANNED	11/8/2021	4	56	14
PLANNED	11/8/2021	1	7	7
PLANNED	11/8/2021	3	183	61

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/8/2021	2	8	4
PLANNED	11/8/2021	1	3	3
PLANNED	11/8/2021	2	6	3
PLANNED	11/8/2021	2	10	5
PLANNED	11/8/2021	1	3	3
PLANNED	11/8/2021	1	7	7
CUSTOMER REQUEST	11/8/2021	11	297	27
PLANNED	11/8/2021	6	18	3
PLANNED	11/8/2021	10	630	63
CUSTOMER REQUEST	11/8/2021	1	258	258
CUSTOMER REQUEST	11/8/2021	1	220	220
PLANNED	11/8/2021	89	4,005	45
PLANNED	11/8/2021	1	15	15
PLANNED	11/8/2021	1	52	52
PLANNED	11/8/2021	13	429	33
PLANNED	11/8/2021	8	1,456	182
PLANNED	11/8/2021	1	423	423
PLANNED	11/8/2021	3	531	177
PLANNED	11/8/2021	7	2,352	336
PLANNED	11/8/2021	6	876	146
PLANNED	11/8/2021	1	25	25
PLANNED	11/9/2021	8	1,008	126
PLANNED	11/9/2021	2	204	102
PLANNED	11/9/2021	3	126	42
PLANNED	11/9/2021	2	334	167
PLANNED	11/9/2021	1	3	3
PLANNED	11/9/2021	15	480	32
PLANNED	11/9/2021	1	41	41
PLANNED	11/9/2021	4	52	13
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	1	28	28
PLANNED	11/9/2021	1	204	204
PLANNED	11/9/2021	1	8	8
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	1	71	71
PLANNED	11/9/2021	3	36	12
PLANNED	11/9/2021	2	54	27
PLANNED	11/9/2021	1	99	99
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	1	132	132
PLANNED	11/9/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	29	2,581	89
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	1	13	13
PLANNED	11/9/2021	1	71	71
PLANNED	11/9/2021	2	24	12
PLANNED	11/9/2021	4	100	25
PLANNED	11/9/2021	2	98	49
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	3	12	4
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	1	4	4
PLANNED	11/9/2021	1	14	14
PLANNED	11/9/2021	2	12	6
PLANNED	11/9/2021	4	160	40
PLANNED	11/9/2021	3	147	49
PLANNED	11/9/2021	4	188	47
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	11	319	29
PLANNED	11/9/2021	7	245	35
PLANNED	11/9/2021	1	26	26
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	4	96	24
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	2	156	78
PLANNED	11/9/2021	3	36	12
PLANNED	11/9/2021	1	78	78
PLANNED	11/9/2021	10	110	11
PLANNED	11/9/2021	3	231	77
PLANNED	11/9/2021	2	154	77
PLANNED	11/9/2021	2	198	106
PLANNED	11/9/2021	2	16	8
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	1	9	9
CUSTOMER REQUEST	11/9/2021	63	19,152	304
CUSTOMER REQUEST	11/9/2021	5	85	17
PLANNED	11/9/2021	2	16	8
PLANNED	11/9/2021	2	322	161
PLANNED	11/9/2021	2	170	85
PLANNED	11/9/2021	1	68	68
PLANNED	11/9/2021	1	14	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	10	140	14
PLANNED	11/9/2021	3	99	33
PLANNED	11/9/2021	8	608	76
PLANNED	11/9/2021	1	80	80
CUSTOMER REQUEST	11/9/2021	7	63	9
PLANNED	11/9/2021	3	33	11
PLANNED	11/9/2021	7	546	78
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	1	19	19
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	25	6,375	255
PLANNED	11/9/2021	6	678	188
PLANNED	11/9/2021	5	105	21
PLANNED	11/9/2021	7	2,359	337
PLANNED	11/9/2021	8	160	20
PLANNED	11/9/2021	1	148	148
PLANNED	11/9/2021	2	34	17
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	3	21	7
PLANNED	11/9/2021	3	18	6
PLANNED	11/9/2021	2	16	8
CUSTOMER REQUEST	11/9/2021	8	768	96
PLANNED	11/9/2021	3	234	78
PLANNED	11/9/2021	3	93	31
PLANNED	11/9/2021	1	290	290
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	8	280	35
PLANNED	11/9/2021	10	380	38
PLANNED	11/9/2021	3	21	7
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	2	16	8
PLANNED	11/9/2021	2	124	62
PLANNED	11/9/2021	4	248	62
PLANNED	11/9/2021	3	27	9
PLANNED	11/9/2021	3	30	10
PLANNED	11/9/2021	2	262	131
PLANNED	11/9/2021	2	146	73
CUSTOMER REQUEST	11/9/2021	19	5,187	273
PLANNED	11/9/2021	7	406	58
PLANNED	11/9/2021	4	64	16
CUSTOMER REQUEST	11/9/2021	18	252	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	11	66	6
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	1	3	3
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	2	64	32
PLANNED	11/9/2021	1	4	4
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	1	136	136
CUSTOMER REQUEST	11/9/2021	8	88	11
PLANNED	11/9/2021	2	160	80
PLANNED	11/9/2021	7	672	96
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	3	99	33
PLANNED	11/9/2021	4	512	128
PLANNED	11/9/2021	9	1,773	197
PLANNED	11/9/2021	1	8	8
PLANNED	11/9/2021	2	456	228
PLANNED	11/9/2021	2	32	16
PLANNED	11/9/2021	3	123	41
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	6	66	11
PLANNED	11/9/2021	1	70	70
PLANNED	11/9/2021	2	48	24
PLANNED	11/9/2021	8	848	106
PLANNED	11/9/2021	1	10	10
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	2	124	62
PLANNED	11/9/2021	8	968	121
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	10	900	90
PLANNED	11/9/2021	5	210	42
PLANNED	11/9/2021	2	78	39
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	8	672	84
PLANNED	11/9/2021	2	28	14
PLANNED	11/9/2021	1	15	15
PLANNED	11/9/2021	159	10,653	67
PLANNED	11/9/2021	1	257	257
PLANNED	11/9/2021	1	257	257

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	1	260	260
PLANNED	11/9/2021	1	121	121
PLANNED	11/9/2021	2	12	6
PLANNED	11/9/2021	1	11	11
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	3	81	27
PLANNED	11/9/2021	2	16	8
PLANNED	11/9/2021	2	92	46
PLANNED	11/9/2021	2	14	7
CUSTOMER REQUEST	11/9/2021	11	165	15
PLANNED	11/9/2021	4	60	15
PLANNED	11/9/2021	4	72	18
PLANNED	11/9/2021	2	298	149
PLANNED	11/9/2021	3	9	3
PLANNED	11/9/2021	2	18	9
PLANNED	11/9/2021	2	76	38
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	4	64	16
PLANNED	11/9/2021	2	6	3
PLANNED	11/9/2021	1	191	191
PLANNED	11/9/2021	2	414	207
PLANNED	11/9/2021	4	188	47
PLANNED	11/9/2021	7	252	36
PLANNED	11/9/2021	1	66	66
PLANNED	11/9/2021	1	16	16
PLANNED	11/9/2021	4	92	23
PLANNED	11/9/2021	2	28	14
PLANNED	11/9/2021	3	39	13
PLANNED	11/9/2021	5	50	10
PLANNED	11/9/2021	5	60	12
PLANNED	11/9/2021	1	16	16
PLANNED	11/9/2021	5	80	16
PLANNED	11/9/2021	2	126	63
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	3	15	5
PLANNED	11/9/2021	2	128	64
PLANNED	11/9/2021	4	24	6
PLANNED	11/9/2021	3	228	76
PLANNED	11/9/2021	1	64	64
PLANNED	11/9/2021	3	24	8
PLANNED	11/9/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	7	357	51
PLANNED	11/9/2021	3	93	31
PLANNED	11/9/2021	1	22	22
PLANNED	11/9/2021	3	186	62
PLANNED	11/9/2021	4	32	8
PLANNED	11/9/2021	2	34	17
PLANNED	11/9/2021	4	112	28
PLANNED	11/9/2021	3	24	8
PLANNED	11/9/2021	5	390	78
PLANNED	11/9/2021	3	24	8
PLANNED	11/9/2021	37	14,319	387
PLANNED	11/9/2021	3	48	16
PLANNED	11/9/2021	2	118	59
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	4	44	11
PLANNED	11/9/2021	3	192	64
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	1	50	50
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	2	148	74
PLANNED	11/9/2021	8	88	11
PLANNED	11/9/2021	3	39	13
PLANNED	11/9/2021	3	24	8
PLANNED	11/9/2021	1	3	3
PLANNED	11/9/2021	2	130	65
PLANNED	11/9/2021	4	60	15
PLANNED	11/9/2021	3	60	20
PLANNED	11/9/2021	15	450	30
PLANNED	11/9/2021	1	12	12
PLANNED	11/9/2021	4	32	8
PLANNED	11/9/2021	4	52	13
PLANNED	11/9/2021	2	74	37
PLANNED	11/9/2021	12	5,472	456
PLANNED	11/9/2021	4	116	29
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	2	6	3
PLANNED	11/9/2021	2	28	14
PLANNED	11/9/2021	2	284	142
PLANNED	11/9/2021	1	20	20
PLANNED	11/9/2021	6	198	33
PLANNED	11/9/2021	5	425	85

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	1	246	246
PLANNED	11/9/2021	3	30	10
PLANNED	11/9/2021	6	66	11
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	1	112	112
PLANNED	11/9/2021	1	75	75
PLANNED	11/9/2021	3	27	9
PLANNED	11/9/2021	1	71	71
PLANNED	11/9/2021	1	15	15
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	1	70	70
PLANNED	11/9/2021	4	36	9
PLANNED	11/9/2021	3	339	113
PLANNED	11/9/2021	1	82	82
PLANNED	11/9/2021	9	54	6
PLANNED	11/9/2021	3	258	86
PLANNED	11/9/2021	1	137	137
PLANNED	11/9/2021	3	36	12
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	1	13	13
PLANNED	11/9/2021	8	683	181
PLANNED	11/9/2021	3	90	30
PLANNED	11/9/2021	1	99	99
PLANNED	11/9/2021	3	243	81
PLANNED	11/9/2021	19	798	42
PLANNED	11/9/2021	3	33	11
PLANNED	11/9/2021	8	56	7
PLANNED	11/9/2021	1	181	181
PLANNED	11/9/2021	2	18	9
PLANNED	11/9/2021	4	20	5
PLANNED	11/9/2021	1	52	52
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	7	2,338	334
PLANNED	11/9/2021	7	98	14
PLANNED	11/9/2021	2	30	15
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	11	594	54
PLANNED	11/9/2021	4	48	12
PLANNED	11/9/2021	4	48	12
PLANNED	11/9/2021	4	28	7
PLANNED	11/9/2021	10	940	94

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	2	8	4
PLANNED	11/9/2021	2	20	10
PLANNED	11/9/2021	1	8	8
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	1	3	3
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	1	12	12
PLANNED	11/9/2021	9	711	79
PLANNED	11/9/2021	2	20	10
PLANNED	11/9/2021	6	210	35
PLANNED	11/9/2021	5	270	54
PLANNED	11/9/2021	5	55	11
PLANNED	11/9/2021	4	160	40
PLANNED	11/9/2021	3	27	9
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	6	12	2
PLANNED	11/9/2021	1	82	82
PLANNED	11/9/2021	2	164	82
PLANNED	11/9/2021	7	490	70
PLANNED	11/9/2021	2	132	66
PLANNED	11/9/2021	2	162	81
PLANNED	11/9/2021	4	32	8
PLANNED	11/9/2021	2	12	6
PLANNED	11/9/2021	2	12	6
PLANNED	11/9/2021	3	198	66
PLANNED	11/9/2021	3	42	14
PLANNED	11/9/2021	2	128	64
PLANNED	11/9/2021	3	18	6
PLANNED	11/9/2021	1	10	10
PLANNED	11/9/2021	2	30	15
PLANNED	11/9/2021	3	48	16
PLANNED	11/9/2021	8	600	75
PLANNED	11/9/2021	6	252	42
PLANNED	11/9/2021	4	68	17
PLANNED	11/9/2021	1	13	13
CUSTOMER REQUEST	11/9/2021	18	216	12
PLANNED	11/9/2021	5	470	94
PLANNED	11/9/2021	3	126	42
PLANNED	11/9/2021	2	370	185
PLANNED	11/9/2021	15	180	12
PLANNED	11/9/2021	2	26	13

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	2	14	7
CUSTOMER REQUEST	11/9/2021	2	104	52
PLANNED	11/9/2021	2	80	40
PLANNED	11/9/2021	4	100	25
PLANNED	11/9/2021	1	117	117
PLANNED	11/9/2021	10	640	64
PLANNED	11/9/2021	3	354	118
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	5	50	10
PLANNED	11/9/2021	6	108	18
PLANNED	11/9/2021	1	18	18
PLANNED	11/9/2021	1	9	9
PLANNED	11/9/2021	1	8	8
PLANNED	11/9/2021	2	272	136
PLANNED	11/9/2021	2	156	78
PLANNED	11/9/2021	3	156	52
PLANNED	11/9/2021	4	128	32
PLANNED	11/9/2021	1	5	5
PLANNED	11/9/2021	3	42	14
PLANNED	11/9/2021	2	74	37
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	3	18	6
PLANNED	11/9/2021	1	47	47
PLANNED	11/9/2021	17	561	33
PLANNED	11/9/2021	1	97	97
PLANNED	11/9/2021	12	336	28
PLANNED	11/9/2021	1	1	1
PLANNED	11/9/2021	2	22	11
PLANNED	11/9/2021	25	375	15
PLANNED	11/9/2021	2	284	142
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	5	95	19
PLANNED	11/9/2021	3	36	12
PLANNED	11/9/2021	2	14	7
PLANNED	11/9/2021	2	178	89
PLANNED	11/9/2021	3	45	15
PLANNED	11/9/2021	4	348	87
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	3	114	38
PLANNED	11/9/2021	3	192	64
PLANNED	11/9/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	3	324	108
PLANNED	11/9/2021	3	66	22
PLANNED	11/9/2021	1	13	13
PLANNED	11/9/2021	8	320	40
PLANNED	11/9/2021	3	39	13
CUSTOMER REQUEST	11/9/2021	1	34	34
PLANNED	11/9/2021	6	702	117
PLANNED	11/9/2021	1	22	22
PLANNED	11/9/2021	10	340	34
PLANNED	11/9/2021	1	11	11
PLANNED	11/9/2021	1	11	11
PLANNED	11/9/2021	2	196	98
PLANNED	11/9/2021	3	27	9
CUSTOMER REQUEST	11/9/2021	7	84	12
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	2	30	15
PLANNED	11/9/2021	6	540	90
PLANNED	11/9/2021	4	36	9
PLANNED	11/9/2021	10	240	24
PLANNED	11/9/2021	2	140	70
PLANNED	11/9/2021	4	84	21
CUSTOMER REQUEST	11/9/2021	8	152	19
PLANNED	11/9/2021	3	24	8
PLANNED	11/9/2021	1	35	35
PLANNED	11/9/2021	9	108	12
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	12	564	47
PLANNED	11/9/2021	4	392	98
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	2	98	49
PLANNED	11/9/2021	1	13	13
PLANNED	11/9/2021	3	42	14
PLANNED	11/9/2021	6	180	30
PLANNED	11/9/2021	2	10	5
PLANNED	11/9/2021	3	33	11
PLANNED	11/9/2021	2	38	19
PLANNED	11/9/2021	3	261	87
PLANNED	11/9/2021	4	392	98
PLANNED	11/9/2021	3	102	34
PLANNED	11/9/2021	37	999	27
PLANNED	11/9/2021	4	28	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/9/2021	1	8	8
PLANNED	11/9/2021	6	678	147
CUSTOMER REQUEST	11/9/2021	1	217	217
PLANNED	11/9/2021	4	16	4
PLANNED	11/9/2021	3	48	16
PLANNED	11/9/2021	1	6	6
PLANNED	11/9/2021	5	255	51
PLANNED	11/9/2021	4	24	6
PLANNED	11/9/2021	1	4	4
PLANNED	11/9/2021	1	7	7
PLANNED	11/9/2021	1	93	93
PLANNED	11/9/2021	2	56	28
PLANNED	11/9/2021	1	20	20
PLANNED	11/9/2021	4	44	11
PLANNED	11/9/2021	2	16	8
PLANNED	11/9/2021	2	18	9
PLANNED	11/9/2021	1	25	25
PLANNED	11/9/2021	6	78	13
PLANNED	11/9/2021	1	15	15
PLANNED	11/9/2021	2	20	10
PLANNED	11/9/2021	1	29	29
PLANNED	11/9/2021	4	228	57
PLANNED	11/9/2021	1	66	66
PLANNED	11/9/2021	7	392	56
PLANNED	11/9/2021	1	479	479
PLANNED	11/9/2021	9	2,007	223
PLANNED	11/9/2021	1	30	30
PLANNED	11/9/2021	1	229	229
PLANNED	11/10/2021	10	500	50
PLANNED	11/10/2021	1	94	94
PLANNED	11/10/2021	1	84	84
PLANNED	11/10/2021	1	75	75
PLANNED	11/10/2021	1	75	75
PLANNED	11/10/2021	3	228	76
PLANNED	11/10/2021	2	264	132
PLANNED	11/10/2021	4	164	41
PLANNED	11/10/2021	2	32	16
PLANNED	11/10/2021	3	117	39
PLANNED	11/10/2021	1	165	165
PLANNED	11/10/2021	12	444	37
PLANNED	11/10/2021	1	46	46

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/10/2021	2	556	278
PLANNED	11/10/2021	1	333	333
PLANNED	11/10/2021	4	920	230
PLANNED	11/10/2021	9	279	31
PLANNED	11/10/2021	4	84	21
PLANNED	11/10/2021	6	1,076	296
PLANNED	11/10/2021	1	47	47
PLANNED	11/10/2021	6	30	5
PLANNED	11/10/2021	2	698	349
PLANNED	11/10/2021	1	19	19
PLANNED	11/10/2021	2	56	28
PLANNED	11/10/2021	1	57	57
PLANNED	11/10/2021	1	15	15
PLANNED	11/10/2021	4	48	12
PLANNED	11/10/2021	2	48	24
PLANNED	11/10/2021	1	35	35
PLANNED	11/10/2021	1	53	53
PLANNED	11/10/2021	2	126	63
PLANNED	11/10/2021	8	144	18
PLANNED	11/10/2021	1	141	141
PLANNED	11/10/2021	4	80	20
PLANNED	11/10/2021	3	33	11
PLANNED	11/10/2021	6	78	13
PLANNED	11/10/2021	1	17	17
PLANNED	11/10/2021	1	240	240
PLANNED	11/10/2021	4	580	145
PLANNED	11/10/2021	4	560	140
PLANNED	11/10/2021	2	182	91
PLANNED	11/10/2021	2	102	51
PLANNED	11/10/2021	2	698	349
PLANNED	11/10/2021	10	1,020	102
CUSTOMER REQUEST	11/10/2021	63	14,868	236
CUSTOMER REQUEST	11/10/2021	32	29,568	924
PLANNED	11/10/2021	2	216	108
PLANNED	11/10/2021	2	356	178
PLANNED	11/10/2021	2	100	50
CUSTOMER REQUEST	11/10/2021	9	729	81
PLANNED	11/10/2021	9	603	67
PLANNED	11/10/2021	2	6	3
PLANNED	11/10/2021	1	208	208
PLANNED	11/10/2021	2	36	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/10/2021	1	24	24
PLANNED	11/10/2021	1	50	50
PLANNED	11/10/2021	3	45	15
PLANNED	11/10/2021	4	28	7
PLANNED	11/10/2021	5	40	8
PLANNED	11/10/2021	1	5	5
PLANNED	11/10/2021	4	44	11
PLANNED	11/10/2021	8	272	34
PLANNED	11/10/2021	2	256	128
PLANNED	11/10/2021	3	165	55
PLANNED	11/10/2021	1	127	127
PLANNED	11/10/2021	3	378	126
PLANNED	11/10/2021	1	126	126
PLANNED	11/10/2021	1	126	126
PLANNED	11/10/2021	2	42	21
PLANNED	11/10/2021	2	330	165
PLANNED	11/10/2021	4	16	4
PLANNED	11/10/2021	1	43	43
PLANNED	11/10/2021	2	26	13
PLANNED	11/10/2021	4	72	18
PLANNED	11/10/2021	13	338	26
CUSTOMER REQUEST	11/10/2021	25	3,275	131
PLANNED	11/10/2021	2	192	96
PLANNED	11/10/2021	9	864	96
PLANNED	11/10/2021	1	43	43
PLANNED	11/10/2021	2	212	106
PLANNED	11/10/2021	6	432	72
PLANNED	11/10/2021	8	544	68
PLANNED	11/10/2021	5	845	169
PLANNED	11/10/2021	6	852	142
CUSTOMER REQUEST	11/10/2021	2	14	7
PLANNED	11/10/2021	2	382	191
PLANNED	11/10/2021	4	48	12
PLANNED	11/10/2021	12	1,741	153
PLANNED	11/10/2021	7	21	3
PLANNED	11/10/2021	2	114	57
PLANNED	11/10/2021	3	117	39
PLANNED	11/10/2021	4	80	20
CUSTOMER REQUEST	11/10/2021	2	184	92
CUSTOMER REQUEST	11/10/2021	2	182	91
CUSTOMER REQUEST	11/10/2021	1	91	91

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/10/2021	4	364	91
CUSTOMER REQUEST	11/10/2021	2	182	91
PLANNED	11/10/2021	137	14,385	105
CUSTOMER REQUEST	11/10/2021	8	56	7
PLANNED	11/10/2021	1	18	18
PLANNED	11/10/2021	9	2,033	384
PLANNED	11/10/2021	7	273	39
PLANNED	11/10/2021	9	1,404	156
PLANNED	11/10/2021	3	255	85
PLANNED	11/10/2021	4	340	85
CUSTOMER REQUEST	11/10/2021	7	14	2
CUSTOMER REQUEST	11/10/2021	1	818	818
CUSTOMER REQUEST	11/10/2021	4	56	14
PLANNED	11/10/2021	20	2,320	116
PLANNED	11/10/2021	2	38	19
PLANNED	11/10/2021	2	148	74
PLANNED	11/10/2021	14	350	25
PLANNED	11/10/2021	2	258	129
PLANNED	11/10/2021	5	635	127
PLANNED	11/10/2021	1	131	131
PLANNED	11/10/2021	8	3,232	404
PLANNED	11/10/2021	32	4,416	138
PLANNED	11/10/2021	14	322	23
PLANNED	11/10/2021	11	1,397	127
PLANNED	11/10/2021	3	84	28
PLANNED	11/10/2021	1	60	60
PLANNED	11/10/2021	2	332	166
PLANNED	11/10/2021	17	1,292	76
PLANNED	11/10/2021	1	43	43
PLANNED	11/10/2021	60	3,240	54
PLANNED	11/10/2021	2	100	50
PLANNED	11/10/2021	3	213	71
PLANNED	11/10/2021	1	167	167
PLANNED	11/10/2021	1	16	16
PLANNED	11/10/2021	2	74	37
PLANNED	11/10/2021	2	20	10
PLANNED	11/10/2021	3	159	53
PLANNED	11/10/2021	3	237	79
PLANNED	11/10/2021	5	405	81
PLANNED	11/10/2021	4	192	48
PLANNED	11/10/2021	2	172	86

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/10/2021	3	78	26
PLANNED	11/10/2021	3	27	9
PLANNED	11/10/2021	2	14	7
PLANNED	11/10/2021	1	51	51
PLANNED	11/10/2021	8	352	44
PLANNED	11/10/2021	1	12	12
PLANNED	11/10/2021	2	146	73
PLANNED	11/10/2021	2	146	73
PLANNED	11/10/2021	1	73	73
CUSTOMER REQUEST	11/10/2021	1	259	259
PLANNED	11/10/2021	2	144	72
PLANNED	11/10/2021	9	612	68
PLANNED	11/10/2021	3	228	76
CUSTOMER REQUEST	11/10/2021	1	203	203
PLANNED	11/10/2021	4	48	12
CUSTOMER REQUEST	11/10/2021	1	127	127
PLANNED	11/10/2021	5	105	21
PLANNED	11/10/2021	1	93	93
PLANNED	11/10/2021	1	92	92
PLANNED	11/10/2021	2	26	13
PLANNED	11/10/2021	1	95	95
PLANNED	11/10/2021	9	324	36
PLANNED	11/10/2021	3	30	10
PLANNED	11/10/2021	4	88	22
PLANNED	11/10/2021	4	68	17
CUSTOMER REQUEST	11/10/2021	15	45	3
PLANNED	11/10/2021	4	120	30
PLANNED	11/10/2021	1	219	219
PLANNED	11/10/2021	1	32	32
PLANNED	11/10/2021	3	219	73
PLANNED	11/10/2021	12	408	34
PLANNED	11/10/2021	1	10	10
PLANNED	11/10/2021	2	46	23
PLANNED	11/10/2021	2	30	15
PLANNED	11/10/2021	4	76	19
PLANNED	11/10/2021	2	248	124
PLANNED	11/10/2021	7	417	105
PLANNED	11/10/2021	1	17	17
PLANNED	11/10/2021	3	66	22
PLANNED	11/10/2021	10	190	19
PLANNED	11/10/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/10/2021	4	204	51
PLANNED	11/10/2021	4	68	17
PLANNED	11/10/2021	7	70	10
PLANNED	11/10/2021	13	416	32
PLANNED	11/10/2021	1	8	8
PLANNED	11/10/2021	4	592	148
PLANNED	11/10/2021	2	18	9
PLANNED	11/10/2021	1	13	13
PLANNED	11/10/2021	3	15	5
PLANNED	11/10/2021	8	144	18
PLANNED	11/10/2021	3	72	24
PLANNED	11/10/2021	3	24	8
PLANNED	11/10/2021	6	462	77
PLANNED	11/10/2021	6	228	38
PLANNED	11/10/2021	2	264	132
PLANNED	11/10/2021	4	240	60
PLANNED	11/10/2021	2	212	106
PLANNED	11/10/2021	3	27	9
PLANNED	11/10/2021	4	488	122
PLANNED	11/10/2021	9	63	7
PLANNED	11/10/2021	2	16	8
PLANNED	11/10/2021	3	348	116
PLANNED	11/10/2021	8	144	18
PLANNED	11/10/2021	3	12	4
PLANNED	11/10/2021	2	114	57
PLANNED	11/10/2021	3	27	9
CUSTOMER REQUEST	11/10/2021	1	135	135
PLANNED	11/10/2021	8	96	12
PLANNED	11/10/2021	1	24	24
PLANNED	11/10/2021	1	6	6
PLANNED	11/10/2021	9	1,296	144
PLANNED	11/10/2021	1	9	9
PLANNED	11/10/2021	6	870	145
PLANNED	11/10/2021	2	12	6
PLANNED	11/10/2021	5	315	63
PLANNED	11/10/2021	3	171	57
PLANNED	11/10/2021	16	592	37
PLANNED	11/10/2021	20	1,620	81
PLANNED	11/10/2021	2	24	12
PLANNED	11/10/2021	1	14	14
PLANNED	11/10/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/10/2021	1	36	36
PLANNED	11/10/2021	1	35	35
CUSTOMER REQUEST	11/10/2021	1	12	12
PLANNED	11/10/2021	3	27	9
PLANNED	11/10/2021	6	456	106
PLANNED	11/10/2021	1	10	10
PLANNED	11/10/2021	2	10	5
PLANNED	11/10/2021	2	60	30
PLANNED	11/10/2021	2	10	5
PLANNED	11/10/2021	3	54	18
PLANNED	11/10/2021	2	20	10
PLANNED	11/10/2021	2	10	5
PLANNED	11/10/2021	4	32	8
PLANNED	11/10/2021	3	93	31
PLANNED	11/10/2021	3	42	14
PLANNED	11/10/2021	2	32	16
PLANNED	11/10/2021	3	33	11
PLANNED	11/10/2021	9	864	96
PLANNED	11/10/2021	1	96	96
CUSTOMER REQUEST	11/10/2021	1	32	32
CUSTOMER REQUEST	11/10/2021	1	76	76
CUSTOMER REQUEST	11/10/2021	1	337	337
PLANNED	11/10/2021	2	226	113
PLANNED	11/10/2021	19	3,971	209
PLANNED	11/10/2021	11	3,608	328
PLANNED	11/10/2021	3	141	47
CUSTOMER REQUEST	11/11/2021	51	18,666	366
PLANNED	11/11/2021	1	98	98
PLANNED	11/11/2021	11	990	90
PLANNED	11/11/2021	7	784	112
PLANNED	11/11/2021	1	239	239
PLANNED	11/11/2021	5	610	122
PLANNED	11/11/2021	8	80	10
PLANNED	11/11/2021	1	154	154
PLANNED	11/11/2021	12	204	17
PLANNED	11/11/2021	2	16	8
PLANNED	11/11/2021	4	244	61
PLANNED	11/11/2021	1	105	105
PLANNED	11/11/2021	1	65	65
PLANNED	11/11/2021	10	90	9
PLANNED	11/11/2021	22	550	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/11/2021	1	18	18
PLANNED	11/11/2021	1	59	59
PLANNED	11/11/2021	2	278	154
PLANNED	11/11/2021	12	192	16
PLANNED	11/11/2021	11	1,452	132
PLANNED	11/11/2021	5	1,135	227
PLANNED	11/11/2021	1	14	14
PLANNED	11/11/2021	17	1,003	59
PLANNED	11/11/2021	4	56	14
PLANNED	11/11/2021	4	108	27
PLANNED	11/11/2021	1	26	26
PLANNED	11/11/2021	3	261	87
PLANNED	11/11/2021	2	150	75
PLANNED	11/11/2021	11	1,683	153
PLANNED	11/11/2021	5	430	86
PLANNED	11/11/2021	4	326	95
PLANNED	11/11/2021	4	520	130
PLANNED	11/11/2021	5	606	162
PLANNED	11/11/2021	30	1,860	62
PLANNED	11/11/2021	5	60	12
PLANNED	11/11/2021	2	8	4
PLANNED	11/11/2021	35	700	20
PLANNED	11/11/2021	15	3,721	271
PLANNED	11/11/2021	7	1,509	368
PLANNED	11/11/2021	1	145	145
PLANNED	11/11/2021	4	56	14
PLANNED	11/11/2021	5	410	82
PLANNED	11/11/2021	1	22	22
PLANNED	11/11/2021	1	285	285
PLANNED	11/11/2021	1	17	17
PLANNED	11/11/2021	4	76	19
PLANNED	11/11/2021	2	58	29
PLANNED	11/11/2021	2	94	47
PLANNED	11/11/2021	1	5	5
PLANNED	11/11/2021	1	193	193
PLANNED	11/11/2021	1	148	148
PLANNED	11/11/2021	2	24	12
PLANNED	11/11/2021	8	192	24
PLANNED	11/11/2021	10	1,950	195
PLANNED	11/11/2021	12	156	13
PLANNED	11/11/2021	13	2,535	195

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/11/2021	2	152	76
PLANNED	11/11/2021	2	392	196
PLANNED	11/11/2021	5	985	197
PLANNED	11/11/2021	13	1,898	146
PLANNED	11/11/2021	5	30	6
PLANNED	11/11/2021	14	3,178	227
PLANNED	11/11/2021	2	40	20
PLANNED	11/11/2021	1	234	234
PLANNED	11/11/2021	1	34	34
PLANNED	11/11/2021	1	199	199
PLANNED	11/11/2021	2	236	118
PLANNED	11/11/2021	4	84	21
PLANNED	11/11/2021	8	408	51
PLANNED	11/11/2021	1	14	14
PLANNED	11/11/2021	2	34	17
PLANNED	11/11/2021	13	806	62
PLANNED	11/11/2021	3	15	5
PLANNED	11/11/2021	1	196	196
PLANNED	11/11/2021	1	297	297
PLANNED	11/11/2021	1	236	236
PLANNED	11/11/2021	1	67	67
PLANNED	11/11/2021	1	36	36
PLANNED	11/11/2021	2	122	61
PLANNED	11/11/2021	2	74	37
PLANNED	11/11/2021	6	492	82
CUSTOMER REQUEST	11/11/2021	1	171	171
PLANNED	11/11/2021	1	183	183
PLANNED	11/11/2021	1	96	96
PLANNED	11/11/2021	13	78	6
PLANNED	11/11/2021	5	950	190
PLANNED	11/11/2021	1	239	239
CUSTOMER REQUEST	11/11/2021	1	150	150
PLANNED	11/11/2021	2	714	357
CUSTOMER REQUEST	11/11/2021	1	63	63
PLANNED	11/11/2021	3	315	105
PLANNED	11/11/2021	1	166	166
PLANNED	11/11/2021	18	1,782	99
PLANNED	11/11/2021	6	48	8
PLANNED	11/11/2021	3	378	126
PLANNED	11/12/2021	8	800	100
PLANNED	11/12/2021	2	200	100

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/12/2021	1	123	123
PLANNED	11/12/2021	6	420	70
PLANNED	11/12/2021	1	37	37
PLANNED	11/12/2021	2	209	163
PLANNED	11/12/2021	7	455	65
PLANNED	11/12/2021	5	155	31
PLANNED	11/12/2021	1	85	85
PLANNED	11/12/2021	19	323	17
PLANNED	11/12/2021	1	220	220
PLANNED	11/12/2021	4	76	19
PLANNED	11/12/2021	3	45	15
PLANNED	11/12/2021	9	423	47
PLANNED	11/12/2021	2	198	99
PLANNED	11/12/2021	3	339	113
PLANNED	11/12/2021	3	558	186
PLANNED	11/12/2021	1	169	169
PLANNED	11/12/2021	9	774	86
PLANNED	11/12/2021	4	960	240
CUSTOMER REQUEST	11/12/2021	7	42	6
CUSTOMER REQUEST	11/12/2021	2	918	459
PLANNED	11/12/2021	8	120	15
PLANNED	11/12/2021	3	312	104
PLANNED	11/12/2021	9	243	27
PLANNED	11/12/2021	4	72	18
PLANNED	11/12/2021	4	408	102
PLANNED	11/12/2021	2	208	104
PLANNED	11/12/2021	5	330	66
PLANNED	11/12/2021	4	72	18
PLANNED	11/12/2021	1	221	221
PLANNED	11/12/2021	1	31	31
PLANNED	11/12/2021	10	220	22
CUSTOMER REQUEST	11/12/2021	20	200	10
PLANNED	11/12/2021	1	160	160
PLANNED	11/12/2021	1	242	242
PLANNED	11/12/2021	9	2,142	238
PLANNED	11/12/2021	1	192	192
PLANNED	11/12/2021	1	34	34
PLANNED	11/12/2021	5	382	107
PLANNED	11/12/2021	2	144	72
PLANNED	11/12/2021	1	34	34
CUSTOMER REQUEST	11/12/2021	1	21	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/12/2021	5	60	12
PLANNED	11/12/2021	7	154	22
PLANNED	11/12/2021	2	138	69
PLANNED	11/12/2021	1	61	61
PLANNED	11/12/2021	2	154	77
PLANNED	11/12/2021	2	18	9
PLANNED	11/12/2021	4	52	13
CUSTOMER REQUEST	11/12/2021	5	90	18
PLANNED	11/12/2021	21	1,533	73
CUSTOMER REQUEST	11/12/2021	3	51	17
CUSTOMER REQUEST	11/12/2021	1	103	103
PLANNED	11/12/2021	2	24	12
PLANNED	11/12/2021	13	260	20
PLANNED	11/12/2021	5	50	10
PLANNED	11/12/2021	6	246	41
PLANNED	11/12/2021	9	369	41
PLANNED	11/12/2021	1	167	167
PLANNED	11/12/2021	3	54	18
PLANNED	11/12/2021	2	198	99
PLANNED	11/12/2021	2	320	160
PLANNED	11/12/2021	5	850	170
PLANNED	11/12/2021	8	80	10
PLANNED	11/12/2021	3	141	47
PLANNED	11/12/2021	1	19	19
PLANNED	11/12/2021	1	42	42
PLANNED	11/12/2021	3	87	29
CUSTOMER REQUEST	11/12/2021	12	528	44
PLANNED	11/12/2021	2	220	110
PLANNED	11/12/2021	3	438	146
PLANNED	11/12/2021	4	240	60
PLANNED	11/12/2021	3	84	28
PLANNED	11/12/2021	10	680	68
PLANNED	11/12/2021	5	5	1
PLANNED	11/12/2021	6	252	42
PLANNED	11/12/2021	8	312	39
PLANNED	11/12/2021	8	542	82
CUSTOMER REQUEST	11/12/2021	1	24	24
PLANNED	11/12/2021	3	249	83
CUSTOMER REQUEST	11/12/2021	1	72	72
CUSTOMER REQUEST	11/12/2021	1	44	44
PLANNED	11/12/2021	8	2,632	329

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/12/2021	1	32	32
PLANNED	11/12/2021	1	138	138
PLANNED	11/12/2021	1	160	160
PLANNED	11/13/2021	3	831	277
PLANNED	11/13/2021	17	663	39
PLANNED	11/13/2021	1	195	195
PLANNED	11/13/2021	4	1,496	374
PLANNED	11/13/2021	3	285	95
PLANNED	11/13/2021	2	62	31
PLANNED	11/13/2021	4	84	21
PLANNED	11/13/2021	2	132	66
PLANNED	11/13/2021	1	227	227
PLANNED	11/13/2021	1	80	80
PLANNED	11/13/2021	1	127	127
PLANNED	11/13/2021	11	1,232	112
CUSTOMER REQUEST	11/13/2021	1	150	150
PLANNED	11/13/2021	2	372	186
PLANNED	11/13/2021	1	220	220
PLANNED	11/13/2021	3	756	252
PLANNED	11/13/2021	3	36	12
PLANNED	11/13/2021	3	255	85
PLANNED	11/13/2021	3	396	132
PLANNED	11/13/2021	2	146	73
PLANNED	11/13/2021	1	96	96
PLANNED	11/13/2021	17	153	9
PLANNED	11/13/2021	2	258	129
PLANNED	11/13/2021	2	18	9
PLANNED	11/13/2021	1	7	7
CUSTOMER REQUEST	11/13/2021	1	5,824	5,824
PLANNED	11/13/2021	1	22	22
PLANNED	11/13/2021	2	86	43
PLANNED	11/13/2021	3	474	158
PLANNED	11/13/2021	2	188	94
PLANNED	11/13/2021	1	10	10
PLANNED	11/13/2021	7	1,771	253
CUSTOMER REQUEST	11/14/2021	1	174	174
PLANNED	11/14/2021	2	562	281
PLANNED	11/14/2021	1	157	157
PLANNED	11/14/2021	2	480	240
PLANNED	11/14/2021	1	153	153
PLANNED	11/14/2021	2	114	57

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/14/2021	1	16	16
PLANNED	11/14/2021	11	1,452	132
PLANNED	11/14/2021	7	161	23
PLANNED	11/14/2021	2	258	129
PLANNED	11/14/2021	1	123	123
PLANNED	11/14/2021	2	326	163
PLANNED	11/14/2021	23	8,970	390
PLANNED	11/14/2021	3	252	84
PLANNED	11/15/2021	7	371	53
PLANNED	11/15/2021	1	169	169
PLANNED	11/15/2021	15	1,890	126
PLANNED	11/15/2021	7	168	24
PLANNED	11/15/2021	2	376	188
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	4	407	125
PLANNED	11/15/2021	2	284	142
PLANNED	11/15/2021	5	125	25
PLANNED	11/15/2021	5	375	75
PLANNED	11/15/2021	8	592	74
PLANNED	11/15/2021	10	240	24
PLANNED	11/15/2021	5	80	16
PLANNED	11/15/2021	5	321	128
PLANNED	11/15/2021	4	436	109
PLANNED	11/15/2021	2	304	152
PLANNED	11/15/2021	3	363	121
PLANNED	11/15/2021	6	390	65
PLANNED	11/15/2021	18	486	27
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	2	12	6
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	4	24	6
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	1	212	212
PLANNED	11/15/2021	2	48	24
PLANNED	11/15/2021	3	1,014	338
PLANNED	11/15/2021	2	42	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	2	108	54
PLANNED	11/15/2021	3	33	11
PLANNED	11/15/2021	5	635	127
PLANNED	11/15/2021	8	128	16
PLANNED	11/15/2021	3	183	61
PLANNED	11/15/2021	4	40	10
PLANNED	11/15/2021	13	130	10
PLANNED	11/15/2021	7	140	20
PLANNED	11/15/2021	2	12	6
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	2	12	6
PLANNED	11/15/2021	1	5	5
PLANNED	11/15/2021	6	210	35
PLANNED	11/15/2021	2	10	5
PLANNED	11/15/2021	4	64	16
CUSTOMER REQUEST	11/15/2021	9	45	5
PLANNED	11/15/2021	32	1,920	60
PLANNED	11/15/2021	6	120	20
PLANNED	11/15/2021	7	623	89
PLANNED	11/15/2021	5	40	8
CUSTOMER REQUEST	11/15/2021	1	259	259
PLANNED	11/15/2021	3	102	34
PLANNED	11/15/2021	2	6	3
PLANNED	11/15/2021	3	81	27
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	1	57	57
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	4	44	11
PLANNED	11/15/2021	1	2	2
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	22	528	24
PLANNED	11/15/2021	16	240	15
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	4	100	25
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	4	72	18
PLANNED	11/15/2021	3	30	10
PLANNED	11/15/2021	2	50	25
PLANNED	11/15/2021	1	216	216
PLANNED	11/15/2021	3	45	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	12	276	23
PLANNED	11/15/2021	1	68	68
PLANNED	11/15/2021	6	456	76
PLANNED	11/15/2021	4	108	27
PLANNED	11/15/2021	7	49	7
PLANNED	11/15/2021	4	160	40
CUSTOMER REQUEST	11/15/2021	16	64	4
CUSTOMER REQUEST	11/15/2021	2	38	19
PLANNED	11/15/2021	2	28	14
PLANNED	11/15/2021	7	63	9
PLANNED	11/15/2021	9	288	32
PLANNED	11/15/2021	1	90	90
PLANNED	11/15/2021	1	22	22
PLANNED	11/15/2021	3	117	39
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	3	30	10
PLANNED	11/15/2021	8	40	5
PLANNED	11/15/2021	3	60	20
PLANNED	11/15/2021	15	480	32
PLANNED	11/15/2021	1	13	13
PLANNED	11/15/2021	4	56	14
PLANNED	11/15/2021	4	60	15
PLANNED	11/15/2021	5	25	5
PLANNED	11/15/2021	5	20	4
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	1	4	4
PLANNED	11/15/2021	4	52	13
PLANNED	11/15/2021	2	10	5
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	1	54	54
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	3	9	3
PLANNED	11/15/2021	2	20	10
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	2	16	8
PLANNED	11/15/2021	3	63	21

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	3	42	14
PLANNED	11/15/2021	7	147	21
PLANNED	11/15/2021	5	265	53
PLANNED	11/15/2021	8	1,280	160
PLANNED	11/15/2021	13	364	28
PLANNED	11/15/2021	2	12	6
PLANNED	11/15/2021	12	72	6
PLANNED	11/15/2021	1	5	5
PLANNED	11/15/2021	4	76	19
PLANNED	11/15/2021	2	128	64
PLANNED	11/15/2021	2	10	5
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	1	14	14
PLANNED	11/15/2021	4	820	205
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	166	83
PLANNED	11/15/2021	30	420	14
PLANNED	11/15/2021	1	11	11
PLANNED	11/15/2021	9	81	9
PLANNED	11/15/2021	9	90	10
CUSTOMER REQUEST	11/15/2021	5	30	6
PLANNED	11/15/2021	1	16	16
PLANNED	11/15/2021	4	236	59
PLANNED	11/15/2021	1	11	11
PLANNED	11/15/2021	2	36	18
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	9	279	31
PLANNED	11/15/2021	12	108	9
PLANNED	11/15/2021	4	32	8
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	4	48	12
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	2	30	15
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	4	76	19
PLANNED	11/15/2021	6	48	8
PLANNED	11/15/2021	4	272	68
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	3	117	39
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	340	170
PLANNED	11/15/2021	2	34	17
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	33	957	29
PLANNED	11/15/2021	2	40	20
PLANNED	11/15/2021	3	144	48
PLANNED	11/15/2021	5	35	7
PLANNED	11/15/2021	4	724	181
PLANNED	11/15/2021	5	30	6
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	9	54	6
PLANNED	11/15/2021	3	54	18
PLANNED	11/15/2021	4	36	9
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	2	32	16
PLANNED	11/15/2021	2	34	17
PLANNED	11/15/2021	7	56	8
PLANNED	11/15/2021	6	18	3
PLANNED	11/15/2021	5	20	4
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	1	82	82
PLANNED	11/15/2021	10	140	14
PLANNED	11/15/2021	3	87	29
PLANNED	11/15/2021	7	413	59
PLANNED	11/15/2021	26	26	1
PLANNED	11/15/2021	3	60	20
PLANNED	11/15/2021	1	14	14
PLANNED	11/15/2021	6	36	6
PLANNED	11/15/2021	8	128	16
PLANNED	11/15/2021	2	144	72
PLANNED	11/15/2021	5	110	22
PLANNED	11/15/2021	2	22	11
PLANNED	11/15/2021	4	100	25
PLANNED	11/15/2021	10	630	63
PLANNED	11/15/2021	29	2,262	78
PLANNED	11/15/2021	3	18	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	4	164	41
PLANNED	11/15/2021	1	9	9
PLANNED	11/15/2021	2	368	184
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	3	9	3
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	4	124	31
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	3	24	8
PLANNED	11/15/2021	3	60	20
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	264	132
PLANNED	11/15/2021	5	50	10
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	12	804	67
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	2	52	26
PLANNED	11/15/2021	8	24	3
PLANNED	11/15/2021	8	72	9
PLANNED	11/15/2021	4	232	58
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	7	147	21
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	2	16	8
PLANNED	11/15/2021	1	11	11
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	3	27	9
PLANNED	11/15/2021	7	14	2
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	3	36	12
CUSTOMER REQUEST	11/15/2021	11	308	28
PLANNED	11/15/2021	9	63	7
PLANNED	11/15/2021	4	170	67
PLANNED	11/15/2021	1	216	216
PLANNED	11/15/2021	19	285	15
PLANNED	11/15/2021	2	436	218

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	5	65	13
PLANNED	11/15/2021	2	182	91
PLANNED	11/15/2021	7	49	7
PLANNED	11/15/2021	6	72	12
PLANNED	11/15/2021	1	117	117
PLANNED	11/15/2021	6	84	14
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	2	20	10
PLANNED	11/15/2021	1	4	4
PLANNED	11/15/2021	3	75	25
PLANNED	11/15/2021	2	16	8
PLANNED	11/15/2021	4	84	21
PLANNED	11/15/2021	8	120	15
PLANNED	11/15/2021	5	285	57
PLANNED	11/15/2021	4	28	7
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	5	40	8
PLANNED	11/15/2021	3	27	9
PLANNED	11/15/2021	6	36	6
PLANNED	11/15/2021	3	432	144
PLANNED	11/15/2021	9	2,538	282
PLANNED	11/15/2021	6	186	31
PLANNED	11/15/2021	2	14	7
PLANNED	11/15/2021	2	10	5
PLANNED	11/15/2021	2	156	78
PLANNED	11/15/2021	2	226	113
PLANNED	11/15/2021	8	112	14
PLANNED	11/15/2021	2	24	12
PLANNED	11/15/2021	8	48	6
PLANNED	11/15/2021	1	12	12
PLANNED	11/15/2021	1	10	10
PLANNED	11/15/2021	4	112	28
PLANNED	11/15/2021	5	410	82
PLANNED	11/15/2021	2	412	206
PLANNED	11/15/2021	3	297	99
PLANNED	11/15/2021	8	80	10
PLANNED	11/15/2021	1	7	7
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	5	75	15
PLANNED	11/15/2021	5	25	5
PLANNED	11/15/2021	5	90	18
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	4	32	8
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	8	72	9
PLANNED	11/15/2021	12	288	24
PLANNED	11/15/2021	10	240	24
PLANNED	11/15/2021	6	54	9
PLANNED	11/15/2021	10	300	30
PLANNED	11/15/2021	1	11	11
PLANNED	11/15/2021	7	1,820	260
PLANNED	11/15/2021	12	972	81
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	3	12	4
PLANNED	11/15/2021	1	4	4
CUSTOMER REQUEST	11/15/2021	8	80	10
PLANNED	11/15/2021	1	10	10
PLANNED	11/15/2021	12	60	5
PLANNED	11/15/2021	3	60	20
PLANNED	11/15/2021	14	56	4
PLANNED	11/15/2021	19	171	9
PLANNED	11/15/2021	7	1,685	267
PLANNED	11/15/2021	1	14	14
PLANNED	11/15/2021	4	172	43
PLANNED	11/15/2021	13	507	39
PLANNED	11/15/2021	1	14	14
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	3	129	43
PLANNED	11/15/2021	18	144	8
PLANNED	11/15/2021	2	10	5
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	41	492	12
PLANNED	11/15/2021	1	12	12
PLANNED	11/15/2021	115	3,795	33
PLANNED	11/15/2021	1	61	61
PLANNED	11/15/2021	4	16	4
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	1	11	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	3	30	10
PLANNED	11/15/2021	1	138	138
PLANNED	11/15/2021	1	36	36
PLANNED	11/15/2021	8	272	34
PLANNED	11/15/2021	5	35	7
PLANNED	11/15/2021	6	156	26
PLANNED	11/15/2021	1	7	7
PLANNED	11/15/2021	2	40	20
PLANNED	11/15/2021	7	70	10
PLANNED	11/15/2021	3	24	8
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	12	6
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	2	8	4
PLANNED	11/15/2021	8	72	9
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	5	35	7
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	2	18	9
PLANNED	11/15/2021	1	10	10
PLANNED	11/15/2021	3	21	7
PLANNED	11/15/2021	12	36	3
PLANNED	11/15/2021	3	39	13
PLANNED	11/15/2021	3	252	84
PLANNED	11/15/2021	2	20	10
PLANNED	11/15/2021	1	5	5
PLANNED	11/15/2021	6	6	1
CUSTOMER REQUEST	11/15/2021	1	11	11
PLANNED	11/15/2021	4	52	13
PLANNED	11/15/2021	3	195	65
PLANNED	11/15/2021	3	18	6
PLANNED	11/15/2021	4	52	13
CUSTOMER REQUEST	11/15/2021	1	28	28
PLANNED	11/15/2021	3	33	11
PLANNED	11/15/2021	4	20	5
PLANNED	11/15/2021	6	102	17
PLANNED	11/15/2021	1	67	67
PLANNED	11/15/2021	3	15	5
PLANNED	11/15/2021	6	24	4
PLANNED	11/15/2021	2	22	11
PLANNED	11/15/2021	4	32	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/15/2021	3	24	8
PLANNED	11/15/2021	1	10	10
PLANNED	11/15/2021	1	9	9
PLANNED	11/15/2021	5	45	9
PLANNED	11/15/2021	4	52	13
PLANNED	11/15/2021	2	42	21
PLANNED	11/15/2021	1	148	148
PLANNED	11/15/2021	3	186	62
PLANNED	11/15/2021	1	90	90
PLANNED	11/15/2021	3	735	245
PLANNED	11/15/2021	1	49	49
PLANNED	11/15/2021	2	124	62
PLANNED	11/15/2021	1	468	468
PLANNED	11/16/2021	2	162	81
PLANNED	11/16/2021	1	93	93
PLANNED	11/16/2021	7	399	57
PLANNED	11/16/2021	2	112	56
PLANNED	11/16/2021	1	46	46
PLANNED	11/16/2021	15	1,110	74
PLANNED	11/16/2021	1	17	17
PLANNED	11/16/2021	7	93	34
PLANNED	11/16/2021	1	86	86
CUSTOMER REQUEST	11/16/2021	1	553	553
PLANNED	11/16/2021	6	642	107
PLANNED	11/16/2021	38	418	11
PLANNED	11/16/2021	4	76	19
PLANNED	11/16/2021	1	82	82
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	2	218	109
PLANNED	11/16/2021	7	98	14
PLANNED	11/16/2021	3	345	115
PLANNED	11/16/2021	4	40	10
PLANNED	11/16/2021	5	75	15
PLANNED	11/16/2021	4	12	3
PLANNED	11/16/2021	1	9	9
PLANNED	11/16/2021	2	8	4
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	3	9	3
PLANNED	11/16/2021	6	18	3
PLANNED	11/16/2021	12	408	34
PLANNED	11/16/2021	5	480	96

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	5	65	13
PLANNED	11/16/2021	3	654	218
PLANNED	11/16/2021	12	1,584	132
PLANNED	11/16/2021	5	425	85
PLANNED	11/16/2021	3	33	11
PLANNED	11/16/2021	48	9,552	199
PLANNED	11/16/2021	1	26	26
PLANNED	11/16/2021	3	48	16
PLANNED	11/16/2021	3	210	70
PLANNED	11/16/2021	4	52	13
PLANNED	11/16/2021	4	52	13
PLANNED	11/16/2021	2	358	179
PLANNED	11/16/2021	3	27	9
PLANNED	11/16/2021	5	175	35
PLANNED	11/16/2021	3	24	8
PLANNED	11/16/2021	2	38	19
PLANNED	11/16/2021	8	80	10
PLANNED	11/16/2021	4	220	55
PLANNED	11/16/2021	1	7	7
PLANNED	11/16/2021	3	21	7
PLANNED	11/16/2021	4	48	12
PLANNED	11/16/2021	4	24	6
PLANNED	11/16/2021	3	18	6
PLANNED	11/16/2021	4	36	9
PLANNED	11/16/2021	2	26	13
PLANNED	11/16/2021	5	35	7
PLANNED	11/16/2021	6	54	9
PLANNED	11/16/2021	6	114	19
PLANNED	11/16/2021	4	452	113
PLANNED	11/16/2021	3	36	12
PLANNED	11/16/2021	3	96	32
PLANNED	11/16/2021	1	76	76
PLANNED	11/16/2021	7	658	94
PLANNED	11/16/2021	1	9	9
PLANNED	11/16/2021	7	651	93
PLANNED	11/16/2021	15	2,898	252
PLANNED	11/16/2021	2	20	10
PLANNED	11/16/2021	1	49	49
PLANNED	11/16/2021	7	49	7
PLANNED	11/16/2021	4	56	14
PLANNED	11/16/2021	3	9	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	19	1,311	69
PLANNED	11/16/2021	2	8	4
PLANNED	11/16/2021	1	3	3
PLANNED	11/16/2021	1	87	87
PLANNED	11/16/2021	4	20	5
PLANNED	11/16/2021	4	16	4
PLANNED	11/16/2021	2	18	9
PLANNED	11/16/2021	4	24	6
PLANNED	11/16/2021	1	9	9
PLANNED	11/16/2021	17	119	7
PLANNED	11/16/2021	21	903	43
PLANNED	11/16/2021	79	9,322	118
PLANNED	11/16/2021	1	10	10
PLANNED	11/16/2021	2	110	55
PLANNED	11/16/2021	4	740	185
PLANNED	11/16/2021	2	30	15
PLANNED	11/16/2021	2	372	186
PLANNED	11/16/2021	1	186	186
PLANNED	11/16/2021	1	186	186
PLANNED	11/16/2021	4	32	8
PLANNED	11/16/2021	4	188	47
PLANNED	11/16/2021	4	24	6
PLANNED	11/16/2021	3	15	5
PLANNED	11/16/2021	3	60	20
PLANNED	11/16/2021	1	8	8
CUSTOMER REQUEST	11/16/2021	8	432	54
PLANNED	11/16/2021	7	1,582	226
PLANNED	11/16/2021	2	214	123
PLANNED	11/16/2021	6	180	30
PLANNED	11/16/2021	4	60	15
CUSTOMER REQUEST	11/16/2021	8	592	74
PLANNED	11/16/2021	7	77	11
PLANNED	11/16/2021	3	21	7
PLANNED	11/16/2021	2	14	7
PLANNED	11/16/2021	2	10	5
PLANNED	11/16/2021	3	33	11
PLANNED	11/16/2021	4	20	5
PLANNED	11/16/2021	1	4	4
PLANNED	11/16/2021	3	24	8
PLANNED	11/16/2021	194	12,804	66
PLANNED	11/16/2021	2	20	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	6	144	24
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	3	33	11
PLANNED	11/16/2021	4	16	4
PLANNED	11/16/2021	1	6	6
PLANNED	11/16/2021	3	9	3
PLANNED	11/16/2021	2	10	5
PLANNED	11/16/2021	4	16	4
PLANNED	11/16/2021	3	12	4
PLANNED	11/16/2021	8	352	44
PLANNED	11/16/2021	1	7	7
PLANNED	11/16/2021	3	12	4
PLANNED	11/16/2021	4	240	60
PLANNED	11/16/2021	1	32	32
PLANNED	11/16/2021	2	100	50
PLANNED	11/16/2021	6	48	8
PLANNED	11/16/2021	1	8	8
PLANNED	11/16/2021	4	28	7
PLANNED	11/16/2021	10	160	16
PLANNED	11/16/2021	38	1,368	36
PLANNED	11/16/2021	5	5	1
PLANNED	11/16/2021	9	1,134	126
PLANNED	11/16/2021	7	672	96
PLANNED	11/16/2021	7	602	86
PLANNED	11/16/2021	13	78	6
PLANNED	11/16/2021	2	110	55
PLANNED	11/16/2021	4	172	43
PLANNED	11/16/2021	3	36	12
PLANNED	11/16/2021	1	17	17
PLANNED	11/16/2021	2	142	71
CUSTOMER REQUEST	11/16/2021	5	35	7
PLANNED	11/16/2021	1	31	31
PLANNED	11/16/2021	1	10	10
PLANNED	11/16/2021	3	482	273
PLANNED	11/16/2021	1	9	9
PLANNED	11/16/2021	5	370	74
PLANNED	11/16/2021	5	20	4
PLANNED	11/16/2021	1	130	130
PLANNED	11/16/2021	3	9	3
PLANNED	11/16/2021	5	265	53
PLANNED	11/16/2021	4	12	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	2	8	4
PLANNED	11/16/2021	4	20	5
PLANNED	11/16/2021	3	771	257
PLANNED	11/16/2021	4	204	51
PLANNED	11/16/2021	1	6	6
PLANNED	11/16/2021	11	121	11
PLANNED	11/16/2021	2	120	60
PLANNED	11/16/2021	4	256	64
PLANNED	11/16/2021	7	56	8
PLANNED	11/16/2021	3	507	291
PLANNED	11/16/2021	4	36	9
PLANNED	11/16/2021	3	21	7
PLANNED	11/16/2021	11	275	25
PLANNED	11/16/2021	4	308	77
PLANNED	11/16/2021	3	24	8
PLANNED	11/16/2021	3	15	5
PLANNED	11/16/2021	15	2,190	146
PLANNED	11/16/2021	3	24	8
PLANNED	11/16/2021	3	21	7
PLANNED	11/16/2021	4	36	9
PLANNED	11/16/2021	3	235	102
PLANNED	11/16/2021	4	68	17
PLANNED	11/16/2021	1	11	11
PLANNED	11/16/2021	1	65	65
PLANNED	11/16/2021	1	116	116
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	1	4	4
PLANNED	11/16/2021	3	18	6
PLANNED	11/16/2021	3	18	6
PLANNED	11/16/2021	3	21	7
PLANNED	11/16/2021	2	20	10
PLANNED	11/16/2021	7	189	27
CUSTOMER REQUEST	11/16/2021	12	144	12
PLANNED	11/16/2021	10	280	28
PLANNED	11/16/2021	1	11	11
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	1	154	154
PLANNED	11/16/2021	2	10	5
PLANNED	11/16/2021	2	8	4
PLANNED	11/16/2021	4	60	15
PLANNED	11/16/2021	3	9	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	6	18	3
PLANNED	11/16/2021	7	28	4
PLANNED	11/16/2021	12	108	9
PLANNED	11/16/2021	6	78	13
PLANNED	11/16/2021	47	3,619	77
PLANNED	11/16/2021	13	1,092	84
PLANNED	11/16/2021	6	252	42
PLANNED	11/16/2021	3	15	5
PLANNED	11/16/2021	4	28	7
PLANNED	11/16/2021	4	20	5
PLANNED	11/16/2021	5	50	10
PLANNED	11/16/2021	5	30	6
PLANNED	11/16/2021	5	175	35
PLANNED	11/16/2021	5	25	5
PLANNED	11/16/2021	4	28	7
PLANNED	11/16/2021	4	40	10
PLANNED	11/16/2021	20	180	9
PLANNED	11/16/2021	6	138	23
PLANNED	11/16/2021	2	288	144
PLANNED	11/16/2021	1	17	17
PLANNED	11/16/2021	1	11	11
PLANNED	11/16/2021	1	58	58
PLANNED	11/16/2021	6	42	7
PLANNED	11/16/2021	2	14	7
PLANNED	11/16/2021	4	72	18
PLANNED	11/16/2021	4	20	5
PLANNED	11/16/2021	3	15	5
PLANNED	11/16/2021	3	12	4
PLANNED	11/16/2021	4	168	42
PLANNED	11/16/2021	7	903	129
PLANNED	11/16/2021	6	564	94
PLANNED	11/16/2021	1	11	11
PLANNED	11/16/2021	3	30	10
PLANNED	11/16/2021	15	165	11
PLANNED	11/16/2021	13	195	15
PLANNED	11/16/2021	7	77	11
PLANNED	11/16/2021	14	98	7
PLANNED	11/16/2021	8	256	32
PLANNED	11/16/2021	5	30	6
PLANNED	11/16/2021	10	280	28
PLANNED	11/16/2021	9	54	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	3	24	8
PLANNED	11/16/2021	4	64	16
PLANNED	11/16/2021	5	110	22
PLANNED	11/16/2021	12	96	8
PLANNED	11/16/2021	12	84	7
PLANNED	11/16/2021	1	12	12
PLANNED	11/16/2021	5	35	7
PLANNED	11/16/2021	5	120	24
PLANNED	11/16/2021	4	260	65
PLANNED	11/16/2021	5	145	29
PLANNED	11/16/2021	10	70	7
PLANNED	11/16/2021	21	252	12
PLANNED	11/16/2021	10	60	6
PLANNED	11/16/2021	3	27	9
PLANNED	11/16/2021	1	4	4
PLANNED	11/16/2021	8	40	5
PLANNED	11/16/2021	2	16	8
PLANNED	11/16/2021	3	93	31
PLANNED	11/16/2021	8	128	16
PLANNED	11/16/2021	2	10	5
PLANNED	11/16/2021	6	108	18
PLANNED	11/16/2021	3	39	13
PLANNED	11/16/2021	17	85	5
PLANNED	11/16/2021	1	175	175
PLANNED	11/16/2021	1	10	10
PLANNED	11/16/2021	4	184	46
PLANNED	11/16/2021	5	60	12
PLANNED	11/16/2021	9	270	30
PLANNED	11/16/2021	8	552	69
PLANNED	11/16/2021	1	72	72
PLANNED	11/16/2021	2	20	10
PLANNED	11/16/2021	1	50	50
PLANNED	11/16/2021	3	57	19
PLANNED	11/16/2021	4	332	83
PLANNED	11/16/2021	9	90	10
PLANNED	11/16/2021	1	30	30
PLANNED	11/16/2021	1	17	17
PLANNED	11/16/2021	4	164	41
PLANNED	11/16/2021	1	117	117
PLANNED	11/16/2021	11	330	30
PLANNED	11/16/2021	2	126	63

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/16/2021	2	12	6
PLANNED	11/16/2021	5	250	50
PLANNED	11/16/2021	1	1	1
PLANNED	11/16/2021	3	33	11
PLANNED	11/16/2021	3	243	81
PLANNED	11/16/2021	2	36	18
PLANNED	11/16/2021	6	54	9
PLANNED	11/16/2021	6	420	70
PLANNED	11/16/2021	4	28	7
PLANNED	11/16/2021	1	5	5
PLANNED	11/16/2021	2	398	199
PLANNED	11/16/2021	2	22	11
PLANNED	11/16/2021	2	38	19
PLANNED	11/16/2021	3	249	83
PLANNED	11/16/2021	13	104	8
PLANNED	11/16/2021	3	18	6
CUSTOMER REQUEST	11/16/2021	1	274	274
PLANNED	11/16/2021	11	77	7
PLANNED	11/16/2021	3	45	15
PLANNED	11/16/2021	2	30	15
PLANNED	11/16/2021	4	336	114
PLANNED	11/16/2021	2	108	54
PLANNED	11/16/2021	1	37	37
PLANNED	11/16/2021	8	56	7
PLANNED	11/16/2021	4	156	39
PLANNED	11/16/2021	5	165	33
PLANNED	11/16/2021	7	259	37
PLANNED	11/16/2021	4	84	21
PLANNED	11/16/2021	10	1,380	138
PLANNED	11/16/2021	45	585	13
PLANNED	11/16/2021	3	45	15
PLANNED	11/16/2021	11	88	8
PLANNED	11/16/2021	6	42	7
PLANNED	11/16/2021	3	207	69
PLANNED	11/16/2021	9	243	27
PLANNED	11/16/2021	13	858	66
PLANNED	11/16/2021	6	48	8
CUSTOMER REQUEST	11/16/2021	1	164	164
PLANNED	11/16/2021	11	66	6
PLANNED	11/16/2021	3	492	164
PLANNED	11/16/2021	8	48	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/16/2021	1	10	10
PLANNED	11/16/2021	1	334	334
PLANNED	11/16/2021	4	196	49
PLANNED	11/16/2021	9	279	31
PLANNED	11/16/2021	1	155	155
PLANNED	11/16/2021	2	134	67
PLANNED	11/16/2021	17	3,926	280
PLANNED	11/16/2021	5	1,405	281
PLANNED	11/16/2021	1	71	71
PLANNED	11/16/2021	5	830	166
PLANNED	11/16/2021	2	324	162
PLANNED	11/16/2021	1	127	127
PLANNED	11/16/2021	1	82	82
PLANNED	11/16/2021	1	132	132
PLANNED	11/16/2021	3	192	64
PLANNED	11/16/2021	5	895	179
CUSTOMER REQUEST	11/17/2021	5	350	70
PLANNED	11/17/2021	12	3,924	327
PLANNED	11/17/2021	2	284	142
PLANNED	11/17/2021	50	15,850	317
PLANNED	11/17/2021	10	1,210	121
PLANNED	11/17/2021	5	85	17
PLANNED	11/17/2021	9	162	18
PLANNED	11/17/2021	4	144	36
PLANNED	11/17/2021	3	45	15
PLANNED	11/17/2021	3	120	40
PLANNED	11/17/2021	3	147	49
PLANNED	11/17/2021	3	198	66
PLANNED	11/17/2021	1	7	7
PLANNED	11/17/2021	4	48	12
PLANNED	11/17/2021	9	207	23
PLANNED	11/17/2021	13	250	31
PLANNED	11/17/2021	2	10	5
PLANNED	11/17/2021	1	8	8
PLANNED	11/17/2021	3	266	124
PLANNED	11/17/2021	3	18	6
PLANNED	11/17/2021	6	580	202
PLANNED	11/17/2021	25	3,375	135
PLANNED	11/17/2021	3	75	25
PLANNED	11/17/2021	2	8	4
PLANNED	11/17/2021	3	488	218

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/17/2021	6	474	79
PLANNED	11/17/2021	5	45	9
PLANNED	11/17/2021	3	135	45
PLANNED	11/17/2021	1	212	212
PLANNED	11/17/2021	2	10	5
PLANNED	11/17/2021	5	1,570	314
PLANNED	11/17/2021	2	34	17
PLANNED	11/17/2021	2	28	14
PLANNED	11/17/2021	13	1,893	273
PLANNED	11/17/2021	1	4	4
CUSTOMER REQUEST	11/17/2021	25	450	18
PLANNED	11/17/2021	13	286	22
PLANNED	11/17/2021	2	10	5
PLANNED	11/17/2021	1	12	12
PLANNED	11/17/2021	1	107	107
PLANNED	11/17/2021	16	3,921	281
PLANNED	11/17/2021	1	13	13
PLANNED	11/17/2021	3	72	24
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	1	184	184
PLANNED	11/17/2021	4	292	73
PLANNED	11/17/2021	4	72	18
PLANNED	11/17/2021	13	312	24
PLANNED	11/17/2021	3	60	20
PLANNED	11/17/2021	2	46	23
PLANNED	11/17/2021	5	530	106
PLANNED	11/17/2021	2	40	20
PLANNED	11/17/2021	2	320	160
PLANNED	11/17/2021	4	48	12
PLANNED	11/17/2021	4	96	24
PLANNED	11/17/2021	2	18	9
PLANNED	11/17/2021	7	77	11
PLANNED	11/17/2021	5	45	9
PLANNED	11/17/2021	69	621	9
PLANNED	11/17/2021	6	546	91
PLANNED	11/17/2021	3	48	16
PLANNED	11/17/2021	20	1,000	50
PLANNED	11/17/2021	12	276	23
PLANNED	11/17/2021	4	120	30
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	9	1,647	183

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/17/2021	19	133	7
PLANNED	11/17/2021	6	360	60
PLANNED	11/17/2021	3	21	7
PLANNED	11/17/2021	13	1,768	136
PLANNED	11/17/2021	14	840	60
PLANNED	11/17/2021	15	2,700	180
PLANNED	11/17/2021	5	545	109
PLANNED	11/17/2021	7	42	6
PLANNED	11/17/2021	3	33	11
PLANNED	11/17/2021	2	342	171
PLANNED	11/17/2021	1	361	361
PLANNED	11/17/2021	1	14	14
PLANNED	11/17/2021	7	35	5
PLANNED	11/17/2021	9	738	82
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	2	90	45
PLANNED	11/17/2021	12	60	5
PLANNED	11/17/2021	3	108	36
PLANNED	11/17/2021	4	56	14
PLANNED	11/17/2021	5	65	13
PLANNED	11/17/2021	20	260	13
PLANNED	11/17/2021	7	910	130
PLANNED	11/17/2021	6	492	82
PLANNED	11/17/2021	3	167	141
PLANNED	11/17/2021	2	84	50
PLANNED	11/17/2021	3	12	4
PLANNED	11/17/2021	5	730	146
PLANNED	11/17/2021	9	567	63
PLANNED	11/17/2021	4	520	130
PLANNED	11/17/2021	5	650	130
PLANNED	11/17/2021	8	32	4
PLANNED	11/17/2021	3	390	130
PLANNED	11/17/2021	6	18	3
PLANNED	11/17/2021	1	5	5
PLANNED	11/17/2021	3	12	4
PLANNED	11/17/2021	13	247	19
PLANNED	11/17/2021	5	405	81
PLANNED	11/17/2021	4	764	191
PLANNED	11/17/2021	1	153	153
PLANNED	11/17/2021	1	199	199
PLANNED	11/17/2021	7	819	117

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/17/2021	1	232	232
PLANNED	11/17/2021	4	64	16
PLANNED	11/17/2021	2	8	4
PLANNED	11/17/2021	3	30	10
PLANNED	11/17/2021	12	336	28
PLANNED	11/17/2021	56	448	8
PLANNED	11/17/2021	2	20	10
PLANNED	11/17/2021	11	1,375	125
PLANNED	11/17/2021	46	3,126	196
PLANNED	11/17/2021	1	6	6
PLANNED	11/17/2021	4	84	21
PLANNED	11/17/2021	5	825	165
PLANNED	11/17/2021	4	212	53
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	17	748	44
PLANNED	11/17/2021	2	8	4
PLANNED	11/17/2021	1	13	13
PLANNED	11/17/2021	12	372	31
PLANNED	11/17/2021	1	4	4
PLANNED	11/17/2021	13	273	21
PLANNED	11/17/2021	3	36	12
PLANNED	11/17/2021	1	8	8
PLANNED	11/17/2021	4	24	6
PLANNED	11/17/2021	1	108	108
PLANNED	11/17/2021	4	848	212
PLANNED	11/17/2021	4	500	125
PLANNED	11/17/2021	41	369	9
PLANNED	11/17/2021	5	345	69
PLANNED	11/17/2021	4	28	7
PLANNED	11/17/2021	3	60	20
PLANNED	11/17/2021	1	10	10
PLANNED	11/17/2021	2	14	7
PLANNED	11/17/2021	2	24	12
PLANNED	11/17/2021	1	10	10
PLANNED	11/17/2021	2	14	7
PLANNED	11/17/2021	2	298	149
PLANNED	11/17/2021	10	280	28
PLANNED	11/17/2021	12	2,724	227
PLANNED	11/17/2021	4	16	4
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	6	108	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/17/2021	6	48	8
PLANNED	11/17/2021	18	378	21
PLANNED	11/17/2021	2	8	4
PLANNED	11/17/2021	3	66	22
PLANNED	11/17/2021	2	50	25
PLANNED	11/17/2021	2	14	7
PLANNED	11/17/2021	1	4	4
PLANNED	11/17/2021	7	511	78
PLANNED	11/17/2021	6	642	107
PLANNED	11/17/2021	1	2	2
PLANNED	11/17/2021	5	45	9
PLANNED	11/17/2021	3	30	10
PLANNED	11/17/2021	8	744	93
PLANNED	11/17/2021	10	1,080	108
PLANNED	11/17/2021	4	372	93
PLANNED	11/17/2021	4	808	202
PLANNED	11/17/2021	4	212	53
PLANNED	11/17/2021	2	12	6
PLANNED	11/17/2021	1	9	9
PLANNED	11/17/2021	3	18	6
PLANNED	11/17/2021	4	248	62
PLANNED	11/17/2021	3	18	6
PLANNED	11/17/2021	3	339	113
PLANNED	11/17/2021	3	24	8
PLANNED	11/17/2021	4	280	70
PLANNED	11/17/2021	9	207	23
PLANNED	11/17/2021	10	1,960	196
PLANNED	11/17/2021	1	43	43
PLANNED	11/17/2021	5	55	11
PLANNED	11/17/2021	4	80	20
PLANNED	11/17/2021	2	174	87
PLANNED	11/17/2021	3	30	10
PLANNED	11/17/2021	1	32	32
PLANNED	11/17/2021	3	27	9
PLANNED	11/17/2021	9	4,167	463
PLANNED	11/17/2021	2	16	8
PLANNED	11/17/2021	4	52	13
PLANNED	11/17/2021	11	88	8
PLANNED	11/17/2021	3	435	145
PLANNED	11/17/2021	2	152	76
PLANNED	11/17/2021	3	325	192

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/17/2021	4	20	5
PLANNED	11/17/2021	1	13	13
PLANNED	11/17/2021	3	1,086	362
PLANNED	11/17/2021	4	196	49
PLANNED	11/17/2021	4	80	20
PLANNED	11/17/2021	18	36	2
PLANNED	11/17/2021	35	2,835	81
PLANNED	11/17/2021	2	26	13
PLANNED	11/17/2021	3	18	6
PLANNED	11/17/2021	9	369	41
PLANNED	11/17/2021	3	30	10
PLANNED	11/17/2021	4	408	102
PLANNED	11/17/2021	1	10	10
PLANNED	11/17/2021	2	26	13
PLANNED	11/17/2021	1	22	22
PLANNED	11/17/2021	5	325	65
PLANNED	11/17/2021	2	18	9
PLANNED	11/17/2021	4	64	16
PLANNED	11/17/2021	3	21	7
PLANNED	11/17/2021	3	324	108
PLANNED	11/17/2021	2	10	5
PLANNED	11/17/2021	3	396	132
PLANNED	11/17/2021	6	96	16
PLANNED	11/17/2021	4	240	60
PLANNED	11/17/2021	4	208	52
PLANNED	11/17/2021	5	65	13
PLANNED	11/17/2021	1	112	112
PLANNED	11/17/2021	6	150	25
PLANNED	11/17/2021	2	245	127
CUSTOMER REQUEST	11/17/2021	3	216	72
PLANNED	11/17/2021	1	25	25
PLANNED	11/17/2021	1	76	76
PLANNED	11/17/2021	1	22	22
PLANNED	11/17/2021	8	2,200	275
PLANNED	11/17/2021	10	210	21
PLANNED	11/17/2021	1	43	43
PLANNED	11/17/2021	1	143	143
PLANNED	11/17/2021	3	882	294
PLANNED	11/17/2021	1	251	251
PLANNED	11/17/2021	1	53	53
PLANNED	11/17/2021	3	396	132

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/18/2021	11	627	57
PLANNED	11/18/2021	8	1,800	225
PLANNED	11/18/2021	1	76	76
PLANNED	11/18/2021	1	15	15
PLANNED	11/18/2021	2	418	210
PLANNED	11/18/2021	76	7,980	105
PLANNED	11/18/2021	2	78	39
PLANNED	11/18/2021	1	59	59
PLANNED	11/18/2021	2	26	13
PLANNED	11/18/2021	4	156	39
PLANNED	11/18/2021	3	84	28
PLANNED	11/18/2021	4	480	120
PLANNED	11/18/2021	1	60	60
PLANNED	11/18/2021	2	120	60
PLANNED	11/18/2021	5	560	112
PLANNED	11/18/2021	5	80	16
PLANNED	11/18/2021	8	976	122
PLANNED	11/18/2021	9	1,098	122
PLANNED	11/18/2021	2	197	106
PLANNED	11/18/2021	36	7,524	209
PLANNED	11/18/2021	4	328	82
PLANNED	11/18/2021	6	312	52
PLANNED	11/18/2021	1	123	123
CUSTOMER REQUEST	11/18/2021	1	34	34
PLANNED	11/18/2021	1	13	13
PLANNED	11/18/2021	1	118	118
PLANNED	11/18/2021	3	216	72
PLANNED	11/18/2021	2	8	4
PLANNED	11/18/2021	1	198	198
PLANNED	11/18/2021	7	364	52
PLANNED	11/18/2021	4	144	36
PLANNED	11/18/2021	10	270	27
PLANNED	11/18/2021	1	47	47
PLANNED	11/18/2021	5	85	17
PLANNED	11/18/2021	4	96	24
PLANNED	11/18/2021	1	107	107
PLANNED	11/18/2021	23	1,840	80
PLANNED	11/18/2021	1	9	9
CUSTOMER REQUEST	11/18/2021	1	91	91
PLANNED	11/18/2021	2	66	33
PLANNED	11/18/2021	46	4,551	177

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/18/2021	13	481	37
CUSTOMER REQUEST	11/18/2021	1	163	163
PLANNED	11/18/2021	2	100	50
PLANNED	11/18/2021	3	80	43
PLANNED	11/18/2021	6	252	42
PLANNED	11/18/2021	2	126	63
PLANNED	11/18/2021	4	4	1
CUSTOMER REQUEST	11/18/2021	1	239	239
PLANNED	11/18/2021	2	14	7
PLANNED	11/18/2021	13	910	70
PLANNED	11/18/2021	8	1,408	176
CUSTOMER REQUEST	11/18/2021	9	18	2
CUSTOMER REQUEST	11/18/2021	10	30	3
PLANNED	11/18/2021	6	1,302	217
CUSTOMER REQUEST	11/18/2021	6	18	3
PLANNED	11/18/2021	2	312	156
PLANNED	11/18/2021	2	210	105
PLANNED	11/18/2021	2	132	66
PLANNED	11/18/2021	3	186	62
PLANNED	11/18/2021	1	13	13
PLANNED	11/18/2021	3	459	153
PLANNED	11/18/2021	127	8,382	66
PLANNED	11/18/2021	1	21	21
PLANNED	11/18/2021	4	96	24
PLANNED	11/18/2021	3	300	100
PLANNED	11/18/2021	2	6	3
PLANNED	11/18/2021	3	81	27
PLANNED	11/18/2021	6	96	16
PLANNED	11/18/2021	10	160	16
PLANNED	11/18/2021	5	80	16
PLANNED	11/18/2021	4	1,132	283
PLANNED	11/18/2021	50	2,350	47
PLANNED	11/18/2021	8	592	74
PLANNED	11/18/2021	3	477	159
PLANNED	11/18/2021	13	793	61
PLANNED	11/18/2021	4	36	9
PLANNED	11/18/2021	8	32	4
PLANNED	11/18/2021	9	126	14
PLANNED	11/18/2021	1	10	10
CUSTOMER REQUEST	11/18/2021	2	516	258
PLANNED	11/18/2021	26	442	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/18/2021	4	32	8
PLANNED	11/18/2021	8	1,136	142
PLANNED	11/18/2021	4	92	23
PLANNED	11/18/2021	3	45	15
PLANNED	11/18/2021	5	205	41
PLANNED	11/18/2021	3	27	9
PLANNED	11/18/2021	1	48	48
PLANNED	11/18/2021	7	420	60
PLANNED	11/18/2021	18	432	24
CUSTOMER REQUEST	11/18/2021	8	376	47
PLANNED	11/18/2021	8	752	94
PLANNED	11/18/2021	1	64	64
PLANNED	11/18/2021	3	84	28
PLANNED	11/18/2021	2	16	8
PLANNED	11/18/2021	4	68	17
PLANNED	11/18/2021	1	9	9
PLANNED	11/18/2021	3	54	18
PLANNED	11/18/2021	1	12	12
PLANNED	11/18/2021	7	350	50
PLANNED	11/18/2021	7	161	23
PLANNED	11/18/2021	2	44	22
PLANNED	11/18/2021	8	224	28
PLANNED	11/18/2021	1	13	13
PLANNED	11/18/2021	1	61	61
PLANNED	11/18/2021	5	170	34
PLANNED	11/18/2021	8	96	12
CUSTOMER REQUEST	11/18/2021	3	36	12
PLANNED	11/18/2021	4	60	15
PLANNED	11/18/2021	12	276	23
PLANNED	11/18/2021	1	21	21
PLANNED	11/18/2021	7	350	50
PLANNED	11/18/2021	4	240	60
PLANNED	11/18/2021	3	72	24
PLANNED	11/18/2021	2	32	16
CUSTOMER REQUEST	11/18/2021	1	27	27
CUSTOMER REQUEST	11/18/2021	1	233	233
PLANNED	11/18/2021	5	165	33
PLANNED	11/18/2021	1	219	219
PLANNED	11/18/2021	2	428	214
PLANNED	11/18/2021	14	1,302	93
PLANNED	11/18/2021	5	790	158

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/18/2021	1	158	158
PLANNED	11/18/2021	1	26	26
PLANNED	11/18/2021	1	19	19
PLANNED	11/18/2021	2	162	81
PLANNED	11/18/2021	7	329	47
PLANNED	11/18/2021	1	64	64
PLANNED	11/18/2021	2	24	12
PLANNED	11/18/2021	1	69	69
PLANNED	11/18/2021	1	212	212
PLANNED	11/18/2021	1	248	248
PLANNED	11/19/2021	8	2,176	272
PLANNED	11/19/2021	1	92	92
PLANNED	11/19/2021	1	97	97
PLANNED	11/19/2021	1	93	93
PLANNED	11/19/2021	1	70	70
PLANNED	11/19/2021	1	92	92
CUSTOMER REQUEST	11/19/2021	1	407	407
PLANNED	11/19/2021	1	119	119
PLANNED	11/19/2021	1	118	118
PLANNED	11/19/2021	5	460	92
PLANNED	11/19/2021	2	138	69
PLANNED	11/19/2021	7	1,141	163
PLANNED	11/19/2021	2	20	10
PLANNED	11/19/2021	3	360	120
PLANNED	11/19/2021	6	342	57
PLANNED	11/19/2021	7	2,331	333
PLANNED	11/19/2021	4	20	5
PLANNED	11/19/2021	2	10	5
PLANNED	11/19/2021	19	1,748	92
PLANNED	11/19/2021	4	20	5
PLANNED	11/19/2021	3	15	5
CUSTOMER REQUEST	11/19/2021	1	465	465
PLANNED	11/19/2021	3	221	114
PLANNED	11/19/2021	3	12	4
PLANNED	11/19/2021	3	12	4
PLANNED	11/19/2021	4	40	10
PLANNED	11/19/2021	3	24	8
PLANNED	11/19/2021	8	648	81
PLANNED	11/19/2021	11	154	14
PLANNED	11/19/2021	3	81	27
PLANNED	11/19/2021	1	72	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/19/2021	6	222	37
PLANNED	11/19/2021	1	2	2
PLANNED	11/19/2021	20	780	39
PLANNED	11/19/2021	27	189	7
CUSTOMER REQUEST	11/19/2021	1	45	45
PLANNED	11/19/2021	3	201	67
PLANNED	11/19/2021	4	28	7
CUSTOMER REQUEST	11/19/2021	1	47	47
CUSTOMER REQUEST	11/19/2021	21	10,962	522
PLANNED	11/19/2021	1	23	23
PLANNED	11/19/2021	3	345	115
PLANNED	11/19/2021	21	4,515	215
PLANNED	11/19/2021	2	10	5
PLANNED	11/19/2021	21	3,885	185
PLANNED	11/19/2021	21	4,263	203
CUSTOMER REQUEST	11/19/2021	87	16,617	191
PLANNED	11/19/2021	24	4,901	205
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	3	15	5
PLANNED	11/19/2021	4	24	6
PLANNED	11/19/2021	5	480	96
PLANNED	11/19/2021	3	21	7
PLANNED	11/19/2021	10	1,600	160
PLANNED	11/19/2021	5	1,255	251
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	2	92	46
PLANNED	11/19/2021	3	18	6
PLANNED	11/19/2021	2	144	72
PLANNED	11/19/2021	13	65	5
PLANNED	11/19/2021	4	264	66
CUSTOMER REQUEST	11/19/2021	8	2,176	272
PLANNED	11/19/2021	39	3,432	88
CUSTOMER REQUEST	11/19/2021	5	1,040	208
PLANNED	11/19/2021	1	53	53
PLANNED	11/19/2021	8	64	8
PLANNED	11/19/2021	6	492	82
PLANNED	11/19/2021	4	12	3
PLANNED	11/19/2021	4	48	12
PLANNED	11/19/2021	4	20	5
PLANNED	11/19/2021	4	24	6
PLANNED	11/19/2021	4	16	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/19/2021	3	472	197
PLANNED	11/19/2021	21	840	40
PLANNED	11/19/2021	1	18	18
PLANNED	11/19/2021	2	14	7
PLANNED	11/19/2021	6	1,206	201
PLANNED	11/19/2021	8	48	6
PLANNED	11/19/2021	4	28	7
PLANNED	11/19/2021	3	24	8
PLANNED	11/19/2021	2	14	7
PLANNED	11/19/2021	2	12	6
PLANNED	11/19/2021	2	114	57
PLANNED	11/19/2021	6	48	8
PLANNED	11/19/2021	1	61	61
PLANNED	11/19/2021	1	78	78
PLANNED	11/19/2021	1	81	81
PLANNED	11/19/2021	5	365	73
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	3	15	5
PLANNED	11/19/2021	5	40	8
PLANNED	11/19/2021	6	42	7
PLANNED	11/19/2021	5	415	83
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	2	22	11
PLANNED	11/19/2021	6	42	7
PLANNED	11/19/2021	1	58	58
PLANNED	11/19/2021	3	96	32
PLANNED	11/19/2021	5	150	30
PLANNED	11/19/2021	8	232	29
PLANNED	11/19/2021	221	44,421	201
PLANNED	11/19/2021	5	210	42
PLANNED	11/19/2021	3	15	5
PLANNED	11/19/2021	4	28	7
PLANNED	11/19/2021	2	12	6
PLANNED	11/19/2021	3	15	5
PLANNED	11/19/2021	3	18	6
PLANNED	11/19/2021	3	12	4
PLANNED	11/19/2021	3	705	235
PLANNED	11/19/2021	3	15	5
PLANNED	11/19/2021	3	18	6
PLANNED	11/19/2021	3	18	6
PLANNED	11/19/2021	4	20	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/19/2021	6	12	2
PLANNED	11/19/2021	1	10	10
PLANNED	11/19/2021	2	66	33
PLANNED	11/19/2021	16	400	25
PLANNED	11/19/2021	4	460	115
PLANNED	11/19/2021	4	364	91
PLANNED	11/19/2021	4	852	213
PLANNED	11/19/2021	1	19	19
PLANNED	11/19/2021	2	116	58
PLANNED	11/19/2021	2	12	6
PLANNED	11/19/2021	5	50	10
PLANNED	11/19/2021	4	40	10
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	4	24	6
PLANNED	11/19/2021	3	21	7
PLANNED	11/19/2021	4	40	10
PLANNED	11/19/2021	5	40	8
PLANNED	11/19/2021	5	30	6
PLANNED	11/19/2021	4	56	14
PLANNED	11/19/2021	1	52	52
PLANNED	11/19/2021	2	206	103
PLANNED	11/19/2021	1	59	59
PLANNED	11/19/2021	4	20	5
CUSTOMER REQUEST	11/19/2021	441	9,261	21
PLANNED	11/19/2021	5	5	1
PLANNED	11/19/2021	3	168	56
PLANNED	11/19/2021	4	48	12
PLANNED	11/19/2021	4	28	7
PLANNED	11/19/2021	4	32	8
PLANNED	11/19/2021	2	20	10
PLANNED	11/19/2021	3	21	7
PLANNED	11/19/2021	6	78	13
CUSTOMER REQUEST	11/19/2021	1	338	338
CUSTOMER REQUEST	11/19/2021	1	226	226
CUSTOMER REQUEST	11/19/2021	441	27,342	62
CUSTOMER REQUEST	11/19/2021	1	271	271
PLANNED	11/19/2021	32	2,624	82
CUSTOMER REQUEST	11/19/2021	1	98	98
CUSTOMER REQUEST	11/19/2021	21	1,575	75
CUSTOMER REQUEST	11/19/2021	1	91	91
PLANNED	11/19/2021	1	238	238

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/19/2021	1	350	350
PLANNED	11/19/2021	6	1,689	346
PLANNED	11/19/2021	15	1,875	125
PLANNED	11/20/2021	9	2,970	330
PLANNED	11/20/2021	5	45	9
PLANNED	11/20/2021	3	390	130
PLANNED	11/20/2021	1	6	6
PLANNED	11/20/2021	2	48	24
PLANNED	11/20/2021	8	528	66
PLANNED	11/20/2021	2	378	189
PLANNED	11/20/2021	3	363	170
PLANNED	11/20/2021	20	3,640	182
PLANNED	11/20/2021	6	318	53
PLANNED	11/20/2021	8	1,392	174
PLANNED	11/20/2021	4	16	4
PLANNED	11/20/2021	1	178	178
PLANNED	11/20/2021	1	29	29
PLANNED	11/20/2021	3	1,125	375
PLANNED	11/20/2021	2	196	98
PLANNED	11/20/2021	7	826	118
PLANNED	11/20/2021	7	1,043	149
PLANNED	11/20/2021	9	1,737	193
PLANNED	11/20/2021	11	132	12
PLANNED	11/20/2021	16	1,128	82
PLANNED	11/20/2021	2	414	207
PLANNED	11/20/2021	12	540	45
PLANNED	11/20/2021	1	113	113
PLANNED	11/20/2021	1	145	145
PLANNED	11/20/2021	2	224	112
PLANNED	11/20/2021	2	226	113
PLANNED	11/20/2021	11	1,738	158
PLANNED	11/20/2021	6	1,611	270
PLANNED	11/20/2021	5	390	78
CUSTOMER REQUEST	11/20/2021	1	71	71
PLANNED	11/20/2021	4	344	86
PLANNED	11/20/2021	1	87	87
CUSTOMER REQUEST	11/20/2021	1	221	221
PLANNED	11/20/2021	2	52	26
PLANNED	11/21/2021	4	372	93
PLANNED	11/21/2021	6	60	10
PLANNED	11/21/2021	8	922	245

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/21/2021	3	273	91
PLANNED	11/21/2021	1	93	93
PLANNED	11/21/2021	20	60	3
PLANNED	11/21/2021	7	1,120	160
PLANNED	11/21/2021	7	616	88
PLANNED	11/21/2021	6	540	90
PLANNED	11/21/2021	2	198	99
CUSTOMER REQUEST	11/21/2021	4	576	144
PLANNED	11/21/2021	8	232	29
PLANNED	11/21/2021	1	39	39
PLANNED	11/22/2021	15	2,970	198
PLANNED	11/22/2021	1	43	43
PLANNED	11/22/2021	2	34	17
PLANNED	11/22/2021	7	797	179
PLANNED	11/22/2021	3	288	96
PLANNED	11/22/2021	3	501	167
PLANNED	11/22/2021	1	43	43
PLANNED	11/22/2021	4	264	66
PLANNED	11/22/2021	1	133	133
PLANNED	11/22/2021	6	54	9
PLANNED	11/22/2021	6	36	6
PLANNED	11/22/2021	18	522	29
PLANNED	11/22/2021	3	15	5
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	3	45	15
PLANNED	11/22/2021	4	112	28
PLANNED	11/22/2021	14	1,442	103
PLANNED	11/22/2021	4	344	86
PLANNED	11/22/2021	5	275	55
PLANNED	11/22/2021	3	240	80
PLANNED	11/22/2021	4	72	18
PLANNED	11/22/2021	13	832	64
PLANNED	11/22/2021	15	840	56
PLANNED	11/22/2021	12	792	66
PLANNED	11/22/2021	12	900	75
PLANNED	11/22/2021	8	448	56
PLANNED	11/22/2021	2	22	11
PLANNED	11/22/2021	8	1,120	140
PLANNED	11/22/2021	6	840	140
CUSTOMER REQUEST	11/22/2021	7	616	88

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	2	200	100
CUSTOMER REQUEST	11/22/2021	1	256	256
PLANNED	11/22/2021	8	104	13
CUSTOMER REQUEST	11/22/2021	170	20,230	119
PLANNED	11/22/2021	11	220	20
PLANNED	11/22/2021	9	747	83
PLANNED	11/22/2021	2	274	137
CUSTOMER REQUEST	11/22/2021	35	1,330	38
PLANNED	11/22/2021	3	60	20
PLANNED	11/22/2021	4	36	9
PLANNED	11/22/2021	3	39	13
PLANNED	11/22/2021	1	18	18
PLANNED	11/22/2021	4	36	9
PLANNED	11/22/2021	2	10	5
PLANNED	11/22/2021	3	60	20
PLANNED	11/22/2021	1	111	111
PLANNED	11/22/2021	2	24	12
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	3	9	3
PLANNED	11/22/2021	2	16	8
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	1	146	146
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	7	203	29
PLANNED	11/22/2021	14	770	55
PLANNED	11/22/2021	2	342	171
PLANNED	11/22/2021	10	60	6
PLANNED	11/22/2021	2	300	150
PLANNED	11/22/2021	2	178	89
PLANNED	11/22/2021	7	371	53
PLANNED	11/22/2021	15	90	6
PLANNED	11/22/2021	3	15	5
PLANNED	11/22/2021	7	2,019	291
PLANNED	11/22/2021	3	18	6
PLANNED	11/22/2021	1	9	9
PLANNED	11/22/2021	5	85	17
PLANNED	11/22/2021	1	124	124
PLANNED	11/22/2021	4	128	32
PLANNED	11/22/2021	2	166	83

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	2	42	21
PLANNED	11/22/2021	4	100	25
PLANNED	11/22/2021	2	24	12
PLANNED	11/22/2021	19	1,465	99
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	1	90	90
PLANNED	11/22/2021	2	24	12
PLANNED	11/22/2021	1	43	43
PLANNED	11/22/2021	4	72	18
PLANNED	11/22/2021	4	1,144	286
PLANNED	11/22/2021	17	204	12
PLANNED	11/22/2021	7	63	9
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	2	22	11
PLANNED	11/22/2021	4	36	9
PLANNED	11/22/2021	4	40	10
PLANNED	11/22/2021	4	36	9
PLANNED	11/22/2021	5	10	2
PLANNED	11/22/2021	5	50	10
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	2	8	4
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	3	30	10
PLANNED	11/22/2021	14	196	14
PLANNED	11/22/2021	3	147	49
PLANNED	11/22/2021	2	58	29
PLANNED	11/22/2021	4	32	8
PLANNED	11/22/2021	5	390	78
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	2	30	15
PLANNED	11/22/2021	7	1,092	156
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	3	33	11
PLANNED	11/22/2021	4	204	51
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	21	1,365	65
PLANNED	11/22/2021	3	18	6
PLANNED	11/22/2021	3	15	5
PLANNED	11/22/2021	5	35	7
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	4	20	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	7	105	15
PLANNED	11/22/2021	1	2	2
PLANNED	11/22/2021	3	705	235
PLANNED	11/22/2021	1	43	43
PLANNED	11/22/2021	5	35	7
PLANNED	11/22/2021	4	128	32
PLANNED	11/22/2021	4	48	12
PLANNED	11/22/2021	4	36	9
PLANNED	11/22/2021	2	14	7
PLANNED	11/22/2021	4	40	10
PLANNED	11/22/2021	8	872	109
PLANNED	11/22/2021	7	1,449	207
PLANNED	11/22/2021	4	12	3
CUSTOMER REQUEST	11/22/2021	9	306	34
PLANNED	11/22/2021	1	11	11
PLANNED	11/22/2021	4	32	8
PLANNED	11/22/2021	4	112	28
PLANNED	11/22/2021	2	22	11
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	3	327	109
PLANNED	11/22/2021	8	232	29
PLANNED	11/22/2021	2	310	155
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	5	35	7
PLANNED	11/22/2021	2	8	4
PLANNED	11/22/2021	3	15	5
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	5	20	4
PLANNED	11/22/2021	3	21	7
PLANNED	11/22/2021	13	143	11
PLANNED	11/22/2021	2	196	98
PLANNED	11/22/2021	6	30	5
PLANNED	11/22/2021	1	103	103
PLANNED	11/22/2021	7	21	3
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	2	16	8
PLANNED	11/22/2021	1	14	14
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	5	260	52
PLANNED	11/22/2021	2	90	45
PLANNED	11/22/2021	4	28	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	2	12	6
PLANNED	11/22/2021	2	18	9
PLANNED	11/22/2021	9	684	76
PLANNED	11/22/2021	1	16	16
PLANNED	11/22/2021	4	64	16
PLANNED	11/22/2021	1	148	148
PLANNED	11/22/2021	3	18	6
PLANNED	11/22/2021	4	80	20
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	33	1,782	54
PLANNED	11/22/2021	3	66	22
PLANNED	11/22/2021	2	22	11
PLANNED	11/22/2021	2	250	125
PLANNED	11/22/2021	4	112	28
PLANNED	11/22/2021	10	980	98
PLANNED	11/22/2021	1	49	49
PLANNED	11/22/2021	1	10	10
PLANNED	11/22/2021	2	60	30
PLANNED	11/22/2021	23	4,347	189
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	4	32	8
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	2	18	9
PLANNED	11/22/2021	4	40	10
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	3	27	9
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	11	1,161	131
PLANNED	11/22/2021	3	24	8
PLANNED	11/22/2021	3	33	11
PLANNED	11/22/2021	1	109	109
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	2	14	7
PLANNED	11/22/2021	3	6	2
PLANNED	11/22/2021	4	16	4
PLANNED	11/22/2021	4	40	10
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	4	52	13
PLANNED	11/22/2021	4	24	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	1	8	8
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	3	18	6
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	2	30	15
PLANNED	11/22/2021	3	30	10
PLANNED	11/22/2021	8	96	12
PLANNED	11/22/2021	4	64	16
PLANNED	11/22/2021	16	2,176	136
PLANNED	11/22/2021	3	12	4
PLANNED	11/22/2021	12	84	7
PLANNED	11/22/2021	1	11	11
PLANNED	11/22/2021	5	35	7
PLANNED	11/22/2021	2	20	10
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	3	21	7
PLANNED	11/22/2021	2	12	6
PLANNED	11/22/2021	3	129	43
PLANNED	11/22/2021	2	290	145
PLANNED	11/22/2021	4	40	10
PLANNED	11/22/2021	4	76	19
PLANNED	11/22/2021	2	14	7
PLANNED	11/22/2021	18	1,476	82
PLANNED	11/22/2021	4	32	8
PLANNED	11/22/2021	5	35	7
PLANNED	11/22/2021	2	36	18
PLANNED	11/22/2021	1	25	25
PLANNED	11/22/2021	3	186	62
PLANNED	11/22/2021	1	4	4
PLANNED	11/22/2021	3	27	9
PLANNED	11/22/2021	2	140	70
PLANNED	11/22/2021	1	3	3
PLANNED	11/22/2021	3	24	8
PLANNED	11/22/2021	1	115	115
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	2	14	7
PLANNED	11/22/2021	2	148	74
PLANNED	11/22/2021	1	7	7
PLANNED	11/22/2021	5	45	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/22/2021	1	73	73
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	4	20	5
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	4	28	7
PLANNED	11/22/2021	4	292	73
PLANNED	11/22/2021	1	4	4
CUSTOMER REQUEST	11/22/2021	1	170	170
PLANNED	11/22/2021	2	190	95
PLANNED	11/22/2021	4	24	6
PLANNED	11/22/2021	5	30	6
PLANNED	11/22/2021	7	42	6
PLANNED	11/22/2021	7	665	95
PLANNED	11/22/2021	1	50	50
CUSTOMER REQUEST	11/22/2021	1	99	99
PLANNED	11/22/2021	1	92	92
CUSTOMER REQUEST	11/22/2021	1	598	598
PLANNED	11/22/2021	1	37	37
PLANNED	11/22/2021	5	1,115	223
PLANNED	11/22/2021	1	70	70
CUSTOMER REQUEST	11/22/2021	1	288	288
PLANNED	11/22/2021	4	936	234
PLANNED	11/22/2021	1	152	152
PLANNED	11/22/2021	38	228	6
PLANNED	11/22/2021	17	2,040	120
PLANNED	11/22/2021	2	126	63
PLANNED	11/22/2021	1	101	101
PLANNED	11/22/2021	1	318	318
PLANNED	11/23/2021	1	155	155
PLANNED	11/23/2021	505	4,040	8
PLANNED	11/23/2021	7	644	92
PLANNED	11/23/2021	2	312	156
PLANNED	11/23/2021	2	52	26
PLANNED	11/23/2021	1	223	223
PLANNED	11/23/2021	25	2,275	91
PLANNED	11/23/2021	1	104	104
PLANNED	11/23/2021	2	170	85
PLANNED	11/23/2021	1	95	95
PLANNED	11/23/2021	2	100	51
PLANNED	11/23/2021	7	987	141
PLANNED	11/23/2021	5	215	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/23/2021	1	10	10
PLANNED	11/23/2021	3	96	32
PLANNED	11/23/2021	2	241	179
PLANNED	11/23/2021	2	284	142
PLANNED	11/23/2021	4	20	5
PLANNED	11/23/2021	16	2,752	172
PLANNED	11/23/2021	6	606	101
PLANNED	11/23/2021	3	441	147
PLANNED	11/23/2021	8	360	45
PLANNED	11/23/2021	5	45	9
PLANNED	11/23/2021	3	489	163
CUSTOMER REQUEST	11/23/2021	10	1,610	161
PLANNED	11/23/2021	5	25	5
PLANNED	11/23/2021	5	560	112
CUSTOMER REQUEST	11/23/2021	198	4,752	24
PLANNED	11/23/2021	3	222	74
PLANNED	11/23/2021	14	1,496	192
PLANNED	11/23/2021	5	560	112
PLANNED	11/23/2021	20	1,700	85
PLANNED	11/23/2021	17	544	32
PLANNED	11/23/2021	17	1,547	91
PLANNED	11/23/2021	19	1,596	84
PLANNED	11/23/2021	2	96	48
CUSTOMER REQUEST	11/23/2021	18	1,332	74
PLANNED	11/23/2021	9	1,998	222
PLANNED	11/23/2021	2	48	24
PLANNED	11/23/2021	1	239	239
PLANNED	11/23/2021	3	275	169
PLANNED	11/23/2021	10	780	78
PLANNED	11/23/2021	5	785	157
PLANNED	11/23/2021	9	549	61
PLANNED	11/23/2021	7	1,092	156
PLANNED	11/23/2021	6	942	157
CUSTOMER REQUEST	11/23/2021	2	78	39
PLANNED	11/23/2021	8	1,264	158
PLANNED	11/23/2021	13	1,586	122
PLANNED	11/23/2021	4	116	29
PLANNED	11/23/2021	2	70	35
PLANNED	11/23/2021	1	75	75
PLANNED	11/23/2021	4	100	25
PLANNED	11/23/2021	3	153	51

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/23/2021	5	185	37
PLANNED	11/23/2021	8	808	101
PLANNED	11/23/2021	7	567	81
PLANNED	11/23/2021	4	600	150
PLANNED	11/23/2021	1	16	16
PLANNED	11/23/2021	6	486	81
PLANNED	11/23/2021	1	6	6
PLANNED	11/23/2021	183	7,485	112
PLANNED	11/23/2021	27	2,592	96
PLANNED	11/23/2021	18	1,944	108
PLANNED	11/23/2021	3	9	3
PLANNED	11/23/2021	7	182	26
PLANNED	11/23/2021	3	1,008	336
PLANNED	11/23/2021	6	60	10
PLANNED	11/23/2021	4	1,088	272
PLANNED	11/23/2021	4	28	7
PLANNED	11/23/2021	3	78	26
PLANNED	11/23/2021	3	492	164
PLANNED	11/23/2021	2	68	34
PLANNED	11/23/2021	1	9	9
PLANNED	11/23/2021	1	16	16
PLANNED	11/23/2021	1	333	333
PLANNED	11/23/2021	8	8	1
PLANNED	11/23/2021	9	279	31
PLANNED	11/23/2021	4	180	45
PLANNED	11/23/2021	4	28	7
PLANNED	11/23/2021	5	25	5
CUSTOMER REQUEST	11/23/2021	5	500	100
CUSTOMER REQUEST	11/23/2021	10	280	28
PLANNED	11/23/2021	3	204	68
PLANNED	11/23/2021	3	27	9
PLANNED	11/23/2021	2	10	5
PLANNED	11/23/2021	2	18	9
PLANNED	11/23/2021	7	595	85
PLANNED	11/23/2021	7	546	78
PLANNED	11/23/2021	46	506	11
PLANNED	11/23/2021	4	192	48
PLANNED	11/23/2021	3	225	75
PLANNED	11/23/2021	3	60	20
PLANNED	11/23/2021	5	580	116
PLANNED	11/23/2021	4	272	68

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/23/2021	4	116	29
PLANNED	11/23/2021	1	9	9
PLANNED	11/23/2021	2	20	10
PLANNED	11/23/2021	70	1,610	23
PLANNED	11/23/2021	2	6	3
PLANNED	11/23/2021	3	24	8
PLANNED	11/23/2021	5	450	90
PLANNED	11/23/2021	3	252	84
PLANNED	11/23/2021	4	44	11
PLANNED	11/23/2021	2	18	9
PLANNED	11/23/2021	81	22,275	275
PLANNED	11/23/2021	2	92	46
PLANNED	11/23/2021	9	891	99
PLANNED	11/23/2021	4	20	5
PLANNED	11/23/2021	2	178	89
PLANNED	11/23/2021	2	70	35
PLANNED	11/23/2021	3	150	50
PLANNED	11/23/2021	3	222	74
PLANNED	11/23/2021	3	405	135
PLANNED	11/23/2021	4	108	27
PLANNED	11/23/2021	1	86	86
PLANNED	11/23/2021	4	164	41
PLANNED	11/23/2021	3	36	12
PLANNED	11/23/2021	5	350	70
PLANNED	11/23/2021	2	182	91
PLANNED	11/23/2021	3	30	10
PLANNED	11/23/2021	2	22	11
PLANNED	11/23/2021	1	7	7
PLANNED	11/23/2021	1	75	75
PLANNED	11/23/2021	15	1,110	74
PLANNED	11/23/2021	4	56	14
PLANNED	11/23/2021	2	22	11
PLANNED	11/23/2021	1	98	98
PLANNED	11/23/2021	3	234	78
PLANNED	11/23/2021	1	9	9
PLANNED	11/23/2021	4	668	167
PLANNED	11/23/2021	4	628	157
PLANNED	11/23/2021	2	20	10
PLANNED	11/23/2021	2	100	50
PLANNED	11/23/2021	1	11	11
PLANNED	11/23/2021	7	945	135

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/23/2021	1	23	23
PLANNED	11/23/2021	4	408	102
PLANNED	11/23/2021	1	113	113
PLANNED	11/23/2021	9	225	25
PLANNED	11/23/2021	46	920	20
PLANNED	11/23/2021	1	65	65
PLANNED	11/23/2021	2	156	78
PLANNED	11/23/2021	1	41	41
CUSTOMER REQUEST	11/23/2021	1	185	185
CUSTOMER REQUEST	11/23/2021	1	153	153
PLANNED	11/23/2021	1	101	101
PLANNED	11/23/2021	3	573	191
PLANNED	11/23/2021	8	3,720	465
PLANNED	11/23/2021	2	258	129
PLANNED	11/23/2021	3	204	68
PLANNED	11/23/2021	1	60	60
PLANNED	11/23/2021	5	1,160	232
PLANNED	11/23/2021	1	86	86
PLANNED	11/23/2021	1	93	93
PLANNED	11/24/2021	1	50	50
PLANNED	11/24/2021	1	50	50
PLANNED	11/24/2021	1	139	139
PLANNED	11/24/2021	1	77	77
PLANNED	11/24/2021	1	36	36
PLANNED	11/24/2021	11	275	25
PLANNED	11/24/2021	3	303	101
PLANNED	11/24/2021	1	197	197
CUSTOMER REQUEST	11/24/2021	1	123	123
PLANNED	11/24/2021	1	186	186
PLANNED	11/24/2021	1	284	284
PLANNED	11/24/2021	1	51	51
PLANNED	11/24/2021	2	8	4
PLANNED	11/24/2021	1	155	155
PLANNED	11/24/2021	7	1,722	246
CUSTOMER REQUEST	11/24/2021	72	2,088	29
PLANNED	11/24/2021	15	2,520	168
PLANNED	11/24/2021	1	98	98
PLANNED	11/24/2021	1	38	38
PLANNED	11/24/2021	1	55	55
PLANNED	11/24/2021	1	36	36
PLANNED	11/24/2021	1	31	31

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/24/2021	33	7,062	214
PLANNED	11/24/2021	2	30	15
PLANNED	11/24/2021	7	539	77
PLANNED	11/24/2021	2	4	2
PLANNED	11/24/2021	1	41	41
PLANNED	11/24/2021	50	171	122
PLANNED	11/24/2021	2	194	97
PLANNED	11/24/2021	7	364	52
PLANNED	11/24/2021	11	506	46
PLANNED	11/24/2021	51	5,508	108
CUSTOMER REQUEST	11/24/2021	4	140	35
PLANNED	11/24/2021	3	99	33
PLANNED	11/24/2021	7	147	21
PLANNED	11/24/2021	1	32	32
PLANNED	11/24/2021	5	546	151
PLANNED	11/24/2021	9	54	6
PLANNED	11/24/2021	1	118	118
PLANNED	11/24/2021	2	130	65
PLANNED	11/24/2021	5	70	14
PLANNED	11/24/2021	3	135	45
CUSTOMER REQUEST	11/24/2021	1	17	17
PLANNED	11/24/2021	5	560	112
PLANNED	11/24/2021	5	115	23
PLANNED	11/24/2021	2	28	14
PLANNED	11/24/2021	3	168	56
PLANNED	11/24/2021	4	8	2
PLANNED	11/24/2021	1	213	213
PLANNED	11/24/2021	2	206	103
PLANNED	11/24/2021	4	704	176
PLANNED	11/24/2021	5	815	163
PLANNED	11/24/2021	1	5	5
PLANNED	11/24/2021	5	130	26
PLANNED	11/24/2021	4	208	52
PLANNED	11/24/2021	1	12	12
PLANNED	11/24/2021	3	267	89
PLANNED	11/24/2021	3	303	101
PLANNED	11/24/2021	1	38	38
PLANNED	11/24/2021	1	16	16
PLANNED	11/24/2021	5	70	14
PLANNED	11/24/2021	2	10	5
CUSTOMER REQUEST	11/24/2021	1	149	149

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/24/2021	1	56	56
PLANNED	11/24/2021	6	138	23
PLANNED	11/24/2021	18	1,800	100
PLANNED	11/24/2021	1	167	167
PLANNED	11/24/2021	1	30	30
CUSTOMER REQUEST	11/24/2021	1	393	393
PLANNED	11/24/2021	1	12	12
PLANNED	11/24/2021	3	204	68
PLANNED	11/24/2021	6	516	86
CUSTOMER REQUEST	11/24/2021	1	15	15
CUSTOMER REQUEST	11/24/2021	1	342	342
CUSTOMER REQUEST	11/24/2021	1	64	64
CUSTOMER REQUEST	11/24/2021	1	83	83
PLANNED	11/24/2021	2	112	56
PLANNED	11/24/2021	1	59	59
PLANNED	11/24/2021	2	166	83
PLANNED	11/24/2021	1	81	81
PLANNED	11/24/2021	8	208	26
PLANNED	11/24/2021	1	69	69
PLANNED	11/24/2021	13	1,092	84
PLANNED	11/24/2021	5	380	76
CUSTOMER REQUEST	11/25/2021	11	121	11
CUSTOMER REQUEST	11/25/2021	3	39	13
CUSTOMER REQUEST	11/25/2021	1	72	72
CUSTOMER REQUEST	11/26/2021	871	21,775	25
PLANNED	11/27/2021	28	84	3
PLANNED	11/27/2021	2	28	14
PLANNED	11/27/2021	6	132	22
CUSTOMER REQUEST	11/27/2021	1	38	38
CUSTOMER REQUEST	11/27/2021	4	6,488	1,622
PLANNED	11/28/2021	2	250	125
PLANNED	11/28/2021	2	28	14
PLANNED	11/28/2021	5	335	67
CUSTOMER REQUEST	11/28/2021	2	684	342
PLANNED	11/29/2021	1	35	35
PLANNED	11/29/2021	1	158	158
PLANNED	11/29/2021	105	630	6
PLANNED	11/29/2021	7	1,085	155
PLANNED	11/29/2021	1	122	122
PLANNED	11/29/2021	1	4	4
PLANNED	11/29/2021	1	4	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/29/2021	3	15	5
PLANNED	11/29/2021	3	12	4
PLANNED	11/29/2021	3	18	6
PLANNED	11/29/2021	5	455	91
PLANNED	11/29/2021	3	18	6
PLANNED	11/29/2021	2	4	2
PLANNED	11/29/2021	6	48	8
PLANNED	11/29/2021	3	39	13
PLANNED	11/29/2021	6	42	7
PLANNED	11/29/2021	4	28	7
PLANNED	11/29/2021	3	51	17
PLANNED	11/29/2021	5	45	9
PLANNED	11/29/2021	4	64	16
PLANNED	11/29/2021	1	22	22
CUSTOMER REQUEST	11/29/2021	4	1,096	274
PLANNED	11/29/2021	4	276	69
CUSTOMER REQUEST	11/29/2021	5	1,120	224
CUSTOMER REQUEST	11/29/2021	2	450	225
PLANNED	11/29/2021	1	33	33
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	7	600	118
PLANNED	11/29/2021	2	180	90
PLANNED	11/29/2021	47	8,460	180
PLANNED	11/29/2021	6	612	102
PLANNED	11/29/2021	78	5,289	74
PLANNED	11/29/2021	4	300	75
PLANNED	11/29/2021	4	260	65
CUSTOMER REQUEST	11/29/2021	10	910	91
PLANNED	11/29/2021	1	58	58
PLANNED	11/29/2021	6	732	122
PLANNED	11/29/2021	2	158	79
CUSTOMER REQUEST	11/29/2021	1	67	67
PLANNED	11/29/2021	3	12	4
PLANNED	11/29/2021	9	162	18
PLANNED	11/29/2021	4	16	4
PLANNED	11/29/2021	5	120	24
PLANNED	11/29/2021	3	18	6
PLANNED	11/29/2021	3	27	9
PLANNED	11/29/2021	3	9	3
PLANNED	11/29/2021	6	642	107
PLANNED	11/29/2021	11	924	84

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/29/2021	1	10	10
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	4	88	22
PLANNED	11/29/2021	4	52	13
PLANNED	11/29/2021	7	861	123
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	4	24	6
PLANNED	11/29/2021	1	7	7
PLANNED	11/29/2021	1	146	146
PLANNED	11/29/2021	3	30	10
PLANNED	11/29/2021	2	22	11
PLANNED	11/29/2021	2	76	38
PLANNED	11/29/2021	3	6	2
PLANNED	11/29/2021	1	11	11
PLANNED	11/29/2021	14	1,736	124
PLANNED	11/29/2021	4	84	21
PLANNED	11/29/2021	6	282	47
PLANNED	11/29/2021	2	12	6
PLANNED	11/29/2021	3	33	11
PLANNED	11/29/2021	3	57	19
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	1	8	8
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	4	68	17
PLANNED	11/29/2021	4	48	12
PLANNED	11/29/2021	4	32	8
PLANNED	11/29/2021	3	30	10
PLANNED	11/29/2021	4	220	55
PLANNED	11/29/2021	10	2,550	255
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	23	1,127	49
PLANNED	11/29/2021	1	17	17
PLANNED	11/29/2021	2	14	7
CUSTOMER REQUEST	11/29/2021	1	52	52
PLANNED	11/29/2021	4	16	4
PLANNED	11/29/2021	2	6	3
PLANNED	11/29/2021	4	20	5
PLANNED	11/29/2021	3	528	176
PLANNED	11/29/2021	3	12	4
PLANNED	11/29/2021	4	20	5
PLANNED	11/29/2021	1	89	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/29/2021	1	36	36
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	4	36	9
PLANNED	11/29/2021	4	372	93
PLANNED	11/29/2021	3	36	12
PLANNED	11/29/2021	6	894	149
PLANNED	11/29/2021	5	475	95
PLANNED	11/29/2021	17	4,335	255
PLANNED	11/29/2021	15	3,990	266
PLANNED	11/29/2021	19	4,636	244
CUSTOMER REQUEST	11/29/2021	1	181	181
PLANNED	11/29/2021	9	2,097	233
PLANNED	11/29/2021	2	12	6
PLANNED	11/29/2021	29	2,842	98
PLANNED	11/29/2021	10	90	9
CUSTOMER REQUEST	11/29/2021	3	144	48
PLANNED	11/29/2021	3	30	10
CUSTOMER REQUEST	11/29/2021	1	355	355
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	1	164	164
PLANNED	11/29/2021	11	462	42
PLANNED	11/29/2021	1	7	7
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	3	45	15
PLANNED	11/29/2021	4	16	4
PLANNED	11/29/2021	3	21	7
PLANNED	11/29/2021	4	16	4
PLANNED	11/29/2021	4	16	4
PLANNED	11/29/2021	1	8	8
PLANNED	11/29/2021	5	265	53
PLANNED	11/29/2021	4	84	21
CUSTOMER REQUEST	11/29/2021	7	154	22
PLANNED	11/29/2021	1	4	4
PLANNED	11/29/2021	4	36	9
PLANNED	11/29/2021	11	220	20
PLANNED	11/29/2021	3	24	8
PLANNED	11/29/2021	7	798	114
PLANNED	11/29/2021	5	90	18
PLANNED	11/29/2021	5	50	10
PLANNED	11/29/2021	12	180	15
PLANNED	11/29/2021	1	84	84

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/29/2021	1	7	7
PLANNED	11/29/2021	4	28	7
PLANNED	11/29/2021	8	104	13
PLANNED	11/29/2021	5	35	7
PLANNED	11/29/2021	2	12	6
PLANNED	11/29/2021	1	9	9
PLANNED	11/29/2021	4	244	61
PLANNED	11/29/2021	4	344	86
PLANNED	11/29/2021	6	588	98
PLANNED	11/29/2021	8	144	18
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	2	12	6
PLANNED	11/29/2021	1	59	59
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	2	16	8
PLANNED	11/29/2021	5	35	7
PLANNED	11/29/2021	5	60	12
PLANNED	11/29/2021	4	52	13
PLANNED	11/29/2021	3	135	45
PLANNED	11/29/2021	2	22	11
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	1	315	315
PLANNED	11/29/2021	9	387	43
PLANNED	11/29/2021	1	119	119
PLANNED	11/29/2021	3	21	7
PLANNED	11/29/2021	3	12	4
PLANNED	11/29/2021	10	100	10
PLANNED	11/29/2021	3	12	4
PLANNED	11/29/2021	7	28	4
PLANNED	11/29/2021	5	40	8
PLANNED	11/29/2021	1	7	7
PLANNED	11/29/2021	3	51	17
PLANNED	11/29/2021	3	135	45
PLANNED	11/29/2021	10	120	12
PLANNED	11/29/2021	11	473	43
PLANNED	11/29/2021	3	261	87
PLANNED	11/29/2021	13	91	7
PLANNED	11/29/2021	2	34	17
PLANNED	11/29/2021	1	10	10
PLANNED	11/29/2021	4	48	12
PLANNED	11/29/2021	6	30	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	11/29/2021	3	657	219
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	3	36	12
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	2	30	15
PLANNED	11/29/2021	1	12	12
PLANNED	11/29/2021	11	649	59
PLANNED	11/29/2021	1	141	141
PLANNED	11/29/2021	3	162	54
PLANNED	11/29/2021	1	13	13
PLANNED	11/29/2021	4	20	5
PLANNED	11/29/2021	9	315	35
PLANNED	11/29/2021	7	392	56
PLANNED	11/29/2021	2	156	78
PLANNED	11/29/2021	7	119	17
PLANNED	11/29/2021	1	10	10
PLANNED	11/29/2021	4	76	19
PLANNED	11/29/2021	4	28	7
PLANNED	11/29/2021	4	108	27
PLANNED	11/29/2021	4	32	8
PLANNED	11/29/2021	1	31	31
PLANNED	11/29/2021	1	14	14
CUSTOMER REQUEST	11/29/2021	1	69	69
PLANNED	11/29/2021	2	114	57
PLANNED	11/29/2021	3	18	6
PLANNED	11/29/2021	2	94	47
PLANNED	11/29/2021	4	32	8
PLANNED	11/29/2021	4	36	9
PLANNED	11/29/2021	4	48	12
PLANNED	11/29/2021	3	36	12
CUSTOMER REQUEST	11/29/2021	5	155	31
PLANNED	11/29/2021	2	40	20
PLANNED	11/29/2021	2	32	16
PLANNED	11/29/2021	5	55	11
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	1	15	15
PLANNED	11/29/2021	4	24	6
PLANNED	11/29/2021	21	1,701	81
PLANNED	11/29/2021	10	170	17
PLANNED	11/29/2021	2	72	36
PLANNED	11/29/2021	8	616	77

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/29/2021	4	32	8
PLANNED	11/29/2021	4	36	9
PLANNED	11/29/2021	2	12	6
PLANNED	11/29/2021	1	6	6
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	2	14	7
PLANNED	11/29/2021	4	24	6
PLANNED	11/29/2021	5	40	8
PLANNED	11/29/2021	3	39	13
PLANNED	11/29/2021	3	33	11
PLANNED	11/29/2021	4	204	51
PLANNED	11/29/2021	1	75	75
PLANNED	11/29/2021	21	1,323	63
CUSTOMER REQUEST	11/29/2021	1	249	249
PLANNED	11/29/2021	10	1,720	172
PLANNED	11/29/2021	10	840	84
PLANNED	11/29/2021	4	40	10
PLANNED	11/29/2021	4	52	13
PLANNED	11/29/2021	4	32	8
PLANNED	11/29/2021	2	22	11
PLANNED	11/29/2021	4	68	17
CUSTOMER REQUEST	11/29/2021	1	111	111
PLANNED	11/29/2021	12	2,016	168
PLANNED	11/29/2021	2	18	9
PLANNED	11/29/2021	9	585	65
PLANNED	11/29/2021	3	588	196
PLANNED	11/29/2021	1	212	212
PLANNED	11/29/2021	2	112	56
PLANNED	11/29/2021	21	2,184	104
PLANNED	11/29/2021	1	122	122
PLANNED	11/29/2021	4	432	108
PLANNED	11/29/2021	1	263	263
PLANNED	11/29/2021	2	122	61
PLANNED	11/29/2021	9	891	99
PLANNED	11/29/2021	1	39	39
PLANNED	11/30/2021	8	408	51
PLANNED	11/30/2021	1	130	130
PLANNED	11/30/2021	7	595	85
PLANNED	11/30/2021	3	105	35
PLANNED	11/30/2021	6	546	91
PLANNED	11/30/2021	4	316	79

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	3	240	80
PLANNED	11/30/2021	2	182	91
PLANNED	11/30/2021	6	96	16
PLANNED	11/30/2021	21	1,869	89
PLANNED	11/30/2021	5	400	80
PLANNED	11/30/2021	12	1,200	100
PLANNED	11/30/2021	2	228	114
PLANNED	11/30/2021	1	339	339
PLANNED	11/30/2021	31	2,201	71
PLANNED	11/30/2021	2	68	34
PLANNED	11/30/2021	6	84	14
PLANNED	11/30/2021	5	90	18
PLANNED	11/30/2021	6	48	8
PLANNED	11/30/2021	4	76	19
PLANNED	11/30/2021	5	105	21
PLANNED	11/30/2021	4	106	34
PLANNED	11/30/2021	8	402	60
PLANNED	11/30/2021	4	72	18
PLANNED	11/30/2021	6	120	20
PLANNED	11/30/2021	1	452	452
PLANNED	11/30/2021	2	24	12
PLANNED	11/30/2021	1	12	12
PLANNED	11/30/2021	7	665	95
PLANNED	11/30/2021	2	314	157
PLANNED	11/30/2021	3	33	11
CUSTOMER REQUEST	11/30/2021	5	1,650	330
PLANNED	11/30/2021	2	206	103
PLANNED	11/30/2021	2	24	12
PLANNED	11/30/2021	3	15	5
PLANNED	11/30/2021	7	42	6
PLANNED	11/30/2021	4	260	65
PLANNED	11/30/2021	1	227	227
PLANNED	11/30/2021	1	12	12
PLANNED	11/30/2021	4	1,064	266
PLANNED	11/30/2021	12	552	46
PLANNED	11/30/2021	5	400	80
PLANNED	11/30/2021	10	1,270	127
PLANNED	11/30/2021	7	42	6
PLANNED	11/30/2021	4	52	13
PLANNED	11/30/2021	34	1,802	53
PLANNED	11/30/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	2	144	72
PLANNED	11/30/2021	13	1,612	124
PLANNED	11/30/2021	11	1,430	130
PLANNED	11/30/2021	11	363	33
PLANNED	11/30/2021	6	78	13
PLANNED	11/30/2021	1	164	164
PLANNED	11/30/2021	5	85	17
PLANNED	11/30/2021	1	9	9
PLANNED	11/30/2021	1	61	61
PLANNED	11/30/2021	3	36	12
PLANNED	11/30/2021	2	8	4
CUSTOMER REQUEST	11/30/2021	130	12,090	93
PLANNED	11/30/2021	2	100	50
PLANNED	11/30/2021	17	2,278	134
PLANNED	11/30/2021	20	2,480	124
PLANNED	11/30/2021	7	840	120
PLANNED	11/30/2021	4	208	52
PLANNED	11/30/2021	3	39	13
PLANNED	11/30/2021	10	1,925	205
PLANNED	11/30/2021	2	10	5
PLANNED	11/30/2021	9	536	204
PLANNED	11/30/2021	6	1,060	234
PLANNED	11/30/2021	4	44	11
CUSTOMER REQUEST	11/30/2021	7	191	59
PLANNED	11/30/2021	3	39	13
PLANNED	11/30/2021	1	176	176
PLANNED	11/30/2021	5	30	6
PLANNED	11/30/2021	1	7	7
PLANNED	11/30/2021	3	51	17
PLANNED	11/30/2021	2	144	72
PLANNED	11/30/2021	1	47	47
PLANNED	11/30/2021	4	860	215
PLANNED	11/30/2021	4	32	8
PLANNED	11/30/2021	3	30	10
PLANNED	11/30/2021	4	32	8
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	5	65	13
PLANNED	11/30/2021	6	18	3
PLANNED	11/30/2021	1	31	31
PLANNED	11/30/2021	33	3,300	100

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	4	64	16
PLANNED	11/30/2021	6	924	154
PLANNED	11/30/2021	4	1,064	266
PLANNED	11/30/2021	8	1,118	187
PLANNED	11/30/2021	3	36	12
PLANNED	11/30/2021	6	108	18
PLANNED	11/30/2021	1	6	6
PLANNED	11/30/2021	4	64	16
PLANNED	11/30/2021	3	30	10
PLANNED	11/30/2021	2	14	7
PLANNED	11/30/2021	5	75	15
PLANNED	11/30/2021	5	60	12
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	8	32	4
PLANNED	11/30/2021	7	245	35
PLANNED	11/30/2021	3	33	11
PLANNED	11/30/2021	1	100	100
PLANNED	11/30/2021	71	8,662	122
CUSTOMER REQUEST	11/30/2021	4	36	9
PLANNED	11/30/2021	4	16	4
PLANNED	11/30/2021	4	20	5
PLANNED	11/30/2021	5	20	4
PLANNED	11/30/2021	4	16	4
PLANNED	11/30/2021	4	16	4
PLANNED	11/30/2021	6	54	9
PLANNED	11/30/2021	1	8	8
PLANNED	11/30/2021	3	27	9
PLANNED	11/30/2021	6	36	6
PLANNED	11/30/2021	2	236	118
PLANNED	11/30/2021	6	450	75
PLANNED	11/30/2021	2	8	4
PLANNED	11/30/2021	5	625	125
PLANNED	11/30/2021	9	387	43
PLANNED	11/30/2021	1	290	290
PLANNED	11/30/2021	4	492	123
PLANNED	11/30/2021	2	6	3
PLANNED	11/30/2021	4	124	31
PLANNED	11/30/2021	2	34	17
PLANNED	11/30/2021	1	10	10
PLANNED	11/30/2021	4	36	9
PLANNED	11/30/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	2	24	12
PLANNED	11/30/2021	2	16	8
PLANNED	11/30/2021	6	84	14
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	2	22	11
PLANNED	11/30/2021	5	30	6
PLANNED	11/30/2021	4	56	14
CUSTOMER REQUEST	11/30/2021	7	42	6
PLANNED	11/30/2021	3	24	8
PLANNED	11/30/2021	4	468	117
PLANNED	11/30/2021	5	55	11
PLANNED	11/30/2021	2	24	12
PLANNED	11/30/2021	11	946	86
PLANNED	11/30/2021	6	96	16
PLANNED	11/30/2021	11	660	60
PLANNED	11/30/2021	19	209	11
PLANNED	11/30/2021	2	18	9
PLANNED	11/30/2021	4	112	28
PLANNED	11/30/2021	4	449	122
PLANNED	11/30/2021	3	9	3
PLANNED	11/30/2021	3	12	4
PLANNED	11/30/2021	9	216	24
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	5	30	6
PLANNED	11/30/2021	6	24	4
PLANNED	11/30/2021	6	174	29
PLANNED	11/30/2021	1	33	33
PLANNED	11/30/2021	2	8	4
PLANNED	11/30/2021	19	1,995	105
PLANNED	11/30/2021	1	48	48
PLANNED	11/30/2021	2	10	5
PLANNED	11/30/2021	34	7,616	224
CUSTOMER REQUEST	11/30/2021	6	90	15
PLANNED	11/30/2021	2	10	5
PLANNED	11/30/2021	9	153	17
PLANNED	11/30/2021	1	229	229
PLANNED	11/30/2021	5	60	12
PLANNED	11/30/2021	1	8	8
PLANNED	11/30/2021	4	192	48
PLANNED	11/30/2021	4	32	8
PLANNED	11/30/2021	1	12	12

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	3	21	7
PLANNED	11/30/2021	9	855	95
PLANNED	11/30/2021	4	512	128
PLANNED	11/30/2021	2	244	122
PLANNED	11/30/2021	8	1,952	244
PLANNED	11/30/2021	2	30	15
PLANNED	11/30/2021	2	40	20
PLANNED	11/30/2021	4	100	25
PLANNED	11/30/2021	3	114	38
PLANNED	11/30/2021	3	63	21
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	7	126	18
PLANNED	11/30/2021	2	14	7
PLANNED	11/30/2021	2	236	118
PLANNED	11/30/2021	7	70	10
PLANNED	11/30/2021	12	84	7
PLANNED	11/30/2021	7	70	10
PLANNED	11/30/2021	2	14	7
PLANNED	11/30/2021	5	350	70
PLANNED	11/30/2021	6	420	70
PLANNED	11/30/2021	3	33	11
PLANNED	11/30/2021	2	10	5
PLANNED	11/30/2021	3	30	10
PLANNED	11/30/2021	7	56	8
PLANNED	11/30/2021	1	16	16
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	5	660	132
PLANNED	11/30/2021	5	70	14
PLANNED	11/30/2021	2	12	6
CUSTOMER REQUEST	11/30/2021	1	19	19
PLANNED	11/30/2021	3	54	18
CUSTOMER REQUEST	11/30/2021	1	83	83
PLANNED	11/30/2021	1	10	10
PLANNED	11/30/2021	11	242	22
PLANNED	11/30/2021	3	15	5
PLANNED	11/30/2021	2	20	10
PLANNED	11/30/2021	3	21	7
PLANNED	11/30/2021	4	16	4
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	3	18	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	2	14	7
PLANNED	11/30/2021	11	297	27
PLANNED	11/30/2021	14	1,414	101
PLANNED	11/30/2021	6	60	10
PLANNED	11/30/2021	8	656	82
PLANNED	11/30/2021	1	7	7
PLANNED	11/30/2021	4	40	10
PLANNED	11/30/2021	4	84	21
PLANNED	11/30/2021	1	18	18
PLANNED	11/30/2021	5	660	132
PLANNED	11/30/2021	3	18	6
PLANNED	11/30/2021	14	588	42
CUSTOMER REQUEST	11/30/2021	1	230	230
PLANNED	11/30/2021	1	123	123
PLANNED	11/30/2021	2	108	54
PLANNED	11/30/2021	1	7	7
PLANNED	11/30/2021	2	14	7
PLANNED	11/30/2021	1	40	40
PLANNED	11/30/2021	1	8	8
PLANNED	11/30/2021	11	88	8
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	1	38	38
PLANNED	11/30/2021	3	30	10
PLANNED	11/30/2021	11	638	58
PLANNED	11/30/2021	14	700	50
PLANNED	11/30/2021	3	48	16
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	3	15	5
PLANNED	11/30/2021	3	81	27
PLANNED	11/30/2021	4	40	10
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	3	27	9
PLANNED	11/30/2021	18	1,170	65
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	5	50	10
CUSTOMER REQUEST	11/30/2021	4	112	28
PLANNED	11/30/2021	10	90	9
PLANNED	11/30/2021	21	252	12
PLANNED	11/30/2021	2	26	13
PLANNED	11/30/2021	2	18	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	1	7	7
PLANNED	11/30/2021	5	350	70
PLANNED	11/30/2021	11	44	4
PLANNED	11/30/2021	3	48	16
PLANNED	11/30/2021	3	24	8
CUSTOMER REQUEST	11/30/2021	1	201	201
CUSTOMER REQUEST	11/30/2021	1	74	74
PLANNED	11/30/2021	1	135	135
PLANNED	11/30/2021	4	116	29
PLANNED	11/30/2021	4	32	8
PLANNED	11/30/2021	2	32	16
PLANNED	11/30/2021	15	585	39
PLANNED	11/30/2021	2	96	48
PLANNED	11/30/2021	1	8	8
PLANNED	11/30/2021	6	114	19
PLANNED	11/30/2021	4	80	20
PLANNED	11/30/2021	3	15	5
PLANNED	11/30/2021	11	297	27
PLANNED	11/30/2021	4	48	12
PLANNED	11/30/2021	2	24	12
PLANNED	11/30/2021	5	35	7
PLANNED	11/30/2021	4	36	9
PLANNED	11/30/2021	4	36	9
PLANNED	11/30/2021	4	40	10
PLANNED	11/30/2021	8	224	28
PLANNED	11/30/2021	1	6	6
PLANNED	11/30/2021	21	525	25
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	4	56	14
PLANNED	11/30/2021	2	54	27
PLANNED	11/30/2021	1	33	33
PLANNED	11/30/2021	8	352	44
PLANNED	11/30/2021	4	60	15
PLANNED	11/30/2021	1	67	67
PLANNED	11/30/2021	4	576	144
PLANNED	11/30/2021	5	35	7
PLANNED	11/30/2021	3	27	9
PLANNED	11/30/2021	2	128	64
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	3	21	7
PLANNED	11/30/2021	4	12	3

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	1	100	100
PLANNED	11/30/2021	1	7	7
PLANNED	11/30/2021	4	36	9
PLANNED	11/30/2021	1	16	16
PLANNED	11/30/2021	7	133	19
PLANNED	11/30/2021	10	140	14
PLANNED	11/30/2021	2	182	91
PLANNED	11/30/2021	3	12	4
PLANNED	11/30/2021	4	28	7
PLANNED	11/30/2021	15	180	12
PLANNED	11/30/2021	1	69	69
PLANNED	11/30/2021	14	252	18
PLANNED	11/30/2021	3	27	9
PLANNED	11/30/2021	2	60	30
PLANNED	11/30/2021	4	60	15
PLANNED	11/30/2021	2	20	10
PLANNED	11/30/2021	6	30	5
CUSTOMER REQUEST	11/30/2021	1	215	215
PLANNED	11/30/2021	3	15	5
PLANNED	11/30/2021	5	45	9
PLANNED	11/30/2021	3	27	9
CUSTOMER REQUEST	11/30/2021	1	178	178
CUSTOMER REQUEST	11/30/2021	1	117	117
PLANNED	11/30/2021	1	11	11
PLANNED	11/30/2021	18	918	51
PLANNED	11/30/2021	1	25	25
PLANNED	11/30/2021	7	462	66
PLANNED	11/30/2021	3	45	15
PLANNED	11/30/2021	1	41	41
PLANNED	11/30/2021	6	378	63
PLANNED	11/30/2021	2	12	6
PLANNED	11/30/2021	4	48	12
PLANNED	11/30/2021	4	56	14
PLANNED	11/30/2021	4	24	6
PLANNED	11/30/2021	4	16	4
CUSTOMER REQUEST	11/30/2021	1	36	36
PLANNED	11/30/2021	7	49	7
PLANNED	11/30/2021	1	12	12
PLANNED	11/30/2021	2	348	174
PLANNED	11/30/2021	1	278	278
PLANNED	11/30/2021	1	111	111

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	11/30/2021	6	264	44
PLANNED	11/30/2021	4	624	156
PLANNED	11/30/2021	1	166	166
PLANNED	12/1/2021	2	610	305
PLANNED	12/1/2021	1	69	69
PLANNED	12/1/2021	1	69	69
PLANNED	12/1/2021	22	3,498	159
PLANNED	12/1/2021	13	988	76
PLANNED	12/1/2021	8	736	92
PLANNED	12/1/2021	3	429	143
PLANNED	12/1/2021	5	460	92
PLANNED	12/1/2021	3	45	15
PLANNED	12/1/2021	11	836	76
PLANNED	12/1/2021	13	182	14
PLANNED	12/1/2021	3	27	9
PLANNED	12/1/2021	6	786	131
PLANNED	12/1/2021	2	10	5
PLANNED	12/1/2021	2	14	7
PLANNED	12/1/2021	25	1,575	63
CUSTOMER REQUEST	12/1/2021	7	224	32
PLANNED	12/1/2021	1	275	275
PLANNED	12/1/2021	7	203	29
PLANNED	12/1/2021	3	39	13
PLANNED	12/1/2021	2	14	7
PLANNED	12/1/2021	3	15	5
PLANNED	12/1/2021	4	468	117
PLANNED	12/1/2021	9	45	5
PLANNED	12/1/2021	1	12	12
PLANNED	12/1/2021	8	88	11
PLANNED	12/1/2021	4	76	19
PLANNED	12/1/2021	1	8	8
PLANNED	12/1/2021	2	38	19
PLANNED	12/1/2021	2	10	5
PLANNED	12/1/2021	12	1,032	86
PLANNED	12/1/2021	1	10	10
PLANNED	12/1/2021	4	32	8
PLANNED	12/1/2021	4	56	14
PLANNED	12/1/2021	3	45	15
PLANNED	12/1/2021	2	38	19
PLANNED	12/1/2021	4	32	8
PLANNED	12/1/2021	1	200	200

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/1/2021	2	12	6
PLANNED	12/1/2021	3	15	5
PLANNED	12/1/2021	6	42	7
PLANNED	12/1/2021	1	9	9
PLANNED	12/1/2021	1	243	243
PLANNED	12/1/2021	5	320	64
PLANNED	12/1/2021	3	369	123
PLANNED	12/1/2021	2	10	5
PLANNED	12/1/2021	1	8	8
CUSTOMER REQUEST	12/1/2021	10	480	48
PLANNED	12/1/2021	1	7	7
PLANNED	12/1/2021	4	16	4
PLANNED	12/1/2021	3	117	39
PLANNED	12/1/2021	2	18	9
PLANNED	12/1/2021	17	102	6
PLANNED	12/1/2021	2	24	12
PLANNED	12/1/2021	1	191	191
PLANNED	12/1/2021	4	48	12
PLANNED	12/1/2021	1	258	258
PLANNED	12/1/2021	9	252	28
PLANNED	12/1/2021	6	1,614	269
PLANNED	12/1/2021	4	396	99
PLANNED	12/1/2021	2	14	7
PLANNED	12/1/2021	4	32	8
PLANNED	12/1/2021	1	84	84
CUSTOMER REQUEST	12/1/2021	1	106	106
PLANNED	12/1/2021	2	242	121
PLANNED	12/1/2021	2	18	9
PLANNED	12/1/2021	3	105	35
PLANNED	12/1/2021	1	338	338
PLANNED	12/1/2021	2	154	77
PLANNED	12/1/2021	3	15	5
CUSTOMER REQUEST	12/1/2021	41	11,808	288
PLANNED	12/1/2021	2	148	74
PLANNED	12/1/2021	6	30	5
PLANNED	12/1/2021	5	120	24
PLANNED	12/1/2021	1	215	215
PLANNED	12/1/2021	13	325	25
PLANNED	12/1/2021	1	4	4
PLANNED	12/1/2021	14	392	28
PLANNED	12/1/2021	3	15	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/1/2021	2	12	6
CUSTOMER REQUEST	12/1/2021	14	5,054	361
PLANNED	12/1/2021	3	30	10
PLANNED	12/1/2021	2	434	217
PLANNED	12/1/2021	4	44	11
PLANNED	12/1/2021	4	20	5
PLANNED	12/1/2021	30	450	15
PLANNED	12/1/2021	3	102	34
PLANNED	12/1/2021	4	108	27
PLANNED	12/1/2021	13	130	10
PLANNED	12/1/2021	1	217	217
PLANNED	12/1/2021	1	5	5
PLANNED	12/1/2021	2	18	9
PLANNED	12/1/2021	13	325	25
PLANNED	12/1/2021	3	24	8
PLANNED	12/1/2021	162	2,034	17
PLANNED	12/1/2021	5	278	67
PLANNED	12/1/2021	8	472	59
PLANNED	12/1/2021	2	8	4
PLANNED	12/1/2021	10	1,130	113
PLANNED	12/1/2021	2	394	197
PLANNED	12/1/2021	7	28	4
PLANNED	12/1/2021	4	48	12
PLANNED	12/1/2021	2	68	34
PLANNED	12/1/2021	2	146	73
PLANNED	12/1/2021	2	18	9
PLANNED	12/1/2021	15	75	5
PLANNED	12/1/2021	2	6	3
PLANNED	12/1/2021	3	18	6
PLANNED	12/1/2021	2	26	13
PLANNED	12/1/2021	1	8	8
PLANNED	12/1/2021	4	256	64
PLANNED	12/1/2021	1	6	6
PLANNED	12/1/2021	2	10	5
PLANNED	12/1/2021	10	60	6
PLANNED	12/1/2021	2	116	58
PLANNED	12/1/2021	2	94	47
PLANNED	12/1/2021	3	12	4
PLANNED	12/1/2021	2	14	7
PLANNED	12/1/2021	16	848	53
PLANNED	12/1/2021	1	225	225

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/1/2021	7	1,225	175
PLANNED	12/1/2021	2	2	1
PLANNED	12/1/2021	3	39	13
PLANNED	12/1/2021	3	39	13
PLANNED	12/1/2021	3	33	11
PLANNED	12/1/2021	3	15	5
PLANNED	12/1/2021	2	8	4
PLANNED	12/1/2021	8	176	22
PLANNED	12/1/2021	2	20	10
PLANNED	12/1/2021	6	150	25
PLANNED	12/1/2021	10	650	65
PLANNED	12/1/2021	8	488	61
PLANNED	12/1/2021	9	126	14
PLANNED	12/1/2021	2	8	4
PLANNED	12/1/2021	2	8	4
PLANNED	12/1/2021	2	8	4
PLANNED	12/1/2021	1	180	180
PLANNED	12/1/2021	40	2,960	74
PLANNED	12/1/2021	1	193	193
PLANNED	12/1/2021	6	90	15
PLANNED	12/1/2021	4	16	4
PLANNED	12/1/2021	3	45	15
PLANNED	12/1/2021	2	10	5
PLANNED	12/1/2021	17	578	34
PLANNED	12/1/2021	8	48	6
PLANNED	12/1/2021	3	24	8
PLANNED	12/1/2021	2	24	12
PLANNED	12/1/2021	3	12	4
PLANNED	12/1/2021	6	12	2
PLANNED	12/1/2021	4	28	7
PLANNED	12/1/2021	1	51	51
PLANNED	12/1/2021	2	176	88
PLANNED	12/1/2021	4	223	69
PLANNED	12/1/2021	6	156	26
PLANNED	12/1/2021	3	18	6
PLANNED	12/1/2021	1	7	7
PLANNED	12/1/2021	15	75	5
PLANNED	12/1/2021	3	18	6
PLANNED	12/1/2021	8	48	6
PLANNED	12/1/2021	1	131	131
PLANNED	12/1/2021	2	50	25

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/1/2021	1	8	8
PLANNED	12/1/2021	2	32	16
PLANNED	12/1/2021	10	200	20
PLANNED	12/1/2021	10	100	10
PLANNED	12/1/2021	5	80	16
PLANNED	12/1/2021	2	154	77
PLANNED	12/1/2021	1	7	7
PLANNED	12/1/2021	7	763	109
PLANNED	12/1/2021	1	9	9
PLANNED	12/1/2021	16	192	12
PLANNED	12/1/2021	2	175	107
PLANNED	12/1/2021	6	102	17
PLANNED	12/1/2021	6	192	32
PLANNED	12/1/2021	1	10	10
PLANNED	12/1/2021	1	8	8
PLANNED	12/1/2021	8	240	30
PLANNED	12/1/2021	118	15,222	129
PLANNED	12/1/2021	1	88	88
PLANNED	12/1/2021	8	80	10
PLANNED	12/1/2021	3	84	28
PLANNED	12/1/2021	3	18	6
PLANNED	12/1/2021	1	40	40
PLANNED	12/1/2021	25	2,125	85
PLANNED	12/1/2021	4	16	4
PLANNED	12/1/2021	11	638	58
PLANNED	12/1/2021	6	78	13
PLANNED	12/1/2021	6	36	6
PLANNED	12/1/2021	2	16	8
PLANNED	12/1/2021	4	24	6
PLANNED	12/1/2021	3	15	5
PLANNED	12/1/2021	2	20	10
PLANNED	12/1/2021	3	81	27
PLANNED	12/1/2021	15	135	9
PLANNED	12/1/2021	2	170	85
PLANNED	12/1/2021	2	72	36
PLANNED	12/1/2021	9	207	23
PLANNED	12/1/2021	2	272	136
PLANNED	12/1/2021	1	169	169
PLANNED	12/1/2021	2	30	15
PLANNED	12/1/2021	8	200	25
PLANNED	12/1/2021	6	1,014	169

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/1/2021	4	68	17
PLANNED	12/1/2021	32	4,064	127
PLANNED	12/1/2021	1	116	116
PLANNED	12/1/2021	11	88	8
CUSTOMER REQUEST	12/1/2021	8	392	49
PLANNED	12/1/2021	11	44	4
PLANNED	12/1/2021	9	288	32
PLANNED	12/1/2021	1	11	11
PLANNED	12/1/2021	12	108	9
PLANNED	12/1/2021	8	864	108
PLANNED	12/1/2021	3	210	70
PLANNED	12/1/2021	10	60	6
PLANNED	12/1/2021	2	46	23
PLANNED	12/1/2021	1	35	35
PLANNED	12/1/2021	6	30	5
PLANNED	12/1/2021	11	385	35
PLANNED	12/1/2021	3	21	7
PLANNED	12/1/2021	1	4	4
PLANNED	12/1/2021	3	42	14
PLANNED	12/1/2021	1	9	9
PLANNED	12/1/2021	9	486	54
PLANNED	12/1/2021	4	24	6
PLANNED	12/1/2021	3	45	15
PLANNED	12/1/2021	9	459	51
PLANNED	12/1/2021	1	81	81
CUSTOMER REQUEST	12/1/2021	27	1,377	51
PLANNED	12/1/2021	8	912	114
PLANNED	12/1/2021	1	67	67
PLANNED	12/1/2021	2	40	20
PLANNED	12/1/2021	5	760	152
PLANNED	12/1/2021	1	119	119
PLANNED	12/1/2021	2	112	66
PLANNED	12/1/2021	42	10,080	240
PLANNED	12/1/2021	2	346	173
PLANNED	12/1/2021	3	6	2
PLANNED	12/1/2021	1	345	345
PLANNED	12/2/2021	1	46	46
PLANNED	12/2/2021	1	148	148
PLANNED	12/2/2021	1	35	35
PLANNED	12/2/2021	1	261	261
PLANNED	12/2/2021	11	616	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	7	392	56
PLANNED	12/2/2021	2	124	62
PLANNED	12/2/2021	3	177	59
PLANNED	12/2/2021	7	280	40
CUSTOMER REQUEST	12/2/2021	1,403	98,210	70
PLANNED	12/2/2021	6	468	78
PLANNED	12/2/2021	1	28	28
PLANNED	12/2/2021	7	147	21
PLANNED	12/2/2021	6	318	53
PLANNED	12/2/2021	2	130	65
PLANNED	12/2/2021	2	30	15
PLANNED	12/2/2021	3	261	87
PLANNED	12/2/2021	8	320	40
PLANNED	12/2/2021	4	316	102
PLANNED	12/2/2021	1	24	24
PLANNED	12/2/2021	8	240	30
PLANNED	12/2/2021	8	240	30
PLANNED	12/2/2021	3	117	39
PLANNED	12/2/2021	6	66	11
CUSTOMER REQUEST	12/2/2021	268	58,156	217
PLANNED	12/2/2021	8	352	44
PLANNED	12/2/2021	2	14	7
PLANNED	12/2/2021	2	40	20
PLANNED	12/2/2021	11	1,342	122
PLANNED	12/2/2021	8	104	13
PLANNED	12/2/2021	1	122	122
CUSTOMER REQUEST	12/2/2021	7	566	524
PLANNED	12/2/2021	2	324	162
PLANNED	12/2/2021	7	525	75
PLANNED	12/2/2021	2	198	99
PLANNED	12/2/2021	7	91	13
PLANNED	12/2/2021	2	24	12
PLANNED	12/2/2021	15	1,320	88
PLANNED	12/2/2021	5	935	187
PLANNED	12/2/2021	20	1,540	77
CUSTOMER REQUEST	12/2/2021	19	676	304
PLANNED	12/2/2021	2	684	342
PLANNED	12/2/2021	12	1,128	94
PLANNED	12/2/2021	8	744	93
PLANNED	12/2/2021	1	142	142
PLANNED	12/2/2021	2	324	162

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	6	126	21
PLANNED	12/2/2021	2	48	24
PLANNED	12/2/2021	12	1,080	90
PLANNED	12/2/2021	1	33	33
PLANNED	12/2/2021	1	8	8
PLANNED	12/2/2021	3	39	13
PLANNED	12/2/2021	1	8	8
PLANNED	12/2/2021	3	30	10
PLANNED	12/2/2021	4	44	11
PLANNED	12/2/2021	25	2,350	94
PLANNED	12/2/2021	3	90	30
PLANNED	12/2/2021	8	96	12
PLANNED	12/2/2021	19	3,838	202
PLANNED	12/2/2021	1	40	40
PLANNED	12/2/2021	8	1,736	217
PLANNED	12/2/2021	4	696	174
PLANNED	12/2/2021	1	11	11
PLANNED	12/2/2021	1	7	7
PLANNED	12/2/2021	9	72	8
PLANNED	12/2/2021	23	7,659	333
PLANNED	12/2/2021	1	194	194
PLANNED	12/2/2021	3	142	53
PLANNED	12/2/2021	14	1,672	171
PLANNED	12/2/2021	7	521	122
PLANNED	12/2/2021	2	20	11
PLANNED	12/2/2021	5	245	49
PLANNED	12/2/2021	1	10	10
PLANNED	12/2/2021	2	196	98
PLANNED	12/2/2021	3	216	72
PLANNED	12/2/2021	6	48	8
PLANNED	12/2/2021	5	135	27
PLANNED	12/2/2021	3	48	16
CUSTOMER REQUEST	12/2/2021	8	104	13
PLANNED	12/2/2021	2	92	46
PLANNED	12/2/2021	3	546	182
PLANNED	12/2/2021	1	162	162
PLANNED	12/2/2021	8	680	85
CUSTOMER REQUEST	12/2/2021	3	273	91
PLANNED	12/2/2021	9	1,386	154
PLANNED	12/2/2021	4	48	12
PLANNED	12/2/2021	3	174	58

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	2	119	108
PLANNED	12/2/2021	1	7	7
PLANNED	12/2/2021	1	7	7
PLANNED	12/2/2021	2	10	5
PLANNED	12/2/2021	2	14	7
PLANNED	12/2/2021	4	284	71
PLANNED	12/2/2021	3	243	111
PLANNED	12/2/2021	16	752	47
PLANNED	12/2/2021	15	600	40
PLANNED	12/2/2021	4	104	26
PLANNED	12/2/2021	4	360	90
PLANNED	12/2/2021	3	96	32
PLANNED	12/2/2021	9	342	38
PLANNED	12/2/2021	10	1,540	154
PLANNED	12/2/2021	12	720	60
PLANNED	12/2/2021	8	408	51
PLANNED	12/2/2021	16	1,648	103
PLANNED	12/2/2021	9	207	23
PLANNED	12/2/2021	5	40	8
PLANNED	12/2/2021	1	9	9
PLANNED	12/2/2021	2	20	10
PLANNED	12/2/2021	3	417	139
PLANNED	12/2/2021	1	7	7
PLANNED	12/2/2021	3	45	15
PLANNED	12/2/2021	10	710	71
PLANNED	12/2/2021	4	56	14
PLANNED	12/2/2021	3	660	220
PLANNED	12/2/2021	1	10	10
PLANNED	12/2/2021	3	321	107
PLANNED	12/2/2021	2	18	9
PLANNED	12/2/2021	4	40	10
PLANNED	12/2/2021	3	6	2
PLANNED	12/2/2021	2	44	22
PLANNED	12/2/2021	2	16	8
PLANNED	12/2/2021	1	10	10
PLANNED	12/2/2021	7	336	48
PLANNED	12/2/2021	1	62	62
PLANNED	12/2/2021	16	1,072	67
PLANNED	12/2/2021	3	45	15
PLANNED	12/2/2021	3	69	23
CUSTOMER REQUEST	12/2/2021	1	336	336

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	9	2,646	294
PLANNED	12/2/2021	1	6	6
PLANNED	12/2/2021	220	22,220	201
PLANNED	12/2/2021	6	198	33
PLANNED	12/2/2021	8	312	39
PLANNED	12/2/2021	15	165	11
PLANNED	12/2/2021	2	60	30
CUSTOMER REQUEST	12/2/2021	6	210	35
PLANNED	12/2/2021	1	12	12
PLANNED	12/2/2021	5	120	24
CUSTOMER REQUEST	12/2/2021	4	360	90
PLANNED	12/2/2021	1	18	18
PLANNED	12/2/2021	2	56	28
PLANNED	12/2/2021	2	120	60
PLANNED	12/2/2021	1	46	46
PLANNED	12/2/2021	11	847	77
PLANNED	12/2/2021	6	468	78
PLANNED	12/2/2021	1	178	178
PLANNED	12/2/2021	20	940	47
PLANNED	12/2/2021	1	38	38
PLANNED	12/2/2021	3	75	25
PLANNED	12/2/2021	5	390	78
PLANNED	12/2/2021	3	90	30
PLANNED	12/2/2021	2	478	239
PLANNED	12/2/2021	3	210	70
PLANNED	12/2/2021	3	51	17
PLANNED	12/2/2021	6	108	18
CUSTOMER REQUEST	12/2/2021	8	96	12
PLANNED	12/2/2021	2	134	67
PLANNED	12/2/2021	4	128	32
PLANNED	12/2/2021	2	26	13
PLANNED	12/2/2021	1	11	11
PLANNED	12/2/2021	2	68	34
PLANNED	12/2/2021	11	990	90
PLANNED	12/2/2021	4	140	35
PLANNED	12/2/2021	2	138	69
PLANNED	12/2/2021	3	48	16
PLANNED	12/2/2021	3	456	152
PLANNED	12/2/2021	23	3,519	153
PLANNED	12/2/2021	1	1	1
PLANNED	12/2/2021	17	1,173	69

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	6	150	25
PLANNED	12/2/2021	10	616	90
PLANNED	12/2/2021	1	49	49
PLANNED	12/2/2021	2	48	24
PLANNED	12/2/2021	2	134	67
PLANNED	12/2/2021	4	36	9
PLANNED	12/2/2021	1	111	111
PLANNED	12/2/2021	3	348	116
CUSTOMER REQUEST	12/2/2021	1	140	140
PLANNED	12/2/2021	9	369	41
PLANNED	12/2/2021	3	279	93
PLANNED	12/2/2021	2	60	30
PLANNED	12/2/2021	11	583	53
PLANNED	12/2/2021	4	28	7
PLANNED	12/2/2021	2	92	46
PLANNED	12/2/2021	10	500	50
PLANNED	12/2/2021	3	78	26
PLANNED	12/2/2021	13	416	32
PLANNED	12/2/2021	8	1,840	230
PLANNED	12/2/2021	2	280	140
PLANNED	12/2/2021	1	19	19
PLANNED	12/2/2021	1	29	29
PLANNED	12/2/2021	1	40	40
PLANNED	12/2/2021	1	52	52
PLANNED	12/2/2021	198	3,960	20
PLANNED	12/2/2021	1	35	35
PLANNED	12/2/2021	10	2,300	230
PLANNED	12/2/2021	1	16	16
PLANNED	12/2/2021	1	58	58
PLANNED	12/2/2021	3	33	11
PLANNED	12/2/2021	1	9	9
PLANNED	12/2/2021	1	102	102
PLANNED	12/2/2021	1	107	107
PLANNED	12/2/2021	3	150	50
PLANNED	12/2/2021	2	478	239
PLANNED	12/2/2021	36	1,692	47
PLANNED	12/2/2021	7	623	89
PLANNED	12/2/2021	5	385	77
PLANNED	12/2/2021	9	1,557	173
PLANNED	12/2/2021	1	68	68
PLANNED	12/2/2021	1	332	332

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/2/2021	2	344	172
PLANNED	12/2/2021	10	1,510	151
PLANNED	12/2/2021	1	82	82
PLANNED	12/2/2021	8	448	56
PLANNED	12/2/2021	1	91	91
PLANNED	12/3/2021	1	259	259
CUSTOMER REQUEST	12/3/2021	20	1,220	61
PLANNED	12/3/2021	6	978	163
PLANNED	12/3/2021	4	524	131
PLANNED	12/3/2021	2	232	116
PLANNED	12/3/2021	1	125	125
PLANNED	12/3/2021	1	96	96
PLANNED	12/3/2021	11	1,518	138
PLANNED	12/3/2021	1	59	59
PLANNED	12/3/2021	6	678	113
PLANNED	12/3/2021	1	114	114
PLANNED	12/3/2021	7	210	30
PLANNED	12/3/2021	6	30	5
PLANNED	12/3/2021	2	98	49
PLANNED	12/3/2021	7	1,694	242
PLANNED	12/3/2021	2	192	96
PLANNED	12/3/2021	9	369	41
PLANNED	12/3/2021	2	32	16
PLANNED	12/3/2021	6	204	34
PLANNED	12/3/2021	27	8,019	297
PLANNED	12/3/2021	32	9,888	309
PLANNED	12/3/2021	27	7,911	293
PLANNED	12/3/2021	1	28	28
CUSTOMER REQUEST	12/3/2021	7	248	236
PLANNED	12/3/2021	7	749	107
PLANNED	12/3/2021	2	74	37
PLANNED	12/3/2021	3	111	37
PLANNED	12/3/2021	6	6	1
PLANNED	12/3/2021	2	342	171
PLANNED	12/3/2021	6	204	34
PLANNED	12/3/2021	11	132	12
PLANNED	12/3/2021	4	28	7
PLANNED	12/3/2021	1	132	132
PLANNED	12/3/2021	1	7	7
PLANNED	12/3/2021	2	24	12
PLANNED	12/3/2021	1	6	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/3/2021	1	5	5
PLANNED	12/3/2021	1	61	61
PLANNED	12/3/2021	1	103	103
PLANNED	12/3/2021	14	168	12
PLANNED	12/3/2021	4	32	8
PLANNED	12/3/2021	9	270	30
PLANNED	12/3/2021	1	34	34
PLANNED	12/3/2021	5	140	28
PLANNED	12/3/2021	1	321	321
PLANNED	12/3/2021	13	1,508	156
PLANNED	12/3/2021	2	240	120
PLANNED	12/3/2021	5	955	191
CUSTOMER REQUEST	12/3/2021	6	150	25
PLANNED	12/3/2021	8	232	29
PLANNED	12/3/2021	3	201	67
PLANNED	12/3/2021	1	139	139
PLANNED	12/3/2021	13	117	9
CUSTOMER REQUEST	12/3/2021	37	6,475	175
PLANNED	12/3/2021	6	102	17
PLANNED	12/3/2021	1	4	4
PLANNED	12/3/2021	10	1,380	138
PLANNED	12/3/2021	3	315	105
PLANNED	12/3/2021	33	1,815	55
PLANNED	12/3/2021	12	168	14
PLANNED	12/3/2021	4	144	36
PLANNED	12/3/2021	6	474	79
PLANNED	12/3/2021	4	436	109
PLANNED	12/3/2021	18	2,646	147
PLANNED	12/3/2021	10	1,080	108
PLANNED	12/3/2021	6	642	107
PLANNED	12/3/2021	14	826	59
CUSTOMER REQUEST	12/3/2021	2	18	9
PLANNED	12/3/2021	6	216	36
PLANNED	12/3/2021	1	58	58
PLANNED	12/3/2021	2	150	75
PLANNED	12/3/2021	9	162	18
PLANNED	12/3/2021	3	426	142
PLANNED	12/3/2021	4	296	74
PLANNED	12/3/2021	9	180	20
PLANNED	12/3/2021	3	51	17
PLANNED	12/3/2021	1	119	119

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/3/2021	2	222	111
PLANNED	12/3/2021	1	254	254
PLANNED	12/3/2021	15	840	56
PLANNED	12/3/2021	4	56	14
PLANNED	12/3/2021	4	100	25
PLANNED	12/3/2021	1	25	25
PLANNED	12/3/2021	6	96	16
PLANNED	12/3/2021	6	210	35
CUSTOMER REQUEST	12/3/2021	1	42	42
PLANNED	12/3/2021	1	53	53
PLANNED	12/3/2021	4	64	16
PLANNED	12/3/2021	2	122	61
PLANNED	12/3/2021	3	159	53
PLANNED	12/3/2021	2	40	20
PLANNED	12/3/2021	2	64	32
PLANNED	12/3/2021	2	52	26
PLANNED	12/3/2021	6	78	13
PLANNED	12/3/2021	3	315	105
PLANNED	12/3/2021	10	70	7
PLANNED	12/3/2021	19	475	25
PLANNED	12/3/2021	1	39	39
PLANNED	12/3/2021	10	80	8
PLANNED	12/3/2021	4	64	16
PLANNED	12/3/2021	8	760	95
PLANNED	12/3/2021	21	252	12
PLANNED	12/3/2021	6	72	12
PLANNED	12/3/2021	8	1,048	131
PLANNED	12/3/2021	8	80	10
PLANNED	12/3/2021	7	294	42
PLANNED	12/3/2021	3	36	12
PLANNED	12/3/2021	4	544	136
PLANNED	12/3/2021	7	1,211	173
PLANNED	12/3/2021	2	44	22
CUSTOMER REQUEST	12/3/2021	7	21	3
PLANNED	12/3/2021	3	259	103
PLANNED	12/3/2021	3	225	75
PLANNED	12/3/2021	2	134	67
PLANNED	12/3/2021	2	196	98
PLANNED	12/3/2021	3	390	130
PLANNED	12/3/2021	1	114	114
CUSTOMER REQUEST	12/3/2021	7	511	73

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	12/3/2021	4	272	68
PLANNED	12/3/2021	5	95	19
PLANNED	12/3/2021	7	1,701	243
PLANNED	12/3/2021	3	162	54
PLANNED	12/3/2021	10	740	74
PLANNED	12/3/2021	6	300	50
PLANNED	12/3/2021	3	42	14
PLANNED	12/3/2021	1	15	15
PLANNED	12/3/2021	21	483	23
PLANNED	12/3/2021	14	2,674	191
CUSTOMER REQUEST	12/3/2021	19	3,306	174
PLANNED	12/3/2021	3	183	61
PLANNED	12/3/2021	2	220	110
PLANNED	12/3/2021	2	324	162
PLANNED	12/3/2021	2	196	98
PLANNED	12/3/2021	2	228	114
CUSTOMER REQUEST	12/4/2021	8	17,096	2,137
CUSTOMER REQUEST	12/4/2021	5	5	2,129
PLANNED	12/4/2021	1	42	42
PLANNED	12/4/2021	10	2,272	361
PLANNED	12/4/2021	5	340	68
PLANNED	12/4/2021	10	690	69
PLANNED	12/4/2021	2	232	116
PLANNED	12/4/2021	3	261	87
PLANNED	12/4/2021	4	744	186
PLANNED	12/4/2021	7	2,737	391
PLANNED	12/4/2021	8	232	29
PLANNED	12/4/2021	9	243	27
PLANNED	12/4/2021	3	420	140
PLANNED	12/4/2021	2	578	289
PLANNED	12/4/2021	1	142	142
PLANNED	12/4/2021	5	705	141
PLANNED	12/4/2021	8	1,120	140
PLANNED	12/4/2021	9	1,278	142
PLANNED	12/4/2021	29	4,089	141
PLANNED	12/4/2021	3	423	141
PLANNED	12/4/2021	2	654	327
PLANNED	12/4/2021	9	2,850	322
CUSTOMER REQUEST	12/4/2021	10	380	38
PLANNED	12/4/2021	1	84	84
PLANNED	12/4/2021	1	62	62

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/4/2021	1	81	81
CUSTOMER REQUEST	12/4/2021	1	221	221
PLANNED	12/4/2021	2	174	87
PLANNED	12/4/2021	4	156	39
PLANNED	12/4/2021	3	321	107
PLANNED	12/4/2021	11	869	79
PLANNED	12/4/2021	1	87	87
PLANNED	12/4/2021	3	756	252
PLANNED	12/5/2021	16	2,816	176
PLANNED	12/5/2021	3	408	136
PLANNED	12/5/2021	3	396	132
PLANNED	12/5/2021	1	33	33
PLANNED	12/5/2021	13	2,886	222
PLANNED	12/5/2021	2	322	161
PLANNED	12/5/2021	1	83	83
PLANNED	12/6/2021	1	73	73
PLANNED	12/6/2021	1	104	104
PLANNED	12/6/2021	5	500	100
PLANNED	12/6/2021	4	160	40
PLANNED	12/6/2021	4	364	91
PLANNED	12/6/2021	1	95	95
PLANNED	12/6/2021	1	38	38
PLANNED	12/6/2021	10	60	6
PLANNED	12/6/2021	13	143	11
PLANNED	12/6/2021	8	96	12
CUSTOMER REQUEST	12/6/2021	17	9,894	582
PLANNED	12/6/2021	3	189	63
PLANNED	12/6/2021	13	2,652	204
PLANNED	12/6/2021	3	114	38
PLANNED	12/6/2021	9	6,012	668
PLANNED	12/6/2021	1	161	161
PLANNED	12/6/2021	2	16	8
PLANNED	12/6/2021	13	312	24
PLANNED	12/6/2021	3	33	11
CUSTOMER REQUEST	12/6/2021	2	450	225
PLANNED	12/6/2021	6	138	23
PLANNED	12/6/2021	2	30	15
PLANNED	12/6/2021	4	60	15
PLANNED	12/6/2021	13	104	8
PLANNED	12/6/2021	2	210	105
PLANNED	12/6/2021	5	55	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	3	75	25
PLANNED	12/6/2021	4	36	9
PLANNED	12/6/2021	2	20	10
PLANNED	12/6/2021	4	4	1
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	1	90	90
PLANNED	12/6/2021	3	90	30
PLANNED	12/6/2021	1	42	42
CUSTOMER REQUEST	12/6/2021	8	48	6
PLANNED	12/6/2021	4	652	163
PLANNED	12/6/2021	7	140	20
PLANNED	12/6/2021	5	55	11
PLANNED	12/6/2021	4	100	25
PLANNED	12/6/2021	22	418	19
PLANNED	12/6/2021	7	315	45
PLANNED	12/6/2021	2	44	22
CUSTOMER REQUEST	12/6/2021	2	24	12
CUSTOMER REQUEST	12/6/2021	1	66	66
PLANNED	12/6/2021	1	18	18
PLANNED	12/6/2021	2	34	17
PLANNED	12/6/2021	4	124	31
PLANNED	12/6/2021	2	214	107
PLANNED	12/6/2021	6	36	6
PLANNED	12/6/2021	5	110	22
CUSTOMER REQUEST	12/6/2021	1	21	21
PLANNED	12/6/2021	8	616	77
PLANNED	12/6/2021	17	2,363	139
PLANNED	12/6/2021	5	180	36
PLANNED	12/6/2021	7	245	35
PLANNED	12/6/2021	6	294	49
PLANNED	12/6/2021	3	48	16
CUSTOMER REQUEST	12/6/2021	1	1	4,586
PLANNED	12/6/2021	1	8	8
PLANNED	12/6/2021	4	76	19
PLANNED	12/6/2021	10	340	34
PLANNED	12/6/2021	34	1,360	40
PLANNED	12/6/2021	4	24	6
PLANNED	12/6/2021	3	189	63
PLANNED	12/6/2021	10	160	16
PLANNED	12/6/2021	2	184	92
PLANNED	12/6/2021	5	55	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	2	16	8
PLANNED	12/6/2021	5	115	23
PLANNED	12/6/2021	8	96	12
PLANNED	12/6/2021	7	112	16
PLANNED	12/6/2021	8	192	24
PLANNED	12/6/2021	12	264	22
PLANNED	12/6/2021	3	135	45
PLANNED	12/6/2021	9	90	10
PLANNED	12/6/2021	2	156	78
CUSTOMER REQUEST	12/6/2021	6	228	38
PLANNED	12/6/2021	2	80	44
PLANNED	12/6/2021	2	50	25
PLANNED	12/6/2021	3	27	9
PLANNED	12/6/2021	1	188	188
PLANNED	12/6/2021	5	835	167
PLANNED	12/6/2021	3	261	87
PLANNED	12/6/2021	7	98	14
CUSTOMER REQUEST	12/6/2021	7	35	5
PLANNED	12/6/2021	9	639	71
CUSTOMER REQUEST	12/6/2021	3	24	8
CUSTOMER REQUEST	12/6/2021	4	24	6
PLANNED	12/6/2021	2	18	9
PLANNED	12/6/2021	3	60	20
PLANNED	12/6/2021	2	44	22
PLANNED	12/6/2021	34	1,666	49
PLANNED	12/6/2021	19	1,444	76
PLANNED	12/6/2021	3	18	6
PLANNED	12/6/2021	9	720	80
PLANNED	12/6/2021	8	72	9
PLANNED	12/6/2021	8	560	70
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	6	570	95
PLANNED	12/6/2021	21	147	7
PLANNED	12/6/2021	10	1,010	101
PLANNED	12/6/2021	1	106	106
PLANNED	12/6/2021	2	148	74
PLANNED	12/6/2021	1	33	33
PLANNED	12/6/2021	3	30	10
PLANNED	12/6/2021	9	126	14
PLANNED	12/6/2021	4	32	8
PLANNED	12/6/2021	7	1,666	238

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	4	20	5
PLANNED	12/6/2021	3	63	22
PLANNED	12/6/2021	3	63	21
PLANNED	12/6/2021	10	60	6
PLANNED	12/6/2021	13	988	76
PLANNED	12/6/2021	1	4	4
PLANNED	12/6/2021	3	15	5
PLANNED	12/6/2021	2	12	6
PLANNED	12/6/2021	2	102	51
PLANNED	12/6/2021	3	18	6
PLANNED	12/6/2021	4	28	7
PLANNED	12/6/2021	2	12	6
PLANNED	12/6/2021	34	2,958	87
PLANNED	12/6/2021	4	60	15
PLANNED	12/6/2021	10	50	5
PLANNED	12/6/2021	9	27	3
PLANNED	12/6/2021	9	45	5
PLANNED	12/6/2021	6	132	22
PLANNED	12/6/2021	10	50	5
PLANNED	12/6/2021	6	42	7
PLANNED	12/6/2021	10	70	7
PLANNED	12/6/2021	4	132	33
PLANNED	12/6/2021	12	1,332	111
PLANNED	12/6/2021	10	1,168	118
PLANNED	12/6/2021	4	780	195
PLANNED	12/6/2021	2	364	182
PLANNED	12/6/2021	6	30	5
PLANNED	12/6/2021	2	8	4
PLANNED	12/6/2021	4	608	152
PLANNED	12/6/2021	3	15	5
PLANNED	12/6/2021	4	32	8
PLANNED	12/6/2021	2	6	3
PLANNED	12/6/2021	4	220	55
PLANNED	12/6/2021	4	28	7
PLANNED	12/6/2021	12	72	6
PLANNED	12/6/2021	9	72	8
PLANNED	12/6/2021	13	78	6
PLANNED	12/6/2021	4	48	12
PLANNED	12/6/2021	2	170	85
PLANNED	12/6/2021	2	236	118
PLANNED	12/6/2021	6	294	49

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	4	84	21
PLANNED	12/6/2021	5	55	11
PLANNED	12/6/2021	2	158	79
PLANNED	12/6/2021	5	10	2
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	13	26	2
PLANNED	12/6/2021	5	25	5
PLANNED	12/6/2021	9	36	4
PLANNED	12/6/2021	12	96	8
PLANNED	12/6/2021	4	464	116
PLANNED	12/6/2021	10	60	6
PLANNED	12/6/2021	1	110	110
PLANNED	12/6/2021	4	24	6
PLANNED	12/6/2021	4	40	10
PLANNED	12/6/2021	4	20	5
PLANNED	12/6/2021	2	20	10
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	2	182	91
PLANNED	12/6/2021	6	156	26
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	31	3,042	162
PLANNED	12/6/2021	6	372	62
PLANNED	12/6/2021	13	585	45
PLANNED	12/6/2021	7	98	14
PLANNED	12/6/2021	6	60	10
PLANNED	12/6/2021	9	108	12
PLANNED	12/6/2021	2	32	16
PLANNED	12/6/2021	7	168	24
PLANNED	12/6/2021	1	42	42
PLANNED	12/6/2021	2	232	116
PLANNED	12/6/2021	11	99	9
PLANNED	12/6/2021	10	70	7
PLANNED	12/6/2021	8	48	6
PLANNED	12/6/2021	8	56	7
PLANNED	12/6/2021	184	23,000	125
PLANNED	12/6/2021	7	49	7
PLANNED	12/6/2021	4	24	6
PLANNED	12/6/2021	1	77	77
PLANNED	12/6/2021	1	10	10
PLANNED	12/6/2021	1	89	89
PLANNED	12/6/2021	1	63	63

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	5	80	16
PLANNED	12/6/2021	24	168	7
PLANNED	12/6/2021	3	333	111
PLANNED	12/6/2021	4	36	9
PLANNED	12/6/2021	13	156	12
PLANNED	12/6/2021	2	298	149
PLANNED	12/6/2021	7	315	45
PLANNED	12/6/2021	4	20	5
PLANNED	12/6/2021	1	48	48
PLANNED	12/6/2021	8	120	15
PLANNED	12/6/2021	1	97	97
PLANNED	12/6/2021	6	84	14
PLANNED	12/6/2021	5	120	24
PLANNED	12/6/2021	4	148	37
PLANNED	12/6/2021	2	188	94
PLANNED	12/6/2021	1	11	11
PLANNED	12/6/2021	7	77	11
PLANNED	12/6/2021	12	396	33
PLANNED	12/6/2021	4	72	18
PLANNED	12/6/2021	11	759	69
PLANNED	12/6/2021	8	128	16
PLANNED	12/6/2021	1	9	9
PLANNED	12/6/2021	15	240	16
PLANNED	12/6/2021	8	56	7
PLANNED	12/6/2021	6	36	6
PLANNED	12/6/2021	6	60	10
PLANNED	12/6/2021	4	60	15
PLANNED	12/6/2021	6	30	5
PLANNED	12/6/2021	3	15	5
PLANNED	12/6/2021	10	80	8
PLANNED	12/6/2021	1	6	6
PLANNED	12/6/2021	1	41	41
PLANNED	12/6/2021	1	9	9
PLANNED	12/6/2021	10	200	20
PLANNED	12/6/2021	4	40	10
PLANNED	12/6/2021	10	1,220	122
PLANNED	12/6/2021	34	2,074	61
PLANNED	12/6/2021	3	54	18
PLANNED	12/6/2021	4	16	4
PLANNED	12/6/2021	6	102	17
PLANNED	12/6/2021	8	144	18

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/6/2021	5	50	10
PLANNED	12/6/2021	4	32	8
PLANNED	12/6/2021	2	486	243
PLANNED	12/6/2021	9	126	14
PLANNED	12/6/2021	5	35	7
PLANNED	12/6/2021	1	15	15
PLANNED	12/6/2021	29	493	17
PLANNED	12/6/2021	5	40	8
PLANNED	12/6/2021	10	190	19
PLANNED	12/6/2021	7	84	12
PLANNED	12/6/2021	10	140	14
PLANNED	12/6/2021	2	14	7
PLANNED	12/6/2021	3	60	20
PLANNED	12/6/2021	4	76	19
CUSTOMER REQUEST	12/6/2021	1	132	132
PLANNED	12/6/2021	13	91	7
PLANNED	12/6/2021	5	25	5
PLANNED	12/6/2021	1	15	15
PLANNED	12/6/2021	4	32	8
PLANNED	12/6/2021	1	13	13
PLANNED	12/6/2021	7	315	45
PLANNED	12/6/2021	1	8	8
PLANNED	12/6/2021	5	1,255	251
PLANNED	12/6/2021	1	35	35
PLANNED	12/6/2021	1	325	325
CUSTOMER REQUEST	12/6/2021	1	34	34
PLANNED	12/6/2021	4	368	92
PLANNED	12/7/2021	1	307	307
PLANNED	12/7/2021	6	1,116	186
PLANNED	12/7/2021	1	243	243
PLANNED	12/7/2021	1	116	116
PLANNED	12/7/2021	2	62	31
PLANNED	12/7/2021	6	1,788	298
PLANNED	12/7/2021	5	45	9
PLANNED	12/7/2021	15	1,050	70
PLANNED	12/7/2021	6	72	12
PLANNED	12/7/2021	11	374	34
PLANNED	12/7/2021	3	150	50
PLANNED	12/7/2021	8	1,000	125
PLANNED	12/7/2021	6	36	6
PLANNED	12/7/2021	1	52	52

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	7	119	17
PLANNED	12/7/2021	5	30	6
PLANNED	12/7/2021	5	10	2
PLANNED	12/7/2021	12	120	10
PLANNED	12/7/2021	6	522	87
PLANNED	12/7/2021	7	35	5
PLANNED	12/7/2021	6	492	82
PLANNED	12/7/2021	11	165	15
PLANNED	12/7/2021	2	680	340
PLANNED	12/7/2021	10	90	9
PLANNED	12/7/2021	10	70	7
PLANNED	12/7/2021	10	910	91
PLANNED	12/7/2021	3	63	21
PLANNED	12/7/2021	8	728	91
PLANNED	12/7/2021	1	150	150
PLANNED	12/7/2021	4	28	7
PLANNED	12/7/2021	11	55	5
PLANNED	12/7/2021	14	2,558	247
PLANNED	12/7/2021	9	135	15
PLANNED	12/7/2021	7	63	9
PLANNED	12/7/2021	3	18	6
PLANNED	12/7/2021	5	70	14
PLANNED	12/7/2021	4	480	120
PLANNED	12/7/2021	8	360	45
PLANNED	12/7/2021	9	1,098	122
PLANNED	12/7/2021	6	84	14
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	9	441	49
CUSTOMER REQUEST	12/7/2021	4	748	187
PLANNED	12/7/2021	2	16	8
PLANNED	12/7/2021	5	85	17
PLANNED	12/7/2021	2	30	15
PLANNED	12/7/2021	5	35	7
PLANNED	12/7/2021	12	108	9
PLANNED	12/7/2021	6	78	13
PLANNED	12/7/2021	2	24	12
PLANNED	12/7/2021	8	64	8
PLANNED	12/7/2021	3	24	8
PLANNED	12/7/2021	4	508	127
CUSTOMER REQUEST	12/7/2021	14	3,472	491
PLANNED	12/7/2021	3	21	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	11	220	20
PLANNED	12/7/2021	13	364	28
PLANNED	12/7/2021	12	1,328	174
PLANNED	12/7/2021	12	1,088	218
PLANNED	12/7/2021	1	2	2
PLANNED	12/7/2021	1	256	256
PLANNED	12/7/2021	9	738	82
PLANNED	12/7/2021	3	18	6
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	2	22	11
PLANNED	12/7/2021	2	352	176
PLANNED	12/7/2021	2	28	14
PLANNED	12/7/2021	4	72	18
PLANNED	12/7/2021	9	837	93
PLANNED	12/7/2021	1	60	60
PLANNED	12/7/2021	2	12	6
PLANNED	12/7/2021	3	732	244
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	7	1,379	197
PLANNED	12/7/2021	2	112	56
PLANNED	12/7/2021	3	45	15
CUSTOMER REQUEST	12/7/2021	42	7,350	175
PLANNED	12/7/2021	2	282	141
PLANNED	12/7/2021	1	94	94
PLANNED	12/7/2021	1	57	57
PLANNED	12/7/2021	8	808	101
CUSTOMER REQUEST	12/7/2021	25	2,825	113
PLANNED	12/7/2021	8	2,136	267
PLANNED	12/7/2021	1	11	11
PLANNED	12/7/2021	4	40	10
PLANNED	12/7/2021	8	80	10
PLANNED	12/7/2021	8	96	12
PLANNED	12/7/2021	4	228	57
PLANNED	12/7/2021	1	16	16
PLANNED	12/7/2021	2	284	142
CUSTOMER REQUEST	12/7/2021	12	1,116	93
CUSTOMER REQUEST	12/7/2021	1	225	225
PLANNED	12/7/2021	2	312	156
PLANNED	12/7/2021	1	30	30
PLANNED	12/7/2021	1	12	12
PLANNED	12/7/2021	5	410	82

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	3	18	6
PLANNED	12/7/2021	8	1,096	137
PLANNED	12/7/2021	2	30	15
PLANNED	12/7/2021	2	28	14
PLANNED	12/7/2021	2	14	7
PLANNED	12/7/2021	5	100	20
CUSTOMER REQUEST	12/7/2021	12	1,932	161
PLANNED	12/7/2021	4	128	32
CUSTOMER REQUEST	12/7/2021	7	1,113	159
PLANNED	12/7/2021	3	246	82
CUSTOMER REQUEST	12/7/2021	7	162	120
PLANNED	12/7/2021	4	172	43
PLANNED	12/7/2021	4	44	11
PLANNED	12/7/2021	2	62	31
PLANNED	12/7/2021	10	150	15
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	4	56	14
PLANNED	12/7/2021	3	21	7
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	3	30	10
PLANNED	12/7/2021	5	20	4
PLANNED	12/7/2021	4	68	17
PLANNED	12/7/2021	27	7,884	292
CUSTOMER REQUEST	12/7/2021	1	207	207
PLANNED	12/7/2021	1	10	10
PLANNED	12/7/2021	3	477	159
PLANNED	12/7/2021	3	30	10
CUSTOMER REQUEST	12/7/2021	4	212	53
PLANNED	12/7/2021	11	1,155	130
CUSTOMER REQUEST	12/7/2021	7	21	3
PLANNED	12/7/2021	1	84	84
PLANNED	12/7/2021	7	476	68
PLANNED	12/7/2021	1	13	13
PLANNED	12/7/2021	3	18	6
PLANNED	12/7/2021	1	53	53
PLANNED	12/7/2021	8	464	58
PLANNED	12/7/2021	7	231	33
PLANNED	12/7/2021	3	498	166
PLANNED	12/7/2021	4	196	49
PLANNED	12/7/2021	4	28	7
PLANNED	12/7/2021	3	12	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	1	6	6
PLANNED	12/7/2021	1	5	5
PLANNED	12/7/2021	5	130	26
PLANNED	12/7/2021	3	15	5
PLANNED	12/7/2021	8	16	2
PLANNED	12/7/2021	11	66	6
PLANNED	12/7/2021	13	299	23
PLANNED	12/7/2021	8	40	5
PLANNED	12/7/2021	8	128	16
PLANNED	12/7/2021	12	60	5
PLANNED	12/7/2021	2	28	14
PLANNED	12/7/2021	2	28	14
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	4	52	13
PLANNED	12/7/2021	2	216	108
PLANNED	12/7/2021	1	75	75
PLANNED	12/7/2021	4	48	12
PLANNED	12/7/2021	1	29	29
PLANNED	12/7/2021	44	4,796	109
PLANNED	12/7/2021	27	2,727	101
PLANNED	12/7/2021	5	220	44
PLANNED	12/7/2021	2	30	15
CUSTOMER REQUEST	12/7/2021	5	100	20
PLANNED	12/7/2021	1	16	16
PLANNED	12/7/2021	1	9	9
PLANNED	12/7/2021	6	438	73
PLANNED	12/7/2021	4	32	8
PLANNED	12/7/2021	9	162	18
PLANNED	12/7/2021	5	55	11
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	3	45	15
PLANNED	12/7/2021	6	420	70
PLANNED	12/7/2021	15	150	10
PLANNED	12/7/2021	1	11	11
PLANNED	12/7/2021	1	157	157
PLANNED	12/7/2021	1	28	28
PLANNED	12/7/2021	8	32	4
PLANNED	12/7/2021	2	12	6
PLANNED	12/7/2021	1	10	10
PLANNED	12/7/2021	46	138	3
PLANNED	12/7/2021	3	399	133

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	1	16	16
PLANNED	12/7/2021	12	216	18
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	8	72	9
PLANNED	12/7/2021	3	48	16
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	6	258	43
PLANNED	12/7/2021	2	174	87
PLANNED	12/7/2021	2	180	90
PLANNED	12/7/2021	1	9	9
PLANNED	12/7/2021	2	14	7
PLANNED	12/7/2021	4	36	9
PLANNED	12/7/2021	6	216	36
PLANNED	12/7/2021	1	20	20
PLANNED	12/7/2021	12	180	15
PLANNED	12/7/2021	5	95	19
PLANNED	12/7/2021	1	8	8
PLANNED	12/7/2021	4	28	7
PLANNED	12/7/2021	12	1,512	126
PLANNED	12/7/2021	11	66	6
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	3	18	6
PLANNED	12/7/2021	15	255	17
PLANNED	12/7/2021	10	140	14
PLANNED	12/7/2021	12	216	18
PLANNED	12/7/2021	1	8	8
PLANNED	12/7/2021	1	140	140
PLANNED	12/7/2021	8	40	5
PLANNED	12/7/2021	6	84	14
PLANNED	12/7/2021	1	8	8
CUSTOMER REQUEST	12/7/2021	1	109	109
PLANNED	12/7/2021	8	64	8
PLANNED	12/7/2021	1	8	8
PLANNED	12/7/2021	2	20	10
PLANNED	12/7/2021	2	20	10
PLANNED	12/7/2021	6	48	8
PLANNED	12/7/2021	3	21	7
PLANNED	12/7/2021	6	84	14
PLANNED	12/7/2021	1	31	31
PLANNED	12/7/2021	6	354	59
PLANNED	12/7/2021	1	89	89

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	4	88	22
PLANNED	12/7/2021	1	8	8
PLANNED	12/7/2021	2	18	9
PLANNED	12/7/2021	3	27	9
PLANNED	12/7/2021	7	56	8
PLANNED	12/7/2021	1	20	20
PLANNED	12/7/2021	1	14	14
PLANNED	12/7/2021	2	20	10
PLANNED	12/7/2021	3	42	14
PLANNED	12/7/2021	8	80	10
PLANNED	12/7/2021	1	15	15
PLANNED	12/7/2021	1	73	73
PLANNED	12/7/2021	7	84	12
PLANNED	12/7/2021	2	16	8
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	14	140	10
CUSTOMER REQUEST	12/7/2021	1	228	228
PLANNED	12/7/2021	3	111	37
PLANNED	12/7/2021	1	5	5
PLANNED	12/7/2021	3	27	9
PLANNED	12/7/2021	3	57	19
PLANNED	12/7/2021	15	1,605	107
PLANNED	12/7/2021	17	255	15
PLANNED	12/7/2021	3	21	7
PLANNED	12/7/2021	8	64	8
PLANNED	12/7/2021	3	471	157
PLANNED	12/7/2021	1	35	35
PLANNED	12/7/2021	3	261	87
PLANNED	12/7/2021	5	35	7
PLANNED	12/7/2021	3	24	8
PLANNED	12/7/2021	5	240	48
PLANNED	12/7/2021	1	8	8
PLANNED	12/7/2021	12	168	14
CUSTOMER REQUEST	12/7/2021	1	125	125
PLANNED	12/7/2021	2	20	10
PLANNED	12/7/2021	2	20	10
PLANNED	12/7/2021	13	91	7
PLANNED	12/7/2021	8	80	10
PLANNED	12/7/2021	6	66	11
PLANNED	12/7/2021	4	52	13
PLANNED	12/7/2021	7	77	11

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/7/2021	1	6	6
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	2	8	4
PLANNED	12/7/2021	11	55	5
PLANNED	12/7/2021	1	134	134
PLANNED	12/7/2021	19	285	15
PLANNED	12/7/2021	2	12	6
PLANNED	12/7/2021	1	7	7
PLANNED	12/7/2021	13	221	17
PLANNED	12/7/2021	6	60	10
PLANNED	12/7/2021	3	39	13
PLANNED	12/7/2021	1	2	2
PLANNED	12/7/2021	1	78	78
PLANNED	12/7/2021	4	20	5
PLANNED	12/7/2021	4	24	6
PLANNED	12/7/2021	9	117	13
PLANNED	12/7/2021	11	44	4
PLANNED	12/7/2021	7	35	5
PLANNED	12/7/2021	10	170	17
CUSTOMER REQUEST	12/7/2021	1	61	61
PLANNED	12/7/2021	3	15	5
PLANNED	12/7/2021	8	8	1
PLANNED	12/7/2021	1	10	10
PLANNED	12/7/2021	8	56	7
PLANNED	12/7/2021	4	60	15
PLANNED	12/7/2021	5	25	5
PLANNED	12/7/2021	9	63	7
PLANNED	12/7/2021	3	258	86
PLANNED	12/7/2021	10	80	8
PLANNED	12/7/2021	10	90	9
PLANNED	12/7/2021	33	726	22
PLANNED	12/7/2021	3	69	23
CUSTOMER REQUEST	12/7/2021	1	66	66
PLANNED	12/7/2021	5	235	47
PLANNED	12/7/2021	4	192	48
PLANNED	12/7/2021	4	532	133
PLANNED	12/7/2021	1	218	218
PLANNED	12/7/2021	1	36	36
PLANNED	12/7/2021	4	592	148
PLANNED	12/7/2021	2	292	146
PLANNED	12/7/2021	4	584	146

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	1	176	176
PLANNED	12/8/2021	1	173	173
PLANNED	12/8/2021	1	49	49
PLANNED	12/8/2021	5	275	55
PLANNED	12/8/2021	3	57	19
PLANNED	12/8/2021	7	315	45
PLANNED	12/8/2021	2	152	76
PLANNED	12/8/2021	2	12	6
PLANNED	12/8/2021	1	10	10
PLANNED	12/8/2021	9	90	10
PLANNED	12/8/2021	3	192	64
PLANNED	12/8/2021	28	5,404	193
PLANNED	12/8/2021	5	20	4
PLANNED	12/8/2021	4	24	6
PLANNED	12/8/2021	8	128	16
PLANNED	12/8/2021	1	31	31
PLANNED	12/8/2021	3	21	7
PLANNED	12/8/2021	8	56	7
PLANNED	12/8/2021	10	250	25
PLANNED	12/8/2021	6	84	14
PLANNED	12/8/2021	6	240	40
PLANNED	12/8/2021	2	286	143
PLANNED	12/8/2021	1	11	11
PLANNED	12/8/2021	12	3,048	368
PLANNED	12/8/2021	4	508	127
PLANNED	12/8/2021	4	448	112
PLANNED	12/8/2021	7	546	78
PLANNED	12/8/2021	3	30	10
PLANNED	12/8/2021	3	12	4
PLANNED	12/8/2021	12	96	8
PLANNED	12/8/2021	7	637	91
PLANNED	12/8/2021	18	558	31
PLANNED	12/8/2021	1	42	42
PLANNED	12/8/2021	2	10	5
PLANNED	12/8/2021	7	498	94
PLANNED	12/8/2021	7	483	69
PLANNED	12/8/2021	7	199	39
PLANNED	12/8/2021	2	46	23
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	10	70	7
PLANNED	12/8/2021	3	6	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	6	594	99
PLANNED	12/8/2021	4	40	10
PLANNED	12/8/2021	13	468	36
PLANNED	12/8/2021	11	935	85
CUSTOMER REQUEST	12/8/2021	25	750	30
PLANNED	12/8/2021	3	30	10
PLANNED	12/8/2021	20	460	23
PLANNED	12/8/2021	4	44	11
PLANNED	12/8/2021	2	96	48
PLANNED	12/8/2021	1	186	186
PLANNED	12/8/2021	4	40	10
PLANNED	12/8/2021	1	78	78
PLANNED	12/8/2021	16	2,768	173
PLANNED	12/8/2021	7	217	31
PLANNED	12/8/2021	2	22	11
PLANNED	12/8/2021	2	20	10
PLANNED	12/8/2021	15	195	13
CUSTOMER REQUEST	12/8/2021	8	32	4
PLANNED	12/8/2021	2	264	132
PLANNED	12/8/2021	2	16	8
PLANNED	12/8/2021	2	8	4
PLANNED	12/8/2021	5	115	23
PLANNED	12/8/2021	7	1,218	174
PLANNED	12/8/2021	2	130	65
PLANNED	12/8/2021	10	1,040	104
PLANNED	12/8/2021	1	4	4
PLANNED	12/8/2021	7	1,281	183
PLANNED	12/8/2021	1	3	3
PLANNED	12/8/2021	7	1,055	159
PLANNED	12/8/2021	1	5	5
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	11	154	14
PLANNED	12/8/2021	2	20	10
PLANNED	12/8/2021	3	24	8
PLANNED	12/8/2021	22	550	25
PLANNED	12/8/2021	3	21	7
PLANNED	12/8/2021	4	56	14
PLANNED	12/8/2021	4	28	7
CUSTOMER REQUEST	12/8/2021	6	12	2
PLANNED	12/8/2021	2	18	9
PLANNED	12/8/2021	2	228	114

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	2	16	8
PLANNED	12/8/2021	4	20	5
PLANNED	12/8/2021	1	387	387
PLANNED	12/8/2021	3	48	16
PLANNED	12/8/2021	9	180	20
PLANNED	12/8/2021	4	24	6
PLANNED	12/8/2021	12	828	69
PLANNED	12/8/2021	1	14	14
PLANNED	12/8/2021	4	20	5
PLANNED	12/8/2021	1	382	382
PLANNED	12/8/2021	28	4,984	178
PLANNED	12/8/2021	1	380	380
PLANNED	12/8/2021	1	91	91
PLANNED	12/8/2021	5	30	6
PLANNED	12/8/2021	11	253	23
PLANNED	12/8/2021	1	5	5
PLANNED	12/8/2021	1	7	7
PLANNED	12/8/2021	8	376	47
PLANNED	12/8/2021	5	915	183
PLANNED	12/8/2021	6	180	30
PLANNED	12/8/2021	3	108	36
PLANNED	12/8/2021	5	240	48
PLANNED	12/8/2021	3	54	18
PLANNED	12/8/2021	83	9,628	116
PLANNED	12/8/2021	18	594	33
PLANNED	12/8/2021	1	59	59
PLANNED	12/8/2021	2	16	8
PLANNED	12/8/2021	1	9	9
PLANNED	12/8/2021	5	55	11
PLANNED	12/8/2021	1	13	13
PLANNED	12/8/2021	4	376	94
PLANNED	12/8/2021	1	207	207
PLANNED	12/8/2021	10	200	20
PLANNED	12/8/2021	4	28	7
PLANNED	12/8/2021	3	261	87
PLANNED	12/8/2021	4	8	2
PLANNED	12/8/2021	2	20	10
PLANNED	12/8/2021	6	762	127
PLANNED	12/8/2021	3	9	3
PLANNED	12/8/2021	12	132	11
PLANNED	12/8/2021	4	8	2

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	1	23	23
PLANNED	12/8/2021	2	10	5
PLANNED	12/8/2021	2	8	4
PLANNED	12/8/2021	3	18	6
PLANNED	12/8/2021	3	18	6
PLANNED	12/8/2021	4	44	11
PLANNED	12/8/2021	3	27	9
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	2	18	9
PLANNED	12/8/2021	3	234	78
PLANNED	12/8/2021	1	56	56
PLANNED	12/8/2021	2	2	1
PLANNED	12/8/2021	1	107	107
PLANNED	12/8/2021	1	113	113
PLANNED	12/8/2021	4	80	20
PLANNED	12/8/2021	8	104	13
PLANNED	12/8/2021	2	30	15
PLANNED	12/8/2021	1	8	8
CUSTOMER REQUEST	12/8/2021	2	26	13
PLANNED	12/8/2021	4	32	8
CUSTOMER REQUEST	12/8/2021	10	190	19
PLANNED	12/8/2021	4	172	43
PLANNED	12/8/2021	5	60	12
PLANNED	12/8/2021	8	72	9
PLANNED	12/8/2021	21	1,134	54
PLANNED	12/8/2021	17	1,003	59
PLANNED	12/8/2021	1	11	11
PLANNED	12/8/2021	1	40	40
PLANNED	12/8/2021	19	1,045	55
PLANNED	12/8/2021	15	825	55
PLANNED	12/8/2021	23	1,127	49
PLANNED	12/8/2021	2	40	20
PLANNED	12/8/2021	17	935	55
PLANNED	12/8/2021	8	1,120	140
PLANNED	12/8/2021	1	2	2
PLANNED	12/8/2021	2	10	5
PLANNED	12/8/2021	2	226	113
PLANNED	12/8/2021	4	32	8
PLANNED	12/8/2021	1	6	6
PLANNED	12/8/2021	10	370	37
PLANNED	12/8/2021	5	40	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	4	28	7
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	1	9	9
PLANNED	12/8/2021	4	64	16
PLANNED	12/8/2021	1	9	9
PLANNED	12/8/2021	1	7	7
CUSTOMER REQUEST	12/8/2021	34	5,984	176
PLANNED	12/8/2021	2	14	7
PLANNED	12/8/2021	5	40	8
PLANNED	12/8/2021	1	18	18
PLANNED	12/8/2021	1	15	15
PLANNED	12/8/2021	2	62	31
PLANNED	12/8/2021	13	494	38
PLANNED	12/8/2021	7	168	24
PLANNED	12/8/2021	1	8	8
PLANNED	12/8/2021	3	504	168
PLANNED	12/8/2021	6	36	6
PLANNED	12/8/2021	3	726	242
PLANNED	12/8/2021	1	7	7
PLANNED	12/8/2021	2	8	4
CUSTOMER REQUEST	12/8/2021	1	15	15
PLANNED	12/8/2021	12	336	28
PLANNED	12/8/2021	4	824	206
PLANNED	12/8/2021	4	60	15
PLANNED	12/8/2021	3	570	190
PLANNED	12/8/2021	1	34	34
PLANNED	12/8/2021	2	140	70
PLANNED	12/8/2021	3	12	4
CUSTOMER REQUEST	12/8/2021	1	14	14
PLANNED	12/8/2021	3	24	8
PLANNED	12/8/2021	2	8	4
PLANNED	12/8/2021	2	40	20
PLANNED	12/8/2021	19	209	11
PLANNED	12/8/2021	1	66	66
PLANNED	12/8/2021	2	20	10
PLANNED	12/8/2021	4	8	2
PLANNED	12/8/2021	1	5	5
PLANNED	12/8/2021	8	104	13
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	2	12	6
PLANNED	12/8/2021	1	111	111

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	13	962	74
PLANNED	12/8/2021	12	24	2
PLANNED	12/8/2021	3	45	15
PLANNED	12/8/2021	1	2	2
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	8	392	49
PLANNED	12/8/2021	3	15	5
PLANNED	12/8/2021	1	4	4
PLANNED	12/8/2021	6	348	58
PLANNED	12/8/2021	2	10	5
PLANNED	12/8/2021	4	32	8
PLANNED	12/8/2021	8	72	9
PLANNED	12/8/2021	6	126	21
PLANNED	12/8/2021	4	28	7
PLANNED	12/8/2021	1	9	9
PLANNED	12/8/2021	3	57	19
PLANNED	12/8/2021	1	7	7
PLANNED	12/8/2021	5	55	11
PLANNED	12/8/2021	3	348	116
PLANNED	12/8/2021	4	316	79
PLANNED	12/8/2021	2	8	4
PLANNED	12/8/2021	1	51	51
PLANNED	12/8/2021	4	48	12
PLANNED	12/8/2021	8	1,096	137
PLANNED	12/8/2021	28	1,120	40
PLANNED	12/8/2021	3	33	11
PLANNED	12/8/2021	10	70	7
PLANNED	12/8/2021	1	65	65
PLANNED	12/8/2021	2	22	11
PLANNED	12/8/2021	2	98	49
PLANNED	12/8/2021	1	64	64
PLANNED	12/8/2021	8	1,696	212
PLANNED	12/8/2021	4	32	8
PLANNED	12/8/2021	2	174	87
PLANNED	12/8/2021	3	30	10
PLANNED	12/8/2021	16	224	14
PLANNED	12/8/2021	11	561	51
CUSTOMER REQUEST	12/8/2021	8	936	117
PLANNED	12/8/2021	9	198	22
PLANNED	12/8/2021	2	8	4
PLANNED	12/8/2021	13	182	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/8/2021	1	91	91
PLANNED	12/8/2021	1	4	4
PLANNED	12/8/2021	3	21	7
PLANNED	12/8/2021	3	93	31
PLANNED	12/8/2021	2	286	143
PLANNED	12/8/2021	2	84	42
PLANNED	12/8/2021	7	189	27
PLANNED	12/8/2021	6	18	3
PLANNED	12/8/2021	3	207	69
CUSTOMER REQUEST	12/8/2021	1	60	60
PLANNED	12/8/2021	5	90	18
PLANNED	12/8/2021	6	570	95
PLANNED	12/8/2021	2	354	177
PLANNED	12/8/2021	1	59	59
PLANNED	12/8/2021	3	831	277
PLANNED	12/8/2021	2	52	26
PLANNED	12/8/2021	1	182	182
PLANNED	12/8/2021	1	182	182
PLANNED	12/8/2021	3	549	183
PLANNED	12/8/2021	1	230	230
PLANNED	12/8/2021	1	232	232
PLANNED	12/8/2021	1	311	311
PLANNED	12/8/2021	8	928	116
PLANNED	12/8/2021	4	1,238	317
PLANNED	12/8/2021	9	2,583	287
PLANNED	12/9/2021	8	1,752	219
PLANNED	12/9/2021	3	36	12
PLANNED	12/9/2021	23	8,602	374
PLANNED	12/9/2021	1	132	132
PLANNED	12/9/2021	3	225	75
PLANNED	12/9/2021	1	46	46
PLANNED	12/9/2021	1	128	128
PLANNED	12/9/2021	6	864	144
PLANNED	12/9/2021	8	1,424	178
PLANNED	12/9/2021	1	90	90
PLANNED	12/9/2021	1	90	90
PLANNED	12/9/2021	1	137	137
PLANNED	12/9/2021	1	130	130
PLANNED	12/9/2021	6	786	131
PLANNED	12/9/2021	6	786	131
PLANNED	12/9/2021	1	142	142

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/9/2021	7	1,589	227
PLANNED	12/9/2021	13	1,196	92
PLANNED	12/9/2021	10	4,460	446
PLANNED	12/9/2021	7	315	45
PLANNED	12/9/2021	3	57	19
PLANNED	12/9/2021	8	488	61
PLANNED	12/9/2021	2	32	16
PLANNED	12/9/2021	7	840	120
PLANNED	12/9/2021	3	27	9
PLANNED	12/9/2021	4	320	80
CUSTOMER REQUEST	12/9/2021	10	2,270	227
PLANNED	12/9/2021	9	1,989	221
PLANNED	12/9/2021	8	24	3
PLANNED	12/9/2021	1	123	123
PLANNED	12/9/2021	16	976	61
PLANNED	12/9/2021	15	1,125	75
PLANNED	12/9/2021	2	82	41
CUSTOMER REQUEST	12/9/2021	1	278	278
PLANNED	12/9/2021	17	425	25
PLANNED	12/9/2021	1	243	243
PLANNED	12/9/2021	2	16	8
PLANNED	12/9/2021	13	130	10
PLANNED	12/9/2021	21	616	177
PLANNED	12/9/2021	1	52	52
PLANNED	12/9/2021	5	170	34
PLANNED	12/9/2021	5	75	15
PLANNED	12/9/2021	16	848	53
PLANNED	12/9/2021	3	39	13
PLANNED	12/9/2021	7	188	79
PLANNED	12/9/2021	5	225	45
PLANNED	12/9/2021	1	30	30
PLANNED	12/9/2021	3	36	12
PLANNED	12/9/2021	3	390	130
PLANNED	12/9/2021	4	584	146
CUSTOMER REQUEST	12/9/2021	8	56	7
PLANNED	12/9/2021	5	95	19
PLANNED	12/9/2021	6	1,302	217
PLANNED	12/9/2021	2	44	22
PLANNED	12/9/2021	11	396	36
PLANNED	12/9/2021	3	785	297
PLANNED	12/9/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/9/2021	5	420	84
PLANNED	12/9/2021	3	6	2
PLANNED	12/9/2021	5	635	127
PLANNED	12/9/2021	4	1,388	347
PLANNED	12/9/2021	2	104	52
PLANNED	12/9/2021	5	75	15
PLANNED	12/9/2021	1	8	8
PLANNED	12/9/2021	1	81	81
CUSTOMER REQUEST	12/9/2021	4	120	30
PLANNED	12/9/2021	1	163	163
PLANNED	12/9/2021	82	1,574	374
PLANNED	12/9/2021	2	14	7
PLANNED	12/9/2021	5	390	78
PLANNED	12/9/2021	1	148	148
PLANNED	12/9/2021	3	84	28
PLANNED	12/9/2021	3	42	14
PLANNED	12/9/2021	6	108	18
PLANNED	12/9/2021	8	728	91
PLANNED	12/9/2021	2	188	94
PLANNED	12/9/2021	2	12	6
PLANNED	12/9/2021	2	50	25
PLANNED	12/9/2021	4	610	205
PLANNED	12/9/2021	8	768	96
PLANNED	12/9/2021	9	2,124	236
PLANNED	12/9/2021	4	52	13
PLANNED	12/9/2021	6	1,164	194
PLANNED	12/9/2021	1	13	13
PLANNED	12/9/2021	9	1,170	130
PLANNED	12/9/2021	3	71	36
PLANNED	12/9/2021	3	294	98
PLANNED	12/9/2021	6	660	110
PLANNED	12/9/2021	2	10	5
PLANNED	12/9/2021	5	410	82
PLANNED	12/9/2021	2	76	38
PLANNED	12/9/2021	2	388	194
PLANNED	12/9/2021	2	66	33
PLANNED	12/9/2021	1	111	111
PLANNED	12/9/2021	8	744	93
PLANNED	12/9/2021	1	5	5
PLANNED	12/9/2021	11	3,069	279
PLANNED	12/9/2021	2	66	33

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/9/2021	16	4,656	291
PLANNED	12/9/2021	2	16	8
PLANNED	12/9/2021	8	72	9
PLANNED	12/9/2021	1	2	2
PLANNED	12/9/2021	7	1,540	220
PLANNED	12/9/2021	3	33	11
PLANNED	12/9/2021	8	64	8
PLANNED	12/9/2021	3	18	6
PLANNED	12/9/2021	4	120	30
CUSTOMER REQUEST	12/9/2021	9	1,521	169
PLANNED	12/9/2021	4	272	68
PLANNED	12/9/2021	2	28	14
PLANNED	12/9/2021	4	72	18
PLANNED	12/9/2021	9	81	9
PLANNED	12/9/2021	14	280	20
PLANNED	12/9/2021	3	15	5
PLANNED	12/9/2021	7	63	9
PLANNED	12/9/2021	8	472	59
PLANNED	12/9/2021	11	88	8
PLANNED	12/9/2021	3	30	10
PLANNED	12/9/2021	11	1,584	144
PLANNED	12/9/2021	5	290	58
PLANNED	12/9/2021	8	432	54
PLANNED	12/9/2021	4	460	115
PLANNED	12/9/2021	17	204	12
PLANNED	12/9/2021	2	136	68
PLANNED	12/9/2021	8	176	22
PLANNED	12/9/2021	3	9	3
PLANNED	12/9/2021	1	63	63
PLANNED	12/9/2021	6	72	12
PLANNED	12/9/2021	3	243	81
PLANNED	12/9/2021	7	595	85
PLANNED	12/9/2021	17	306	18
PLANNED	12/9/2021	4	36	9
PLANNED	12/9/2021	2	226	113
PLANNED	12/9/2021	1	7	7
PLANNED	12/9/2021	1	8	8
PLANNED	12/9/2021	1	4	4
PLANNED	12/9/2021	3	330	110
PLANNED	12/9/2021	8	56	7
PLANNED	12/9/2021	3	237	79

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/9/2021	3	27	9
PLANNED	12/9/2021	1	62	62
PLANNED	12/9/2021	3	12	4
PLANNED	12/9/2021	1	9	9
CUSTOMER REQUEST	12/9/2021	1	97	97
PLANNED	12/9/2021	1	36	36
PLANNED	12/9/2021	15	225	15
PLANNED	12/9/2021	6	384	64
PLANNED	12/9/2021	2	76	38
PLANNED	12/9/2021	2	10	5
PLANNED	12/9/2021	4	420	105
PLANNED	12/9/2021	3	429	143
PLANNED	12/9/2021	2	78	39
PLANNED	12/9/2021	15	420	28
PLANNED	12/9/2021	2	254	127
PLANNED	12/9/2021	3	210	70
PLANNED	12/9/2021	2	44	22
PLANNED	12/9/2021	2	38	19
PLANNED	12/9/2021	1	40	40
PLANNED	12/9/2021	2	184	92
PLANNED	12/9/2021	5	300	60
PLANNED	12/9/2021	1	55	55
CUSTOMER REQUEST	12/9/2021	1	124	124
PLANNED	12/9/2021	4	32	8
CUSTOMER REQUEST	12/9/2021	10	1,040	104
CUSTOMER REQUEST	12/9/2021	119	1,428	12
PLANNED	12/9/2021	3	183	61
PLANNED	12/9/2021	9	351	39
PLANNED	12/9/2021	6	240	40
PLANNED	12/9/2021	8	296	37
PLANNED	12/9/2021	17	2,023	119
PLANNED	12/9/2021	2	102	51
PLANNED	12/9/2021	1	282	282
PLANNED	12/9/2021	1	186	186
PLANNED	12/9/2021	9	135	15
PLANNED	12/9/2021	1	142	142
PLANNED	12/9/2021	1	137	137
PLANNED	12/9/2021	4	116	29
PLANNED	12/9/2021	1	70	70
PLANNED	12/9/2021	1	109	109
PLANNED	12/10/2021	3	450	150

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/10/2021	4	712	178
PLANNED	12/10/2021	1	74	74
PLANNED	12/10/2021	1	74	74
PLANNED	12/10/2021	5	400	80
PLANNED	12/10/2021	1	90	90
PLANNED	12/10/2021	1	72	72
PLANNED	12/10/2021	7	1,435	205
PLANNED	12/10/2021	1	47	47
PLANNED	12/10/2021	1	280	280
PLANNED	12/10/2021	1	87	87
PLANNED	12/10/2021	7	434	62
PLANNED	12/10/2021	10	1,030	103
CUSTOMER REQUEST	12/10/2021	1	230	230
PLANNED	12/10/2021	7	1,057	151
PLANNED	12/10/2021	8	392	49
PLANNED	12/10/2021	1	45	45
PLANNED	12/10/2021	2	120	60
PLANNED	12/10/2021	6	258	43
PLANNED	12/10/2021	4	52	13
PLANNED	12/10/2021	1	39	39
PLANNED	12/10/2021	1	96	96
PLANNED	12/10/2021	1	171	171
PLANNED	12/10/2021	8	216	27
PLANNED	12/10/2021	4	196	49
PLANNED	12/10/2021	5	100	20
PLANNED	12/10/2021	11	924	84
PLANNED	12/10/2021	3	33	11
CUSTOMER REQUEST	12/10/2021	40	8,080	202
PLANNED	12/10/2021	6	348	58
PLANNED	12/10/2021	6	408	68
PLANNED	12/10/2021	7	1,358	194
PLANNED	12/10/2021	4	420	105
CUSTOMER REQUEST	12/10/2021	1	279	279
PLANNED	12/10/2021	2	130	65
PLANNED	12/10/2021	7	490	70
CUSTOMER REQUEST	12/10/2021	3	96	32
PLANNED	12/10/2021	1	11	11
PLANNED	12/10/2021	4	436	109
PLANNED	12/10/2021	1	23	23
PLANNED	12/10/2021	2	198	99
PLANNED	12/10/2021	5	85	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	12/10/2021	1	63	63
PLANNED	12/10/2021	3	243	81
PLANNED	12/10/2021	2	230	115
PLANNED	12/10/2021	5	505	101
PLANNED	12/10/2021	2	110	55
PLANNED	12/10/2021	9	1,341	149
PLANNED	12/10/2021	3	51	17
CUSTOMER REQUEST	12/10/2021	6	2,490	415
PLANNED	12/10/2021	2	398	199
PLANNED	12/10/2021	4	112	28
PLANNED	12/10/2021	22	132	6
PLANNED	12/10/2021	3	66	22
PLANNED	12/10/2021	6	570	95
PLANNED	12/10/2021	2	84	42
PLANNED	12/10/2021	4	12	3
PLANNED	12/10/2021	4	56	14
PLANNED	12/10/2021	2	34	17
PLANNED	12/10/2021	10	1,330	133
PLANNED	12/10/2021	4	132	33
PLANNED	12/10/2021	8	96	12
PLANNED	12/10/2021	1	48	48
PLANNED	12/10/2021	5	35	7
PLANNED	12/10/2021	2	114	57
PLANNED	12/10/2021	6	786	131
PLANNED	12/10/2021	5	655	131
PLANNED	12/10/2021	3	393	131
PLANNED	12/10/2021	16	1,264	184
PLANNED	12/10/2021	7	77	11
PLANNED	12/10/2021	3	141	47
PLANNED	12/10/2021	11	33	3
PLANNED	12/10/2021	1	122	122
PLANNED	12/10/2021	3	292	104
CUSTOMER REQUEST	12/10/2021	25	3,375	135
PLANNED	12/10/2021	7	455	65
PLANNED	12/10/2021	1	96	96
CUSTOMER REQUEST	12/10/2021	1	135	135
CUSTOMER REQUEST	12/10/2021	1	107	107
CUSTOMER REQUEST	12/10/2021	1	245	245
PLANNED	12/10/2021	9	1,152	128
CUSTOMER REQUEST	12/10/2021	1	15	15
PLANNED	12/10/2021	26	1,638	63

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/10/2021	3	183	61
CUSTOMER REQUEST	12/10/2021	16	17,472	1,092
PLANNED	12/10/2021	1	106	106
PLANNED	12/10/2021	2	468	234
PLANNED	12/10/2021	1	120	120
PLANNED	12/10/2021	3	1,089	363
PLANNED	12/10/2021	2	722	361
PLANNED	12/10/2021	1	29	29
PLANNED	12/11/2021	1	127	127
PLANNED	12/11/2021	7	693	99
PLANNED	12/11/2021	2	624	312
PLANNED	12/11/2021	2	190	95
CUSTOMER REQUEST	12/11/2021	811	28,385	35
PLANNED	12/11/2021	22	1,232	56
PLANNED	12/11/2021	13	2,158	166
PLANNED	12/11/2021	17	1,394	82
PLANNED	12/11/2021	17	1,428	84
PLANNED	12/11/2021	1	81	81
PLANNED	12/11/2021	3	891	297
PLANNED	12/11/2021	10	240	24
PLANNED	12/11/2021	3	135	45
PLANNED	12/11/2021	4	448	112
PLANNED	12/11/2021	2	152	76
PLANNED	12/11/2021	16	4,336	271
PLANNED	12/11/2021	1	101	101
PLANNED	12/11/2021	1	185	185
PLANNED	12/11/2021	2	118	59
PLANNED	12/11/2021	1	228	228
PLANNED	12/11/2021	1	180	180
PLANNED	12/11/2021	2	130	65
PLANNED	12/11/2021	4	212	53
PLANNED	12/11/2021	3	99	33
CUSTOMER REQUEST	12/11/2021	1	88	88
CUSTOMER REQUEST	12/11/2021	6	3,450	575
PLANNED	12/12/2021	1	159	159
PLANNED	12/12/2021	25	3,875	155
PLANNED	12/12/2021	1	225	225
PLANNED	12/12/2021	1	8	8
PLANNED	12/12/2021	1	120	120
PLANNED	12/12/2021	4	1,784	446
PLANNED	12/12/2021	8	1,904	238

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/12/2021	9	2,142	238
PLANNED	12/12/2021	5	1,549	313
PLANNED	12/12/2021	3	291	97
PLANNED	12/12/2021	1	57	57
PLANNED	12/12/2021	5	195	39
PLANNED	12/12/2021	1	5	5
PLANNED	12/12/2021	2	106	53
PLANNED	12/12/2021	1	162	162
CUSTOMER REQUEST	12/12/2021	10	1,790	179
PLANNED	12/12/2021	2	552	276
PLANNED	12/13/2021	1	15	15
PLANNED	12/13/2021	1	30	30
PLANNED	12/13/2021	1	16	16
PLANNED	12/13/2021	1	137	137
PLANNED	12/13/2021	5	110	22
PLANNED	12/13/2021	6	336	56
PLANNED	12/13/2021	1	171	171
PLANNED	12/13/2021	8	56	7
PLANNED	12/13/2021	9	54	6
PLANNED	12/13/2021	9	855	95
PLANNED	12/13/2021	16	1,392	87
PLANNED	12/13/2021	4	296	74
PLANNED	12/13/2021	1	135	135
PLANNED	12/13/2021	7	308	44
PLANNED	12/13/2021	1	55	55
PLANNED	12/13/2021	9	1,413	157
PLANNED	12/13/2021	16	2,048	128
PLANNED	12/13/2021	2	208	104
PLANNED	12/13/2021	17	1,989	117
CUSTOMER REQUEST	12/13/2021	20	12,780	639
PLANNED	12/13/2021	4	60	15
PLANNED	12/13/2021	1	8	8
PLANNED	12/13/2021	1	305	305
PLANNED	12/13/2021	2	68	34
PLANNED	12/13/2021	10	150	15
PLANNED	12/13/2021	1	111	111
PLANNED	12/13/2021	76	7,828	103
PLANNED	12/13/2021	7	35	5
PLANNED	12/13/2021	8	1,768	221
PLANNED	12/13/2021	3	33	11
PLANNED	12/13/2021	4	320	80

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	6	66	11
PLANNED	12/13/2021	5	20	4
PLANNED	12/13/2021	4	36	9
PLANNED	12/13/2021	10	100	10
PLANNED	12/13/2021	7	861	123
PLANNED	12/13/2021	5	595	119
PLANNED	12/13/2021	1	184	184
PLANNED	12/13/2021	2	168	84
PLANNED	12/13/2021	1	83	83
PLANNED	12/13/2021	10	2,140	214
PLANNED	12/13/2021	9	171	19
PLANNED	12/13/2021	3	39	13
PLANNED	12/13/2021	4	116	29
PLANNED	12/13/2021	6	84	14
PLANNED	12/13/2021	3	18	6
PLANNED	12/13/2021	10	2,390	241
PLANNED	12/13/2021	6	36	6
PLANNED	12/13/2021	51	14,433	283
PLANNED	12/13/2021	6	84	14
PLANNED	12/13/2021	4	144	36
PLANNED	12/13/2021	36	4,884	247
PLANNED	12/13/2021	1	9	9
PLANNED	12/13/2021	1	170	170
PLANNED	12/13/2021	5	180	36
PLANNED	12/13/2021	13	39	3
PLANNED	12/13/2021	7	1,498	214
PLANNED	12/13/2021	4	28	7
PLANNED	12/13/2021	1	25	25
PLANNED	12/13/2021	5	30	6
PLANNED	12/13/2021	1	4	4
PLANNED	12/13/2021	1	11	11
PLANNED	12/13/2021	2	196	98
PLANNED	12/13/2021	12	96	8
PLANNED	12/13/2021	8	32	4
PLANNED	12/13/2021	4	28	7
PLANNED	12/13/2021	1	7	7
PLANNED	12/13/2021	6	30	5
PLANNED	12/13/2021	7	70	10
PLANNED	12/13/2021	1	278	278
CUSTOMER REQUEST	12/13/2021	29	145	5
PLANNED	12/13/2021	5	45	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	1	14	14
PLANNED	12/13/2021	10	290	29
PLANNED	12/13/2021	5	15	3
PLANNED	12/13/2021	7	679	97
PLANNED	12/13/2021	2	312	156
PLANNED	12/13/2021	1	115	115
PLANNED	12/13/2021	2	64	32
PLANNED	12/13/2021	10	220	22
PLANNED	12/13/2021	2	106	53
PLANNED	12/13/2021	5	185	37
PLANNED	12/13/2021	2	46	23
CUSTOMER REQUEST	12/13/2021	3	21	7
PLANNED	12/13/2021	6	18	3
PLANNED	12/13/2021	1	115	115
PLANNED	12/13/2021	12	36	3
PLANNED	12/13/2021	4	148	37
PLANNED	12/13/2021	24	336	14
PLANNED	12/13/2021	6	36	6
PLANNED	12/13/2021	8	80	10
PLANNED	12/13/2021	2	22	11
PLANNED	12/13/2021	2	12	6
PLANNED	12/13/2021	5	160	32
PLANNED	12/13/2021	3	453	151
PLANNED	12/13/2021	1	131	131
PLANNED	12/13/2021	1	9	9
PLANNED	12/13/2021	3	15	5
PLANNED	12/13/2021	2	34	17
PLANNED	12/13/2021	1	7	7
PLANNED	12/13/2021	2	226	113
PLANNED	12/13/2021	2	294	147
PLANNED	12/13/2021	1	125	125
PLANNED	12/13/2021	2	108	54
CUSTOMER REQUEST	12/13/2021	8	160	20
PLANNED	12/13/2021	12	816	68
PLANNED	12/13/2021	1	69	69
PLANNED	12/13/2021	15	105	7
PLANNED	12/13/2021	3	21	7
PLANNED	12/13/2021	1	43	43
PLANNED	12/13/2021	2	320	160
PLANNED	12/13/2021	2	2	1
PLANNED	12/13/2021	4	128	32

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	17	680	40
PLANNED	12/13/2021	4	208	52
PLANNED	12/13/2021	8	120	15
PLANNED	12/13/2021	11	330	30
PLANNED	12/13/2021	1	17	17
PLANNED	12/13/2021	13	1,196	92
CUSTOMER REQUEST	12/13/2021	1	3	3
PLANNED	12/13/2021	2	42	21
PLANNED	12/13/2021	9	216	24
PLANNED	12/13/2021	2	14	7
PLANNED	12/13/2021	8	16	2
PLANNED	12/13/2021	5	25	5
PLANNED	12/13/2021	10	190	19
PLANNED	12/13/2021	2	12	6
PLANNED	12/13/2021	6	945	205
PLANNED	12/13/2021	8	48	6
PLANNED	12/13/2021	9	432	48
PLANNED	12/13/2021	3	102	34
PLANNED	12/13/2021	5	25	5
PLANNED	12/13/2021	14	84	6
PLANNED	12/13/2021	3	27	9
PLANNED	12/13/2021	7	903	129
PLANNED	12/13/2021	1	7	7
PLANNED	12/13/2021	6	762	127
PLANNED	12/13/2021	4	20	5
PLANNED	12/13/2021	1	63	63
PLANNED	12/13/2021	7	791	113
PLANNED	12/13/2021	5	15	3
PLANNED	12/13/2021	4	32	8
PLANNED	12/13/2021	6	72	12
CUSTOMER REQUEST	12/13/2021	2,571	38,565	15
PLANNED	12/13/2021	11	66	6
PLANNED	12/13/2021	1	7	7
PLANNED	12/13/2021	18	198	11
PLANNED	12/13/2021	9	279	31
PLANNED	12/13/2021	10	100	10
PLANNED	12/13/2021	17	323	19
PLANNED	12/13/2021	1	4	4
PLANNED	12/13/2021	14	280	20
PLANNED	12/13/2021	6	432	72
PLANNED	12/13/2021	2	8	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	8	32	4
PLANNED	12/13/2021	3	39	13
PLANNED	12/13/2021	11	440	40
PLANNED	12/13/2021	6	408	68
PLANNED	12/13/2021	4	344	86
PLANNED	12/13/2021	5	340	68
PLANNED	12/13/2021	12	84	7
PLANNED	12/13/2021	1	39	39
PLANNED	12/13/2021	10	200	20
PLANNED	12/13/2021	3	27	9
PLANNED	12/13/2021	7	42	6
PLANNED	12/13/2021	8	664	83
PLANNED	12/13/2021	9	81	9
PLANNED	12/13/2021	9	153	17
PLANNED	12/13/2021	17	374	22
PLANNED	12/13/2021	4	56	14
PLANNED	12/13/2021	1	121	121
PLANNED	12/13/2021	1	3	3
PLANNED	12/13/2021	4	720	180
PLANNED	12/13/2021	2	78	39
PLANNED	12/13/2021	2	18	9
PLANNED	12/13/2021	10	80	8
PLANNED	12/13/2021	11	66	6
PLANNED	12/13/2021	1	113	113
PLANNED	12/13/2021	11	451	41
PLANNED	12/13/2021	1	3	3
PLANNED	12/13/2021	9	45	5
PLANNED	12/13/2021	3	87	29
PLANNED	12/13/2021	6	90	15
PLANNED	12/13/2021	1	10	10
PLANNED	12/13/2021	3	12	4
PLANNED	12/13/2021	2	10	5
PLANNED	12/13/2021	7	49	7
PLANNED	12/13/2021	10	40	4
PLANNED	12/13/2021	2	252	126
PLANNED	12/13/2021	3	45	15
PLANNED	12/13/2021	5	85	17
PLANNED	12/13/2021	4	104	26
PLANNED	12/13/2021	3	9	3
PLANNED	12/13/2021	11	462	42
PLANNED	12/13/2021	2	8	4

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	3	21	7
PLANNED	12/13/2021	7	245	35
PLANNED	12/13/2021	12	204	17
PLANNED	12/13/2021	6	180	30
PLANNED	12/13/2021	12	60	5
PLANNED	12/13/2021	13	338	26
PLANNED	12/13/2021	1	134	134
PLANNED	12/13/2021	8	88	11
PLANNED	12/13/2021	7	259	37
PLANNED	12/13/2021	4	204	51
PLANNED	12/13/2021	4	80	20
PLANNED	12/13/2021	7	49	7
PLANNED	12/13/2021	2	6	3
PLANNED	12/13/2021	7	56	8
PLANNED	12/13/2021	1	62	62
PLANNED	12/13/2021	7	1,148	164
PLANNED	12/13/2021	6	1,290	215
PLANNED	12/13/2021	6	168	28
PLANNED	12/13/2021	12	396	33
PLANNED	12/13/2021	7	35	5
PLANNED	12/13/2021	9	252	28
PLANNED	12/13/2021	6	618	103
PLANNED	12/13/2021	7	140	20
PLANNED	12/13/2021	9	585	65
CUSTOMER REQUEST	12/13/2021	3	15	5
PLANNED	12/13/2021	3	18	6
PLANNED	12/13/2021	9	108	12
PLANNED	12/13/2021	3	84	28
PLANNED	12/13/2021	4	28	7
PLANNED	12/13/2021	7	301	43
PLANNED	12/13/2021	2	14	7
PLANNED	12/13/2021	4	28	7
PLANNED	12/13/2021	11	110	10
PLANNED	12/13/2021	14	126	9
PLANNED	12/13/2021	5	60	12
CUSTOMER REQUEST	12/13/2021	1	10	10
PLANNED	12/13/2021	1	9	9
PLANNED	12/13/2021	12	108	9
PLANNED	12/13/2021	9	1,116	124
PLANNED	12/13/2021	2	14	7
PLANNED	12/13/2021	2	28	14

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/13/2021	7	42	6
PLANNED	12/13/2021	10	80	8
PLANNED	12/13/2021	13	169	13
PLANNED	12/13/2021	10	50	5
PLANNED	12/13/2021	2	258	129
PLANNED	12/13/2021	3	255	85
CUSTOMER REQUEST	12/13/2021	5	590	118
PLANNED	12/14/2021	3	396	132
PLANNED	12/14/2021	5	735	147
PLANNED	12/14/2021	1	98	98
PLANNED	12/14/2021	6	408	68
PLANNED	12/14/2021	3	39	13
PLANNED	12/14/2021	4	232	58
PLANNED	12/14/2021	2	332	166
PLANNED	12/14/2021	2	130	65
PLANNED	12/14/2021	6	102	17
PLANNED	12/14/2021	3	438	146
PLANNED	12/14/2021	1	6	6
PLANNED	12/14/2021	2	208	104
PLANNED	12/14/2021	1	43	43
PLANNED	12/14/2021	1	7	7
PLANNED	12/14/2021	6	258	43
PLANNED	12/14/2021	9	90	10
PLANNED	12/14/2021	3	24	8
PLANNED	12/14/2021	2	287	150
PLANNED	12/14/2021	6	84	14
CUSTOMER REQUEST	12/14/2021	10	60	6
PLANNED	12/14/2021	16	1,040	65
PLANNED	12/14/2021	3	18	6
PLANNED	12/14/2021	12	312	26
CUSTOMER REQUEST	12/14/2021	5	60	12
PLANNED	12/14/2021	1	10	10
PLANNED	12/14/2021	4	744	186
PLANNED	12/14/2021	7	322	46
PLANNED	12/14/2021	3	21	7
PLANNED	12/14/2021	13	1,300	100
PLANNED	12/14/2021	3	12	4
PLANNED	12/14/2021	8	144	18
PLANNED	12/14/2021	19	266	14
PLANNED	12/14/2021	1	40	40
PLANNED	12/14/2021	2	34	17

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/14/2021	1	100	100
PLANNED	12/14/2021	8	480	60
PLANNED	12/14/2021	2	26	13
PLANNED	12/14/2021	1	13	13
PLANNED	12/14/2021	2	18	9
PLANNED	12/14/2021	1	60	60
PLANNED	12/14/2021	12	264	22
PLANNED	12/14/2021	8	192	24
CUSTOMER REQUEST	12/14/2021	1	279	279
PLANNED	12/14/2021	5	30	6
PLANNED	12/14/2021	3	33	11
PLANNED	12/14/2021	2	6	3
CUSTOMER REQUEST	12/14/2021	4	24	6
CUSTOMER REQUEST	12/14/2021	11	55	5
PLANNED	12/14/2021	3	162	54
PLANNED	12/14/2021	3	27	9
PLANNED	12/14/2021	4	36	9
PLANNED	12/14/2021	10	430	43
PLANNED	12/14/2021	2	244	122
PLANNED	12/14/2021	4	80	20
PLANNED	12/14/2021	8	200	25
PLANNED	12/14/2021	8	96	12
PLANNED	12/14/2021	8	2,024	253
PLANNED	12/14/2021	10	150	15
PLANNED	12/14/2021	3	39	13
PLANNED	12/14/2021	1	207	207
PLANNED	12/14/2021	2	122	61
PLANNED	12/14/2021	2	18	9
PLANNED	12/14/2021	10	140	14
PLANNED	12/14/2021	2	14	7
PLANNED	12/14/2021	2	116	58
PLANNED	12/14/2021	4	28	7
PLANNED	12/14/2021	4	312	78
PLANNED	12/14/2021	7	35	5
PLANNED	12/14/2021	8	336	42
PLANNED	12/14/2021	75	1,275	17
PLANNED	12/14/2021	7	224	32
PLANNED	12/14/2021	10	300	30
PLANNED	12/14/2021	10	100	10
PLANNED	12/14/2021	4	224	56
PLANNED	12/14/2021	1	9	9

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/14/2021	2	354	177
PLANNED	12/14/2021	3	423	141
PLANNED	12/14/2021	4	96	24
PLANNED	12/14/2021	6	30	5
PLANNED	12/14/2021	14	112	8
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	8	64	8
PLANNED	12/14/2021	2	364	182
PLANNED	12/14/2021	7	70	10
PLANNED	12/14/2021	5	40	8
PLANNED	12/14/2021	3	30	10
CUSTOMER REQUEST	12/14/2021	3	342	114
PLANNED	12/14/2021	7	238	34
PLANNED	12/14/2021	9	234	26
PLANNED	12/14/2021	3	12	4
PLANNED	12/14/2021	2	20	10
PLANNED	12/14/2021	11	264	24
PLANNED	12/14/2021	6	78	13
CUSTOMER REQUEST	12/14/2021	2	38	19
PLANNED	12/14/2021	7	280	40
PLANNED	12/14/2021	7	119	17
PLANNED	12/14/2021	9	315	35
CUSTOMER REQUEST	12/14/2021	1	485	485
PLANNED	12/14/2021	4	128	32
PLANNED	12/14/2021	11	946	86
PLANNED	12/14/2021	1	50	50
PLANNED	12/14/2021	1	5	5
PLANNED	12/14/2021	6	36	6
PLANNED	12/14/2021	4	32	8
PLANNED	12/14/2021	3	36	12
PLANNED	12/14/2021	7	1,918	274
PLANNED	12/14/2021	4	288	72
PLANNED	12/14/2021	1	7	7
PLANNED	12/14/2021	1	77	77
PLANNED	12/14/2021	7	336	48
PLANNED	12/14/2021	12	108	9
PLANNED	12/14/2021	4	80	20
PLANNED	12/14/2021	18	1,900	167
PLANNED	12/14/2021	1	6	6
PLANNED	12/14/2021	2	22	11
PLANNED	12/14/2021	7	273	39

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/14/2021	10	420	42
PLANNED	12/14/2021	4	236	59
PLANNED	12/14/2021	10	140	14
PLANNED	12/14/2021	4	248	62
PLANNED	12/14/2021	1	10	10
PLANNED	12/14/2021	1	6	6
PLANNED	12/14/2021	27	3,024	112
PLANNED	12/14/2021	12	192	16
CUSTOMER REQUEST	12/14/2021	1	128	128
PLANNED	12/14/2021	14	2,884	206
PLANNED	12/14/2021	5	30	6
PLANNED	12/14/2021	6	306	51
PLANNED	12/14/2021	4	44	11
PLANNED	12/14/2021	10	180	18
PLANNED	12/14/2021	5	45	9
PLANNED	12/14/2021	4	40	10
PLANNED	12/14/2021	4	146	41
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	2	14	7
PLANNED	12/14/2021	1	113	113
PLANNED	12/14/2021	7	77	11
PLANNED	12/14/2021	7	147	21
PLANNED	12/14/2021	6	48	8
PLANNED	12/14/2021	4	68	17
PLANNED	12/14/2021	2	8	4
PLANNED	12/14/2021	1	43	43
CUSTOMER REQUEST	12/14/2021	15	1,350	90
PLANNED	12/14/2021	4	40	10
PLANNED	12/14/2021	10	410	41
PLANNED	12/14/2021	20	640	32
PLANNED	12/14/2021	2	18	9
PLANNED	12/14/2021	7	182	26
PLANNED	12/14/2021	10	60	6
PLANNED	12/14/2021	11	66	6
PLANNED	12/14/2021	2	10	5
PLANNED	12/14/2021	11	66	6
PLANNED	12/14/2021	4	56	14
PLANNED	12/14/2021	1	49	49
PLANNED	12/14/2021	6	252	42
PLANNED	12/14/2021	2	128	64
CUSTOMER REQUEST	12/14/2021	4	804	201

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/14/2021	2	12	6
PLANNED	12/14/2021	10	70	7
PLANNED	12/14/2021	12	348	29
PLANNED	12/14/2021	7	623	89
PLANNED	12/14/2021	10	100	10
PLANNED	12/14/2021	8	200	25
PLANNED	12/14/2021	9	144	16
PLANNED	12/14/2021	10	150	15
PLANNED	12/14/2021	9	261	29
PLANNED	12/14/2021	3	21	7
PLANNED	12/14/2021	4	68	17
PLANNED	12/14/2021	10	110	11
CUSTOMER REQUEST	12/14/2021	1	261	261
PLANNED	12/14/2021	4	44	11
PLANNED	12/14/2021	1	7	7
PLANNED	12/14/2021	10	220	22
PLANNED	12/14/2021	6	1,158	193
PLANNED	12/14/2021	1	3	3
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	1	5	5
PLANNED	12/14/2021	1	9	9
PLANNED	12/14/2021	3	27	9
PLANNED	12/14/2021	7	168	24
PLANNED	12/14/2021	1	3	3
PLANNED	12/14/2021	6	144	24
PLANNED	12/14/2021	11	33	3
PLANNED	12/14/2021	4	28	7
PLANNED	12/14/2021	61	7,808	128
PLANNED	12/14/2021	4	116	29
PLANNED	12/14/2021	1	9	9
CUSTOMER REQUEST	12/14/2021	1	66	66
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	11	209	19
PLANNED	12/14/2021	13	234	18
PLANNED	12/14/2021	1	19	19
PLANNED	12/14/2021	10	140	14
PLANNED	12/14/2021	7	21	3
PLANNED	12/14/2021	6	30	5
PLANNED	12/14/2021	3	24	8
PLANNED	12/14/2021	12	300	25
PLANNED	12/14/2021	1	28	28

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/14/2021	3	318	106
PLANNED	12/14/2021	11	264	24
PLANNED	12/14/2021	4	36	9
PLANNED	12/14/2021	8	128	16
PLANNED	12/14/2021	3	84	28
PLANNED	12/14/2021	2	16	8
PLANNED	12/14/2021	4	12	3
PLANNED	12/14/2021	2	10	5
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	1	5	5
PLANNED	12/14/2021	9	54	6
CUSTOMER REQUEST	12/14/2021	1	149	149
PLANNED	12/14/2021	1	5	5
PLANNED	12/14/2021	1	103	103
PLANNED	12/14/2021	10	60	6
PLANNED	12/14/2021	1	3	3
PLANNED	12/14/2021	6	750	125
PLANNED	12/14/2021	12	96	8
PLANNED	12/14/2021	9	441	49
PLANNED	12/14/2021	4	20	5
PLANNED	12/14/2021	3	138	46
PLANNED	12/14/2021	2	20	10
PLANNED	12/14/2021	12	84	7
PLANNED	12/14/2021	2	114	57
PLANNED	12/14/2021	6	96	16
PLANNED	12/14/2021	1	89	89
PLANNED	12/14/2021	1	47	47
PLANNED	12/14/2021	3	36	12
PLANNED	12/14/2021	6	504	84
PLANNED	12/14/2021	5	775	155
PLANNED	12/14/2021	2	14	7
PLANNED	12/14/2021	3	180	60
PLANNED	12/14/2021	2	8	4
PLANNED	12/14/2021	8	80	10
PLANNED	12/14/2021	4	56	14
PLANNED	12/14/2021	8	280	35
PLANNED	12/14/2021	3	87	29
PLANNED	12/14/2021	1	30	30
PLANNED	12/14/2021	1	5	5
PLANNED	12/14/2021	12	336	28
PLANNED	12/14/2021	6	30	5

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
CUSTOMER REQUEST	12/14/2021	19	1,919	101
PLANNED	12/14/2021	2	14	7
PLANNED	12/14/2021	3	15	5
PLANNED	12/14/2021	4	28	7
PLANNED	12/14/2021	3	72	24
PLANNED	12/14/2021	2	8	4
PLANNED	12/14/2021	3	15	5
PLANNED	12/14/2021	10	340	34
PLANNED	12/14/2021	6	114	19
PLANNED	12/14/2021	4	40	10
PLANNED	12/14/2021	6	66	11
CUSTOMER REQUEST	12/14/2021	1	249	249
PLANNED	12/14/2021	4	20	5
PLANNED	12/14/2021	1	18	18
PLANNED	12/14/2021	1	4	4
PLANNED	12/14/2021	1	8	8
PLANNED	12/14/2021	3	201	67
PLANNED	12/14/2021	10	80	8
PLANNED	12/14/2021	4	20	5
PLANNED	12/14/2021	4	64	16
PLANNED	12/14/2021	1	12	12
PLANNED	12/14/2021	3	702	234
PLANNED	12/14/2021	4	220	55
PLANNED	12/14/2021	1	82	82
PLANNED	12/14/2021	7	476	68
PLANNED	12/14/2021	4	36	9
PLANNED	12/14/2021	2	26	13
PLANNED	12/14/2021	47	3,525	75
PLANNED	12/14/2021	4	28	7
PLANNED	12/14/2021	4	32	8
PLANNED	12/14/2021	4	24	6
PLANNED	12/14/2021	4	612	153
PLANNED	12/14/2021	1	199	199
PLANNED	12/14/2021	11	1,012	92
PLANNED	12/14/2021	2	138	69
PLANNED	12/15/2021	15	705	47
PLANNED	12/15/2021	20	1,000	50
PLANNED	12/15/2021	8	1,488	186
PLANNED	12/15/2021	16	176	11
PLANNED	12/15/2021	4	524	131
PLANNED	12/15/2021	1	71	71

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/15/2021	5	65	13
PLANNED	12/15/2021	10	280	28
PLANNED	12/15/2021	2	348	174
PLANNED	12/15/2021	2	242	121
PLANNED	12/15/2021	2	98	49
PLANNED	12/15/2021	4	32	8
PLANNED	12/15/2021	4	428	107
PLANNED	12/15/2021	2	134	67
PLANNED	12/15/2021	8	1,106	152
PLANNED	12/15/2021	1	23	23
PLANNED	12/15/2021	3	387	129
PLANNED	12/15/2021	4	156	39
PLANNED	12/15/2021	6	672	112
PLANNED	12/15/2021	9	45	5
PLANNED	12/15/2021	4	496	124
PLANNED	12/15/2021	1	65	65
PLANNED	12/15/2021	1	44	44
PLANNED	12/15/2021	8	64	8
PLANNED	12/15/2021	3	249	83
PLANNED	12/15/2021	1	120	120
PLANNED	12/15/2021	7	42	6
PLANNED	12/15/2021	8	72	9
PLANNED	12/15/2021	1	77	77
PLANNED	12/15/2021	7	203	29
PLANNED	12/15/2021	2	96	48
PLANNED	12/15/2021	5	695	139
PLANNED	12/15/2021	5	360	72
PLANNED	12/15/2021	4	192	48
PLANNED	12/15/2021	2	26	13
PLANNED	12/15/2021	5	365	73
PLANNED	12/15/2021	9	90	10
PLANNED	12/15/2021	4	276	69
PLANNED	12/15/2021	2	64	32
PLANNED	12/15/2021	5	762	205
PLANNED	12/15/2021	8	64	8
PLANNED	12/15/2021	6	1,050	175
PLANNED	12/15/2021	26	3,666	141
PLANNED	12/15/2021	14	686	49
PLANNED	12/15/2021	8	520	65
PLANNED	12/15/2021	12	288	24
PLANNED	12/15/2021	3	660	220

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/15/2021	4	136	34
PLANNED	12/15/2021	2	116	58
PLANNED	12/15/2021	4	64	16
PLANNED	12/15/2021	1	235	235
PLANNED	12/15/2021	1	31	31
PLANNED	12/15/2021	3	9	3
PLANNED	12/15/2021	3	45	15
PLANNED	12/15/2021	2	136	68
PLANNED	12/15/2021	3	132	44
PLANNED	12/15/2021	4	64	16
PLANNED	12/15/2021	25	1,175	47
PLANNED	12/15/2021	3	273	91
PLANNED	12/15/2021	1	95	95
PLANNED	12/15/2021	2	166	83
PLANNED	12/15/2021	6	60	10
PLANNED	12/15/2021	5	240	48
PLANNED	12/15/2021	3	27	9
PLANNED	12/15/2021	12	1,824	152
PLANNED	12/15/2021	2	8	4
PLANNED	12/15/2021	12	1,800	150
PLANNED	12/15/2021	6	852	142
PLANNED	12/15/2021	1	58	58
PLANNED	12/15/2021	2	26	13
PLANNED	12/15/2021	3	51	17
PLANNED	12/15/2021	1	14	14
PLANNED	12/15/2021	7	168	24
PLANNED	12/15/2021	1	38	38
PLANNED	12/15/2021	10	250	25
PLANNED	12/15/2021	2	188	94
PLANNED	12/15/2021	2	110	55
PLANNED	12/15/2021	2	174	87
PLANNED	12/15/2021	4	692	173
PLANNED	12/15/2021	4	104	26
PLANNED	12/15/2021	3	27	9
PLANNED	12/15/2021	3	9	3
PLANNED	12/15/2021	1	6	6
PLANNED	12/15/2021	2	10	5
PLANNED	12/15/2021	2	44	22
PLANNED	12/15/2021	6	168	28
PLANNED	12/15/2021	3	21	7
PLANNED	12/15/2021	3	216	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/15/2021	7	168	24
PLANNED	12/15/2021	12	1,728	232
PLANNED	12/15/2021	2	12	6
PLANNED	12/15/2021	1	162	162
PLANNED	12/15/2021	8	376	47
PLANNED	12/15/2021	4	128	32
PLANNED	12/15/2021	1	9	9
PLANNED	12/15/2021	6	504	84
PLANNED	12/15/2021	3	15	5
PLANNED	12/15/2021	5	5	1
PLANNED	12/15/2021	2	16	8
PLANNED	12/15/2021	7	658	94
PLANNED	12/15/2021	10	940	94
PLANNED	12/15/2021	8	96	12
PLANNED	12/15/2021	7	280	40
PLANNED	12/15/2021	3	33	11
PLANNED	12/15/2021	9	162	18
PLANNED	12/15/2021	2	10	5
PLANNED	12/15/2021	1	87	87
PLANNED	12/15/2021	7	266	38
PLANNED	12/15/2021	1	3	3
PLANNED	12/15/2021	2	16	8
PLANNED	12/15/2021	6	60	10
PLANNED	12/15/2021	2	14	7
PLANNED	12/15/2021	2	250	125
PLANNED	12/15/2021	9	81	9
PLANNED	12/15/2021	8	88	11
PLANNED	12/15/2021	6	54	9
PLANNED	12/15/2021	3	18	6
PLANNED	12/15/2021	3	36	12
PLANNED	12/15/2021	4	20	5
PLANNED	12/15/2021	2	22	11
PLANNED	12/15/2021	3	6	2
PLANNED	12/15/2021	2	10	5
PLANNED	12/15/2021	4	36	9
PLANNED	12/15/2021	5	115	23
PLANNED	12/15/2021	4	60	15
PLANNED	12/15/2021	2	12	6
PLANNED	12/15/2021	2	154	77
PLANNED	12/15/2021	2	12	6
PLANNED	12/15/2021	11	594	54

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/15/2021	3	240	80
PLANNED	12/15/2021	12	72	6
PLANNED	12/15/2021	9	54	6
PLANNED	12/15/2021	5	310	62
PLANNED	12/15/2021	4	60	15
PLANNED	12/15/2021	2	62	31
PLANNED	12/15/2021	4	16	4
PLANNED	12/15/2021	7	91	13
PLANNED	12/15/2021	13	91	7
PLANNED	12/15/2021	4	356	124
PLANNED	12/15/2021	6	54	9
PLANNED	12/15/2021	2	44	22
PLANNED	12/15/2021	2	74	37
PLANNED	12/15/2021	1	115	115
PLANNED	12/15/2021	13	130	10
PLANNED	12/15/2021	3	24	8
PLANNED	12/15/2021	4	200	50
CUSTOMER REQUEST	12/15/2021	1	82	82
PLANNED	12/15/2021	13	117	9
PLANNED	12/15/2021	11	99	9
PLANNED	12/15/2021	15	300	20
PLANNED	12/15/2021	17	153	9
PLANNED	12/15/2021	1	14	14
CUSTOMER REQUEST	12/15/2021	7	308	44
PLANNED	12/15/2021	8	344	43
PLANNED	12/15/2021	1	79	79
PLANNED	12/15/2021	1	300	300
PLANNED	12/15/2021	1	93	93
PLANNED	12/15/2021	6	582	97
PLANNED	12/15/2021	2	156	78
PLANNED	12/15/2021	13	2,106	162
PLANNED	12/15/2021	2	126	63
PLANNED	12/15/2021	9	27	3
PLANNED	12/15/2021	10	2,420	242
PLANNED	12/16/2021	1	64	64
PLANNED	12/16/2021	8	72	9
PLANNED	12/16/2021	9	225	25
PLANNED	12/16/2021	19	4,674	246
PLANNED	12/16/2021	8	584	73
PLANNED	12/16/2021	5	295	59
PLANNED	12/16/2021	8	760	95

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/16/2021	1	99	99
PLANNED	12/16/2021	1	121	121
PLANNED	12/16/2021	2	24	12
PLANNED	12/16/2021	4	220	55
PLANNED	12/16/2021	6	960	160
PLANNED	12/16/2021	8	224	28
PLANNED	12/16/2021	9	394	59
PLANNED	12/16/2021	4	116	29
CUSTOMER REQUEST	12/16/2021	1	557	557
PLANNED	12/16/2021	3	48	16
PLANNED	12/16/2021	35	4,935	141
PLANNED	12/16/2021	18	5,310	295
PLANNED	12/16/2021	5	1,706	433
PLANNED	12/16/2021	1	43	43
PLANNED	12/16/2021	6	48	8
PLANNED	12/16/2021	9	2,213	442
PLANNED	12/16/2021	7	588	84
PLANNED	12/16/2021	1	216	216
PLANNED	12/16/2021	2	22	11
PLANNED	12/16/2021	4	1,116	279
PLANNED	12/16/2021	8	152	19
PLANNED	12/16/2021	8	40	5
PLANNED	12/16/2021	1	38	38
PLANNED	12/16/2021	2	164	82
PLANNED	12/16/2021	6	114	19
PLANNED	12/16/2021	4	188	47
PLANNED	12/16/2021	1	68	68
PLANNED	12/16/2021	3	18	6
PLANNED	12/16/2021	13	884	68
PLANNED	12/16/2021	2	314	157
PLANNED	12/16/2021	6	1,530	255
PLANNED	12/16/2021	2	14	7
PLANNED	12/16/2021	2	212	106
PLANNED	12/16/2021	2	84	42
PLANNED	12/16/2021	13	338	26
PLANNED	12/16/2021	4	64	16
PLANNED	12/16/2021	4	864	216
PLANNED	12/16/2021	5	155	31
PLANNED	12/16/2021	1	8	8
PLANNED	12/16/2021	1	29	29
CUSTOMER REQUEST	12/16/2021	3	853	304

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/16/2021	3	45	15
PLANNED	12/16/2021	5	50	10
PLANNED	12/16/2021	13	1,352	104
PLANNED	12/16/2021	9	252	28
PLANNED	12/16/2021	2	28	14
PLANNED	12/16/2021	17	2,703	159
PLANNED	12/16/2021	2	10	5
PLANNED	12/16/2021	132	1,452	11
PLANNED	12/16/2021	2	92	46
PLANNED	12/16/2021	3	390	130
PLANNED	12/16/2021	12	648	54
PLANNED	12/16/2021	7	245	35
PLANNED	12/16/2021	6	90	15
PLANNED	12/16/2021	2	328	164
PLANNED	12/16/2021	35	5,915	169
PLANNED	12/16/2021	9	45	5
PLANNED	12/16/2021	10	170	17
PLANNED	12/16/2021	1	71	71
PLANNED	12/16/2021	1	14	14
PLANNED	12/16/2021	11	231	21
PLANNED	12/16/2021	15	165	11
PLANNED	12/16/2021	8	72	9
CUSTOMER REQUEST	12/16/2021	11	440	40
PLANNED	12/16/2021	1	10	10
PLANNED	12/16/2021	2	270	135
PLANNED	12/16/2021	1	12	12
PLANNED	12/16/2021	12	192	16
PLANNED	12/16/2021	7	1,239	177
PLANNED	12/16/2021	2	36	18
PLANNED	12/16/2021	3	351	117
PLANNED	12/16/2021	59	826	14
PLANNED	12/16/2021	5	195	39
PLANNED	12/16/2021	3	117	39
PLANNED	12/16/2021	9	981	109
PLANNED	12/16/2021	17	1,615	95
PLANNED	12/16/2021	1	219	219
PLANNED	12/16/2021	7	112	16
PLANNED	12/16/2021	4	776	194
PLANNED	12/16/2021	3	24	8
CUSTOMER REQUEST	12/16/2021	1	169	169
PLANNED	12/16/2021	2	14	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/16/2021	3	12	4
PLANNED	12/16/2021	17	833	49
CUSTOMER REQUEST	12/16/2021	19	57	3
PLANNED	12/16/2021	1	6	6
PLANNED	12/16/2021	8	872	109
PLANNED	12/16/2021	1	124	124
PLANNED	12/16/2021	2	444	222
PLANNED	12/16/2021	1	25	25
PLANNED	12/16/2021	2	146	73
PLANNED	12/16/2021	15	390	26
PLANNED	12/16/2021	2	20	10
PLANNED	12/16/2021	2	10	5
PLANNED	12/16/2021	3	303	101
PLANNED	12/16/2021	2	124	62
PLANNED	12/16/2021	8	1,364	287
PLANNED	12/16/2021	1	77	77
CUSTOMER REQUEST	12/16/2021	1	310	310
PLANNED	12/16/2021	1	6	6
PLANNED	12/16/2021	2	10	5
PLANNED	12/16/2021	2	132	66
PLANNED	12/16/2021	1	58	58
PLANNED	12/16/2021	4	124	31
PLANNED	12/16/2021	1	6	6
PLANNED	12/16/2021	4	28	7
PLANNED	12/16/2021	8	136	17
PLANNED	12/16/2021	8	136	17
PLANNED	12/16/2021	4	128	32
PLANNED	12/16/2021	1	73	73
PLANNED	12/16/2021	8	512	64
PLANNED	12/16/2021	5	170	34
CUSTOMER REQUEST	12/16/2021	1	314	314
PLANNED	12/16/2021	1	6	6
PLANNED	12/16/2021	2	168	84
PLANNED	12/16/2021	3	15	5
CUSTOMER REQUEST	12/16/2021	3,760	56,400	15
PLANNED	12/16/2021	4	28	7
PLANNED	12/16/2021	4	432	108
PLANNED	12/16/2021	8	1,296	162
PLANNED	12/16/2021	3	72	24
PLANNED	12/16/2021	2	22	11
PLANNED	12/16/2021	2	16	8

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/16/2021	8	120	15
PLANNED	12/16/2021	1	5	5
PLANNED	12/16/2021	22	484	22
PLANNED	12/16/2021	4	64	16
PLANNED	12/16/2021	1	67	67
CUSTOMER REQUEST	12/16/2021	1	438	438
PLANNED	12/16/2021	5	55	11
PLANNED	12/16/2021	2	14	7
PLANNED	12/16/2021	4	44	11
PLANNED	12/16/2021	2	84	42
PLANNED	12/16/2021	2	16	8
PLANNED	12/16/2021	4	60	15
PLANNED	12/16/2021	38	456	12
PLANNED	12/16/2021	3	348	116
PLANNED	12/16/2021	3	15	5
CUSTOMER REQUEST	12/16/2021	8	56	7
CUSTOMER REQUEST	12/16/2021	1	97	97
PLANNED	12/16/2021	16	5,424	339
PLANNED	12/16/2021	8	56	7
PLANNED	12/16/2021	2	346	173
PLANNED	12/16/2021	9	180	60
PLANNED	12/16/2021	4	1,176	294
PLANNED	12/16/2021	1	104	104
PLANNED	12/16/2021	1	1,449	1,449
PLANNED	12/16/2021	4	456	114
PLANNED	12/16/2021	1	111	111
PLANNED	12/16/2021	7	357	51
PLANNED	12/16/2021	14	210	15
PLANNED	12/16/2021	3	762	254
PLANNED	12/16/2021	11	1,595	145
PLANNED	12/16/2021	1	252	252
PLANNED	12/16/2021	1	63	63
PLANNED	12/16/2021	6	1,422	237
PLANNED	12/16/2021	10	2,990	299
PLANNED	12/16/2021	1	122	122
PLANNED	12/16/2021	9	1,008	112
PLANNED	12/16/2021	33	5,148	156
PLANNED	12/16/2021	3	309	103
PLANNED	12/17/2021	2	168	84
PLANNED	12/17/2021	2	266	133
PLANNED	12/17/2021	14	4,466	319

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/17/2021	1	82	82
PLANNED	12/17/2021	1	111	111
PLANNED	12/17/2021	1	29	29
PLANNED	12/17/2021	1	96	96
PLANNED	12/17/2021	7	721	103
PLANNED	12/17/2021	5	285	57
PLANNED	12/17/2021	8	776	97
PLANNED	12/17/2021	1	3	3
PLANNED	12/17/2021	3	510	170
PLANNED	12/17/2021	8	896	112
PLANNED	12/17/2021	8	1,314	282
PLANNED	12/17/2021	8	328	41
PLANNED	12/17/2021	2	292	146
PLANNED	12/17/2021	2	10	5
PLANNED	12/17/2021	11	1,012	92
PLANNED	12/17/2021	11	737	67
PLANNED	12/17/2021	1	29	29
PLANNED	12/17/2021	2	140	70
PLANNED	12/17/2021	10	120	12
PLANNED	12/17/2021	1	41	41
PLANNED	12/17/2021	7	49	7
PLANNED	12/17/2021	2	416	208
PLANNED	12/17/2021	3	243	81
PLANNED	12/17/2021	1	23	23
PLANNED	12/17/2021	12	192	16
PLANNED	12/17/2021	6	54	9
PLANNED	12/17/2021	1	195	195
PLANNED	12/17/2021	1	30	30
CUSTOMER REQUEST	12/17/2021	3	21	7
PLANNED	12/17/2021	6	36	6
CUSTOMER REQUEST	12/17/2021	1	294	294
PLANNED	12/17/2021	1	487	487
PLANNED	12/17/2021	31	62	2
PLANNED	12/17/2021	7	84	12
PLANNED	12/17/2021	10	1,900	190
PLANNED	12/17/2021	6	786	131
PLANNED	12/17/2021	2	30	15
PLANNED	12/17/2021	5	585	117
PLANNED	12/17/2021	4	120	30
PLANNED	12/17/2021	25	6,825	273
PLANNED	12/17/2021	35	8,470	242

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/17/2021	1	6	6
PLANNED	12/17/2021	3	42	14
PLANNED	12/17/2021	3	93	31
PLANNED	12/17/2021	12	1,068	89
PLANNED	12/17/2021	4	1,184	296
PLANNED	12/17/2021	46	4,048	88
PLANNED	12/17/2021	30	180	6
PLANNED	12/17/2021	8	40	5
PLANNED	12/17/2021	4	48	12
PLANNED	12/17/2021	4	448	112
CUSTOMER REQUEST	12/17/2021	2	916	458
PLANNED	12/17/2021	2	12	6
PLANNED	12/17/2021	4	92	23
PLANNED	12/17/2021	3	372	124
PLANNED	12/17/2021	6	36	6
PLANNED	12/17/2021	1	24	24
PLANNED	12/17/2021	5	392	136
PLANNED	12/17/2021	4	340	85
PLANNED	12/17/2021	4	768	192
PLANNED	12/17/2021	8	568	71
PLANNED	12/17/2021	3	51	17
PLANNED	12/17/2021	1	75	75
PLANNED	12/17/2021	1	59	59
PLANNED	12/17/2021	2	106	53
PLANNED	12/17/2021	2	36	18
PLANNED	12/17/2021	4	428	107
CUSTOMER REQUEST	12/17/2021	4	92	23
PLANNED	12/17/2021	3	306	102
PLANNED	12/17/2021	2	272	136
PLANNED	12/17/2021	4	20	5
CUSTOMER REQUEST	12/17/2021	1	53	53
PLANNED	12/17/2021	28	4,762	273
PLANNED	12/17/2021	1	106	106
PLANNED	12/17/2021	1	18	18
PLANNED	12/17/2021	1	5	5
CUSTOMER REQUEST	12/17/2021	1	274	274
PLANNED	12/17/2021	19	1,406	74
PLANNED	12/17/2021	2	10	5
PLANNED	12/17/2021	5	50	10
PLANNED	12/17/2021	5	45	9
PLANNED	12/17/2021	2	148	74

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/17/2021	1	107	107
PLANNED	12/17/2021	16	1,424	89
PLANNED	12/17/2021	2	118	59
PLANNED	12/17/2021	7	357	51
PLANNED	12/17/2021	4	12	3
PLANNED	12/17/2021	1	5	5
PLANNED	12/17/2021	23	1,150	50
PLANNED	12/17/2021	31	2,232	72
PLANNED	12/17/2021	6	228	38
CUSTOMER REQUEST	12/17/2021	27	756	28
PLANNED	12/17/2021	5	255	51
PLANNED	12/17/2021	1	36	36
PLANNED	12/17/2021	4	64	16
PLANNED	12/17/2021	2	62	31
PLANNED	12/17/2021	3	30	10
PLANNED	12/17/2021	3	21	7
PLANNED	12/17/2021	3	345	115
PLANNED	12/17/2021	2	14	7
PLANNED	12/17/2021	3	12	4
PLANNED	12/17/2021	4	256	64
PLANNED	12/17/2021	2	14	7
PLANNED	12/17/2021	3	36	12
PLANNED	12/17/2021	8	32	4
PLANNED	12/17/2021	4	320	80
PLANNED	12/17/2021	4	436	109
PLANNED	12/17/2021	4	224	56
PLANNED	12/17/2021	3	78	26
PLANNED	12/17/2021	16	576	36
CUSTOMER REQUEST	12/17/2021	3,165	106,532	40
PLANNED	12/17/2021	13	403	31
CUSTOMER REQUEST	12/17/2021	1	127	127
CUSTOMER REQUEST	12/17/2021	1	189	189
PLANNED	12/17/2021	2	138	69
CUSTOMER REQUEST	12/17/2021	1	96	96
CUSTOMER REQUEST	12/17/2021	1	76	76
PLANNED	12/17/2021	13	2,080	160
PLANNED	12/17/2021	1	100	100
PLANNED	12/17/2021	1	341	341
PLANNED	12/17/2021	1	148	148
PLANNED	12/17/2021	1	204	204
PLANNED	12/18/2021	1	170	170

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/18/2021	2	172	86
PLANNED	12/18/2021	1	65	65
CUSTOMER REQUEST	12/18/2021	1	403	403
PLANNED	12/18/2021	1	234	234
PLANNED	12/18/2021	14	8,092	578
PLANNED	12/18/2021	4	328	82
PLANNED	12/18/2021	6	648	108
CUSTOMER REQUEST	12/18/2021	1	184	184
PLANNED	12/18/2021	6	510	85
PLANNED	12/18/2021	1	212	212
PLANNED	12/18/2021	15	315	21
CUSTOMER REQUEST	12/18/2021	1	67	67
PLANNED	12/18/2021	1	334	334
PLANNED	12/18/2021	15	90	6
PLANNED	12/18/2021	1	338	338
PLANNED	12/18/2021	1	108	108
PLANNED	12/18/2021	4	76	19
PLANNED	12/18/2021	1	192	192
PLANNED	12/18/2021	2	90	45
PLANNED	12/18/2021	1	204	204
CUSTOMER REQUEST	12/18/2021	1	105	105
PLANNED	12/18/2021	4	100	25
PLANNED	12/18/2021	1	195	195
PLANNED	12/18/2021	17	2,176	128
PLANNED	12/18/2021	1	106	106
PLANNED	12/18/2021	1	193	193
PLANNED	12/18/2021	2	142	71
PLANNED	12/18/2021	10	1,370	137
PLANNED	12/18/2021	1	89	89
PLANNED	12/18/2021	1	48	48
PLANNED	12/18/2021	2	262	131
PLANNED	12/19/2021	1	199	199
PLANNED	12/19/2021	2	242	121
PLANNED	12/19/2021	2	906	453
PLANNED	12/19/2021	2	864	432
PLANNED	12/19/2021	9	3,393	377
PLANNED	12/19/2021	2	477	256
PLANNED	12/19/2021	8	3,016	377
PLANNED	12/19/2021	5	970	194
PLANNED	12/19/2021	1	87	87
PLANNED	12/19/2021	1	264	264

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/19/2021	3	450	150
PLANNED	12/19/2021	4	232	58
CUSTOMER REQUEST	12/19/2021	478	6,340	75
PLANNED	12/19/2021	7	833	119
PLANNED	12/19/2021	10	520	52
PLANNED	12/20/2021	8	656	82
PLANNED	12/20/2021	1	128	128
PLANNED	12/20/2021	8	152	19
PLANNED	12/20/2021	10	110	11
PLANNED	12/20/2021	3	21	7
PLANNED	12/20/2021	6	54	9
PLANNED	12/20/2021	2	16	8
PLANNED	12/20/2021	3	18	6
PLANNED	12/20/2021	2	44	22
PLANNED	12/20/2021	3	294	98
PLANNED	12/20/2021	5	875	175
PLANNED	12/20/2021	2	10	5
PLANNED	12/20/2021	13	13	1
PLANNED	12/20/2021	15	405	27
PLANNED	12/20/2021	7	56	8
PLANNED	12/20/2021	3	63	21
PLANNED	12/20/2021	11	1,694	154
PLANNED	12/20/2021	9	171	19
PLANNED	12/20/2021	2	166	83
PLANNED	12/20/2021	1	4	4
PLANNED	12/20/2021	1	32	32
PLANNED	12/20/2021	11	110	10
PLANNED	12/20/2021	7	455	65
PLANNED	12/20/2021	3	270	90
PLANNED	12/20/2021	2	28	14
PLANNED	12/20/2021	8	120	15
PLANNED	12/20/2021	2	58	29
PLANNED	12/20/2021	1	140	140
PLANNED	12/20/2021	5	440	88
PLANNED	12/20/2021	2	224	112
PLANNED	12/20/2021	3	15	5
PLANNED	12/20/2021	1	5	5
PLANNED	12/20/2021	2	22	11
PLANNED	12/20/2021	1	59	59
PLANNED	12/20/2021	8	1,456	182
PLANNED	12/20/2021	2	114	57

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/20/2021	13	767	59
PLANNED	12/20/2021	3	426	142
PLANNED	12/20/2021	4	204	51
PLANNED	12/20/2021	14	252	18
PLANNED	12/20/2021	1	9	9
PLANNED	12/20/2021	4	720	180
PLANNED	12/20/2021	7	217	31
PLANNED	12/20/2021	1	9	9
PLANNED	12/20/2021	1	153	153
PLANNED	12/20/2021	4	24	6
PLANNED	12/20/2021	4	784	196
PLANNED	12/20/2021	5	310	62
PLANNED	12/20/2021	3	54	18
PLANNED	12/20/2021	7	63	9
PLANNED	12/20/2021	8	64	8
PLANNED	12/20/2021	3	24	8
PLANNED	12/20/2021	1	95	95
PLANNED	12/20/2021	1	141	141
PLANNED	12/20/2021	4	572	143
PLANNED	12/20/2021	12	1,188	99
PLANNED	12/20/2021	4	316	79
PLANNED	12/20/2021	1	66	66
PLANNED	12/20/2021	20	2,540	127
PLANNED	12/20/2021	1	6	6
PLANNED	12/20/2021	2	54	27
PLANNED	12/20/2021	2	26	13
PLANNED	12/20/2021	2	222	111
PLANNED	12/20/2021	31	3,937	127
PLANNED	12/20/2021	1	7	7
PLANNED	12/20/2021	40	3,600	90
PLANNED	12/20/2021	3	18	6
PLANNED	12/20/2021	3	129	43
PLANNED	12/20/2021	26	3,172	122
PLANNED	12/20/2021	5	255	51
PLANNED	12/20/2021	6	246	41
PLANNED	12/20/2021	6	570	95
PLANNED	12/20/2021	8	584	73
PLANNED	12/20/2021	2	56	28
PLANNED	12/20/2021	3	42	14
PLANNED	12/20/2021	23	805	35
PLANNED	12/20/2021	4	60	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/20/2021	5	45	9
PLANNED	12/20/2021	3	9	3
PLANNED	12/20/2021	4	300	75
PLANNED	12/20/2021	10	80	8
PLANNED	12/20/2021	2	110	55
PLANNED	12/20/2021	3	513	171
PLANNED	12/20/2021	11	187	17
PLANNED	12/20/2021	4	164	41
PLANNED	12/20/2021	2	18	9
PLANNED	12/20/2021	3	21	7
PLANNED	12/20/2021	7	791	113
CUSTOMER REQUEST	12/20/2021	36	2,628	73
PLANNED	12/20/2021	1	77	77
PLANNED	12/20/2021	8	536	67
PLANNED	12/20/2021	8	536	67
PLANNED	12/20/2021	14	126	9
PLANNED	12/20/2021	1	7	7
PLANNED	12/20/2021	8	536	67
PLANNED	12/20/2021	4	348	87
PLANNED	12/20/2021	1	48	48
PLANNED	12/20/2021	24	384	16
PLANNED	12/20/2021	8	536	67
PLANNED	12/20/2021	8	64	8
CUSTOMER REQUEST	12/20/2021	1	59	59
PLANNED	12/20/2021	7	182	26
PLANNED	12/20/2021	4	56	14
PLANNED	12/20/2021	11	143	13
PLANNED	12/20/2021	3	51	17
PLANNED	12/20/2021	11	264	24
PLANNED	12/20/2021	7	630	90
PLANNED	12/20/2021	20	2,940	147
PLANNED	12/20/2021	10	140	14
PLANNED	12/20/2021	1	43	43
PLANNED	12/20/2021	2	14	7
PLANNED	12/20/2021	1	9	9
PLANNED	12/20/2021	1	11	11
PLANNED	12/20/2021	2	32	16
PLANNED	12/20/2021	3	30	10
PLANNED	12/20/2021	8	88	11
PLANNED	12/20/2021	2	126	63
PLANNED	12/20/2021	9	135	15

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/20/2021	3	33	11
PLANNED	12/20/2021	1	18	18
PLANNED	12/20/2021	3	45	15
PLANNED	12/20/2021	1	35	35
PLANNED	12/20/2021	3	54	18
PLANNED	12/20/2021	1	12	12
PLANNED	12/20/2021	10	470	47
PLANNED	12/20/2021	4	32	8
PLANNED	12/20/2021	3	33	11
PLANNED	12/20/2021	5	45	9
PLANNED	12/20/2021	5	620	124
PLANNED	12/20/2021	6	714	119
PLANNED	12/20/2021	6	48	8
PLANNED	12/20/2021	8	312	39
CUSTOMER REQUEST	12/20/2021	1	273	273
PLANNED	12/20/2021	6	480	80
PLANNED	12/20/2021	6	42	7
PLANNED	12/20/2021	1	30	30
PLANNED	12/20/2021	1	5	5
PLANNED	12/20/2021	1	5	5
PLANNED	12/20/2021	3	87	29
PLANNED	12/20/2021	3	258	86
PLANNED	12/20/2021	6	774	129
PLANNED	12/20/2021	7	651	93
PLANNED	12/20/2021	6	618	103
PLANNED	12/20/2021	2	54	27
PLANNED	12/20/2021	2	16	8
PLANNED	12/20/2021	9	1,710	190
PLANNED	12/20/2021	5	45	9
PLANNED	12/20/2021	7	77	11
PLANNED	12/20/2021	10	180	18
PLANNED	12/20/2021	9	2,520	280
PLANNED	12/20/2021	5	210	42
PLANNED	12/20/2021	3	27	9
PLANNED	12/20/2021	11	297	27
PLANNED	12/20/2021	5	295	59
PLANNED	12/20/2021	3	36	12
PLANNED	12/20/2021	2	28	14
PLANNED	12/20/2021	10	70	7
PLANNED	12/20/2021	7	1,372	196
PLANNED	12/20/2021	6	42	7

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/20/2021	10	530	53
PLANNED	12/20/2021	9	189	21
PLANNED	12/20/2021	5	15	3
PLANNED	12/20/2021	2	14	7
PLANNED	12/20/2021	4	28	7
PLANNED	12/20/2021	1	206	206
PLANNED	12/20/2021	3	24	8
PLANNED	12/20/2021	2	18	9
PLANNED	12/20/2021	9	135	15
PLANNED	12/20/2021	4	28	7
PLANNED	12/20/2021	4	32	8
PLANNED	12/20/2021	10	70	7
PLANNED	12/20/2021	2	248	124
PLANNED	12/20/2021	1	9	9
PLANNED	12/20/2021	1	73	73
PLANNED	12/20/2021	3	72	24
PLANNED	12/20/2021	2	70	35
PLANNED	12/20/2021	11	77	7
PLANNED	12/20/2021	5	245	49
PLANNED	12/20/2021	10	110	11
PLANNED	12/20/2021	2	14	7
PLANNED	12/20/2021	13	117	9
PLANNED	12/20/2021	5	100	20
PLANNED	12/20/2021	5	180	36
PLANNED	12/20/2021	3	24	8
PLANNED	12/20/2021	8	80	10
PLANNED	12/20/2021	1	115	115
PLANNED	12/20/2021	3	24	8
PLANNED	12/20/2021	1	78	78
PLANNED	12/20/2021	8	144	18
PLANNED	12/20/2021	6	60	10
PLANNED	12/20/2021	3	30	10
PLANNED	12/20/2021	3	225	75
PLANNED	12/20/2021	8	88	11
PLANNED	12/20/2021	11	341	31
PLANNED	12/20/2021	9	144	16
PLANNED	12/20/2021	12	264	22
PLANNED	12/20/2021	10	650	65
PLANNED	12/20/2021	1	51	51
PLANNED	12/20/2021	2	10	5
PLANNED	12/20/2021	5	50	10

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/20/2021	11	165	15
PLANNED	12/20/2021	5	55	11
PLANNED	12/20/2021	11	110	10
PLANNED	12/20/2021	3	33	11
PLANNED	12/20/2021	14	1,764	126
PLANNED	12/20/2021	6	1,044	174
PLANNED	12/20/2021	1	20	20
PLANNED	12/20/2021	6	90	15
PLANNED	12/20/2021	4	40	10
PLANNED	12/20/2021	4	76	19
PLANNED	12/20/2021	7	532	76
PLANNED	12/20/2021	1	79	79
CUSTOMER REQUEST	12/20/2021	1	76	76
PLANNED	12/20/2021	10	350	35
PLANNED	12/20/2021	7	49	7
PLANNED	12/20/2021	4	64	16
PLANNED	12/20/2021	5	50	10
PLANNED	12/20/2021	1	13	13
PLANNED	12/20/2021	10	490	49
PLANNED	12/20/2021	12	132	11
PLANNED	12/20/2021	6	66	11
PLANNED	12/20/2021	6	408	68
PLANNED	12/20/2021	7	1,253	179
PLANNED	12/20/2021	1	67	67
PLANNED	12/20/2021	5	595	119
PLANNED	12/22/2021	1	111	111
PLANNED	12/22/2021	13	910	70
PLANNED	12/22/2021	1	8	8
PLANNED	12/22/2021	1	35	35
PLANNED	12/22/2021	1	105	105
PLANNED	12/22/2021	1	52	52
PLANNED	12/22/2021	1	43	43
PLANNED	12/22/2021	5	1,530	306
PLANNED	12/22/2021	4	316	79
PLANNED	12/22/2021	43	1,892	44
PLANNED	12/22/2021	12	132	11
PLANNED	12/22/2021	9	234	26
CUSTOMER REQUEST	12/22/2021	60	5,340	89
PLANNED	12/22/2021	55	3,905	71
PLANNED	12/22/2021	4	36	9
PLANNED	12/22/2021	6	540	90

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/22/2021	3	42	14
PLANNED	12/22/2021	9	405	45
CUSTOMER REQUEST	12/22/2021	44	2,156	49
PLANNED	12/22/2021	20	1,860	93
PLANNED	12/22/2021	3	24	8
PLANNED	12/22/2021	1	75	75
PLANNED	12/22/2021	13	156	12
PLANNED	12/22/2021	6	462	77
PLANNED	12/22/2021	9	27	3
PLANNED	12/22/2021	9	108	12
PLANNED	12/22/2021	1	98	98
PLANNED	12/22/2021	4	198	87
PLANNED	12/22/2021	2	58	29
PLANNED	12/22/2021	4	84	21
PLANNED	12/22/2021	3	246	82
PLANNED	12/22/2021	2	30	15
PLANNED	12/22/2021	6	36	6
PLANNED	12/22/2021	1	244	244
PLANNED	12/22/2021	6	1,194	199
PLANNED	12/22/2021	9	1,566	174
PLANNED	12/22/2021	6	1,038	173
PLANNED	12/22/2021	10	1,740	174
PLANNED	12/22/2021	2	588	294
PLANNED	12/22/2021	10	820	82
PLANNED	12/22/2021	8	1,536	192
PLANNED	12/22/2021	6	1,092	182
PLANNED	12/22/2021	7	1,211	173
PLANNED	12/22/2021	11	110	10
CUSTOMER REQUEST	12/22/2021	1	34	34
PLANNED	12/22/2021	2	62	31
PLANNED	12/22/2021	5	185	37
PLANNED	12/22/2021	8	200	25
PLANNED	12/22/2021	4	568	142
CUSTOMER REQUEST	12/22/2021	4	64	16
PLANNED	12/22/2021	3	39	13
PLANNED	12/22/2021	1	6	6
PLANNED	12/22/2021	2	12	6
PLANNED	12/22/2021	12	168	14
PLANNED	12/22/2021	13	143	11
PLANNED	12/22/2021	1	113	113
PLANNED	12/22/2021	2	12	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/22/2021	3	27	9
PLANNED	12/22/2021	8	120	15
PLANNED	12/22/2021	11	583	53
PLANNED	12/22/2021	11	1,122	102
PLANNED	12/22/2021	10	140	14
PLANNED	12/22/2021	4	220	55
PLANNED	12/22/2021	3	120	40
PLANNED	12/22/2021	8	80	10
PLANNED	12/22/2021	2	30	15
PLANNED	12/22/2021	2	18	9
PLANNED	12/22/2021	10	370	37
PLANNED	12/22/2021	1	49	49
PLANNED	12/22/2021	2	30	15
PLANNED	12/22/2021	3	30	10
PLANNED	12/22/2021	3	240	80
PLANNED	12/22/2021	9	63	7
PLANNED	12/22/2021	2	28	14
PLANNED	12/22/2021	2	16	8
PLANNED	12/22/2021	26	1,638	63
PLANNED	12/22/2021	2	30	15
CUSTOMER REQUEST	12/22/2021	3	219	73
PLANNED	12/22/2021	4	56	14
PLANNED	12/22/2021	7	105	15
PLANNED	12/22/2021	9	117	13
PLANNED	12/22/2021	1	99	99
PLANNED	12/22/2021	6	126	21
PLANNED	12/22/2021	2	18	9
PLANNED	12/22/2021	2	10	5
PLANNED	12/22/2021	2	14	7
PLANNED	12/22/2021	6	48	8
PLANNED	12/22/2021	23	2,990	130
PLANNED	12/22/2021	11	781	71
PLANNED	12/22/2021	1	15	15
PLANNED	12/22/2021	1	11	11
PLANNED	12/22/2021	11	99	9
PLANNED	12/22/2021	7	301	43
PLANNED	12/22/2021	3	51	17
PLANNED	12/22/2021	6	96	16
PLANNED	12/22/2021	1	29	29
PLANNED	12/22/2021	1	11	11
PLANNED	12/22/2021	1	24	24

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/22/2021	2	16	8
PLANNED	12/22/2021	13	169	13
PLANNED	12/22/2021	1	8	8
PLANNED	12/22/2021	1	1	1
PLANNED	12/22/2021	2	4	2
PLANNED	12/22/2021	4	216	54
PLANNED	12/22/2021	10	120	12
PLANNED	12/22/2021	10	140	14
PLANNED	12/22/2021	4	52	13
PLANNED	12/22/2021	7	77	11
PLANNED	12/22/2021	44	1,980	45
CUSTOMER REQUEST	12/22/2021	1	113	113
PLANNED	12/22/2021	3	18	6
PLANNED	12/22/2021	2	18	9
PLANNED	12/22/2021	1	37	37
PLANNED	12/22/2021	2	12	6
PLANNED	12/22/2021	1	9	9
PLANNED	12/22/2021	11	99	9
PLANNED	12/22/2021	2	14	7
PLANNED	12/22/2021	2	32	16
PLANNED	12/22/2021	1	24	24
PLANNED	12/22/2021	5	510	102
PLANNED	12/22/2021	1	135	135
PLANNED	12/22/2021	1	194	194
PLANNED	12/22/2021	19	5,662	298
PLANNED	12/22/2021	3	687	229
PLANNED	12/23/2021	1	76	76
PLANNED	12/23/2021	4	480	120
PLANNED	12/23/2021	1	79	79
PLANNED	12/23/2021	5	335	67
PLANNED	12/23/2021	5	345	69
PLANNED	12/23/2021	2	156	78
PLANNED	12/23/2021	2	50	25
PLANNED	12/23/2021	1	297	297
PLANNED	12/23/2021	12	384	32
CUSTOMER REQUEST	12/23/2021	1	99	99
PLANNED	12/23/2021	2	66	42
PLANNED	12/23/2021	1	206	206
PLANNED	12/23/2021	5	338	85
PLANNED	12/23/2021	8	1,088	136
PLANNED	12/23/2021	2	60	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/23/2021	8	1,512	189
PLANNED	12/23/2021	4	60	15
PLANNED	12/23/2021	2	104	52
PLANNED	12/23/2021	5	150	30
PLANNED	12/23/2021	4	76	19
PLANNED	12/23/2021	1	19	19
PLANNED	12/23/2021	1	66	66
CUSTOMER REQUEST	12/23/2021	1	114	114
CUSTOMER REQUEST	12/23/2021	1	175	175
PLANNED	12/23/2021	2	122	65
PLANNED	12/23/2021	7	749	107
PLANNED	12/23/2021	8	72	9
PLANNED	12/23/2021	2	140	70
PLANNED	12/23/2021	1	106	106
PLANNED	12/23/2021	1	39	39
PLANNED	12/24/2021	8	96	12
CUSTOMER REQUEST	12/24/2021	1	164	164
PLANNED	12/26/2021	1	122	122
CUSTOMER REQUEST	12/26/2021	1	40	40
CUSTOMER REQUEST	12/27/2021	2,556	22,230	24
PLANNED	12/27/2021	5	470	94
PLANNED	12/27/2021	2	283	172
PLANNED	12/27/2021	5	265	84
PLANNED	12/27/2021	2	250	125
PLANNED	12/27/2021	1	359	359
PLANNED	12/27/2021	2	74	37
PLANNED	12/27/2021	7	49	7
PLANNED	12/27/2021	6	546	91
PLANNED	12/27/2021	1	246	246
PLANNED	12/27/2021	4	776	194
PLANNED	12/27/2021	18	684	38
PLANNED	12/27/2021	5	15	3
PLANNED	12/27/2021	8	1,728	216
PLANNED	12/27/2021	13	91	7
PLANNED	12/27/2021	5	50	10
PLANNED	12/27/2021	20	1,100	55
PLANNED	12/27/2021	1	127	127
PLANNED	12/27/2021	1	6	6
PLANNED	12/27/2021	4	236	59
PLANNED	12/27/2021	14	252	18
PLANNED	12/27/2021	61	3,416	56

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/27/2021	6	300	50
PLANNED	12/27/2021	15	3,570	238
PLANNED	12/27/2021	6	444	74
PLANNED	12/27/2021	12	144	12
PLANNED	12/27/2021	1	7	7
CUSTOMER REQUEST	12/27/2021	1	105	105
PLANNED	12/27/2021	1	117	117
PLANNED	12/27/2021	4	380	95
PLANNED	12/27/2021	10	1,140	114
PLANNED	12/27/2021	3	21	7
PLANNED	12/27/2021	3	558	186
PLANNED	12/27/2021	5	30	6
PLANNED	12/27/2021	4	40	10
PLANNED	12/27/2021	2	68	34
PLANNED	12/27/2021	9	90	10
PLANNED	12/27/2021	4	16	4
PLANNED	12/27/2021	6	66	11
PLANNED	12/27/2021	1	95	95
PLANNED	12/27/2021	1	37	37
PLANNED	12/27/2021	9	234	26
PLANNED	12/27/2021	1	67	67
PLANNED	12/27/2021	4	12	3
PLANNED	12/27/2021	11	308	28
PLANNED	12/27/2021	3	150	50
PLANNED	12/27/2021	6	102	17
CUSTOMER REQUEST	12/27/2021	1	20	20
PLANNED	12/27/2021	1	51	51
PLANNED	12/27/2021	10	110	11
PLANNED	12/27/2021	1	61	61
PLANNED	12/27/2021	4	1,438	361
PLANNED	12/27/2021	8	136	17
PLANNED	12/27/2021	2	221	132
PLANNED	12/27/2021	3	450	150
PLANNED	12/27/2021	15	90	6
PLANNED	12/27/2021	1	71	71
PLANNED	12/27/2021	1	8	8
PLANNED	12/27/2021	1	118	118
PLANNED	12/27/2021	10	70	7
PLANNED	12/27/2021	12	588	49
PLANNED	12/27/2021	10	1,690	193
CUSTOMER REQUEST	12/27/2021	1	115	115

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/27/2021	2	132	66
CUSTOMER REQUEST	12/27/2021	1	10	10
PLANNED	12/27/2021	3	30	10
PLANNED	12/27/2021	2	40	20
PLANNED	12/27/2021	7	189	27
PLANNED	12/27/2021	6	210	35
PLANNED	12/27/2021	12	120	10
PLANNED	12/27/2021	10	70	7
PLANNED	12/27/2021	6	84	14
PLANNED	12/27/2021	3	93	31
CUSTOMER REQUEST	12/27/2021	37	777	21
PLANNED	12/27/2021	9	153	17
PLANNED	12/27/2021	3	30	10
PLANNED	12/27/2021	8	48	6
PLANNED	12/27/2021	10	170	17
PLANNED	12/27/2021	9	81	9
PLANNED	12/27/2021	9	108	12
PLANNED	12/27/2021	4	36	9
PLANNED	12/27/2021	1	39	39
PLANNED	12/27/2021	1	56	56
PLANNED	12/27/2021	1	83	83
PLANNED	12/27/2021	1	70	70
PLANNED	12/27/2021	1	248	248
PLANNED	12/28/2021	2	220	110
PLANNED	12/28/2021	2	292	146
PLANNED	12/28/2021	5	550	110
PLANNED	12/28/2021	3	108	36
PLANNED	12/28/2021	10	610	61
PLANNED	12/28/2021	1	6	6
PLANNED	12/28/2021	1	245	245
PLANNED	12/28/2021	7	217	31
PLANNED	12/28/2021	5	545	109
PLANNED	12/28/2021	6	558	93
PLANNED	12/28/2021	5	35	7
PLANNED	12/28/2021	8	216	27
PLANNED	12/28/2021	8	288	36
PLANNED	12/28/2021	8	280	35
PLANNED	12/28/2021	3	249	83
PLANNED	12/28/2021	10	60	6
PLANNED	12/28/2021	5	240	48
PLANNED	12/28/2021	11	792	72

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/28/2021	1	8	8
PLANNED	12/28/2021	5	450	90
PLANNED	12/28/2021	13	247	19
PLANNED	12/28/2021	1	5	5
PLANNED	12/28/2021	5	160	32
PLANNED	12/28/2021	1	94	94
PLANNED	12/28/2021	3	303	101
PLANNED	12/28/2021	1	70	70
PLANNED	12/28/2021	10	70	7
PLANNED	12/28/2021	1	40	40
PLANNED	12/28/2021	58	4,872	84
PLANNED	12/28/2021	5	40	8
PLANNED	12/28/2021	1	4	4
PLANNED	12/28/2021	1	74	74
CUSTOMER REQUEST	12/28/2021	1	192	192
PLANNED	12/28/2021	2	14	7
PLANNED	12/28/2021	1	172	172
PLANNED	12/28/2021	8	504	63
PLANNED	12/28/2021	12	72	6
PLANNED	12/28/2021	2	10	5
PLANNED	12/28/2021	1	100	100
PLANNED	12/28/2021	8	72	9
PLANNED	12/28/2021	2	16	8
CUSTOMER REQUEST	12/28/2021	5	20	4
PLANNED	12/28/2021	2	130	65
PLANNED	12/28/2021	3	3	1
PLANNED	12/28/2021	8	56	7
PLANNED	12/28/2021	1	8	8
PLANNED	12/28/2021	2	276	138
PLANNED	12/28/2021	1	5	5
PLANNED	12/28/2021	2	4	2
PLANNED	12/28/2021	2	12	6
PLANNED	12/28/2021	2	348	174
PLANNED	12/28/2021	1	7	7
PLANNED	12/28/2021	10	1,002	131
PLANNED	12/28/2021	4	316	79
PLANNED	12/28/2021	6	828	138
PLANNED	12/28/2021	4	20	5
PLANNED	12/28/2021	3	24	8
PLANNED	12/28/2021	7	301	43
PLANNED	12/28/2021	4	192	48

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/28/2021	2	104	52
PLANNED	12/28/2021	16	4,256	266
PLANNED	12/28/2021	2	12	6
PLANNED	12/28/2021	6	156	26
PLANNED	12/28/2021	1	50	50
PLANNED	12/28/2021	5	30	6
PLANNED	12/28/2021	5	35	7
PLANNED	12/28/2021	6	390	65
PLANNED	12/28/2021	7	462	66
PLANNED	12/28/2021	4	388	97
PLANNED	12/28/2021	2	24	12
PLANNED	12/28/2021	2	14	7
PLANNED	12/28/2021	11	286	26
PLANNED	12/28/2021	2	186	93
PLANNED	12/28/2021	3	21	7
PLANNED	12/28/2021	4	508	127
PLANNED	12/28/2021	2	430	215
PLANNED	12/28/2021	1	224	224
PLANNED	12/28/2021	4	936	234
PLANNED	12/28/2021	3	126	42
PLANNED	12/28/2021	2	16	8
PLANNED	12/28/2021	1	13	13
PLANNED	12/28/2021	2	36	18
PLANNED	12/28/2021	12	96	8
PLANNED	12/28/2021	4	196	49
PLANNED	12/28/2021	1	10	10
PLANNED	12/28/2021	7	231	33
PLANNED	12/28/2021	9	90	10
PLANNED	12/28/2021	1	10	10
PLANNED	12/28/2021	1	193	193
PLANNED	12/28/2021	1	13	13
CUSTOMER REQUEST	12/28/2021	8	216	27
PLANNED	12/28/2021	7	49	7
PLANNED	12/28/2021	3	540	180
PLANNED	12/28/2021	1	7	7
PLANNED	12/28/2021	10	1,260	126
PLANNED	12/28/2021	8	352	44
PLANNED	12/28/2021	9	117	13
CUSTOMER REQUEST	12/28/2021	1	84	84
PLANNED	12/28/2021	3	36	12
PLANNED	12/28/2021	8	240	30

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/28/2021	9	1,170	130
PLANNED	12/28/2021	17	1,598	94
PLANNED	12/28/2021	6	12	2
PLANNED	12/28/2021	1	141	141
PLANNED	12/28/2021	1	4	4
PLANNED	12/28/2021	3	15	5
PLANNED	12/28/2021	2	8	4
PLANNED	12/28/2021	2	8	4
PLANNED	12/28/2021	3	133	52
PLANNED	12/28/2021	6	228	38
PLANNED	12/28/2021	1	68	68
PLANNED	12/28/2021	2	12	6
PLANNED	12/28/2021	2	10	5
PLANNED	12/28/2021	1	9	9
CUSTOMER REQUEST	12/28/2021	1	51	51
CUSTOMER REQUEST	12/28/2021	1	36	36
PLANNED	12/28/2021	6	144	24
PLANNED	12/28/2021	1	331	331
CUSTOMER REQUEST	12/28/2021	1	134	134
PLANNED	12/29/2021	4	380	95
PLANNED	12/29/2021	6	840	140
PLANNED	12/29/2021	1	171	171
PLANNED	12/29/2021	6	180	30
PLANNED	12/29/2021	6	654	109
PLANNED	12/29/2021	2	168	84
PLANNED	12/29/2021	2	442	221
PLANNED	12/29/2021	1	127	127
PLANNED	12/29/2021	1	86	86
PLANNED	12/29/2021	2	28	14
PLANNED	12/29/2021	4	56	14
PLANNED	12/29/2021	19	475	25
PLANNED	12/29/2021	10	220	22
PLANNED	12/29/2021	1	33	33
PLANNED	12/29/2021	1	77	77
PLANNED	12/29/2021	3	24	8
PLANNED	12/29/2021	4	160	40
PLANNED	12/29/2021	4	164	41
PLANNED	12/29/2021	2	4	2
PLANNED	12/29/2021	21	2,667	127
PLANNED	12/29/2021	8	784	98
PLANNED	12/29/2021	3	18	6

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/29/2021	5	325	65
PLANNED	12/29/2021	3	30	10
PLANNED	12/29/2021	7	567	81
PLANNED	12/29/2021	8	3,056	382
PLANNED	12/29/2021	11	396	36
PLANNED	12/29/2021	10	1,130	113
CUSTOMER REQUEST	12/29/2021	4	48	12
CUSTOMER REQUEST	12/29/2021	6	18	3
PLANNED	12/29/2021	2	24	12
PLANNED	12/29/2021	1	167	167
PLANNED	12/29/2021	5	160	32
PLANNED	12/29/2021	2	136	68
PLANNED	12/29/2021	2	58	29
PLANNED	12/29/2021	1	13	13
PLANNED	12/29/2021	1	18	18
PLANNED	12/29/2021	2	514	257
PLANNED	12/29/2021	8	112	14
PLANNED	12/29/2021	1	10	10
PLANNED	12/29/2021	1	121	121
PLANNED	12/29/2021	9	405	45
PLANNED	12/29/2021	3	21	7
PLANNED	12/29/2021	3	27	9
PLANNED	12/29/2021	2	14	7
PLANNED	12/29/2021	1	46	46
PLANNED	12/29/2021	1	7	7
PLANNED	12/29/2021	3	45	15
PLANNED	12/29/2021	14	686	49
PLANNED	12/29/2021	2	136	68
PLANNED	12/29/2021	2	16	8
CUSTOMER REQUEST	12/29/2021	3	90	30
PLANNED	12/29/2021	1	170	170
PLANNED	12/29/2021	3	650	223
CUSTOMER REQUEST	12/29/2021	2	332	166
PLANNED	12/29/2021	2	50	25
PLANNED	12/29/2021	1	6	6
PLANNED	12/29/2021	2	96	48
PLANNED	12/29/2021	2	84	42
PLANNED	12/29/2021	13	2,288	176
PLANNED	12/29/2021	1	74	74
PLANNED	12/29/2021	81	2,916	36
PLANNED	12/29/2021	5	620	124

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/29/2021	8	512	64
PLANNED	12/29/2021	4	172	43
PLANNED	12/29/2021	7	245	35
PLANNED	12/29/2021	2	268	134
PLANNED	12/29/2021	2	70	35
PLANNED	12/29/2021	3	462	154
PLANNED	12/29/2021	1	430	430
PLANNED	12/29/2021	9	234	26
PLANNED	12/30/2021	1	102	102
PLANNED	12/30/2021	1	261	261
PLANNED	12/30/2021	15	525	35
PLANNED	12/30/2021	54	6,372	118
PLANNED	12/30/2021	1	70	70
PLANNED	12/30/2021	4	128	32
PLANNED	12/30/2021	3	426	142
PLANNED	12/30/2021	5	195	39
PLANNED	12/30/2021	4	588	147
PLANNED	12/30/2021	10	690	69
CUSTOMER REQUEST	12/30/2021	8	96	12
CUSTOMER REQUEST	12/30/2021	3	168	56
PLANNED	12/30/2021	1	39	39
PLANNED	12/30/2021	1	100	100
PLANNED	12/30/2021	1	8	8
PLANNED	12/30/2021	1	95	95
PLANNED	12/30/2021	12	1,200	100
PLANNED	12/30/2021	9	801	89
PLANNED	12/30/2021	4	480	120
PLANNED	12/30/2021	3	63	21
PLANNED	12/30/2021	18	9,504	528
PLANNED	12/30/2021	1	49	49
PLANNED	12/30/2021	8	128	16
PLANNED	12/30/2021	12	468	39
CUSTOMER REQUEST	12/30/2021	14	140	10
PLANNED	12/30/2021	1	4	4
PLANNED	12/30/2021	2	58	29
PLANNED	12/30/2021	2	18	9
PLANNED	12/30/2021	7	102	30
PLANNED	12/30/2021	20	1,140	57
CUSTOMER REQUEST	12/30/2021	10	60	6
PLANNED	12/30/2021	21	882	42
PLANNED	12/30/2021	16	688	43

Q13 - Distribution Excluded Outage Events

Causation	Date	CI	CMI	L-Bar
PLANNED	12/30/2021	13	559	43
PLANNED	12/30/2021	1	6	6
PLANNED	12/30/2021	23	2,829	123
PLANNED	12/30/2021	11	682	62
PLANNED	12/30/2021	10	710	71
PLANNED	12/30/2021	1	14	14
PLANNED	12/30/2021	3	96	32
CUSTOMER REQUEST	12/30/2021	7	154	22
PLANNED	12/30/2021	2	782	391
PLANNED	12/30/2021	14	1,204	86
PLANNED	12/30/2021	9	801	89
PLANNED	12/30/2021	30	630	21
PLANNED	12/30/2021	5	270	54
CUSTOMER REQUEST	12/30/2021	5	540	186
PLANNED	12/30/2021	4	48	12
PLANNED	12/30/2021	8	192	24
PLANNED	12/30/2021	2	18	9
CUSTOMER REQUEST	12/30/2021	1	201	201
PLANNED	12/30/2021	13	247	19
PLANNED	12/30/2021	1	8	8
PLANNED	12/30/2021	3	21	7
PLANNED	12/30/2021	9	1,062	118
PLANNED	12/30/2021	9	504	56
PLANNED	12/30/2021	2	250	125
CUSTOMER REQUEST	12/30/2021	11	88	8
PLANNED	12/30/2021	9	603	67
PLANNED	12/30/2021	4	60	15
PLANNED	12/30/2021	7	35	5
PLANNED	12/30/2021	13	3,068	236
CUSTOMER REQUEST	12/30/2021	1	89	89
PLANNED	12/30/2021	1	101	101
PLANNED	12/31/2021	1	17	17
PLANNED	12/31/2021	5	150	30
PLANNED	12/31/2021	5	95	19
PLANNED	12/31/2021	2	210	105
PLANNED	12/31/2021	2	184	92
CUSTOMER REQUEST	12/31/2021	1	205	205

Feeder Specific Data and Attached Laterals

FPL Feeder Specific Data and attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR	
800335	BUENA VISTA	Hybrid	2,296	22	22	3	5.4	1.4	3.6	1.1	9.0	2.5	11.5	2,019	58,474	Yes	0.11	8.21	18	
203135	ROCKLEDGE	Hybrid	685	15	22	3	3.5	0.3	6.1	3.3	9.6	3.6	13.2	634	55,402	Yes	-0.51	4.39	26	
400935	BELLE GLADE	Hybrid	1,338	41	25	6	8.5	0.5	11.0	2.6	19.5	3.1	22.6	709	47,853	Yes	0.11	5.21	32	
801833	BISCAYNE	Hybrid	1,521	18	0	3	1.5	0.9	12.4	0.1	13.9	1.0	14.9	1,494	295,658	Yes	-0.21	6.89	104	
201731	SYKES CREEK	Hybrid	771	24	11	5	3.4	1.8	4.5	1.3	7.9	3.1	11.0	734	54,326	Yes	-0.35	4.55	22	
500836	WHITFIELD	Hybrid	1,009	20	32	7	4.4	2.7	5.9	7.3	10.3	10.0	20.3	2,311	181,371	Yes	0.16	9.76	35	
406336	ROEBUCK	Hybrid	1,664	4	24	0	1.7	1.2	0.9	8.6	2.6	9.8	12.4	260	34,305	Yes	-0.30	8.00	10	
400732	BOCA RATON	Hybrid	879	3	14	2	1.0	0.7	1.3	0.7	2.3	1.4	3.7	44	6,834	Yes	0.03	2.23	8	
801033	NORMANDY BEACH	Hybrid	1,236	4	14	2	1.9	1.2	1.2	0.8	3.1	2.0	5.1	3,149	89,051	Yes	0.15	4.75	14	
700966	HALLANDALE	UG	1,945	0	17	0	-	3.2	-	6.6	-	-	9.8	9.8	987	71,039	Yes	-0.13	6.87	4
404940	PORT SEWALL	Hybrid	1,880	18	29	9	5.1	3.9	4.2	17.4	9.3	21.3	30.6	5	255	Yes	0.00	0.00	1	
700841	BEVERLY	UG	16	0	3	0	-	1.0	-	0.6	-	-	1.6	1.6	-	Yes	0.35	1.15	0	
207262	CHULUOTA	Hybrid	1,451	11	19	0	2.8	3.6	4.3	19.0	7.1	22.6	29.7	446	54,404	Yes	-1.05	11.55	41	
812166	BEACON	UG	33	0	8	0	-	2.3	-	1.5	-	-	3.8	3.8	-	Yes	0.48	8.98	0	
506966	WOODS	Hybrid	2,063	4	39	2	2.4	1.2	2.3	20.5	4.7	21.7	26.4	7	689	Yes	0.00	0.00	3	
501064	FRUITVILLE	Hybrid	2,153	15	72	10	7.1	5.0	7.6	31.8	14.7	36.8	51.5	743	248,128	Yes	-0.10	10.80	27	
705233	TIMBERLAKE	Hybrid	490	8	18	6	2.9	1.6	2.8	3.4	5.7	5.0	10.7	173	32,361	Yes	-0.10	6.90	15	
812162	BEACON	Hybrid	1,117	2	41	1	5.1	5.0	0.3	5.7	5.4	10.7	16.1	2,171	54,936	Yes	0.85	13.05	8	
106863	FOREST GROVE	Hybrid	2,338	17	36	8	2.8	5.2	9.5	19.1	12.3	24.3	36.6	2,819	120,165	Yes	-0.29	9.81	51	
704666	SPRINGTREE	Hybrid	1,422	3	49	0	3.7	0.4	0.3	8.3	4.0	8.7	12.7	2,220	109,592	Yes	-0.14	6.56	15	
700136	SISTRUNK	Hybrid	1,443	5	24	3	2.3	2.7	0.8	1.0	3.1	3.7	6.8	32	3,937	Yes	0.43	6.23	7	
701038	SAMPLE ROAD	Hybrid	2,566	11	35	7	3.5	0.5	3.9	8.2	7.4	8.7	16.1	758	65,674	Yes	-0.89	7.71	37	
411735	INLET	OH	1,425	30	6	1	3.1	0.2	8.5	0.4	11.6	0.6	12.2	1,429	34,233	Yes	0.00	0.00	3	
801934	DEAUVILLE	UG	852	0	5	0	-	1.1	-	0.4	-	-	1.5	1.5	148	6,808	Yes	-0.48	1.52	1
409534	LAKE IDA	UG	2,819	0	41	0	1.1	3.4	-	20.4	1.1	23.8	24.9	155	19,626	Yes	-0.09	7.51	15	
102233	MADISON	Hybrid	1,560	34	16	9	5.1	0.1	10.5	2.0	15.6	2.1	17.7	477	48,363	Yes	-0.42	7.18	39	
201437	GRANDVIEW	Hybrid	878	28	10	4	3.4	0.4	5.6	4.1	9.0	4.5	13.5	254	29,885	Yes	0.43	4.63	30	
813231	KNOWLTON	UG	1,663	0	8	0	-	4.4	-	1.4	-	-	5.8	5.8	-	Yes	-0.08	8.12	0	
504664	CASTLE	Hybrid	1,544	56	26	5	6.1	0.7	12.1	7.8	18.2	8.5	26.7	236	29,879	Yes	-0.17	12.73	55	
800336	BUENA VISTA	Hybrid	1,641	14	5	4	2.9	0.5	3.4	0.4	6.3	0.9	7.2	1,559	171,062	Yes	-0.07	3.63	32	
805136	LAWRENCE	Hybrid	2,668	21	9	9	2.7	0.5	3.9	1.0	6.6	1.5	8.1	4,028	154,105	Yes	-0.13	8.37	32	
100233	ST AUGUSTINE	Hybrid	890	34	8	3	3.8	0.2	5.0	0.5	8.8	0.7	9.5	177	21,153	Yes	0.10	4.10	17	
800635	LITTLE RIVER	Hybrid	1,485	16	19	2	4.2	0.1	2.3	1.3	6.5	1.4	7.9	539	74,503	Yes	2.25	7.25	24	
802035	CUTLER	Hybrid	1,072	7	37	5	3.5	1.8	3.1	17.5	6.6	19.3	25.9	1,446	176,988	Yes	0.29	8.99	36	
805332	KEY BISCAYNE	Hybrid	1,204	3	26	2	2.4	1.4	3.1	4.2	5.5	5.6	11.1	1,471	142,655	Yes	-0.74	8.26	31	
702031	DRIFTWOOD	Hybrid	846	3	26	2	2.4	0.9	1.6	4.8	4.0	5.7	9.7	40	9,033	Yes	-0.19	6.81	8	
703433	RESERVATION	Hybrid	971	12	15	0	3.2	0.2	3.7	1.2	6.9	1.4	8.3	1,307	194,169	Yes	-0.08	6.52	45	
813531	JACKSON	Hybrid	867	5	27	3	2.7	1.9	1.2	1.1	3.9	3.0	6.9	1,825	8,928	Yes	-0.10	5.20	5	
803236	HOMESTEAD	Hybrid	1,031	6	17	3	3.0	1.3	4.1	7.5	7.1	8.8	15.9	230	52,127	Yes	0.29	5.99	23	
811563	KOGER	Hybrid	1,389	4	45	1	4.0	2.8	1.1	7.0	5.1	9.8	14.9	38	5,177	Yes	0.24	11.44	7	
707135	CULLUM	Hybrid	1,532	5	30	3	1.3	5.3	1.9	14.1	3.2	19.4	22.6	133	27,000	Yes	-0.05	8.05	13	
810362	NEWTON	UG	2,761	0	24	0	0.5	4.4	-	26.5	0.5	30.9	31.4	3,733	262,024	Yes	-0.05	13.25	14	
106231	GERONA	Hybrid	1,147	11	24	1	2.5	0.9	5.4	6.7	7.9	7.6	15.5	542	34,782	Yes	0.50	5.80	25	
408163	ROSS	Hybrid	2,912	0	61	0	2.6	5.5	-	33.5	2.6	39.0	41.6	127	13,818	Yes	0.06	12.06	10	
405037	SANDALFOOT	UG	1,406	0	15	0	0.2	3.2	-	17.1	0.2	20.3	20.5	3	758	Yes	0.29	6.99	3	
104734	KACIE	Hybrid	1,546	24	34	0	4.4	1.8	8.2	17.7	12.6	19.5	32.1	560	55,951	Yes	-0.23	5.37	40	
406234	OAKES	Hybrid	1,744	0	35	2	2.8	4.1	0.5	21.3	3.3	25.4	28.7	111	20,967	Yes	-0.57	8.23	12	
809936	SIMPSON	Hybrid	2,088	17	15	4	2.9	0.3	3.8	1.1	6.7	1.4	8.1	1,024	69,038	Yes	0.01	8.21	35	
106464	SPRUCE	Hybrid	1,428	12	42	3	4.0	0.3	3.4	13.7	7.4	14.0	21.4	162	16,278	Yes	0.38	8.88	18	
707861	PARKLAND	UG	1,900	0	51	0	-	6.9	-	23.9	-	-	30.8	30.8	79	11,794	Yes	-0.04	12.86	8
408962	PLUMOSUS	Hybrid	1,738	0	31	1	3.0	0.7	0.2	14.6	3.2	15.3	18.5	889	59,358	Yes	-0.16	6.54	30	

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
409763	CATCHMENT	Hybrid	2,124	5	73	4	5.9	4.8	2.3	27.9	8.2	32.7	40.9	317	40,227	Yes	-0.01	13.09	24
203531	HIBISCUS	Hybrid	929	6	16	5	2.1	1.3	2.3	7.0	4.4	8.3	12.7	266	39,166	Yes	-0.10	4.80	14
810937	LATIN QUARTER	UG	1	0	0	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	1.52	2.32	0
808439	SNAKE CREEK	UG	-	0	0	0	-	3.0	-	-	-	3.0	3.0	-	-	Yes	-1.07	0.23	0
201632	PALM BAY	Hybrid	1,439	26	10	3	3.7	0.2	13.0	2.0	16.7	2.2	18.9	1,103	41,565	Yes	-1.90	4.80	37
101631	HUDSON	OH	-	0	0	0	0.6	-	-	-	0.6	-	0.6	-	-	Yes	0.03	17.03	0
700339	PINEHURST	UG	2	0	0	0	-	1.3	-	-	-	1.3	1.3	-	-	Yes	-0.05	2.25	0
808066	FLAGAMI	Hybrid	1,307	6	21	4	2.6	1.0	2.6	3.6	5.2	4.6	9.8	473	112,537	Yes	-0.24	6.76	22
702138	CYPRESS CREEK	Hybrid	259	3	11	1	1.4	0.8	1.6	2.6	3.0	3.4	6.4	64	7,549	Yes	-0.05	5.15	14
805134	LAWRENCE	Hybrid	2,324	18	18	7	3.0	0.5	4.7	1.1	7.7	1.6	9.3	1,093	107,354	Yes	-0.43	7.67	33
501765	IONA	Hybrid	4,072	4	63	5	4.9	1.2	3.4	22.0	8.3	23.2	31.5	5,687	134,634	Yes	0.04	11.34	35
810569	JASMINE	UG	3,448	0	24	0	-	5.2	-	9.3	-	14.5	14.5	3,229	118,136	Yes	1.31	8.71	13
506361	DEEPCREEK	Hybrid	3,678	20	33	9	5.1	1.1	33.1	13.3	38.2	14.4	52.6	1,550	139,710	Yes	-0.38	15.32	55
413737	RUNWAY	Hybrid	658	6	17	2	4.3	0.1	3.0	5.4	7.3	5.5	12.8	133	20,126	Yes	0.43	2.93	14
408562	ALEXANDER	Hybrid	1,783	30	35	15	19.5	6.6	47.0	21.4	66.5	28.0	94.5	2,698	119,153	Yes	0.36	10.96	89
301135	COLUMBIA	Hybrid	613	46	14	2	14.4	0.3	17.5	1.5	31.9	1.8	33.7	1,010	17,322	Yes	0.00	5.00	26
502637	COLONIAL	Hybrid	1,199	15	25	6	3.4	0.6	4.5	2.4	7.9	3.0	10.9	196	30,970	Yes	-0.15	5.35	27
503038	PHILLIPPI	Hybrid	2,642	3	15	11	1.0	1.9	2.5	5.7	3.5	7.6	11.1	2,774	87,197	Yes	-0.16	5.54	9
814040	BRICKELL	UG	793	0	4	0	-	1.3	-	0.4	-	1.7	1.7	-	-	Yes	0.24	3.34	0
111131	HALIFAX	UG	2	0	4	0	-	1.6	-	-	-	1.6	1.6	-	-	Yes	-0.24	2.96	0
200533	MELBOURNE	Hybrid	623	7	21	5	2.5	0.2	2.8	1.7	5.3	1.9	7.2	724	32,611	Yes	-0.09	4.41	13
401033	GREENACRES	Hybrid	1,683	22	19	12	4.2	0.5	8.0	10.8	12.2	11.3	23.5	3,231	174,226	Yes	-0.11	7.79	64
412061	GIFFORD	Hybrid	963	44	27	7	7.6	0.7	17.7	11.7	25.3	12.4	37.7	192	32,743	Yes	-0.43	4.77	34
700143	SISTRUNK	Hybrid	1,940	19	32	4	4.9	1.1	5.3	3.5	10.2	4.6	14.8	724	144,821	Yes	-1.00	8.70	56
501239	NAPLES	Hybrid	1,115	5	33	7	2.2	1.0	2.6	3.6	4.8	4.6	9.4	182	34,226	Yes	-4.65	4.75	17
508462	GATEWAY	Hybrid	2,607	35	26	6	8.9	0.4	31.1	7.0	40.0	7.4	47.4	4,952	228,425	Yes	-0.51	13.09	48
800736	HIALEAH	UG	-	0	0	0	-	0.3	-	-	-	0.3	0.3	-	-	Yes	-1.05	3.75	0
210134	DERBY	Hybrid	2,250	3	40	0	3.0	0.5	0.3	15.2	3.3	15.7	19.0	190	12,223	Yes	-0.43	7.77	11
804931	OJUS	Hybrid	1,510	19	17	9	3.1	0.9	7.2	2.4	10.3	3.3	13.6	2,290	185,760	Yes	-0.73	9.07	68
412262	OTTER	Hybrid	2,877	60	3	1	5.1	2.2	38.5	0.3	43.6	2.5	46.1	1,249	111,821	Yes	-0.24	13.06	66
500335	VENICE	Hybrid	2,694	10	24	11	3.6	1.2	6.9	2.9	10.5	4.1	14.6	1,070	50,066	Yes	-0.41	7.19	27
208632	TULSA	Hybrid	1,704	39	7	2	5.8	1.6	14.5	5.4	20.3	7.0	27.3	1,893	174,418	Yes	-0.08	7.72	18
406864	KIMBERLY	Hybrid	2,504	2	43	0	5.7	1.4	0.2	21.2	5.9	22.6	28.5	1,959	70,094	Yes	-0.23	9.77	12
101039	HOLLY HILL	Hybrid	552	7	4	1	1.6	0.9	1.5	0.5	3.1	1.4	4.5	45	6,709	Yes	1.04	2.24	10
505461	WINKLER	Hybrid	2,044	17	21	4	3.7	0.8	3.5	5.6	7.2	6.4	13.6	30	6,103	Yes	-0.47	7.83	9
703233	WOODLANDS	Hybrid	1,739	0	19	0	1.3	0.6	-	7.9	1.3	8.5	9.8	475	31,787	Yes	-0.17	4.33	6
801435	FULFORD	Hybrid	2,846	34	40	3	3.2	0.8	12.5	13.4	15.7	14.2	29.9	11,210	240,599	Yes	-0.16	9.64	146
401035	GREENACRES	Hybrid	3,139	7	33	2	3.4	0.3	1.5	14.9	4.9	15.2	20.1	4,485	37,825	Yes	0.18	8.08	26
700967	HALLANDALE	UG	1,877	0	11	0	-	4.8	-	2.7	-	7.5	7.5	142	10,953	Yes	-1.01	6.29	2
700239	HOLLYWOOD	Hybrid	2,586	26	46	3	4.2	0.6	3.0	6.6	7.2	7.2	14.4	139	12,687	Yes	-0.15	9.55	24
705563	SOUTHSIDE	UG	128	0	5	0	-	5.8	-	0.6	-	6.4	6.4	2	766	Yes	-0.07	3.53	2
104932	MOULTRIE	Hybrid	1,676	9	25	1	3.0	2.3	3.2	17.8	6.2	20.1	26.3	456	59,800	Yes	-0.27	7.03	31
811942	OVERTOWN	UG	-	0	0	0	-	1.8	-	-	-	1.8	1.8	-	-	Yes	1.06	2.86	0
404434	PURDY LANE	Hybrid	2,437	25	24	5	2.8	0.2	7.5	8.4	10.3	8.6	18.9	1,594	155,712	Yes	0.10	7.40	41
406062	SHERMAN	Hybrid	3,974	63	15	14	13.2	6.7	44.9	12.8	58.1	19.5	77.6	3,771	158,203	Yes	-0.14	12.36	83
404436	PURDY LANE	Hybrid	2,354	12	28	3	4.3	0.5	2.5	9.4	6.8	9.9	16.7	4,323	280,529	Yes	-0.06	7.54	21
102364	ST JOE	Hybrid	2,818	29	36	4	5.9	2.7	17.3	18.7	23.2	21.4	44.6	8,530	106,248	Yes	-0.70	11.00	46
106363	REGIS	OH	1,166	90	18	7	24.9	-	64.1	3.5	89.0	3.5	92.5	3,563	157,918	Yes	0.40	4.60	73
402936	OSLO	Hybrid	728	14	18	2	5.5	0.4	9.6	8.5	15.1	8.9	24.0	53	7,969	Yes	-0.02	2.58	16
804732	HAULOVER	UG	1,052	0	6	0	-	1.5	-	1.8	-	3.3	3.3	169	40,703	Yes	-0.25	3.75	2
405861	DELTRAIL	Hybrid	3,637	8	64	3	4.8	1.4	1.7	23.9	6.5	25.3	31.8	947	31,812	Yes	0.15	10.25	27
503437	SOUTH VENICE	Hybrid	1,589	35	6	3	5.1	0.3	14.4	0.9	19.5	1.2	20.7	234	35,643	Yes	0.30	5.00	34

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
705564	SOUTHSIDE	Hybrid	1,918	26	8	3	2.9	0.5	6.6	2.0	9.5	2.5	12.0	5,014	206,602	Yes	-0.17	6.83	56
503135	SOLANA	Hybrid	1,523	6	26	1	2.3	2.3	2.3	4.4	4.6	6.7	11.3	1,478	125,478	Yes	0.06	10.16	8
400137	WEST PALM BEACH	Hybrid	713	8	6	1	1.1	2.9	0.4	0.6	1.5	3.5	5.0	5	580	Yes	-0.16	5.04	1
800832	RAILWAY	Hybrid	2,453	7	28	5	2.7	1.6	1.3	3.1	4.0	4.7	8.7	3,591	182,517	Yes	0.29	4.99	13
700736	FAIRMONT	Hybrid	1,446	32	22	1	4.3	0.9	7.9	1.6	12.2	2.5	14.7	531	79,264	Yes	-0.09	8.31	56
810165	SEAGULL	Hybrid	165	5	20	0	7.0	1.4	0.7	1.8	7.7	3.2	10.9	73	8,158	Yes	0.26	10.66	4
709163	GRIFFIN	UG	16	0	0	0	-	2.6	-	-	-	2.6	2.6	-	-	Yes	0.19	2.09	0
206933	BARNA	Hybrid	1,542	18	24	4	4.8	2.1	7.8	8.8	12.6	10.9	23.5	233	19,917	Yes	-0.29	8.51	19
300631	LIVE OAK	OH	1,313	64	11	9	12.5	0.2	38.5	2.0	51.0	2.2	53.2	601	89,229	Yes	-0.17	5.23	69
510661	KELLY	Hybrid	3,623	12	39	6	2.3	4.6	10.7	20.4	13.0	25.0	38.0	4,771	276,138	Yes	-0.28	9.32	37
803031	TROPICAL	Hybrid	1,515	10	30	4	2.8	0.3	4.5	5.8	7.3	6.1	13.4	5,541	168,834	Yes	-0.04	7.36	30
701037	SAMPLE ROAD	OH	1,383	27	0	1	3.3	0.4	7.8	-	11.1	0.4	11.5	562	102,887	Yes	0.00	5.10	46
100838	PORT ORANGE	Hybrid	1,224	0	41	0	3.0	0.5	-	13.7	3.0	14.2	17.2	5	515	Yes	-0.24	7.76	5
700838	BEVERLY	Hybrid	1,577	27	4	3	2.1	0.8	7.8	0.4	9.9	1.2	11.1	527	86,069	Yes	-0.56	6.14	57
505766	AUBURN	Hybrid	2,387	2	47	2	4.5	1.7	2.8	21.2	7.3	22.9	30.2	281	58,865	Yes	-0.37	5.83	14
808166	MILAM	Hybrid	551	0	17	0	0.7	3.6	-	7.1	0.7	10.7	11.4	22	5,810	Yes	-0.13	5.87	5
707933	TWINLAKES	Hybrid	330	3	0	0	0.8	0.4	0.6	-	1.4	0.4	1.8	48	18,014	Yes	0.08	1.98	4
704663	SPRINGTREE	Hybrid	2,171	1	39	0	2.2	0.6	0.2	11.8	2.4	12.4	14.8	223	49,399	Yes	0.06	8.16	10
707461	SAWGRASS	UG	2	0	0	0	-	2.7	-	-	-	2.7	2.7	-	-	Yes	1.17	3.37	0
407933	QUANTUM	Hybrid	1,367	12	35	6	3.5	2.2	2.2	7.6	5.7	9.8	15.5	85	5,828	Yes	0.43	7.93	13
703235	WOODLANDS	Hybrid	2,161	1	35	0	2.8	0.9	0.1	14.3	2.9	15.2	18.1	77	14,670	Yes	-0.24	6.66	7
800231	MIAMI BEACH	Hybrid	2,497	3	20	1	1.8	1.5	0.2	0.9	2.0	2.4	4.4	124	5,830	Yes	-0.35	6.25	11
701134	LYONS	Hybrid	1,425	0	24	1	1.3	0.2	0.2	2.6	1.5	2.8	4.3	226	23,131	Yes	-3.36	6.64	6
803801	137TH AVE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-17.20	0.00	0
411733	INLET	Hybrid	1,544	10	20	4	0.9	2.7	5.5	3.8	6.4	6.5	12.9	2,580	201,603	Yes	-0.17	7.83	25
804032	LE JEUNE	UG	3	0	2	0	-	2.6	-	-	-	2.6	2.6	-	-	Yes	0.47	4.27	0
802731	MARION	Hybrid	442	1	33	1	2.2	0.3	0.7	6.9	2.9	7.2	10.1	81	9,557	Yes	-0.04	5.06	9
412062	GIFFORD	Hybrid	2,921	33	64	3	5.6	9.8	10.2	28.6	15.8	38.4	54.2	4,049	209,044	Yes	-0.29	9.41	50
809231	MITCHELL	Hybrid	1,496	3	19	2	1.4	1.1	2.0	8.1	3.4	9.2	12.6	232	41,629	Yes	1.79	6.89	15
413931	TULIP	Hybrid	1,128	5	47	5	2.4	0.4	1.5	4.2	3.9	4.6	8.5	104	17,537	Yes	0.02	5.12	15
204363	SUNTREE	Hybrid	2,870	0	49	4	3.2	3.0	1.2	30.2	4.4	33.2	37.6	3,231	55,501	Yes	-0.11	12.49	19
100938	SOUTH DAYTONA	Hybrid	2,553	24	15	2	1.9	3.2	3.4	4.1	5.3	7.3	12.6	330	98,593	Yes	-0.41	6.39	11
508864	PANACEA	OH	2,607	63	2	0	6.4	0.2	49.0	0.4	55.4	0.6	56.0	85	6,723	Yes	0.19	10.29	29
502836	PAYNE	Hybrid	679	5	8	3	1.0	2.1	0.4	1.3	1.4	3.4	4.8	65	6,345	Yes	-1.26	3.24	3
813138	FIREHOUSE	UG	717	0	4	0	-	2.4	-	0.7	-	3.1	3.1	-	-	Yes	0.47	3.87	0
504666	CASTLE	Hybrid	1,543	2	37	0	2.5	2.8	-	15.4	2.5	18.2	20.7	2,312	40,600	Yes	-1.13	11.67	31
402833	LANTANA	Hybrid	1,977	11	28	3	3.7	2.4	5.2	4.8	8.9	7.2	16.1	1,161	100,089	Yes	0.24	8.44	33
809039	AVENTURA	UG	1,112	0	5	0	-	3.2	-	0.9	-	4.1	4.1	-	-	Yes	0.46	4.66	0
808064	FLAGAMI	Hybrid	1,149	0	19	4	1.4	2.8	1.0	7.0	2.4	9.8	12.2	54	7,389	Yes	0.13	8.43	9
702936	HAWKINS	Hybrid	895	0	20	0	1.7	0.2	-	7.1	1.7	7.3	9.0	345	56,466	Yes	0.07	4.77	23
111132	HALIFAX	Hybrid	822	8	33	4	4.1	0.6	1.5	4.6	5.6	5.2	10.8	32	4,866	Yes	0.12	5.92	11
814050	BRICKELL	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.00	0.00	0
401431	WHITE CITY	Hybrid	1,615	37	16	8	6.2	-	22.9	2.6	29.1	2.6	31.7	1,318	109,751	Yes	0.15	8.35	48
406334	ROEBUCK	Hybrid	1,244	0	20	1	2.6	0.7	0.1	7.2	2.7	7.9	10.6	20	2,021	Yes	-0.08	4.52	6
800103	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.00	0.00	0
412264	OTTER	Hybrid	2,765	46	2	0	5.8	1.9	33.6	0.2	39.4	2.1	41.5	212	6,566	Yes	11.09	11.09	15
702532	DAVIE	Hybrid	67	0	26	1	1.1	2.4	0.6	4.0	1.7	6.4	8.1	4	564	Yes	-0.31	9.59	2
203536	HIBISCUS	Hybrid	753	23	8	2	3.3	1.0	7.9	3.5	11.2	4.5	15.7	1,659	61,687	Yes	-0.01	3.99	17
807161	PENSUCO	Hybrid	738	23	46	2	17.2	3.3	13.5	9.7	30.7	13.0	43.7	1,966	148,841	Yes	4.94	16.34	50
801738	62ND AVE	Hybrid	751	20	1	0	2.4	0.7	5.2	-	7.6	0.7	8.3	379	85,396	Yes	-0.13	3.27	41
706661	NOBHILL	Hybrid	2,155	17	41	6	5.6	0.5	13.4	11.9	19.0	12.4	31.4	994	145,054	Yes	-0.76	11.24	41
203538	HIBISCUS	Hybrid	1,295	30	20	6	3.5	2.6	11.0	3.5	14.5	6.1	20.6	1,565	75,381	Yes	-0.90	7.50	33

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
500934	OSPREY	Hybrid	1,908	4	27	1	3.4	0.6	2.1	25.3	5.5	25.9	31.4	190	32.101	Yes	0.01	7.71	13
500231	BRADENTON	UG	22	0	2	0	-	1.0	-	1.1	-	2.1	2.1	-	-	Yes	0.02	3.72	0
804034	LE JEUNE	UG	19	0	0	0	-	1.7	-	-	-	1.7	1.7	-	-	Yes	-0.24	2.06	0
707533	COLLINS	Hybrid	565	13	14	2	2.5	0.5	2.7	1.0	5.2	1.5	6.7	382	52.208	Yes	0.02	3.92	23
102532	MATANZAS	Hybrid	1,594	16	18	4	3.8	0.6	7.3	6.2	11.1	6.8	17.9	1,653	84.126	Yes	-0.37	4.63	42
800845	RAILWAY	UG	1,879	1	14	2	-	6.2	0.1	1.2	0.1	7.4	7.5	19	3.477	Yes	-0.41	6.79	5
807963	MIAMI LAKES	UG	1,632	0	32	0	1.0	2.0	-	20.3	1.0	22.3	23.3	583	128.464	Yes	-0.25	11.95	21
701132	LYONS	Hybrid	1,608	18	4	5	2.3	0.1	8.2	1.3	10.5	1.4	11.9	1,970	72.649	Yes	-0.31	5.89	21
801433	FULFORD	Hybrid	1,776	21	27	2	4.1	0.3	6.1	1.4	10.2	1.7	11.9	5,134	185.502	Yes	0.06	7.16	67
805733	GALLOWAY	Hybrid	684	9	14	4	3.4	0.1	4.1	3.0	7.5	3.1	10.6	144	31.276	Yes	-0.38	5.12	24
207934	RINEHART	Hybrid	725	0	21	3	2.6	1.0	0.5	6.1	3.1	7.1	10.2	35	5.138	Yes	-5.19	3.51	5
405936	BUTTS	UG	1,515	0	25	0	0.7	3.6	-	11.2	0.7	14.8	15.5	206	39.738	Yes	0.22	5.72	14
208163	HIELD	Hybrid	2,317	51	5	1	9.4	1.8	27.2	0.8	36.6	2.6	39.2	808	87.588	Yes	-0.18	9.52	63
413635	BONANZA	Hybrid	1,733	33	32	13	6.1	0.3	7.9	4.1	14.0	4.4	18.4	449	44.074	Yes	0.27	8.37	27
506262	SHADE	Hybrid	1,416	18	51	9	6.3	1.1	5.7	11.6	12.0	12.7	24.7	1,393	102.660	Yes	-0.95	10.75	19
106234	GERONA	Hybrid	1,706	3	36	4	4.0	1.5	1.8	11.2	5.8	12.7	18.5	48	8.213	Yes	-0.11	6.19	5
802232	GLADEVIEW	Hybrid	2,692	55	18	1	6.1	0.3	12.2	2.3	18.3	2.6	20.9	1,479	114.169	Yes	-0.07	10.23	73
802938	GRAPELAND	Hybrid	1,147	12	7	2	1.8	1.1	2.9	0.5	4.7	1.6	6.3	313	68.148	Yes	4.01	4.01	21
707264	FLAMINGO	Hybrid	2,034	1	44	1	4.5	1.9	0.1	16.2	4.6	18.1	22.7	35	2.260	Yes	-0.43	13.97	5
503134	SOLANA	Hybrid	1,777	0	48	2	1.5	2.3	0.6	13.9	2.1	16.2	18.3	963	134.529	Yes	-0.36	7.64	11
811063	PALMETTO	Hybrid	3,897	0	52	1	2.6	0.4	0.3	15.4	2.9	15.8	18.7	520	65.824	Yes	-0.25	11.55	22
813232	KNOWLTON	UG	2,375	0	5	0	-	7.0	-	0.5	-	7.5	7.5	-	-	Yes	-1.69	5.01	0
407864	TARTAN	Hybrid	3,902	17	51	5	5.6	0.5	7.6	22.4	13.2	22.9	36.1	1,518	93.687	Yes	0.04	12.04	43
500235	BRADENTON	Hybrid	1,151	29	5	5	2.9	1.2	8.7	0.9	11.6	2.1	13.7	188	32.217	Yes	-0.07	5.43	30
501535	PUNTA GORDA	Hybrid	1,580	21	35	5	7.9	2.4	6.5	11.2	14.4	13.6	28.0	111	7.449	Yes	0.41	5.31	18
408169	ROSS	Hybrid	766	0	16	0	0.5	2.0	-	6.0	0.5	8.0	8.5	26	4.752	Yes	0.41	4.51	3
800536	RIVERSIDE	Hybrid	1,278	14	9	4	2.0	0.2	2.8	0.9	4.8	1.1	5.9	2,660	35.122	Yes	-0.18	5.92	17
505962	CARLSTROM	Hybrid	2,601	32	26	8	9.3	0.3	29.0	12.5	38.3	12.8	51.1	512	56.886	Yes	-0.50	8.70	36
810163	SEAGULL	Hybrid	1,609	0	37	0	2.4	1.2	-	8.3	2.4	9.5	11.9	337	18.211	Yes	-0.08	8.42	6
807540	DADELAND	UG	391	0	6	0	-	3.3	-	0.4	-	3.7	3.7	-	-	Yes	-0.01	1.59	0
801936	DEAUVILLE	Hybrid	1,242	1	3	3	0.8	0.8	0.6	0.4	1.4	1.2	2.6	315	15.614	Yes	0.10	2.80	6
109961	PACETTI	UG	2,989	0	83	0	1.6	14.5	-	45.7	1.6	60.2	61.8	202	26.101	Yes	15.00	15.00	14
807933	MIAMI LAKES	UG	1,761	0	17	0	-	2.8	-	10.2	-	13.0	13.0	93	20.708	Yes	-0.03	6.07	5
800337	BUENA VISTA	Hybrid	1,606	2	21	3	0.8	2.8	0.7	3.4	1.5	6.2	7.7	1,775	61.359	Yes	0.53	7.13	9
400335	NORTHWOOD	Hybrid	163	2	15	3	2.6	0.9	1.0	0.9	3.6	1.8	5.4	9	1.450	Yes	-0.11	5.49	7
804039	LE JEUNE	UG	-	0	0	0	-	1.5	-	-	-	-	1.5	-	-	Yes	0.02	0.62	0
801734	62ND AVE	Hybrid	1,709	14	10	3	3.3	0.4	5.2	0.7	8.5	1.1	9.6	665	125.952	Yes	-2.56	7.84	45
702632	ELY	Hybrid	1,214	21	10	2	3.7	0.2	7.6	2.1	11.3	2.3	13.6	311	36.782	Yes	-0.08	7.12	40
507563	PARRISH	Hybrid	3,161	3	49	1	3.9	7.2	0.7	47.6	4.6	54.8	59.4	419	83.717	Yes	-0.78	14.22	14
400334	NORTHWOOD	Hybrid	276	5	5	0	1.0	0.1	0.9	0.3	1.9	0.4	2.3	66	13.745	Yes	-0.01	1.59	4
504962	GOLDEN GATE	Hybrid	2,255	18	24	6	5.2	0.2	10.7	3.6	15.9	3.8	19.7	1,538	57.632	Yes	-0.16	12.84	54
400332	NORTHWOOD	Hybrid	552	15	20	7	2.9	1.2	5.0	1.9	7.9	3.1	11.0	2,337	168.250	Yes	-0.31	6.39	69
804334	KENDALL	Hybrid	885	31	13	10	3.3	0.5	12.5	6.0	15.8	6.5	22.3	468	99.517	Yes	0.02	7.02	74
503031	PHILLIPPI	Hybrid	1,986	10	31	12	3.3	0.3	6.1	7.2	9.4	7.5	16.9	815	101.229	Yes	-0.25	7.55	28
807036	ROSELAWN	Hybrid	1,475	8	27	4	4.4	1.2	2.2	2.5	6.6	3.7	10.3	174	60.143	Yes	0.76	9.36	19
807731	LEMON CITY	Hybrid	1,336	38	4	1	2.4	0.4	9.4	0.8	11.8	1.2	13.0	2,080	172.917	Yes	-0.17	6.63	81
700237	HOLLYWOOD	Hybrid	1,897	7	11	8	2.7	0.6	3.8	1.1	6.5	1.7	8.2	934	127.252	Yes	-0.82	7.08	56
408865	ABERDEEN	Hybrid	2,657	1	47	1	4.6	3.5	0.9	32.0	5.5	35.5	41.0	3,573	233.826	Yes	-0.63	13.67	29
402761	PORT MAYACA	Hybrid	541	62	18	7	35.1	3.7	63.7	16.7	98.8	20.4	119.2	1,364	164.431	Yes	0.41	4.81	51
704463	FASHION	Hybrid	2,754	33	46	4	6.3	0.7	11.2	9.3	17.5	10.0	27.5	2,631	133.484	Yes	-1.03	14.07	62
407231	JOG	Hybrid	1,336	24	35	2	6.1	1.3	6.7	19.4	12.8	20.7	33.5	2,450	78.301	Yes	-0.27	6.13	34
410461	GATLIN	Hybrid	2,515	41	5	0	3.2	2.1	24.5	4.4	27.7	6.5	34.2	743	130.996	Yes	0.81	11.61	48

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
408563	ALEXANDER	UG	5	0	13	0	-	3.7	-	1.7	-	5.4	5.4	-	-	Yes	1.01	4.51	0
807531	DADELAND	Hybrid	592	22	16	4	3.7	0.2	4.6	2.6	8.3	2.8	11.1	1,868	103,615	Yes	-0.13	3.07	37
100236	ST AUGUSTINE	Hybrid	1,413	18	16	8	3.3	0.2	4.3	2.7	7.6	2.9	10.5	112	10,352	Yes	-0.05	7.85	12
804134	GARDEN	Hybrid	1,106	14	1	2	2.3	0.1	6.4	1.3	8.7	1.4	10.1	915	60,131	Yes	-0.22	5.68	43
704162	MOFFETT	UG	1,926	0	9	0	-	6.5	-	1.0	-	7.5	7.5	-	-	Yes	0.62	7.32	0
407232	JOG	Hybrid	1,038	13	10	3	3.7	0.1	6.7	5.6	10.4	5.7	16.1	2,552	113,678	Yes	-0.34	3.86	31
204061	DELTONA	Hybrid	2,989	23	22	10	4.5	1.1	33.6	6.1	38.1	7.2	45.3	2,632	255,111	Yes	-0.39	13.11	47
209764	VIERA	Hybrid	3,137	12	67	4	6.8	1.9	6.9	24.7	13.7	26.6	40.3	570	94,708	Yes	-0.26	12.14	22
508631	LIME	UG	665	0	12	1	-	3.5	0.1	2.7	0.1	6.2	6.3	-	-	Yes	0.05	5.25	0
101133	ORMOND	Hybrid	1,495	7	33	10	3.4	0.3	4.2	8.3	7.6	8.6	16.2	1,301	38,746	Yes	-0.28	7.72	26
702537	DAVIE	Hybrid	1,102	3	23	0	1.9	1.0	0.2	2.5	2.1	3.5	5.6	1,136	46,104	Yes	0.13	6.63	4
703431	RESERVATION	Hybrid	1,858	29	17	7	3.7	0.4	8.7	2.6	12.4	3.0	15.4	487	59,930	Yes	0.03	7.93	48
801831	BISCAYNE	Hybrid	668	18	7	0	2.5	-	4.0	1.1	6.5	1.1	7.6	1,244	150,968	Yes	0.13	5.83	49
408764	SABAL	Hybrid	2,023	0	71	0	5.7	1.0	-	20.3	5.7	21.3	27.0	51	11,118	Yes	-0.97	10.73	5
706164	HOLLYBROOK	Hybrid	3,452	1	59	1	4.6	0.8	0.4	17.7	5.0	18.5	23.5	192	33,009	Yes	-0.03	13.67	20
806340	ULETA	Hybrid	1,448	13	13	5	2.9	0.4	3.0	1.7	5.9	2.1	8.0	2,033	157,185	Yes	0.29	7.09	31
704134	MOFFETT	Hybrid	2,095	12	6	5	4.4	1.1	2.8	0.8	7.2	1.9	9.1	1,110	74,339	Yes	-0.32	7.38	33
801037	NORMANDY BEACH	Hybrid	677	15	1	0	2.0	0.2	3.1	2.4	5.1	2.6	7.7	1,505	151,374	Yes	0.34	4.84	21
814131	BAUER	Hybrid	944	38	23	7	7.9	0.3	12.3	10.9	20.2	11.2	31.4	1,279	96,192	Yes	-0.05	5.75	65
804535	GRATIGNY	Hybrid	12	0	1	0	0.1	1.3	-	-	0.1	1.3	1.4	-	-	Yes	-0.13	3.67	0
800433	COCONUT GROVE	Hybrid	1,223	6	6	3	2.5	0.5	1.9	0.6	4.4	1.1	5.5	1,168	10,534	Yes	-0.20	5.30	10
500764	ENGLEWOOD	Hybrid	2,473	28	21	10	4.7	1.3	22.5	6.8	27.2	8.1	35.3	5,004	177,369	Yes	-0.05	9.25	45
404140	GOLF	UG	2	0	2	0	-	0.6	-	0.3	-	0.9	0.9	-	-	Yes	-0.12	4.48	0
806935	BIRD	Hybrid	812	24	2	2	2.5	0.4	6.9	0.6	9.4	1.0	10.4	317	41,745	Yes	-0.22	4.98	41
407164	CRANE	Hybrid	2,593	9	59	4	4.4	4.7	2.8	33.5	7.2	38.2	45.4	203	31,398	Yes	-0.24	12.16	19
407161	CRANE	Hybrid	2,940	9	49	1	3.4	3.8	5.4	30.3	8.8	34.1	42.9	5,721	154,891	Yes	-1.52	10.88	31
701235	PLAYLAND	Hybrid	1,618	6	21	9	1.9	0.4	2.7	7.5	4.6	7.9	12.5	385	83,239	Yes	0.07	7.27	22
700342	PINEHURST	Hybrid	372	0	13	1	0.4	2.1	0.1	1.0	0.5	3.1	3.6	279	19,296	Yes	-0.06	3.54	9
412162	ALLAPATTAH	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.04	8.54	0
806035	GOLDEN GLADES	Hybrid	196	5	26	1	1.5	0.3	0.8	1.4	2.3	1.7	4.0	241	66,815	Yes	-0.35	5.55	17
704262	IMAGINATION	Hybrid	1,388	23	45	2	5.9	4.8	10.7	25.5	16.6	30.3	46.9	118	19,395	Yes	-0.51	10.79	22
807233	MERCHANDISE	UG	279	0	10	0	-	2.5	-	1.0	-	3.5	3.5	-	-	Yes	-1.04	2.26	0
404831	GERMANTOWN	Hybrid	1,813	17	30	3	5.3	0.3	6.3	6.7	11.6	7.0	18.6	3,034	60,204	Yes	-0.19	8.11	43
702831	PERRY	Hybrid	1,212	6	41	1	4.2	0.2	1.5	10.3	5.7	10.5	16.2	113	10,805	Yes	-0.35	10.25	16
200532	MELBOURNE	Hybrid	973	11	32	5	3.8	1.1	2.1	5.9	5.9	7.0	12.9	116	16,860	Yes	-0.22	6.68	9
802734	MARION	Hybrid	2,299	1	35	0	2.0	0.7	0.1	9.2	2.1	9.9	12.0	312	29,583	Yes	-0.18	6.52	22
814045	BRICKELL	UG	1,143	0	5	0	-	2.9	-	0.7	-	3.6	3.6	10	210	Yes	0.46	5.46	1
800741	HIALEAH	Hybrid	1,854	15	3	2	2.1	0.6	5.8	0.1	7.9	0.7	8.6	2,528	189,247	Yes	-0.77	6.93	49
101031	HOLLY HILL	Hybrid	1,329	11	17	3	1.9	2.5	5.6	2.1	7.5	4.6	12.1	239	47,059	Yes	-0.24	4.96	27
408334	MONTEREY	Hybrid	1,772	55	28	14	5.5	2.3	11.1	8.2	16.6	10.5	27.1	2,121	85,020	Yes	-0.59	8.21	65
300833	LIVE OAK	OH	1,314	58	9	5	12.6	-	31.3	1.3	43.9	1.3	45.2	2,731	203,158	Yes	-0.50	5.30	54
410232	CONGRESS	Hybrid	121	4	31	0	3.1	0.7	0.9	4.4	4.0	5.1	9.1	2	1,111	Yes	-0.24	6.16	2
502201	FRUIT INDUSTRIES	OH	1	0	0	0	0.1	-	-	-	0.1	-	0.1	-	-	Yes	-0.73	1.87	0
406936	DELMAR	Hybrid	1,866	0	23	2	2.7	2.1	0.8	13.4	3.5	15.5	19.0	303	25,345	Yes	-0.10	6.40	4
809336	RONEY	UG	1,120	0	7	0	-	1.7	-	0.6	-	2.3	2.3	-	-	Yes	0.54	4.64	0
809033	AVENTURA	UG	627	0	9	0	-	3.5	-	3.5	-	7.0	7.0	1,357	148,563	Yes	-0.05	2.55	7
803436	MIAMI SHORES	Hybrid	1,216	22	5	2	2.3	0.2	6.0	0.3	8.3	0.5	8.8	1,021	85,762	Yes	0.43	5.43	58
407663	LOXAHATCHEE	Hybrid	2,181	17	50	1	7.0	4.0	5.7	24.7	12.7	28.7	41.4	315	28,391	Yes	-1.60	11.10	30
505865	BUCKEYE	UG	1	0	0	0	-	1.3	-	-	-	1.3	1.3	-	-	Yes	0.82	6.82	0
409964	PINEWOOD	UG	2,029	0	46	0	0.1	7.3	-	34.8	0.1	42.1	42.2	3,817	109,401	Yes	1.77	12.27	5
703031	ROHAN	Hybrid	1,405	25	12	0	3.1	0.5	6.1	1.9	9.2	2.4	11.6	322	58,565	Yes	-0.11	4.39	40
709164	GRIFFIN	UG	19	0	0	0	-	2.0	-	-	-	2.0	2.0	-	-	Yes	0.19	2.49	0

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
814133	BAUER	Hybrid	1,084	45	18	8	8.7	1.9	14.6	3.1	23.3	5.0	28.3	1,257	63,074	Yes	-0.03	4.87	35
102031	BULOW	Hybrid	1,610	2	32	2	2.8	4.8	0.6	33.2	3.4	38.0	41.4	170	27,409	Yes	0.00	6.10	11
306131	NASH	Hybrid	519	46	14	4	8.4	2.3	14.2	5.4	22.6	7.7	30.3	618	57,919	Yes	0.60	5.70	21
204066	DELTONA	Hybrid	1,896	43	0	3	3.6	1.4	17.8	0.8	21.4	2.2	23.6	132	13,181	Yes	0.00	0.00	8
404032	WESTWARD	Hybrid	1,820	32	14	7	3.5	0.3	8.2	2.7	11.7	3.0	14.7	698	144,051	Yes	-0.07	7.43	48
404737	HILLSBORO	Hybrid	768	6	5	5	1.7	0.2	4.0	1.6	5.7	1.8	7.5	125	20,535	Yes	-0.02	3.28	22
703835	HIGHLANDS	Hybrid	726	8	25	2	2.2	0.6	3.7	2.2	5.9	2.8	8.7	153	28,262	Yes	-0.42	9.38	22
802034	CUTLER	Hybrid	308	6	6	3	1.5	1.0	2.7	4.2	4.2	5.2	9.4	190	48,326	Yes	0.02	2.82	21
802239	GLADEVIEW	UG	1	0	0	0	-	3.9	-	-	-	3.9	3.9	-	-	Yes	0.44	1.94	0
703035	ROHAN	Hybrid	918	34	9	1	2.0	1.1	6.9	2.9	8.9	4.0	12.9	274	47,283	Yes	-0.16	4.84	46
705766	TRACE	UG	2,678	0	38	0	-	7.7	-	28.9	-	36.6	36.6	1,927	35,287	Yes	-0.92	12.98	7
700132	SISTRUNK	Hybrid	2,634	31	11	8	6.0	0.4	8.1	0.9	14.1	1.3	15.4	2,510	284,516	Yes	0.21	9.71	70
807235	MERCHANDISE	Hybrid	479	0	8	0	0.4	1.4	-	0.8	0.4	2.2	2.6	-	-	Yes	0.09	3.89	0
208161	HIELD	OH	1,689	31	1	0	4.0	0.1	21.7	0.2	25.7	0.3	26.0	1,786	96,330	Yes	0.27	6.87	46
802939	GRAPELAND	Hybrid	1,934	13	2	6	2.5	1.6	5.0	0.2	7.5	1.8	9.3	2,119	139,823	Yes	7.25	7.25	30
500135	SARASOTA	Hybrid	849	9	13	10	3.1	0.2	3.0	1.6	6.1	1.8	7.9	19	3,431	Yes	-2.52	3.88	6
705863	REMSBURG	Hybrid	1,659	0	30	1	0.9	6.1	2.1	16.5	3.0	22.6	25.6	19	5,424	Yes	-0.74	9.56	5
408161	ROSS	Hybrid	1,894	7	56	2	4.2	4.9	1.7	31.0	5.9	35.9	41.8	1,043	61,801	Yes	0.01	13.51	24
400534	BOYNTON	Hybrid	373	3	0	3	0.7	0.2	2.8	0.8	3.5	1.0	4.5	585	33,555	Yes	0.00	1.70	17
809035	AVENTURA	UG	67	0	11	0	-	5.8	-	1.7	-	7.5	7.5	19	9,271	Yes	0.18	6.38	3
205631	SARNO	Hybrid	847	36	20	6	5.9	1.1	12.0	15.3	17.9	16.4	34.3	898	18,484	Yes	-0.17	6.33	27
704768	STONEBRIDGE	UG	3,325	0	49	0	0.8	4.5	-	20.6	0.8	25.1	25.9	1,392	29,307	Yes	0.15	12.85	13
500663	CORTEZ	Hybrid	3,052	3	51	3	3.9	2.3	0.7	19.9	4.6	22.2	26.8	2,470	36,138	Yes	-0.44	11.96	12
200262	CELERY	Hybrid	1,250	23	13	9	7.0	2.6	22.8	10.4	29.8	13.0	42.8	829	70,452	Yes	0.31	3.91	43
812165	BEACON	UG	737	0	19	0	-	4.6	-	8.8	-	13.4	13.4	1,562	136,040	Yes	-2.16	6.24	7
805241	NATOMA	UG	29	0	5	0	-	1.5	-	0.2	-	1.7	1.7	-	-	Yes	1.16	4.66	0
505764	AUBURN	Hybrid	2,003	25	58	6	8.3	1.7	10.1	19.8	18.4	21.5	39.9	392	55,190	Yes	0.34	11.74	29
405338	BEELINE	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	0.04	2.74	0
404131	GOLF	Hybrid	1,790	9	40	2	4.0	0.1	3.5	15.2	7.5	15.3	22.8	600	71,655	Yes	-0.21	7.29	42
700731	FAIRMONT	Hybrid	1,041	12	1	2	1.3	0.4	5.9	0.3	7.2	0.7	7.9	660	101,273	Yes	-0.04	3.56	54
504832	SORRENTO	Hybrid	2,016	21	36	11	3.8	1.6	13.0	13.4	16.8	15.0	31.8	532	104,466	Yes	-0.11	7.89	44
701637	PLANTATION	Hybrid	1,310	9	11	4	4.0	0.2	5.0	2.8	9.0	3.0	12.0	1,064	105,769	Yes	-0.03	4.17	28
507761	RATTLESLAKE	Hybrid	3,291	2	50	3	4.8	3.5	6.0	33.6	10.8	37.1	47.9	3,751	125,119	Yes	1.23	12.73	18
804731	HAULOVER	UG	396	0	7	0	-	2.5	-	3.9	-	6.4	6.4	884	64,162	Yes	-0.42	6.28	11
505862	BUCKEYE	Hybrid	2,436	16	43	7	13.8	6.5	12.1	31.9	25.9	38.4	64.3	121	14,714	Yes	0.68	9.08	14
814043	BRICKELL	UG	129	1	5	0	-	2.4	-	0.4	-	2.8	2.8	-	-	Yes	0.95	4.95	0
306134	NASH	Hybrid	1,238	74	10	20	13.4	0.8	58.2	13.3	71.6	14.1	85.7	620	88,830	Yes	-0.19	5.71	67
503631	EDISON	Hybrid	1,448	25	14	6	2.8	0.6	9.9	7.7	12.7	8.3	21.0	2,117	101,231	Yes	-0.34	6.96	33
804442	VENETIAN	UG	2,364	0	13	0	0.2	5.4	-	1.6	0.2	7.0	7.2	224	36,752	Yes	-0.66	7.64	2
805235	NATOMA	Hybrid	956	17	17	2	2.5	1.5	1.7	1.1	4.2	2.6	6.8	1,135	59,145	Yes	-0.27	5.23	25
809839	DUMFOUNDLING	UG	821	0	3	0	-	1.6	-	0.4	-	2.0	2.0	-	-	Yes	0.32	4.92	0
702038	DRIFTWOOD	Hybrid	1,919	2	36	1	1.5	3.2	0.4	12.4	1.9	15.6	17.5	39	6,242	Yes	-0.40	7.80	7
803536	MARKET	UG	2	0	3	0	-	1.5	-	0.1	-	1.6	1.6	-	-	Yes	-2.86	2.24	0
508063	COOPER	Hybrid	2,729	36	42	11	16.9	2.6	28.7	13.8	45.6	16.4	62.0	2,981	138,787	Yes	-0.50	12.70	61
503133	SOLANA	Hybrid	1,644	15	31	3	3.1	2.5	3.0	8.8	6.1	11.3	17.4	34	16,578	Yes	-0.18	4.92	8
800836	RAILWAY	UG	5	0	2	0	-	1.9	-	-	-	1.9	1.9	-	-	Yes	-0.27	4.53	0
801937	DEAUVILLE	Hybrid	722	3	10	0	2.9	0.9	0.3	0.4	3.2	1.3	4.5	1,492	79,077	Yes	1.36	5.46	17
204365	SUNTREE	UG	3,046	1	60	0	1.4	8.2	-	35.4	1.4	43.6	45.0	89	11,376	Yes	0.78	13.78	6
402836	LANTANA	Hybrid	1,220	10	26	2	3.3	0.6	4.1	3.1	7.4	3.7	11.1	317	27,161	Yes	-0.21	4.79	22
100935	SOUTH DAYTONA	Hybrid	1,312	44	6	7	3.8	1.4	8.1	1.5	11.9	2.9	14.8	1,269	41,736	Yes	0.06	5.96	44
806436	HAINLIN	Hybrid	212	26	2	4	4.1	1.8	8.0	0.9	12.1	2.7	14.8	281	41,595	Yes	-0.06	1.54	32
403433	JENSEN	Hybrid	961	7	24	2	4.3	1.1	4.4	8.1	8.7	9.2	17.9	140	20,403	Yes	0.00	5.40	29

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
802837	ARCH CREEK	Hybrid	1,740	17	16	12	4.0	0.2	3.9	0.8	7.9	1.0	8.9	1,064	137,480	Yes	0.20	6.10	60
700138	SISTRUNK	Hybrid	934	5	13	6	1.0	1.4	0.6	1.2	1.6	2.6	4.2	26	2,552	Yes	0.78	5.28	3
805737	GALLOWAY	Hybrid	1,272	17	21	3	3.3	0.2	7.8	3.2	11.1	3.4	14.5	509	80,780	Yes	-0.18	8.12	45
804935	OJUS	UG	228	0	6	0	-	3.3	-	2.5	-	5.8	5.8	-	-	Yes	0.31	9.41	0
404533	NORTON	Hybrid	1,216	27	5	2	2.8	0.1	8.3	0.6	11.1	0.7	11.8	375	66,716	Yes	-0.11	7.09	48
306133	NASH	Hybrid	870	39	23	13	5.2	1.3	11.2	4.6	16.4	5.9	22.3	171	34,813	Yes	-0.19	7.71	30
501237	NAPLES	Hybrid	1,052	4	20	7	2.3	1.1	2.4	3.1	4.7	4.2	8.9	197	99,059	Yes	-0.70	5.10	14
105131	COMO	OH	645	32	0	3	5.3	-	18.6	0.5	23.9	0.5	24.4	816	114,827	Yes	-0.04	1.96	37
805936	COUNTRY CLUB	Hybrid	1,507	4	21	0	1.3	1.5	1.8	9.5	3.1	11.0	14.1	289	34,580	Yes	-0.50	6.50	17
811061	PALMETTO	Hybrid	4,010	0	47	0	2.0	0.8	0.3	15.8	2.3	16.6	18.9	1,237	80,923	Yes	0.49	14.09	9
201434	GRANDVIEW	Hybrid	1,973	23	28	5	5.5	0.1	7.2	3.9	12.7	4.0	16.7	217	49,032	Yes	0.13	6.63	41
703634	PALM AIRE	Hybrid	2,627	2	22	1	3.3	2.6	0.9	11.5	4.2	14.1	18.3	2,419	56,537	Yes	0.06	6.56	9
102962	EAGLE	Hybrid	1,620	24	22	5	9.7	1.7	15.9	17.5	25.6	19.2	44.8	652	83,888	Yes	-0.10	6.40	30
408863	HOMELAND	Hybrid	3,085	16	68	2	8.7	2.4	11.1	43.1	19.8	45.5	65.3	822	106,051	Yes	-0.73	14.67	47
406434	SAVANNAH	Hybrid	1,102	0	26	2	3.0	0.2	0.5	11.4	3.5	11.6	15.1	104	14,065	Yes	-2.90	3.70	19
806235	INDIAN CREEK	UG	1,224	0	11	0	-	2.9	-	0.5	-	3.4	3.4	1,086	26,243	Yes	-3.85	0.85	2
405637	FOUNTAIN	Hybrid	2,109	24	24	3	5.0	1.6	9.8	11.6	14.8	13.2	28.0	533	86,028	Yes	-0.02	8.28	48
701533	DANIA	Hybrid	1,782	18	18	5	3.8	1.4	4.2	3.4	8.0	4.8	12.8	113	16,003	Yes	-0.31	8.39	21
101463	FLAGLER BEACH	Hybrid	2,646	26	60	3	17.8	11.8	4.4	31.6	22.2	43.4	65.6	5,053	216,299	Yes	0.53	10.13	29
503568	ALLIGATOR	Hybrid	3,277	13	65	11	5.7	1.3	8.8	11.2	14.5	12.5	27.0	1,742	244,190	Yes	-1.36	11.14	45
206931	BARNA	Hybrid	1,310	9	41	2	5.2	0.9	3.1	11.2	8.3	12.1	20.4	533	29,836	Yes	-0.29	5.51	14
502833	PAYNE	Hybrid	547	2	12	5	1.0	0.8	0.7	1.4	1.7	2.2	3.9	633	10,763	Yes	-2.06	2.64	5
800842	RAILWAY	UG	2,695	0	12	0	-	4.5	-	1.7	-	6.2	6.2	4	1,039	Yes	0.69	8.09	4
106061	TOMOKA	Hybrid	1,705	18	39	12	4.4	1.0	9.5	17.6	13.9	18.6	32.5	3,402	167,454	Yes	0.24	12.24	39
402537	BELVEDERE	Hybrid	841	21	21	4	2.9	0.7	2.9	0.9	5.8	1.6	7.4	638	29,344	Yes	0.04	5.54	16
804141	GARDEN	Hybrid	825	2	23	1	2.5	2.4	0.8	5.0	3.3	7.4	10.7	102	12,335	Yes	0.00	6.10	21
812733	NATURAL BRIDGE	UG	1,176	0	4	1	-	4.7	0.1	0.6	0.1	5.3	5.4	730	50,515	Yes	-1.66	6.94	3
507161	POLO	UG	3,886	0	71	1	2.6	16.9	1.2	59.4	3.8	76.3	80.1	509	49,042	Yes	-1.54	15.56	18
706266	VALENCIA	Hybrid	1,789	20	50	8	7.5	4.7	12.4	37.3	19.9	42.0	61.9	2,088	150,964	Yes	1.49	16.59	40
500632	CORTEZ	Hybrid	2,896	8	49	2	3.7	-	4.2	16.5	7.9	16.5	24.4	2,447	24,495	Yes	-0.81	9.09	19
208633	TULSA	Hybrid	1,362	23	2	2	3.0	0.9	11.6	2.0	14.6	2.9	17.5	132	16,441	Yes	-0.07	6.13	20
401434	WHITE CITY	Hybrid	923	50	41	2	12.7	1.3	7.1	9.8	19.8	11.1	30.9	604	47,499	Yes	-0.27	6.13	21
207932	RINEHART	Hybrid	210	0	28	0	0.4	1.7	-	4.5	0.4	6.2	6.6	-	-	Yes	-0.36	5.84	0
706664	NOBHILL	UG	1,838	0	42	0	1.0	5.8	-	22.1	1.0	27.9	28.9	81	13,057	Yes	-0.05	11.75	11
102236	MADISON	Hybrid	1,130	22	17	4	2.6	1.0	9.7	3.6	12.3	4.6	16.9	578	83,823	Yes	2.44	6.74	56
707463	SAWGRASS	Hybrid	72	0	24	1	0.6	2.7	0.4	3.7	1.0	6.4	7.4	24	1,752	Yes	-0.18	4.32	2
208862	WINDOVER	Hybrid	1,566	0	17	2	0.9	3.3	0.3	17.9	1.2	21.2	22.4	138	15,715	Yes	-7.76	7.84	10
408762	SABAL	Hybrid	3,327	18	61	2	5.0	2.3	16.0	24.3	21.0	26.6	47.6	3,616	107,517	Yes	-0.32	15.78	35
502162	BONITA SPRINGS	Hybrid	3,050	8	59	2	4.2	1.9	2.8	28.1	7.0	30.0	37.0	1,321	88,255	Yes	-0.16	13.74	34
203431	MICCO	Hybrid	1,514	1	33	2	1.9	1.0	0.7	12.5	2.6	13.5	16.1	23	687	Yes	-0.20	4.50	4
202232	MIMS	Hybrid	1,532	27	10	6	4.7	0.4	24.8	2.2	29.5	2.6	32.1	3,844	157,168	Yes	0.00	5.10	48
414132	CANAL	Hybrid	1,753	2	28	3	2.9	0.4	0.8	9.8	3.7	10.2	13.9	653	11,663	Yes	-0.01	3.79	8
806142	DOUGLAS	Hybrid	122	1	8	1	0.1	2.5	0.2	0.3	0.3	2.8	3.1	78	30,810	Yes	0.02	4.02	1
406762	ACREAGE	Hybrid	2,351	86	7	0	9.8	0.4	40.0	3.0	49.8	3.4	53.2	2,017	113,866	Yes	0.00	12.20	65
809338	RONEY	UG	89	1	5	0	-	2.6	0.1	1.5	0.1	4.1	4.2	-	-	Yes	-0.21	5.39	0
804836	COUNTY LINE	Hybrid	2,091	26	12	4	3.9	0.5	8.6	2.9	12.5	3.4	15.9	2,269	162,217	Yes	0.00	7.00	69
407862	TARTAN	Hybrid	2,433	6	40	1	3.7	2.9	2.6	23.9	6.3	26.8	33.1	333	33,350	Yes	-0.23	11.17	19
420061	CORBETT	Hybrid	6	2	4	0	1.5	2.3	-	1.4	1.5	3.7	5.2	1	79	Yes	-0.40	3.60	1
406433	SAVANNAH	Hybrid	1,940	10	41	2	4.6	0.9	5.7	9.5	10.3	10.4	20.7	136	24,810	Yes	0.36	6.96	18
706535	TRAIN	Hybrid	788	8	3	0	1.2	0.3	3.9	0.5	5.1	0.8	5.9	222	26,740	Yes	-0.05	2.85	19
213361	GLENN	UG	7	0	8	0	-	1.8	-	0.7	-	2.5	2.5	-	-	Yes	0.01	0.41	0
401531	FT PIERCE	Hybrid	1,638	27	27	3	6.2	1.7	7.4	6.3	13.6	8.0	21.6	544	107,055	Yes	-0.01	4.69	33

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
506364	DEEPCREEK	Hybrid	2,461	26	31	5	11.9	0.9	21.6	22.8	33.5	23.7	57.2	377	27,999	Yes	-0.38	10.62	29
508363	TERRY	Hybrid	3,162	32	34	14	5.1	0.9	14.5	14.0	19.6	14.9	34.5	492	121,793	Yes	-0.28	12.12	45
503767	HARBOR	UG	26	0	1	0	-	3.3	-	0.1	-	3.4	3.4	-	-	Yes	0.35	4.15	0
501066	FRUITVILLE	Hybrid	1,702	20	34	7	5.5	2.5	11.7	24.2	17.2	26.7	43.9	86	13,477	Yes	-2.11	9.69	19
806836	RED ROAD	Hybrid	1,321	4	29	0	1.1	0.2	0.4	3.3	1.5	3.5	5.0	205	53,860	Yes	-0.14	5.46	13
509961	LAURELWOOD	Hybrid	2,130	12	83	3	15.6	8.0	6.1	45.1	21.7	53.1	74.8	103	15,653	Yes	0.77	11.17	14
706367	BASSCREEK	UG	1,648	0	39	0	0.9	5.9	-	20.0	0.9	25.9	26.8	2,886	62,112	Yes	-0.34	12.96	7
300964	MACCLENNY	Hybrid	1,116	27	18	5	10.9	0.3	17.6	4.7	28.5	5.0	33.5	150	25,476	Yes	-0.43	6.27	21
203933	MCDONNELL	Hybrid	789	22	24	10	8.1	0.1	6.7	3.9	14.8	4.0	18.8	1,056	27,844	Yes	0.22	4.12	20
803437	MIAMI SHORES	Hybrid	1,527	25	22	4	4.0	1.0	8.1	2.5	12.1	3.5	15.6	2,041	106,400	Yes	-0.17	5.63	47
800233	MIAMI BEACH	UG	938	0	8	0	-	3.4	-	0.8	-	4.2	4.2	565	70,735	Yes	0.24	4.34	9
504662	CASTLE	Hybrid	2,801	21	59	8	9.8	0.9	12.1	30.0	21.9	30.9	52.8	169	24,078	Yes	-0.66	15.44	28
106062	TOMOKA	Hybrid	926	44	4	12	11.3	0.3	30.8	4.5	42.1	4.8	46.9	399	53,543	Yes	-0.13	4.57	42
202533	AURORA	Hybrid	1,765	36	4	5	3.2	-	13.7	0.9	16.9	0.9	17.8	8,936	177,569	Yes	0.00	7.10	69
101635	HUDSON	Hybrid	126	13	14	4	5.5	0.2	2.7	2.2	8.2	2.4	10.6	3	483	Yes	-0.09	1.71	3
802537	GREYNOLDS	UG	1	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	1.05	4.25	0
807333	GOULDS	Hybrid	1,997	14	23	2	3.2	1.7	6.3	5.5	9.5	7.2	16.7	2,515	155,454	Yes	0.25	8.65	50
702239	MARGATE	Hybrid	826	0	12	0	0.8	0.9	-	5.9	0.8	6.8	7.6	15	2,304	Yes	0.00	3.20	4
702136	CYPRESS CREEK	Hybrid	245	0	23	1	1.7	1.5	0.2	2.8	1.9	4.3	6.2	5	620	Yes	0.41	4.91	1
502067	MURDOCK	Hybrid	2,359	51	15	5	7.6	0.1	35.5	2.7	43.1	2.8	45.9	1,641	197,667	Yes	-0.42	11.28	117
808270	LINDGREN	Hybrid	3,203	2	48	2	2.6	3.8	0.5	29.8	3.1	33.6	36.7	411	57,694	Yes	1.53	15.03	38
810834	BELL	Hybrid	775	14	7	3	2.2	1.5	3.3	1.0	5.5	2.5	8.0	218	36,856	Yes	0.06	3.86	18
804635	INDUSTRIAL	Hybrid	113	3	8	0	1.5	0.2	0.4	0.3	1.9	0.5	2.4	13	4,873	Yes	0.33	2.23	6
408262	COVE	Hybrid	2,811	30	22	11	5.3	0.9	17.4	14.0	22.7	14.9	37.6	291	34,756	Yes	-0.65	9.85	35
802238	GLADEVIEW	UG	1	0	0	0	-	2.7	-	-	-	2.7	2.7	-	-	Yes	0.07	0.87	0
401835	JUPITER	Hybrid	1,812	37	11	6	4.3	0.8	9.5	2.3	13.8	3.1	16.9	303	47,280	Yes	-0.35	7.05	41
802933	GRAPELAND	Hybrid	1,416	11	6	2	2.0	0.3	3.3	0.8	5.3	1.1	6.4	882	63,917	Yes	-4.33	5.07	11
207065	COX	UG	1	0	1	0	-	0.9	-	-	-	0.9	0.9	-	-	Yes	0.18	2.78	0
803537	MARKET	UG	158	0	4	0	-	2.9	-	0.3	-	3.2	3.2	-	-	Yes	0.02	5.62	0
202832	CLEARLAKE	Hybrid	2,010	40	6	3	3.9	0.4	14.4	0.6	18.3	1.0	19.3	2,557	116,151	Yes	-0.25	6.65	69
701034	SAMPLE ROAD	Hybrid	929	20	8	5	1.7	0.7	5.1	0.8	6.8	1.5	8.3	122	26,778	Yes	-0.07	5.03	21
813134	FIREHOUSE	UG	1,298	0	6	0	-	1.4	-	0.7	-	2.1	2.1	1	113	Yes	-0.05	4.25	1
200536	MELBOURNE	Hybrid	1,654	34	12	13	3.8	-	9.0	1.8	12.8	1.8	14.6	1,871	24,548	Yes	0.53	8.53	20
706465	HOLMBERG	Hybrid	1,185	6	29	5	3.1	1.9	11.5	27.2	14.6	29.1	43.7	1,038	160,380	Yes	-0.19	9.41	45
408667	HOMELAND	Hybrid	1,565	4	36	4	3.3	4.4	1.7	22.2	5.0	26.6	31.6	2,042	39,948	Yes	-1.06	10.34	16
806131	DOUGLAS	UG	169	0	4	1	-	2.5	-	0.3	-	2.8	2.8	185	55,676	Yes	0.09	5.89	7
200431	COCOA	Hybrid	793	17	11	5	2.1	0.2	5.2	1.2	7.3	1.4	8.7	213	37,088	Yes	-0.16	6.54	19
700141	SISTRUNK	Hybrid	2,261	14	7	1	4.4	0.4	9.0	1.3	13.4	1.7	15.1	1,059	193,669	Yes	-0.20	7.80	70
805331	KEY BISCAYNE	Hybrid	1,212	2	13	2	1.9	1.6	1.4	4.0	3.3	5.6	8.9	57	11,667	Yes	-0.45	4.35	6
405934	BUTTS	Hybrid	1,318	2	26	0	2.1	2.2	0.2	12.1	2.3	14.3	16.6	161	23,821	Yes	-0.95	5.65	15
408863	ABERDEEN	UG	3,141	0	59	0	1.5	6.7	-	32.7	1.5	39.4	40.9	2,359	188,654	Yes	-0.35	13.55	17
810365	NEWTON	Hybrid	2,751	0	41	1	1.4	7.6	0.8	30.7	2.2	38.3	40.5	1,922	43,525	Yes	-0.76	15.14	9
805133	LAWRENCE	Hybrid	3,176	16	16	3	3.3	0.2	2.1	0.5	5.4	0.7	6.1	220	24,177	Yes	-0.36	7.64	12
806534	SUNILAND	Hybrid	826	17	10	2	1.8	0.1	6.7	2.5	8.5	2.6	11.1	307	83,563	Yes	-0.23	5.27	48
703632	PALM AIRE	Hybrid	2,900	0	21	0	1.1	1.5	-	16.4	1.1	17.9	19.0	482	27,989	Yes	-0.23	7.27	19
408034	CALDWELL	Hybrid	1,480	14	16	2	3.1	0.1	5.7	0.7	8.8	0.8	9.6	1,472	136,661	Yes	0.05	5.65	47
701838	ROCK ISLAND	Hybrid	1,650	11	16	2	2.9	0.7	4.4	2.3	7.3	3.0	10.3	356	59,169	Yes	0.48	6.98	34
102731	INTERLACHEN	OH	603	40	3	5	5.5	-	27.2	0.8	32.7	0.8	33.5	1,039	86,287	Yes	-0.27	3.83	35
705631	COPANS	Hybrid	3,009	2	17	0	2.1	1.7	0.6	9.2	2.7	10.9	13.6	3,115	159,238	Yes	-0.19	5.71	12
200131	SANFORD	Hybrid	1,658	13	24	7	3.6	0.3	2.9	5.9	6.5	6.2	12.7	413	30,155	Yes	-0.95	5.25	15
413933	TULIP	Hybrid	532	1	20	2	1.9	0.3	1.0	6.7	2.9	7.0	9.9	124	33,389	Yes	0.02	2.32	12
408564	ALEXANDER	Hybrid	1,481	40	29	1	8.7	1.7	30.1	5.0	38.8	6.7	45.5	677	74,581	Yes	0.31	9.51	94

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
705565	SOUTHSIDE	UG	500	0	10	1	-	3.9	0.1	0.8	0.1	4.7	4.8	61	5,412	Yes	-0.21	6.39	2
406337	ROEBUCK	Hybrid	3,075	9	35	2	3.3	1.5	2.4	15.6	5.7	17.1	22.8	1,961	78,785	Yes	-0.38	7.32	24
702132	CYPRESS CREEK	Hybrid	328	0	18	2	1.9	0.6	0.2	2.3	2.1	2.9	5.0	9	372	Yes	-0.55	2.55	7
407461	INDRIO	Hybrid	2,416	70	9	2	4.5	1.5	23.4	6.0	27.9	7.5	35.4	2,933	98,655	Yes	-0.02	9.28	73
703534	DEERFIELD BEACH	Hybrid	2,304	9	20	0	2.4	1.0	1.5	6.2	3.9	7.2	11.1	442	70,857	Yes	-0.10	5.30	16
501436	ARCADIA	Hybrid	1	0	0	0	1.3	1.3	-	-	-	1.3	1.3	2.6	-	Yes	0.58	3.98	0
409434	SKYPASS	Hybrid	352	10	5	2	1.8	1.0	2.5	0.4	4.3	1.4	5.7	565	67,468	Yes	-0.09	3.01	11
701732	STIRLING	Hybrid	1,074	21	16	1	3.4	0.3	4.5	3.2	7.9	3.5	11.4	364	52,947	Yes	0.21	8.31	47
810564	JASMINE	Hybrid	2,997	0	31	0	2.0	3.9	-	18.5	2.0	22.4	24.4	64	16,595	Yes	-0.33	12.37	4
809232	MITCHELL	Hybrid	595	3	18	0	2.2	0.7	0.3	2.9	2.5	3.6	6.1	232	29,844	Yes	0.12	7.02	7
406766	ACREAGE	Hybrid	3,202	40	50	0	11.4	3.8	17.2	34.2	28.6	38.0	66.6	832	87,770	Yes	-0.18	16.62	48
501767	IONA	Hybrid	4,063	13	69	6	5.5	1.8	4.7	24.0	10.2	25.8	36.0	4,726	211,111	Yes	-0.36	9.84	32
507564	PARRISH	Hybrid	2,817	10	45	5	4.3	2.0	5.8	34.0	10.1	36.0	46.1	8,806	125,243	Yes	-0.24	10.96	26
704665	SPRINGTREE	Hybrid	4,067	3	67	1	4.4	0.7	0.6	24.9	5.0	25.6	30.6	2,457	98,562	Yes	-0.56	14.44	27
800735	HIALEAH	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.86	6.26	0
406235	OAKES	Hybrid	2,288	16	52	5	4.1	1.9	2.6	7.2	6.7	9.1	15.8	301	50,419	Yes	-0.04	6.46	19
204064	DELTONA	Hybrid	1,563	31	6	5	5.4	-	15.5	4.9	20.9	4.9	25.8	340	38,536	Yes	0.09	7.09	24
412762	HUMMINGBIRD	UG	4	0	0	0	-	5.8	-	-	-	5.8	5.8	7	10,080	Yes	0.21	0.81	1
406333	ROEBUCK	Hybrid	2,032	0	30	0	2.8	1.1	-	9.6	2.8	10.7	13.5	4	735	Yes	-0.22	5.68	4
811631	LUMMUS	UG	33	0	9	0	-	6.6	-	3.0	-	9.6	9.6	-	-	Yes	0.54	3.54	0
410161	PLAZA	Hybrid	2,421	28	7	2	6.3	0.1	20.3	3.0	26.6	3.1	29.7	560	42,856	Yes	-0.19	10.71	42
800437	COCONUT GROVE	Hybrid	692	13	3	0	1.5	0.4	1.3	0.2	2.8	0.6	3.4	590	50,954	Yes	-0.10	1.80	12
101531	GENERAL ELECTRIC	UG	1	0	0	0	-	2.1	-	-	-	2.1	2.1	-	-	Yes	-0.04	1.46	0
100933	SOUTH DAYTONA	Hybrid	1,417	11	19	2	2.1	0.2	2.0	4.3	4.1	4.5	8.6	98	19,113	Yes	-0.11	3.99	4
804538	GRATIGNY	Hybrid	1,356	1	20	1	1.3	0.9	0.4	3.4	1.7	4.3	6.0	593	44,709	Yes	-0.09	4.71	6
101466	FLAGLER BEACH	Hybrid	2,049	47	28	15	10.5	4.4	20.4	6.6	30.9	11.0	41.9	1,410	89,225	Yes	0.01	10.71	34
206934	BARNA	Hybrid	1,657	42	13	9	5.0	2.0	17.4	10.1	22.4	12.1	34.5	3,289	204,102	Yes	7.26	7.26	51
507464	CORKSCREW	Hybrid	17	3	14	0	6.5	2.2	1.1	0.8	7.6	3.0	10.6	23	289	Yes	0.42	7.72	3
708434	BUTTERFLY	Hybrid	1,034	12	24	2	3.6	1.3	3.2	8.2	6.8	9.5	16.3	101	23,305	Yes	-0.14	6.86	12
810265	INTERNATIONAL	Hybrid	4,670	5	49	6	3.1	1.0	3.4	7.2	6.5	8.2	14.7	5,222	350,405	Yes	0.06	12.96	42
507861	IXORA	UG	6	0	7	0	-	0.8	-	0.2	-	1.0	1.0	-	-	Yes	-0.10	3.90	0
405336	BEELINE	Hybrid	1,748	7	32	3	3.1	1.7	4.7	8.4	7.8	10.1	17.9	206	30,645	Yes	-0.12	8.68	19
805434	DADE	Hybrid	615	3	29	3	2.9	0.2	0.5	2.1	3.4	2.3	5.7	653	23,901	Yes	0.22	6.72	9
200538	MELBOURNE	Hybrid	588	14	4	0	2.5	0.6	3.5	2.0	6.0	2.6	8.6	153	24,321	Yes	-0.16	2.44	10
101134	ORMOND	Hybrid	799	11	20	1	3.6	1.0	3.1	5.6	6.7	6.6	13.3	438	58,987	Yes	-2.60	3.90	53
410861	SOUTHFORK	Hybrid	3,111	56	38	13	12.9	1.4	27.6	25.8	40.5	27.2	67.7	1,257	78,234	Yes	0.28	12.68	53
203432	MICCO	Hybrid	1,883	6	17	3	1.7	-	10.0	10.7	11.7	10.7	22.4	587	100,296	Yes	-0.15	5.95	7
700636	VERENA	Hybrid	1,788	17	9	8	3.3	1.5	7.0	2.2	10.3	3.7	14.0	5,611	317,901	Yes	0.24	7.84	31
503565	ALLIGATOR	Hybrid	1,949	0	31	1	2.0	0.2	1.4	15.7	3.4	15.9	19.3	1,091	270,320	Yes	-0.22	4.68	21
813237	KNOWLTON	UG	480	0	0	0	-	2.4	-	-	-	2.4	2.4	1	234	Yes	1.49	3.99	1
407035	RIO	Hybrid	1,483	36	29	8	3.6	1.5	7.2	3.1	10.8	4.6	15.4	236	13,432	Yes	-0.10	6.50	15
500436	HYDE PARK	Hybrid	1,360	24	13	14	3.2	0.4	9.4	3.5	12.6	3.9	16.5	1,005	109,599	Yes	-0.21	6.99	39
408761	SABAL	Hybrid	2,904	12	26	1	5.4	1.1	18.2	11.5	23.6	12.6	36.2	3,592	82,905	Yes	0.39	10.89	23
106663	COQUINA	Hybrid	998	7	18	0	1.4	3.7	3.7	12.5	5.1	16.2	21.3	609	40,832	Yes	-0.07	4.43	12
500332	VENICE	Hybrid	2,097	19	15	13	4.4	0.4	10.6	3.4	15.0	3.8	18.8	1,298	80,742	Yes	-0.16	6.74	36
509063	SUMMIT	Hybrid	4,321	7	72	3	5.4	5.2	2.5	38.8	7.9	44.0	51.9	640	90,835	Yes	0.22	17.32	20
806334	ULETA	Hybrid	1,672	32	5	2	3.7	0.2	10.0	1.5	13.7	1.7	15.4	3,455	293,564	Yes	0.05	6.85	115
405761	SEBASTIAN	Hybrid	2,547	74	25	9	8.5	2.8	27.9	13.1	36.4	15.9	52.3	645	109,235	Yes	-0.29	9.31	61
705535	SOUTHSIDE	UG	344	0	5	0	-	2.4	-	0.5	-	2.9	2.9	2	278	Yes	-1.90	2.10	2
806432	HAINLIN	Hybrid	548	46	7	2	6.8	0.1	14.0	1.9	20.8	2.0	22.8	1,171	26,251	Yes	-0.16	4.54	30
806531	SUNILAND	OH	813	29	7	1	2.9	0.1	11.6	0.3	14.5	0.4	14.9	1,139	106,967	Yes	-0.26	5.74	45
805033	UNIVERSITY	Hybrid	1,190	12	13	3	3.4	1.7	3.9	11.0	7.3	12.7	20.0	220	71,739	Yes	0.76	8.76	37

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
401836	JUPITER	Hybrid	217	2	3	0	0.5	-	0.3	1.2	0.8	1.2	2.0	31	974	Yes	-0.01	0.99	4
808434	SNAKE CREEK	Hybrid	1,468	10	13	4	2.4	1.0	6.0	4.0	8.4	5.0	13.4	531	110,843	Yes	-0.02	4.98	41
806036	GOLDEN GLADES	Hybrid	146	0	22	0	1.8	0.7	-	1.2	1.8	1.9	3.7	149	24,158	Yes	0.06	5.66	3
801737	62ND AVE	Hybrid	1,729	26	9	3	3.6	0.2	7.4	0.7	11.0	0.9	11.9	853	84,390	Yes	-0.31	7.59	43
504065	CAPRI	Hybrid	3,657	0	42	3	2.7	2.8	3.5	5.6	6.2	8.4	14.6	245	51,728	Yes	2.44	10.34	13
800531	RIVERSIDE	Hybrid	1,150	9	11	0	1.3	0.5	1.0	0.7	2.3	1.2	3.5	362	59,171	Yes	0.51	4.41	18
201234	TROPICANA	Hybrid	1,906	17	14	7	2.8	0.4	3.2	1.4	6.0	1.8	7.8	1,869	111,987	Yes	-0.51	4.09	22
101137	ORMOND	Hybrid	1,929	37	11	6	4.5	1.3	8.7	5.1	13.2	6.4	19.6	1,131	120,929	Yes	-1.60	7.20	58
402031	CLEWISTON	OH	122	22	5	0	58.1	0.1	16.7	0.2	74.8	0.3	75.1	745	135,002	Yes	0.01	0.91	40
803439	MIAMI SHORES	Hybrid	1,737	37	4	3	2.4	1.0	10.1	0.4	12.5	1.4	13.9	2,274	140,282	Yes	-0.10	7.20	80
500634	CORTEZ	Hybrid	1,485	1	28	6	2.5	0.9	1.4	10.7	3.9	11.6	15.5	315	36,540	Yes	-0.38	6.72	13
405631	FOUNTAIN	Hybrid	2,638	8	44	1	4.6	1.3	1.2	15.0	5.8	16.3	22.1	1,345	88,261	Yes	-0.13	8.37	8
506035	WALKER	Hybrid	1,341	13	9	3	3.2	0.2	5.5	5.1	8.7	5.3	14.0	274	28,854	Yes	-0.21	5.39	33
701434	PORT	Hybrid	69	0	13	2	1.6	3.9	0.2	2.1	1.8	6.0	7.8	77	1,232	Yes	1.42	3.22	1
701731	STIRLING	Hybrid	421	9	4	1	1.3	0.6	2.9	0.4	4.2	1.0	5.2	81	12,529	Yes	0.00	3.60	9
800843	RAILWAY	UG	94	2	9	0	-	5.1	0.1	0.7	0.1	5.8	5.9	19	1,406	Yes	1.69	3.89	5
205936	SYLVAN	Hybrid	724	2	11	0	0.7	2.8	0.2	3.4	0.9	6.2	7.1	677	37,229	Yes	-0.33	2.87	7
803136	FLORIDA CITY	Hybrid	906	5	17	2	1.7	5.7	1.5	6.8	3.2	12.5	15.7	243	30,500	Yes	0.36	5.06	9
414332	COBIA	Hybrid	1,131	13	15	5	1.9	0.3	4.6	2.0	6.5	2.3	8.8	1,329	72,996	Yes	3.01	3.01	22
814432	BANYAN	Hybrid	1,084	33	2	2	2.1	0.9	6.2	0.2	8.3	1.1	9.4	239	56,246	Yes	-0.20	7.40	42
207936	RINEHART	Hybrid	857	2	12	1	0.7	1.1	1.0	3.5	1.7	4.6	6.3	975	52,839	Yes	-0.02	3.88	11
510931	ITALY	Hybrid	1,793	8	50	11	2.8	1.0	5.1	5.3	7.9	6.3	14.2	351	70,513	Yes	8.35	8.35	32
101138	ORMOND	Hybrid	1,298	21	13	4	5.8	1.2	5.1	4.2	10.9	5.4	16.3	1,621	239,537	Yes	-0.18	5.72	33
804633	INDUSTRIAL	Hybrid	134	7	13	2	2.5	0.2	0.7	0.5	3.2	0.7	3.9	12	3,665	Yes	-0.06	4.54	7
401032	GREENACRES	Hybrid	2,498	32	32	3	4.0	-	8.8	5.0	12.8	5.0	17.8	5,457	97,916	Yes	-0.02	8.58	48
803937	SUNNY ISLES	UG	2,184	0	7	0	-	3.4	-	2.1	-	5.5	5.5	-	-	Yes	-0.19	5.01	0
413538	VIOLET	Hybrid	793	21	25	2	2.7	0.2	5.2	4.2	7.9	4.4	12.3	956	51,909	Yes	-0.09	6.21	23
806738	IVES	Hybrid	3,281	0	35	3	0.8	2.4	0.2	11.9	1.0	14.3	15.3	3,320	12,973	Yes	0.68	7.38	12
506762	VANDERBILT	Hybrid	1,857	2	35	6	3.3	0.5	3.0	13.9	6.3	14.4	20.7	1,032	127,803	Yes	-0.05	11.25	24
413633	BONANZA	Hybrid	189	1	13	4	1.3	0.1	1.3	3.0	2.6	3.1	5.7	33	2,766	Yes	-0.02	1.18	6
413736	RUNWAY	Hybrid	1,145	3	18	5	2.4	0.8	8.8	6.6	11.2	7.4	18.6	2,686	67,612	Yes	-0.14	6.16	40
807437	VILLAGE GREEN	UG	-	0	2	0	-	0.3	-	-	-	0.3	0.3	-	-	Yes	0.16	1.16	0
803636	SEABOARD	Hybrid	1,042	10	6	1	1.9	0.3	1.4	0.4	3.3	0.7	4.0	1,177	44,678	Yes	-0.52	5.38	18
205937	SYLVAN	Hybrid	826	20	23	3	2.7	2.4	10.6	11.0	13.3	13.4	26.7	248	29,873	Yes	-0.88	4.42	21
800248	MIAMI BEACH	Hybrid	868	4	14	2	0.7	3.8	3.5	4.8	4.2	8.6	12.8	3,901	421,920	Yes	0.43	7.03	51
806338	ULETA	Hybrid	555	8	4	2	1.8	1.3	2.4	0.3	4.2	1.6	5.8	202	34,447	Yes	-0.13	4.57	26
405263	ACME	Hybrid	3,130	2	64	0	6.1	0.3	1.1	30.4	7.2	30.7	37.9	3,621	62,672	Yes	-0.49	12.51	46
804239	PERRINE	Hybrid	1,912	18	18	3	3.2	1.4	8.9	7.9	12.1	9.3	21.4	2,821	232,130	Yes	-0.04	8.66	66
406166	TURNPIKE	Hybrid	2,483	17	46	1	7.3	0.3	16.1	13.9	23.4	14.2	37.6	337	41,355	Yes	-0.13	10.87	46
406431	SAVANNAH	Hybrid	1,887	6	25	3	3.6	0.9	1.4	17.3	5.0	18.2	23.2	222	35,343	Yes	-0.41	6.59	14
706063	HIATUS	Hybrid	1,358	5	46	1	2.9	3.8	1.6	14.0	4.5	17.8	22.3	181	34,545	Yes	-0.52	11.38	11
209865	YORKE	UG	2,525	0	25	0	0.3	4.8	-	22.5	0.3	27.3	27.6	1,594	27,694	Yes	7.78	8.18	3
503569	ALLIGATOR	Hybrid	2,697	3	48	1	5.3	0.3	1.4	17.5	6.7	17.8	24.5	324	52,405	Yes	-0.26	6.24	13
705633	COPANS	Hybrid	1,622	1	18	0	1.0	0.9	0.1	12.1	1.1	13.0	14.1	731	35,886	Yes	-0.25	5.35	8
703438	RESERVATION	UG	3	0	2	0	-	2.2	-	-	-	2.2	2.2	-	-	Yes	-0.10	2.10	0
300431	LAKE BUTLER	OH	1,015	69	8	10	12.3	-	36.6	2.3	48.9	2.3	51.2	280	41,458	Yes	-0.62	7.38	43
805232	NATOMA	Hybrid	1,789	31	3	2	2.7	0.4	6.3	0.4	9.0	0.8	9.8	382	42,850	Yes	-0.34	7.56	34
706461	HOLMBERG	Hybrid	946	0	13	0	0.6	2.3	-	8.5	0.6	10.8	11.4	94	17,997	Yes	0.47	5.17	4
407162	CRANE	Hybrid	1,019	15	19	11	8.4	3.0	37.4	13.5	45.8	16.5	62.3	760	134,411	Yes	0.60	7.60	55
507062	IMPERIAL	Hybrid	3,988	24	43	2	4.4	3.7	14.2	31.3	18.6	35.0	53.6	834	108,850	Yes	-0.63	12.97	40
100134	DAYTONA BEACH	Hybrid	533	8	4	1	1.0	2.8	1.5	1.1	2.5	3.9	6.4	639	17,275	Yes	-0.09	2.71	15
108362	GATOR	Hybrid	1,877	92	35	16	16.4	3.7	44.1	25.2	60.5	28.9	89.4	2,748	96,906	Yes	1.76	9.56	51

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
402631	JUNO BEACH	Hybrid	1,058	1	13	0	0.4	1.8	0.1	3.3	0.5	5.1	5.6	42	4,698	Yes	-0.19	3.01	3
703961	WESTINGHOUSE	UG	1,637	0	27	0	-	2.8	-	22.5	-	25.3	25.3	98	18,347	Yes	-0.61	8.49	4
704571	MALLARD	Hybrid	2,638	1	28	0	2.3	1.2	-	10.6	2.3	11.8	14.1	589	98,452	Yes	0.41	6.81	19
401832	JUPITER	Hybrid	1,728	23	20	7	5.1	0.7	4.3	5.8	9.4	6.5	15.9	1,504	32,620	Yes	-0.09	6.51	31
800438	COCONUT GROVE	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.00	2.40	0
700333	PINEHURST	Hybrid	2,036	21	29	2	4.3	0.7	3.9	2.3	8.2	3.0	11.2	2,380	61,071	Yes	0.17	7.97	40
809134	TAMIAMI	Hybrid	872	17	6	1	2.2	0.2	2.7	0.4	4.9	0.6	5.5	267	48,128	Yes	-0.11	5.09	23
704664	SPRINGTREE	Hybrid	2,363	3	33	3	4.0	0.6	1.2	17.3	5.2	17.9	23.1	1,655	149,994	Yes	-0.43	10.87	36
808732	BOULEVARD	Hybrid	895	4	9	2	1.5	1.0	1.3	1.0	2.8	2.0	4.8	1,942	70,675	Yes	-1.02	3.28	24
500131	SARASOTA	Hybrid	1,709	30	19	5	5.3	0.3	10.6	3.1	15.9	3.4	19.3	5,629	180,149	Yes	-0.78	7.92	33
108961	DURBIN	Hybrid	1,500	6	19	1	2.4	3.2	2.7	18.6	5.1	21.8	26.9	940	66,801	Yes	-2.48	6.32	9
806143	DOUGLAS	Hybrid	626	7	7	5	1.1	1.0	1.0	0.8	2.1	1.8	3.9	640	11,560	Yes	0.07	7.07	9
706667	NOHILL	Hybrid	2,291	1	30	0	1.2	2.2	0.1	10.0	1.3	12.2	13.5	205	22,622	Yes	6.60	6.60	4
806139	DOUGLAS	UG	378	0	9	0	0.1	2.1	-	0.3	0.1	2.4	2.5	87	3,693	Yes	1.38	5.58	3
807236	MERCHANDISE	UG	34	0	14	0	-	3.3	-	2.3	-	5.6	5.6	-	-	Yes	0.28	5.08	0
405933	BUTTS	Hybrid	1,030	0	14	0	1.3	0.2	-	3.4	1.3	3.6	4.9	101	6,836	Yes	0.00	2.60	5
207064	COX	Hybrid	1,386	80	20	5	6.9	0.4	24.3	7.4	31.2	7.8	39.0	2,238	80,745	Yes	-0.53	6.87	50
105763	RIVERTON	Hybrid	1,560	100	28	22	13.6	4.3	38.2	14.9	51.8	19.2	71.0	1,821	217,688	Yes	-0.56	5.74	71
707664	CROSSBOW	UG	1,924	2	51	1	0.7	7.5	0.3	17.9	1.0	25.4	26.4	9	3,629	Yes	-0.67	13.63	5
811432	WATKINS	Hybrid	367	10	20	0	4.0	3.1	1.5	3.0	5.5	6.1	11.6	88	28,983	Yes	1.02	7.42	6
203638	HARRIS	Hybrid	814	26	10	6	3.8	0.9	6.8	0.8	10.6	1.7	12.3	239	36,307	Yes	-0.19	3.41	22
701934	HOLY CROSS	Hybrid	843	10	6	2	1.9	0.6	4.7	0.4	6.6	1.0	7.6	407	90,396	Yes	-0.07	7.73	25
400238	DATURA ST	UG	5	0	0	1	-	0.7	-	0.2	-	0.9	0.9	-	-	Yes	-0.07	2.33	0
201834	MINUTEMAN	Hybrid	1,020	11	3	5	1.5	0.4	6.0	1.5	7.5	1.9	9.4	379	60,423	Yes	-1.61	4.69	25
709362	ORCHID	Hybrid	2,153	7	26	5	2.7	6.9	4.3	3.5	7.0	10.4	17.4	3,748	178,197	Yes	1.15	10.15	26
504134	BENEVA	Hybrid	2,003	14	25	9	3.7	0.6	9.5	9.2	13.2	9.8	23.0	1,545	102,265	Yes	0.02	7.82	43
402638	JUNO BEACH	Hybrid	1,772	30	22	4	4.1	0.7	11.5	3.6	15.6	4.3	19.9	255	41,728	Yes	-0.44	8.36	37
800448	COCONUT GROVE	Hybrid	1,087	16	7	1	2.3	2.0	3.3	0.5	5.6	2.5	8.1	2,440	188,101	Yes	-0.06	4.64	20
809840	DUMFOUNDLING	UG	1,203	0	4	0	-	2.7	-	1.4	-	4.1	4.1	935	50,023	Yes	-0.15	2.45	5
105832	ELKTON	Hybrid	1,221	90	12	19	19.2	-	71.3	9.0	90.5	9.0	99.5	910	69,442	Yes	-0.19	4.11	86
101135	ORMOND	Hybrid	1,220	1	21	2	1.8	0.6	1.5	12.4	3.3	13.0	16.3	259	57,874	Yes	-0.02	4.78	22
808267	LINDGREN	Hybrid	2,671	0	27	0	2.0	3.4	-	18.1	2.0	21.5	23.5	163	29,339	Yes	-1.38	10.62	16
811161	SPOONBILL	Hybrid	2,672	8	42	1	2.8	6.0	4.1	26.3	6.9	34.3	41.2	373	96,639	Yes	-0.48	15.72	41
700834	BEVERLY	Hybrid	1,348	19	4	9	2.6	0.1	6.5	1.2	9.1	1.3	10.4	2,105	69,176	Yes	0.17	5.17	43
806732	IVES	Hybrid	2,285	6	23	0	1.5	1.2	0.5	8.9	2.0	10.1	12.1	179	25,080	Yes	-0.14	6.86	17
808063	FLAGAMI	UG	4,455	0	27	0	-	4.2	-	14.0	-	18.2	18.2	99	20,143	Yes	-1.79	11.81	6
509962	LAURELWOOD	Hybrid	2,451	28	43	6	14.3	6.1	21.0	31.9	35.3	38.0	73.3	272	47,506	Yes	0.68	8.08	36
402135	TERMINAL	Hybrid	1,258	17	17	1	2.2	0.5	1.7	2.4	3.9	2.9	6.8	54	7,531	Yes	-0.08	3.22	11
505061	JETPORT	Hybrid	812	2	32	1	3.0	4.0	1.0	11.6	4.0	15.6	19.6	127	12,641	Yes	-8.94	8.66	6
405864	DELTRAIL	Hybrid	2,721	2	45	0	5.5	5.7	0.8	29.8	6.3	35.5	41.8	949	93,709	Yes	0.57	14.07	14
508533	HANSON	Hybrid	1	0	0	0	0.8	1.0	-	-	0.8	1.0	1.8	-	-	Yes	-0.03	4.57	0
806032	GOLDEN GLADES	Hybrid	424	5	20	0	2.3	0.1	1.6	1.2	3.9	1.3	5.2	275	80,392	Yes	-0.04	5.56	27
700234	HOLLYWOOD	Hybrid	1,472	13	9	6	1.4	1.9	4.5	0.7	5.9	2.6	8.5	503	106,705	Yes	-0.33	6.77	43
406761	ACREAGE	Hybrid	1,671	22	29	2	8.0	3.9	28.6	20.7	36.6	24.6	61.2	2,363	46,203	Yes	-0.12	10.18	42
412361	WATTS	Hybrid	1,802	40	13	1	5.4	1.8	26.4	11.6	31.8	13.4	45.2	1,222	90,593	Yes	0.17	10.27	53
307764	ONEIL	Hybrid	3,625	18	71	7	7.2	13.3	8.8	51.6	16.0	64.9	80.9	936	69,137	Yes	-0.33	15.37	28
811265	EUREKA	Hybrid	1,509	16	29	3	3.4	1.6	7.3	13.4	10.7	15.0	25.7	287	65,715	Yes	-0.35	8.65	43
701141	LYONS	Hybrid	1,358	17	4	0	2.7	0.8	7.6	0.2	10.3	1.0	11.3	1,245	101,506	Yes	2.88	6.58	40
704067	MOTOROLA	Hybrid	1,646	22	25	3	3.3	0.3	6.1	2.2	9.4	2.5	11.9	1,029	238,082	Yes	0.32	6.52	40
703640	PALM AIRE	Hybrid	1,765	2	27	2	2.2	0.6	0.7	10.0	2.9	10.6	13.5	277	54,288	Yes	0.06	6.36	19
802432	SOUTH MIAMI	Hybrid	623	8	11	1	1.6	0.6	2.1	1.1	3.7	1.7	5.4	193	38,406	Yes	1.17	8.17	13
704465	FASHION	Hybrid	1,779	18	9	3	1.9	2.0	5.8	2.1	7.7	4.1	11.8	2,410	176,583	Yes	-0.20	5.10	25

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
505062	JETPORT	Hybrid	444	0	36	1	3.9	12.5	1.3	22.3	5.2	34.8	40.0	89	21,825	Yes	1.38	8.78	8
800434	COCONUT GROVE	Hybrid	994	3	11	0	0.6	2.3	0.2	0.7	0.8	3.0	3.8	740	18,581	Yes	0.15	4.25	3
409961	PINEWOOD	Hybrid	1,579	11	35	2	6.1	5.0	4.6	25.8	10.7	30.8	41.5	47	5,442	Yes	0.16	12.06	17
409962	PINEWOOD	Hybrid	1,867	2	38	2	4.4	1.0	0.6	19.2	5.0	20.2	25.2	1,467	36,650	Yes	0.25	10.95	12
800636	LITTLE RIVER	Hybrid	1,354	16	9	5	2.5	0.4	3.2	0.4	5.7	0.8	6.5	325	40,766	Yes	0.39	4.89	36
411231	MORAY	UG	613	0	14	0	-	4.9	-	12.1	-	17.0	17.0	29	5,174	Yes	-0.46	5.24	6
804138	GARDEN	Hybrid	743	5	23	3	3.5	0.2	1.9	7.0	5.4	7.2	12.6	103	25,868	Yes	-0.58	7.22	18
501238	NAPLES	Hybrid	871	8	29	4	2.6	3.1	6.0	3.9	8.6	7.0	15.6	343	59,424	Yes	-0.43	6.57	40
408961	PLUMOSUS	Hybrid	1,310	2	41	2	3.4	0.8	0.6	15.3	4.0	16.1	20.1	167	13,613	Yes	-0.25	10.85	16
412161	ALLAPATTAH	Hybrid	1,617	21	35	6	16.1	4.1	19.2	23.0	35.3	27.1	62.4	1,387	42,660	Yes	0.67	7.87	24
810433	BLUE LAGOON	Hybrid	1,480	18	7	2	1.7	0.3	5.0	0.3	6.7	0.6	7.3	723	80,005	Yes	0.11	5.41	27
700733	FAIRMONT	OH	1,188	14	7	2	2.6	-	8.8	0.6	11.4	0.6	12.0	482	59,354	Yes	-0.18	4.82	44
107631	TOLOMATO	Hybrid	1,702	21	20	4	3.9	3.1	15.5	20.2	19.4	23.3	42.7	582	123,618	Yes	-2.84	5.36	33
810561	JASMINE	Hybrid	3,065	2	40	0	1.8	6.2	0.1	26.6	1.9	32.8	34.7	102	12,016	Yes	0.21	13.91	6
101866	ORANGEDALE	Hybrid	2,032	0	34	0	2.5	7.5	-	30.1	2.5	37.6	40.1	1,357	14,504	Yes	0.31	9.31	4
809835	DUMFOUNDLING	UG	1,864	0	10	0	-	2.5	-	3.7	-	6.2	6.2	9	2,395	Yes	0.00	6.20	1
811264	EUREKA	Hybrid	2,236	2	36	1	2.5	1.6	0.6	20.3	3.1	21.9	25.0	311	55,275	Yes	-0.23	10.47	17
202031	INDIAN HARBOR	Hybrid	1,498	15	25	4	2.8	0.1	6.2	4.3	9.0	4.4	13.4	1,212	71,754	Yes	-0.39	5.51	42
809766	SWEETWATER	Hybrid	3,406	0	37	0	1.9	2.9	-	21.2	1.9	24.1	26.0	910	154,814	Yes	0.00	12.90	23
501833	TICE	Hybrid	2,106	102	15	18	11.7	-	66.3	14.4	78.0	14.4	92.4	810	123,840	Yes	-0.20	9.60	63
403238	ATLANTIC	Hybrid	5	0	0	0	0.4	1.0	-	-	0.4	1.0	1.4	1	178	Yes	0.71	1.41	1
502835	PAYNE	Hybrid	1,391	15	20	5	1.9	2.7	2.2	2.2	4.1	4.9	9.0	919	78,995	Yes	-0.13	5.67	14
403931	LAKE PARK	Hybrid	1,518	8	19	2	2.8	0.1	3.3	1.7	6.1	1.8	7.9	543	98,795	Yes	-0.33	7.77	53
707261	FLAMINGO	Hybrid	2,514	0	28	1	2.6	2.7	0.4	20.1	3.0	22.8	25.8	915	57,494	Yes	-0.95	9.85	22
809436	SAGA	UG	-	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	0.11	2.61	0
506362	DEEPCREEK	OH	2,434	45	0	4	4.7	0.1	28.4	0.9	33.1	1.0	34.1	432	68,869	Yes	0.11	10.81	50
703733	CRYSTAL	Hybrid	2,074	1	45	1	2.8	1.3	0.2	7.5	3.0	8.8	11.8	413	76,789	Yes	-0.04	5.66	20
814041	BRICKELL	UG	1,657	0	8	1	-	3.6	-	1.5	-	5.1	5.1	76	27,436	Yes	-0.39	2.91	1
811066	PALMETTO	Hybrid	3,853	0	60	2	2.5	0.4	0.6	18.3	3.1	18.7	21.8	587	83,672	Yes	-0.52	13.18	22
810861	MONTGOMERY	Hybrid	2,199	0	33	0	1.8	4.7	-	18.0	1.8	22.7	24.5	181	18,658	Yes	0.01	10.81	15
701136	LYONS	Hybrid	1,328	2	20	2	0.7	2.7	1.5	3.8	2.2	6.5	8.7	305	58,078	Yes	0.20	5.40	9
813236	KNOWLTON	UG	19	0	6	1	-	2.3	-	0.3	-	2.6	2.6	1,933	40,406	Yes	0.06	3.76	2
406866	KIMBERLY	Hybrid	3,569	0	49	0	2.9	2.7	0.1	22.7	3.0	25.4	28.4	343	63,991	Yes	-0.49	7.01	25
409965	PINEWOOD	Hybrid	3,678	20	80	1	8.8	6.0	5.2	29.4	14.0	35.4	49.4	1,456	62,584	Yes	13.31	13.31	26
801939	DEAUVILLE	Hybrid	1,741	1	16	2	1.3	5.4	0.8	2.9	2.1	8.3	10.4	189	37,110	Yes	0.29	5.79	9
408965	PLUMOSUS	Hybrid	850	3	28	0	2.6	1.8	0.4	10.6	3.0	12.4	15.4	951	9,588	Yes	-0.07	4.73	10
501834	TICE	UG	-	0	1	0	-	-	-	-	-	-	-	-	-	Yes	0.07	0.17	0
706166	HOLLYBROOK	Hybrid	1,545	0	37	0	2.5	2.2	0.1	7.5	2.6	9.7	12.3	787	47,412	Yes	-1.24	11.36	5
800535	RIVERSIDE	Hybrid	1,746	31	11	2	3.1	0.3	4.8	0.4	7.9	0.7	8.6	167	48,016	Yes	-0.72	6.78	28
200831	LAUREL	Hybrid	1,139	22	16	4	3.0	0.7	7.4	3.9	10.4	4.6	15.0	996	104,083	Yes	-0.98	5.92	26
805336	KEY BISCAYNE	Hybrid	1,515	0	17	0	0.8	3.8	-	1.2	0.8	5.0	5.8	620	50,139	Yes	-1.27	5.03	5
404531	NORTON	Hybrid	1,740	35	5	9	3.9	0.1	8.0	1.8	11.9	1.9	13.8	244	45,232	Yes	-0.21	7.19	46
504831	SORRENTO	Hybrid	2,197	36	26	15	5.1	0.7	11.4	8.0	16.5	8.7	25.2	656	44,337	Yes	-0.30	6.90	37
502531	PALMA SOLA	Hybrid	392	3	12	1	1.3	0.1	1.1	4.2	2.4	4.3	6.7	24	2,808	Yes	-0.61	3.09	4
507061	IMPERIAL	Hybrid	2,683	3	43	2	3.3	0.8	0.8	20.3	4.1	21.1	25.2	1,155	79,565	Yes	-0.16	7.44	17
707534	COLLINS	Hybrid	1,596	13	15	10	2.7	1.4	6.2	6.4	8.9	7.8	16.7	4,462	155,623	Yes	-0.13	7.07	50
204133	SATELLITE	Hybrid	1,710	10	29	6	2.2	3.5	4.9	8.8	7.1	12.3	19.4	1,214	115,063	Yes	-0.43	6.57	46
705536	SOUTHSIDE	UG	471	0	2	0	-	1.7	-	-	-	1.7	1.7	-	-	Yes	0.11	1.01	0
804331	KENDALL	Hybrid	789	18	21	2	2.8	0.1	4.7	3.0	7.5	3.1	10.6	414	38,075	Yes	-0.18	5.52	31
813234	KNOWLTON	UG	424	0	5	0	-	4.3	-	0.9	-	5.2	5.2	-	-	Yes	-1.02	8.58	0
810263	INTERNATIONAL	Hybrid	3,627	4	48	4	2.8	0.4	2.2	9.9	5.0	10.3	15.3	2,832	139,264	Yes	-2.54	11.26	37
803938	SUNNY ISLES	Hybrid	430	0	21	2	0.8	3.5	0.3	1.0	1.1	4.5	5.6	20	450	Yes	-0.40	6.20	2

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
500133	SARASOTA	Hybrid	1,297	7	22	4	2.1	1.7	0.8	1.6	2.9	3.3	6.2	11	1,749	Yes	-0.90	4.50	4
804135	GARDEN	Hybrid	868	12	5	1	1.5	0.8	6.3	0.7	7.8	1.5	9.3	333	61,892	Yes	0.01	5.72	39
805238	NATOMA	UG	1	0	0	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	-0.12	0.98	0
704264	IMAGINATION	Hybrid	1,826	44	28	4	6.2	2.8	22.2	16.1	28.4	18.9	47.3	2,398	89,904	Yes	0.55	12.15	69
705566	SOUTHSIDE	Hybrid	706	0	1	5	-	3.4	2.4	5.1	2.4	8.5	10.9	634	112,811	Yes	-1.28	3.82	27
107162	HIGHRIDGE	Hybrid	1,329	54	29	10	19.1	5.4	25.2	13.8	44.3	19.2	63.5	686	85,795	Yes	0.07	9.77	44
401435	WHITE CITY	Hybrid	962	30	8	1	3.0	0.4	6.1	0.8	9.1	1.2	10.3	694	170,755	Yes	0.59	5.49	31
500437	HYDE PARK	Hybrid	1,644	21	27	8	4.3	1.1	6.8	2.9	11.1	4.0	15.1	582	76,021	Yes	-0.69	8.01	32
808335	WHISPERING PINES	Hybrid	932	12	26	2	2.6	0.9	6.3	8.2	8.9	9.1	18.0	738	46,971	Yes	-0.14	6.46	30
704266	IMAGINATION	UG	1,070	0	67	0	-	8.3	-	9.8	-	18.1	18.1	62	10,396	Yes	0.02	13.22	3
107633	TOLOMATO	Hybrid	1,670	2	27	1	5.0	3.4	3.6	12.7	8.6	16.1	24.7	5,267	86,724	Yes	-0.33	6.07	45
502161	BONITA SPRINGS	Hybrid	3,170	41	63	13	6.5	0.4	13.3	12.6	19.8	13.0	32.8	1,513	104,587	Yes	0.46	13.46	50
807833	WESTON VILLAGE	Hybrid	1,710	8	44	2	3.8	0.1	2.3	5.1	6.1	5.2	11.3	3,980	65,608	Yes	-0.39	7.21	27
808436	SNAKE CREEK	UG	1,103	0	20	0	-	4.0	-	11.0	-	15.0	15.0	93	5,147	Yes	-0.04	5.46	14
201133	PATRICK	Hybrid	1,726	12	19	4	2.5	1.0	7.7	2.5	10.2	3.5	13.7	768	97,506	Yes	0.18	5.28	42
702032	DRIFTWOOD	Hybrid	1,769	30	15	4	2.5	0.9	5.6	3.8	8.1	4.7	12.8	360	29,724	Yes	-0.08	6.32	27
810566	JASMINE	Hybrid	45	2	4	1	3.5	0.7	2.1	0.8	5.6	1.5	7.1	337	68,359	Yes	0.18	4.68	10
805531	MASTER	Hybrid	74	1	18	1	1.7	2.2	0.2	3.7	1.9	5.9	7.8	160	8,626	Yes	0.84	9.24	4
504135	BENEVA	Hybrid	1,028	18	15	5	2.8	0.5	6.0	3.2	8.8	3.7	12.5	219	24,076	Yes	0.00	4.00	24
507065	IMPERIAL	Hybrid	1,318	1	35	3	0.4	5.5	1.2	10.9	1.6	16.4	18.0	126	27,804	Yes	-0.54	8.46	4
804336	KENDALL	Hybrid	1,434	12	36	7	2.7	1.3	2.8	8.0	5.5	9.3	14.8	1,795	115,676	Yes	-0.25	6.55	35
506165	METRO	Hybrid	1,577	12	42	6	5.6	0.5	2.8	13.5	8.4	14.0	22.4	355	31,127	Yes	-0.18	11.62	20
505661	ROTONDA	Hybrid	2,270	30	15	2	7.2	0.2	28.0	4.2	35.2	4.4	39.6	6,833	149,626	Yes	-0.07	15.73	91
102732	INTERLACHEN	OH	1,495	97	8	6	11.6	-	51.2	1.3	62.8	1.3	64.1	3,722	81,496	Yes	-0.34	5.66	71
503961	ESTERO	Hybrid	3,908	29	35	13	3.5	4.3	12.7	5.3	16.2	9.6	25.8	3,951	126,686	Yes	0.21	12.51	69
706364	BASSCREEK	Hybrid	1,377	0	22	0	2.8	1.4	-	13.8	2.8	15.2	18.0	3,309	59,127	Yes	0.85	8.95	4
404732	HILLSBORO	Hybrid	1,615	19	14	3	4.1	3.7	11.5	5.4	15.6	9.1	24.7	733	98,973	Yes	-0.06	7.94	71
806134	DOUGLAS	Hybrid	2,596	26	18	5	3.2	0.8	3.7	1.1	6.9	1.9	8.8	1,384	83,741	Yes	-0.08	9.02	30
507462	CORKSCREW	Hybrid	3,002	2	50	1	4.4	5.3	1.2	27.2	5.6	32.5	38.1	322	45,529	Yes	-0.36	13.74	8
811938	OVERTOWN	UG	2,071	0	12	2	-	4.1	0.2	1.8	0.2	5.9	6.1	776	49,497	Yes	1.17	7.57	8
101033	HOLLY HILL	Hybrid	1,024	20	11	2	3.5	2.7	4.9	1.8	8.4	4.3	12.7	1,023	123,366	Yes	0.41	5.01	26
801238	OPA LOCKA	Hybrid	1,460	6	7	7	1.6	0.7	2.7	2.6	4.3	3.3	7.6	162	26,839	Yes	4.05	4.05	25
502937	ONECCO	Hybrid	1,441	12	15	1	2.4	0.5	2.5	6.0	4.9	6.5	11.4	245	42,088	Yes	-0.74	8.06	14
106662	COQUINA	Hybrid	777	29	43	8	9.9	3.5	15.6	11.6	25.5	15.1	40.6	328	24,712	Yes	0.39	8.79	23
702933	HAWKINS	Hybrid	1,400	14	23	5	3.4	0.7	4.5	3.9	7.9	4.6	12.5	1,733	156,325	Yes	-1.08	8.22	42
803544	MARKET	UG	3	0	3	0	-	1.2	-	0.1	-	1.3	1.3	-	-	Yes	-0.13	2.47	0
805533	MASTER	Hybrid	323	6	18	1	2.4	0.4	2.4	1.0	4.8	1.4	6.2	417	64,159	Yes	-0.23	4.27	19
805831	CORAL REEF	Hybrid	1,332	7	28	0	3.5	0.1	3.8	7.7	7.3	7.8	15.1	638	156,976	Yes	-0.19	6.71	35
400337	NORTHWOOD	Hybrid	1,164	25	15	2	5.2	0.4	6.8	0.8	12.0	1.2	13.2	1,583	84,947	Yes	-0.03	6.57	36
400665	WABASSO	Hybrid	1,588	31	14	3	3.7	0.7	13.6	5.3	17.3	6.0	23.3	216	36,467	Yes	-0.27	5.83	27
804035	LE JEUNE	UG	-	0	2	0	-	0.2	-	0.1	-	0.3	0.3	-	-	Yes	0.07	7.27	0
503563	ALLIGATOR	Hybrid	2,243	1	44	6	4.1	1.3	3.9	12.0	8.0	13.3	21.3	302	39,370	Yes	1.14	9.24	28
508162	INTERSTATE	Hybrid	3,406	51	69	16	18.2	5.1	66.7	52.8	84.9	57.9	142.8	3,519	377,399	Yes	0.11	16.01	88
805140	LAWRENCE	UG	1	0	0	0	-	1.4	-	-	-	1.4	1.4	-	-	Yes	1.52	2.92	0
408164	ROSS	Hybrid	2,118	37	15	1	4.2	2.5	8.0	6.3	12.2	8.8	21.0	3,273	174,138	Yes	-0.29	7.91	25
404836	GERMANTOWN	Hybrid	1,464	8	53	3	3.3	1.3	1.0	4.3	4.3	5.6	9.9	4,979	152,458	Yes	0.26	7.66	15
411732	INLET	Hybrid	1,262	8	16	0	0.4	2.7	0.8	3.2	1.2	5.9	7.1	32	10,298	Yes	-0.04	4.66	2
807039	ROSELAWN	Hybrid	1,500	0	30	0	2.1	0.2	-	3.4	2.1	3.6	5.7	1,001	32,763	Yes	-0.20	4.20	6
101132	ORMOND	Hybrid	925	10	15	7	1.8	3.6	4.5	3.0	6.3	6.6	12.9	111	14,572	Yes	-0.34	4.86	18
700442	OAKLAND PARK	Hybrid	461	3	16	0	1.8	2.4	0.1	0.5	1.9	2.9	4.8	270	26,330	Yes	0.93	4.43	12
101038	HOLLY HILL	Hybrid	1,359	24	6	3	4.6	0.3	8.1	0.9	12.7	1.2	13.9	628	93,843	Yes	-0.30	6.00	48
811940	OVERTOWN	UG	2,098	0	8	0	-	3.6	-	2.1	-	5.7	5.7	1	61	Yes	-0.83	6.17	1

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
405265	ACME	Hybrid	2,948	3	49	1	3.9	0.9	2.4	22.4	6.3	23.3	29.6	1,984	80,659	Yes	-1.27	10.93	47
402632	JUNO BEACH	Hybrid	1,518	6	37	1	2.3	2.3	1.6	2.6	3.9	4.9	8.8	857	95,020	Yes	-0.05	6.45	6
705865	REMSBURG	Hybrid	1,656	1	27	0	3.6	1.2	0.9	13.7	4.5	14.9	19.4	349	52,139	Yes	-0.93	9.27	14
702931	HAWKINS	Hybrid	1,813	7	15	0	1.6	0.1	2.1	4.0	3.7	4.1	7.8	249	54,506	Yes	-0.21	3.99	14
503434	SOUTH VENICE	OH	1,142	17	7	1	3.0	0.3	10.4	0.3	13.4	0.6	14.0	498	65,336	Yes	-3.75	4.55	58
706264	VALENCIA	Hybrid	1,679	30	45	9	8.3	3.6	12.1	25.3	20.4	28.9	49.3	248	56,078	Yes	0.23	14.53	46
707932	TWINLAKES	Hybrid	1,271	15	10	2	2.5	0.1	2.3	1.9	4.8	2.0	6.8	1,487	125,487	Yes	-0.07	3.83	10
108431	SAN MATEO	OH	722	80	13	7	19.1	0.1	33.6	2.4	52.7	2.5	55.2	345	49,622	Yes	-0.08	3.12	55
500432	HYDE PARK	Hybrid	519	3	21	4	2.2	0.3	1.2	1.4	3.4	1.7	5.1	155	58,606	Yes	-0.94	3.76	8
100435	PALATKA	Hybrid	1,078	40	15	5	6.1	0.1	7.1	0.9	13.2	1.0	14.2	99	32,624	Yes	-0.01	4.99	19
104834	TAYLOR	Hybrid	1,332	15	19	2	2.7	3.2	4.6	6.1	7.3	9.3	16.6	604	54,899	Yes	-0.06	4.34	16
100132	DAYTONA BEACH	Hybrid	1,401	16	23	5	2.4	1.0	1.5	2.7	3.9	3.7	7.6	174	18,538	Yes	-0.04	5.06	20
402834	LANTANA	Hybrid	1,796	3	27	3	2.6	1.8	1.3	3.2	3.9	5.0	8.9	530	14,204	Yes	0.16	6.26	9
407864	LOXAHATCHEE	Hybrid	1,879	11	25	6	6.8	1.7	25.1	24.4	31.9	26.1	58.0	642	79,912	Yes	-0.32	8.28	64
400933	BELLE GLADE	Hybrid	2,343	38	11	7	6.0	-	8.8	2.7	14.8	2.7	17.5	1,847	118,050	Yes	-0.35	7.95	35
803432	MIAMI SHORES	OH	2,059	21	5	3	3.4	-	7.9	0.3	11.3	0.3	11.6	5,832	348,115	Yes	0.25	7.35	68
413532	VIOLET	Hybrid	1,672	3	40	5	2.6	1.6	3.6	11.5	6.2	13.1	19.3	1,925	177,910	Yes	-0.48	6.52	9
201636	PALM BAY	Hybrid	-	0	0	0	0.1	0.4	-	-	0.1	0.4	0.5	-	-	Yes	0.03	0.23	0
810262	INTERNATIONAL	UG	1,563	0	16	0	-	4.8	-	4.3	-	9.1	9.1	1,099	10,980	Yes	-2.53	11.37	3
405334	BEELINE	Hybrid	1,064	10	17	5	3.3	2.2	4.9	6.9	8.2	9.1	17.3	730	80,553	Yes	-0.50	4.10	42
505464	WINKLER	Hybrid	5,177	3	57	2	3.7	3.3	0.8	24.8	4.5	28.1	32.6	8,387	354,077	Yes	1.53	17.23	28
702935	HAWKINS	Hybrid	1,724	6	28	1	3.0	0.1	1.9	10.7	4.9	10.8	15.7	213	35,788	Yes	0.44	8.04	28
804933	OJUS	UG	66	0	1	0	-	3.4	-	0.4	-	3.8	3.8	-	-	Yes	-0.65	3.05	0
810063	AVOCADO	Hybrid	481	48	14	4	7.5	0.8	14.6	2.8	22.1	3.6	25.7	1,504	72,365	Yes	0.21	3.11	47
203234	INDIALANTIC	OH	978	29	4	2	3.7	0.1	7.7	0.2	11.4	0.3	11.7	757	48,525	Yes	0.06	4.76	27
102231	MADISON	Hybrid	1,578	16	6	5	3.2	0.9	9.7	3.1	12.9	4.0	16.9	2,106	202,943	Yes	-0.43	5.37	42
805635	MILLER	Hybrid	1,255	6	29	5	2.3	1.5	6.0	6.2	8.3	7.7	16.0	290	63,345	Yes	-0.07	7.03	34
810062	AVOCADO	OH	964	69	3	4	11.6	1.3	41.9	0.6	53.5	1.9	55.4	1,089	161,908	Yes	0.22	8.92	129
802632	AIRPORT	UG	7	0	6	0	-	3.6	-	1.3	-	4.9	4.9	-	-	Yes	0.02	4.42	0
407034	RIO	Hybrid	830	4	22	2	2.6	0.3	0.8	6.1	3.4	6.4	9.8	27	6,930	Yes	0.18	3.78	6
507264	SAN CARLOS	Hybrid	3,546	48	4	3	4.5	1.5	28.2	6.3	32.7	7.8	40.5	3,010	236,061	Yes	0.13	14.83	81
410531	GRAMERCY	Hybrid	801	1	35	0	2.1	1.8	0.1	5.8	2.2	7.6	9.8	82	4,302	Yes	0.10	7.80	8
503265	COCOPLUM	Hybrid	3,559	2	54	9	6.0	-	11.8	35.4	17.8	35.4	53.2	1,121	53,789	Yes	-0.02	13.48	37
809836	DUMFOUNDLING	UG	543	0	2	0	-	3.5	-	1.6	-	5.1	5.1	-	-	Yes	-0.93	3.17	0
509132	TIMUCUAN	Hybrid	2,007	14	13	6	1.9	0.1	5.3	3.8	7.2	3.9	11.1	2,493	132,622	Yes	5.14	5.14	32
206932	BARNA	Hybrid	971	15	19	12	5.2	0.1	7.5	5.9	12.7	6.0	18.7	363	65,306	Yes	-2.08	4.32	25
405532	PRIMAVISTA	Hybrid	1,942	22	21	1	6.6	0.2	11.5	7.2	18.1	7.4	25.5	2,794	155,728	Yes	0.27	7.27	26
106461	SPRUCE	Hybrid	4,015	1	70	2	5.0	0.8	2.2	32.5	7.2	33.3	40.5	1,653	17,341	Yes	1.08	18.08	16
404932	PORT SEWALL	Hybrid	1,286	13	20	5	3.7	0.4	3.6	10.6	7.3	11.0	18.3	268	30,174	Yes	-0.87	6.23	29
804438	VENETIAN	UG	1,043	0	8	0	0.2	2.6	-	1.4	0.2	4.0	4.2	452	34,574	Yes	2.31	4.31	4
409861	HAMLET	Hybrid	2,396	0	23	1	1.4	1.0	0.1	8.1	1.5	9.1	10.6	3,017	167,020	Yes	0.05	5.05	10
408561	ALEXANDER	OH	381	36	2	4	12.5	0.2	28.7	1.0	41.2	1.2	42.4	626	87,726	Yes	-0.12	2.38	28
803633	SEABOARD	Hybrid	489	10	18	1	2.7	1.2	2.0	1.8	4.7	3.0	7.7	1,620	51,284	Yes	0.09	3.89	29
709162	GRIFFIN	Hybrid	21	2	7	1	0.5	1.1	0.8	1.3	1.3	2.4	3.7	2	1,036	Yes	-0.86	1.64	2
211063	GARVEY	OH	2,552	71	8	2	7.2	0.1	39.8	1.1	47.0	1.2	48.2	1,786	197,233	Yes	-0.31	11.49	84
803935	SUNNY ISLES	UG	1,802	0	11	0	-	4.8	-	1.1	-	5.9	5.9	4,390	435,147	Yes	0.37	7.17	19
405261	ACME	Hybrid	2,559	2	58	0	8.0	1.4	0.7	28.0	8.7	29.4	38.1	1,105	75,456	Yes	-0.80	11.30	32
507964	MCCALL	OH	3,385	60	2	3	7.5	1.5	60.3	1.1	67.8	2.6	70.4	2	260	Yes	0.00	0.00	1
806434	HAINLIN	Hybrid	1,551	22	36	2	4.2	1.2	3.1	22.4	7.3	23.6	30.9	80	19,755	Yes	-0.30	8.50	12
701935	HOLY CROSS	Hybrid	1,874	15	22	2	2.6	1.2	2.9	3.7	5.5	4.9	10.4	1,039	155,841	Yes	-0.25	5.95	25
405131	HUTCHINSON ISL	Hybrid	2,012	0	21	0	0.9	6.4	-	9.3	0.9	15.7	16.6	25	2,298	Yes	-0.01	3.99	10
414034	GRACEWOOD	Hybrid	839	1	33	0	1.9	0.4	0.2	13.8	2.1	14.2	16.3	910	17,462	Yes	-0.13	5.17	14

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR	
810935	LATIN QUARTER	Hybrid	2,503	14	11	4	2.2	0.3	2.4	0.7	4.6	1.0	5.6	1,162	93,843	Yes	0.08	6.38	23	
807231	MERCHANDISE	Hybrid	1,124	21	8	1	1.8	1.4	5.1	1.2	6.9	2.6	9.5	280	66,387	Yes	-0.26	4.74	23	
405639	FOUNTAIN	Hybrid	2,494	7	22	0	1.9	2.2	3.4	11.2	5.3	13.4	18.7	364	41,944	Yes	-0.13	6.17	20	
505564	VAMO	Hybrid	2,569	2	39	0	3.3	2.7	0.5	19.2	3.8	21.9	25.7	280	85,200	Yes	-0.85	10.05	8	
409864	HAMLET	Hybrid	625	1	15	2	0.7	0.5	0.6	2.5	1.3	3.0	4.3	32	5,728	Yes	-0.02	7.48	7	
201532	CITY POINT	Hybrid	1,382	26	17	4	4.2	1.1	14.2	2.6	18.4	3.7	22.1	1,045	63,320	Yes	-0.08	5.52	45	
101034	HOLLY HILL	Hybrid	1,668	36	20	6	3.6	0.8	7.0	5.8	10.6	6.6	17.2	163	12,192	Yes	-0.27	7.03	29	
406931	DELMAR	Hybrid	1,505	0	23	0	2.2	0.3	-	11.7	2.2	12.0	14.2	17	433	Yes	-0.16	5.04	3	
502063	MURDOCK	Hybrid	2,127	24	13	2	4.7	0.4	21.8	1.3	26.5	1.7	28.2	2,505	139,719	Yes	-0.03	8.57	50	
500162	SARASOTA	Hybrid	3,863	16	75	3	2.8	10.1	2.7	19.8	5.5	29.9	35.4	333	60,450	Yes	-0.86	11.44	27	
802736	MARION	Hybrid	1,895	0	29	0	1.2	2.0	-	12.4	1.2	14.4	15.6	209	48,193	Yes	-0.30	6.40	14	
800742	HIALEAH	UG	-	0	0	0	-	0.2	-	-	-	-	0.2	0.2	-	Yes	-1.08	1.92	0	
202035	INDIAN HARBOR	Hybrid	1,361	13	32	6	2.6	0.4	3.6	5.2	6.2	5.6	11.8	202	49,408	Yes	-0.34	7.86	18	
811562	KOGER	Hybrid	3,238	1	51	0	4.2	4.3	-	15.0	4.2	19.3	23.5	51	4,685	Yes	0.62	12.12	4	
809034	AVENTURA	UG	775	0	5	0	-	3.1	-	1.2	-	4.3	4.3	-	Yes	-1.52	4.18	0		
407462	INDRIO	Hybrid	2,661	50	43	8	15.2	1.8	29.8	24.1	45.0	25.9	70.9	2,898	57,312	Yes	0.12	9.12	38	
801436	FULFORD	Hybrid	1,711	26	19	0	4.2	1.4	6.7	3.6	10.9	5.0	15.9	1,409	279,870	Yes	-1.36	7.94	92	
406868	KIMBERLY	Hybrid	541	3	17	1	2.4	2.9	1.6	10.3	4.0	13.2	17.2	59	8,502	Yes	5.80	5.80	8	
808535	SEMINOLA	UG	1	0	0	0	-	4.5	-	-	-	-	4.5	4.5	-	Yes	-0.23	4.87	0	
412362	WATTS	UG	983	0	18	0	-	2.8	-	-	8.9	-	11.7	11.7	4	76	Yes	0.80	3.90	2
801938	DEAUVILLE	Hybrid	1,601	8	20	1	1.5	2.2	1.6	1.2	3.1	3.4	6.5	1,867	132,110	Yes	-1.87	4.83	11	
404234	BOCA TECCA	Hybrid	2,396	3	24	3	1.4	2.7	1.0	5.1	2.4	7.8	10.2	462	91,243	Yes	-0.42	7.48	23	
209864	YORKE	Hybrid	1,620	18	44	7	7.3	0.2	5.1	11.1	12.4	11.3	23.7	98	12,170	Yes	-0.25	8.75	19	
502462	LABELLE	Hybrid	1,828	60	15	22	21.9	-	60.1	5.5	82.0	5.5	87.5	3,256	169,969	Yes	-0.50	8.50	90	
407332	HILLS	Hybrid	1,529	9	45	7	7.1	4.9	3.8	20.0	10.9	24.9	35.8	945	36,171	Yes	-0.62	8.28	18	
807734	LEMON CITY	Hybrid	1,492	25	4	3	3.0	0.5	6.5	0.8	9.5	1.3	10.8	567	107,527	Yes	-2.21	7.39	65	
501236	NAPLES	Hybrid	225	1	16	2	1.4	2.8	0.6	4.4	2.0	7.2	9.2	26	6,182	Yes	0.01	2.71	6	
708064	WINDMILL	Hybrid	1,999	4	37	1	0.9	5.5	1.7	20.4	2.6	25.9	28.5	64	12,060	Yes	-0.53	10.97	9	
703631	PALM AIRE	Hybrid	1,103	8	22	1	2.6	0.6	1.2	4.3	3.8	4.9	8.7	712	23,689	Yes	0.37	5.07	15	
701043	SAMPLE ROAD	Hybrid	1,667	13	10	9	2.5	0.4	6.5	3.7	9.0	4.1	13.1	361	44,649	Yes	0.11	7.71	38	
808632	BRANDON	Hybrid	2,189	33	15	3	5.4	1.0	13.8	2.7	19.2	3.7	22.9	3,760	330,638	Yes	0.35	9.95	170	
805139	LAWRENCE	UG	-	0	0	0	-	1.4	-	-	-	1.4	1.4	-	-	Yes	0.88	1.78	0	
701937	HOLY CROSS	Hybrid	1,052	17	1	5	2.4	1.0	4.5	0.5	6.9	1.5	8.4	1,270	72,796	Yes	0.49	5.49	29	
502166	BONITA SPRINGS	Hybrid	2,755	27	50	10	6.1	6.7	11.0	25.3	17.1	32.0	49.1	1,065	147,305	Yes	-0.53	12.57	53	
705532	SOUTHSIDE	Hybrid	1,362	17	5	9	2.1	0.3	5.9	1.2	8.0	1.5	9.5	1,004	82,599	Yes	-0.33	4.27	38	
208763	GRANT	Hybrid	2,434	22	29	5	6.4	1.0	20.5	23.2	26.9	24.2	51.1	3,682	224,844	Yes	0.00	7.50	21	
814134	BAUER	Hybrid	2,558	1	37	1	2.6	2.1	1.1	16.9	3.7	19.0	22.7	5,964	199,572	Yes	-0.10	7.80	19	
708433	BUTTERFLY	Hybrid	1,445	0	32	1	1.7	2.1	0.2	8.8	1.9	10.9	12.8	138	16,029	Yes	0.04	7.14	2	
806335	ULETA	UG	-	0	0	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	0.02	0.02	0	
502064	MURDOCK	Hybrid	2,148	19	61	5	5.8	0.3	21.7	12.4	27.5	12.7	40.2	2,169	120,833	Yes	-0.26	13.74	48	
805932	COUNTRY CLUB	Hybrid	1,589	1	29	0	1.1	1.7	0.3	16.4	1.4	18.1	19.5	190	59,119	Yes	-0.51	8.29	13	
402531	BELVEDERE	Hybrid	835	21	21	5	3.6	0.6	2.9	5.1	6.5	5.7	12.2	54	8,129	Yes	-0.06	5.04	15	
809233	MITCHELL	Hybrid	167	1	12	0	0.8	1.0	-	3.2	0.8	4.2	5.0	3	655	Yes	0.10	2.70	3	
404036	WESTWARD	Hybrid	1,504	12	15	0	2.0	0.8	3.1	4.2	5.1	5.0	10.1	178	27,608	Yes	-0.09	3.61	14	
209231	MARS	UG	10	0	10	0	-	1.6	-	0.9	-	2.5	2.5	-	-	Yes	0.35	3.55	0	
204635	COLLEGE	Hybrid	1,304	3	18	0	1.2	0.8	0.5	11.7	1.7	12.5	14.2	206	11,805	Yes	-0.26	5.74	5	
708933	HACIENDA	Hybrid	221	0	12	0	0.9	0.2	0.1	0.7	1.0	0.9	1.9	13	2,079	Yes	0.08	6.28	4	
703636	PALM AIRE	Hybrid	2,192	0	30	0	2.4	1.8	0.1	12.5	2.5	14.3	16.8	1,024	16,844	Yes	0.03	6.53	5	
200263	CELERY	Hybrid	1,284	25	34	4	6.8	3.1	13.9	15.5	20.7	18.6	39.3	1,290	42,737	Yes	1.06	4.76	28	
407331	HILLS	Hybrid	1,916	22	38	4	3.6	0.8	4.4	9.3	8.0	10.1	18.1	200	32,100	Yes	-0.26	7.74	20	
704661	SPRINGTREE	Hybrid	2,697	0	41	0	3.0	0.3	0.1	15.2	3.1	15.5	18.6	4,045	105,347	Yes	-1.61	8.99	24	
404232	BOCA TECCA	Hybrid	2,186	10	26	7	2.2	1.1	3.0	7.9	5.2	9.0	14.2	131	19,193	Yes	-0.02	6.08	12	

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
400138	WEST PALM BEACH	Hybrid	380	0	6	1	0.1	1.2	0.1	1.7	0.2	2.9	3.1	506	32,965	Yes	-0.57	3.03	4
504961	GOLDEN GATE	Hybrid	2,272	25	29	3	6.3	0.6	11.5	15.0	17.8	15.6	33.4	245	54,187	Yes	-0.29	10.21	35
705461	PHOENIX	Hybrid	2,761	0	30	1	2.1	2.6	0.4	23.0	2.5	25.6	28.1	358	65,544	Yes	-0.35	11.05	17
807962	MIAMI LAKES	Hybrid	2,571	0	62	2	1.7	5.1	0.3	18.7	2.0	23.8	25.8	950	119,252	Yes	0.49	15.19	17
100936	SOUTH DAYTONA	Hybrid	212	1	10	1	0.4	0.7	0.2	1.4	0.6	2.1	2.7	153	15,733	Yes	-0.03	0.77	5
104733	KACIE	Hybrid	1,681	10	39	5	5.3	0.7	4.2	11.6	9.5	12.3	21.8	123	17,847	Yes	-0.80	8.70	21
807732	LEMON CITY	Hybrid	1,790	8	9	6	0.7	1.8	3.7	0.8	4.4	2.6	7.0	1,905	50,810	Yes	-0.17	4.83	22
301131	COLUMBIA	Hybrid	761	22	20	6	6.2	0.1	5.3	4.3	11.5	4.4	15.9	96	6,125	Yes	-0.28	7.72	13
501435	ARCADIA	Hybrid	1,138	32	21	5	5.3	0.2	15.2	3.8	20.5	4.0	24.5	207	20,028	Yes	-0.22	6.58	13
809433	SAGA	Hybrid	2,803	9	30	1	3.7	3.6	3.0	16.7	6.7	20.3	27.0	251	29,581	Yes	-0.23	10.07	21
808931	OLYMPIA HEIGHTS	Hybrid	1,471	33	9	3	4.8	0.4	8.6	1.1	13.4	1.5	14.9	241	53,669	Yes	-0.18	8.92	45
404733	HILLSBORO	Hybrid	1,128	0	18	1	2.0	0.1	0.1	10.1	2.1	10.2	12.3	287	24,007	Yes	0.05	5.55	17
204263	BABCOCK	OH	1,538	27	6	2	4.5	0.3	22.6	0.8	27.1	1.1	28.2	2,053	177,113	Yes	-0.08	7.22	78
800331	BUENA VISTA	Hybrid	1,434	28	0	2	2.5	0.5	7.1	0.1	9.6	0.6	10.2	294	58,996	Yes	0.08	4.08	40
807733	LEMON CITY	Hybrid	1,302	11	9	3	2.6	1.0	1.8	0.5	4.4	1.5	5.9	5,485	344,821	Yes	0.11	4.21	41
502205	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-5.14	3.96	0
405337	BEELINE	Hybrid	628	1	26	3	4.5	0.3	1.0	6.4	5.5	6.7	12.2	192	31,761	Yes	-0.65	6.85	18
709161	GRIFFIN	UG	39	0	2	0	-	5.1	-	0.5	-	5.6	5.6	-	-	Yes	0.41	5.01	0
202634	HOLLAND PARK	Hybrid	1,954	36	34	7	4.9	0.5	7.4	12.4	12.3	12.9	25.2	188	59,207	Yes	6.90	6.90	31
503861	ORTIZ	Hybrid	2,479	41	27	11	5.1	0.1	14.1	8.3	19.2	8.4	27.6	3,022	259,338	Yes	-1.59	7.01	73
700462	OAKLAND PARK	UG	2,973	0	18	0	-	7.2	-	1.8	-	9.0	9.0	372	17,978	Yes	-2.82	7.58	5
102035	BULOW	Hybrid	1,663	2	34	1	2.1	9.6	0.7	33.1	2.8	42.7	45.5	112	15,026	Yes	-0.04	6.86	9
404934	PORT SEWALL	Hybrid	835	9	28	5	4.9	0.2	3.6	2.6	8.5	2.8	11.3	673	46,431	Yes	-0.34	8.56	17
408165	ROSS	Hybrid	1,988	11	47	5	3.8	4.3	3.1	21.7	6.9	26.0	32.9	164	30,049	Yes	-0.13	10.97	23
805441	DADE	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	1.27	2.17	0
510663	KELLY	Hybrid	3,667	25	48	4	6.6	1.8	9.3	22.7	15.9	24.5	40.4	5,613	122,970	Yes	0.12	11.82	51
503432	SOUTH VENICE	Hybrid	1,744	16	29	10	4.9	1.3	12.8	6.9	17.7	8.2	25.9	675	144,052	Yes	-1.48	7.02	34
409635	RAINBERRY	Hybrid	867	0	9	3	0.9	1.1	0.5	5.7	1.4	6.8	8.2	-	-	Yes	0.00	0.00	0
801635	PRINCETON	Hybrid	1,587	1	17	0	2.7	1.1	-	13.2	2.7	14.3	17.0	234	26,832	Yes	0.09	7.09	13
406164	TURNPIKE	Hybrid	3,553	47	16	1	6.5	0.3	38.2	3.5	44.7	3.8	48.5	7,774	129,311	Yes	-0.06	15.34	66
508263	RYE	Hybrid	2,845	3	47	2	2.5	6.9	1.9	28.9	4.4	35.8	40.2	2,069	79,645	Yes	-0.71	10.69	12
408263	COVE	Hybrid	3,232	3	54	1	5.4	3.6	1.7	33.1	7.1	36.7	43.8	346	62,725	Yes	-1.61	9.89	23
406768	ACREAGE	Hybrid	2,942	26	25	1	7.1	0.8	24.7	16.3	31.8	17.1	48.9	530	55,385	Yes	-0.21	13.89	53
801835	BISCAYNE	Hybrid	1,423	18	1	1	1.8	0.8	8.4	0.1	10.2	0.9	11.1	585	136,265	Yes	0.02	6.02	66
503968	ESTERO	Hybrid	2,678	6	41	9	3.8	2.4	3.1	32.5	6.9	34.9	41.8	188	49,737	Yes	-0.53	11.07	20
702536	DAVIE	Hybrid	1,198	1	36	0	2.7	0.3	0.2	5.5	2.9	5.8	8.7	844	89,887	Yes	-0.03	6.87	10
805731	GALLOWAY	Hybrid	1,875	7	13	5	1.6	1.4	7.1	8.1	8.7	9.5	18.2	2,071	31,467	Yes	-0.61	8.29	40
701638	PLANTATION	Hybrid	1,781	14	26	3	3.5	0.3	3.1	4.8	6.6	5.1	11.7	280	29,422	Yes	-0.22	6.38	30
709265	PROGRESSO	UG	763	0	4	0	-	5.4	-	0.4	-	5.8	5.8	165	28,746	Yes	-0.68	4.52	3
700635	VERENA	Hybrid	1,525	40	11	2	4.5	-	10.0	1.2	14.5	1.2	15.7	1,132	126,685	Yes	-0.34	8.36	65
503765	HARBOR	Hybrid	3,034	43	22	5	8.0	0.3	40.9	5.7	48.9	6.0	54.9	1,253	94,437	Yes	-0.53	12.77	58
107632	TOLOMATO	Hybrid	868	22	14	7	5.0	1.3	14.7	6.1	19.7	7.4	27.1	490	82,890	Yes	-0.62	6.68	41
504665	CASTLE	Hybrid	3,197	10	45	8	3.0	3.2	7.5	20.5	10.5	23.7	34.2	466	93,231	Yes	1.08	12.18	29
802138	MIRAMAR	Hybrid	450	6	9	0	2.4	0.5	0.8	0.4	3.2	0.9	4.1	1,098	48,038	Yes	-0.51	2.59	4
707733	GOOLSBY	UG	-	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	-4.07	2.53	0
702137	CYPRESS CREEK	Hybrid	357	7	21	2	2.5	1.5	1.1	1.4	3.6	2.9	6.5	491	17,881	Yes	-0.04	6.26	16
800101	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.91	1.91	0
510762	OVERBROOK	Hybrid	1,904	20	17	4	2.9	0.3	13.8	7.6	16.7	7.9	24.6	534	66,402	Yes	-0.23	6.17	44
405632	FOUNTAIN	Hybrid	2,262	2	41	2	2.0	0.7	0.9	13.0	2.9	13.7	16.6	485	84,256	Yes	0.51	8.41	35
803546	MARKET	UG	1	0	0	0	-	1.2	-	-	-	1.2	1.2	1	83	Yes	0.77	5.77	1
808432	SNAKE CREEK	Hybrid	1,392	2	18	2	0.6	2.4	0.9	7.0	1.5	9.4	10.9	813	64,788	Yes	-0.55	4.15	13
700833	BEVERLY	Hybrid	1,157	25	13	5	3.0	0.4	3.5	1.4	6.5	1.8	8.3	2,296	223,054	Yes	0.05	5.25	59

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
400437	HILLCREST	Hybrid	1,396	13	37	1	2.1	4.0	1.8	6.5	3.9	10.5	14.4	2,458	42,231	Yes	5.65	5.65	13
202235	MIMS	Hybrid	2,390	61	34	12	14.4	1.6	40.0	16.9	54.4	18.5	72.9	1,521	131,281	Yes	-0.01	9.49	64
401634	OKEECHOBEE	Hybrid	1,638	46	8	9	14.0	0.4	40.9	7.0	54.9	7.4	62.3	765	107,985	Yes	0.10	6.30	51
709831	FESTIVAL	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.01	0.11	0
702834	PERRY	Hybrid	2,296	11	24	1	3.5	-	4.6	9.5	8.1	9.5	17.6	53	8,114	Yes	-0.08	8.32	12
704032	MOTOROLA	Hybrid	3,293	19	32	0	4.2	2.3	9.1	6.8	13.3	9.1	22.4	7,528	315,915	Yes	-0.34	10.26	46
810567	JASMINE	UG	1,279	0	12	0	-	3.1	-	7.8	-	10.9	10.9	1,126	18,454	Yes	-0.18	4.42	3
408665	HOMELAND	Hybrid	1,554	0	33	1	4.4	10.8	1.0	29.3	5.4	40.1	45.5	362	46,271	Yes	-1.64	10.66	11
807735	LEMON CITY	Hybrid	1,263	9	6	1	1.7	0.3	0.6	0.4	2.3	0.7	3.0	1,725	50,296	Yes	0.09	2.99	15
808337	WHISPERING PINES	Hybrid	1,831	10	33	3	3.4	1.0	3.1	14.8	6.5	15.8	22.3	472	62,874	Yes	-0.46	9.34	30
503761	HARBOR	Hybrid	1,821	32	21	11	4.9	0.1	11.6	11.6	16.5	11.7	28.2	2,340	18,536	Yes	0.13	8.53	29
507961	MCCALL	Hybrid	3,443	50	17	8	12.3	0.1	72.0	13.6	84.3	13.7	98.0	5,896	225,655	Yes	0.19	13.99	83
510562	BERMONT	Hybrid	476	25	4	3	14.1	0.2	30.4	3.3	44.5	3.5	48.0	1,148	160,132	Yes	-0.04	0.66	37
807539	DADELAND	UG	2	0	0	0	-	0.3	-	-	-	0.3	0.3	-	-	Yes	0.21	1.41	0
402835	LANTANA	Hybrid	2,842	9	73	4	3.6	2.5	3.5	7.4	7.1	9.9	17.0	570	116,209	Yes	-0.23	8.57	32
106236	GERONA	Hybrid	2,015	24	24	8	3.7	2.5	5.3	13.5	9.0	16.0	25.0	896	96,980	Yes	-1.50	8.60	35
700437	OAKLAND PARK	Hybrid	1,409	10	20	7	3.4	0.4	4.0	2.1	7.4	2.5	9.9	2,392	155,376	Yes	-0.12	5.98	29
811933	VERTOWN	UG	1,875	0	7	2	-	4.5	0.1	1.5	0.1	6.0	6.1	93	13,699	Yes	0.84	5.04	5
400136	WEST PALM BEACH	Hybrid	906	1	10	1	0.1	2.7	0.3	1.3	0.4	4.0	4.4	5	905	Yes	0.09	5.09	1
100135	DAYTONA BEACH	Hybrid	1,448	23	21	16	3.3	1.6	4.2	6.5	7.5	8.1	15.6	299	60,467	Yes	-0.44	7.06	23
404833	GERMANTOWN	Hybrid	2,916	11	40	1	4.2	0.6	3.7	14.7	7.9	15.3	23.2	1,591	170,091	Yes	-0.27	8.43	33
502834	PAYNE	Hybrid	1,586	32	22	15	3.2	0.5	10.6	4.4	13.8	4.9	18.7	2,992	178,863	Yes	-0.12	7.38	56
102533	MATANZAS	Hybrid	2,874	17	26	4	6.2	1.5	8.0	17.1	14.2	18.6	32.8	2,050	80,163	Yes	-0.72	8.78	34
508163	INTERSTATE	Hybrid	3,500	3	59	0	5.2	5.2	1.5	38.6	6.7	43.8	50.5	372	37,764	Yes	0.00	15.30	27
106366	REGIS	Hybrid	3,055	35	2	0	6.3	2.8	34.6	1.4	40.9	4.2	45.1	3,049	140,775	Yes	-0.83	13.67	35
801634	PRINCETON	Hybrid	2,295	12	45	3	4.8	2.0	2.8	10.5	7.6	12.5	20.1	72	15,368	Yes	0.27	6.77	10
705767	TRACE	Hybrid	2,345	4	66	2	2.6	11.3	4.2	31.0	6.8	42.3	49.1	1,770	77,912	Yes	-0.55	14.25	17
809667	COURT	Hybrid	1,166	2	43	3	2.4	2.3	3.1	4.6	5.5	6.9	12.4	145	21,164	Yes	0.20	4.80	18
701632	PLANTATION	Hybrid	1,229	36	13	2	4.3	0.3	11.0	7.5	15.3	7.8	23.1	2,765	145,600	Yes	-0.46	7.74	67
700537	POMPANO	Hybrid	958	19	28	8	3.1	0.9	3.1	5.5	6.2	6.4	12.6	35	4,248	Yes	0.53	8.63	8
808834	SNAPPER CREEK	Hybrid	736	18	25	4	4.1	0.6	6.2	2.8	10.3	3.2	13.5	1,465	151,313	Yes	-0.32	5.48	62
701165	LYONS	UG	1,472	0	9	0	-	3.0	-	0.7	-	3.7	3.7	225	9,155	Yes	-0.03	3.17	4
209801	YORKE	UG	1	0	0	0	-	0.6	-	-	-	0.6	0.6	-	-	Yes	-2.85	3.95	0
501531	PUNTA GORDA	Hybrid	1,541	21	35	5	5.9	0.6	5.2	7.5	11.1	8.1	19.2	51	7,291	Yes	-0.26	7.54	18
804735	HAULOVER	Hybrid	1,439	0	10	0	0.4	3.5	-	4.1	0.4	7.6	8.0	352	37,217	Yes	0.45	2.35	6
811162	SPOONBILL	Hybrid	4,704	8	77	4	4.9	5.3	3.6	36.2	8.5	41.5	50.0	156	22,437	Yes	-2.97	16.23	29
804533	GRATIGNY	Hybrid	2,273	0	24	0	2.0	0.3	-	6.3	2.0	6.6	8.6	290	35,203	Yes	-0.39	6.31	11
703237	WOODLANDS	Hybrid	3,774	1	70	1	4.3	0.9	0.2	22.9	4.5	23.8	28.3	5,116	71,207	Yes	-0.87	10.93	34
500433	HYDE PARK	Hybrid	1,613	34	13	3	3.9	0.3	12.6	2.1	16.5	2.4	18.9	574	80,657	Yes	0.35	8.05	66
703535	DEERFIELD BEACH	Hybrid	1,767	7	19	6	1.1	1.6	2.0	2.2	3.1	3.8	6.9	232	28,880	Yes	0.09	4.49	16
504063	CAPRI	Hybrid	221	2	1	2	3.9	1.6	4.5	1.4	8.4	3.0	11.4	186	32,271	Yes	0.96	2.46	8
700139	SISTRUNK	Hybrid	2,400	18	18	5	3.9	0.6	12.8	7.1	16.7	7.7	24.4	4,952	412,316	Yes	-0.18	9.82	96
203635	HARRIS	Hybrid	2,300	10	40	5	3.2	0.3	3.4	10.1	6.6	10.4	17.0	1,449	53,996	Yes	-0.40	6.90	21
201733	SYKES CREEK	Hybrid	1,792	29	7	9	3.5	0.4	11.8	3.5	15.3	3.9	19.2	229	31,893	Yes	-0.37	7.33	28
706534	TRAIN	Hybrid	1,208	7	9	0	1.7	0.7	2.5	1.4	4.2	2.1	6.3	181	21,579	Yes	0.85	4.05	11
200331	TITUSVILLE	Hybrid	1,111	32	18	8	5.2	0.2	5.9	2.5	11.1	2.7	13.8	1,511	55,040	Yes	-0.08	5.62	29
201638	PALM BAY	Hybrid	1,842	17	28	4	3.4	1.0	3.5	18.6	6.9	19.6	26.5	985	74,693	Yes	-0.27	5.53	29
804140	GARDEN	UG	116	0	17	0	0.5	3.8	-	6.2	0.5	10.0	10.5	673	55,794	Yes	0.48	5.68	5
801236	OPA LOCKA	Hybrid	597	4	19	0	1.7	2.3	1.9	3.2	3.6	5.5	9.1	802	59,370	Yes	-0.91	6.49	17
100835	PORT ORANGE	Hybrid	1,856	7	17	5	1.3	3.1	1.9	5.1	3.2	8.2	11.4	272	32,403	Yes	-0.05	4.75	18
704161	MOFFETT	UG	1,260	0	6	0	-	5.7	-	1.1	-	6.8	6.8	30	7,920	Yes	-0.04	6.66	1
706962	CHAPEL	Hybrid	1,096	0	22	0	1.7	3.7	-	13.2	1.7	16.9	18.6	1,127	35,548	Yes	-0.10	6.90	5

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
500831	WHITFIELD	Hybrid	438	7	23	5	2.0	0.5	2.7	4.9	4.7	5.4	10.1	16	4.384	Yes	0.44	6.84	5
803940	SUNNY ISLES	UG	975	0	1	0	-	4.1	-	-	-	4.1	4.1	-	-	Yes	0.77	7.47	0
409535	LAKE IDA	Hybrid	1,242	24	30	3	5.3	0.5	7.6	2.6	12.9	3.1	16.0	990	116.172	Yes	5.51	9.81	51
400134	WEST PALM BEACH	Hybrid	628	3	24	5	1.3	1.8	0.9	2.6	2.2	4.4	6.6	2,006	155,590	Yes	-0.06	4.94	28
807537	DADELAND	UG	628	0	4	0	-	3.3	-	0.4	-	3.7	3.7	1,028	6.168	Yes	-0.74	3.56	1
408864	ABERDEEN	Hybrid	2,627	0	44	0	2.4	5.1	0.1	27.4	2.5	32.5	35.0	1,524	102,760	Yes	0.78	12.28	9
702433	PEMBROKE	Hybrid	1,247	10	10	4	2.1	0.6	5.8	2.4	7.9	3.0	10.9	1,291	10,027	Yes	-0.04	5.86	24
506034	WALKER	Hybrid	853	19	2	5	2.0	0.1	8.2	1.3	10.2	1.4	11.6	392	36,392	Yes	0.19	4.49	44
202632	HOLLAND PARK	Hybrid	1,298	23	22	5	3.7	0.1	5.7	6.9	9.4	7.0	16.4	3,245	221,238	Yes	-0.28	5.62	46
300731	LAWTEY	UG	1	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.07	0.73	0
808164	MILAM	Hybrid	588	5	38	4	3.8	0.5	1.2	3.4	5.0	3.9	8.9	657	34,576	Yes	1.61	10.71	11
805738	GALLOWAY	Hybrid	1,586	9	47	4	2.2	0.3	4.0	8.6	6.2	8.9	15.1	558	93,428	Yes	-0.27	8.53	32
700436	OAKLAND PARK	Hybrid	1,441	17	12	3	3.1	0.1	6.8	2.2	9.9	2.3	12.2	2,088	111,227	Yes	-0.08	6.82	64
704070	MOTOROLA	Hybrid	791	4	16	0	2.2	0.7	1.1	2.1	3.3	2.8	6.1	122	19,567	Yes	-0.13	3.37	9
804132	GARDEN	Hybrid	744	8	19	2	2.2	0.1	3.2	2.8	5.4	2.9	8.3	147	27,700	Yes	0.12	5.22	25
804733	HAULOVER	Hybrid	1,214	2	11	0	1.6	2.9	0.1	2.3	1.7	5.2	6.9	238	4,375	Yes	0.11	4.91	4
704938	LAKEVIEW	Hybrid	1,495	0	17	0	1.6	1.3	-	10.3	1.6	11.6	13.2	600	22,664	Yes	-0.10	4.50	11
812163	BEACON	UG	28	0	1	0	-	2.3	-	-	-	2.3	2.3	-	-	Yes	-1.59	6.11	0
407464	INDRIO	Hybrid	2,330	33	28	5	14.4	3.2	16.5	11.0	30.9	14.2	45.1	3,286	63,030	Yes	-0.27	8.73	39
407036	RIO	Hybrid	1,649	23	31	3	3.7	4.6	5.4	6.9	9.1	11.5	20.6	87	13,299	Yes	-0.22	4.68	19
404331	IBM	UG	1	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	-0.06	3.54	0
700535	POMPANO	Hybrid	1,747	19	13	2	2.7	0.7	5.6	2.9	8.3	3.6	11.9	306	51,082	Yes	-0.19	5.61	30
208166	HIELD	Hybrid	2,508	25	44	11	12.2	2.5	16.2	14.0	28.4	16.5	44.9	964	30,139	Yes	0.06	12.06	29
705864	REMSBURG	Hybrid	2,873	3	37	0	2.4	2.8	1.6	17.9	4.0	20.7	24.7	1,284	72,772	Yes	-0.11	12.19	26
700444	OAKLAND PARK	Hybrid	1,514	24	11	3	2.4	0.6	4.3	1.4	6.7	2.0	8.7	138	25,998	Yes	1.50	4.50	23
406237	OAKES	Hybrid	1,484	5	41	3	4.2	2.2	1.0	11.4	5.2	13.6	18.8	108	16,835	Yes	0.31	5.91	13
405268	ACME	UG	1,554	0	44	0	0.8	5.7	-	19.4	0.8	25.1	25.9	1,499	26,344	Yes	-0.12	10.38	8
802834	ARCH CREEK	Hybrid	1,501	8	17	4	1.9	0.6	1.7	2.8	3.6	3.4	7.0	4,667	109,729	Yes	0.01	6.31	20
701739	STIRLING	Hybrid	730	3	44	1	3.4	0.9	0.6	3.7	4.0	4.6	8.6	164	23,132	Yes	0.51	5.11	12
810064	AVOCADO	Hybrid	965	73	5	5	11.5	0.8	36.9	2.0	48.4	2.8	51.2	726	116,289	Yes	-0.31	6.69	86
502838	PAYNE	Hybrid	667	0	12	1	0.2	2.1	0.1	1.5	0.3	3.6	3.9	590	23,126	Yes	-0.73	3.87	1
200434	COCOA	Hybrid	1,738	41	24	11	5.3	0.3	8.4	1.6	13.7	1.9	15.6	666	34,581	Yes	-0.18	6.82	24
807037	ROSELAWN	Hybrid	1,092	2	32	1	2.3	1.5	0.2	2.6	2.5	4.1	6.6	685	3,341	Yes	0.34	5.94	6
503763	HARBOR	Hybrid	1,262	15	4	3	3.3	0.3	11.1	1.5	14.4	1.8	16.2	1,562	32,846	Yes	0.16	5.66	23
703234	WOODLANDS	UG	3,035	0	16	0	-	1.6	-	8.4	-	10.0	10.0	1,325	21,015	Yes	-0.62	5.08	1
807435	VILLAGE GREEN	Hybrid	1,936	5	22	0	2.5	2.5	0.8	13.5	3.3	16.0	19.3	1,352	39,445	Yes	-1.48	7.72	24
108262	LPGA	UG	2,853	2	38	0	1.2	8.2	0.7	38.8	1.9	47.0	48.9	105	13,530	Yes	0.64	7.44	11
707131	CULLUM	UG	2,138	0	34	0	-	4.8	-	15.2	-	20.0	20.0	2,228	65,547	Yes	-0.30	9.00	4
101865	ORANGEDALE	Hybrid	199	11	4	2	4.9	0.1	5.5	2.8	10.4	2.9	13.3	54	12,626	Yes	-0.03	0.77	8
805131	LAWRENCE	Hybrid	1,874	22	11	6	2.3	0.3	4.9	1.1	7.2	1.4	8.6	4,825	204,494	Yes	-3.61	7.19	23
108434	SAN MATEO	Hybrid	1,395	83	9	6	15.7	2.1	39.9	3.7	55.6	5.8	61.4	606	98,364	Yes	-0.29	4.11	92
803435	MIAMI SHORES	Hybrid	1,612	25	6	2	2.8	0.3	7.0	0.3	9.8	0.6	10.4	4,924	285,045	Yes	-0.20	5.30	88
402136	TERMINAL	Hybrid	996	0	29	0	0.6	3.5	-	7.1	0.6	10.6	11.2	115	11,931	Yes	0.57	7.87	8
401232	BRIGHTON	OH	203	23	1	3	22.2	-	44.8	1.5	67.0	1.5	68.5	406	86,957	Yes	-0.07	0.53	24
201035	EAU GALLIE	Hybrid	861	6	11	4	2.9	0.1	2.8	3.1	5.7	3.2	8.9	318	28,653	Yes	0.27	3.47	8
809664	COURT	Hybrid	3,391	1	72	1	4.7	4.9	0.7	30.6	5.4	35.5	40.9	606	102,469	Yes	0.16	17.36	36
800533	RIVERSIDE	Hybrid	1,104	7	19	0	2.0	0.9	2.0	2.3	4.0	3.2	7.2	205	31,995	Yes	-0.59	6.11	17
702938	HAWKINS	Hybrid	2,016	12	31	3	3.4	2.2	2.6	14.8	6.0	17.0	23.0	2,570	62,274	Yes	-0.41	7.19	39
407563	GLENDALE	Hybrid	537	19	14	3	15.7	1.1	10.7	4.5	26.4	5.6	32.0	50	8,608	Yes	-0.22	4.28	6
502933	ONECO	Hybrid	1,752	10	28	2	2.9	0.3	4.5	6.7	7.4	7.0	14.4	1,082	106,216	Yes	-0.32	6.28	31
201735	SYKES CREEK	Hybrid	1,140	18	10	2	4.2	1.0	7.2	2.3	11.4	3.3	14.7	171	24,089	Yes	-0.42	4.68	27
101032	HOLLY HILL	Hybrid	1,199	24	5	2	2.4	1.9	5.2	0.6	7.6	2.5	10.1	307	33,301	Yes	-0.22	3.68	34

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
406764	ACREAGE	OH	2,370	72	11	1	14.2	0.5	56.2	0.9	70.4	1.4	71.8	1,841	180,198	Yes	-0.39	14.21	79
810732	MCGREGOR	Hybrid	16	5	6	1	7.1	1.0	1.6	1.9	8.7	2.9	11.6	3	265	Yes	0.02	1.32	3
500435	HYDE PARK	Hybrid	2,008	15	18	9	3.1	-	8.2	9.3	11.3	9.3	20.6	314	29,028	Yes	-0.33	7.67	46
510364	PIRATE	Hybrid	1,451	14	23	5	3.8	1.8	5.5	13.2	9.3	15.0	24.3	202	25,499	Yes	-0.47	6.73	17
409431	SKYPASS	Hybrid	712	17	10	1	2.0	1.2	2.9	1.5	4.9	2.7	7.6	256	45,205	Yes	0.03	3.03	21
506464	FRANKLIN	Hybrid	3,127	49	4	12	9.3	0.4	68.3	3.8	77.6	4.2	81.8	963	125,307	Yes	0.25	12.55	93
404233	BOCA TECCA	Hybrid	2,529	2	40	1	2.4	0.4	0.4	2.9	2.8	3.3	6.1	141	13,913	Yes	-0.34	6.96	10
806237	INDIAN CREEK	Hybrid	397	5	6	0	3.2	0.7	0.2	1.7	3.4	2.4	5.8	1,537	108,560	Yes	-0.35	4.15	16
802636	AIRPORT	Hybrid	375	6	10	1	1.5	0.7	1.1	1.7	2.6	2.4	5.0	102	15,389	Yes	-0.08	3.52	6
406539	OSBORNE	Hybrid	767	3	23	0	1.8	0.8	0.8	7.2	2.6	8.0	10.6	62	10,626	Yes	0.29	3.09	12
102232	MADISON	Hybrid	273	6	3	1	1.6	0.7	1.8	0.2	3.4	0.9	4.3	148	24,185	Yes	-0.17	2.13	19
200537	MELBOURNE	Hybrid	126	6	13	3	2.1	0.2	0.8	1.0	2.9	1.2	4.1	138	10,265	Yes	1.79	5.69	5
805132	LAWRENCE	Hybrid	1,160	15	7	2	2.2	0.3	1.7	0.3	3.9	0.6	4.5	57	5,617	Yes	0.11	5.11	10
706865	CONSERVATION	Hybrid	2,272	0	31	0	1.9	2.5	0.2	8.7	2.1	11.2	13.3	291	48,562	Yes	-0.46	8.04	15
701938	HOLY CROSS	OH	1,512	12	0	4	2.6	0.3	6.9	0.1	9.5	0.4	9.9	2,750	171,745	Yes	-0.16	5.64	51
804036	LE JEUNE	Hybrid	127	4	12	0	2.2	1.3	0.1	0.8	2.3	2.1	4.4	14	3,727	Yes	-0.40	3.40	3
706665	NOBHILL	Hybrid	3,935	1	49	1	3.4	4.9	0.3	18.6	3.7	23.5	27.2	174	18,814	Yes	-1.15	13.55	14
700440	OAKLAND PARK	Hybrid	185	2	15	0	1.0	1.9	0.8	1.0	1.8	2.9	4.7	118	22,549	Yes	1.35	3.15	5
507361	ORANGETREE	OH	2,417	104	8	9	11.1	0.1	71.2	1.5	82.3	1.6	83.9	8,154	174,097	Yes	-0.02	12.48	95
802634	AIRPORT	UG	4	0	1	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	0.14	1.84	0
407235	JOG	Hybrid	1,974	28	22	7	7.7	1.6	12.8	7.0	20.5	8.6	29.1	719	105,830	Yes	-0.65	9.35	74
411036	EDEN	Hybrid	1,518	15	14	1	2.7	3.2	12.2	5.8	14.9	9.0	23.9	952	20,169	Yes	7.17	7.17	29
505264	RUBONIA	Hybrid	2,924	46	24	13	8.2	0.3	22.4	7.4	30.6	7.7	38.3	1,815	118,740	Yes	-1.55	12.25	78
702636	ELY	Hybrid	1,780	4	19	3	2.9	0.4	2.5	3.8	5.4	4.2	9.6	336	65,354	Yes	0.21	5.51	12
814035	BRICKELL	Hybrid	2,176	9	20	3	2.4	0.7	1.0	0.7	3.4	1.4	4.8	2,290	43,049	Yes	0.01	5.72	18
709431	ANDREWS	Hybrid	319	5	32	2	2.8	0.3	0.6	4.4	3.4	4.7	8.1	8	1,322	Yes	-0.65	8.25	4
707532	COLLINS	Hybrid	1,477	12	35	6	3.2	1.2	2.1	6.6	5.3	7.8	13.1	80	13,399	Yes	-0.57	7.63	15
502464	LABELLE	Hybrid	4,057	104	33	34	25.8	0.1	105.3	15.6	131.1	15.7	146.8	8,269	747,510	Yes	0.02	13.42	138
702631	ELY	Hybrid	2,585	14	18	3	3.1	2.6	3.3	2.1	6.4	4.7	11.1	3,107	98,966	Yes	1.03	6.73	27
502831	PAYNE	UG	1,473	0	32	1	0.2	8.7	-	9.8	0.2	18.5	18.7	2,933	161,959	Yes	0.05	7.85	17
805636	MILLER	Hybrid	1,818	21	7	1	2.8	0.6	12.5	4.0	15.3	4.6	19.9	4,887	279,730	Yes	-0.06	8.94	52
701042	SAMPLE ROAD	Hybrid	1,115	15	12	1	1.0	4.1	3.0	1.9	4.0	6.0	10.0	170	27,094	Yes	0.16	3.76	22
707931	TWINLAKES	Hybrid	468	9	25	1	3.3	0.5	2.0	2.7	5.3	3.2	8.5	408	39,168	Yes	1.87	5.57	10
703236	WOODLANDS	Hybrid	2,224	1	31	0	1.5	2.1	-	11.9	1.5	14.0	15.5	1,928	72,972	Yes	-1.63	6.57	11
507565	PARRISH	Hybrid	2,052	26	33	15	5.5	4.0	16.1	9.3	21.6	13.3	34.9	1,034	189,220	Yes	-0.52	10.48	35
806837	RED ROAD	Hybrid	903	22	6	2	2.7	0.6	5.7	0.5	8.4	1.1	9.5	202	41,450	Yes	-0.02	6.48	24
504432	CLEVELAND	Hybrid	1,738	27	27	9	5.9	-	15.8	10.2	21.7	10.2	31.9	2,830	67,048	Yes	-0.06	5.44	36
802036	CUTLER	Hybrid	1,007	24	16	5	4.9	3.6	6.7	6.7	11.6	10.3	21.9	4,380	295,632	Yes	-0.14	6.66	58
812732	NATURAL BRIDGE	UG	782	0	3	0	-	5.1	-	0.9	-	6.0	6.0	-	-	Yes	0.23	5.53	0
411663	PEACOCK	Hybrid	2,349	19	28	4	6.9	4.5	24.4	9.6	31.3	14.1	45.4	1,360	82,190	Yes	-0.20	10.80	39
708561	SILVERLAKES	Hybrid	1,166	4	34	0	3.3	1.6	0.8	15.9	4.1	17.5	21.6	1,200	7,484	Yes	-0.27	7.23	10
805137	LAWRENCE	Hybrid	1,799	15	9	7	3.1	0.7	4.0	0.6	7.1	1.3	8.4	607	117,539	Yes	0.01	6.51	26
405868	DELTRAIL	Hybrid	3,111	1	61	0	4.1	6.2	0.3	27.4	4.4	33.6	38.0	153	20,682	Yes	-0.18	11.32	10
404740	HILLSBORO	UG	804	1	17	0	0.3	3.1	0.1	15.1	0.4	18.2	18.6	59	7,826	Yes	-0.16	8.34	13
806736	IVES	Hybrid	2,325	1	26	0	2.0	2.7	0.3	9.0	2.3	11.7	14.0	315	43,059	Yes	-0.17	6.63	14
500538	CLARK	Hybrid	1,742	14	25	5	3.1	0.4	7.5	7.4	10.6	7.8	18.4	336	45,877	Yes	-0.63	6.27	39
814042	BRICKELL	UG	11	0	4	0	-	2.3	-	0.1	-	2.4	2.4	-	-	Yes	-0.01	2.99	0
503261	COCOPLUM	Hybrid	3,900	17	31	4	6.9	0.6	24.4	17.6	31.3	18.2	49.5	4,489	289,746	Yes	0.17	10.47	56
703732	CRYSTAL	Hybrid	366	5	23	4	2.9	0.1	1.1	1.9	4.0	2.0	6.0	229	50,179	Yes	-0.66	5.44	7
702236	MARGATE	Hybrid	1,272	0	21	1	1.5	1.4	0.3	5.5	1.8	6.9	8.7	22	3,244	Yes	-0.16	6.34	5
802733	MARION	Hybrid	509	4	29	1	1.1	0.8	0.4	4.8	1.5	5.6	7.1	557	24,863	Yes	-0.10	7.00	5
407033	RIO	Hybrid	1,514	18	14	6	3.8	0.3	8.5	5.3	12.3	5.6	17.9	400	47,209	Yes	-0.05	5.75	31

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
504966	GOLDEN GATE	Hybrid	2,908	29	7	11	4.7	0.3	23.0	3.5	27.7	3.8	31.5	9,544	161,833	Yes	-0.35	9.95	68
104432	NOVA	Hybrid	99	6	19	0	1.1	1.7	0.8	4.4	1.9	6.1	8.0	12	1,668	Yes	-0.06	6.64	1
802833	ARCH CREEK	Hybrid	2,190	40	12	11	3.8	0.3	10.4	1.1	14.2	1.4	15.6	2,109	151,823	Yes	0.16	8.36	80
707732	GOOLSBY	Hybrid	1,824	5	38	1	2.4	0.3	0.6	8.5	3.0	8.8	11.8	59	12,349	Yes	0.36	8.76	8
301464	YULEE	Hybrid	1,792	41	24	3	7.9	1.8	23.1	12.5	31.0	14.3	45.3	791	70,245	Yes	4.34	7.84	42
102362	ST JOE	Hybrid	1,885	25	10	0	4.8	1.4	16.5	1.5	21.3	2.9	24.2	2,559	126,295	Yes	1.32	14.32	44
101862	ORANGEDALE	Hybrid	1,550	18	41	4	5.0	8.2	6.9	26.8	11.9	35.0	46.9	757	42,150	Yes	-9.17	4.53	25
800633	LITTLE RIVER	Hybrid	1,695	24	8	3	2.9	0.3	4.3	0.8	7.2	1.1	8.3	772	79,598	Yes	-0.02	7.98	60
413331	SAILFISH	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	0.11	0.21	0
108433	SAN MATEO	Hybrid	1,230	64	13	11	9.4	0.3	27.8	2.4	37.2	2.7	39.9	1,046	41,862	Yes	-1.17	4.73	58
301561	WIREMILL	Hybrid	-	0	4	0	0.3	0.2	-	0.1	0.3	0.3	0.6	-	-	Yes	0.03	6.53	0
800138	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.06	2.16	0
508464	GATEWAY	Hybrid	4,191	1	56	3	2.2	9.8	0.9	43.0	3.1	52.8	55.9	4,320	149,159	Yes	0.35	13.95	22
812834	WILCOX	UG	32	0	1	0	-	2.1	-	-	-	2.1	2.1	-	-	Yes	-0.27	2.43	0
809335	RONEY	Hybrid	307	2	6	1	0.2	1.9	0.2	0.3	0.4	2.2	2.6	18	378	Yes	-0.07	2.23	1
802037	CUTLER	Hybrid	734	26	8	3	2.8	0.5	12.5	3.5	15.3	4.0	19.3	509	104,933	Yes	-0.19	5.91	73
506166	METRO	Hybrid	1,586	6	47	7	4.0	1.1	2.5	5.8	6.5	6.9	13.4	138	38,398	Yes	-0.18	7.22	19
503766	HARBOR	Hybrid	2,710	45	7	4	8.0	0.4	22.8	1.4	30.8	1.8	32.6	877	130,273	Yes	-0.14	9.76	94
701931	HOLY CROSS	Hybrid	1,516	8	27	8	3.8	0.3	4.0	1.3	7.8	1.6	9.4	3,289	117,578	Yes	-0.01	7.99	27
406231	OAKES	Hybrid	2,707	0	37	0	2.9	0.8	-	16.3	2.9	17.1	20.0	557	44,969	Yes	-1.35	7.35	17
806333	ULETA	Hybrid	2,528	25	11	3	3.2	0.1	8.7	1.6	11.9	1.7	13.6	6,827	355,192	Yes	-0.47	7.83	91
802637	AIRPORT	UG	9	0	2	0	-	4.0	-	0.4	-	4.4	4.4	-	-	Yes	-0.95	0.75	0
202531	AURORA	Hybrid	1,774	8	35	6	2.6	0.3	6.0	8.1	8.6	8.4	17.0	1,696	38,818	Yes	-1.10	6.60	18
401136	STUART	Hybrid	1,877	11	34	3	3.1	0.8	2.6	6.9	5.7	7.7	13.4	133	16,152	Yes	-0.16	4.24	22
810936	LATIN QUARTER	UG	4	0	0	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	1.37	2.77	0
812161	BEACON	Hybrid	531	3	26	1	1.8	2.3	1.1	5.8	2.9	8.1	11.0	1,965	65,443	Yes	0.17	6.07	15
810835	BELL	Hybrid	390	0	30	0	1.7	1.3	-	5.3	1.7	6.6	8.3	393	44,378	Yes	0.21	6.81	3
806331	ULETA	Hybrid	2,224	14	17	5	3.3	0.3	4.7	1.5	8.0	1.8	9.8	2,775	84,192	Yes	-0.50	6.90	40
403734	MONET	UG	298	0	10	0	-	4.4	-	1.6	-	6.0	6.0	-	-	Yes	0.12	1.72	0
506261	SHADE	Hybrid	2,180	14	42	12	4.9	0.4	6.5	13.9	11.4	14.3	25.7	1,273	185,563	Yes	-0.16	10.14	40
700639	VERENA	Hybrid	1,766	24	20	5	3.4	0.6	3.7	1.8	7.1	2.4	9.5	5,278	182,201	Yes	-1.37	6.53	51
802131	MIRAMAR	Hybrid	1,922	20	17	3	4.9	0.5	3.9	1.0	8.8	1.5	10.3	2,387	57,322	Yes	0.71	8.91	31
801933	DEAUVILLE	Hybrid	89	0	5	0	0.3	0.1	-	0.2	0.3	0.3	0.6	5	2,198	Yes	-0.01	0.79	3
102432	FLEMING	Hybrid	1,150	16	15	7	4.9	0.7	5.7	5.6	10.6	6.3	16.9	1,485	51,077	Yes	0.02	4.52	26
702435	PEMBROKE	Hybrid	2,400	5	27	6	3.0	0.8	3.3	5.1	6.3	5.9	12.2	361	50,766	Yes	-0.07	8.13	17
204532	BARWICK	Hybrid	261	0	0	1	0.1	0.4	1.2	1.3	1.3	1.7	3.0	19	775	Yes	-0.12	0.88	5
811431	WATKINS	Hybrid	43	0	6	1	0.4	4.6	0.1	1.6	0.5	6.2	6.7	-	-	Yes	-0.15	2.25	0
810563	JASMINE	UG	2,431	1	28	0	-	7.0	-	16.7	-	23.7	23.7	69	19,976	Yes	-0.15	12.35	2
800849	RAILWAY	UG	581	0	7	0	-	4.8	-	0.5	-	5.3	5.3	-	-	Yes	-0.67	5.43	0
500161	SARASOTA	Hybrid	3,388	16	56	0	2.7	7.9	4.4	23.6	7.1	31.5	38.6	5	776	Yes	0.34	11.14	2
308062	MILLS	Hybrid	521	35	7	12	22.2	0.7	28.6	4.7	50.8	5.4	56.2	2,078	285,364	Yes	-0.01	2.59	20
404040	WESTWARD	Hybrid	561	9	24	6	2.5	0.3	2.5	2.3	5.0	2.6	7.6	779	40,895	Yes	0.48	5.28	16
101864	ORANGEDALE	Hybrid	2,546	2	42	0	4.0	5.7	0.2	41.1	4.2	46.8	51.0	1,155	74,684	Yes	0.13	10.83	1
804832	COUNTY LINE	Hybrid	1,753	29	7	3	3.3	0.4	10.8	2.3	14.1	2.7	16.8	530	104,707	Yes	-0.11	9.49	59
414134	CANAL	Hybrid	1,217	12	9	7	1.8	0.1	8.2	2.7	10.0	2.8	12.8	1,771	71,083	Yes	-0.73	4.27	35
202033	INDIAN HARBOR	Hybrid	2,242	11	17	7	1.4	2.1	8.8	3.7	10.2	5.8	16.0	732	82,631	Yes	-0.20	6.90	48
800242	MIAMI BEACH	UG	308	0	7	0	-	3.2	-	0.8	-	4.0	4.0	120	3,954	Yes	0.16	3.16	2
705166	JACARANDA	Hybrid	1,407	0	38	0	1.7	3.3	-	13.4	1.7	16.7	18.4	1,496	46,263	Yes	0.17	12.37	14
704063	MOTOROLA	Hybrid	2,187	14	13	4	3.0	0.5	6.3	6.9	9.3	7.4	16.7	3,099	31,438	Yes	0.06	8.06	28
708932	HACIENDA	Hybrid	1,239	25	11	4	3.2	0.9	5.8	2.3	9.0	3.2	12.2	766	118,176	Yes	0.36	6.06	42
709832	FESTIVAL	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.04	9.14	0
812931	WOLFSON	UG	565	0	6	0	-	2.7	-	0.8	-	3.5	3.5	-	-	Yes	1.87	1.87	0

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
404734	HILLSBORO	Hybrid	1,860	1	20	0	4.7	2.7	0.1	9.4	4.8	12.1	16.9	1,934	108,856	Yes	0.03	6.03	15
501061	FRUITVILLE	Hybrid	2,946	17	63	6	7.5	0.7	6.6	19.6	14.1	20.3	34.4	4,764	171,058	Yes	-0.91	12.49	39
705235	TIMBERLAKE	Hybrid	2,793	14	36	9	3.2	1.1	5.5	10.9	8.7	12.0	20.7	205	27,025	Yes	0.05	5.25	22
405937	BUTTS	UG	771	0	19	0	-	2.2	-	8.7	-	10.9	10.9	8	1,853	Yes	-2.00	4.50	8
501764	IONA	Hybrid	3,895	10	45	7	3.8	1.5	3.0	22.6	6.8	24.1	30.9	9,596	126,651	Yes	0.15	12.65	41
508161	INTERSTATE	Hybrid	4,529	2	66	1	4.7	7.9	0.6	55.1	5.3	63.0	68.3	3,992	334,927	Yes	0.37	13.07	22
207363	WYOMING	Hybrid	2,495	37	35	1	5.9	2.9	14.2	29.4	20.1	32.3	52.4	1,656	41,934	Yes	0.91	10.81	14
805440	DADE	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	2.69	4.69	0
405466	CLINTMOORE	Hybrid	2,074	2	37	4	4.3	1.9	2.2	27.7	6.5	29.6	36.1	4,354	183,408	Yes	-0.04	12.36	32
504833	SORRENTO	Hybrid	1,476	22	23	2	3.5	3.3	11.2	18.8	14.7	22.1	36.8	263	43,089	Yes	-0.45	6.45	31
812362	URBAN	Hybrid	594	1	23	0	0.9	5.3	0.6	8.4	1.5	13.7	15.2	979	32,851	Yes	-0.26	10.84	8
802936	GRAPELAND	Hybrid	1,925	13	12	6	2.5	0.9	3.9	1.2	6.4	2.1	8.5	3,063	198,300	Yes	-2.01	6.89	15
205431	MERRITT	Hybrid	1,972	67	26	9	6.0	0.6	16.1	7.9	22.1	8.5	30.6	4,027	105,680	Yes	-0.45	7.35	50
101035	HOLLY HILL	Hybrid	785	5	8	1	1.3	2.6	1.3	2.0	2.6	4.6	7.2	457	31,775	Yes	0.13	3.53	12
800537	RIVERSIDE	Hybrid	1,366	3	18	1	1.0	2.9	0.2	2.8	1.2	5.7	6.9	1,469	4,835	Yes	-0.89	6.11	5
705231	TIMBERLAKE	Hybrid	1,327	11	24	3	3.4	0.1	4.5	10.2	7.9	10.3	18.2	1,644	78,924	Yes	-0.19	7.61	46
812731	NATURAL BRIDGE	UG	1,254	0	0	0	-	3.6	-	-	-	3.6	3.6	-	-	Yes	0.13	6.03	0
400336	NORTHWOOD	Hybrid	1,477	33	9	0	5.3	0.4	5.0	0.8	10.3	1.2	11.5	304	41,197	Yes	-0.33	7.97	42
203331	SOUTH CAPE	Hybrid	122	3	17	5	5.4	1.5	1.8	4.1	7.2	5.6	12.8	133	6,734	Yes	-0.02	3.88	9
400733	BOCA RATON	Hybrid	757	7	13	6	2.4	1.1	1.8	1.8	4.2	2.9	7.1	850	25,565	Yes	0.03	5.93	16
703434	RESERVATION	Hybrid	627	9	14	2	2.2	0.5	3.2	3.1	5.4	3.6	9.0	198	41,581	Yes	-0.41	4.09	11
706961	CHAPEL	Hybrid	1,962	6	43	1	6.3	1.9	3.4	20.4	9.7	22.3	32.0	2,013	16,247	Yes	-0.62	12.48	14
804532	GRATIGNY	Hybrid	1,683	6	20	1	1.8	1.3	1.2	4.5	3.0	5.8	8.8	1,240	23,381	Yes	1.19	7.99	13
405133	HUTCHINSON ISL	Hybrid	425	2	9	0	0.7	2.1	0.7	2.5	1.4	4.6	6.0	-	-	Yes	-0.04	0.96	0
201231	TROPICANA	Hybrid	2,703	16	19	6	2.0	0.5	4.3	4.5	6.3	5.0	11.3	360	59,647	Yes	0.36	5.36	28
411031	EDEN	Hybrid	1,724	24	2	0	2.4	0.1	19.2	1.1	21.6	1.2	22.8	735	18,084	Yes	-2.34	6.66	29
809763	SWEETWATER	Hybrid	2,048	1	41	16	5.2	0.5	4.3	18.2	9.5	18.7	28.2	1,586	94,945	Yes	-0.41	12.69	35
806039	GOLDEN GLADES	Hybrid	544	13	4	2	1.4	1.8	4.0	0.5	5.4	2.3	7.7	296	50,629	Yes	0.11	4.41	42
702732	MCARTHUR	Hybrid	2,261	14	16	2	2.6	-	6.3	4.0	8.9	4.0	12.9	1,020	147,781	Yes	0.01	7.31	57
809663	COURT	Hybrid	1,850	0	40	1	0.7	2.4	0.7	13.8	1.4	16.2	17.6	3,409	85,399	Yes	-0.31	8.99	29
705768	TRACE	Hybrid	2,591	1	45	1	3.3	0.4	0.1	21.0	3.4	21.4	24.8	139	30,050	Yes	-0.46	9.74	15
806937	BIRD	Hybrid	1,077	18	0	2	2.1	0.7	6.1	0.2	8.2	0.9	9.1	769	73,426	Yes	0.03	5.03	31
814039	BRICKELL	UG	37	0	4	0	-	1.5	-	0.5	-	2.0	2.0	-	-	Yes	0.09	2.39	0
707661	CROSSBOW	Hybrid	761	11	19	4	4.2	1.1	5.7	10.4	9.9	11.5	21.4	43	9,063	Yes	0.02	5.42	10
403031	MILITARY TRAIL	Hybrid	672	17	22	2	4.5	0.1	5.2	2.9	9.7	3.0	12.7	75	10,732	Yes	0.12	6.42	25
811564	KOGER	Hybrid	3,259	3	58	3	3.4	4.6	1.1	17.2	4.5	21.8	26.3	10,496	190,577	Yes	-2.77	12.53	13
810431	BLUE LAGOON	Hybrid	195	0	6	0	0.3	1.6	-	0.6	0.3	2.2	2.5	1	255	Yes	0.11	5.01	1
400662	WABASSO	Hybrid	1,668	56	58	8	11.2	2.3	17.6	23.2	28.8	25.5	54.3	4,549	234,787	Yes	0.17	6.37	54
205931	SYLVAN	Hybrid	893	9	36	5	2.9	6.6	6.3	20.1	9.2	26.7	35.9	168	21,579	Yes	-0.23	5.27	15
204132	SATELLITE	Hybrid	1,119	25	3	5	1.5	0.8	8.0	1.5	9.5	2.3	11.8	1,235	124,921	Yes	-0.49	4.61	37
805437	DADE	UG	-	0	0	0	-	3.0	-	-	-	3.0	3.0	-	-	Yes	-0.03	2.17	0
401831	JUPITER	Hybrid	1,326	19	28	6	3.7	0.8	5.6	4.9	9.3	5.7	15.0	377	29,009	Yes	-0.22	5.48	30
209933	LIGHTHOUSE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.17	0.03	0
503036	PHILLIPPI	Hybrid	1,821	7	30	8	3.5	1.2	6.4	8.9	9.9	10.1	20.0	242	44,142	Yes	-0.38	7.82	33
504136	BENEVA	Hybrid	1,687	16	25	6	3.3	0.3	6.8	4.8	10.1	5.1	15.2	1,194	76,982	Yes	-0.30	5.50	37
301465	YULEE	Hybrid	2,461	19	51	6	11.5	10.5	13.2	32.1	24.7	42.6	67.3	2,556	110,459	Yes	0.40	8.90	21
805933	COUNTRY CLUB	Hybrid	1,698	8	33	4	4.0	0.9	3.0	7.7	7.0	8.6	15.6	295	28,927	Yes	0.58	8.58	20
800332	BUENA VISTA	Hybrid	940	10	22	5	2.4	2.4	2.5	4.6	4.9	7.0	11.9	736	37,541	Yes	0.18	8.78	35
800841	RAILWAY	UG	149	1	9	1	-	5.1	0.1	0.9	0.1	6.0	6.1	3	1,560	Yes	-0.01	4.79	1
809234	MITCHELL	Hybrid	1,397	15	13	1	1.6	1.9	3.4	14.0	5.0	15.9	20.9	351	75,990	Yes	-0.16	6.64	39
200134	SANFORD	Hybrid	592	11	8	6	2.9	0.6	2.2	2.5	5.1	3.1	8.2	54	5,435	Yes	0.07	3.67	7
207264	CHULUOTA	Hybrid	839	32	9	13	5.3	0.6	15.0	2.6	20.3	3.2	23.5	32	6,048	Yes	0.00	0.00	1

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY-pk Prior)	Peak Load (MVA)	Number of N on FDR
501761	IONA	Hybrid	3,789	16	41	7	4.1	0.2	5.4	13.3	9.5	13.5	23.0	3,286	193,610	Yes	0.27	11.17	51
809939	SIMPSON	UG	1,547	0	12	0	-	2.9	-	0.9	-	3.8	3.8	-	-	Yes	0.38	5.88	0
404134	GOLF	Hybrid	1,307	5	32	5	4.0	0.6	2.3	9.5	6.3	10.1	16.4	3,202	95,597	Yes	-0.20	7.10	21
507661	GLADIOLUS	Hybrid	939	3	29	1	3.1	2.6	1.3	10.7	4.4	13.3	17.7	2,218	56,767	Yes	-0.11	10.79	11
811435	WATKINS	Hybrid	235	1	20	0	1.4	0.6	-	3.0	1.4	3.6	5.0	27	4,477	Yes	-0.04	5.66	3
802635	AIRPORT	Hybrid	753	14	23	0	3.6	0.6	3.0	1.3	6.6	1.9	8.5	397	35,700	Yes	-0.22	5.58	30
808536	SEMINOLA	UG	2	0	0	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	-1.54	1.96	0
701040	SAMPLE ROAD	Hybrid	628	1	7	4	0.4	3.4	0.5	0.9	0.9	4.3	5.2	736	38,743	Yes	-0.01	2.39	4
803433	MIAMI SHORES	OH	1,539	32	2	2	2.9	0.1	10.8	0.2	13.7	0.3	14.0	2,699	162,955	Yes	-0.14	7.86	73
709031	SPANGLER	UG	15	0	1	0	-	4.1	-	0.3	-	4.4	4.4	-	-	Yes	0.60	4.50	0
510363	PIRATE	Hybrid	941	16	29	6	4.2	1.3	5.1	3.5	9.3	4.8	14.1	16	4,417	Yes	0.69	7.69	10
804139	GARDEN	Hybrid	1,195	13	16	6	5.2	0.2	4.8	2.3	10.0	2.5	12.5	335	66,676	Yes	0.46	7.96	36
800334	BUENA VISTA	Hybrid	420	4	10	0	1.4	1.5	0.1	0.7	1.5	2.2	3.7	14	1,001	Yes	0.23	3.63	4
800333	BUENA VISTA	Hybrid	1,377	16	8	2	3.1	0.5	4.1	0.7	7.2	1.2	8.4	1,709	163,928	Yes	0.01	8.51	70
209762	VIERA	UG	1,330	0	27	0	0.4	3.4	-	12.3	0.4	15.7	16.1	257	1,953	Yes	0.02	8.02	2
808631	BRANDON	Hybrid	1,382	4	20	5	2.3	0.7	3.1	4.5	5.4	5.2	10.6	1,056	40,564	Yes	0.63	4.43	21
807165	PENNSUCO	Hybrid	3,239	6	50	2	3.5	2.5	1.0	18.4	4.5	20.9	25.4	1,556	136,554	Yes	0.05	13.85	18
709263	PROGRESSO	Hybrid	1,569	14	5	8	1.3	2.0	4.1	2.4	5.4	4.4	9.8	552	83,135	Yes	-1.15	5.25	45
204062	DELTONA	OH	1,877	34	4	0	3.6	-	17.3	0.5	20.9	0.5	21.4	3,332	168,310	Yes	-0.11	8.99	29
503034	PHILLIPPI	Hybrid	1,488	37	31	10	4.6	0.3	8.6	3.9	13.2	4.2	17.4	1,026	95,151	Yes	-0.34	7.76	44
504969	GOLDEN GATE	Hybrid	915	6	26	3	4.3	0.8	13.6	4.5	17.9	5.3	23.2	586	73,480	Yes	-0.12	7.88	38
805432	DADE	Hybrid	532	3	42	4	4.0	0.6	1.3	4.1	5.3	4.7	10.0	589	71,067	Yes	0.37	8.17	12
303163	STARKE	UG	-	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.01	17.81	0
806831	RED ROAD	Hybrid	1,049	11	18	0	2.8	0.3	5.3	0.6	8.1	0.9	9.0	722	33,757	Yes	-0.32	6.88	22
104835	TAYLOR	Hybrid	1,768	13	40	9	3.4	4.9	4.2	8.4	7.6	13.3	20.9	238	37,255	Yes	-0.15	5.75	29
405638	FOUNTAIN	Hybrid	2,188	0	36	0	2.9	0.7	0.2	16.7	3.1	17.4	20.5	2,746	59,364	Yes	0.42	8.72	19
508531	HANSON	Hybrid	1,652	51	13	15	6.4	0.4	10.5	1.7	16.9	2.1	19.0	634	90,127	Yes	-0.09	6.81	47
203637	HARRIS	Hybrid	1,649	20	24	1	4.1	0.4	5.0	5.9	9.1	6.3	15.4	4,552	38,501	Yes	-0.07	5.53	23
401763	OLYMPIA	Hybrid	89	8	5	1	5.1	0.6	3.8	2.3	8.9	2.9	11.8	153	10,363	Yes	0.05	0.45	11
802237	GLADEVIEW	Hybrid	1,498	28	13	5	5.5	0.5	5.8	0.6	11.3	1.1	12.4	2,524	101,159	Yes	-0.08	6.32	53
802832	ARCH CREEK	Hybrid	673	7	14	1	1.9	0.1	1.3	0.6	3.2	0.7	3.9	234	51,632	Yes	-0.05	3.15	18
305231	PRICE	Hybrid	1,275	41	11	7	11.3	0.7	19.1	2.3	30.4	3.0	33.4	1,182	32,239	Yes	-0.21	8.19	52
700243	HOLLYWOOD	UG	744	0	3	0	-	1.0	-	0.7	-	1.7	1.7	133	5,985	Yes	0.03	2.23	1
202233	MIMS	Hybrid	1,162	30	12	5	5.9	0.7	9.0	3.4	14.9	4.1	19.0	3,535	77,305	Yes	0.14	5.84	37
700932	HALLANDALE	Hybrid	2,125	3	21	1	2.3	2.2	0.6	4.7	2.9	6.9	9.8	19	4,386	Yes	-0.64	6.86	6
700934	HALLANDALE	Hybrid	2,213	5	28	2	2.2	1.0	2.4	3.6	4.6	4.6	9.2	146	21,247	Yes	-0.15	5.75	17
204063	DELTONA	Hybrid	1,764	35	2	1	4.8	-	16.0	1.4	20.8	1.4	22.2	512	76,314	Yes	-1.37	14.03	47
802437	SOUTH MIAMI	Hybrid	1,254	23	16	6	3.2	0.8	8.4	1.9	11.6	2.7	14.3	2,024	126,318	Yes	0.06	8.56	69
703539	DEERFIELD BEACH	Hybrid	59	0	8	0	1.3	0.8	-	0.9	1.3	1.7	3.0	-	-	Yes	-0.12	0.98	0
708931	HACIENDA	UG	-	0	0	0	-	1.1	-	-	-	1.1	1.1	-	-	Yes	-0.41	4.09	0
703735	CRYSTAL	Hybrid	339	3	18	2	2.2	2.5	1.2	1.5	3.4	4.0	7.4	159	7,143	Yes	0.07	3.47	9
503964	ESTERO	Hybrid	3,300	3	36	3	1.7	7.4	2.1	7.2	3.8	14.6	18.4	241	34,527	Yes	-0.12	7.28	15
703436	RESERVATION	Hybrid	1,041	6	18	0	2.2	2.1	1.5	7.3	3.7	9.4	13.1	1,550	114,036	Yes	-0.09	4.71	28
100131	DAYTONA BEACH	Hybrid	2,003	35	17	4	3.8	1.0	6.7	1.8	10.5	2.8	13.3	406	15,632	Yes	2.26	9.06	27
500635	CORTEZ	Hybrid	2,468	9	41	0	3.4	1.0	1.3	10.6	4.7	11.6	16.3	234	20,618	Yes	0.49	6.29	16
804231	PERRINE	Hybrid	452	4	21	2	1.8	0.1	1.5	3.1	3.3	3.2	6.5	123	38,881	Yes	-2.17	2.93	14
404735	HILLSBORO	Hybrid	1,897	5	24	1	3.5	1.5	3.0	12.7	6.5	14.2	20.7	333	32,308	Yes	0.15	7.35	30
700332	PINEHURST	Hybrid	536	10	8	4	2.2	0.1	2.3	0.6	4.5	0.7	5.2	286	57,023	Yes	-2.99	3.51	28
800440	COCONUT GROVE	Hybrid	996	22	6	5	1.5	2.0	5.7	1.2	7.2	3.2	10.4	392	67,284	Yes	0.49	5.69	55
414335	COBIA	Hybrid	1,106	16	30	10	3.4	0.2	3.7	2.6	7.1	2.8	9.9	718	56,725	Yes	5.80	5.80	28
812167	BEACON	Hybrid	610	1	29	7	2.2	2.3	4.3	5.3	6.5	7.6	14.1	960	56,405	Yes	0.09	13.99	26
802935	GRAPELAND	Hybrid	1,312	13	9	0	2.2	0.3	3.9	0.3	6.1	0.6	6.7	229	39,976	Yes	-0.30	5.30	24

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
102366	ST JOE	Hybrid	2,020	23	47	1	4.4	2.4	14.9	10.8	19.3	13.2	32.5	684	51,910	Yes	0.16	9.56	9
203632	HARRIS	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	2	224	Yes	-0.06	1.14	2
207061	COX	Hybrid	1,983	67	10	7	10.2	10.7	37.6	11.7	47.8	22.4	70.2	2,116	268,985	Yes	-1.31	7.59	89
405332	BEELINE	Hybrid	1,275	4	29	3	4.1	1.2	1.0	6.3	5.1	7.5	12.6	2,753	145,416	Yes	-0.43	7.07	13
700735	FAIRMONT	Hybrid	1,482	21	16	4	4.0	0.1	7.0	2.1	11.0	2.2	13.2	444	56,151	Yes	0.22	6.92	51
404333	IBM	Hybrid	348	6	16	4	2.7	0.5	0.8	3.1	3.5	3.6	7.1	117	9,335	Yes	-0.10	5.90	9
110361	PRINGLE	Hybrid	3,073	29	29	11	8.3	3.9	27.6	8.3	35.9	12.2	48.1	1,972	192,362	Yes	-1.42	13.48	64
409862	HAMLET	Hybrid	1,892	1	23	0	2.4	0.6	-	6.6	2.4	7.2	9.6	96	5,404	Yes	-1.48	3.42	10
506664	LIVINGSTON	Hybrid	4,241	23	56	7	8.2	0.2	8.0	25.9	16.2	26.1	42.3	4,858	187,695	Yes	-1.22	11.28	52
101461	FLAGLER BEACH	Hybrid	2,702	29	36	4	9.6	3.1	24.8	13.7	34.4	16.8	51.2	737	49,196	Yes	0.20	12.00	18
805138	LAWRENCE	Hybrid	2,214	8	14	2	2.1	1.0	1.6	0.4	3.7	1.4	5.1	525	38,489	Yes	0.08	6.58	16
501240	NAPLES	Hybrid	913	3	41	10	3.4	2.4	4.9	8.7	8.3	11.1	19.4	954	102,894	Yes	0.04	8.74	45
409765	CATCHMENT	Hybrid	3,851	5	73	3	4.8	2.0	1.9	22.5	6.7	24.5	31.2	652	76,132	Yes	-0.49	11.61	36
202831	HOLLAND PARK	Hybrid	1,228	6	8	1	0.8	-	1.5	4.8	2.3	4.8	7.1	3,870	283,980	Yes	-7.26	2.64	48
805035	UNIVERSITY	Hybrid	802	33	11	3	4.1	1.7	7.0	1.1	11.1	2.8	13.9	1,274	82,941	Yes	-0.57	7.73	61
808261	LINDGREN	UG	3,522	0	27	0	0.6	3.7	-	23.1	0.6	26.8	27.4	231	41,927	Yes	-0.55	11.45	22
803631	SEABOARD	Hybrid	1,584	24	1	1	2.0	1.3	7.0	0.1	9.0	1.4	10.4	1,363	57,474	Yes	0.01	7.51	57
407734	SQUARE LAKE	Hybrid	920	2	16	0	3.3	2.8	0.1	10.9	3.4	13.7	17.1	1,103	32,388	Yes	-0.09	4.91	7
700337	PINEHURST	Hybrid	1,131	17	14	2	1.5	0.1	4.8	3.8	6.3	3.9	10.2	1,023	105,335	Yes	-2.39	6.71	33
501431	ARCADIA	Hybrid	1,980	68	19	11	14.7	0.3	61.3	5.7	76.0	6.0	82.0	744	99,815	Yes	0.12	7.32	65
507165	POLO	UG	2,130	0	50	0	-	11.5	-	35.3	-	46.8	46.8	3,874	121,429	Yes	-1.09	12.31	5
705465	PHOENIX	Hybrid	3,354	0	42	0	3.3	0.7	0.1	13.0	3.4	13.7	17.1	622	65,074	Yes	-0.62	7.58	12
208165	HIELD	Hybrid	2,776	62	9	2	7.1	7.4	30.4	2.7	37.5	10.1	47.6	1,696	139,207	Yes	-0.49	10.81	94
801231	OPA LOCKA	Hybrid	589	2	8	3	1.1	0.1	1.6	1.3	2.7	1.4	4.1	977	16,112	Yes	-4.91	2.09	8
404242	BOCA TECCA	Hybrid	451	6	17	4	1.4	1.0	0.7	1.1	2.1	2.1	4.2	2	129	Yes	-0.09	4.11	2
808531	SEMINOLA	Hybrid	1,478	22	4	2	2.2	0.2	9.1	0.4	11.3	0.6	11.9	2,584	220,775	Yes	-0.06	7.84	56
408568	ALEXANDER	UG	-	0	3	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	-0.01	5.49	0
704261	IMAGINATION	Hybrid	2,287	38	54	4	8.9	1.7	10.0	20.2	18.9	21.9	40.8	881	125,133	Yes	-0.16	13.44	59
503962	ESTERO	Hybrid	3,775	37	35	3	5.8	1.9	15.8	24.5	21.6	26.4	48.0	926	133,055	Yes	-0.38	14.62	61
401933	LINTON	Hybrid	1,645	25	25	8	4.4	0.4	5.9	1.7	10.3	2.1	12.4	173	26,645	Yes	0.09	7.09	32
807031	ROSELAWN	Hybrid	2,172	2	25	0	0.8	1.9	0.1	5.0	0.9	6.9	7.8	516	18,833	Yes	-0.61	5.09	14
703437	RESERVATION	UG	1	0	6	0	-	2.0	-	0.1	-	2.1	2.1	-	-	Yes	-0.12	5.88	0
700938	HALLANDALE	Hybrid	2,011	5	11	7	2.2	1.8	4.4	1.3	6.6	3.1	9.7	308	45,324	Yes	-0.13	6.37	14
405463	CLINTMOORE	Hybrid	1,547	1	38	0	3.7	2.6	0.1	25.9	3.8	28.5	32.3	2,281	55,105	Yes	-0.41	13.09	21
808336	WHISPERING PINES	Hybrid	1,737	17	23	4	3.3	1.4	6.6	10.7	9.9	12.1	22.0	2,532	79,717	Yes	0.30	8.60	41
502165	BONITA SPRINGS	Hybrid	2,808	6	45	5	3.0	3.7	3.1	23.4	6.1	27.1	33.2	7,804	179,884	Yes	-0.25	13.95	21
800445	COCONUT GROVE	Hybrid	1,301	7	14	2	0.9	3.8	1.3	1.5	2.2	5.3	7.5	32	2,574	Yes	0.21	7.01	9
707662	CROSSBOW	Hybrid	1,959	0	26	0	1.5	2.4	-	17.7	1.5	20.1	21.6	132	14,641	Yes	-0.80	11.50	10
408565	ALEXANDER	Hybrid	1,586	45	3	1	6.8	3.6	35.4	1.4	42.2	5.0	47.2	726	112,043	Yes	0.15	9.25	79
707665	CROSSBOW	UG	1,451	1	26	1	0.5	3.4	0.1	12.1	0.6	15.5	16.1	57	8,819	Yes	-0.20	7.80	13
702741	MCARTHUR	Hybrid	2,266	3	20	0	1.4	0.2	0.6	5.6	2.0	5.8	7.8	614	32,694	Yes	-0.21	4.69	12
200432	COCOA	OH	1,070	28	6	4	4.0	0.1	8.2	0.4	12.2	0.5	12.7	1,052	90,994	Yes	-0.74	3.76	39
500763	ENGLEWOOD	Hybrid	1,678	19	25	6	4.2	0.2	9.3	3.2	13.5	3.4	16.9	219	49,352	Yes	-0.19	5.71	24
411233	MORAY	Hybrid	2,506	44	28	2	3.9	1.5	9.5	8.1	13.4	9.6	23.0	549	88,625	Yes	0.14	7.84	58
507465	CORKSCREW	Hybrid	169	17	26	1	14.9	5.0	9.7	7.7	24.6	12.7	37.3	156	3,511	Yes	0.81	12.41	7
501134	FT MYERS	Hybrid	457	9	28	3	1.2	1.3	0.7	2.6	1.9	3.9	5.8	443	11,652	Yes	-0.33	7.77	4
703638	PALM AIRE	Hybrid	1,207	3	36	3	3.2	0.8	2.3	6.2	5.5	7.0	12.5	21	1,978	Yes	-0.55	9.05	8
700933	HALLANDALE	Hybrid	1,181	0	4	5	0.5	2.8	0.7	1.0	1.2	3.8	5.0	340	45,809	Yes	0.09	2.39	9
505363	PARK	Hybrid	3,748	18	75	7	5.3	2.9	12.2	39.0	17.5	41.9	59.4	533	77,923	Yes	-1.34	16.06	46
407861	TARTAN	Hybrid	3,326	4	56	4	6.0	2.1	0.8	25.1	6.8	27.2	34.0	582	49,929	Yes	-0.12	10.88	21
701633	PLANTATION	Hybrid	1,316	16	11	3	4.1	1.3	8.7	6.3	12.8	7.6	20.4	187	26,455	Yes	-0.01	8.29	38
507466	CORKSCREW	UG	3,301	0	79	0	0.4	12.7	-	46.0	0.4	58.7	59.1	4,516	371,258	Yes	-0.76	17.54	13

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
814037	BRICKELL	UG	55	0	4	0	-	1.8	-	0.1	-	1.9	1.9	-	-	Yes	0.50	3.00	0
702739	MCARTHUR	Hybrid	1,640	0	26	2	1.6	0.2	0.4	5.2	2.0	5.4	7.4	788	111,194	Yes	-0.14	4.56	11
803232	HOMESTEAD	Hybrid	1,834	2	34	0	3.1	0.5	0.1	13.0	3.2	13.5	16.7	62	13,359	Yes	0.16	7.56	7
700441	OAKLAND PARK	Hybrid	1,001	9	10	1	1.8	2.2	3.3	0.5	5.1	2.7	7.8	692	7,883	Yes	0.45	5.05	15
409634	RAINBERRY	Hybrid	985	0	16	1	1.1	1.4	0.9	5.4	2.0	6.8	8.8	216	17,269	Yes	0.62	7.22	5
811561	KOGER	Hybrid	1,053	4	56	2	5.5	0.4	0.9	3.7	6.4	4.1	10.5	37	2,730	Yes	-0.12	11.58	8
814433	BANYAN	Hybrid	906	14	16	1	2.9	2.7	5.2	1.1	8.1	3.8	11.9	99	22,143	Yes	0.02	6.32	20
400231	DATURA ST	Hybrid	677	0	10	2	1.0	1.9	0.2	1.0	1.2	2.9	4.1	12	990	Yes	0.36	4.66	4
400338	NORTHWOOD	Hybrid	858	9	22	5	3.2	0.3	4.9	2.8	8.1	3.1	11.2	274	47,029	Yes	-0.38	5.12	25
410862	SOUTHFOK	Hybrid	1,617	15	43	11	6.6	2.4	8.6	17.6	15.2	20.0	35.2	998	167,176	Yes	-0.61	8.79	23
203031	FRONTENAC	Hybrid	2,011	61	20	9	6.3	0.2	23.5	5.2	29.8	5.4	35.2	1,979	86,936	Yes	0.17	7.27	42
405633	FOUNTAIN	Hybrid	2,208	11	32	1	3.3	0.6	2.2	9.7	5.5	10.3	15.8	156	22,493	Yes	-0.07	6.93	18
207931	RINEHART	Hybrid	2,188	20	71	3	5.4	1.7	4.8	22.9	10.2	24.6	34.8	688	55,668	Yes	0.26	10.16	22
701031	SAMPLE ROAD	Hybrid	1,907	29	13	1	3.3	1.2	8.4	2.5	11.7	3.7	15.4	544	110,470	Yes	0.03	6.63	57
806137	DOUGLAS	Hybrid	1,528	7	14	2	2.9	0.5	1.2	0.4	4.1	0.9	5.0	686	49,519	Yes	0.07	6.57	12
500132	SARASOTA	Hybrid	1,023	10	10	9	2.0	1.3	2.3	2.1	4.3	3.4	7.7	52	18,663	Yes	0.45	5.95	6
703538	DEERFIELD BEACH	Hybrid	1,681	3	33	0	3.0	2.0	0.6	10.6	3.6	12.6	16.2	99	13,251	Yes	-0.40	7.50	19
407333	HILLS	Hybrid	1,755	40	21	5	5.3	0.5	11.2	7.0	16.5	7.5	24.0	1,286	85,060	Yes	-0.25	6.85	46
201431	GRANDVIEW	Hybrid	1,510	21	33	3	4.8	0.9	5.1	5.1	9.9	6.0	15.9	1,901	197,953	Yes	-0.03	7.87	38
800436	COCONUT GROVE	Hybrid	1,229	25	12	11	3.7	0.6	6.2	3.2	9.9	3.8	13.7	2,405	162,837	Yes	-0.35	7.45	62
809136	TAMAMI	Hybrid	3,026	14	23	8	1.7	0.6	2.1	2.7	3.8	3.3	7.1	1,376	117,156	Yes	0.03	8.43	16
709261	PROGRESSO	Hybrid	858	5	15	0	1.0	9.3	0.2	2.6	1.2	11.9	13.1	10	1,992	Yes	1.34	8.14	5
202633	HOLLAND PARK	Hybrid	1,059	27	12	4	2.8	6.0	5.4	3.7	8.2	9.7	17.9	133	33,811	Yes	-1.98	3.52	28
100432	PALATKA	Hybrid	517	27	4	1	3.0	0.2	4.0	0.2	7.0	0.4	7.4	128	12,433	Yes	-0.51	2.19	18
101636	HUDSON	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.34	21.64	0
506036	WALKER	Hybrid	2,427	25	8	17	4.1	0.3	12.3	1.9	16.4	2.2	18.6	179	17,669	Yes	-0.53	8.67	33
809533	VIRGINIA KEY	Hybrid	345	3	8	0	4.0	4.6	0.5	3.5	4.5	8.1	12.6	6	2,221	Yes	-0.96	3.14	6
807636	KILLIAN	UG	5	0	3	0	-	4.0	-	-	-	-	4.0	4.0	-	Yes	4.85	8.25	0
805535	MASTER	Hybrid	890	14	8	1	3.3	0.7	4.7	0.9	8.0	1.6	9.6	138	34,516	Yes	0.11	7.51	29
504363	PINE RIDGE	Hybrid	3,577	16	71	6	6.2	2.5	3.2	22.3	9.4	24.8	34.2	1,115	110,852	Yes	-0.50	16.60	18
409533	LAKE IDA	Hybrid	3,222	7	26	3	2.8	1.2	3.6	16.5	6.4	17.7	24.1	2,793	88,206	Yes	-0.22	7.28	27
404035	WESTWARD	Hybrid	2,164	22	31	5	5.1	0.3	5.9	5.7	11.0	6.0	17.0	477	80,708	Yes	0.42	8.82	42
700142	SISTRUNK	UG	587	0	11	0	-	3.0	-	1.7	-	4.7	4.7	2	46	Yes	0.37	4.27	2
408766	SABAL	Hybrid	323	2	29	1	1.7	1.3	0.2	2.4	1.9	3.7	5.6	60	8,879	Yes	0.08	2.18	6
707132	CULLUM	Hybrid	1,552	0	25	0	2.4	1.1	0.4	5.0	2.8	6.1	8.9	47	3,699	Yes	-0.12	5.38	3
401633	OKEECHOBEE	Hybrid	911	20	23	7	6.9	0.3	10.6	3.8	17.5	4.1	21.6	265	31,332	Yes	-0.08	5.62	29
108963	DURBIN	Hybrid	1,640	2	46	1	2.9	15.8	1.8	32.2	4.7	48.0	52.7	210	70,201	Yes	-8.84	8.36	11
702034	DRIFTWOOD	Hybrid	1,666	27	20	1	4.2	1.5	5.9	6.5	10.1	8.0	18.1	415	73,675	Yes	0.32	7.82	34
401936	LINTON	Hybrid	459	17	5	2	2.1	0.4	2.5	0.3	4.6	0.7	5.3	585	39,387	Yes	0.15	2.55	22
102961	EAGLE	Hybrid	1,096	6	13	5	3.7	2.2	6.9	13.5	10.6	15.7	26.3	359	122,901	Yes	-0.03	4.97	15
413732	RUNWAY	Hybrid	617	9	18	8	4.5	1.2	4.6	4.6	9.1	5.8	14.9	649	38,672	Yes	0.15	3.55	19
809838	DUMFOUNDLING	UG	1,404	0	8	0	-	1.5	-	1.0	-	2.5	2.5	1	393	Yes	-0.43	4.07	1
806535	SUNILAND	Hybrid	749	28	13	1	3.1	0.6	12.5	4.5	15.6	5.1	20.7	795	111,684	Yes	-0.18	6.82	76
805634	MILLER	Hybrid	934	2	23	0	1.8	0.7	0.6	6.6	2.4	7.3	9.7	213	38,452	Yes	-0.07	5.03	17
506862	NOTRE DAME	Hybrid	2,446	39	20	10	12.4	4.5	58.9	14.0	71.3	18.5	89.8	816	80,788	Yes	0.94	5.84	48
808331	WHISPERING PINES	Hybrid	1,411	18	11	1	3.5	0.1	7.8	3.5	11.3	3.6	14.9	2,506	375,508	Yes	0.24	7.84	89
403237	ATLANTIC	Hybrid	755	8	26	3	3.0	1.1	2.0	4.7	5.0	5.8	10.8	1,654	34,823	Yes	-0.45	5.45	14
307763	ONEIL	Hybrid	1,073	3	14	3	2.3	1.7	4.4	13.0	6.7	14.7	21.4	107	4,942	Yes	-0.19	2.31	7
808332	WHISPERING PINES	Hybrid	1,217	13	7	0	2.3	0.6	6.4	1.9	8.7	2.5	11.2	406	75,314	Yes	0.06	5.16	37
502164	BONITA SPRINGS	Hybrid	1,917	1	42	0	3.1	2.2	-	15.8	3.1	18.0	21.1	1,112	41,634	Yes	-0.05	6.65	16
808269	LINDGREN	Hybrid	3,436	0	32	0	1.0	2.6	-	15.7	1.0	18.3	19.3	2,882	178,105	Yes	0.51	11.01	11
806232	INDIAN CREEK	UG	327	0	4	0	-	2.2	-	0.6	-	2.8	2.8	22	726	Yes	-1.07	4.23	1

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
806034	GOLDEN GLADES	Hybrid	1,680	17	6	3	3.3	2.4	11.6	2.3	14.9	4.7	19.6	2,720	204,542	Yes	0.07	8.07	106
807736	LEMON CITY	Hybrid	1,508	0	19	0	0.7	3.5	-	1.4	0.7	4.9	5.6	1,156	59,566	Yes	1.55	4.15	2
202231	MIMS	Hybrid	1,128	13	13	4	5.9	0.7	6.8	7.5	12.7	8.2	20.9	2,145	51,682	Yes	0.17	6.17	32
407166	CRANE	Hybrid	1,975	26	38	3	2.3	3.0	6.5	15.2	8.8	18.2	27.0	1,524	158,289	Yes	-0.41	8.99	19
813533	JACKSON	Hybrid	1,223	17	4	2	2.0	1.5	3.9	0.2	5.9	1.7	7.6	3,391	126,930	Yes	0.17	6.37	36
807832	WESTON VILLAGE	Hybrid	1,888	14	21	3	3.2	1.0	3.9	3.3	7.1	4.3	11.4	2,936	178,131	Yes	-0.15	7.25	47
807237	MERCHANDISE	Hybrid	1,415	0	26	0	0.9	0.7	0.1	2.8	1.0	3.5	4.5	-	-	Yes	-0.25	3.35	0
814038	BRICKELL	UG	490	0	1	0	-	2.2	-	-	-	2.2	2.2	-	-	Yes	0.08	3.38	0
500931	OSPREY	Hybrid	1,490	21	45	5	5.9	1.1	5.2	10.5	11.1	11.6	22.7	2,848	157,843	Yes	0.14	7.74	47
803235	HOMESTEAD	Hybrid	189	0	14	0	1.5	1.1	-	2.9	1.5	4.0	5.5	6	1,104	Yes	-0.05	1.15	6
802836	ARCH CREEK	Hybrid	2,337	22	20	4	3.4	0.9	4.9	2.4	8.3	3.3	11.6	5,458	289,849	Yes	-0.49	8.61	45
106463	SPRUCE	Hybrid	2,926	35	57	4	5.4	3.7	14.8	47.3	20.2	51.0	71.2	3,266	102,279	Yes	-0.89	12.81	49
705765	TRACE	UG	2,360	0	32	0	-	5.2	-	24.5	-	29.7	29.7	2,866	219,142	Yes	1.13	13.13	12
502931	ONECO	Hybrid	1,797	10	28	3	3.3	1.1	5.9	3.2	9.2	4.3	13.5	3,885	246,357	Yes	-0.99	6.11	29
706162	HOLLYBROOK	Hybrid	2,437	0	36	1	2.1	1.9	0.1	11.0	2.2	12.9	15.1	1,129	81,495	Yes	-0.40	6.90	5
808934	OLYMPIA HEIGHTS	Hybrid	1,571	8	17	5	1.6	0.9	6.2	2.9	7.8	3.8	11.6	125	19,445	Yes	-0.22	6.58	27
500767	ENGLEWOOD	OH	2,899	44	10	4	11.1	0.3	62.1	1.4	73.2	1.7	74.9	344	40,863	Yes	0.50	11.50	53
404938	PORT SEWALL	Hybrid	970	34	32	7	6.4	3.7	7.9	15.4	14.3	19.1	33.4	1,070	43,998	Yes	-0.34	6.96	14
810164	SEAGULL	Hybrid	1,881	0	49	0	2.4	3.4	-	14.2	2.4	17.6	20.0	1,983	125,747	Yes	-0.02	12.68	10
500333	VENICE	Hybrid	561	6	32	3	2.4	0.2	2.3	2.5	4.7	2.7	7.4	56	9,609	Yes	-0.14	7.66	8
803135	FLORIDA CITY	Hybrid	1,304	3	24	2	12.7	2.0	6.2	12.1	18.9	14.1	33.0	193	28,859	Yes	2.81	3.81	7
108962	DURBIN	Hybrid	2,921	3	56	5	8.2	8.9	9.6	50.9	17.8	59.8	77.6	4,660	139,409	Yes	-0.02	13.48	22
500766	ENGLEWOOD	Hybrid	2,416	86	35	7	11.2	1.6	14.3	9.3	25.5	10.9	36.4	4,033	162,553	Yes	-0.01	7.09	46
405461	CLINTMOORE	Hybrid	3,671	4	73	1	3.9	4.1	0.7	29.7	4.6	33.8	38.4	340	38,235	Yes	0.37	14.07	28
203231	INDIALANTIC	Hybrid	1,542	10	18	7	1.4	0.1	6.1	3.1	7.5	3.2	10.7	855	49,757	Yes	0.15	5.75	31
702432	PEMBROKE	Hybrid	2,211	6	15	2	2.1	1.4	1.1	9.2	3.2	10.6	13.8	955	46,856	Yes	-0.96	6.54	12
811832	MEMORIAL	Hybrid	1,321	19	22	2	4.0	0.3	4.8	3.7	8.8	4.0	12.8	1,684	67,055	Yes	0.28	7.78	47
808935	OLYMPIA HEIGHTS	Hybrid	1,183	18	36	3	3.7	0.5	3.2	7.2	6.9	7.7	14.6	219	38,656	Yes	-0.94	6.66	38
410662	RYDER	UG	1,253	0	51	0	0.2	8.2	-	24.8	0.2	33.0	33.2	5	1,650	Yes	-0.61	10.89	1
703543	DEERFIELD BEACH	Hybrid	1,517	10	21	3	3.0	1.6	2.6	7.1	5.6	8.7	14.3	647	58,223	Yes	0.05	6.75	21
706165	HOLLYBROOK	Hybrid	2,691	0	30	0	2.4	0.9	-	9.2	2.4	10.1	12.5	738	75,927	Yes	-0.18	8.62	2
101933	EDGEWATER	Hybrid	1,938	15	14	12	3.2	0.5	11.6	6.8	14.8	7.3	22.1	721	92,692	Yes	-0.08	7.52	38
500765	ENGLEWOOD	Hybrid	2,514	30	41	5	8.8	0.4	9.4	16.1	18.2	16.5	34.7	1,999	75,848	Yes	0.03	8.53	31
805239	NATOMA	UG	-	0	0	0	-	5.0	-	-	-	5.0	5.0	-	-	Yes	0.03	0.23	0
809831	DUMFOUNDLING	UG	715	0	6	0	-	2.6	-	1.3	-	3.9	3.9	-	-	Yes	0.79	5.19	0
203134	ROCKLEDGE	Hybrid	1,415	11	26	2	2.9	0.9	5.1	10.8	8.0	11.7	19.7	512	65,699	Yes	-0.17	6.03	38
404532	NORTON	Hybrid	2,372	4	41	1	1.2	4.6	2.0	9.8	3.2	14.4	17.6	147	9,868	Yes	-0.32	8.98	11
402838	LANTANA	Hybrid	3,181	20	38	6	3.3	0.4	7.3	10.6	10.6	11.0	21.6	7,205	152,498	Yes	-0.59	6.61	46
202731	BANANA RIVER	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.65	2.75	0
800738	HIALEAH	Hybrid	1,524	12	13	3	2.4	2.1	5.3	1.5	7.7	3.6	11.3	1,302	124,664	Yes	-0.08	6.22	37
803639	SEABOARD	UG	2	0	1	0	-	4.8	-	-	-	4.8	4.8	-	-	Yes	0.93	1.23	0
504368	PINE RIDGE	Hybrid	1,302	8	7	2	0.5	2.2	4.5	5.3	5.0	7.5	12.5	524	122,877	Yes	-0.08	5.42	32
407732	SQUARE LAKE	Hybrid	1,851	15	36	6	2.8	0.6	4.9	9.7	7.7	10.3	18.0	523	61,826	Yes	-0.52	6.48	34
706163	HOLLYBROOK	Hybrid	2,651	0	44	1	2.7	1.7	0.1	10.4	2.8	12.1	14.9	4,971	28,040	Yes	-0.32	9.88	7
707731	GOOLSBY	Hybrid	1,796	2	49	1	2.7	0.2	0.6	9.8	3.3	10.0	13.3	475	36,034	Yes	-0.24	5.86	12
402635	JUNO BEACH	Hybrid	1,150	6	44	1	2.7	3.5	0.6	17.3	3.3	20.8	24.1	238	36,803	Yes	-0.23	8.07	24
810562	JASMINE	Hybrid	3,567	2	34	0	3.2	5.7	2.7	24.7	5.9	30.4	36.3	3,226	162,716	Yes	-0.09	14.61	13
207933	RINEHART	Hybrid	522	0	34	1	1.7	1.8	0.1	8.1	1.8	9.9	11.7	11	1,528	Yes	0.10	7.60	5
500537	CLARK	Hybrid	1,284	8	19	7	2.2	1.9	8.0	6.5	10.2	8.4	18.6	432	68,838	Yes	-0.07	6.43	24
505761	AUBURN	Hybrid	2,675	6	60	8	4.1	0.6	6.2	19.1	10.3	19.7	30.0	286	33,980	Yes	-0.91	7.39	21
801131	FRONTON	Hybrid	221	2	18	3	2.8	1.0	1.0	1.7	3.8	2.7	6.5	231	21,849	Yes	-0.01	3.89	6
708562	SILVERLAKES	UG	1,353	0	23	0	0.8	4.7	-	15.3	0.8	20.0	20.8	179	15,640	Yes	-0.44	7.76	5

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
406165	TURNPIKE	OH	3,368	60	6	1	10.1	0.7	30.9	0.5	41.0	1.2	42.2	7,312	140,136	Yes	0.16	13.46	62
405533	PRIMA VISTA	Hybrid	1,692	32	10	1	5.6	0.7	19.8	3.5	25.4	4.2	29.6	1,134	31,463	Yes	0.26	6.86	41
400833	PAHOKEE	Hybrid	1,494	58	8	3	8.1	-	11.1	1.1	19.2	1.1	20.3	1,914	383,781	Yes	-0.15	4.95	54
406533	OSBORNE	Hybrid	2,137	22	35	3	4.0	2.7	6.1	18.1	10.1	20.8	30.9	4,095	121,156	Yes	0.10	9.40	29
801941	DEAUVILLE	Hybrid	1,784	13	12	2	1.8	1.1	2.0	0.7	3.8	1.8	5.6	91	16,562	Yes	-0.33	6.17	16
802436	SOUTH MIAMI	Hybrid	1,217	11	31	5	2.3	1.4	2.3	2.2	4.6	3.6	8.2	50	8,040	Yes	-0.45	6.75	15
505961	CARLSTROM	OH	2,677	100	8	17	18.9	0.2	106.3	5.4	125.2	5.6	130.8	2,657	214,299	Yes	0.90	9.90	122
410661	RYDER	Hybrid	2,141	1	34	1	3.5	5.3	3.4	22.8	6.9	28.1	35.0	2,283	134,098	Yes	-0.38	6.72	17
703439	RESERVATION	UG	3	0	5	0	-	2.3	-	0.3	-	2.6	2.6	-	-	Yes	0.13	4.63	0
700435	OAKLAND PARK	Hybrid	786	3	2	3	2.7	1.7	0.8	0.5	3.5	2.2	5.7	3,337	165,096	Yes	-0.54	1.86	9
208761	GRANT	Hybrid	1,582	63	33	5	6.9	6.7	10.9	9.2	17.8	15.9	33.7	766	64,133	Yes	-0.30	6.00	47
501065	FRUITVILLE	Hybrid	2,472	16	42	5	4.5	1.5	8.8	15.9	13.3	17.4	30.7	420	78,995	Yes	0.91	10.01	19
106534	REED	UG	781	0	17	1	-	4.8	0.1	3.9	0.1	8.7	8.8	10	1,770	Yes	-0.17	4.13	2
702037	DRIFTWOOD	Hybrid	2,074	35	10	5	4.6	0.5	10.6	1.9	15.4	2.4	17.8	757	233,011	Yes	-0.23	9.17	59
706365	BASSCREEK	UG	2,382	0	44	0	1.2	4.8	-	20.5	1.2	25.3	26.5	2,431	50,837	Yes	-0.70	13.00	12
800108	MIAMI	UG	93	0	1	0	-	0.2	-	1.8	-	2.0	2.0	-	-	Yes	2.38	2.38	0
801132	FRONTON	Hybrid	188	3	2	1	1.2	0.3	0.3	0.1	1.5	0.4	1.9	18	5,282	Yes	-0.31	3.89	2
411962	TRONTO	Hybrid	1,674	17	5	3	2.5	0.3	18.9	5.3	21.4	5.6	27.0	618	61,589	Yes	-0.11	7.69	31
706532	TRAIN	Hybrid	1,549	4	38	6	3.1	0.6	3.9	5.0	7.0	5.6	12.6	263	37,436	Yes	0.24	9.04	16
405340	BEELINE	Hybrid	1,224	2	21	3	1.9	1.4	0.6	6.5	2.5	7.9	10.4	21	7,703	Yes	-0.52	4.88	3
103836	WILLOW	Hybrid	2,291	0	29	0	3.5	2.1	0.1	17.5	3.6	19.6	23.2	457	45,814	Yes	-0.25	5.35	19
505863	BUCKEYE	Hybrid	109	6	20	2	4.6	1.9	4.7	3.2	9.3	5.1	14.4	383	38,165	Yes	-0.05	3.65	14
708061	WINDMILL	Hybrid	688	8	3	5	4.9	0.2	13.7	3.8	18.6	4.0	22.6	1,808	98,070	Yes	-0.28	5.22	26
701737	STIRLING	Hybrid	1,935	1	31	1	2.0	0.7	0.5	9.3	2.5	10.0	12.5	197	19,293	Yes	-0.35	6.45	13
705764	TRACE	Hybrid	2,498	3	42	0	3.0	5.4	2.9	12.9	5.9	18.3	24.2	1,419	38,478	Yes	-0.64	9.66	19
801636	PRINCETON	Hybrid	2,560	38	41	5	7.8	1.8	13.5	21.0	21.3	22.8	44.1	2,875	104,571	Yes	0.71	10.01	45
806435	HAINLIN	Hybrid	1,645	7	18	0	2.4	3.0	1.9	10.5	4.3	13.5	17.8	461	77,923	Yes	-0.29	6.61	8
700241	HOLLYWOOD	UG	-	0	0	0	-	2.1	-	-	-	2.1	2.1	-	-	Yes	0.12	0.62	0
407562	GLENDALE	Hybrid	1,603	36	56	13	12.0	2.1	29.0	12.8	41.0	14.9	55.9	1,514	145,117	Yes	-0.22	6.28	72
201031	EAU GALLIE	Hybrid	1,315	21	4	11	4.0	0.4	9.1	1.4	13.1	1.8	14.9	154	19,863	Yes	-0.09	5.51	32
702937	HAWKINS	Hybrid	921	15	14	3	1.4	1.4	2.9	2.9	4.3	4.3	8.6	467	16,683	Yes	-3.72	4.38	20
812835	WILCOX	UG	41	0	2	0	-	4.8	-	-	-	4.8	4.8	-	-	Yes	-0.04	2.86	0
810831	BELL	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.03	2.57	0
811363	ANHINGA	Hybrid	562	28	9	3	15.2	79.0	33.1	22.5	48.3	101.5	149.8	1,262	110,375	Yes	0.31	3.71	52
402933	OSLO	Hybrid	2,399	30	29	1	5.4	2.5	11.2	17.5	16.6	20.0	36.6	502	38,450	Yes	1.15	9.35	29
509062	SUMMIT	Hybrid	3,979	20	33	4	4.8	0.5	9.7	27.3	14.5	27.8	42.3	3,323	122,740	Yes	0.11	13.31	20
401931	LINTON	Hybrid	1,141	12	21	4	2.2	0.7	3.8	3.5	6.0	4.2	10.2	702	94,089	Yes	-4.54	4.66	27
800848	RAILWAY	UG	2	0	3	0	-	3.2	-	-	-	3.2	3.2	-	-	Yes	0.69	0.99	0
504532	TUTTLE	Hybrid	2,620	7	47	6	4.1	0.2	8.9	12.9	13.0	13.1	26.1	3,517	229,819	Yes	-1.15	8.85	55
414035	GRACEWOOD	Hybrid	670	2	24	2	1.2	1.1	0.7	2.5	1.9	3.6	5.5	170	11,329	Yes	-0.04	1.26	9
400737	BOCA RATON	Hybrid	2,135	2	35	4	4.0	3.4	2.0	3.9	6.0	7.3	13.3	3,442	209,251	Yes	-0.04	8.66	26
406232	OAKES	Hybrid	2,462	2	29	6	1.7	2.2	1.3	11.0	3.0	13.2	16.2	5,257	173,020	Yes	0.12	6.02	16
706366	BASSCREEK	Hybrid	1	0	4	0	3.8	1.9	-	0.7	3.8	2.6	6.4	4	844	Yes	-0.08	11.62	4
400331	NORTHWOOD	Hybrid	2,168	3	33	5	3.3	1.1	3.8	10.2	7.1	11.3	18.4	274	47,235	Yes	0.00	6.90	22
203433	MICCO	Hybrid	1,841	43	17	15	5.7	0.7	17.2	7.8	22.9	8.5	31.4	2,029	85,081	Yes	-0.15	6.65	56
510362	PIRATE	Hybrid	3,300	50	25	13	6.7	1.4	14.9	5.2	21.6	6.6	28.2	55	4,193	Yes	0.00	0.00	10
202833	CLEARLAKE	Hybrid	1,421	53	12	4	6.5	1.0	16.7	5.3	23.2	6.3	29.5	652	100,500	Yes	-3.11	6.29	51
803540	MARKET	Hybrid	1,451	9	7	5	2.0	0.2	2.6	0.4	4.6	0.6	5.2	1,660	115,380	Yes	2.91	7.11	14
504362	PINE RIDGE	UG	2,845	1	33	0	0.4	4.4	0.2	16.0	0.6	20.4	21.0	40	4,113	Yes	-0.92	9.98	2
504132	BENEVA	Hybrid	2,115	27	34	3	3.2	0.1	12.0	6.4	15.2	6.5	21.7	372	54,660	Yes	-0.87	7.83	32
801940	DEAUVILLE	Hybrid	781	3	8	0	1.3	3.7	0.9	0.5	2.2	4.2	6.4	16	3,969	Yes	-0.14	3.16	7
802937	GRAPELAND	Hybrid	1,564	15	8	7	3.2	0.8	3.6	0.5	6.8	1.3	8.1	1,697	139,416	Yes	-2.12	6.38	21

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
704131	MOFFETT	Hybrid	2,037	16	14	9	3.8	0.5	6.5	1.3	10.3	1.8	12.1	482	68,186	Yes	0.46	6.26	30
705164	JACARANDA	Hybrid	629	2	10	1	0.8	1.1	1.5	2.1	2.3	3.2	5.5	33	5,657	Yes	0.30	3.20	7
410764	ROSEDALE	UG	-	0	0	0	-	5.0	-	-	-	5.0	5.0	-	-	Yes	0.01	0.71	0
801035	NORMANDY BEACH	Hybrid	1,175	13	10	2	3.0	1.0	2.7	2.1	5.7	3.1	8.8	3,865	172,589	Yes	-0.23	6.47	36
404135	GOLF	Hybrid	2,277	24	22	11	4.7	0.2	8.6	7.9	13.3	8.1	21.4	3,473	148,899	Yes	-0.05	8.45	40
802431	SOUTH MIAMI	Hybrid	1,049	11	19	6	1.5	1.4	1.7	1.2	3.2	2.6	5.8	41	10,538	Yes	0.49	6.59	6
812164	BEACON	Hybrid	312	0	30	1	1.1	3.5	0.3	7.0	1.4	10.5	11.9	658	14,400	Yes	-0.15	10.85	8
410165	PLAZA	Hybrid	2,285	2	44	3	3.3	0.3	1.1	20.8	4.4	21.1	25.5	238	12,176	Yes	-0.54	11.26	10
507262	SAN CARLOS	Hybrid	3,142	9	34	9	6.7	0.4	6.7	27.8	13.4	28.2	41.6	10,007	316,546	Yes	0.22	11.92	41
100834	PORT ORANGE	Hybrid	1,779	17	37	5	3.1	0.6	4.5	12.5	7.6	13.1	20.7	876	10,294	Yes	-0.05	6.25	20
203034	FRONTENAC	Hybrid	930	31	11	2	8.3	0.2	9.4	2.9	17.7	3.1	20.8	714	62,366	Yes	0.01	5.61	25
400738	BOCA RATON	Hybrid	987	1	27	2	0.5	2.8	0.2	2.4	0.7	5.2	5.9	460	7,548	Yes	0.52	8.52	3
804734	HAULOVER	UG	1,055	0	7	0	-	2.5	-	1.4	-	3.9	3.9	269	111,091	Yes	-0.74	5.56	6
500164	SARASOTA	Hybrid	893	7	20	3	1.4	4.6	1.1	2.1	2.5	6.7	9.2	1,304	69,022	Yes	-0.26	5.74	11
402634	JUNO BEACH	Hybrid	1,771	4	36	5	2.1	0.8	0.8	11.7	2.9	12.5	15.4	435	132,257	Yes	0.04	9.24	17
802931	GRAPELAND	Hybrid	2,250	14	12	3	2.6	0.2	3.6	1.0	6.2	1.2	7.4	1,537	178,283	Yes	-0.35	6.35	23
808936	OLYMPIA HEIGHTS	Hybrid	1,395	9	16	8	2.9	0.4	3.4	2.4	6.3	2.8	9.1	255	28,763	Yes	-0.41	7.09	27
709731	BRONCO	Hybrid	1	0	0	0	0.5	1.0	-	-	0.5	1.0	1.5	-	-	Yes	0.07	2.17	0
701736	STIRLING	Hybrid	2,434	21	16	2	3.6	0.2	8.5	2.5	12.1	2.7	14.8	400	56,138	Yes	-0.09	9.11	41
700240	HOLLYWOOD	Hybrid	2,223	14	16	3	3.0	0.7	2.0	6.6	5.0	7.3	12.3	468	78,437	Yes	-0.09	5.91	20
408031	CALDWELL	Hybrid	1,057	8	21	4	2.2	0.1	1.8	3.1	4.0	3.2	7.2	71	11,658	Yes	0.11	5.01	11
506031	WALKER	Hybrid	974	19	16	8	3.3	0.1	5.0	3.4	8.3	3.5	11.8	146	16,750	Yes	0.12	6.02	26
805435	DADE	Hybrid	184	3	19	1	1.3	0.1	0.4	0.8	1.7	0.9	2.6	1	37	Yes	-1.00	2.20	1
804631	INDUSTRIAL	Hybrid	364	6	21	2	3.4	-	1.3	0.9	4.7	0.9	5.6	44	9,487	Yes	0.19	6.09	13
401036	GREENACRES	Hybrid	2,499	19	39	4	4.9	0.1	5.4	9.6	10.3	9.7	20.0	300	62,576	Yes	0.03	8.73	31
709931	ELLER	UG	1	0	0	0	-	3.0	-	-	-	3.0	3.0	-	-	Yes	3.79	3.79	0
404939	PORT SEWALL	Hybrid	1,680	23	30	2	5.2	1.4	5.8	16.4	11.0	17.8	28.8	224	49,874	Yes	-0.40	7.60	28
704461	FASHION	UG	14	0	3	0	-	1.4	-	0.1	-	1.5	1.5	-	-	Yes	0.18	0.78	0
402935	OSLO	Hybrid	1,829	24	20	2	6.3	0.2	12.6	7.7	18.9	7.9	26.8	536	32,486	Yes	0.15	6.95	29
701735	STIRLING	Hybrid	1,002	27	7	3	4.2	0.6	6.1	0.5	10.3	1.1	11.4	133	21,916	Yes	-0.64	7.26	29
402535	BELVEDERE	UG	3	0	2	0	-	1.7	-	0.1	-	1.8	1.8	-	-	Yes	0.16	4.56	0
704941	LAKEVIEW	Hybrid	1,399	2	26	0	2.4	0.5	0.2	9.8	2.6	10.3	12.9	360	27,119	Yes	-0.11	5.69	14
813233	KNOWLTON	UG	1,538	0	6	0	-	0.8	-	0.8	-	1.6	1.6	-	-	Yes	0.11	5.01	0
506767	VANDERBILT	Hybrid	3,691	8	67	2	7.0	4.5	3.3	29.2	10.3	33.7	44.0	8,092	146,691	Yes	0.56	12.16	23
101938	EDGEWATER	Hybrid	2,154	16	17	8	3.6	1.3	12.2	12.3	15.8	13.6	29.4	1,572	91,950	Yes	-0.27	7.23	37
402534	BELVEDERE	Hybrid	1,198	23	19	0	3.4	0.8	2.7	1.1	6.1	1.9	8.0	187	31,842	Yes	0.05	7.35	30
509061	SUMMIT	Hybrid	3,012	6	55	1	4.9	1.6	5.0	26.7	9.9	28.3	38.2	614	108,006	Yes	-2.25	14.75	31
508865	PANACEA	OH	3,093	49	27	3	9.4	0.1	89.0	3.4	98.4	3.5	101.9	3,400	31,445	Yes	0.51	15.11	44
209232	MARS	UG	7	0	7	0	-	4.9	-	1.0	-	5.9	5.9	-	-	Yes	-0.14	1.66	0
700931	HALLANDALE	Hybrid	1,852	15	22	6	3.3	0.1	2.3	2.5	5.6	2.6	8.2	293	41,398	Yes	0.21	6.81	13
707464	SAWGRASS	Hybrid	861	1	37	1	2.5	1.8	0.3	9.1	2.8	10.9	13.7	13	3,667	Yes	-1.28	10.42	6
207863	OSTEEN	OH	878	52	5	17	19.7	0.4	67.2	3.3	86.9	3.7	90.6	1,467	97,119	Yes	-0.09	3.21	61
701535	DANIA	Hybrid	1,631	33	7	6	4.5	0.2	5.1	0.7	9.6	0.9	10.5	748	31,996	Yes	-0.39	6.41	34
809666	COURT	Hybrid	1,524	4	40	1	4.1	2.7	0.5	14.8	4.6	17.5	22.1	1,729	239,717	Yes	0.29	7.19	8
403932	LAKE PARK	OH	1,909	42	6	1	4.1	0.2	9.9	0.5	14.0	0.7	14.7	331	70,901	Yes	-0.16	6.94	36
506665	LIVINGSTON	Hybrid	1,232	3	44	3	6.9	0.9	0.5	10.8	7.4	11.7	19.1	1,264	35,147	Yes	-1.64	10.96	11
100833	PORT ORANGE	Hybrid	1,948	13	48	8	4.5	-	4.8	13.7	9.3	13.7	23.0	326	29,436	Yes	-0.14	7.76	19
700235	HOLLYWOOD	Hybrid	1,481	22	2	3	2.1	0.2	5.3	0.2	7.4	0.4	7.8	1,169	86,864	Yes	0.48	5.28	21
707864	PARKLAND	UG	1,644	0	30	0	-	6.4	-	24.3	-	30.7	30.7	259	39,854	Yes	0.78	8.58	12
404937	PORT SEWALL	Hybrid	1,188	12	21	1	1.3	1.6	3.7	17.2	5.0	18.8	23.8	57	10,513	Yes	-0.77	8.43	20
404835	GERMANTOWN	Hybrid	2,061	17	22	7	4.9	0.3	6.8	4.8	11.7	5.1	16.8	131	19,626	Yes	-0.02	8.28	30
801140	FRONTON	Hybrid	1,460	18	10	4	5.0	0.5	3.2	0.7	8.2	1.2	9.4	920	60,027	Yes	0.03	7.03	21

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
101632	HUDSON	OH	-	0	0	0	0.2	-	-	-	0.2	-	0.2	-	-	Yes	0.22	3.92	0
813136	FIREHOUSE	UG	2,502	0	9	1	-	2.2	0.1	1.6	0.1	3.8	3.9	-	-	Yes	0.35	7.85	0
805034	UNIVERSITY	UG	16	0	6	0	-	3.4	-	0.3	-	3.7	3.7	-	-	Yes	0.54	7.04	0
808932	OLYMPIA HEIGHTS	OH	1,280	23	0	1	1.8	0.3	7.0	0.1	8.8	0.4	9.2	1,666	240,508	Yes	-0.12	5.98	29
507266	SAN CARLOS	Hybrid	3,842	5	70	6	8.7	6.5	4.8	39.0	13.5	45.5	59.0	7,766	609,559	Yes	-0.50	14.30	37
404933	PORT SEWALL	Hybrid	1,792	12	39	5	4.3	4.9	3.6	19.4	7.9	24.3	32.2	1,140	14,319	Yes	-0.57	9.63	22
800241	MIAMI BEACH	UG	1,721	0	9	0	-	3.0	-	1.6	-	4.6	4.6	1	81	Yes	-0.14	4.56	1
707031	SHERIDAN	Hybrid	1,913	0	16	0	2.3	1.4	-	15.0	2.3	16.4	18.7	358	76,730	Yes	-0.07	7.53	30
413535	VIOLET	Hybrid	429	2	17	1	1.4	0.2	0.4	5.9	1.8	6.1	7.9	14	1,440	Yes	0.49	3.39	3
810161	SEAGULL	Hybrid	3,679	0	49	0	1.7	2.2	-	24.6	1.7	26.8	28.5	3,917	250,465	Yes	-0.30	16.10	14
808266	LINDGREN	Hybrid	2,475	1	25	1	2.5	2.8	1.3	19.8	3.8	22.6	26.4	2,017	36,299	Yes	0.04	11.24	10
402131	TERMINAL	Hybrid	1,818	31	32	9	4.6	1.5	4.8	4.3	9.4	5.8	15.2	4,268	226,183	Yes	-0.11	8.29	53
503564	ALLIGATOR	Hybrid	3,552	12	61	9	5.0	0.9	7.5	19.8	12.5	20.7	33.2	3,799	219,341	Yes	-2.07	11.13	59
801038	NORMANDY BEACH	Hybrid	1,652	2	29	2	1.0	2.5	0.7	1.3	1.7	3.8	5.5	1,295	42,676	Yes	0.38	7.18	15
507263	SAN CARLOS	Hybrid	2,360	38	49	8	8.8	1.3	18.3	15.2	27.1	16.5	43.6	1,116	150,236	Yes	-0.72	11.18	70
804834	COUNTY LINE	Hybrid	715	3	10	0	1.3	3.5	0.4	2.6	1.7	6.1	7.8	349	13,960	Yes	-0.10	4.20	1
408566	ALEXANDER	Hybrid	1,133	31	4	2	6.6	3.7	23.3	2.8	29.9	6.5	36.4	213	21,933	Yes	-1.13	4.57	50
204265	BABCOCK	Hybrid	2,475	124	25	16	13.3	0.2	50.4	12.9	63.7	13.1	76.8	1,542	104,263	Yes	-0.19	9.21	74
509862	ANGLER	Hybrid	4,244	3	63	2	5.0	2.9	1.9	19.2	6.9	22.1	29.0	180	53,398	Yes	0.30	13.00	9
204631	COLLEGE	Hybrid	1,687	10	40	1	3.6	1.7	2.3	15.1	5.9	16.8	22.7	389	26,827	Yes	-0.67	7.13	24
506964	WOODS	Hybrid	2,447	18	81	5	5.8	1.3	4.2	21.4	10.0	22.7	32.7	845	84,292	Yes	-0.02	13.78	34
400739	BOCA RATON	Hybrid	2,077	15	19	6	2.4	3.3	3.5	2.6	5.9	5.9	11.8	3,517	158,991	Yes	-0.34	7.46	38
400132	WEST PALM BEACH	Hybrid	908	6	19	0	1.5	1.6	1.2	2.7	2.7	4.3	7.0	939	6,299	Yes	-0.20	5.70	9
807538	DADELAND	UG	-	0	0	0	-	2.5	-	-	-	2.5	2.5	-	-	Yes	0.08	1.68	0
806838	RED ROAD	Hybrid	1,271	4	27	1	3.5	0.9	0.6	4.4	4.1	5.3	9.4	2,606	47,587	Yes	2.23	7.03	15
702531	DAVIE	Hybrid	1,728	5	35	1	2.6	1.4	0.8	13.8	3.4	15.2	18.6	1,162	17,484	Yes	-0.01	6.09	19
809333	RONEY	UG	897	0	6	0	-	1.9	-	2.0	-	3.9	3.9	1	695	Yes	0.09	2.69	1
504531	TUTTLE	Hybrid	2,958	37	46	7	5.6	0.3	11.7	9.0	17.3	9.3	26.6	318	38,485	Yes	-0.43	9.67	35
203636	HARRIS	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	-0.11	4.19	0
403231	ATLANTIC	Hybrid	1,778	11	33	3	4.7	0.5	6.7	5.0	11.4	5.5	16.9	1,131	89,144	Yes	0.05	8.55	46
802235	GLADEVIEW	OH	2,039	44	7	2	4.0	-	8.6	0.3	12.6	0.3	12.9	6,320	123,336	Yes	0.14	7.14	68
809137	TAMAMI	Hybrid	1,358	22	14	1	2.7	1.0	3.8	0.6	6.5	1.6	8.1	856	51,076	Yes	-1.26	7.44	24
706167	HOLLYBROOK	Hybrid	2,999	9	33	0	1.9	2.1	2.7	17.2	4.6	19.3	23.9	1,298	66,907	Yes	-0.50	11.70	26
709434	ANDREWS	UG	-	0	0	0	-	0.6	-	-	-	0.6	0.6	-	-	Yes	-0.15	7.85	0
404631	PLATT	Hybrid	2,382	32	30	20	8.7	0.5	44.2	12.5	52.9	13.0	65.9	5,320	152,372	Yes	0.10	10.20	48
308061	MILLS	Hybrid	1,403	70	41	19	20.3	0.1	45.1	15.9	65.4	16.0	81.4	354	72,959	Yes	-3.17	4.23	26
813139	FIREHOUSE	Hybrid	1,581	13	14	2	1.8	1.3	1.8	0.8	3.6	2.1	5.7	239	38,184	Yes	0.42	5.02	16
408862	ABERDEEN	Hybrid	2,957	0	49	1	4.5	3.1	0.2	26.2	4.7	29.3	34.0	4,358	108,944	Yes	0.08	12.18	18
812363	URBAN	UG	3,830	0	32	0	-	5.1	-	14.9	-	20.0	20.0	1	93	Yes	1.04	11.54	1
404138	GOLF	Hybrid	1,662	1	31	2	2.0	2.7	0.4	9.0	2.4	11.7	14.1	122	15,216	Yes	0.14	6.64	5
700842	BEVERLY	OH	1,835	21	4	1	3.5	0.3	8.1	0.2	11.6	0.5	12.1	1,329	139,471	Yes	-0.08	7.42	69
104832	TAYLOR	Hybrid	1,375	18	5	4	2.5	1.0	10.4	1.0	12.9	2.0	14.9	3,313	84,941	Yes	-0.17	2.23	41
201533	CITY POINT	Hybrid	1,505	47	12	8	5.1	1.6	14.8	6.0	19.9	7.6	27.5	1,225	56,326	Yes	0.11	6.81	46
406534	OSBORNE	Hybrid	1,066	1	24	2	2.2	0.5	0.7	6.5	2.9	7.0	9.9	145	27,047	Yes	-0.22	2.58	6
200531	MELBOURNE	Hybrid	635	10	9	5	2.2	0.5	4.6	3.1	6.8	3.6	10.4	104	12,043	Yes	-0.92	5.88	18
405938	BUTTS	Hybrid	313	2	9	0	0.4	3.4	0.2	3.3	0.6	6.7	7.3	98	9,464	Yes	0.32	4.22	2
800847	RAILWAY	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	-0.06	0.34	0
809040	AVENTURA	UG	263	0	4	0	-	2.0	-	0.8	-	2.8	2.8	-	-	Yes	0.00	0.00	0
700937	HALLANDALE	Hybrid	947	0	22	2	1.6	-	0.3	2.0	1.9	2.0	3.9	7	565	Yes	0.24	2.84	2
800851	RAILWAY	UG	5	0	4	0	-	1.4	-	0.4	-	1.8	1.8	-	-	Yes	-0.07	2.03	0
202032	INDIAN HARBOR	Hybrid	1,558	14	44	3	2.6	0.7	3.0	13.9	5.6	14.6	20.2	189	24,071	Yes	-0.31	7.39	22
702837	PERRY	Hybrid	1,315	19	8	0	3.0	1.1	5.8	2.5	8.8	3.6	12.4	186	20,790	Yes	0.26	8.76	35

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
200333	TITUSVILLE	Hybrid	1,594	49	15	5	4.9	0.3	10.1	2.5	15.0	2.8	17.8	2,878	152,034	Yes	-2.96	5.84	49
405132	HUTCHINSON ISL	Hybrid	25	6	14	2	3.2	0.9	0.9	5.5	4.1	6.4	10.5	26	1,781	Yes	1.17	3.97	2
805233	NATOMA	Hybrid	1,787	14	8	2	2.1	0.1	3.3	2.2	5.4	2.3	7.7	366	61,229	Yes	-0.25	6.05	21
810832	BELL	UG	827	0	10	0	-	1.3	-	3.9	-	5.2	5.2	28	3,045	Yes	-0.12	3.88	3
704033	MOTOROLA	Hybrid	796	1	18	0	1.7	0.1	0.3	3.1	2.0	3.2	5.2	35	5,561	Yes	0.06	4.36	5
809235	MITCHELL	Hybrid	945	12	38	0	3.8	0.8	1.3	3.8	5.1	4.6	9.7	88	21,148	Yes	-0.05	6.95	8
405333	BEELINE	Hybrid	1,760	0	45	2	6.1	1.0	0.7	13.1	6.8	14.1	20.9	838	63,019	Yes	-0.55	7.55	21
411232	MORAY	UG	6	0	4	0	-	0.8	-	0.2	-	1.0	1.0	-	-	Yes	0.15	3.35	0
700231	HOLLYWOOD	Hybrid	1,403	14	12	3	3.2	0.4	3.6	1.1	6.8	1.5	8.3	419	66,719	Yes	-0.16	4.34	32
101633	HUDSON	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	-0.71	26.69	0
403735	MONET	Hybrid	1,547	0	37	0	2.0	3.4	-	17.8	2.0	21.2	23.2	4,663	81,712	Yes	0.10	6.00	7
203533	HIBISCUS	Hybrid	188	3	18	2	2.5	2.1	1.2	1.8	3.7	3.9	7.6	209	1,716	Yes	-0.21	6.09	7
808168	MILAM	Hybrid	498	0	33	0	2.5	1.3	-	4.7	2.5	6.0	8.5	545	31,477	Yes	-0.03	7.17	6
800439	COCONUT GROVE	UG	1	0	0	0	-	3.2	-	-	-	3.2	3.2	-	-	Yes	-0.01	3.79	0
705531	SOUTHSIDE	Hybrid	960	13	11	4	1.7	1.0	2.8	0.9	4.5	1.9	6.4	1,121	108,206	Yes	0.40	5.20	31
407866	TARTAN	Hybrid	2,376	6	55	1	4.6	3.0	1.8	25.7	6.4	28.7	35.1	3,499	45,973	Yes	0.29	12.39	32
102367	ST JOE	Hybrid	2,850	6	55	3	4.3	5.0	1.7	38.9	6.0	43.9	49.9	712	49,290	Yes	-0.96	11.94	23
410532	GRAMERCY	Hybrid	574	9	12	5	3.3	1.2	2.6	2.6	5.9	3.8	9.7	430	96,037	Yes	0.90	7.90	15
503137	SOLANA	UG	2,002	0	19	0	0.5	7.0	-	4.8	0.5	11.8	12.3	38	15,050	Yes	-0.21	6.29	5
810733	MCGREGOR	UG	-	0	4	0	-	1.3	-	0.9	-	2.2	2.2	-	-	Yes	-0.08	2.12	0
100433	PALATKA	Hybrid	1,845	43	11	11	5.5	0.9	21.1	1.8	26.6	2.7	29.3	2,359	79,351	Yes	-0.17	6.43	52
801134	FRONTON	Hybrid	1,990	40	18	5	6.0	0.2	5.3	1.3	11.3	1.5	12.8	4,158	238,755	Yes	-0.08	9.32	40
803931	SUNNY ISLES	UG	858	0	9	1	-	2.8	-	0.9	-	3.7	3.7	293	34,885	Yes	-0.05	3.25	2
203032	FRONTENAC	Hybrid	927	13	15	0	2.2	0.4	4.7	1.8	6.9	2.2	9.1	170	46,579	Yes	0.03	3.43	10
700841	VERENA	Hybrid	1,206	11	9	3	2.1	3.6	1.3	0.5	3.4	4.1	7.5	1,317	105,111	Yes	-0.25	4.65	26
704265	IMAGINATION	UG	1,925	0	34	0	-	5.5	-	17.9	-	23.4	23.4	1,978	79,719	Yes	0.16	12.06	3
804439	VENETIAN	Hybrid	1,658	3	13	0	1.5	2.1	0.1	0.4	1.6	2.5	4.1	146	6,387	Yes	-0.09	7.81	8
806138	DOUGLAS	Hybrid	1,696	15	8	5	2.9	1.6	4.1	0.3	7.0	1.9	8.9	1,144	150,549	Yes	-0.24	6.46	24
201032	EAU GALLIE	Hybrid	1,556	31	8	6	3.3	0.1	6.6	3.5	9.9	3.6	13.5	1,386	36,106	Yes	-0.22	4.58	19
505366	PARK	UG	2,137	0	46	0	1.2	5.0	-	19.2	1.2	24.2	25.4	144	25,026	Yes	-0.20	12.40	3
403435	JENSEN	Hybrid	2,153	19	56	3	4.3	4.7	1.8	12.7	6.1	17.4	23.5	3,479	76,310	Yes	-0.05	6.25	26
705638	COPANS	Hybrid	854	1	25	2	1.5	0.9	0.3	5.6	1.8	6.5	8.3	14	3,551	Yes	0.10	5.30	7
704565	MALLARD	Hybrid	2,891	0	33	0	2.0	0.1	0.1	17.9	2.1	18.0	20.1	428	73,620	Yes	-0.24	11.96	41
307762	ONEIL	Hybrid	1,437	73	27	7	9.9	0.4	24.8	10.1	34.7	10.5	45.2	1,238	47,753	Yes	0.48	5.78	71
802132	MIRAMAR	Hybrid	638	12	8	0	1.9	0.3	1.0	1.3	2.9	1.6	4.5	763	84,746	Yes	0.09	2.29	9
703932	WESTINGHOUSE	Hybrid	1,777	0	27	0	2.2	0.4	-	11.9	2.2	12.3	14.5	74	10,182	Yes	-0.40	6.10	12
808263	LINDGREN	Hybrid	3,472	1	39	0	2.3	2.4	0.1	18.9	2.4	21.3	23.7	13,612	359,196	Yes	0.41	12.41	28
509864	ANGLER	Hybrid	1,426	0	30	0	2.2	0.7	0.3	10.8	2.5	11.5	14.0	39	9,126	Yes	0.00	0.00	1
811437	WATKINS	UG	20	0	5	0	-	4.0	-	0.8	-	4.8	4.8	-	-	Yes	-0.93	2.67	0
805832	CORAL REEF	Hybrid	577	3	16	0	1.8	0.5	1.2	3.7	3.0	4.2	7.2	207	77,060	Yes	-4.29	4.51	15
801032	NORMANDY BEACH	UG	575	0	12	0	-	3.6	-	0.3	-	3.9	3.9	-	-	Yes	-0.49	5.01	0
501533	PUNTA GORDA	Hybrid	1,041	34	22	4	5.0	0.5	6.4	3.1	11.4	3.6	15.0	835	21,290	Yes	0.91	5.51	24
706663	NOBHILL	Hybrid	2,915	10	50	4	5.2	1.8	3.1	15.7	8.3	17.5	25.8	8,447	198,516	Yes	0.37	13.67	23
707133	CULLUM	UG	1,093	0	14	0	-	3.6	-	10.1	-	13.7	13.7	82	9,884	Yes	-0.33	5.17	4
106232	GERONA	Hybrid	389	7	8	1	1.4	0.9	4.0	1.3	5.4	2.2	7.6	360	19,220	Yes	-0.85	5.05	8
205634	SARNO	Hybrid	958	17	24	5	4.3	1.1	5.3	7.5	9.6	8.6	18.2	1,060	94,080	Yes	5.59	7.79	15
803635	SEABOARD	Hybrid	60	0	5	0	1.0	0.6	-	0.1	1.0	0.7	1.7	3	654	Yes	-0.08	6.92	3
402536	BELVEDERE	Hybrid	898	29	10	1	3.9	1.0	3.0	2.3	6.9	3.3	10.2	117	18,985	Yes	0.02	6.42	17
702633	ELY	Hybrid	1,895	12	18	4	2.1	1.4	2.8	4.7	4.9	6.1	11.0	258	29,339	Yes	-0.07	7.63	16
408462	ADAMS	Hybrid	468	40	2	9	6.4	0.3	57.1	5.9	63.5	6.2	69.7	1,122	126,095	Yes	-0.22	1.88	46
704931	LAKEVIEW	Hybrid	1,754	4	36	0	3.0	0.8	1.4	11.0	4.4	11.8	16.2	329	50,965	Yes	-0.18	8.12	16
405465	CLINTMOORE	UG	2,016	0	35	0	1.6	5.8	-	29.7	1.6	35.5	37.1	239	24,753	Yes	0.02	13.42	11

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR	
213362	GLENN	UG	9	0	11	0	-	1.9	-	1.5	-	3.4	3.4	1	309	Yes	0.23	0.63	1	
300432	LAKE BUTLER	OH	656	21	3	6	3.3	-	14.4	0.6	17.7	0.6	18.3	127	13,244	Yes	-0.03	3.27	20	
405267	ACME	Hybrid	239	0	4	0	1.0	4.4	-	1.0	1.0	5.4	6.4	198	16,104	Yes	-0.07	7.93	3	
105764	RIVERTON	Hybrid	1,695	1	37	1	3.7	5.8	0.2	40.9	3.9	46.7	50.6	95	15,450	Yes	8.92	8.92	13	
700732	FAIRMONT	Hybrid	1,114	21	13	1	3.1	-	6.8	1.4	9.9	1.4	11.3	658	127,516	Yes	0.20	5.90	79	
809038	AVENTURA	UG	2,147	0	5	0	-	3.2	-	2.3	-	5.5	5.5	29	1,301	Yes	-0.80	6.80	2	
807164	PENNSUCO	Hybrid	1,691	1	60	4	7.3	1.0	1.1	10.6	8.4	11.6	20.0	2,139	24,957	Yes	0.02	11.32	18	
510664	KELLY	UG	1,865	0	29	0	0.7	6.0	0.3	22.0	1.0	28.0	29.0	1,900	119,657	Yes	0.31	8.01	10	
406338	ROEBUCK	UG	-	0	0	0	-	2.6	-	-	-	2.6	2.6	-	-	Yes	8.11	8.11	0	
201134	PATRICK	Hybrid	1,243	64	56	5	9.0	3.5	9.0	23.0	18.0	26.5	44.5	1,740	126,221	Yes	-0.20	6.90	37	
103833	WILLOW	Hybrid	1,528	0	39	1	2.9	0.4	0.2	16.4	3.1	16.8	19.9	1,172	48,956	Yes	-0.18	6.02	22	
406862	KIMBERLY	Hybrid	1,610	0	24	0	2.6	1.8	-	14.5	2.6	16.3	18.9	4,728	218,832	Yes	-4.18	6.42	13	
706062	HIATURA	Hybrid	1,963	20	27	6	4.1	0.6	12.6	8.5	16.7	9.1	25.8	1,540	47,629	Yes	-5.41	11.09	27	
703532	DEERFIELD BEACH	Hybrid	2,460	15	14	4	3.9	0.4	7.4	3.5	11.3	3.9	15.2	394	66,458	Yes	-0.10	7.40	40	
503969	ESTERO	Hybrid	2,986	4	40	3	4.1	3.4	1.9	22.4	6.0	25.8	31.8	281	64,301	Yes	-0.44	7.76	13	
507962	MCCALL	Hybrid	3,251	85	7	10	14.4	0.5	64.7	12.7	79.1	13.2	92.3	2,434	128,936	Yes	3.34	16.14	93	
704932	LAKEVIEW	Hybrid	3,070	0	21	0	1.2	2.4	-	11.8	1.2	14.2	15.4	464	6,053	Yes	-0.13	4.37	4	
807532	DADELAND	Hybrid	2,170	0	20	1	0.3	2.9	0.1	3.3	0.4	6.2	6.6	987	35,232	Yes	0.12	4.82	6	
703731	CRYSTAL	Hybrid	1,242	7	16	5	2.1	1.5	3.7	5.0	5.8	6.5	12.3	776	56,515	Yes	-0.20	6.80	25	
412432	SPANISH LAKES	Hybrid	135	31	5	4	16.1	0.1	45.5	4.3	61.6	4.4	66.0	634	145,435	Yes	-0.09	0.41	29	
107161	HIGHRIDGE	Hybrid	552	28	29	10	17.4	0.5	12.8	4.6	30.2	5.1	35.3	461	31,499	Yes	-0.01	7.59	25	
809032	AVENTURA	UG	1,201	0	13	0	-	4.2	-	4.3	-	8.5	8.5	479	19,208	Yes	-1.19	4.41	6	
706064	HIATURA	Hybrid	1,390	0	19	1	1.1	0.3	-	10.0	1.1	10.3	11.4	86	14,060	Yes	-6.44	4.86	6	
201732	SYKES CREEK	Hybrid	1,100	16	12	0	2.9	0.4	3.8	0.4	6.7	0.8	7.5	130	14,164	Yes	-2.95	3.85	8	
704765	STONEBRIDGE	Hybrid	2,421	0	18	0	1.0	3.0	-	13.6	1.0	16.6	17.6	400	137,424	Yes	-0.36	8.14	19	
507667	GLADIOLUS	Hybrid	3,420	11	41	8	5.5	2.9	6.6	24.4	12.1	27.3	39.4	35	1,365	Yes	0.00	0.00	5	
812831	WILCOX	UG	-	0	0	0	-	0.2	-	-	-	-	0.2	0.2	-	-	Yes	-0.23	2.77	0
210132	DERBY	Hybrid	413	1	30	1	1.5	4.5	0.2	5.3	1.7	9.8	11.5	19	5,675	Yes	0.22	5.42	3	
809332	RONEY	UG	566	0	11	0	-	4.2	-	0.7	-	4.9	4.9	-	-	Yes	-0.14	5.36	0	
207938	RINEHART	Hybrid	283	10	21	3	3.0	0.7	2.2	2.4	5.2	3.1	8.3	10	445	Yes	4.76	4.76	4	
708063	WINDMILL	UG	949	0	28	0	-	6.2	-	10.3	-	16.5	16.5	61	11,128	Yes	0.75	8.25	3	
807337	GOULDS	Hybrid	1,813	14	27	8	3.2	0.5	6.9	12.6	10.1	13.1	23.2	191	15,594	Yes	0.20	6.80	26	
801637	PRINCETON	Hybrid	2,009	8	22	3	2.2	1.3	4.3	18.3	6.5	19.6	26.1	210	14,821	Yes	0.37	8.47	7	
803933	SUNNY ISLES	Hybrid	2,501	8	40	4	2.1	-	2.4	8.0	4.5	8.0	12.5	2,650	33,537	Yes	-0.33	8.47	19	
803033	TROPICAL	Hybrid	2,177	9	24	1	1.3	1.6	3.7	9.8	5.0	11.4	16.4	380	95,827	Yes	-0.18	8.92	25	
801237	OPA LOCKA	Hybrid	3	0	0	0	0.7	0.9	-	-	0.7	0.9	1.6	-	-	Yes	-0.14	6.46	0	
507963	MCCALL	OH	1,399	86	1	1	9.7	1.7	66.8	1.4	76.5	3.1	79.6	1	168	Yes	0.00	0.00	1	
808061	FLAGAMI	Hybrid	3,291	0	51	2	1.7	3.3	0.4	17.3	2.1	20.6	22.7	2,096	128,422	Yes	-0.50	13.80	23	
801838	BISCAYNE	Hybrid	1,621	23	4	3	2.6	2.6	11.0	0.9	13.6	3.5	17.1	1,632	210,319	Yes	0.69	8.09	90	
502532	PALMA SOLA	Hybrid	1,711	8	29	3	2.9	0.4	4.5	9.6	7.4	10.0	17.4	684	192,264	Yes	-0.24	6.16	38	
414032	GRACEWOOD	Hybrid	326	0	7	0	0.9	1.0	-	5.2	0.9	6.2	7.1	9	2,155	Yes	0.52	1.82	2	
702438	PEMBROKE	Hybrid	1,228	0	20	0	0.9	2.5	-	6.0	0.9	8.5	9.4	38	7,048	Yes	0.34	4.24	3	
800238	MIAMI BEACH	Hybrid	755	0	13	1	0.8	3.6	0.1	0.6	0.9	4.2	5.1	2,850	89,130	Yes	0.57	3.67	7	
203133	ROCKLEDGE	Hybrid	1,589	22	5	5	2.3	0.1	15.9	4.0	18.2	4.1	22.3	4,441	213,630	Yes	-0.01	6.29	54	
811062	PALMETTO	Hybrid	2,470	0	59	2	2.4	2.3	0.3	8.6	2.7	10.9	13.6	11	2,732	Yes	-0.40	9.20	3	
502636	COLONIAL	Hybrid	1,882	45	13	7	3.7	0.9	10.7	2.5	14.4	3.4	17.8	2,461	88,902	Yes	-0.24	7.06	59	
702135	CYPRESS CREEK	Hybrid	214	0	29	0	2.5	0.4	0.1	1.6	2.6	2.0	4.6	3	365	Yes	0.35	4.05	2	
414135	CANAL	Hybrid	70	2	0	2	0.5	0.2	1.4	0.1	1.9	0.3	2.2	24	2,296	Yes	-0.10	0.30	2	
801434	FULFORD	Hybrid	930	25	4	6	1.7	0.5	5.9	0.3	7.6	0.8	8.4	1,867	156,184	Yes	-0.05	4.75	61	
106864	FOREST GROVE	Hybrid	1,846	24	4	0	5.6	0.9	21.6	1.1	27.2	2.0	29.2	118	3,894	Yes	2.93	2.93	1	
810364	NEWTON	Hybrid	2,084	0	40	0	1.5	2.8	-	22.2	1.5	25.0	26.5	2,082	174,185	Yes	-0.42	12.78	10	
504762	ALVA	Hybrid	3,423	64	59	24	14.8	7.7	47.4	36.1	62.2	43.8	106.0	4,731	290,849	Yes	-1.64	13.06	76	

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
100831	PORT ORANGE	Hybrid	1,960	23	12	1	2.9	1.5	9.4	5.6	12.3	7.1	19.4	2,754	79,522	Yes	-0.60	5.90	47
401764	OLYMPIA	Hybrid	396	28	17	3	14.4	2.6	20.1	6.8	34.5	9.4	43.9	45	5,800	Yes	-0.45	2.05	17
510761	OVERBROOK	Hybrid	2,532	28	39	9	6.6	1.3	20.7	19.5	27.3	20.8	48.1	387	81,536	Yes	-0.41	7.89	52
104831	TAYLOR	Hybrid	1,088	9	12	2	1.7	0.1	6.7	4.7	8.4	4.8	13.2	282	31,964	Yes	-0.11	4.19	19
402235	PRATT & WHITNEY	OH	-	0	0	0	6.2	-	-	-	6.2	-	6.2	-	-	Yes	0.23	3.63	0
101861	ORANGEDALE	Hybrid	3,186	9	47	2	8.0	3.1	1.2	54.1	9.2	57.2	66.4	5,288	327,654	Yes	0.85	13.35	29
108964	DURBIN	Hybrid	2,476	11	42	3	5.2	7.2	2.3	40.8	7.5	48.0	55.5	2,346	132,789	Yes	0.70	9.00	16
203631	HARRIS	Hybrid	1,245	12	29	1	4.8	0.4	4.6	7.0	9.4	7.4	16.8	233	45,890	Yes	-0.85	6.55	14
100331	HASTINGS	Hybrid	954	79	6	13	14.3	0.2	44.5	3.4	58.8	3.6	62.4	2,200	82,412	Yes	-0.07	3.93	77
700140	SISTRUNK	UG	281	0	5	1	-	2.5	0.1	0.3	0.1	2.8	2.9	-	-	Yes	0.48	6.48	0
706265	VALENCIA	Hybrid	2,548	3	42	2	3.9	3.3	1.7	23.2	5.6	26.5	32.1	6,290	128,132	Yes	-1.51	14.89	17
800831	RAILWAY	UG	54	0	3	0	-	2.9	-	0.2	-	3.1	3.1	16	2,928	Yes	-0.25	4.45	1
208168	HIELD	Hybrid	1,762	12	31	3	3.0	3.7	2.7	22.8	5.7	26.5	32.2	94	12,673	Yes	6.58	6.58	13
804333	KENDALL	Hybrid	457	8	15	6	2.7	0.1	3.6	2.6	6.3	2.7	9.0	160	26,611	Yes	-0.19	3.91	25
411032	EDEN	Hybrid	756	8	30	0	4.1	0.6	4.1	3.9	8.2	4.5	12.7	59	5,288	Yes	0.00	6.30	8
506264	SHADE	Hybrid	1,601	23	23	6	2.9	0.8	6.9	4.8	9.8	5.6	15.4	436	75,096	Yes	-0.19	7.01	21
806431	HAINLIN	Hybrid	972	18	24	3	4.9	0.2	4.6	13.6	9.5	13.8	23.3	983	30,618	Yes	-0.91	6.09	29
503638	EDISON	Hybrid	1,070	8	15	4	1.2	0.6	4.4	5.0	5.6	5.6	11.2	322	36,756	Yes	-0.12	2.78	24
702133	CYPRESS CREEK	Hybrid	245	1	56	2	2.4	0.1	0.5	2.5	2.9	2.6	5.5	257	9,518	Yes	0.02	5.32	7
400232	HIEDURA ST	Hybrid	972	4	7	2	1.2	1.5	0.8	1.1	2.0	2.6	4.6	56	3,916	Yes	-0.31	4.09	5
811433	WATKINS	Hybrid	66	1	13	0	0.7	1.0	-	3.3	0.7	4.3	5.0	-	-	Yes	0.67	6.67	0
705762	TRACE	Hybrid	1,906	0	44	1	3.1	1.3	0.4	15.1	3.5	16.4	19.9	860	24,518	Yes	0.30	7.80	10
200734	COCOA BEACH	Hybrid	763	4	17	3	1.8	0.3	0.6	2.2	2.4	2.5	4.9	108	2,046	Yes	-0.05	3.65	5
707136	CULLUM	UG	1	0	0	0	-	0.7	-	-	-	0.7	0.7	-	-	Yes	-0.10	4.40	0
203233	INDIALANTIC	Hybrid	1,443	41	7	5	2.9	0.5	9.3	1.1	12.2	1.6	13.8	2,449	137,574	Yes	-0.46	5.44	37
400663	WABASSO	Hybrid	458	24	18	9	6.9	0.2	18.6	10.3	25.5	10.5	36.0	393	70,561	Yes	-0.02	3.68	39
800240	MIAMI BEACH	UG	74	1	7	1	-	2.3	0.2	4.6	0.2	6.9	7.1	14	2,891	Yes	0.15	2.95	6
409632	RAINBERRY	Hybrid	183	0	12	0	0.3	0.8	0.1	2.5	0.4	3.3	3.7	-	-	Yes	0.13	3.03	0
407861	LOXAHATCHEE	Hybrid	1,251	45	30	6	23.3	8.7	34.2	18.4	57.5	27.1	84.6	556	62,664	Yes	0.52	5.92	71
202834	CLEARLAKE	Hybrid	1,022	30	6	5	2.7	0.8	10.1	3.1	12.8	3.9	16.7	134	32,860	Yes	4.42	4.42	17
703531	DEERFIELD BEACH	Hybrid	1,785	10	30	8	2.8	2.3	5.2	2.9	8.0	5.2	13.2	573	49,815	Yes	-0.60	6.60	42
700737	FAIRMONT	Hybrid	1,354	13	7	3	1.9	0.2	5.6	0.9	7.5	1.1	8.6	393	58,767	Yes	1.06	5.36	37
301137	COLUMBIA	Hybrid	945	31	5	7	4.2	0.3	7.4	0.5	11.6	0.8	12.4	39	5,307	Yes	-0.05	5.05	13
805431	DADE	Hybrid	537	4	32	1	2.5	0.5	0.9	2.5	3.4	3.0	6.4	571	6,827	Yes	-0.38	5.42	7
400434	HILLCREST	Hybrid	504	17	7	2	1.2	2.4	2.2	1.7	3.4	4.1	7.5	660	25,279	Yes	-0.12	3.28	24
102034	BULLOW	Hybrid	1,930	41	34	11	8.4	0.9	11.9	15.6	20.3	16.5	36.8	301	38,884	Yes	-0.17	3.93	56
210533	APOLLO	UG	11	0	8	0	-	3.6	-	0.3	-	3.9	3.9	-	-	Yes	3.20	3.20	0
706068	HIATUS	UG	55	0	4	0	-	6.6	-	1.1	-	7.7	7.7	-	-	Yes	0.20	4.10	0
100137	DAYTONA BEACH	Hybrid	1,465	28	17	9	3.8	0.7	10.0	2.9	13.8	3.6	17.4	222	42,600	Yes	-1.66	5.84	29
408861	ABERDEEN	Hybrid	2,603	4	53	3	4.5	4.4	2.0	26.1	6.5	30.5	37.0	362	65,913	Yes	-0.35	13.75	13
804238	PERRINE	Hybrid	1,341	4	33	1	3.0	0.4	3.6	3.7	6.6	4.1	10.7	1,571	209,607	Yes	1.55	8.85	25
501434	ARCADIA	OH	903	63	18	5	18.1	0.1	44.1	2.8	62.2	2.9	65.1	646	142,836	Yes	-0.79	5.91	30
408662	HOMELAND	Hybrid	2,459	10	45	2	5.2	4.8	6.0	29.6	11.2	34.4	45.6	166	32,689	Yes	-1.95	10.15	18
403934	LAKE PARK	Hybrid	1,814	22	14	9	3.8	0.5	5.4	2.4	9.2	2.9	12.1	175	20,058	Yes	-0.18	7.32	16
104735	KACIE	Hybrid	1,532	34	17	5	5.0	1.9	12.5	11.0	17.5	12.9	30.4	1,852	120,590	Yes	5.34	5.54	45
404736	HILLSBORO	Hybrid	1,444	3	22	0	1.3	1.6	0.1	4.5	1.4	6.1	7.5	259	45,627	Yes	0.21	6.11	13
806934	BIRD	Hybrid	1,868	10	13	3	0.4	0.7	5.1	2.6	5.5	3.3	8.8	1,646	82,034	Yes	-0.34	5.26	35
412763	HUMMINGBIRD	Hybrid	8	1	4	1	1.6	0.2	9.3	0.9	10.9	1.1	12.0	2	449	Yes	0.54	0.54	1
401533	FT PIERCE	Hybrid	885	49	22	3	8.6	1.2	12.4	11.7	21.0	12.9	33.9	1,833	28,645	Yes	0.41	4.81	32
800443	COCONUT GROVE	Hybrid	858	6	5	2	1.2	1.8	1.0	0.4	2.2	2.2	4.4	861	10,830	Yes	-1.00	3.00	3
402137	TERMINAL	Hybrid	2,776	15	28	2	2.0	3.0	7.1	5.8	9.1	8.8	17.9	405	69,473	Yes	0.01	8.21	26
105761	RIVERTON	Hybrid	1,912	8	35	7	2.7	8.7	13.4	35.4	16.1	44.1	60.2	626	114,882	Yes	-5.32	8.38	49

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY-pk Prior)	Peak Load (MVA)	Number of N on FDR
404231	BOCA TEECA	Hybrid	2,187	6	38	6	2.2	0.6	2.9	12.5	5.1	13.1	18.2	115	17,182	Yes	-0.24	7.96	18
803531	MARKET	Hybrid	808	7	14	2	1.9	0.2	1.6	0.4	3.5	0.6	4.1	1,788	133,102	Yes	-2.65	5.95	15
405636	FOUNTAIN	Hybrid	1,621	1	29	0	3.3	0.1	-	13.4	3.3	13.5	16.8	2,771	79,113	Yes	-0.09	5.72	14
100533	MCMEEKIN	OH	277	21	1	5	5.5	0.1	11.9	0.3	17.4	0.4	17.8	255	29,134	Yes	0.13	2.33	12
404839	GERMANTOWN	Hybrid	1,712	30	26	9	3.9	0.9	7.1	2.9	11.0	3.8	14.8	450	110,991	Yes	0.39	7.59	52
500534	CLARK	Hybrid	2,176	11	36	7	3.8	1.4	8.0	9.1	11.8	10.5	22.3	1,330	49,418	Yes	-0.37	7.43	31
804337	KENDALL	UG	1	0	0	0	-	1.3	-	-	-	1.3	1.3	-	-	Yes	-0.10	1.50	0
811637	LUMMUS	UG	6	0	5	0	-	3.9	-	0.1	-	4.0	4.0	-	-	Yes	1.35	1.35	0
807035	ROSELAWN	Hybrid	1,996	12	22	3	3.2	0.9	4.6	4.7	7.8	5.6	13.4	312	34,742	Yes	-5.26	6.04	41
109032	WRIGHT	Hybrid	1,686	13	53	0	4.2	6.0	4.1	13.3	8.3	19.3	27.6	2,019	78,117	Yes	0.51	11.51	36
100333	HASTINGS	Hybrid	913	71	2	7	11.7	0.1	66.8	4.8	78.5	4.9	83.4	1,575	56,209	Yes	-0.05	2.85	73
803431	MIAMI SHORES	Hybrid	1,485	31	6	2	3.9	0.5	8.9	0.5	12.8	1.0	13.8	686	134,605	Yes	-0.33	6.27	63
301134	COLUMBIA	Hybrid	815	46	10	4	7.1	7.3	9.4	2.0	16.5	9.3	25.8	247	32,883	Yes	-0.38	3.62	40
706963	CHAPEL	UG	1,888	0	27	0	0.5	2.4	-	14.3	0.5	16.7	17.2	131	25,456	Yes	-0.44	9.66	4
405866	DELTRAIL	Hybrid	4,798	2	52	3	3.5	2.0	1.7	31.0	5.2	33.0	38.2	3,281	93,968	Yes	-0.15	11.45	16
408763	SABAL	UG	3,729	1	87	1	2.3	12.5	0.6	51.7	2.9	64.2	67.1	3,318	163,142	Yes	0.76	14.46	19
801832	BISCAYNE	Hybrid	2,741	32	11	12	4.0	0.8	9.9	1.0	13.9	1.8	15.7	1,857	201,964	Yes	-0.33	8.77	81
506963	WOODS	Hybrid	1,273	6	38	3	3.2	0.5	1.6	11.5	4.8	12.0	16.8	138	19,587	Yes	-0.05	5.75	15
106661	COQUINA	Hybrid	1,432	20	24	4	4.8	1.6	7.8	11.6	12.6	13.2	25.8	377	54,818	Yes	-0.23	8.37	31
811263	EUREKA	Hybrid	1,808	4	36	1	2.8	0.8	1.1	11.2	3.9	12.0	15.9	19	3,046	Yes	0.16	7.46	5
704069	MOTOROLA	Hybrid	1,649	1	22	1	2.5	0.5	0.1	11.8	2.6	12.3	14.9	2,146	142,563	Yes	0.02	5.92	20
407561	GLENDALE	Hybrid	258	17	12	4	10.3	0.4	8.4	7.8	18.7	8.2	26.9	624	23,064	Yes	-0.06	1.64	15
401935	LINTON	Hybrid	1,396	24	35	4	2.8	2.7	5.8	12.9	8.4	15.6	24.0	258	41,527	Yes	1.92	7.92	26
504834	SORRENTO	Hybrid	2,537	23	37	4	8.0	1.0	6.8	13.3	14.8	14.3	29.1	910	169,128	Yes	0.73	7.93	47
410365	MARLIN	Hybrid	68	8	2	1	4.5	1.6	1.7	1.1	6.2	2.7	8.9	42	13,640	Yes	3.24	3.24	9
404239	BOCA TEECA	Hybrid	1,513	8	25	2	3.8	1.8	4.0	7.2	7.8	9.0	16.8	1,647	197,566	Yes	0.01	5.61	36
506764	VANDERBILT	Hybrid	3,392	12	50	1	5.2	4.0	2.4	30.2	7.6	34.2	41.8	258	36,638	Yes	-0.38	19.72	31
800245	MIAMI BEACH	UG	1,899	0	14	0	-	3.9	-	1.3	-	5.2	5.2	716	18,923	Yes	-0.08	7.12	4
400537	BOYNTON	Hybrid	449	2	24	0	2.1	0.2	0.5	1.9	2.6	2.1	4.7	189	38,339	Yes	0.27	3.57	6
410163	PLAZA	Hybrid	1,828	30	14	6	4.6	0.5	16.6	4.2	21.2	4.7	25.9	392	24,447	Yes	-0.19	8.21	35
503639	EDISON	Hybrid	2,529	3	35	4	2.7	1.1	3.1	17.7	5.8	18.8	24.6	1,292	86,008	Yes	0.04	8.84	52
411035	EDEN	Hybrid	2,304	29	17	2	3.2	3.0	21.2	8.7	24.4	11.7	36.1	212	10,739	Yes	-0.15	8.75	21
506661	LIVINGSTON	Hybrid	2,211	1	61	2	2.9	4.1	1.9	30.6	4.8	34.7	39.5	6,731	188,865	Yes	-0.72	13.18	21
800844	RAILWAY	UG	322	0	8	0	-	7.9	-	0.6	-	8.5	8.5	1	680	Yes	0.10	4.20	1
301462	YULEE	Hybrid	963	44	7	5	12.3	0.4	26.3	6.3	38.6	6.7	45.3	1,874	126,944	Yes	-0.86	11.54	62
701234	PLAYLAND	Hybrid	1,014	5	5	4	1.3	0.1	3.5	1.5	4.8	1.6	6.4	744	76,509	Yes	-4.42	3.38	25
503035	PHILLIPPI	Hybrid	1,159	4	12	3	1.2	0.3	3.0	7.0	4.2	7.3	11.5	72	11,088	Yes	-0.36	4.24	12
800431	COCONUT GROVE	Hybrid	1,497	29	7	4	3.3	0.7	7.4	0.6	10.7	1.3	12.0	1,873	118,245	Yes	0.55	7.95	54
701538	DANIA	Hybrid	1,725	14	18	2	3.5	0.3	3.2	2.1	6.7	2.4	9.1	845	84,630	Yes	0.13	6.43	40
701135	LYONS	Hybrid	2,111	26	14	2	3.6	0.4	7.4	3.2	11.0	3.6	14.6	296	41,083	Yes	-0.07	7.73	35
805433	DADE	Hybrid	1,619	31	7	4	3.4	0.9	11.8	2.7	15.2	3.6	18.8	733	121,615	Yes	-0.19	7.11	53
400235	DATURA ST	Hybrid	282	7	16	0	0.8	2.1	0.6	1.8	1.4	3.9	5.3	1	160	Yes	0.16	5.46	1
406535	OSBORNE	Hybrid	2,201	12	25	2	3.1	1.0	8.9	6.5	12.0	7.5	19.5	558	71,707	Yes	0.24	9.44	51
404031	WESTWARD	Hybrid	791	17	19	3	3.7	0.2	4.9	0.7	8.6	0.9	9.5	142	17,579	Yes	0.11	6.41	16
106238	GERONA	Hybrid	1,129	22	24	7	4.2	0.1	6.5	8.5	10.7	8.6	19.3	174	17,283	Yes	5.49	5.49	18
808435	SNAKE CREEK	Hybrid	1,147	0	19	1	2.5	1.3	0.1	8.9	2.6	10.2	12.8	1,205	81,624	Yes	-0.04	5.76	28
404335	IBM	Hybrid	305	0	14	0	0.7	1.6	-	4.6	0.7	6.2	6.9	8	1,636	Yes	0.05	4.05	8
307761	ONEIL	Hybrid	2,322	61	42	16	8.0	1.7	18.6	31.3	26.6	33.0	59.6	697	92,530	Yes	1.20	17.70	55
502634	COLONIAL	Hybrid	1,195	11	46	4	4.7	0.4	2.0	6.3	6.7	6.7	13.4	1,195	60,452	Yes	-0.23	4.57	2
204362	SUNTREE	Hybrid	2,729	7	34	0	2.0	4.2	1.6	31.1	3.6	35.3	38.9	5,743	249,826	Yes	-1.53	12.47	22
406934	DELMAR	UG	1,677	0	25	0	0.4	2.4	-	9.9	0.4	12.3	12.7	113	12,806	Yes	-0.28	6.62	8
101535	GENERAL ELECTRIC	Hybrid	382	1	34	2	1.9	4.9	1.2	6.2	3.1	11.1	14.2	625	74,349	Yes	-0.21	5.99	10

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
802135	MIRAMAR	Hybrid	1,990	6	21	3	2.8	1.6	1.5	1.2	4.3	2.8	7.1	3,953	244,689	Yes	0.12	7.32	13
807334	GOULDS	UG	50	0	10	0	-	3.4	-	1.0	-	4.4	4.4	55	744	Yes	0.95	2.95	3
704934	LAKEVIEW	Hybrid	2,666	0	29	0	1.1	2.5	-	14.9	1.1	17.4	18.5	4,005	65,373	Yes	-0.24	7.16	10
105762	RIVERTON	Hybrid	1,439	26	34	12	10.0	0.4	15.8	23.3	25.8	23.7	49.5	5,303	257,577	Yes	-1.36	8.14	42
102431	FLEMING	Hybrid	1,034	29	9	4	2.5	2.3	6.3	1.7	8.8	4.0	12.8	1,670	149,452	Yes	0.01	4.61	47
804835	COUNTY LINE	Hybrid	1,504	7	4	3	1.3	2.0	7.3	3.0	8.6	5.0	13.6	1,105	208,818	Yes	-0.67	7.23	45
706169	HOLLYBROOK	Hybrid	3,481	0	46	0	3.4	1.0	-	12.9	3.4	13.9	17.3	588	155,944	Yes	0.53	9.93	12
410363	MARLIN	Hybrid	1,629	4	37	0	1.3	3.7	0.1	19.9	1.4	23.6	25.0	26	6,392	Yes	-0.12	7.68	5
806234	INDIAN CREEK	UG	1,283	0	10	0	-	2.1	-	0.4	-	2.5	2.5	1	42	Yes	-0.01	3.09	1
800534	RIVERSIDE	OH	1,554	16	1	2	2.4	0.1	5.4	0.1	7.8	0.2	8.0	1,193	151,456	Yes	-0.05	6.05	49
504536	TUTTLE	Hybrid	1,350	12	20	6	2.0	0.8	4.2	2.9	6.2	3.7	9.9	239	26,652	Yes	0.00	6.50	18
101934	EDGEWATER	Hybrid	1,497	30	12	7	6.0	0.4	9.5	2.5	15.5	2.9	18.4	307	35,824	Yes	0.01	5.72	18
800734	HIALEAH	Hybrid	1,253	14	11	3	3.8	1.0	2.7	2.1	6.5	3.1	9.6	784	42,751	Yes	-0.28	7.12	29
705761	TRACE	Hybrid	2,727	0	37	3	2.8	3.9	0.9	20.2	3.7	24.1	27.8	674	106,873	Yes	-0.55	11.65	24
100832	PORT ORANGE	Hybrid	2,378	42	23	8	6.7	1.4	6.9	2.1	13.6	3.5	17.1	4,241	147,404	Yes	-0.15	7.05	65
108361	GATOR	Hybrid	1,898	12	38	2	3.7	3.8	2.8	27.8	6.5	31.6	38.1	208	24,619	Yes	-4.79	8.61	14
507163	POLO	Hybrid	3,240	6	64	8	7.9	1.0	5.0	29.8	12.9	30.8	43.7	700	69,879	Yes	-0.38	11.82	29
800243	MIAMI BEACH	UG	1,147	0	17	1	-	6.2	0.1	2.2	0.1	8.4	8.5	184	12,811	Yes	3.24	6.14	6
207937	RINEHART	Hybrid	1,324	1	30	0	1.1	2.9	-	13.7	1.1	16.6	17.7	45	2,795	Yes	6.23	6.23	3
410361	MARLIN	Hybrid	2,433	21	34	7	4.9	6.6	12.0	25.7	16.9	32.3	49.2	7,436	190,975	Yes	-0.42	11.18	46
201934	COURTENAY	Hybrid	896	4	25	2	4.9	0.6	2.6	8.1	7.5	8.7	16.2	997	58,516	Yes	0.05	6.55	11
202034	INDIAN HARBOR	Hybrid	1,406	7	9	7	1.5	1.6	9.4	4.4	10.9	6.0	16.9	687	34,296	Yes	-0.23	5.27	40
803632	SEABOARD	Hybrid	859	14	13	0	3.6	0.1	4.0	0.6	7.6	0.7	8.3	307	47,043	Yes	-0.30	6.00	35
807836	WESTON VILLAGE	Hybrid	253	1	25	1	1.9	0.4	0.3	1.2	2.2	1.6	3.8	262	14,258	Yes	0.00	8.30	5
802737	MARION	Hybrid	1,273	0	12	0	0.8	1.7	-	5.6	0.8	7.3	8.1	41	5,130	Yes	-0.15	3.35	8
807541	DADELAND	UG	844	0	6	0	-	4.2	-	0.8	-	5.0	5.0	-	-	Yes	2.05	6.05	0
709361	ORCHID	UG	1,331	0	7	0	-	7.3	-	1.4	-	8.7	8.7	-	-	Yes	0.10	9.60	0
700632	VERENA	Hybrid	1,083	5	14	7	2.7	1.2	3.1	1.9	5.8	3.1	8.9	1,170	55,139	Yes	-0.43	6.37	17
800737	HIALEAH	Hybrid	2,183	5	30	5	2.4	0.6	0.8	1.9	3.2	2.5	5.7	179	32,675	Yes	-0.31	6.09	8
704568	MALLARD	Hybrid	1,299	0	24	0	1.4	2.5	-	11.8	1.4	14.3	15.7	3,848	144,098	Yes	-0.73	7.47	19
700338	PINEHURST	Hybrid	954	14	11	4	2.2	0.8	2.3	0.5	4.5	1.3	5.8	60	14,103	Yes	1.64	4.94	8
508061	COOPER	Hybrid	2,259	28	21	1	5.7	2.4	13.5	2.8	19.2	5.2	24.4	2,945	188,719	Yes	-1.49	8.01	39
704562	MALLARD	UG	1,224	0	16	0	0.4	4.4	-	14.9	0.4	19.3	19.7	900	69,854	Yes	-0.44	9.56	14
403232	ATLANTIC	Hybrid	1,109	5	27	2	2.5	0.8	1.3	2.5	3.8	3.3	7.1	118	23,139	Yes	-0.08	5.12	9
801431	FULFORD	Hybrid	2,068	14	31	6	3.3	0.7	8.7	3.1	12.0	3.8	15.8	195	32,870	Yes	-1.22	8.28	44
807339	GOULDS	Hybrid	1,534	5	16	2	1.4	2.1	3.3	10.2	4.7	12.3	17.0	2,461	146,661	Yes	0.06	7.16	26
700144	SISTRUNK	Hybrid	1,744	17	13	10	2.4	1.0	2.6	1.2	5.0	2.2	7.2	726	22,184	Yes	0.17	6.77	16
700839	BEVERLY	Hybrid	804	7	5	1	2.0	1.5	5.5	1.2	7.5	2.7	10.2	429	52,737	Yes	-0.05	6.05	33
106361	REGIS	Hybrid	1,887	108	26	18	17.8	3.9	75.9	13.7	93.7	17.6	111.3	3,972	120,835	Yes	0.36	6.56	85
400234	DATURA ST	Hybrid	639	4	12	1	0.5	3.0	0.5	1.0	1.0	4.0	5.0	97	6,321	Yes	-0.20	5.30	2
701832	ROCK ISLAND	Hybrid	2,580	8	30	3	3.6	1.6	3.3	8.0	6.9	9.6	16.5	1,897	62,811	Yes	-0.13	8.67	23
508632	LIME	UG	437	0	3	0	-	2.7	-	0.5	-	3.2	3.2	-	-	Yes	0.02	1.82	0
805236	NATOMA	Hybrid	1,635	18	20	4	2.9	0.7	3.7	1.8	6.6	2.5	9.1	500	55,939	Yes	-0.89	7.51	24
400236	DATURA ST	UG	473	0	5	2	-	2.2	-	1.3	-	3.5	3.5	-	-	Yes	0.13	5.33	0
705561	SOUTHSIDE	UG	1,033	0	11	0	-	6.1	-	0.4	-	6.5	6.5	-	-	Yes	0.24	5.84	0
814434	BANYAN	Hybrid	1,205	2	34	2	1.8	3.8	0.2	5.0	2.0	8.8	10.8	31	3,198	Yes	0.13	6.03	5
507463	CORKSCREW	Hybrid	989	0	53	1	4.7	7.1	2.8	20.6	7.5	27.7	35.2	649	50,412	Yes	0.42	12.32	8
700532	POMPANO	Hybrid	1,181	12	36	5	5.1	2.0	3.8	5.8	8.9	7.8	16.7	423	21,118	Yes	-0.33	4.37	23
205532	DAIRY	Hybrid	2,066	22	33	5	4.5	0.1	6.1	15.5	10.6	15.6	26.2	430	41,515	Yes	-2.10	7.60	28
704132	MOFFETT	Hybrid	2,410	18	7	8	3.5	-	4.3	0.5	7.8	0.5	8.3	2,327	56,779	Yes	-0.12	6.68	28
406063	SHERMAN	Hybrid	3,025	85	37	16	30.3	0.4	63.6	39.2	93.9	39.6	133.5	3,819	151,189	Yes	0.08	8.78	82
808734	BOULEVARD	Hybrid	2,228	25	14	1	3.2	0.7	6.2	1.9	9.4	2.6	12.0	2,898	206,949	Yes	0.88	6.58	64

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
405935	BUTTS	Hybrid	1,157	0	23	0	0.8	1.3	-	8.2	0.8	9.5	10.3	54	14,871	Yes	-0.75	6.25	6
700968	HALLANDALE	UG	1,638	0	17	0	-	5.0	-	6.4	-	11.4	11.4	36	6,640	Yes	-1.18	7.02	3
801735	62ND AVE	OH	1,096	19	2	1	3.1	0.1	5.3	0.1	8.4	0.2	8.6	4,958	263,285	Yes	-0.33	5.37	56
701537	DANIA	Hybrid	1,128	21	21	1	4.0	2.0	4.3	2.5	8.3	4.5	12.8	1,056	57,604	Yes	-0.43	4.27	24
800731	HIALEAH	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	-0.01	0.09	0
814263	MANGO	UG	-	0	0	0	-	5.0	-	-	-	5.0	5.0	-	-	Yes	0.24	0.24	0
808835	SNAPPER CREEK	UG	609	0	6	0	-	5.7	-	0.7	-	6.4	6.4	-	-	Yes	0.02	2.62	0
811635	LUMMUS	UG	1	0	0	0	-	0.6	-	-	-	0.6	0.6	-	-	Yes	0.44	1.74	0
407031	RIO	Hybrid	2,020	31	15	12	4.3	0.7	11.8	4.1	16.1	4.8	20.9	278	44,107	Yes	-0.23	5.37	32
503863	ORTIZ	Hybrid	2,575	33	31	8	6.4	0.4	14.6	6.2	21.0	6.6	27.6	1,900	114,997	Yes	0.03	9.23	42
506961	WOODS	Hybrid	695	14	37	10	4.7	0.9	4.2	5.0	8.9	5.9	14.8	2,263	27,553	Yes	-0.81	8.29	22
406161	TURNPIKE	OH	2,936	39	8	2	6.2	0.6	33.5	0.5	39.7	1.1	40.8	9,524	164,536	Yes	0.27	15.47	79
808062	FLAGAMI	Hybrid	3,101	0	20	0	1.7	3.7	-	11.4	1.7	15.1	16.8	1,167	84,644	Yes	-0.23	7.17	11
101036	HOLLY HILL	Hybrid	1,206	30	13	7	3.5	0.4	7.3	1.7	10.8	2.1	12.9	742	33,425	Yes	-0.75	4.95	29
810162	SEAGULL	Hybrid	2,969	1	23	0	3.1	2.9	0.2	15.1	3.3	18.0	21.3	106	18,023	Yes	-0.40	10.40	7
400435	HILLCREST	Hybrid	1,071	21	11	2	2.5	0.3	5.7	2.9	8.2	3.2	11.4	1,948	60,670	Yes	0.30	4.70	33
805536	MASTER	Hybrid	169	1	47	0	2.7	0.7	-	2.4	2.7	3.1	5.8	746	37,173	Yes	0.08	5.68	2
505864	BUCKEY	Hybrid	1,786	17	29	5	13.1	1.0	5.8	10.2	18.9	11.2	30.1	519	78,242	Yes	0.04	5.94	27
209862	YORKE	UG	2,514	2	32	0	1.4	4.9	0.2	29.6	1.6	34.5	36.1	40	1,528	Yes	-1.61	11.29	7
806231	INDIAN CREEK	UG	1,114	0	6	0	-	2.3	-	0.5	-	2.8	2.8	-	-	Yes	0.43	4.63	0
303161	STARKE	OH	672	59	4	1	12.2	1.1	22.6	0.3	34.8	1.4	36.2	734	11,176	Yes	-0.27	2.43	28
809535	VIRGINIA KEY	UG	11	0	4	0	-	2.3	-	1.0	-	3.3	3.3	1	1,607	Yes	0.01	1.51	1
704667	SPRINGTREE	Hybrid	2,928	1	45	1	2.3	1.0	0.1	15.9	2.4	16.9	19.3	134	14,052	Yes	-1.20	8.20	12
810266	INTERNATIONAL	Hybrid	1,481	9	42	5	3.9	2.3	3.7	12.0	7.6	14.3	21.9	309	40,476	Yes	-0.11	9.69	23
408166	ROSS	Hybrid	3,094	1	72	0	3.3	6.8	0.2	28.7	3.5	35.5	39.0	53	7,363	Yes	-0.34	14.66	8
508461	GATEWAY	Hybrid	2,339	5	40	3	3.4	4.2	1.2	17.8	4.6	22.0	26.6	215	36,792	Yes	0.80	9.60	12
703231	WOODLANDS	Hybrid	1,688	1	28	1	1.4	2.2	0.3	16.7	1.7	18.9	20.6	2,025	137,785	Yes	-0.67	6.43	22
409432	SKYPASS	Hybrid	840	21	17	1	4.4	0.3	4.6	0.8	9.0	1.1	10.1	436	47,457	Yes	-0.49	5.81	29
101936	EDGEWATER	Hybrid	1,622	19	17	9	8.6	0.7	20.2	10.1	28.8	10.8	39.6	650	132,879	Yes	-0.18	7.32	35
405464	CLINTMOORE	Hybrid	2,284	1	40	2	2.4	5.0	0.8	31.6	3.2	36.6	39.8	2,225	105,795	Yes	-0.19	13.21	34
509064	SUMMIT	Hybrid	2,406	3	47	1	3.4	3.9	0.7	19.7	4.1	23.6	27.7	-	-	Yes	0.00	0.00	0
506465	FRANKLIN	OH	2,914	68	4	1	9.0	0.1	55.6	0.4	64.6	0.5	65.1	601	72,878	Yes	0.26	11.86	80
701433	PORT	Hybrid	91	8	17	1	2.5	0.1	0.4	0.9	2.9	1.0	3.9	182	6,700	Yes	0.47	4.27	6
500535	CLARK	Hybrid	1,678	2	30	4	2.2	0.1	1.7	15.7	3.9	15.8	19.7	326	54,385	Yes	-0.26	6.74	19
700634	VERENA	Hybrid	1,223	20	9	5	2.8	0.6	5.2	0.7	8.0	1.3	9.3	546	107,507	Yes	0.37	6.07	39
809337	RONEY	UG	283	0	6	0	-	5.6	-	0.9	-	6.5	6.5	121	8,635	Yes	-1.07	5.33	3
803234	HOMESTEAD	Hybrid	62	3	14	1	2.7	0.9	0.2	6.4	2.9	7.3	10.2	3	1,088	Yes	0.39	3.49	3
100631	CRESCENT CITY	OH	505	51	8	4	7.1	-	16.5	0.8	23.6	0.8	24.4	620	23,659	Yes	0.06	2.36	32
501536	PUNTA GORDA	Hybrid	1,759	26	24	7	3.6	0.4	6.6	5.7	10.2	6.1	16.3	111	14,894	Yes	-0.05	6.35	19
402937	OSLO	Hybrid	2,224	34	9	7	5.2	0.5	14.0	6.0	19.2	6.5	25.7	1,290	53,728	Yes	-0.26	6.04	22
804335	KENDALL	Hybrid	1,833	8	31	3	1.7	0.9	3.3	6.5	5.0	7.4	12.4	101	23,036	Yes	-0.13	6.77	20
410536	GATEWAY	Hybrid	772	11	19	5	4.3	1.1	3.8	6.1	8.1	7.2	15.3	604	122,514	Yes	0.47	8.27	21
400538	BOYNTON	Hybrid	2,253	0	34	1	2.2	0.9	0.7	8.8	2.9	9.7	12.6	393	33,099	Yes	-0.34	6.46	12
101536	GENERAL ELECTRIC	UG	66	0	5	0	-	1.8	-	0.7	-	2.5	2.5	28	5,106	Yes	-0.14	1.96	2
701163	LYONS	UG	1,459	0	11	0	-	6.5	-	0.4	-	6.9	6.9	728	62,338	Yes	0.80	5.20	4
800112	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	2.17	2.17	0
401432	WHITE CITY	Hybrid	1,422	24	28	8	5.1	0.8	14.1	10.2	19.2	11.0	30.2	1,047	96,654	Yes	0.56	7.86	35
814031	BRICKELL	Hybrid	559	2	10	2	0.3	5.1	0.3	0.5	0.6	5.6	6.2	618	34,366	Yes	0.42	3.52	10
205533	DAIRY	Hybrid	2,253	0	32	1	1.8	1.5	0.1	11.0	1.9	12.5	14.4	323	19,314	Yes	-0.20	6.10	9
404133	GOLF	Hybrid	816	6	8	1	1.3	0.1	5.5	0.9	6.8	1.0	7.8	1,067	151,852	Yes	-0.30	3.60	32
803231	HOMESTEAD	Hybrid	12	2	8	2	2.6	0.1	0.6	0.3	3.2	0.4	3.6	1	21	Yes	-0.48	0.62	1
409762	CATCHMENT	Hybrid	2,676	1	58	1	4.9	2.6	0.3	19.2	5.2	21.8	27.0	300	29,091	Yes	-0.59	12.11	13

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
800447	COCONUT GROVE	UG	282	1	2	0	-	2.2	-	0.2	-	2.4	2.4	-	-	Yes	0.34	5.04	0
803132	FLORIDA CITY	Hybrid	752	11	17	6	5.3	5.7	2.9	4.8	8.2	10.5	18.7	1,310	50,881	Yes	1.26	6.16	17
301138	COLUMBIA	Hybrid	492	14	15	3	8.1	0.8	4.8	8.6	12.9	9.4	22.3	548	34,790	Yes	-0.02	2.08	9
804539	GRATIGNY	Hybrid	843	4	16	1	1.9	0.1	1.9	2.8	3.8	2.9	6.7	343	60,370	Yes	0.17	4.77	19
704662	SPRINGTREE	Hybrid	1,467	2	18	0	1.4	-	0.5	5.6	1.9	5.6	7.5	365	56,023	Yes	-0.21	3.89	11
401837	JUPITER	Hybrid	889	10	19	2	2.3	0.8	2.4	3.4	4.7	4.2	8.9	32	6,773	Yes	-0.09	3.91	5
502207	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-3.74	3.96	0
709264	PROGRESSO	UG	711	0	5	0	-	9.2	-	0.3	-	9.5	9.5	-	-	Yes	-1.73	5.27	0
810565	JASMINE	UG	3,394	0	33	0	1.0	6.7	-	22.0	1.0	28.7	29.7	238	25,233	Yes	-0.69	14.81	9
503864	ORTIZ	Hybrid	1,184	44	29	8	9.2	0.2	15.1	5.7	24.3	5.9	30.2	295	54,976	Yes	0.30	7.10	29
805835	CORAL REEF	Hybrid	1,665	23	9	2	3.1	0.5	9.1	4.8	12.2	5.3	17.5	5,134	214,030	Yes	-0.22	8.08	54
405932	BUTTS	Hybrid	1,330	0	30	0	2.8	1.0	-	14.1	2.8	15.1	17.9	214	38,027	Yes	0.01	6.61	23
507261	SAN CARLOS	Hybrid	3,651	13	53	4	7.6	3.7	11.0	22.2	18.6	25.9	44.5	523	47,658	Yes	0.05	12.55	26
200832	LAUREL	OH	1,373	29	4	3	3.8	0.1	9.4	0.5	13.2	0.6	13.8	826	69,301	Yes	0.46	6.16	35
811932	OVERTOWN	UG	1,573	0	8	0	-	2.2	-	1.4	-	3.6	3.6	1	302	Yes	-0.08	5.52	1
100136	DAYTONA BEACH	Hybrid	257	6	9	4	1.3	0.4	1.1	1.4	2.4	1.8	4.2	10	1,168	Yes	-0.26	3.34	3
413231	WHEELER	Hybrid	129	2	7	1	5.7	0.4	0.9	0.3	6.6	0.7	7.3	-	-	Yes	0.03	2.03	0
707466	SAWGRASS	UG	264	0	4	0	0.2	5.2	-	0.1	0.2	5.3	5.5	-	-	Yes	-0.06	1.84	0
401637	OKEECHOBEE	Hybrid	2,014	26	31	9	5.3	0.3	9.4	10.5	14.7	10.8	25.5	487	20,497	Yes	-0.18	8.42	18
708432	BUTTERFLY	Hybrid	1,379	1	21	1	2.3	2.0	0.5	9.2	2.8	11.2	14.0	160	31,960	Yes	-0.06	5.74	8
702235	MARGATE	Hybrid	1,091	7	18	6	2.8	1.0	2.9	3.4	5.7	4.4	10.1	311	63,879	Yes	-0.57	6.23	17
814032	BRICKELL	Hybrid	1,375	4	6	2	0.1	3.1	0.5	0.8	0.6	3.9	4.5	3,620	340,658	Yes	0.07	3.77	11
202134	INDIAN RIVER	Hybrid	1,569	30	16	1	4.5	0.1	9.1	2.1	13.6	2.2	15.8	5,558	193,758	Yes	-0.03	7.87	41
800239	MIAMI BEACH	UG	196	0	10	0	-	3.5	-	0.5	-	4.0	4.0	90	5,712	Yes	-0.95	2.35	5
801432	FULFORD	Hybrid	127	3	9	3	1.6	0.3	0.5	0.6	2.1	0.9	3.0	1	140	Yes	1.91	5.61	1
806936	BIRD	Hybrid	983	14	5	3	1.6	1.9	5.4	2.0	7.0	3.9	10.9	603	138,707	Yes	0.10	4.70	40
413731	RUNWAY	Hybrid	1,546	17	43	5	4.1	2.2	5.9	12.6	10.0	14.8	24.8	1,637	19,434	Yes	0.03	6.53	22
801139	FRONTON	Hybrid	650	9	12	0	3.4	0.5	0.9	0.4	4.3	0.9	5.2	376	19,871	Yes	0.38	5.28	13
701734	STIRLING	Hybrid	1,393	0	24	1	1.8	0.1	0.2	10.5	2.0	10.6	12.6	820	59,539	Yes	0.00	7.10	15
701532	DANIA	Hybrid	1,950	12	29	11	4.3	0.9	3.7	7.0	8.0	7.9	15.9	2,022	69,033	Yes	0.28	8.58	15
407666	LOXAHATCHEE	OH	1,289	116	9	6	14.0	1.1	61.8	2.5	75.8	3.6	79.4	1,305	181,488	Yes	0.01	7.51	130
104433	NOVA	Hybrid	1,797	4	29	4	2.7	1.5	1.3	9.5	4.0	11.0	15.0	185	31,069	Yes	-0.65	5.45	10
500761	ENGLEWOOD	Hybrid	1,717	32	17	7	4.9	0.1	15.3	3.1	20.2	3.2	23.4	1,815	138,627	Yes	0.17	5.57	22
800444	COCONUT GROVE	Hybrid	899	4	20	1	1.5	3.2	0.4	3.9	1.9	7.1	9.0	1,367	134,675	Yes	-0.88	7.22	10
502163	BONITA SPRINGS	Hybrid	3,371	6	54	6	6.9	4.6	2.9	15.1	9.8	19.7	29.5	3,571	59,061	Yes	-0.38	6.82	17
404038	WESTWARD	Hybrid	2,152	10	59	0	3.1	0.6	3.5	9.1	6.6	9.7	16.3	4,679	103,963	Yes	-0.03	7.57	37
702538	DAVIE	UG	1	0	0	0	-	2.4	-	-	-	2.4	2.4	-	-	Yes	-0.07	4.43	0
501766	IONA	Hybrid	4,004	9	47	7	4.3	1.6	8.8	23.4	13.1	25.0	38.1	9,427	333,738	Yes	-0.20	10.50	69
208863	WINDOVER	Hybrid	1,371	36	13	8	3.4	1.2	6.7	6.6	10.1	7.8	17.9	1,558	106,818	Yes	-4.00	4.90	20
700835	BEVERLY	Hybrid	1,473	14	13	0	2.0	0.1	5.1	2.1	7.1	2.2	9.3	232	32,747	Yes	-0.15	5.25	16
803533	MARKET	UG	536	0	5	0	-	2.3	-	0.1	-	2.4	2.4	1	490	Yes	-0.14	4.66	1
700936	HALLANDALE	Hybrid	2,256	10	14	6	2.4	0.3	4.1	2.9	6.5	3.2	9.7	407	65,313	Yes	-0.18	5.02	26
801631	PRINCETON	Hybrid	2,095	2	30	2	1.7	2.8	0.6	24.0	2.3	26.8	29.1	963	14,828	Yes	-0.14	7.96	4
403032	MILITARY TRAIL	Hybrid	1,633	32	10	1	3.4	-	10.1	2.1	13.5	2.1	15.6	2,028	195,850	Yes	-0.15	6.45	52
407731	SQUARE LAKE	Hybrid	2,655	0	48	1	2.6	3.8	0.6	23.4	3.2	27.2	30.4	402	35,173	Yes	-0.01	10.49	14
802134	MIRAMAR	Hybrid	2,082	12	22	7	2.3	1.2	2.0	1.4	4.3	2.6	6.9	2,407	115,799	Yes	0.49	7.69	23
507863	IXORA	Hybrid	1,715	61	14	12	18.1	2.0	68.3	7.0	86.4	9.0	95.4	1,778	85,455	Yes	0.04	4.94	47
502065	MURDOCK	Hybrid	3,779	39	29	6	5.7	0.2	52.3	7.3	58.0	7.5	65.5	5,669	133,938	Yes	0.04	12.84	81
406335	ROEBUCK	Hybrid	882	0	21	0	2.0	0.9	-	8.9	2.0	9.8	11.8	36	6,361	Yes	-6.57	3.73	4
502635	COLONIAL	Hybrid	1,450	16	20	10	2.1	0.6	7.6	7.0	9.7	7.6	17.3	1,121	63,615	Yes	-0.39	7.61	36
703232	WOODLANDS	Hybrid	1,631	18	14	1	3.7	1.1	4.2	3.5	7.9	4.6	12.5	286	43,483	Yes	-1.12	6.18	27
700432	OAKLAND PARK	Hybrid	789	11	7	1	1.9	0.5	2.0	0.6	3.9	1.1	5.0	46	13,440	Yes	-0.23	4.27	9

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
101464	FLAGLER BEACH	Hybrid	3,776	110	27	12	26.3	5.0	93.0	22.2	119.3	27.2	146.5	2,133	104,152	Yes	-0.35	12.45	52
811438	WATKINS	Hybrid	38	0	8	0	1.7	2.3	0.1	0.9	1.8	3.2	5.0	1	415	Yes	0.03	2.73	1
807038	ROSELAWN	UG	1,364	0	14	1	0.4	1.5	-	7.5	0.4	9.0	9.4	316	17,803	Yes	4.75	9.85	9
204634	COLLEGE	Hybrid	51	3	12	0	2.6	1.1	0.4	1.6	3.0	2.7	5.7	4	543	Yes	0.37	4.87	4
802031	CUTLER	Hybrid	781	15	22	2	1.9	1.8	4.4	3.9	6.3	5.7	12.0	977	107,982	Yes	-0.17	4.23	29
102831	LEWIS	Hybrid	845	20	9	3	2.6	0.1	7.8	3.5	10.4	3.6	14.0	2,366	49,700	Yes	0.20	4.20	29
702035	DRIFTWOOD	Hybrid	2,347	11	35	8	2.8	1.0	2.4	9.4	5.2	10.4	15.6	2,216	75,365	Yes	0.03	9.63	27
509861	ANGLER	Hybrid	1,921	1	65	2	5.1	5.1	0.7	22.5	5.8	27.6	33.4	267	48,263	Yes	1.09	12.89	16
804339	KENDALL	Hybrid	1	0	0	0	0.2	1.7	-	-	0.2	1.7	1.9	-	-	Yes	2.25	5.35	0
503637	EDISON	Hybrid	1,049	3	26	2	2.2	0.6	1.9	6.2	4.1	6.8	10.9	284	52,087	Yes	0.00	4.90	6
702939	HAWKINS	Hybrid	2,249	1	20	1	1.7	0.3	0.5	10.0	2.2	10.3	12.5	468	69,576	Yes	-0.61	5.59	13
203935	MCDONNELL	Hybrid	2,510	9	33	4	3.9	0.1	6.9	16.8	10.8	16.9	27.7	568	85,193	Yes	-0.35	8.85	36
100334	HASTINGS	OH	1,317	109	8	7	18.7	0.1	78.0	1.0	94.7	1.1	95.8	1,214	53,659	Yes	-0.26	5.14	52
405468	CLINTMOORE	UG	1,389	0	24	1	0.1	5.2	0.1	18.1	0.2	23.3	23.5	1,286	13,149	Yes	0.06	9.36	4
708161	HUNTINGTON	Hybrid	1,689	0	28	0	2.0	0.9	-	8.6	2.0	9.5	11.5	65	8,475	Yes	0.72	9.82	6
705635	COPANS	Hybrid	868	5	17	1	2.5	1.3	1.9	6.5	4.4	7.8	12.2	708	33,277	Yes	0.08	5.28	23
500661	CORTEZ	Hybrid	4,128	50	44	16	6.6	5.3	11.2	7.3	17.8	12.6	30.4	671	68,083	Yes	-0.20	12.70	54
400740	BOCA RATON	Hybrid	900	10	15	5	1.3	1.8	3.5	2.9	4.8	4.7	9.5	184	26,172	Yes	0.13	6.43	17
506766	VANDERBILT	Hybrid	2,784	1	19	0	2.7	1.0	0.7	13.2	3.4	14.2	17.6	712	105,386	Yes	-1.11	15.49	26
800934	40TH ST	UG	151	0	3	0	-	2.4	-	0.3	-	2.7	2.7	-	-	Yes	-0.05	4.25	0
808262	LINDGREN	UG	1,963	0	20	0	-	4.3	-	16.8	-	21.1	21.1	306	82,852	Yes	0.02	9.12	24
100532	MCMEEKIN	Hybrid	198	5	0	3	1.4	2.2	7.6	0.3	9.0	2.5	11.5	51	9,617	Yes	-0.07	0.43	14
801732	62ND AVE	Hybrid	1,309	18	6	0	2.1	0.6	2.7	0.4	4.8	1.0	5.8	186	34,586	Yes	1.13	4.53	31
102637	LEWIS	Hybrid	1,801	28	21	6	4.7	2.5	10.7	6.8	15.4	9.3	24.7	861	86,016	Yes	-0.43	9.17	46
709262	PROGRESSO	Hybrid	2,218	17	16	6	2.8	0.7	6.0	2.4	8.8	3.1	11.9	867	140,577	Yes	0.02	6.72	49
506363	DEEPCREEK	Hybrid	3,505	20	16	8	4.5	0.1	21.3	11.3	25.8	11.4	37.2	318	34,756	Yes	0.11	10.21	38
808433	SNAKE CREEK	Hybrid	1,782	15	18	3	4.3	1.6	5.9	11.6	10.2	13.2	23.4	1,596	151,354	Yes	0.62	7.92	71
805940	COUNTRY CLUB	UG	718	0	9	0	-	1.6	-	3.6	-	5.2	5.2	12	696	Yes	0.00	0.00	1
504967	GOLDEN GATE	Hybrid	1,701	90	15	7	16.4	1.3	44.9	8.7	61.3	10.0	71.3	675	101,770	Yes	0.00	8.70	98
800940	40TH ST	UG	2	0	2	0	-	3.4	-	0.2	-	3.6	3.6	-	-	Yes	-0.01	5.19	0
509131	TIMUCUAN	Hybrid	2,325	6	35	2	2.4	0.2	4.0	3.1	6.4	3.3	9.7	640	87,797	Yes	5.68	5.68	29
403631	SOUTH BAY	Hybrid	32	11	8	0	16.9	-	1.2	1.5	18.1	1.5	19.6	2,229	253,189	Yes	0.02	2.42	10
707263	FLAMINGO	Hybrid	3,266	14	61	1	4.8	5.3	2.6	29.4	7.4	34.7	42.1	2,269	161,270	Yes	-0.06	16.54	26
413835	CHAMBERS	Hybrid	611	0	25	0	1.5	1.9	-	11.8	1.5	13.7	15.2	34	10,286	Yes	0.07	3.57	3
405038	SANDALFOOT	Hybrid	901	2	22	0	0.8	3.4	0.1	13.7	0.9	17.1	18.0	156	16,319	Yes	-0.36	5.74	10
808169	MILAM	Hybrid	559	2	40	2	3.2	1.9	0.6	7.0	3.8	8.9	12.7	98	12,759	Yes	0.19	15.19	13
510561	BERMONT	OH	220	56	3	7	25.7	0.2	43.6	2.1	69.3	2.3	71.6	357	51,405	Yes	-0.06	1.14	36
809669	COURT	Hybrid	1,849	3	37	1	1.2	3.1	0.9	11.8	2.1	14.9	17.0	743	32,624	Yes	-0.24	8.36	8
701432	PORT	Hybrid	230	1	9	5	2.1	1.7	1.7	1.9	3.8	3.6	7.4	2,542	149,715	Yes	-0.41	3.69	16
102531	MATANZAS	Hybrid	586	37	30	5	12.9	-	19.4	12.1	32.3	12.1	44.4	871	38,924	Yes	-2.89	3.31	19
805538	MASTER	OH	1,675	26	0	6	5.1	0.1	6.6	0.2	11.7	0.3	12.0	1,660	171,871	Yes	-0.24	8.36	73
209931	LIGHTHOUSE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.18	0.02	0
701635	PLANTATION	OH	2,169	28	2	3	4.7	0.6	12.8	0.2	17.5	0.8	18.3	3,398	252,603	Yes	-0.42	8.78	89
706464	HOLMBERG	Hybrid	1,491	1	29	4	2.1	2.4	1.0	13.0	3.1	15.4	18.5	87	15,845	Yes	-1.32	9.58	5
808268	LINDGREN	UG	3,062	0	31	0	1.0	4.2	-	27.1	1.0	31.3	32.3	2,795	92,039	Yes	-0.82	12.88	28
701140	LYONS	Hybrid	2,338	10	25	1	2.8	0.8	3.0	9.4	5.8	10.2	16.0	264	45,486	Yes	-0.96	7.44	26
704566	MALLARD	Hybrid	2,169	0	28	1	1.8	1.1	0.1	14.9	1.9	16.0	17.9	611	87,461	Yes	-0.44	7.96	24
503634	EDISON	Hybrid	1,827	3	49	2	2.9	0.3	1.8	10.4	4.7	10.7	15.4	374	40,263	Yes	-0.47	4.73	18
700135	SISTRUNK	Hybrid	2,940	9	19	2	2.2	0.9	1.8	1.6	4.0	2.5	6.5	372	56,550	Yes	-0.25	7.55	23
800942	40TH ST	UG	1	0	0	0	-	1.7	-	-	-	1.7	1.7	-	-	Yes	2.95	3.35	0
804037	LE JEUNE	UG	7	0	4	0	-	4.8	-	0.1	-	4.9	4.9	-	-	Yes	-0.35	2.75	0
500933	OSPREY	Hybrid	1,155	0	26	2	2.6	0.1	0.9	13.9	3.5	14.0	17.5	283	38,626	Yes	0.06	6.36	13

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
500662	CORTEZ	Hybrid	4,591	33	48	6	6.2	3.0	9.5	19.3	15.7	22.3	38.0	1,919	146,227	Yes	-0.34	12.96	54
210531	APOLLO	Hybrid	1,305	10	15	6	2.6	1.5	9.1	2.0	11.7	3.5	15.2	373	41,448	Yes	-0.55	9.35	20
207066	COX	Hybrid	1,240	23	14	6	4.2	0.7	9.6	5.7	13.8	6.4	20.2	-	-	Yes	0.00	0.00	0
800939	40TH ST	UG	20	0	5	0	0.1	3.6	-	0.4	0.1	4.0	4.1	35	1,674	Yes	0.41	3.11	2
808438	SNAKE CREEK	UG	6	0	0	0	-	4.0	-	-	-	4.0	4.0	-	-	Yes	0.79	3.99	0
804237	PERRINE	Hybrid	1,390	15	22	4	2.7	1.7	5.5	5.5	8.2	7.2	15.4	318	74,816	Yes	-0.02	8.08	47
505462	WINKLER	Hybrid	1,708	11	38	7	3.7	0.9	2.2	4.9	5.9	5.8	11.7	140	29,714	Yes	-0.15	6.65	15
204261	BABCOCK	Hybrid	2,619	114	12	1	11.5	0.1	46.9	3.4	58.4	3.5	61.9	6,547	215,766	Yes	-0.06	9.84	116
706262	VALENCIA	Hybrid	3,214	16	49	12	6.0	0.2	11.8	26.7	17.8	26.9	44.7	9,704	287,521	Yes	-0.60	16.10	60
807338	GOULDS	Hybrid	1,525	3	34	0	2.1	1.4	0.2	11.6	2.3	13.0	15.3	1,969	42,120	Yes	0.48	6.48	10
804031	LE JEUNE	UG	22	0	5	0	-	5.1	-	0.8	-	5.9	5.9	-	-	Yes	-0.25	2.75	0
804437	VENETIAN	Hybrid	1,305	9	21	1	2.6	2.4	1.7	4.4	4.3	6.8	11.1	1,221	54,754	Yes	-0.40	3.30	24
704933	LAKEVIEW	UG	3,689	0	18	0	0.5	2.5	-	14.8	0.5	17.3	17.8	8,776	159,765	Yes	-0.33	3.67	6
504369	PINE RIDGE	Hybrid	1,394	28	26	5	4.1	2.8	5.8	10.5	9.9	13.3	23.2	2,252	108,440	Yes	0.40	9.60	35
101139	ORMOND	Hybrid	2,187	19	15	5	3.4	4.6	10.5	4.2	13.9	8.8	22.7	1,424	110,069	Yes	6.76	6.76	29
501062	FRUITVILLE	Hybrid	2,835	16	45	10	5.0	0.2	10.2	18.4	15.2	18.6	33.8	1,916	77,957	Yes	-0.88	12.22	47
101532	GENERAL ELECTRIC	UG	2	0	1	0	-	1.8	-	-	-	1.8	1.8	-	-	Yes	0.43	0.53	0
806433	HAINLIN	Hybrid	906	75	12	3	9.4	0.3	24.5	2.2	33.9	2.5	36.4	2,504	88,187	Yes	0.38	5.88	66
703036	ROHAN	Hybrid	1,850	28	10	2	4.3	0.7	8.3	1.5	12.6	2.2	14.8	585	68,252	Yes	-0.22	5.88	51
801233	OPA LOCKA	Hybrid	2,155	17	19	4	3.6	0.5	10.1	1.3	13.7	1.8	15.5	772	104,154	Yes	0.33	8.33	54
703738	CRYSTAL	Hybrid	282	5	14	3	2.9	0.2	0.9	1.4	3.8	1.6	5.4	22	3,470	Yes	-0.57	4.63	6
503963	ESTERO	Hybrid	1,624	2	27	2	3.8	1.3	3.6	15.5	7.4	16.8	24.2	75	10,703	Yes	-0.32	6.08	15
109034	WRIGHT	Hybrid	1,878	0	42	0	3.9	1.0	0.9	17.5	4.8	18.5	23.3	1,952	61,782	Yes	-1.96	7.34	8
200135	SANFORD	Hybrid	63	4	19	0	2.6	1.0	0.6	1.3	3.2	2.3	5.5	72	3,299	Yes	0.17	7.77	6
804436	VENETIAN	UG	725	0	4	0	-	2.3	-	0.4	-	2.7	2.7	-	-	Yes	-1.11	3.69	0
408035	CALDWELL	Hybrid	1,600	12	24	3	4.0	1.0	2.6	3.0	6.6	4.0	10.6	1,498	35,474	Yes	0.28	6.48	20
401034	GREENACRES	Hybrid	1,044	10	25	3	3.3	0.1	2.1	6.6	5.4	6.7	12.1	19	1,799	Yes	0.11	4.21	8
510161	HERCULES	Hybrid	663	0	24	0	4.6	7.8	0.1	14.8	4.7	22.6	27.3	5	487	Yes	1.34	2.84	3
509065	SUMMIT	Hybrid	-	34	29	9	3.7	5.5	16.0	16.5	19.7	22.0	41.7	-	-	Yes	0.00	0.00	0
202135	INDIAN RIVER	Hybrid	1,836	18	29	7	3.8	1.0	8.4	5.7	12.2	6.7	18.9	3,074	106,901	Yes	6.44	6.64	41
800539	RIVERSIDE	Hybrid	1,295	3	26	5	2.3	0.1	1.9	2.8	4.2	2.9	7.1	2,535	155,278	Yes	-0.05	7.25	16
201135	PATRICK	Hybrid	1,175	11	19	5	2.3	2.7	4.9	1.6	7.2	4.3	11.5	666	21,428	Yes	-0.18	5.62	19
800632	LITTLE RIVER	OH	2,861	45	7	4	5.2	-	8.1	0.3	13.3	0.3	13.6	3,020	256,486	Yes	0.18	10.78	64
407733	SQUARE LAKE	UG	743	0	14	0	-	2.4	-	10.1	-	12.5	12.5	1	74	Yes	-0.49	4.71	1
804838	COUNTY LINE	Hybrid	1,189	1	16	0	0.2	1.8	0.3	5.8	0.5	7.6	8.1	3	1,144	Yes	0.30	3.30	2
408162	ROSS	Hybrid	1,445	0	27	0	1.6	2.5	-	8.5	1.6	11.0	12.6	329	27,010	Yes	-0.17	4.63	6
407737	SQUARE LAKE	Hybrid	915	1	21	5	2.4	5.4	1.3	6.2	3.7	11.6	15.3	168	23,810	Yes	0.69	8.79	21
403233	ATLANTIC	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.21	8.59	0
403436	JENSEN	Hybrid	1,486	5	21	9	4.2	3.1	8.9	8.6	13.1	11.7	24.8	272	52,176	Yes	-0.06	7.84	27
102534	MATANZAS	Hybrid	98	1	12	0	3.9	1.1	0.2	1.9	4.1	3.0	7.1	1	125	Yes	-0.05	5.65	1
809938	SIMPSON	UG	879	0	5	0	-	2.0	-	0.6	-	2.6	2.6	-	-	Yes	2.35	6.85	0
102635	LEWIS	Hybrid	1,797	26	22	2	4.5	1.5	10.6	18.5	15.1	20.0	35.1	1,522	81,646	Yes	-0.48	6.32	23
700638	VERENA	UG	15	0	8	0	-	3.2	-	0.2	-	3.4	3.4	-	-	Yes	0.04	4.94	0
812361	URBAN	UG	3,106	0	40	0	0.6	5.7	-	20.3	0.6	26.0	26.6	3,611	288,947	Yes	0.34	13.14	12
707736	GOOLSBY	Hybrid	368	0	20	0	1.0	1.2	0.1	4.1	1.1	5.3	6.4	26	5,427	Yes	0.09	5.49	5
405269	ACME	Hybrid	2,645	4	58	6	5.6	1.7	4.0	20.5	9.6	22.2	31.8	267	29,910	Yes	0.66	13.26	22
805537	MASTER	Hybrid	377	2	21	0	3.4	0.3	0.2	1.5	3.6	1.8	5.4	445	58,173	Yes	0.58	6.18	5
809342	RONEY	UG	682	1	9	4	-	5.1	0.2	2.3	0.2	7.4	7.6	432	31,239	Yes	-1.40	5.60	6
405940	BUTTS	Hybrid	1,885	5	34	2	2.8	2.8	0.7	13.6	3.5	16.4	19.9	398	28,465	Yes	-0.29	7.51	11
410362	MARLIN	Hybrid	3,124	18	70	1	3.5	9.2	7.3	41.5	10.8	50.7	61.5	1,596	57,411	Yes	0.22	17.42	31
209233	MARS	UG	6	0	5	0	-	4.8	-	0.7	-	5.5	5.5	-	-	Yes	0.09	0.89	0
702637	ELY	Hybrid	1,903	22	12	9	3.6	0.5	6.5	1.1	10.1	1.6	11.7	2,481	70,636	Yes	-1.34	6.36	48

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
803802	137TH AVE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	9.36	9.36	0
503566	ALLIGATOR	Hybrid	3,597	3	42	4	3.6	0.1	4.0	21.9	7.6	22.0	29.6	3,677	223,960	Yes	3.43	11.13	26
802434	SOUTH MIAMI	Hybrid	905	14	16	1	2.3	0.8	5.0	0.6	7.3	1.4	8.7	874	185,000	Yes	-0.77	4.63	44
705463	PHOENIX	UG	2,367	0	21	0	0.1	4.8	-	19.5	0.1	24.3	24.4	2,459	67,245	Yes	-0.27	9.73	22
807034	ROSELAWN	Hybrid	903	0	28	0	0.6	3.4	-	3.6	0.6	7.0	7.6	110	4,554	Yes	-0.63	5.97	3
813534	JACKSON	Hybrid	2,030	28	11	2	3.6	1.4	7.4	2.0	11.0	3.4	14.4	260	21,398	Yes	0.00	0.00	17
501763	IONA	Hybrid	2,589	30	16	13	4.0	0.7	9.8	2.7	13.8	3.4	17.2	4,374	134,174	Yes	0.62	8.62	62
709033	SPANGLER	Hybrid	1,226	21	18	5	3.1	1.6	4.5	4.9	7.6	6.5	14.1	225	43,793	Yes	6.45	6.45	33
504964	GOLDEN GATE	Hybrid	1,547	34	6	3	4.4	0.2	17.2	6.2	21.6	6.4	28.0	3,384	207,563	Yes	0.18	9.68	70
814431	BANYAN	Hybrid	1,713	13	7	3	1.9	0.2	6.1	0.4	8.0	0.6	8.6	1,560	89,070	Yes	-0.18	6.92	40
700837	BEVERLY	Hybrid	1,730	22	3	2	2.5	1.7	7.5	0.2	10.0	1.9	11.9	433	51,416	Yes	0.08	6.78	55
803034	TROPICAL	Hybrid	1,409	13	17	3	1.7	1.8	5.9	4.3	7.6	6.1	13.7	175	44,116	Yes	-0.48	6.98	28
806832	RED ROAD	Hybrid	1,639	13	12	2	1.5	0.1	4.0	2.1	5.5	2.2	7.7	2,210	177,750	Yes	-3.80	5.20	35
707035	SHERIDAN	Hybrid	665	4	23	0	2.0	1.2	1.6	6.4	3.6	7.6	11.2	727	73,148	Yes	0.02	5.12	10
808437	SNAKE CREEK	Hybrid	2,365	15	27	4	2.6	2.2	8.7	17.1	11.3	19.3	30.6	728	110,685	Yes	0.13	10.13	67
505963	CARLSTROM	OH	364	35	5	5	8.7	0.1	42.5	1.3	51.2	1.4	52.6	495	93,380	Yes	-0.07	1.23	45
807934	MIAMI LAKES	UG	451	0	16	0	-	2.9	-	7.6	-	10.5	10.5	4	1,409	Yes	-0.40	5.50	2
807534	DADELAND	UG	742	0	5	0	-	2.7	-	1.3	-	4.0	4.0	-	-	Yes	-0.14	3.96	0
507461	CORKSCREW	Hybrid	5,920	9	96	4	13.3	19.8	18.7	87.8	32.0	107.6	139.6	9,476	385,255	Yes	0.12	18.42	53
406061	SHERMAN	Hybrid	1,435	64	13	2	20.4	1.8	43.3	4.4	63.7	6.2	69.9	3,289	184,872	Yes	-0.67	6.83	76
800634	LITTLE RIVER	Hybrid	1,751	22	7	3	2.6	0.7	4.5	0.8	7.1	1.5	8.6	523	77,056	Yes	-0.29	6.11	41
411563	FELLSMERE	Hybrid	2,019	73	3	7	7.2	5.0	56.9	1.8	64.1	6.8	70.9	319	63,987	Yes	-0.28	7.72	54
702237	MARGATE	Hybrid	2,210	0	34	1	2.6	0.9	0.1	13.6	2.7	14.5	17.2	316	31,745	Yes	-0.95	7.25	16
410761	ROSEDALE	Hybrid	1,537	23	25	6	6.2	2.4	13.1	13.8	19.3	16.2	35.5	2,285	264,206	Yes	-0.06	6.04	52
707262	FLAMINGO	Hybrid	2,345	0	27	0	1.8	4.1	-	20.0	1.8	24.1	25.9	366	57,728	Yes	-0.88	11.42	35
411561	FELLSMERE	Hybrid	2,287	87	31	12	15.6	0.4	86.2	12.1	101.8	12.5	114.3	1,767	208,159	Yes	3.02	13.52	109
402934	OSLO	Hybrid	1,265	20	30	7	4.3	0.3	8.2	12.3	12.5	12.6	25.1	189	50,249	Yes	-0.17	6.63	27
401938	LINTON	Hybrid	828	19	12	5	3.0	0.3	5.9	4.3	8.9	4.6	13.5	230	47,399	Yes	0.01	4.51	32
201833	MINUTEMAN	Hybrid	2,038	17	29	7	4.2	0.1	2.4	2.9	6.6	3.0	9.6	956	83,008	Yes	-0.23	5.07	39
800146	MIAMI	UG	-	0	1	0	-	1.4	-	-	-	1.4	1.4	-	-	Yes	-0.36	5.14	0
404241	BOCA TEECA	Hybrid	1,183	2	29	2	1.9	2.1	0.5	6.0	2.4	8.1	10.5	944	15,272	Yes	0.12	5.62	6
501063	FRUITVILLE	Hybrid	2,756	25	62	12	5.7	0.3	9.8	23.6	15.5	23.9	39.4	778	46,452	Yes	-0.26	12.84	43
407335	HILLS	Hybrid	1,486	16	36	6	4.7	3.3	7.3	23.2	12.0	26.5	38.5	154	21,522	Yes	-0.18	8.22	30
510763	OVERBROOK	Hybrid	3,107	4	47	0	6.3	4.8	1.5	42.4	7.8	47.2	55.0	75	12,737	Yes	0.57	7.97	8
405035	SANDALFOOT	Hybrid	2,342	3	29	0	3.5	0.7	1.6	11.5	5.1	12.2	17.3	3,290	78,768	Yes	-0.10	7.70	14
406537	OSBORNE	Hybrid	230	0	15	1	0.6	2.0	0.1	1.6	0.7	3.6	4.3	-	-	Yes	-0.02	5.28	0
806337	ULETA	Hybrid	1,222	20	16	2	3.0	1.1	4.4	0.9	7.4	2.0	9.4	257	41,564	Yes	-0.80	6.60	37
401031	GREENACRES	Hybrid	1,945	37	19	7	4.5	-	12.3	5.9	16.8	5.9	22.7	1,521	134,254	Yes	0.28	8.08	61
803134	FLORIDA CITY	Hybrid	1,443	2	30	2	5.9	3.6	2.5	15.5	8.4	19.1	27.5	6,116	203,651	Yes	-0.40	6.90	38
809764	SWEETWATER	Hybrid	751	2	59	0	7.2	9.5	0.2	8.9	7.4	18.4	25.8	3,061	47,390	Yes	-2.87	13.63	16
805740	GALLOWAY	Hybrid	1,051	27	14	7	4.6	0.6	9.0	3.3	13.6	3.9	17.5	990	74,212	Yes	-0.16	5.84	40
400239	DATURA ST	Hybrid	89	0	10	1	0.2	1.2	-	1.3	0.2	2.5	2.7	-	-	Yes	0.55	3.35	0
510662	KELLY	Hybrid	4,047	20	79	8	5.1	6.5	11.7	36.0	16.8	42.5	59.3	3,479	264,733	Yes	0.72	15.82	72
808833	SNAPPER CREEK	Hybrid	620	48	24	7	4.3	0.3	10.5	8.5	14.8	8.8	23.6	855	93,839	Yes	0.07	7.27	71
403431	JENSEN	Hybrid	530	0	18	1	2.1	0.2	0.2	3.6	2.3	3.8	6.1	194	21,980	Yes	-0.24	4.46	8
802231	GLADEVIEW	Hybrid	1,484	29	5	4	3.2	0.2	4.7	0.6	7.9	0.8	8.7	311	63,787	Yes	-0.01	5.09	36
806236	INDIAN CREEK	UG	1,738	0	9	1	-	2.1	-	1.4	-	3.5	3.5	-	-	Yes	-0.84	5.66	0
409532	LAKE IDA	Hybrid	1,970	2	31	2	3.0	0.2	1.5	19.9	4.5	20.1	24.6	489	42,881	Yes	0.05	6.65	23
204636	COLLEGE	Hybrid	1,875	13	29	3	3.4	1.2	6.4	7.0	9.8	8.2	18.0	1,439	102,371	Yes	-0.28	7.32	31
703736	CRYSTAL	UG	1	0	0	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	-0.93	1.77	0
404433	PURDY LANE	Hybrid	2,313	16	27	6	3.6	0.8	7.2	3.8	10.8	4.6	15.4	3,987	116,744	Yes	-0.03	7.57	47
100931	SOUTH DAYTONA	Hybrid	2,178	27	20	8	3.8	0.3	8.9	5.8	12.7	6.1	18.8	1,426	183,849	Yes	-0.04	7.66	58

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
200535	MELBOURNE	Hybrid	54	1	13	2	1.0	0.7	0.5	1.0	1.5	1.7	3.2	9	216	Yes	-1.32	4.98	1
201634	PALM BAY	Hybrid	-	0	0	0	0.1	0.4	-	-	0.1	0.4	0.5	-	-	Yes	0.11	4.21	0
800532	RIVERSIDE	Hybrid	2,010	0	14	1	0.4	1.0	0.2	3.3	0.6	4.3	4.9	2	202	Yes	-0.21	3.69	2
307765	ONEIL	Hybrid	2,476	41	57	8	9.9	1.8	16.2	25.8	26.1	27.6	53.7	7	1,127	Yes	0.00	0.00	5
500536	CLARK	Hybrid	663	8	36	8	2.8	0.8	3.7	4.5	6.5	5.3	11.8	1,420	91,669	Yes	0.06	6.86	8
409531	LAKE IDA	Hybrid	1,622	12	24	5	3.5	-	1.5	8.7	5.0	8.7	13.7	156	14,923	Yes	0.26	6.66	12
402839	LANTANA	Hybrid	2,863	31	16	7	3.8	0.9	8.8	2.7	12.6	3.6	16.2	1,303	94,024	Yes	-0.34	8.16	45
506663	LIVINGSTON	Hybrid	4,022	5	71	2	4.6	3.7	1.0	34.6	5.6	38.3	43.9	4,373	145,162	Yes	-1.00	16.50	20
704668	SPRINGTREE	Hybrid	2,046	0	45	4	3.9	0.5	0.9	11.3	4.8	11.8	16.6	818	46,748	Yes	-1.36	8.74	24
408964	PLUMOSUS	Hybrid	2,276	0	40	0	1.6	5.7	-	19.3	1.6	25.0	26.6	2,881	44,575	Yes	0.18	8.58	12
203540	HIBISCUS	Hybrid	54	4	15	3	1.8	3.5	0.9	2.5	2.7	6.0	8.7	5	1,373	Yes	-6.63	4.27	4
208631	TULSA	Hybrid	1,614	31	6	0	4.6	0.3	12.5	2.8	17.1	3.1	20.2	271	24,311	Yes	-0.14	6.06	23
505664	ROTONDA	Hybrid	3,727	19	88	18	12.3	3.7	13.8	31.9	26.1	35.6	61.7	6,214	551,860	Yes	-0.61	12.59	95
401231	BRIGHTON	Hybrid	586	25	1	2	16.6	0.8	29.3	1.9	45.9	2.7	48.6	239	29,653	Yes	0.14	1.74	22
406532	OSBORNE	Hybrid	1,089	13	17	0	2.7	0.5	3.6	7.0	6.3	7.5	13.8	78	8,073	Yes	-0.21	4.29	11
701237	PLAYLAND	Hybrid	854	0	24	1	1.1	1.5	0.4	9.7	1.5	11.2	12.7	65	3,587	Yes	5.83	5.83	6
405031	SANDALFOOT	Hybrid	1,797	0	39	0	2.4	0.5	-	10.3	2.4	10.8	13.2	167	22,980	Yes	-0.07	6.53	12
103732	PACIFIC	Hybrid	609	32	1	4	6.0	0.4	11.7	0.8	17.7	1.2	18.9	56	7,536	Yes	-0.13	2.87	11
201432	GRANDVIEW	Hybrid	1,659	27	11	8	4.4	-	11.3	1.6	15.7	1.6	17.3	5,821	164,242	Yes	0.10	7.70	58
806136	DOUGLAS	Hybrid	997	2	15	1	1.0	1.3	0.6	0.9	1.6	2.2	3.8	2,503	102,035	Yes	0.73	7.73	15
502561	PALMA SOLA	Hybrid	2,976	46	31	13	7.4	5.7	13.6	12.7	21.0	18.4	39.4	1,058	185,239	Yes	-0.82	15.88	70
808533	SEMINOLA	Hybrid	1,214	9	14	5	3.7	0.4	5.2	0.7	8.9	1.1	10.0	3,170	311,396	Yes	-0.17	6.73	33
103834	WILLOW	Hybrid	1,575	1	26	1	8.5	2.2	0.1	21.0	8.6	23.2	31.8	1,097	101,119	Yes	-0.33	5.47	11
707134	CULLUM	Hybrid	11	0	2	0	0.5	0.8	-	2.1	0.5	2.9	3.4	-	-	Yes	0.07	0.37	0
704061	MOTOROLA	Hybrid	2,624	0	28	0	1.5	1.8	-	8.2	1.5	10.0	11.5	292	79,946	Yes	-1.75	6.45	11
105061	SCOTTSMOOR	Hybrid	2,347	73	8	23	12.7	-	100.4	9.0	113.1	9.0	122.1	7,789	280,016	Yes	-0.66	9.64	144
108363	GATOR	Hybrid	2,130	35	33	12	7.6	0.9	18.4	14.5	26.0	15.4	41.4	4,828	66,846	Yes	-3.43	10.97	34
803138	FLORIDA CITY	Hybrid	2,046	0	23	0	1.1	2.0	-	14.9	1.1	16.9	18.0	130	42,283	Yes	-1.85	7.95	8
804040	LE JEUNE	UG	4	0	1	0	-	0.2	-	-	-	-	0.2	0.2	-	Yes	-0.41	6.19	0
402133	TERMINAL	Hybrid	1,556	34	12	2	5.3	-	4.6	1.6	9.9	1.6	11.5	2,310	117,706	Yes	-0.08	4.72	45
809435	SAGA	UG	1	0	0	0	-	0.9	-	-	-	-	0.9	0.9	-	Yes	-0.84	2.96	0
507666	GLADIOLUS	Hybrid	2,160	5	45	13	5.2	2.2	7.0	14.3	12.2	16.5	28.7	620	77,659	Yes	-0.33	13.37	19
812061	WILLIAMS	UG	3,698	0	30	0	-	7.2	-	21.1	-	28.3	28.3	6,354	189,340	Yes	0.66	13.56	21
811636	LUMMUS	UG	501	0	18	2	-	3.2	0.1	4.3	0.1	7.5	7.6	-	-	Yes	-0.20	4.40	0
506461	FRANKLIN	Hybrid	914	8	47	4	6.6	-	18.0	6.2	24.6	6.2	30.8	282	40,676	Yes	-0.40	9.00	17
701531	DANIA	Hybrid	1,524	21	11	4	3.0	-	3.1	2.5	6.1	2.5	8.6	542	49,975	Yes	-0.26	5.34	29
803637	SEABOARD	OH	1,959	33	3	4	4.4	0.2	12.0	0.4	16.4	0.6	17.0	4,424	415,317	Yes	-0.46	9.94	107
500633	CORTEZ	Hybrid	361	5	16	1	2.0	0.2	0.8	2.7	2.8	2.9	5.7	107	30,476	Yes	-2.03	3.47	5
203537	HIBISCUS	Hybrid	745	3	19	1	1.8	2.9	1.1	4.2	2.9	7.1	10.0	446	55,766	Yes	0.06	4.56	17
404437	PURDY LANE	Hybrid	2,355	21	26	6	3.4	0.8	7.5	5.9	10.9	6.7	17.6	2,219	106,882	Yes	-0.47	7.33	39
203132	ROCKLEDGE	Hybrid	961	3	34	3	2.8	-	0.7	9.1	3.5	9.1	12.6	92	14,985	Yes	0.24	6.04	6
202536	AURORA	Hybrid	1,895	29	10	2	3.3	0.7	11.7	2.2	15.0	2.9	17.9	439	68,696	Yes	0.55	6.95	34
502932	ONECO	Hybrid	2,824	25	16	8	4.5	0.1	12.7	3.7	17.2	3.8	21.0	1,169	114,744	Yes	-0.29	8.81	26
809837	DUMFOUNDLING	Hybrid	1,662	1	22	3	1.6	2.0	0.4	3.7	2.0	5.7	7.7	1,821	34,193	Yes	3.25	8.25	5
201131	PATRICK	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.43	7.93	0
409436	SKYPASS	Hybrid	530	7	21	0	0.6	3.9	1.0	9.9	1.6	13.8	15.4	4,291	66,819	Yes	-0.11	4.69	18
102535	MATANZAS	Hybrid	2,303	60	42	9	8.7	2.6	12.1	7.5	20.8	10.1	30.9	7,445	401,915	Yes	-0.68	6.72	76
411861	EVERNIA	Hybrid	781	12	15	1	1.8	1.2	1.7	1.7	3.5	2.9	6.4	91	29,903	Yes	0.22	7.42	13
204361	SUNTREE	Hybrid	1,621	0	26	1	1.8	3.4	0.1	18.9	1.9	22.3	24.2	35	4,411	Yes	-1.68	7.32	19
502062	MURDOCK	OH	3,176	39	11	2	7.0	0.1	36.7	0.8	43.7	0.9	44.6	3,860	219,044	Yes	-0.14	13.76	111
804233	PERRINE	Hybrid	1,327	5	29	2	3.5	0.2	2.4	9.7	5.9	9.9	15.8	993	107,626	Yes	0.38	8.58	34
808334	WHISPERING PINES	UG	2,058	0	21	0	0.3	3.3	-	15.9	0.3	19.2	19.5	47	11,829	Yes	0.10	7.70	7

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
504534	TUTTLE	Hybrid	2,249	27	18	10	4.2	0.6	12.5	6.8	16.7	7.4	24.1	821	146,257	Yes	-0.19	8.71	52
409764	CATCHMENT	Hybrid	4,729	7	54	6	5.4	2.4	4.0	21.5	9.4	23.9	33.3	1,650	123,123	Yes	-0.45	12.55	24
504968	GOLDEN GATE	Hybrid	2,169	100	23	8	13.0	4.2	42.0	13.0	55.0	17.2	72.2	341	66,200	Yes	0.10	10.10	56
106861	FOREST GROVE	Hybrid	1,766	21	16	1	3.1	4.0	25.4	14.5	28.5	18.5	47.0	6,092	114,080	Yes	-2.41	8.09	57
202537	AURORA	Hybrid	2,048	2	39	2	3.5	0.6	0.8	14.0	4.3	14.6	18.9	4,947	65,307	Yes	-0.24	6.16	22
303162	STARKE	Hybrid	837	88	3	8	13.1	1.4	33.7	1.7	46.8	3.1	49.9	1,195	75,083	Yes	-0.27	3.23	51
111133	HALIFAX	Hybrid	13	1	6	1	0.3	1.7	0.3	0.8	0.6	2.5	3.1	-	-	Yes	-0.10	3.30	0
400131	WEST PALM BEACH	Hybrid	835	13	10	0	2.8	0.1	1.8	0.5	4.6	0.6	5.2	59	7,714	Yes	0.33	3.63	20
404034	WESTWARD	Hybrid	3,438	3	30	0	3.2	0.2	1.1	10.4	4.3	10.6	14.9	2	88	Yes	-0.72	5.18	2
800931	40TH ST	UG	99	0	6	0	-	2.4	-	0.9	-	3.3	3.3	1	62	Yes	-0.89	3.91	1
806933	BIRD	Hybrid	1,172	13	29	5	3.4	0.4	2.2	2.0	5.6	2.4	8.0	291	44,145	Yes	-0.04	7.46	26
802435	SOUTH MIAMI	Hybrid	1,021	29	21	2	2.7	4.7	4.4	7.5	7.1	12.2	19.3	683	67,183	Yes	-0.51	7.09	37
806843	RED ROAD	UG	28	0	10	0	-	2.7	-	1.8	-	4.5	4.5	-	-	Yes	0.28	2.58	0
811832	LUMMUS	UG	31	0	13	0	-	8.7	-	1.9	-	10.6	10.6	-	-	Yes	-1.08	3.32	0
501538	PUNTA GORDA	Hybrid	1,338	25	12	14	5.1	0.7	15.1	2.4	20.2	3.1	23.3	176	24,987	Yes	-0.08	5.22	17
806037	GOLDEN GLADES	Hybrid	1,033	15	8	2	2.4	0.2	7.4	0.9	9.8	1.1	10.9	1,778	171,070	Yes	-0.20	6.00	56
411562	FELLSMERE	Hybrid	3,602	73	15	8	10.5	0.8	45.7	9.0	56.2	9.8	66.0	982	169,633	Yes	0.29	14.79	108
505767	AUBURN	Hybrid	3,214	5	56	2	6.8	0.6	4.3	25.5	11.1	26.1	37.2	3,271	176,080	Yes	2.41	11.61	23
405765	SEBASTIAN	Hybrid	3,704	62	23	1	10.2	0.7	35.7	6.4	45.9	7.1	53.0	2,784	282,815	Yes	-0.66	13.44	74
703935	WESTINGHOUSE	Hybrid	1,828	0	32	1	3.0	0.3	0.2	13.2	3.2	13.5	16.7	795	23,426	Yes	-0.20	8.70	16
209863	YORKE	Hybrid	1,665	5	27	2	2.4	6.8	1.1	20.6	3.5	27.4	30.9	1,400	76,796	Yes	-6.81	8.49	19
702734	MCARTHUR	Hybrid	2,318	3	23	0	1.9	0.4	0.5	5.4	2.4	5.8	8.2	1,740	37,614	Yes	-0.20	4.30	4
505465	WINKLER	Hybrid	2,736	26	28	15	5.8	0.3	12.1	8.0	17.9	8.3	26.2	887	132,849	Yes	0.71	13.81	55
704068	MOTOROLA	UG	1	0	0	0	-	0.6	-	-	-	0.6	0.6	-	-	Yes	-0.25	4.65	0
809434	SAGA	Hybrid	3,179	0	35	0	2.4	2.6	0.1	18.8	2.5	21.4	23.9	3,245	259,867	Yes	-0.09	11.21	7
101538	GENERAL ELECTRIC	Hybrid	1,424	4	34	7	3.8	2.1	2.5	14.9	6.3	17.0	23.3	191	20,842	Yes	0.00	8.60	18
508365	TERRY	Hybrid	2,206	15	37	3	3.3	5.1	4.2	21.3	7.5	26.4	33.9	744	178,502	Yes	-0.56	8.24	25
101465	FLAGLER BEACH	Hybrid	2,432	22	24	1	4.1	3.9	23.2	9.5	27.3	13.4	40.7	1,968	78,338	Yes	-0.02	8.58	29
807834	KILLIAN	Hybrid	948	11	20	8	2.0	1.1	7.0	8.5	9.0	9.6	18.6	728	155,055	Yes	-1.87	6.53	53
500239	BRADENTON	Hybrid	1,087	18	23	14	4.6	0.7	6.6	2.3	11.2	3.0	14.2	2,158	139,768	Yes	0.16	7.36	25
800137	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.38	2.82	0
801036	NORMANDY BEACH	Hybrid	1,743	4	13	2	1.2	0.1	0.6	1.5	1.8	1.6	3.4	338	51,961	Yes	-0.11	3.29	11
100234	ST AUGUSTINE	Hybrid	388	10	21	2	3.3	0.2	2.2	1.9	5.5	2.1	7.6	161	37,027	Yes	-0.04	5.66	9
811936	OVERTOWN	UG	615	0	4	0	-	1.7	-	0.4	-	2.1	2.1	1	172	Yes	0.00	2.80	1
405536	PRIMA VISTA	Hybrid	1,731	27	26	3	5.2	0.6	8.7	10.4	13.9	11.0	24.9	1,810	38,261	Yes	-0.19	6.71	26
805633	MILLER	Hybrid	1,013	21	6	2	4.5	-	8.3	1.7	12.8	1.7	14.5	583	107,927	Yes	-0.03	6.77	40
106465	SPRUCE	Hybrid	2,704	47	36	9	13.0	5.2	31.5	24.8	44.5	30.0	74.5	2,319	132,839	Yes	-0.65	12.55	47
813132	FIREHOUSE	UG	1,748	0	7	0	-	2.3	-	0.9	-	3.2	3.2	-	-	Yes	-0.38	6.92	0
801039	NORMANDY BEACH	Hybrid	2,164	5	12	4	1.8	0.7	0.9	0.5	2.7	1.2	3.9	1,318	46,757	Yes	-0.06	4.24	7
801931	DEAUVILLE	UG	448	0	8	0	-	1.8	-	2.3	-	4.1	4.1	84	22,793	Yes	-0.48	3.12	5
810432	BLUE LAGOON	Hybrid	1,292	8	12	1	2.7	0.3	2.4	0.4	5.1	0.7	5.8	183	67,545	Yes	-0.25	3.75	19
405469	CLINTMOORE	UG	1,446	0	28	0	-	4.2	-	20.5	-	24.7	24.7	982	64,207	Yes	-0.14	11.96	12
210532	APOLLO	Hybrid	1,266	18	13	6	3.7	0.4	10.1	2.9	13.8	3.3	17.1	429	78,629	Yes	0.03	7.93	46
801733	62ND AVE	Hybrid	1,632	30	17	4	4.0	0.2	7.8	0.9	11.8	1.1	12.9	1,393	67,317	Yes	-0.30	8.90	36
505066	JETPORT	Hybrid	3,513	58	23	2	12.2	2.6	42.3	10.1	54.5	12.7	67.2	570	56,705	Yes	0.80	12.20	35
700534	POMPANO	Hybrid	949	11	30	3	3.2	2.1	3.0	5.2	6.2	7.3	13.5	129	14,228	Yes	-0.43	6.87	16
403234	ATLANTIC	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.46	4.24	0
103832	WILLOW	Hybrid	787	0	15	0	2.5	-	-	7.2	2.5	7.2	9.7	74	18,261	Yes	0.10	3.10	4
507164	POLO	UG	1,136	0	41	0	0.1	9.9	-	14.1	0.1	24.0	24.1	35	4,342	Yes	-3.21	12.49	1
106531	REED	Hybrid	1,507	17	20	4	2.8	0.5	4.3	4.2	7.1	4.7	11.8	57	4,600	Yes	0.78	4.48	16
202535	AURORA	Hybrid	1,792	56	27	10	5.7	0.1	18.0	11.5	23.7	11.6	35.3	1,840	125,913	Yes	-0.33	7.77	39
203634	HARRIS	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.96	2.56	0

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
814048	BRICKELL	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	0.00	0.00	0
503032	PHILLIPPI	Hybrid	966	9	12	14	1.9	0.1	7.0	2.8	8.9	2.9	11.8	258	37,207	Yes	-0.31	5.59	28
200133	SANFORD	Hybrid	1,557	8	33	5	4.7	2.9	1.7	9.4	6.4	12.3	18.7	2,893	74,510	Yes	-3.23	6.97	18
506162	METRO	Hybrid	1,382	4	45	2	3.1	2.0	3.4	14.6	6.5	16.6	23.1	142	16,915	Yes	-0.09	15.71	11
205435	MERRITT	Hybrid	1,362	39	18	5	5.8	0.1	9.2	7.9	15.0	8.0	23.0	2,450	91,817	Yes	-3.00	6.90	30
803137	FLORIDA CITY	Hybrid	1,102	2	19	1	2.3	1.5	0.5	6.8	2.8	8.3	11.1	1,630	115,957	Yes	-0.14	4.76	12
402831	LANTANA	Hybrid	1,624	26	28	5	5.2	0.1	10.3	4.4	15.5	4.5	20.0	1,743	79,797	Yes	-0.08	8.82	37
201233	TROPICANA	Hybrid	666	5	22	6	2.3	2.7	1.1	4.3	3.4	7.0	10.4	414	39,507	Yes	0.83	7.03	4
703137	RAVENSWOOD	Hybrid	199	4	27	1	1.5	2.9	0.4	3.6	1.9	6.5	8.4	17	1,001	Yes	0.19	6.39	3
405266	ACME	Hybrid	2,584	8	63	1	5.1	2.5	2.9	22.8	8.0	25.3	33.3	155	17,929	Yes	-0.74	14.36	15
201736	SYKES CREEK	Hybrid	1,690	68	20	8	7.5	2.1	11.3	4.7	18.8	6.8	25.6	194	44,191	Yes	-0.16	6.64	37
706363	BASSCREEK	Hybrid	1,355	1	24	1	1.6	5.0	1.8	15.4	3.4	20.4	23.8	1,410	76,305	Yes	-0.31	8.59	8
108432	SAN MATEO	Hybrid	1,236	42	7	5	6.3	0.1	22.6	3.4	28.9	3.5	32.4	2,460	198,214	Yes	-0.22	4.38	63
504262	DORR FIELD	OH	194	23	4	5	37.6	0.1	94.4	3.3	132.0	3.4	135.4	797	133,563	Yes	0.01	1.61	65
705466	PHOENIX	UG	2,496	0	26	0	-	4.0	-	24.6	-	28.6	28.6	195	46,559	Yes	-0.83	11.67	9
703135	RAVENSWOOD	Hybrid	700	1	6	1	0.9	2.2	0.5	3.0	1.4	5.2	6.6	59	7,351	Yes	-0.35	4.45	3
403633	SOUTH BAY	OH	978	43	15	5	18.1	0.5	19.5	1.4	37.6	1.9	39.5	2,060	177,926	Yes	-0.44	5.36	51
209763	VIERA	UG	2,249	0	52	0	0.6	8.6	-	41.6	0.6	50.2	50.8	127	23,407	Yes	-0.78	14.42	4
702731	MCARTHUR	Hybrid	2,021	1	38	1	2.9	1.2	0.4	5.4	3.3	6.6	9.9	1,162	57,627	Yes	0.39	7.09	10
507562	PARRISH	Hybrid	3,509	3	54	9	5.0	1.8	6.3	27.5	11.3	29.3	40.6	1,268	110,742	Yes	-0.17	11.73	32
808431	SNAKE CREEK	Hybrid	1,178	2	15	1	2.3	0.3	1.1	9.0	3.4	9.3	12.7	490	124,725	Yes	-2.39	4.41	31
501831	TICE	Hybrid	1,072	27	7	3	3.7	0.1	13.2	2.3	16.9	2.4	19.3	294	39,222	Yes	-0.23	5.07	33
705537	SOUTHSIDE	UG	541	0	16	0	-	2.6	-	0.5	-	3.1	3.1	-	-	Yes	0.83	6.13	0
805036	UNIVERSITY	Hybrid	1,620	33	13	5	3.1	0.6	7.6	1.1	10.7	1.7	12.4	1,933	78,683	Yes	0.63	9.23	51
412261	OTTER	Hybrid	524	13	14	4	12.5	9.0	23.5	19.9	36.0	28.9	64.9	2,575	101,114	Yes	-0.61	3.69	24
412761	HUMMINGBIRD	UG	18	0	1	0	-	5.7	-	9.0	-	14.7	14.7	-	-	Yes	0.13	0.83	0
707266	FLAMINGO	Hybrid	1,674	1	15	0	3.1	0.5	0.5	9.5	3.6	10.0	13.6	2,028	104,719	Yes	-0.47	5.53	25
707034	SHERIDAN	Hybrid	1,452	0	23	0	2.1	1.1	-	11.8	2.1	12.9	15.0	464	81,500	Yes	-1.04	6.16	20
502832	PAYNE	Hybrid	1,412	34	17	6	2.4	0.7	7.5	2.5	9.9	3.2	13.1	834	29,559	Yes	0.30	6.40	37
814044	BRICKELL	UG	452	0	2	0	-	1.3	-	0.3	-	1.6	1.6	-	-	Yes	0.01	1.11	0
412164	ALLAPATTAH	Hybrid	156	16	5	3	10.3	0.4	18.9	1.9	29.2	2.3	31.5	341	64,288	Yes	-0.05	2.95	30
507064	IMPERIAL	Hybrid	3,160	4	44	0	1.5	9.8	1.7	26.7	3.2	36.5	39.7	567	59,360	Yes	-0.65	12.55	21
101634	HUDSON	Hybrid	633	37	36	8	7.6	-	9.5	3.8	17.1	3.8	20.9	173	22,168	Yes	0.25	6.55	25
101539	GENERAL ELECTRIC	Hybrid	273	0	12	0	0.9	3.1	0.2	1.6	1.1	4.7	5.8	14	3,514	Yes	0.11	2.71	1
810434	BLUE LAGOON	Hybrid	2,390	27	3	4	3.7	0.9	9.4	0.3	13.1	1.2	14.3	466	80,407	Yes	-0.08	10.22	53
405264	ACME	Hybrid	1,244	6	44	3	5.9	1.1	2.5	15.9	8.4	17.0	25.4	89	9,674	Yes	0.15	11.55	14
401137	STUART	Hybrid	1,213	22	30	6	4.4	0.7	3.9	3.6	8.3	4.3	12.6	1,278	20,936	Yes	-0.26	6.74	14
100839	PORT ORANGE	Hybrid	865	18	3	5	2.2	0.5	4.8	0.7	7.0	1.2	8.2	1,030	25,851	Yes	-0.13	1.47	20
805836	CORAL REEF	Hybrid	1,309	13	12	2	3.2	1.5	4.9	9.0	8.1	10.5	18.6	601	117,165	Yes	-0.61	4.89	40
404039	WESTWARD	Hybrid	949	0	32	0	1.7	1.6	-	4.3	1.7	5.9	7.6	-	-	Yes	-0.17	5.43	0
701839	ROCK ISLAND	Hybrid	1,982	27	22	6	5.0	0.2	7.7	4.2	12.7	4.4	17.1	2,571	149,681	Yes	-0.78	8.32	48
809932	SIMPSON	UG	821	0	7	1	-	3.2	-	1.2	-	4.4	4.4	-	-	Yes	0.16	6.66	0
200332	TITUSVILLE	Hybrid	2,130	25	13	5	3.5	0.1	12.5	4.9	16.0	5.0	21.0	2,836	180,092	Yes	-0.48	7.22	51
704263	IMAGINATION	UG	775	0	40	1	0.8	5.0	0.2	14.8	1.0	19.8	20.8	40	4,522	Yes	-0.55	11.55	6
807438	VILLAGE GREEN	UG	2	0	3	0	-	0.7	-	-	-	0.7	0.7	-	-	Yes	0.06	3.06	0
503138	SOLANA	Hybrid	1,333	7	60	3	3.7	0.7	3.4	6.5	7.1	7.2	14.3	160	25,183	Yes	-0.29	9.71	27
809131	TAMIAMI	Hybrid	501	13	9	2	1.5	0.2	1.2	0.3	2.7	0.5	3.2	19	3,451	Yes	0.17	4.07	8
809431	SAGA	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.27	6.93	0
102633	LEWIS	Hybrid	554	12	5	2	1.7	3.4	4.4	2.2	6.1	5.6	11.7	141	23,910	Yes	-0.17	2.53	12
505663	ROTONDA	Hybrid	3,587	49	20	3	9.3	0.5	49.5	6.7	58.8	7.2	66.0	9,506	375,755	Yes	0.19	14.89	50
411234	MORAY	Hybrid	1,261	17	16	6	2.4	0.6	4.7	7.4	7.1	8.0	15.1	275	31,060	Yes	-1.03	6.07	23
500932	OSPREY	Hybrid	1,570	5	18	6	2.4	-	5.8	12.0	8.2	12.0	20.2	210	23,027	Yes	0.16	5.06	22

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
501131	FT MYERS	Hybrid	876	23	18	6	2.9	0.1	5.7	2.7	8.6	2.8	11.4	997	16,098	Yes	0.03	6.13	26
502631	COLONIAL	Hybrid	711	10	10	1	1.6	0.5	5.7	5.5	7.3	6.0	13.3	241	31,367	Yes	0.12	4.12	28
200732	COCOA BEACH	Hybrid	1,513	9	21	9	2.3	0.1	3.6	5.1	5.9	5.2	11.1	4,094	53,113	Yes	-4.08	3.62	20
408264	COVE	Hybrid	3,652	21	55	7	5.5	0.6	8.3	25.0	13.8	25.6	39.4	526	118,034	Yes	-0.23	11.57	39
708162	HUNTINGTON	Hybrid	780	1	59	0	2.8	4.5	0.1	12.3	2.9	16.8	19.7	358	38,969	Yes	-1.15	12.45	15
701639	PLANTATION	Hybrid	1,667	32	15	4	3.3	1.1	9.3	3.7	12.6	4.8	17.4	411	80,044	Yes	0.02	8.02	68
505362	PARK	Hybrid	3,426	2	56	2	4.1	1.8	2.4	28.7	6.5	30.5	37.0	498	52,227	Yes	0.10	13.30	23
704766	STONEBRIDGE	Hybrid	1,857	12	45	6	5.3	1.7	6.1	17.4	11.4	19.1	30.5	9,139	151,985	Yes	-0.66	11.74	36
700637	VERENA	Hybrid	1,734	11	19	8	2.0	0.2	4.5	2.2	6.5	2.4	8.9	1,559	114,881	Yes	0.02	5.82	40
700331	PINEHURST	Hybrid	1,620	11	4	1	2.1	0.1	5.1	2.0	7.2	2.1	9.3	1,194	153,512	Yes	-1.24	4.86	23
801632	PRINCETON	Hybrid	1,974	2	28	0	2.4	0.6	0.3	12.4	2.7	13.0	15.7	2,141	132,497	Yes	0.07	6.27	19
403034	MILITARY TRAIL	Hybrid	1,948	43	24	7	3.7	0.6	8.9	10.4	12.6	11.0	23.6	333	48,307	Yes	-0.41	8.79	50
810061	AVOCADO	Hybrid	1,463	62	14	3	12.7	1.0	38.8	6.3	51.5	7.3	58.8	2,053	194,929	Yes	0.46	9.16	133
700533	POMPANO	Hybrid	528	8	4	5	2.1	-	3.0	1.5	5.1	1.5	6.6	261	24,050	Yes	-0.15	4.45	12
502463	LABELLE	Hybrid	1,408	136	27	18	27.2	0.6	101.3	10.6	128.5	11.2	139.7	8,281	301,980	Yes	0.58	4.18	86
811831	MEMORIAL	Hybrid	1,632	0	27	0	1.5	2.8	-	7.8	1.5	10.6	12.1	4,059	151,813	Yes	-0.86	6.04	12
410231	CONGRESS	Hybrid	1,498	15	24	7	3.8	0.4	8.0	4.8	11.8	5.2	17.0	905	62,250	Yes	-0.12	6.18	43
806135	DOUGLAS	Hybrid	262	3	11	1	0.8	1.3	0.2	0.4	1.0	1.7	2.7	9	1,594	Yes	-0.59	4.41	4
205933	SYLVAN	Hybrid	1,088	2	30	1	2.0	2.8	0.6	8.2	2.6	11.0	13.6	186	24,647	Yes	-0.18	7.12	6
407463	INDRIO	Hybrid	1,500	56	46	5	20.8	1.2	15.5	15.7	36.3	16.9	53.2	3,864	108,666	Yes	0.17	5.67	38
100531	MCMEEKIN	OH	1,100	69	2	6	8.9	-	49.3	0.9	58.2	0.9	59.1	1,210	98,543	Yes	-1.23	2.37	71
400539	BOYNTON	Hybrid	1,288	1	33	1	1.2	2.2	1.1	4.0	2.3	6.2	8.5	543	36,815	Yes	0.53	6.93	9
802735	MARION	Hybrid	314	0	15	0	0.4	1.9	-	2.7	0.4	4.6	5.0	364	15,994	Yes	0.34	4.14	6
506463	FRANKLIN	Hybrid	3,827	63	11	3	10.1	0.2	81.4	7.0	91.5	7.2	98.7	4,218	120,193	Yes	-0.51	14.49	78
809534	VIRGINIA KEY	Hybrid	29	0	2	1	0.1	3.2	0.1	0.5	0.2	3.7	3.9	1	40	Yes	0.11	3.31	1
406432	SAVANNAH	Hybrid	480	0	16	1	1.6	0.2	0.1	1.5	1.7	1.7	3.4	9	3,988	Yes	-0.03	3.77	2
505364	PARK	Hybrid	2,855	0	40	1	3.3	3.0	0.5	34.5	3.8	37.5	41.3	225	23,072	Yes	0.06	12.16	4
410033	MARYMOUNT	UG	528	0	21	0	-	2.2	-	5.4	-	7.6	7.6	-	-	Yes	0.03	6.73	0
800936	40TH ST	UG	506	0	7	0	-	2.0	-	0.9	-	2.9	2.9	54	6,426	Yes	-2.28	4.02	1
504261	DORR FIELD	OH	645	40	7	6	15.4	0.1	70.2	1.6	85.6	1.7	87.3	304	43,386	Yes	1.40	5.00	45
806533	SUNILAND	Hybrid	718	25	5	2	3.3	1.5	8.0	0.3	11.3	1.8	13.1	482	74,292	Yes	-0.30	6.00	60
702436	PEMBROKE	UG	1,028	0	9	0	-	2.5	-	0.9	-	3.4	3.4	127	6,866	Yes	0.56	6.36	3
807838	WESTON VILLAGE	UG	9	0	0	0	-	3.7	-	-	-	3.7	3.7	-	-	Yes	-2.22	2.28	0
502938	ONECO	Hybrid	2,676	10	24	10	2.7	1.0	6.4	5.0	9.1	6.0	15.1	452	74,913	Yes	-0.32	7.68	29
503862	ORTIZ	Hybrid	2,930	44	32	10	7.7	0.6	18.2	13.4	25.9	14.0	39.9	6,219	340,729	Yes	-2.69	11.81	57
702934	HAWKINS	Hybrid	2,425	4	24	2	3.9	0.1	2.1	15.0	6.0	15.1	21.1	260	40,185	Yes	-0.42	6.88	23
205632	SARNO	Hybrid	1,274	15	23	2	3.5	0.3	6.2	7.6	9.7	7.9	17.6	2,805	79,792	Yes	-1.87	5.23	18
502167	BONITA SPRINGS	Hybrid	2,669	6	38	10	3.3	1.8	3.4	20.6	6.7	22.4	29.1	3,284	192,452	Yes	0.08	9.78	39
403935	LAKE PARK	Hybrid	2,308	25	18	6	4.8	0.3	8.6	4.3	13.4	4.6	18.0	522	99,988	Yes	-0.28	8.12	51
801235	OPA LOCKA	Hybrid	1,330	26	14	6	3.4	0.9	5.5	1.1	8.9	2.0	10.9	312	32,640	Yes	0.02	6.42	39
700145	SISTRUNK	UG	1,056	0	8	0	-	2.6	-	1.3	-	3.9	3.9	-	-	Yes	-1.23	3.97	0
400832	PAHOKEE	OH	377	15	0	1	47.1	-	5.1	0.2	52.2	0.2	52.4	1,358	94,417	Yes	0.09	1.19	22
702735	MCARTHUR	Hybrid	3,007	1	22	4	1.9	0.2	1.6	7.5	3.5	7.7	11.2	580	126,121	Yes	0.16	7.96	18
802639	AIRPORT	UG	-	0	0	0	-	1.4	-	-	-	1.4	1.4	-	-	Yes	0.01	1.01	0
805534	MASTER	Hybrid	40	0	12	0	1.0	0.1	-	2.7	1.0	2.8	3.8	81	521	Yes	0.02	3.92	3
507063	IMPERIAL	Hybrid	2,725	32	47	10	7.1	0.6	11.0	7.9	18.1	8.5	26.6	4,686	214,311	Yes	-0.35	8.75	34
405339	BEELINE	Hybrid	15	1	2	0	0.3	0.5	0.2	0.1	0.5	0.6	1.1	-	-	Yes	0.10	3.90	0
408265	COVE	Hybrid	2,413	33	33	3	7.2	2.5	7.6	15.7	14.8	18.2	33.0	488	59,642	Yes	0.96	8.36	41
102634	LEWIS	Hybrid	2,321	32	12	4	4.0	0.6	14.8	4.4	18.8	5.0	23.8	745	108,452	Yes	0.00	6.70	46
806733	IVES	Hybrid	2,140	6	30	0	2.1	2.2	3.4	10.0	5.5	12.2	17.7	381	68,404	Yes	-0.47	8.53	37
301563	WIREMILL	UG	4	0	2	0	-	0.5	-	0.2	-	0.7	0.7	-	-	Yes	0.11	3.81	0
700461	OAKLAND PARK	Hybrid	337	1	0	1	0.8	0.9	1.0	0.1	1.8	1.0	2.8	72	8,866	Yes	-0.12	2.08	5

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR	
404931	PORT SEWALL	Hybrid	2,065	21	33	3	5.8	0.8	8.0	7.4	13.8	8.2	22.0	2,205	97,643	Yes	-0.44	7.06	21	
806931	BIRD	Hybrid	561	14	3	0	1.7	0.3	2.7	0.2	4.4	0.5	4.9	92	15,997	Yes	-0.07	5.83	14	
403733	MONET	Hybrid	1,873	0	44	1	2.8	2.3	0.2	8.3	3.0	10.6	13.6	144	12,291	Yes	0.10	7.90	7	
409865	HAMLET	Hybrid	2,325	1	23	0	1.6	2.6	0.3	10.1	1.9	12.7	14.6	526	56,177	Yes	5.27	5.27	10	
400834	PAHOKEE	Hybrid	903	38	12	4	16.1	0.2	15.3	3.1	31.4	3.3	34.7	908	104,617	Yes	0.00	5.40	41	
800111	MIAMI	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	2.24	2.24	0	
414036	GRACEWOOD	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	4.91	4.91	0	
507862	IXORA	Hybrid	1,174	19	13	5	5.9	0.3	23.1	5.5	29.0	5.8	34.8	894	42,002	Yes	-0.14	2.96	30	
502563	PALMA SOLA	Hybrid	4,318	29	57	14	6.4	4.3	10.7	14.6	17.1	18.9	36.0	4,937	156,973	Yes	-0.24	13.26	51	
406435	SAVANNAH	Hybrid	1,810	30	25	2	5.7	0.9	12.5	8.3	18.2	9.2	27.4	928	29,449	Yes	0.03	6.93	23	
704764	STONEBRIDGE	Hybrid	1,752	1	28	0	2.0	0.3	0.1	15.8	2.1	16.1	18.2	302	52,403	Yes	-0.70	8.00	16	
702033	DRIFTWOOD	Hybrid	1,204	1	25	2	1.7	1.0	1.1	7.1	2.8	8.1	10.9	281	51,430	Yes	-0.31	5.49	20	
806835	RED ROAD	Hybrid	1,420	22	6	2	3.0	0.6	7.6	1.3	10.6	1.9	12.5	897	142,353	Yes	-0.09	8.11	70	
700962	HALLANDALE	UG	1,199	0	9	0	-	4.4	-	-	0.7	-	5.1	5.1	1,660	66,543	Yes	-0.93	6.97	5
807436	VILLAGE GREEN	Hybrid	456	32	19	2	5.3	0.7	7.3	2.8	12.6	3.5	16.1	815	52,466	Yes	0.27	6.07	27	
101037	HOLLY HILL	Hybrid	1,790	44	14	4	4.2	0.3	10.6	2.1	14.8	2.4	17.2	484	88,280	Yes	-0.88	7.22	47	
701035	SAMPLE ROAD	Hybrid	2,347	22	29	4	3.4	0.8	6.9	4.5	10.3	5.3	15.6	398	51,431	Yes	-0.22	9.18	32	
102235	MADISON	Hybrid	2,458	52	14	5	3.6	1.7	15.2	3.1	18.8	4.8	23.6	1,133	183,654	Yes	0.57	8.17	103	
103835	WILLOW	Hybrid	2,640	5	47	2	2.9	1.1	2.4	18.1	5.3	19.2	24.5	170	17,307	Yes	0.47	7.77	12	
705868	REMSBURG	Hybrid	1,975	5	33	1	2.9	0.7	1.4	9.2	4.3	9.9	14.2	1,272	52,046	Yes	-0.42	7.18	20	
705462	PHOENIX	Hybrid	249	0	13	0	0.7	3.0	-	1.9	0.7	4.9	5.6	7	493	Yes	0.06	4.36	4	
301133	COLUMBIA	Hybrid	1,086	40	0	6	5.1	0.4	16.9	1.2	22.0	1.6	23.6	1,079	80,735	Yes	-0.25	3.65	43	
507561	PARRISH	Hybrid	4,026	75	74	16	23.8	5.1	36.1	53.2	59.9	58.3	118.2	2,470	169,159	Yes	0.28	15.48	54	
801135	FRONTON	Hybrid	698	15	17	0	2.9	0.2	2.8	0.7	5.7	0.9	6.6	915	78,293	Yes	-0.11	5.09	39	
400934	BELLE GLADE	OH	1,699	69	14	3	35.9	0.3	25.9	1.2	61.8	1.5	63.3	3,229	314,003	Yes	-0.19	7.51	59	
702533	DAVIE	Hybrid	608	1	17	0	2.2	0.1	0.1	5.5	2.3	5.6	7.9	233	40,273	Yes	-0.05	6.25	12	
809334	RONEY	UG	1,272	0	7	0	-	2.9	-	1.1	-	4.0	4.0	6	276	Yes	-0.05	3.45	1	
300962	MACCLENNY	Hybrid	391	9	11	5	4.5	0.7	12.9	1.2	17.4	1.9	19.3	297	37,326	Yes	0.75	5.35	16	
201831	MINUTEMAN	Hybrid	2,092	19	11	9	3.1	0.4	6.5	5.5	9.6	5.9	15.5	812	110,048	Yes	-1.14	5.76	37	
500237	BRADENTON	Hybrid	1,316	2	16	3	0.8	2.1	0.5	4.0	1.3	6.1	7.4	190	43,142	Yes	0.05	5.65	5	
700233	HOLLYWOOD	Hybrid	947	3	9	2	1.9	0.3	1.2	0.5	3.1	0.8	3.9	1,172	74,121	Yes	-0.02	5.88	17	
701033	SAMPLE ROAD	Hybrid	1,204	22	26	0	3.2	0.1	5.1	3.2	8.3	3.3	11.6	146	21,095	Yes	-0.16	6.44	37	
806932	BIRD	OH	1,199	17	3	4	3.7	0.1	9.1	0.5	12.8	0.6	13.4	926	129,121	Yes	-0.32	7.18	61	
504366	PINE RIDGE	Hybrid	2,476	5	19	2	1.5	3.5	2.6	13.1	4.1	16.6	20.7	3,668	179,171	Yes	-0.38	9.52	6	
803440	MIAMI SHORES	Hybrid	1,594	25	22	2	3.0	1.7	6.9	1.3	9.9	3.0	12.9	1,135	105,579	Yes	-0.32	6.38	82	
505262	RUBENIA	Hybrid	3,462	44	32	22	10.8	1.3	30.5	11.8	41.3	13.1	54.4	4,163	124,728	Yes	-0.23	11.57	71	
809935	SIMPSON	Hybrid	841	5	5	0	0.7	1.4	0.4	0.4	1.1	1.8	2.9	294	12,712	Yes	-0.48	3.42	5	
802538	GREYNOLDS	UG	-	0	0	0	-	2.8	-	-	-	2.8	2.8	-	-	Yes	-0.49	0.11	0	
703933	WESTINGHOUSE	Hybrid	1,016	0	20	0	0.9	1.0	-	6.9	0.9	7.9	8.8	220	30,702	Yes	0.33	5.13	7	
402938	OSLO	Hybrid	2,849	22	30	7	5.6	2.4	13.2	10.8	18.8	13.2	32.0	400	88,936	Yes	0.02	7.62	19	
504133	BENEVA	Hybrid	1,493	17	24	2	3.5	0.1	7.6	9.0	11.1	9.1	20.2	257	41,692	Yes	-0.26	6.64	38	
802038	CUTLER	Hybrid	1,273	11	36	6	3.1	2.4	3.6	14.6	6.7	17.0	23.7	1,212	130,374	Yes	0.28	8.28	43	
411235	MORAY	UG	139	0	5	0	-	4.3	-	0.2	-	4.5	4.5	-	-	Yes	-0.37	5.93	0	
504062	CAPRI	Hybrid	3,189	2	49	2	5.5	9.4	2.3	51.5	7.8	60.9	68.7	1,666	151,132	Yes	-2.71	8.69	33	
811833	MEMORIAL	Hybrid	1,248	6	29	2	1.9	2.6	2.6	8.8	4.5	11.4	15.9	3,225	100,595	Yes	0.11	9.01	20	
106237	GERONA	OH	940	22	1	0	1.3	0.1	8.8	-	10.1	0.1	10.2	334	15,808	Yes	-0.18	3.62	26	
811065	PALMETTO	Hybrid	2,715	0	47	0	2.0	0.8	-	7.9	2.0	8.7	10.7	211	17,239	Yes	-1.24	6.16	7	
106233	GERONA	Hybrid	2,678	28	23	2	3.2	2.9	11.0	9.4	14.2	12.3	26.5	791	94,466	Yes	0.42	9.02	56	
409435	SKYPASS	Hybrid	1,006	12	3	3	1.1	0.2	2.0	0.8	3.1	1.0	4.1	68	15,806	Yes	0.04	2.54	11	
101537	GENERAL ELECTRIC	Hybrid	375	0	27	1	0.9	2.0	0.2	3.2	1.1	5.2	6.3	5	1,150	Yes	0.08	2.48	1	
808537	SEMINOLA	Hybrid	1,950	23	9	7	3.5	0.5	7.4	0.8	10.9	1.3	12.2	634	97,707	Yes	-0.18	9.32	50	
700840	VERENA	Hybrid	891	1	17	1	1.1	2.9	0.2	1.1	1.3	4.0	5.3	15	1,073	Yes	-0.18	4.92	2	

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
701733	STIRLING	Hybrid	1,048	29	3	5	3.7	0.4	4.2	0.6	7.9	1.0	8.9	1,854	8,612	Yes	-0.40	5.80	19
408168	ROSS	Hybrid	2,755	1	54	1	4.6	4.1	0.4	22.4	5.0	26.5	31.5	163	14,565	Yes	-0.37	11.63	11
703533	DEERFIELD BEACH	Hybrid	1,740	10	28	7	2.3	0.1	3.4	4.0	5.7	4.1	9.8	332	52,822	Yes	-0.05	5.15	18
502638	COLONIAL	Hybrid	1,258	0	30	5	2.0	0.2	1.1	7.7	3.1	7.9	11.0	66	14,859	Yes	0.42	7.22	3
704133	MOFFETT	Hybrid	1,488	21	17	5	4.1	0.3	5.7	4.2	9.8	4.5	14.3	376	41,657	Yes	-0.12	7.28	31
802934	GRAPELAND	OH	1,296	20	3	2	2.1	0.2	4.7	0.1	6.8	0.3	7.1	1,612	67,627	Yes	0.15	5.75	36
705232	TIMBERLAKE	Hybrid	601	2	16	4	1.7	0.5	0.7	3.2	2.4	3.7	6.1	26	1,830	Yes	0.17	4.47	4
703635	PALM AIRE	Hybrid	883	12	21	1	2.6	1.7	3.0	5.0	5.6	6.7	12.3	70	7,367	Yes	0.08	3.38	15
406765	ACREAGE	Hybrid	3,029	5	52	0	6.4	7.8	3.7	44.6	10.1	52.4	62.5	1,228	23,034	Yes	-0.72	15.68	16
411961	TESORO	Hybrid	1,870	43	32	1	5.3	5.0	26.7	21.7	32.0	26.7	58.7	223	31,577	Yes	0.02	8.12	35
813131	FIREHOUSE	UG	1,559	0	9	0	-	2.4	-	1.7	-	4.1	4.1	2	671	Yes	0.21	7.11	2
801932	DEAUVILLE	UG	769	0	4	0	-	1.1	-	0.3	-	1.4	1.4	-	-	Yes	3.57	5.27	0
701833	ROCK ISLAND	Hybrid	2,208	8	16	3	3.3	-	6.2	2.3	9.5	2.3	11.8	1,491	86,483	Yes	-0.02	8.18	42
810933	LATIN QUARTER	Hybrid	3,498	16	19	3	3.3	0.4	1.4	0.6	4.7	1.0	5.7	4,892	282,279	Yes	-0.59	7.31	19
809668	COURT	UG	1,832	0	34	0	0.6	5.8	-	17.4	0.6	23.2	23.8	1,727	78,286	Yes	-0.28	8.22	11
507362	ORANGETREE	Hybrid	4,016	7	65	3	4.7	16.8	15.1	52.3	19.8	69.1	88.9	69	14,009	Yes	-0.65	13.05	24
704065	MOTOROLA	UG	-	0	0	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	0.05	0.15	0
403239	ATLANTIC	Hybrid	25	0	6	0	0.5	3.2	-	0.2	0.5	3.4	3.9	5	294	Yes	-0.36	5.14	2
506965	WOODS	Hybrid	1,518	2	30	0	3.0	1.9	0.4	17.1	3.4	19.0	22.4	7,639	302,800	Yes	1.29	14.59	24
702833	PERRY	Hybrid	1,557	0	47	0	4.2	0.3	-	6.9	4.2	7.2	11.4	1,760	66,030	Yes	-0.65	6.75	8
205433	MERRITT	Hybrid	887	19	16	7	2.9	-	5.4	1.1	8.3	1.1	9.4	245	48,667	Yes	-0.62	5.78	21
805631	MILLER	Hybrid	1,538	21	9	2	3.2	-	10.5	1.2	13.7	1.2	14.9	788	140,525	Yes	0.01	8.21	48
809937	SIMPSON	UG	451	0	6	0	-	1.7	-	0.3	-	2.0	2.0	-	-	Yes	-0.95	4.35	0
505165	PROCTOR	Hybrid	1,693	9	37	2	3.1	2.3	6.2	12.3	9.3	14.6	23.9	4,279	181,754	Yes	-2.79	11.01	58
503431	SOUTH VENICE	Hybrid	2,366	37	1	4	4.7	0.1	24.2	2.2	28.9	2.3	31.2	974	137,593	Yes	-0.10	7.60	68
502202	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-3.62	6.48	0
811434	WATKINS	UG	61	0	8	1	-	4.7	-	1.1	-	5.8	5.8	-	-	Yes	0.46	5.56	0
505561	VAMO	Hybrid	2,640	26	27	3	2.7	1.4	5.6	7.2	8.3	8.6	16.9	1,436	77,870	Yes	-0.47	6.53	27
405763	SEBASTIAN	Hybrid	1,102	23	29	8	5.4	0.5	9.0	3.8	14.4	4.3	18.7	334	80,888	Yes	-0.04	7.76	16
409362	SWEATT	Hybrid	261	21	5	5	11.6	0.2	22.5	18.5	34.1	18.7	52.8	65	9,491	Yes	0.08	1.68	14
300963	MACCLENNY	Hybrid	2,139	63	15	13	11.3	0.1	44.8	5.3	56.1	5.4	61.5	4,564	133,142	Yes	-0.40	9.90	67
701835	ROCK ISLAND	Hybrid	1,596	3	21	1	1.8	0.3	2.5	2.6	4.3	2.9	7.2	468	64,375	Yes	0.09	3.79	12
701740	STIRLING	UG	2	0	0	0	-	1.8	-	-	-	1.8	1.8	-	-	Yes	0.20	8.50	0
704462	FASHION	UG	70	0	3	0	-	1.5	-	0.1	-	1.6	1.6	3	1,845	Yes	-0.13	1.77	1
510361	PIRATE	Hybrid	2,625	21	31	10	5.8	2.0	12.8	9.5	18.6	11.5	30.1	161	11,142	Yes	0.01	0.91	13
806734	IVES	Hybrid	1,135	0	9	0	0.4	1.2	-	4.0	0.4	5.2	5.6	100	16,010	Yes	0.27	3.67	4
503865	ORTIZ	Hybrid	3,696	17	61	9	7.7	3.5	4.7	54.7	12.4	58.2	70.6	112	16,400	Yes	0.23	16.23	22
700963	HALLANDALE	UG	1,554	0	8	0	-	3.8	-	1.3	-	5.1	5.1	329	40,859	Yes	0.59	7.79	3
506561	GRANADA	UG	2,912	0	33	0	0.6	6.4	-	35.7	0.6	42.1	42.7	156	43,260	Yes	0.02	7.92	9
800104	MIAMI	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	2.14	2.14	0
808065	FLAGAMI	Hybrid	1,241	2	28	2	1.9	0.8	0.9	4.4	2.8	5.2	8.0	122	9,632	Yes	-0.05	4.85	4
412431	SPANISH LAKES	Hybrid	1,318	24	53	10	12.7	2.0	16.0	33.2	28.7	35.2	63.9	1,599	56,004	Yes	-0.36	5.94	22
407165	CRANE	Hybrid	2,277	2	66	0	6.1	12.7	1.1	44.9	7.2	57.6	64.8	1,487	29,077	Yes	-0.05	10.25	22
809765	SWEETWATER	Hybrid	2,832	5	69	7	4.9	2.4	2.6	28.4	7.5	30.8	38.3	192	18,860	Yes	-0.18	16.92	17
407862	LOXAHATCHEE	Hybrid	2,578	4	48	1	5.8	0.5	1.3	32.9	7.1	33.4	40.5	8,761	198,717	Yes	-0.99	14.11	36
805031	UNIVERSITY	Hybrid	106	0	22	0	0.7	3.2	-	1.4	0.7	4.6	5.3	59	3,540	Yes	-1.83	7.47	1
400532	BOYNTON	Hybrid	1,116	4	33	1	3.6	1.5	0.3	8.8	3.9	10.3	14.2	65	5,347	Yes	-0.19	5.91	8
808162	MILAM	Hybrid	408	0	34	0	2.1	1.1	-	6.5	2.1	7.6	9.7	42	10,117	Yes	0.23	10.03	8
805135	LAWRENCE	Hybrid	1,343	5	13	4	1.7	0.9	1.9	0.9	3.6	1.8	5.4	1,547	84,045	Yes	0.38	5.38	21
702733	MCARTHUR	Hybrid	1,739	15	6	1	2.7	2.6	7.4	1.4	10.1	4.0	14.1	2,393	67,432	Yes	-0.28	7.12	32
200335	TITUSVILLE	Hybrid	540	13	13	4	2.4	0.3	4.4	1.0	6.8	1.3	8.1	524	49,103	Yes	-0.10	4.80	18
802835	ARCH CREEK	Hybrid	2,898	9	42	6	4.3	0.2	4.1	3.7	8.4	3.9	12.3	315	77,154	Yes	-0.28	6.52	40

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY-pk Prior)	Peak Load (MVA)	Number of N on FDR
802236	GLADEVIEW	Hybrid	3,173	63	11	2	5.7	0.3	9.7	1.0	15.4	1.3	16.7	457	69,245	Yes	-0.27	9.33	44
808837	SNAPPER CREEK	Hybrid	520	36	9	2	2.7	2.5	6.3	5.0	9.0	7.5	16.5	768	109,046	Yes	-0.56	5.94	54
800432	COCONUT GROVE	Hybrid	1,425	13	19	4	2.0	0.7	2.4	0.6	4.4	1.3	5.7	1,423	46,279	Yes	0.39	6.49	16
807162	PENNSUCO	Hybrid	577	5	44	1	4.1	0.8	0.7	7.6	4.8	8.4	13.2	514	40,383	Yes	0.70	10.60	19
404632	PLATT	Hybrid	159	29	2	4	8.2	0.1	14.6	1.9	22.8	2.0	24.8	20	4,971	Yes	0.05	0.85	12
804938	OJUS	UG	37	0	6	0	-	3.9	-	1.8	-	5.7	5.7	1	85	Yes	0.09	3.39	1
411033	EDEN	Hybrid	2,622	3	48	2	3.8	2.0	4.0	19.5	7.8	21.5	29.3	122	17,910	Yes	-0.10	8.00	17
807632	KILLIAN	Hybrid	1,232	5	25	3	3.3	0.2	3.1	14.4	6.4	14.6	21.0	1,001	73,445	Yes	-0.11	7.79	47
406932	DELMAR	UG	1,383	0	19	0	0.6	1.6	-	10.3	0.6	11.9	12.5	8	1,460	Yes	-0.28	5.52	6
109033	WRIGHT	UG	1	0	4	0	-	2.6	-	-	-	2.6	2.6	-	-	Yes	-0.03	4.27	0
800852	RAILWAY	UG	242	0	4	1	-	4.8	-	0.6	-	5.4	5.4	-	-	Yes	-0.14	4.96	0
702134	CYPRESS CREEK	Hybrid	191	1	30	2	1.8	1.0	0.2	1.8	2.0	2.8	4.8	329	28,396	Yes	0.06	6.66	6
804137	GARDEN	Hybrid	834	4	7	2	1.1	0.7	3.0	2.3	4.1	3.0	7.1	351	45,445	Yes	0.20	3.90	29
508261	RYE	Hybrid	3,099	26	57	4	7.0	2.3	10.0	37.3	17.0	39.6	56.6	450	72,426	Yes	-0.02	14.28	29
703435	RESERVATION	Hybrid	2,075	27	33	7	4.7	0.9	6.8	7.6	11.5	8.5	20.0	1,668	83,750	Yes	-0.32	7.98	32
301463	YULEE	Hybrid	1,470	37	13	10	7.2	0.8	14.2	8.1	21.4	8.9	30.3	67	9,781	Yes	-4.01	7.69	18
703633	PALM AIRE	Hybrid	330	0	36	1	2.2	0.3	0.7	4.3	2.9	4.6	7.5	108	12,467	Yes	0.05	5.55	15
502203	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-3.62	6.48	0
208865	WINDOVER	Hybrid	2,144	25	40	11	4.4	0.5	5.7	14.9	10.1	15.4	25.5	3,971	80,877	Yes	11.51	11.51	15
707862	PARKLAND	UG	1,759	0	51	0	0.4	10.1	-	32.1	0.4	42.2	42.6	59	10,415	Yes	1.22	14.52	4
800105	MIAMI	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	2.06	2.06	0
807232	MERCHANDISE	Hybrid	150	1	20	0	1.4	1.9	-	1.8	1.4	3.7	5.1	2	601	Yes	1.08	3.98	2
400333	NORTHWOOD	Hybrid	476	10	10	3	2.7	0.2	2.2	0.9	4.9	1.1	6.0	35	4,664	Yes	-0.66	2.74	15
706862	CONSERVATION	Hybrid	957	1	41	2	3.2	1.2	0.4	3.6	3.6	4.8	8.4	74	26,409	Yes	0.19	4.79	6
401534	FT PIERCE	Hybrid	1,049	30	3	4	7.5	1.0	20.9	2.0	28.4	3.0	31.4	257	49,824	Yes	0.02	4.22	22
413636	BONANZA	Hybrid	15	1	12	0	1.1	0.1	-	1.4	1.1	1.5	2.6	-	-	Yes	-0.10	4.50	0
406064	SHERMAN	Hybrid	793	61	20	6	32.4	2.2	58.9	11.8	91.3	14.0	105.3	3,752	167,690	Yes	-0.83	4.97	71
702131	CYPRESS CREEK	Hybrid	2,147	3	23	1	2.8	0.2	0.5	5.8	3.3	6.0	9.3	1,288	11,242	Yes	-0.13	6.87	3
301461	YULEE	Hybrid	1,930	21	47	9	6.5	1.9	9.5	14.2	16.0	16.1	32.1	399	31,089	Yes	-0.27	8.13	38
702635	ELY	Hybrid	1,421	10	14	3	3.1	0.5	7.9	2.5	11.0	3.0	14.0	625	86,456	Yes	-0.21	6.89	42
809933	SIMPSON	UG	932	0	9	0	-	3.7	-	0.3	-	4.0	4.0	1	228	Yes	-0.07	5.13	1
401631	OKEECHOBEE	Hybrid	1,803	34	12	8	8.6	0.1	10.4	8.2	19.0	8.3	27.3	4,478	87,925	Yes	-0.83	3.67	29
405939	BUTTS	Hybrid	1,791	1	24	0	1.3	2.7	-	15.2	1.3	17.9	19.2	54	8,506	Yes	0.10	6.40	13
704940	LAKEVIEW	Hybrid	2,536	5	52	1	3.9	1.8	1.5	12.9	5.4	14.7	20.1	278	26,580	Yes	-0.29	10.21	23
701436	PORT	Hybrid	405	10	11	6	1.8	1.2	2.5	1.6	4.3	2.8	7.1	39	10,313	Yes	0.23	3.43	5
700335	PINEHURST	Hybrid	2,070	22	10	6	3.6	0.9	5.0	1.2	8.6	2.1	10.7	3,989	287,692	Yes	0.19	6.49	54
809661	COURT	Hybrid	2,462	0	41	2	2.4	2.5	0.2	15.6	2.6	18.1	20.7	852	86,370	Yes	-1.39	10.11	21
704464	FASHION	Hybrid	3,237	11	31	7	2.1	4.1	2.6	2.8	4.7	6.9	11.6	1,453	96,071	Yes	-0.85	7.85	31
406536	OSBORNE	Hybrid	2,100	14	37	5	3.8	0.4	3.4	15.3	7.2	15.7	22.9	3,427	154,044	Yes	-0.07	8.53	26
700540	POMPANO	Hybrid	2,118	3	11	0	1.3	2.9	0.3	9.3	1.6	12.2	13.8	281	63,142	Yes	0.16	4.76	11
400731	BOCA RATON	Hybrid	1,260	10	27	1	1.4	2.4	1.3	2.6	2.7	5.0	7.7	2,336	53,550	Yes	-0.11	5.99	11
500832	WHITFIELD	Hybrid	205	2	42	1	3.0	0.5	2.6	4.9	5.6	5.4	11.0	3	631	Yes	0.54	8.54	2
804441	VENETIAN	UG	318	1	13	0	0.1	2.8	-	1.1	0.1	3.9	4.0	1	45	Yes	-0.38	3.22	1
504667	CASTLE	Hybrid	1,098	10	31	2	4.9	1.1	4.3	6.4	9.2	7.5	16.7	11	2,310	Yes	-0.14	4.56	5
807033	ROSELAWN	Hybrid	1,379	5	18	3	1.8	0.3	1.8	3.0	3.6	3.3	6.9	2,271	42,857	Yes	-0.18	4.92	16
703737	CRYSTAL	UG	-	0	0	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	-0.01	0.69	0
706065	HIATUS	UG	140	0	3	0	-	3.0	-	0.1	-	3.1	3.1	-	-	Yes	0.02	2.72	0
500631	CORTEZ	Hybrid	1,940	8	28	2	2.7	0.4	2.9	11.7	5.6	12.1	17.7	112	15,571	Yes	-0.03	5.27	21
403732	MONET	UG	1,042	0	29	0	0.5	4.2	0.2	13.5	0.7	17.7	18.4	461	77,818	Yes	-0.16	7.14	13
507265	SAN CARLOS	Hybrid	2,433	19	38	8	6.1	0.5	9.1	12.6	15.2	13.1	28.3	4,137	185,136	Yes	0.02	9.62	32
810731	MCGREGOR	Hybrid	17	0	7	1	1.2	0.3	0.3	0.8	1.5	1.1	2.6	-	-	Yes	-0.42	1.98	0
401932	LINTON	Hybrid	1,489	5	19	6	1.4	0.8	2.9	1.9	4.3	2.7	7.0	1,468	89,498	Yes	0.32	6.12	31

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
500233	BRADENTON	Hybrid	940	18	15	8	3.9	1.6	5.3	1.6	9.2	3.2	12.4	74	8,873	Yes	-0.60	6.00	17
400436	HILLCREST	Hybrid	788	19	2	3	1.8	0.8	3.5	0.2	5.3	1.0	6.3	2,312	74,244	Yes	-3.91	3.79	24
410462	GATLIN	Hybrid	2,222	37	7	4	4.7	0.9	28.8	2.1	33.5	3.0	36.5	2,030	97,506	Yes	-0.21	10.29	39
211061	GARVEY	Hybrid	2,940	117	9	5	10.5	0.1	56.9	5.9	67.4	6.0	73.4	1,340	196,336	Yes	-1.82	11.18	125
405331	BEELINE	Hybrid	1,616	2	29	2	8.2	3.5	1.4	21.0	9.6	24.5	34.1	829	16,783	Yes	-0.53	7.47	11
803438	MIAMI SHORES	Hybrid	1,097	28	6	4	3.1	0.7	7.3	0.4	10.4	1.1	11.5	2,131	91,030	Yes	-0.25	6.65	78
811937	OVERTOWN	UG	1,173	0	6	0	-	2.5	-	0.8	-	3.3	3.3	11	714	Yes	0.89	6.19	3
203036	FRONTENAC	Hybrid	1	0	1	0	0.1	0.7	-	-	0.1	0.7	0.8	-	-	Yes	0.03	0.23	0
705464	PHOENIX	Hybrid	3,535	0	51	0	3.3	0.7	-	15.5	3.3	16.2	19.5	4,769	123,430	Yes	-0.11	8.99	28
506763	VANDERBILT	Hybrid	2,960	2	43	4	5.6	3.4	9.8	23.2	15.4	26.6	42.0	2,214	74,831	Yes	-0.11	11.29	18
501231	NAPLES	Hybrid	414	6	17	2	1.5	0.9	2.2	3.3	3.7	4.2	7.9	27	5,689	Yes	-0.35	4.85	7
800232	MIAMI BEACH	Hybrid	2,081	1	16	2	1.4	1.8	0.2	1.8	1.6	3.6	5.2	257	41,317	Yes	0.43	6.53	8
809532	VIRGINIA KEY	UG	-	0	0	0	-	0.1	-	0.1	-	0.2	0.2	-	-	Yes	1.43	4.33	0
102436	FLEMING	Hybrid	1,178	10	5	3	1.5	3.5	4.4	1.8	5.9	5.3	11.2	304	49,077	Yes	0.20	4.30	29
402532	BELVEDERE	Hybrid	908	25	8	5	2.5	8.7	7.7	2.5	10.2	11.2	21.4	271	40,709	Yes	-0.14	4.96	36
703034	ROHAN	Hybrid	1,231	31	4	1	3.0	0.2	8.0	1.3	11.0	1.5	12.5	383	46,543	Yes	0.07	5.27	51
414331	COBIA	Hybrid	999	1	21	1	1.3	0.1	0.2	4.9	1.5	5.0	6.5	245	66,792	Yes	-0.41	2.49	8
805834	CORAL REEF	Hybrid	1,309	5	32	1	2.5	0.4	1.1	11.9	3.6	12.3	15.9	2,836	102,520	Yes	-0.12	6.78	34
500232	BRADENTON	Hybrid	1,893	23	19	4	3.1	1.7	6.0	4.1	9.1	5.8	14.9	447	64,338	Yes	0.60	5.80	23
403437	JENSEN	Hybrid	282	1	25	0	1.5	0.4	1.3	4.5	2.8	4.9	7.7	43	14,903	Yes	-0.20	4.50	7
507764	RATTLESNAKE	Hybrid	4,079	0	35	2	5.4	3.6	1.3	24.3	6.7	27.9	34.6	4,607	152,921	Yes	1.92	10.72	18
804443	VENETIAN	UG	630	0	12	0	-	2.0	-	1.0	-	3.0	3.0	1	2	Yes	0.11	3.81	1
705866	REMSBURG	UG	2,077	0	57	0	0.2	7.7	-	30.8	0.2	38.5	38.7	2,238	60,834	Yes	-0.59	15.51	11
813532	JACKSON	Hybrid	1,379	11	15	1	3.2	0.7	1.9	1.0	5.1	1.7	6.8	76	9,211	Yes	0.65	8.05	11
402236	PRATT & WHITNEY	OH	-	0	0	0	6.2	-	-	-	6.2	-	6.2	-	-	Yes	0.37	3.77	0
705237	TIMBERLAKE	Hybrid	2,104	9	32	5	3.3	1.7	4.0	11.4	7.3	13.1	20.4	836	40,826	Yes	-0.10	8.40	24
505662	ROTONDA	Hybrid	2,753	28	14	11	5.0	0.4	21.1	9.5	26.1	9.9	36.0	3,747	198,495	Yes	-1.42	10.88	65
404936	PORT SEWALL	Hybrid	1,753	44	30	5	6.2	0.1	10.3	4.1	16.5	4.2	20.7	1,694	92,971	Yes	-0.45	7.15	27
106533	REED	Hybrid	1,165	16	15	7	2.8	0.7	6.1	4.5	8.9	5.2	14.1	527	50,784	Yes	1.07	4.87	32
810862	MONTGOMERY	Hybrid	2,829	2	38	2	2.9	2.7	2.6	25.1	5.5	27.8	33.3	4,877	130,146	Yes	-0.13	13.47	47
800637	LITTLE RIVER	Hybrid	2,566	26	16	4	3.6	2.2	3.2	1.4	6.8	3.6	10.4	2,997	325,839	Yes	0.27	8.07	36
402931	OSLO	Hybrid	1,357	29	26	3	4.2	-	10.3	6.0	14.5	6.0	20.5	1,836	115,910	Yes	-0.27	6.23	46
505063	JETPORT	Hybrid	2,836	51	23	3	9.8	0.3	19.0	13.0	28.8	13.3	42.1	1,074	60,494	Yes	-1.70	10.40	21
506365	DEEPCREEK	Hybrid	2,764	39	13	5	7.8	0.8	37.7	3.3	45.5	4.1	49.6	802	82,583	Yes	0.03	9.43	53
811364	ANHINGA	Hybrid	2,341	31	34	7	7.4	1.8	9.6	7.0	17.0	8.8	25.8	558	103,801	Yes	1.47	8.47	47
207862	OSTEEN	Hybrid	2,410	58	15	6	8.6	0.4	33.4	8.4	42.0	8.8	50.8	416	70,282	Yes	-0.22	11.18	44
205633	SARNO	Hybrid	1,003	2	15	2	2.0	0.2	2.0	8.2	4.0	8.4	12.4	159	19,477	Yes	-3.58	4.32	15
804332	KENDALL	Hybrid	861	15	20	4	3.2	0.5	6.3	2.6	9.5	3.1	12.6	201	53,258	Yes	-0.89	5.81	41
506761	VANDERBILT	Hybrid	4,061	0	66	2	5.3	4.2	0.8	43.7	6.1	47.9	54.0	3,795	296,635	Yes	0.26	15.96	20
502538	PALMA SOLA	Hybrid	1,263	21	28	6	3.6	0.6	7.9	3.6	11.5	4.2	15.7	202	39,007	Yes	0.10	6.80	17
806339	ULETA	Hybrid	961	11	28	7	3.6	0.3	2.6	2.2	6.2	2.5	8.7	414	60,588	Yes	-0.55	6.95	26
802732	MARION	Hybrid	1,560	1	29	0	1.6	1.5	0.6	7.6	2.2	9.1	11.3	1,022	70,064	Yes	-0.42	6.68	10
503264	COCOPLUM	Hybrid	3,220	41	37	4	8.9	0.2	51.0	12.2	59.9	12.4	72.3	857	78,333	Yes	0.16	13.66	51
502632	COLONIAL	Hybrid	1,999	5	34	5	2.7	0.1	3.2	7.7	5.9	7.8	13.7	382	28,914	Yes	-0.49	8.21	22
503433	SOUTH VENICE	Hybrid	1,820	22	10	2	3.7	0.1	7.9	5.8	11.6	5.9	17.5	1,596	61,833	Yes	-0.02	5.78	48
403434	JENSEN	Hybrid	1,812	21	29	7	5.5	0.3	10.7	4.0	16.2	4.3	20.5	711	90,439	Yes	0.27	8.37	57
505861	BUCKEY	Hybrid	81	3	18	0	1.3	4.1	0.2	2.3	1.5	6.4	7.9	33	3,895	Yes	0.03	3.93	2
810261	INTERNATIONAL	Hybrid	77	0	34	0	1.0	4.8	-	6.0	1.0	10.8	11.8	233	13,343	Yes	-0.09	5.21	4
700538	POMPANO	Hybrid	18	1	2	0	0.8	0.6	0.2	0.1	1.0	0.7	1.7	2	380	Yes	0.02	2.62	2
400531	BOYNTON	Hybrid	1,420	6	22	1	2.8	0.1	3.2	5.8	6.0	5.9	11.9	326	54,823	Yes	-0.06	4.64	17
701236	PLAYLAND	Hybrid	131	2	5	0	0.6	2.9	0.1	0.4	0.7	3.3	4.0	-	-	Yes	2.21	2.91	0
410663	RYDER	Hybrid	1,545	3	42	0	1.1	7.3	0.7	19.1	1.8	26.4	28.2	248	32,507	Yes	-0.31	8.49	13

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY-pk Prior)	Peak Load (MVA)	Number of N on FDR
806737	IVES	Hybrid	958	15	15	3	2.8	0.4	4.1	1.1	6.9	1.5	8.4	1,679	112,111	Yes	-0.20	5.00	71
505361	PARK	Hybrid	869	0	20	0	1.3	1.9	-	10.0	1.3	11.9	13.2	169	43,827	Yes	-1.01	11.79	8
403736	MONET	Hybrid	1,136	12	24	6	3.4	1.7	2.9	7.6	6.3	9.3	15.6	228	22,338	Yes	-0.04	6.76	19
401132	STUART	Hybrid	1,566	31	27	4	5.4	0.8	7.0	15.3	12.4	16.1	28.5	2,501	27,427	Yes	-0.40	6.80	22
805240	NATOMA	Hybrid	1,299	2	8	0	0.2	3.2	1.4	1.1	1.6	4.3	5.9	315	46,226	Yes	-0.12	3.98	8
409766	CATCHMENT	Hybrid	2,848	29	61	8	7.4	4.7	5.1	18.5	12.5	23.2	35.7	458	66,187	Yes	-0.86	11.94	22
201433	GRANDVIEW	Hybrid	1,215	14	14	10	3.0	0.9	5.9	6.2	8.9	7.1	16.0	552	87,754	Yes	0.09	6.29	28
700531	POMPANO	Hybrid	711	2	15	4	2.4	0.9	2.1	3.7	4.5	4.6	9.1	96	25,015	Yes	-0.46	5.34	15
807533	DADELAND	UG	81	0	7	0	-	1.6	-	0.1	-	1.7	1.7	-	-	Yes	0.12	2.92	0
408036	CALDWELL	Hybrid	1,397	10	19	4	3.1	0.3	4.3	1.6	7.4	1.9	9.3	417	59,369	Yes	-0.12	5.88	36
100133	DAYTONA BEACH	Hybrid	596	14	11	0	1.9	1.6	1.9	1.9	3.8	3.5	7.3	925	9,391	Yes	-0.03	3.17	10
402539	BELVEDERE	Hybrid	454	1	20	2	1.0	3.0	0.5	2.5	1.5	5.5	7.0	13	1,170	Yes	0.12	4.82	2
100431	PALATKA	OH	937	36	3	3	4.2	-	10.9	0.3	15.1	0.3	15.4	892	24,827	Yes	-0.19	3.61	33
804234	PERRINE	Hybrid	1,710	2	29	1	1.9	0.5	0.6	5.2	2.5	5.7	8.2	1,643	9,780	Yes	-0.13	5.27	9
109031	WRIGHT	Hybrid	2,201	46	11	4	4.5	0.8	13.3	3.8	17.8	4.6	22.4	505	89,079	Yes	0.06	7.86	54
705637	COPANS	Hybrid	849	4	22	4	1.8	1.4	1.0	2.3	2.8	3.7	6.5	145	10,949	Yes	-0.16	4.44	6
504431	CLEVELAND	Hybrid	1,496	55	11	17	12.2	0.6	65.8	8.9	78.0	9.5	87.5	75	11,176	Yes	-0.06	6.24	36
809031	AVENTURA	Hybrid	861	5	21	0	0.9	1.2	0.5	6.1	1.4	7.3	8.7	878	3,965	Yes	-0.85	7.75	5
506037	WALKER	Hybrid	1,823	20	14	6	3.4	0.8	7.4	4.3	10.8	5.1	15.9	473	53,112	Yes	-1.20	6.00	33
414031	GRACEWOOD	Hybrid	1,389	2	57	1	2.1	2.2	0.4	20.2	2.5	22.4	24.9	392	47,186	Yes	-0.62	5.08	15
705636	COPANS	Hybrid	2,454	2	31	0	1.9	1.1	0.7	10.5	2.6	11.6	14.2	214	34,340	Yes	-0.05	6.85	13
405039	SANDALFOOT	Hybrid	1,763	2	35	1	2.7	2.3	0.9	16.0	3.6	18.3	21.9	288	37,813	Yes	0.12	6.52	10
504131	BENEVA	Hybrid	1,735	11	38	4	2.4	-	4.3	6.2	6.7	6.2	12.9	958	80,993	Yes	-0.30	7.00	14
805532	MASTER	Hybrid	1,254	18	18	0	2.1	0.7	7.9	1.1	10.0	1.8	11.8	2,215	177,749	Yes	-0.09	8.41	55
403036	MILITARY TRAIL	Hybrid	863	18	16	2	1.9	0.5	5.2	3.8	7.1	4.3	11.4	1,048	69,695	Yes	-0.17	3.73	31
802638	AIRPORT	UG	3	0	4	0	-	4.7	-	0.1	-	4.8	4.8	-	-	Yes	0.23	2.23	0
801137	FRONTON	UG	1	0	0	0	-	2.8	-	-	-	2.8	2.8	-	-	Yes	0.08	1.48	0
702431	PEMBROKE	Hybrid	1,888	27	8	3	3.1	-	6.8	1.8	9.9	1.8	11.7	240	37,883	Yes	-0.18	6.12	23
813239	KNOWLTON	UG	2	0	2	0	-	2.0	-	0.2	-	2.2	2.2	2	32	Yes	0.46	2.56	1
305232	PRICE	Hybrid	520	42	9	11	17.1	0.9	24.2	6.2	41.3	7.1	48.4	598	80,130	Yes	-0.78	7.02	16
806233	INDIAN CREEK	UG	1,358	0	10	0	-	2.1	-	0.9	-	3.0	3.0	416	567,634	Yes	0.85	4.85	4
401133	STUART	Hybrid	1,194	20	17	7	2.9	0.1	4.5	2.0	7.4	2.1	9.5	967	76,237	Yes	-0.24	5.46	16
402262	PRATT & WHITNEY	Hybrid	47	3	6	2	6.7	3.3	1.4	2.1	8.1	5.4	13.5	-	-	Yes	0.04	1.44	0
812832	WILCOX	UG	13	0	5	0	-	2.9	-	0.8	-	3.7	3.7	-	-	Yes	-0.29	3.11	0
503632	EDISON	Hybrid	1,793	7	41	3	2.6	0.4	2.6	10.5	5.2	10.9	16.1	157	17,134	Yes	-0.04	4.46	25
505765	AUBURN	Hybrid	3,348	22	69	5	6.4	2.4	10.2	21.4	16.6	23.8	40.4	629	64,781	Yes	-0.31	11.09	48
410465	GATLIN	Hybrid	2,478	34	18	1	4.6	1.2	24.7	5.5	29.3	6.7	36.0	1,040	116,195	Yes	-8.82	10.38	66
407935	QUANTUM	Hybrid	2,408	1	48	0	3.8	1.4	0.2	18.9	4.0	20.3	24.3	383	39,013	Yes	0.23	8.33	18
701164	LYONS	Hybrid	1,360	7	17	1	1.1	3.2	1.2	1.1	2.3	4.3	6.6	179	23,722	Yes	-0.06	3.64	10
201232	TROPICANA	Hybrid	1,738	9	30	10	2.7	1.0	3.4	6.6	6.1	7.6	13.7	3,413	108,542	Yes	0.27	7.97	21
808264	LINDGREN	Hybrid	3,784	0	42	0	1.5	3.0	-	21.5	1.5	24.5	26.0	401	81,097	Yes	-0.78	13.22	24
809339	RONEY	Hybrid	1,471	10	12	5	2.1	0.3	1.5	2.1	3.6	2.4	6.0	1,362	106,780	Yes	0.64	6.74	34
404935	PORT SEWALL	Hybrid	1,554	11	24	1	4.3	0.1	2.7	6.7	7.0	6.8	13.8	94	15,365	Yes	0.03	4.63	16
806842	RED ROAD	Hybrid	633	8	28	0	4.0	1.1	1.3	4.7	5.3	5.8	11.1	2,730	148,430	Yes	0.27	6.27	26
201136	PATRICK	Hybrid	1,470	9	15	5	2.6	0.9	6.3	7.1	8.9	8.0	16.9	158	42,936	Yes	-0.25	4.55	23
707033	SHERIDAN	Hybrid	1,122	7	24	2	3.6	0.6	1.3	6.3	4.9	6.9	11.8	1,148	69,577	Yes	-0.79	6.61	20
202831	CLEARLAKE	Hybrid	2,020	27	9	8	3.3	0.1	14.4	2.9	17.7	3.0	20.7	321	82,966	Yes	-0.50	7.70	36
705763	TRACE	UG	1,516	0	30	0	-	6.3	-	27.0	-	33.3	33.3	162	34,184	Yes	0.03	10.43	8
503567	ALLIGATOR	Hybrid	3,552	0	34	3	3.7	1.6	1.2	19.0	4.9	20.6	25.5	221	36,482	Yes	-0.07	6.93	9
505162	PROCTOR	Hybrid	1,377	3	45	2	3.6	1.0	1.8	24.7	5.4	25.7	31.1	176	23,717	Yes	-9.08	7.72	13
205536	DAIRY	Hybrid	1,053	1	18	1	1.5	0.9	0.1	8.5	1.6	9.4	11.0	63	10,126	Yes	3.68	3.88	8
501432	ARCADIA	Hybrid	2,602	64	21	18	14.6	0.2	75.1	13.2	89.7	13.4	103.1	7,241	302,343	Yes	0.14	7.74	53

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
105831	ELKTON	Hybrid	1,445	26	18	0	8.4	2.4	9.8	15.8	18.2	18.2	36.4	3,557	74,629	Yes	-0.34	5.26	26
100235	ST AUGUSTINE	Hybrid	1,788	39	15	6	4.1	2.8	10.0	2.7	14.1	5.5	19.6	375	32,241	Yes	-0.21	7.59	31
410364	MARLIN	UG	3,490	4	67	1	0.8	11.4	0.4	47.4	1.2	58.8	60.0	3,427	43,552	Yes	-1.28	16.12	8
804531	GRATIGNY	Hybrid	1,480	15	9	2	4.2	0.2	5.6	1.1	9.8	1.3	11.1	2,839	187,842	Yes	0.72	7.22	45
703734	CRYSTAL	Hybrid	1,198	3	37	2	3.8	0.3	0.4	9.6	4.2	9.9	14.1	2,475	163,968	Yes	-0.36	6.84	9
700539	POMPANO	Hybrid	206	4	12	2	1.8	0.6	0.5	1.9	2.3	2.5	4.8	6	292	Yes	0.14	1.94	4
811361	ANHINGA	Hybrid	1,172	57	20	8	11.8	0.1	28.2	10.8	40.0	10.9	50.9	262	77,251	Yes	0.11	7.51	70
500434	HYDE PARK	Hybrid	1,078	22	12	4	2.1	0.9	8.0	2.1	10.1	3.0	13.1	255	39,222	Yes	-0.04	5.56	46
810264	INTERNATIONAL	Hybrid	2,214	5	41	5	3.6	2.7	3.5	13.6	7.1	16.3	23.4	1,145	161,532	Yes	-0.49	10.81	30
500337	VENICE	Hybrid	2,167	15	50	4	5.5	0.6	6.1	15.6	11.6	16.2	27.8	2,772	68,190	Yes	-1.19	5.72	39
802139	MIRAMAR	UG	-	0	0	0	-	2.1	-	-	-	2.1	2.1	-	-	Yes	-0.53	5.07	0
207261	CHULUOTA	Hybrid	1,213	43	24	8	10.2	0.1	29.8	19.0	40.0	19.1	59.1	1,965	130,273	Yes	-0.20	6.70	50
402134	TERMINAL	Hybrid	1,534	23	9	6	3.0	0.3	4.6	1.1	7.6	14	9.0	144	23,879	Yes	-0.12	5.48	29
805334	KEY BISCAWAYNE	Hybrid	864	5	15	0	0.6	2.5	0.5	1.2	1.1	3.7	4.8	113	15,051	Yes	-0.14	3.86	9
703639	PALM AIRE	Hybrid	521	7	33	3	3.2	1.9	1.9	2.8	5.1	4.7	9.8	2	386	Yes	0.48	6.88	2
702261	MARGATE	Hybrid	1,463	0	42	0	2.3	1.1	-	9.1	2.3	10.2	12.5	843	46,592	Yes	-0.41	7.09	8
700431	OAKLAND PARK	Hybrid	2,149	13	27	6	3.5	0.4	4.6	2.8	8.1	3.2	11.3	3,201	78,883	Yes	0.01	7.81	15
708062	WINDMILL	UG	1,741	0	27	0	-	5.9	-	24.1	-	30.0	30.0	3,609	214,870	Yes	-0.77	12.43	16
400661	WABASSO	Hybrid	1,213	69	12	2	8.5	1.1	26.8	6.1	34.3	7.2	41.5	690	60,741	Yes	-0.23	5.67	38
409363	SWEATT	Hybrid	450	41	16	4	23.1	2.5	46.4	4.8	69.5	7.3	76.8	94	14,336	Yes	-0.31	5.59	27
805735	GALLOWAY	Hybrid	1,189	21	11	4	2.8	0.3	9.3	1.3	12.1	1.6	13.7	307	103,011	Yes	-0.19	8.41	32
207361	WYOMING	OH	1,826	214	5	6	22.8	0.2	82.4	3.9	105.2	4.1	109.3	2,027	95,594	Yes	-0.43	7.27	71
805237	NATOMA	Hybrid	1,234	9	11	1	0.9	3.3	1.3	2.7	2.2	6.0	8.2	227	22,168	Yes	-2.92	5.98	20
500835	WHITFIELD	Hybrid	284	0	49	2	2.1	0.6	0.7	2.2	2.8	2.8	5.6	309	6,655	Yes	0.16	4.56	13
700935	HALLANDALE	UG	1,172	0	4	0	-	1.2	-	2.4	-	3.6	3.6	242	14,074	Yes	-0.26	2.04	4
700433	OAKLAND PARK	Hybrid	1,962	23	13	3	2.4	0.4	7.2	1.4	9.6	1.8	11.4	2,775	209,834	Yes	0.31	6.51	64
800246	MIAMI BEACH	Hybrid	548	6	18	3	1.4	3.3	1.1	2.1	2.5	5.4	7.9	2,430	85,396	Yes	0.01	4.31	22
102636	LEWIS	Hybrid	878	27	11	5	3.0	0.5	4.5	0.8	7.5	1.3	8.8	233	16,114	Yes	0.09	4.89	18
106364	REGIS	Hybrid	3,744	39	11	2	9.5	0.5	41.2	3.4	50.7	3.9	54.6	1,652	176,332	Yes	-0.03	14.87	33
804837	COUNTY LINE	Hybrid	589	6	0	1	0.5	1.8	4.9	1.3	5.4	3.1	8.5	1,035	60,738	Yes	-0.03	2.77	32
101533	GENERAL ELECTRIC	UG	22	0	1	0	-	1.4	-	0.2	-	1.6	1.6	-	-	Yes	-0.11	1.29	0
704935	LAKEVIEW	UG	-	0	1	0	-	4.4	-	-	-	4.4	4.4	-	-	Yes	0.21	1.11	0
804736	HAULOVER	UG	1,230	0	5	0	-	2.1	-	1.2	-	3.3	3.3	-	-	Yes	-0.07	3.73	0
407236	JOG	Hybrid	1,547	3	29	3	5.8	2.2	4.1	10.6	9.9	12.8	22.7	29	2,997	Yes	-0.26	6.44	10
307562	HAMPTON	Hybrid	225	29	2	3	5.3	0.5	7.1	0.6	12.4	1.1	13.5	180	6,049	Yes	-0.29	1.61	6
802631	AIRPORT	Hybrid	1,645	11	32	3	4.9	1.7	1.9	2.4	6.8	4.1	10.9	154	48,455	Yes	-0.39	6.51	25
406867	KIMBERLY	Hybrid	2,741	1	27	1	2.5	1.7	0.2	18.3	2.7	20.0	22.7	152	12,262	Yes	-1.66	5.84	9
309332	WELLBORN	Hybrid	207	30	2	2	10.1	1.8	10.2	1.6	20.3	3.4	23.7	24	7,088	Yes	-0.08	0.72	9
201132	PATRICK	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.61	5.81	0
809665	COURT	Hybrid	3,033	0	39	5	2.1	2.7	1.2	20.3	3.3	23.0	26.3	5,710	213,063	Yes	-0.52	15.18	38
408463	ADAMS	Hybrid	442	66	9	13	52.3	6.1	128.4	6.1	180.7	12.2	192.9	1,941	226,142	Yes	-1.70	2.10	92
403731	MONET	Hybrid	599	0	29	0	1.4	1.0	-	4.8	1.4	5.8	7.2	10	1,257	Yes	0.05	6.95	3
801633	PRINCETON	Hybrid	2,576	17	41	2	3.4	0.7	4.8	12.2	8.2	12.9	21.1	240	52,954	Yes	-0.06	8.34	23
803032	TROPICAL	Hybrid	745	9	23	2	3.3	0.1	2.5	1.7	5.8	1.8	7.6	1,541	84,921	Yes	0.18	9.08	19
408669	HOMELAND	Hybrid	555	14	15	11	6.6	2.5	20.9	15.0	27.5	17.5	45.0	813	70,130	Yes	-0.39	2.91	41
401934	LINTON	Hybrid	1,498	17	39	2	3.4	0.6	2.8	3.8	6.2	4.4	10.6	2,121	36,771	Yes	0.44	7.64	21
408167	ROSS	UG	6	0	7	0	-	1.2	-	0.3	-	1.5	1.5	1	412	Yes	-0.19	5.41	1
406236	OAKES	Hybrid	1,415	10	38	1	3.3	1.9	1.5	10.8	4.8	12.7	17.5	155	10,319	Yes	-0.47	7.73	9
203932	MCDONNELL	Hybrid	2	0	0	0	0.3	0.5	-	-	0.3	0.5	0.8	-	-	Yes	-0.01	1.69	0
702238	MARGATE	Hybrid	2,142	0	39	0	3.1	0.8	-	11.2	3.1	12.0	15.1	1,472	28,270	Yes	-0.12	7.18	8
307561	HAMPTON	OH	1,279	87	6	8	11.7	0.6	36.4	1.7	48.1	2.3	50.4	377	46,054	Yes	-0.31	4.69	46
803534	MARKET	UG	5	0	4	0	-	2.5	-	0.3	-	2.8	2.8	1	295	Yes	-1.22	2.88	1

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
702639	ELY	Hybrid	1,091	16	15	3	2.9	0.3	3.8	1.5	6.7	1.8	8.5	98	18,071	Yes	-0.17	4.63	20
501136	FT MYERS	Hybrid	1,798	29	22	9	5.6	0.5	10.3	2.3	15.9	2.8	18.7	235	29,858	Yes	0.06	6.36	24
104933	MOULTRIE	Hybrid	2,593	3	26	5	2.2	2.4	3.6	13.6	5.8	16.0	21.8	3,294	210,805	Yes	-0.38	7.32	31
401834	JUPITER	Hybrid	2,209	23	42	1	5.4	4.5	4.7	24.3	10.1	28.8	38.9	7,058	187,977	Yes	-0.42	10.38	30
805231	NATOMA	Hybrid	431	4	5	2	1.3	0.2	0.4	0.5	1.7	0.7	2.4	288	1,817	Yes	0.05	2.35	2
702240	MARGATE	Hybrid	2,272	0	30	0	1.5	2.7	-	12.9	1.5	15.6	17.1	197	38,570	Yes	-0.34	7.76	15
407037	RIO	Hybrid	977	24	20	6	3.9	1.8	6.3	5.0	10.2	6.8	17.0	189	20,671	Yes	-0.33	3.57	32
811939	OVERTOWN	UG	-	0	0	0	-	2.0	-	-	-	2.0	2.0	-	-	Yes	0.04	3.14	0
404840	GERMANTOWN	Hybrid	2,035	9	19	0	2.1	0.9	3.1	7.4	5.2	8.3	13.5	1,350	34,589	Yes	0.13	5.93	15
407667	LOXAHATCHEE	Hybrid	2,554	7	46	1	4.4	1.2	3.7	26.3	8.1	27.5	35.6	468	65,857	Yes	-0.84	14.86	33
203633	HARRIS	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.52	1.22	0
401433	WHITE CITY	Hybrid	1,948	32	19	1	7.4	0.5	13.0	5.8	20.4	6.3	26.7	960	96,779	Yes	0.12	7.32	37
813137	FIREHOUSE	UG	735	0	5	0	-	3.4	-	-	1.3	-	4.7	4.7	-	Yes	2.62	6.92	0
504761	ALVA	Hybrid	2,109	108	36	32	27.1	4.0	66.3	33.9	93.4	37.9	131.3	2,925	331,489	Yes	-0.23	8.57	107
506666	LIVINGSTON	Hybrid	1,550	11	31	15	3.7	0.8	6.5	3.3	10.2	4.1	14.3	1,710	19,710	Yes	0.71	13.41	24
506667	LIVINGSTON	Hybrid	1,796	0	29	2	1.7	2.2	1.2	21.6	2.9	23.8	26.7	193	29,951	Yes	-0.72	8.58	11
100332	HASTINGS	OH	540	43	1	5	8.6	-	27.5	0.5	36.1	0.5	36.6	1,297	110,591	Yes	-0.09	1.71	43
806336	ULETA	Hybrid	2,337	20	10	2	2.1	3.0	4.5	2.6	6.6	5.6	12.2	277	43,555	Yes	-0.62	7.48	24
802133	MIRAMAR	Hybrid	1,487	9	22	0	3.5	0.4	1.1	3.8	4.6	4.2	8.8	1,505	70,132	Yes	3.16	5.36	12
700536	POMPANO	Hybrid	-	2	0	0	0.4	0.2	0.1	-	0.5	0.2	0.7	2	357	Yes	0.30	4.40	2
406233	OAKES	Hybrid	2,704	0	47	4	3.4	1.6	0.9	15.9	4.3	17.5	21.8	197	20,760	Yes	-0.04	9.36	18
401833	JUPITER	Hybrid	1,326	22	42	7	5.3	0.9	8.2	15.3	13.5	16.2	29.7	1,895	104,101	Yes	-0.09	8.61	51
208762	GRANT	Hybrid	1,251	82	30	8	14.7	1.4	22.7	16.3	37.4	17.7	55.1	494	32,664	Yes	-0.25	6.35	34
411731	INLET	UG	1,186	1	29	1	0.4	4.7	0.2	8.5	0.6	13.2	13.8	15	1,634	Yes	-0.29	5.71	2
700232	HOLLYWOOD	Hybrid	650	9	11	3	2.5	0.1	1.7	2.3	4.2	2.4	6.6	1,056	18,212	Yes	-0.24	2.66	9
201936	COURTENAY	Hybrid	1,449	57	28	15	13.0	18.7	23.4	17.5	36.4	36.2	72.6	284	53,540	Yes	-0.15	6.75	37
813133	FIREHOUSE	UG	2,227	0	9	0	-	3.6	-	1.4	-	5.0	5.0	-	-	Yes	-2.75	5.55	0
408963	PLUMOSUS	Hybrid	3,525	20	82	4	7.6	6.8	10.3	28.8	17.9	35.6	53.5	2,798	121,947	Yes	-0.52	16.58	19
309462	GUMSWAMP	OH	513	29	2	4	3.4	0.1	18.5	0.9	21.9	1.0	22.9	169	41,337	Yes	-0.13	2.17	25
811934	OVERTOWN	UG	1,548	0	5	0	-	4.0	-	0.7	-	4.7	4.7	-	-	Yes	0.04	6.94	0
705161	JACARANDA	Hybrid	2,283	12	41	0	4.4	2.3	0.9	10.2	5.3	12.5	17.8	452	46,456	Yes	-0.53	11.37	28
701940	HOLY CROSS	Hybrid	1,071	6	15	2	1.5	0.4	3.6	2.2	5.1	2.6	7.7	1,458	149,953	Yes	-0.08	4.62	27
405867	DELTRAIL	Hybrid	3,424	5	49	9	4.7	0.7	2.1	16.5	6.8	17.2	24.0	414	48,349	Yes	0.09	9.19	28
104935	MOULTRIE	Hybrid	1,549	7	31	5	3.3	1.1	5.1	15.0	8.4	16.1	24.5	1,922	64,923	Yes	-3.03	7.57	13
403632	SOUTH BAY	Hybrid	1,038	30	18	2	54.5	0.6	8.1	2.9	62.6	3.5	66.1	4,140	154,230	Yes	0.18	5.08	22
400932	BELLE GLADE	Hybrid	651	21	12	1	5.0	0.2	7.3	1.4	12.3	1.6	13.9	155	30,638	Yes	0.01	3.41	12
410763	ROSEDALE	Hybrid	1,971	46	37	11	7.5	1.0	16.7	16.6	24.2	17.6	41.8	5,937	253,398	Yes	-0.28	7.22	57
301136	COLUMBIA	Hybrid	1,753	54	26	9	7.7	0.2	12.8	6.5	20.5	6.7	27.2	2,586	60,912	Yes	-0.37	7.03	33
505562	VAMO	Hybrid	2,405	23	42	12	4.1	1.4	6.8	9.4	10.9	10.8	21.7	463	98,643	Yes	-0.05	8.95	36
503263	COCOPLUM	Hybrid	3,263	43	51	3	6.4	0.3	41.0	22.3	47.4	22.6	70.0	2,669	108,797	Yes	-0.15	10.15	53
703936	WESTINGHOUSE	Hybrid	863	0	40	2	2.9	1.3	0.2	8.6	3.1	9.9	13.0	16	3,585	Yes	2.49	8.39	3
705861	REMSBURG	UG	1,172	0	14	0	0.5	2.5	-	18.6	0.5	21.1	21.6	57	14,821	Yes	-1.02	5.58	3
709433	ANDREWS	Hybrid	2,111	0	19	0	1.4	1.4	-	2.0	1.4	3.4	4.8	25	3,690	Yes	0.22	3.12	5
201635	PALM BAY	Hybrid	2,395	7	28	4	4.8	3.7	6.9	21.3	11.7	25.0	36.7	466	59,291	Yes	-0.88	8.72	29
404837	GERMANTOWN	Hybrid	1,935	11	31	8	4.4	0.7	5.7	4.8	10.1	5.5	15.6	702	63,449	Yes	0.09	8.59	29
809340	RONEY	UG	671	1	9	2	-	2.5	0.1	1.0	0.1	3.5	3.6	-	-	Yes	-1.53	4.07	0
805436	DADE	UG	1	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	-0.38	2.72	0
400664	WABASSO	Hybrid	3,456	39	123	4	8.6	9.8	7.7	47.3	16.3	57.1	73.4	2,790	187,747	Yes	-0.72	15.98	38
806840	RED ROAD	Hybrid	26	0	10	0	0.6	2.7	-	0.5	0.6	3.2	3.8	5	991	Yes	-0.28	6.12	3
200334	TITUSVILLE	Hybrid	2,118	14	24	4	3.3	-	7.6	7.1	10.9	7.1	18.0	3,531	225,377	Yes	-0.94	6.26	27
805934	COUNTRY CLUB	Hybrid	1,418	0	15	0	1.7	3.1	-	14.9	1.7	18.0	19.7	339	63,214	Yes	-0.94	7.46	23
501433	ARCADIA	Hybrid	956	17	20	7	3.1	0.2	7.1	1.5	10.2	1.7	11.9	57	3,437	Yes	-0.04	4.46	8

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
700631	VERENA	Hybrid	1,523	25	18	2	2.5	0.6	2.8	1.3	5.3	1.9	7.2	891	84,217	Yes	2.17	7.07	23
406763	ACREAGE	OH	2,268	68	2	0	10.3	0.4	51.3	0.3	61.6	0.7	62.3	1,897	159,355	Yes	-0.56	12.24	57
508362	TERRY	Hybrid	4,901	20	60	6	8.5	6.3	11.0	41.9	19.5	48.2	67.7	5,190	93,487	Yes	1.01	14.21	34
200264	CELERY	Hybrid	1,744	33	45	3	6.1	7.1	14.0	20.6	20.1	27.7	47.8	1,320	85,553	Yes	0.35	11.45	29
501762	IONA	Hybrid	2,426	25	40	16	3.3	1.3	5.7	5.8	9.0	7.1	16.1	1,743	111,228	Yes	0.08	10.68	39
700336	PINEHURST	Hybrid	280	2	15	2	1.7	1.3	0.6	1.0	2.3	2.3	4.6	17	2,524	Yes	0.33	4.03	4
706533	TRAIN	Hybrid	452	6	15	2	2.6	0.2	1.4	0.8	4.0	1.0	5.0	512	18,471	Yes	0.20	5.40	5
802136	MIRAMAR	UG	60	0	3	0	-	7.9	-	0.3	-	8.2	8.2	-	-	Yes	-4.42	1.68	0
412063	GIFFORD	Hybrid	2,118	45	61	9	9.7	1.4	18.3	26.4	28.0	27.8	55.8	173	27,499	Yes	0.08	8.18	33
406937	DELMAR	UG	1,856	0	28	0	0.5	3.0	-	13.0	0.5	16.0	16.5	137	23,589	Yes	0.09	7.29	11
102363	ST JOE	Hybrid	1,766	12	18	0	3.0	0.1	11.5	5.7	14.5	5.8	20.3	1,121	45,952	Yes	-0.24	4.16	37
104732	KACIE	Hybrid	1,848	20	42	5	6.6	5.8	9.2	21.3	15.8	27.1	42.9	201	16,143	Yes	0.17	8.47	20
201436	GRANDVIEW	Hybrid	176	11	17	3	2.9	1.3	1.8	1.9	4.7	3.2	7.9	20	1,452	Yes	-0.23	2.97	8
504963	GOLDEN GATE	Hybrid	1,744	16	11	3	3.1	0.3	8.5	3.0	11.6	3.3	14.9	2,710	159,231	Yes	-0.69	6.21	35
802033	CUTLER	Hybrid	884	15	10	6	3.4	1.3	6.0	5.1	9.4	6.4	15.8	1,181	35,087	Yes	-0.20	6.20	40
804136	GARDEN	Hybrid	315	4	13	0	2.5	0.8	1.3	1.8	3.8	2.6	6.4	150	12,122	Yes	-0.04	4.56	9
203539	HIBISCUS	Hybrid	659	15	19	0	4.3	0.9	6.0	3.7	10.3	4.6	14.9	125	21,826	Yes	-0.03	6.47	12
101540	GENERAL ELECTRIC	Hybrid	2,094	9	25	3	3.4	0.6	4.5	5.6	7.9	6.2	14.1	100	7,820	Yes	-0.94	5.76	18
703238	WOODLANDS	Hybrid	1,940	4	22	0	1.5	0.6	1.3	7.7	2.8	8.3	11.1	46	5,129	Yes	0.19	5.89	6
812169	BEACON	Hybrid	2,966	0	27	0	0.9	3.8	-	12.4	0.9	16.2	17.1	2	161	Yes	10.10	10.10	2
201931	COURTENAY	Hybrid	1,445	39	13	8	4.8	0.2	14.0	10.9	18.8	11.1	29.9	1,622	103,108	Yes	0.04	5.74	25
205935	SYLVAN	UG	1,126	0	16	0	-	3.7	-	14.4	-	18.1	18.1	29	3,542	Yes	-0.47	6.63	2
508364	TERRY	Hybrid	3,480	0	57	0	4.1	6.9	-	41.4	4.1	48.3	52.4	160	30,337	Yes	-0.45	12.85	9
707462	SAWGRASS	Hybrid	1,144	0	51	0	2.8	1.7	-	11.0	2.8	12.7	15.5	78	30,109	Yes	1.60	17.60	11
501537	PUNTA GORDA	Hybrid	1,427	14	26	6	4.3	0.2	8.9	9.1	13.2	9.3	22.5	266	31,924	Yes	0.05	5.65	21
401636	OKEECHOBEE	Hybrid	1,306	61	18	5	8.3	1.0	22.1	4.3	30.4	5.3	35.7	295	65,746	Yes	-0.42	5.28	24
410533	GRAMERCY	Hybrid	2,650	48	18	2	4.5	2.2	11.4	4.3	15.9	6.5	22.4	1,933	88,303	Yes	0.22	9.62	62
507364	ORANGETREE	Hybrid	3,357	124	13	12	16.1	0.9	95.5	9.6	111.6	10.5	122.1	6,922	194,536	Yes	0.60	16.30	76
805335	KEY BISCAIYNE	Hybrid	996	26	14	2	3.0	0.6	6.1	2.4	9.1	3.0	12.1	2,763	157,697	Yes	-1.13	8.37	57
401138	STUART	Hybrid	362	10	21	1	3.1	0.6	0.4	0.9	3.5	1.5	5.0	105	16,925	Yes	-0.08	5.12	6
202036	INDIAN HARBOR	Hybrid	1,453	11	20	5	1.7	1.8	5.0	4.5	6.7	6.3	13.0	368	52,211	Yes	-0.19	4.61	33
800853	RAILWAY	UG	6	0	1	0	-	2.2	-	-	-	2.2	2.2	-	-	Yes	-0.97	5.43	0
205434	MERRITT	Hybrid	1,360	16	19	7	2.5	2.7	7.7	4.9	10.2	7.6	17.8	986	82,288	Yes	-0.10	6.10	22
500833	WHITFIELD	Hybrid	1,991	28	23	8	5.2	0.5	11.0	5.2	16.2	5.7	21.9	423	62,911	Yes	0.17	9.17	44
502536	PALMA SOLA	Hybrid	1,267	0	46	0	2.5	0.5	0.1	11.8	2.6	12.3	14.9	225	38,580	Yes	-0.53	8.27	20
807336	GOULDS	Hybrid	1,855	4	19	3	2.0	0.8	1.2	4.5	3.2	5.3	8.5	1,454	39,533	Yes	-0.16	5.14	22
806833	RED ROAD	Hybrid	1,734	24	12	3	3.7	-	7.5	1.1	11.2	1.1	12.3	665	158,662	Yes	-0.02	9.18	53
800234	MIAMI BEACH	UG	1,136	0	17	1	-	5.5	-	0.9	-	6.4	6.4	12	709	Yes	0.05	3.35	2
808538	SEMINOLA	Hybrid	78	0	3	0	0.6	1.2	-	0.5	0.6	1.7	2.3	-	-	Yes	0.10	1.10	0
807535	DADELAND	Hybrid	698	3	13	3	0.6	2.2	0.5	1.6	1.1	3.8	4.9	269	30,798	Yes	-1.83	3.67	8
703962	WESTINGHOUSE	UG	2,083	0	28	0	1.0	3.0	-	17.1	1.0	20.1	21.1	2,996	212,318	Yes	-0.62	10.38	9
807835	WESTON VILLAGE	Hybrid	1,330	20	22	5	2.6	1.6	5.8	3.8	8.4	5.4	13.8	466	92,335	Yes	-0.18	7.12	36
204262	BABCOCK	Hybrid	1,836	22	14	9	4.1	0.4	17.6	5.3	21.7	5.7	27.4	371	39,850	Yes	-5.94	9.56	38
807432	VILLAGE GREEN	Hybrid	1,456	20	13	1	3.3	0.4	9.2	3.1	12.5	3.5	16.0	1,309	181,353	Yes	-0.18	8.12	55
200433	COCOA	Hybrid	1,963	37	8	5	4.0	-	15.7	1.9	19.7	1.9	21.6	439	53,059	Yes	0.28	7.28	44
811436	WATKINS	UG	7	0	3	0	-	7.1	-	0.2	-	7.3	7.3	-	-	Yes	0.40	3.30	0
501768	IONA	Hybrid	1,544	1	55	1	6.2	3.5	0.2	18.1	6.4	21.6	28.0	219	20,926	Yes	0.40	9.40	12
707863	PARKLAND	UG	3,354	0	69	0	-	10.5	-	43.6	-	54.1	54.1	3,249	25,898	Yes	0.53	16.83	13
803036	TROPICAL	Hybrid	1,365	9	33	1	2.7	0.7	2.8	5.9	5.5	6.6	12.1	197	35,130	Yes	-0.15	6.45	30
704936	LAKEVIEW	UG	-	0	2	0	-	2.7	-	-	-	2.7	2.7	-	-	Yes	-0.32	1.58	0
411461	WESTLAKE	OH	135	16	0	0	4.6	0.2	15.9	-	20.5	0.2	20.7	86	17,943	Yes	-0.42	0.38	22
506032	WALKER	Hybrid	1,331	24	8	4	2.9	-	8.9	2.4	11.8	2.4	14.2	2,054	118,455	Yes	-0.26	5.64	59

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
108965	DURBIN	UG	3,434	0	52	0	-	16.7	-	55.9	-	72.6	72.6	72	13,805	Yes	11.58	11.98	8
411734	INLET	Hybrid	766	13	21	2	1.6	1.1	3.8	1.6	5.4	2.7	8.1	1,040	48,034	Yes	-0.35	4.65	40
208167	HIELD	Hybrid	2,468	51	14	2	6.8	3.6	35.0	11.0	41.8	14.6	56.4	6,469	232,433	Yes	-0.04	9.86	85
405869	DELTRAIL	Hybrid	2,874	11	47	1	5.5	2.8	2.2	30.1	7.7	32.9	40.6	2,542	101,256	Yes	-0.05	9.85	25
809331	RONEY	UG	1,202	0	18	1	-	2.7	-	1.1	-	3.8	3.8	332	39,363	Yes	0.43	5.33	7
501835	TICE	Hybrid	3,577	19	63	7	4.0	7.6	10.9	45.6	14.9	53.1	68.0	1,475	124,728	Yes	-1.20	11.00	23
208864	WINDOVER	Hybrid	1,216	47	14	4	6.6	1.1	13.9	4.0	20.5	5.1	25.6	44	4,736	Yes	0.41	7.61	24
700463	OAKLAND PARK	Hybrid	2,382	19	25	1	5.4	0.2	5.4	3.0	10.8	3.2	14.0	2,401	166,053	Yes	0.73	9.93	44
401838	JUPITER	Hybrid	356	1	6	1	0.9	0.1	1.8	1.1	2.7	1.2	3.9	5	995	Yes	-0.34	2.66	4
404435	PURDY LANE	Hybrid	2,219	10	27	3	2.9	0.3	2.0	6.1	4.9	6.4	11.3	415	41,188	Yes	-0.18	6.22	17
801136	FRONTON	Hybrid	1,707	13	12	4	4.2	0.5	2.5	1.2	6.7	1.7	8.4	3,333	136,814	Yes	-0.24	6.36	28
708431	BUTTERFLY	Hybrid	2,030	1	37	0	1.4	2.9	0.1	15.4	1.5	18.3	19.8	167	28,261	Yes	-0.31	8.09	7
409761	CATCHMENT	Hybrid	3,567	0	72	1	3.5	4.6	0.3	31.7	3.8	36.3	40.1	233	28,848	Yes	-0.44	13.66	10
703540	DEERFIELD BEACH	Hybrid	2,250	20	32	3	2.3	1.3	7.2	3.7	9.5	5.0	14.5	1,175	54,272	Yes	0.00	7.40	30
805739	GALLOWAY	UG	1	0	0	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	-1.54	2.56	0
500533	CLARK	Hybrid	1,588	6	52	5	5.1	1.0	2.6	12.5	7.7	13.5	21.2	155	37,215	Yes	-0.18	7.72	10
805438	DADE	Hybrid	767	5	47	3	3.1	-	1.3	4.7	4.4	4.7	9.1	19	2,338	Yes	0.26	7.86	6
807936	MIAMI LAKES	Hybrid	1,187	13	13	3	3.2	0.4	6.5	3.3	9.7	3.7	13.4	1,289	118,642	Yes	-0.14	6.16	31
700137	SISTRUNK	Hybrid	4,045	17	25	20	3.6	2.0	4.3	4.4	7.9	6.4	14.3	8,705	309,888	Yes	0.91	10.21	39
203033	FRONTENAC	OH	1,565	32	1	1	4.5	0.1	14.7	0.1	19.2	0.2	19.4	859	33,017	Yes	-0.06	5.44	26
700133	SISTRUNK	Hybrid	1,877	35	16	5	2.5	0.3	5.5	2.1	8.0	2.4	10.4	951	89,818	Yes	-0.05	5.35	56
506563	GRANADA	Hybrid	2,913	11	57	2	9.2	7.6	13.7	33.2	22.9	40.8	63.7	2,630	120,304	Yes	0.10	8.30	19
802234	GLADEVIEW	Hybrid	1,424	32	17	2	5.4	0.1	4.8	1.8	10.2	1.9	12.1	1,107	101,580	Yes	-0.15	8.35	49
501232	NAPLES	Hybrid	160	0	7	1	0.7	0.2	0.8	0.4	1.5	0.6	2.1	193	49,063	Yes	-1.97	4.63	10
102632	LEWIS	Hybrid	2,020	16	21	10	3.7	2.2	6.9	10.3	10.6	12.5	23.1	304	33,332	Yes	0.36	7.06	26
409863	HAMLET	Hybrid	1,977	1	26	0	2.5	1.8	0.4	9.2	2.9	11.0	13.9	140	36,251	Yes	-0.28	4.42	5
700334	PINEHURST	Hybrid	585	14	19	3	4.0	0.3	1.8	1.8	5.8	2.1	7.9	25	7,300	Yes	-0.15	5.95	6
800846	RAILWAY	UG	17	0	5	0	-	2.2	-	0.8	-	3.0	3.0	-	-	Yes	-0.37	3.73	0
800631	LITTLE RIVER	Hybrid	2,441	37	6	2	5.4	0.2	6.2	0.9	11.6	1.1	12.7	356	41,971	Yes	0.61	8.11	38
410164	PLAZA	OH	2,061	48	1	0	4.6	0.3	22.1	0.1	26.7	0.4	27.1	257	31,827	Yes	0.13	8.53	41
803541	MARKET	UG	-	0	0	0	-	2.3	-	-	-	2.3	2.3	-	-	Yes	1.36	2.06	0
805833	CORAL REEF	Hybrid	1,348	15	22	3	2.3	-	4.3	11.3	6.6	11.3	17.9	1,893	239,795	Yes	0.24	7.74	45
202532	AURORA	Hybrid	1,666	5	27	6	2.0	-	2.1	7.9	4.1	7.9	12.0	245	24,165	Yes	-0.44	5.36	17
406861	KIMBERLY	Hybrid	1,912	0	33	1	1.4	3.3	0.1	21.8	1.5	25.1	26.6	2,406	118,012	Yes	-0.39	8.01	14
508532	HANSON	Hybrid	971	20	29	7	4.3	0.1	9.9	4.1	14.2	4.2	18.4	190	30,430	Yes	0.36	6.16	23
403937	LAKE PARK	Hybrid	2,130	4	28	0	1.4	1.6	1.1	4.1	2.5	5.7	8.2	2,090	220,965	Yes	-0.22	6.38	8
500134	SARASOTA	Hybrid	1,417	20	19	11	3.7	-	6.0	2.7	9.7	2.7	12.4	143	31,903	Yes	-0.35	8.15	27
403235	ATLANTIC	Hybrid	622	1	28	0	1.7	0.2	0.8	1.8	2.5	2.0	4.5	651	18,398	Yes	-0.05	7.45	10
406933	DELMAR	Hybrid	976	0	25	0	1.0	0.9	-	9.5	1.0	10.4	11.4	26	3,276	Yes	-0.29	6.31	1
202133	INDIAN RIVER	Hybrid	2,411	12	45	6	4.1	4.3	5.1	15.6	9.2	19.9	29.1	378	43,312	Yes	-0.18	7.62	28
408661	HOMELAND	Hybrid	2,585	0	49	0	3.7	4.7	-	37.2	3.7	41.9	45.6	2,410	204,344	Yes	-1.07	12.23	26
106362	REGIS	Hybrid	2,683	42	6	0	6.5	5.7	31.7	1.6	38.2	7.3	45.5	237	12,600	Yes	-0.23	7.77	29
500238	BRADENTON	Hybrid	2,239	19	31	3	4.4	0.2	5.6	6.3	10.0	6.5	16.5	218	38,930	Yes	-0.41	5.69	22
503965	ESTERO	Hybrid	5,548	17	51	4	5.5	2.4	5.3	34.6	10.8	37.0	47.8	523	71,764	Yes	-0.17	14.13	18
406332	ROEBUCK	Hybrid	2,805	1	35	2	3.2	0.1	0.2	21.1	3.4	21.2	24.6	312	76,314	Yes	0.16	7.36	10
205535	DAIRY	Hybrid	2,111	0	34	3	2.8	0.5	0.7	11.5	3.5	12.0	15.5	341	43,992	Yes	-1.64	7.16	7
409631	RAINBERRY	Hybrid	422	1	33	0	1.9	0.5	0.1	3.3	2.0	3.8	5.8	1	94	Yes	0.31	5.31	1
704939	LAKEVIEW	Hybrid	2,484	4	31	0	2.2	1.8	2.0	12.1	4.2	13.9	18.1	41	3,737	Yes	-0.23	6.97	10
209765	VIERA	UG	2,420	0	35	0	-	6.8	-	19.7	-	26.5	26.5	1	149	Yes	1.68	11.98	1
700961	HALLANDALE	UG	2,035	0	18	0	-	3.8	-	0.9	-	4.7	4.7	1,206	109,782	Yes	-0.34	4.56	8
812836	WILCOX	UG	20	0	0	0	-	2.4	-	-	-	2.4	2.4	-	-	Yes	0.08	3.68	0
306132	NASH	Hybrid	1,322	46	39	7	8.1	1.1	16.7	16.5	24.8	17.6	42.4	319	45,234	Yes	0.00	7.00	35

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
805234	NATOMA	Hybrid	729	10	11	5	2.5	1.5	2.3	2.4	4.8	3.9	8.7	1,253	93,397	Yes	-0.17	6.13	30
706861	CONSERVATION	Hybrid	1,184	1	41	0	3.7	1.3	0.2	13.2	3.9	14.5	18.4	199	32,005	Yes	-0.76	9.04	15
706361	BASSCREEK	Hybrid	1,731	1	40	1	2.1	4.5	0.2	18.1	2.3	22.6	24.9	35	9,848	Yes	-0.48	11.92	7
401761	OLYMPIA	Hybrid	1,112	8	37	3	3.7	5.0	3.7	26.0	7.4	31.0	38.4	126	14,963	Yes	-1.26	7.24	16
705533	SOUTHSIDE	UG	3	0	5	0	-	0.7	-	-	-	0.7	0.7	-	-	Yes	-0.13	3.07	0
811834	LUMMUS	UG	-	0	0	0	-	0.3	-	-	-	0.3	0.3	-	-	Yes	0.49	2.29	0
804537	GRATIGNY	Hybrid	854	0	8	0	0.4	0.9	-	2.5	0.4	3.4	3.8	887	43,763	Yes	-0.07	2.03	3
501532	PUNTA GORDA	Hybrid	921	28	20	4	4.9	-	6.9	2.1	11.8	2.1	13.9	1,051	49,345	Yes	-0.02	4.18	26
812063	WILLIAMS	Hybrid	843	45	5	5	12.3	0.2	32.9	2.6	45.2	2.8	48.0	1,703	134,952	Yes	0.22	5.92	100
405535	PRIMA VISTA	Hybrid	1,039	6	24	3	3.3	0.2	2.8	6.2	6.1	6.4	12.5	202	35,741	Yes	0.01	4.01	12
404339	IBM	UG	2	0	1	0	-	1.6	-	0.1	-	1.7	1.7	-	-	Yes	0.11	6.71	0
808068	FLAGAMI	UG	15	0	9	0	-	0.9	-	0.1	-	1.0	1.0	-	-	Yes	0.01	3.11	0
506263	SHADE	Hybrid	2,975	20	60	9	7.0	1.8	12.0	15.4	19.0	17.2	36.2	801	117,178	Yes	0.47	11.47	32
807835	KILLIAN	Hybrid	1,905	1	35	1	2.1	1.7	0.6	14.5	2.7	16.2	18.9	189	27,787	Yes	-0.08	7.62	14
803233	HOMESTEAD	Hybrid	2,601	3	38	1	3.5	2.5	0.3	22.0	3.8	24.5	28.3	51	23,213	Yes	0.19	11.09	15
403037	MILITARY TRAIL	Hybrid	742	14	16	2	2.9	0.5	5.7	1.8	8.6	2.3	10.9	308	46,284	Yes	-0.62	3.38	27
800237	MIAMI BEACH	UG	695	0	2	0	-	4.4	-	0.3	-	4.7	4.7	-	-	Yes	-0.32	3.48	0
501233	NAPLES	Hybrid	775	3	29	3	1.8	-	0.4	1.9	2.2	1.9	4.1	13	1,959	Yes	-3.49	4.21	7
411034	EDEN	Hybrid	1,122	14	33	0	3.5	1.0	3.8	7.2	7.3	8.2	15.5	57	18,912	Yes	-0.88	5.32	14
407865	LOXAHATCHEE	Hybrid	2,772	153	8	6	18.6	1.0	83.7	5.0	102.3	6.0	108.3	454	47,565	Yes	-0.54	15.56	94
407334	HILLS	Hybrid	1,641	5	33	2	3.4	1.9	1.9	17.3	5.3	19.2	24.5	3,602	68,783	Yes	0.12	5.52	24
702932	HAWKINS	Hybrid	1,639	0	23	3	2.1	0.5	1.3	8.9	3.4	9.4	12.8	1,008	62,985	Yes	0.30	7.80	17
504370	PINE RIDGE	Hybrid	2,431	6	46	2	0.7	5.6	3.7	10.9	4.4	16.5	20.9	84	28,996	Yes	0.24	14.04	16
808163	MILAM	Hybrid	662	0	27	0	1.2	3.1	0.1	3.5	1.3	6.6	7.9	694	35,712	Yes	-4.60	8.10	3
806731	IVES	Hybrid	1,474	5	11	0	1.9	0.4	1.8	3.9	3.7	4.3	8.0	1,109	141,531	Yes	-0.15	5.75	30
400237	DATURA ST	Hybrid	799	0	2	0	0.2	2.1	-	-	0.2	2.1	2.3	2	156	Yes	0.51	2.81	2
202534	AURORA	Hybrid	1,747	4	32	2	2.0	0.6	1.1	11.1	3.1	11.7	14.8	1,078	84,728	Yes	-0.21	5.99	17
805632	MILLER	Hybrid	1,855	19	12	9	3.6	1.0	13.1	2.6	16.7	3.6	20.3	4,925	211,670	Yes	0.23	10.23	65
705165	JACARANDA	Hybrid	800	0	26	3	2.8	1.5	0.4	6.0	3.2	7.5	10.7	209	22,410	Yes	-0.50	7.50	11
801942	DEAUVILLE	Hybrid	1,731	6	9	2	1.7	0.7	0.7	0.2	2.4	0.9	3.3	1,947	49,607	Yes	0.18	4.08	13
412163	ALLAPATTAH	UG	-	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.01	9.11	0
403439	JENSEN	Hybrid	1,728	9	25	3	3.3	2.9	6.7	14.0	10.0	16.9	26.9	436	48,505	Yes	-0.36	6.04	27
806132	DOUGLAS	Hybrid	615	0	11	2	0.2	2.8	0.3	1.3	0.5	4.1	4.6	99	8,011	Yes	-1.27	6.93	4
702434	PEMBROKE	Hybrid	2,571	13	38	7	5.7	1.8	4.3	7.0	10.0	8.8	18.8	1,386	223,489	Yes	0.34	8.14	32
413833	CHAMBERS	Hybrid	942	0	29	0	1.3	0.4	-	13.7	1.3	14.1	15.4	139	47,436	Yes	-0.48	3.52	9
211062	GARVEY	Hybrid	2,494	45	20	2	5.9	0.7	27.7	3.3	33.6	4.0	37.6	2,867	180,265	Yes	-0.76	10.54	78
407163	CRANE	Hybrid	2,627	7	53	4	5.0	4.7	5.1	40.8	10.1	45.5	55.6	640	90,169	Yes	-2.17	10.13	39
500834	WHITFIELD	Hybrid	1,575	18	29	8	3.1	1.0	9.8	10.8	12.9	11.8	24.7	107	25,845	Yes	-0.88	7.92	31
803641	SEABOARD	Hybrid	243	5	0	0	1.1	0.5	0.9	-	2.0	0.5	2.5	50	17,844	Yes	-0.12	1.38	8
504365	PINE RIDGE	Hybrid	3,510	11	38	13	5.3	1.7	6.1	15.4	11.4	17.1	28.5	1,186	219,729	Yes	0.07	11.87	40
500637	CORTEZ	Hybrid	1,032	10	7	3	1.8	1.1	3.7	1.8	5.5	2.9	8.4	126	14,378	Yes	-5.01	2.69	15
410535	GRAMERCY	UG	5	0	0	0	-	0.4	-	-	-	0.4	0.4	-	-	Yes	0.06	0.56	0
201531	CITY POINT	Hybrid	1,102	42	3	5	8.0	0.2	20.0	1.5	28.0	1.7	29.7	1,279	73,871	Yes	-0.57	6.73	21
811164	SPOONBILL	UG	1	0	2	0	-	2.3	-	-	-	2.3	2.3	1	46	Yes	0.26	1.76	1
205362	GENEVA	OH	598	72	7	8	10.4	-	32.3	1.9	42.7	1.9	44.6	1,332	46,697	Yes	-0.11	2.19	30
708163	HUNTINGTON	Hybrid	1,521	3	40	0	4.9	2.0	0.6	10.6	5.5	12.6	18.1	29	7,278	Yes	-1.51	12.49	5
404338	IBM	Hybrid	579	0	22	0	1.3	2.1	-	9.3	1.3	11.4	12.7	1,100	28,050	Yes	-0.32	5.68	17
110363	PRINGLE	Hybrid	2,151	16	21	5	6.1	4.8	22.8	6.5	28.9	11.3	40.2	9,170	340,824	Yes	-0.49	12.41	34
412263	OTTER	UG	2,251	0	36	0	-	9.4	-	37.6	-	47.0	47.0	3	659	Yes	5.35	5.35	3
205432	MERRITT	Hybrid	1,289	36	9	6	2.4	0.2	8.6	2.2	11.0	2.4	13.4	239	36,454	Yes	-0.29	4.41	31
407167	CRANE	Hybrid	990	43	14	20	8.0	1.4	38.0	17.0	46.0	18.4	64.4	545	98,365	Yes	-0.38	6.32	62
203534	HIBISCUS	Hybrid	871	12	15	7	2.7	0.1	8.0	2.6	10.7	2.7	13.4	399	39,824	Yes	-0.29	6.11	24

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
803539	MARKET	Hybrid	2,039	14	7	5	2.0	0.2	3.2	0.7	5.2	0.9	6.1	1,218	133,332	Yes	0.36	7.36	36
502936	ONECO	Hybrid	1,187	12	15	3	2.0	0.2	3.6	1.0	5.6	1.2	6.8	87	19,763	Yes	-2.59	5.01	14
102433	FLEMING	Hybrid	1,616	24	19	0	3.0	0.1	7.5	5.1	10.5	5.2	15.7	371	79,511	Yes	-0.23	5.17	38
700836	BEVERLY	Hybrid	1,320	24	16	4	3.4	1.1	7.0	1.6	10.4	2.7	13.1	1,478	69,637	Yes	-0.23	6.17	31
810931	LATIN QUARTER	OH	2,403	26	3	2	3.2	-	6.1	0.2	9.3	0.2	9.5	2,411	171,168	Yes	-0.26	8.84	45
404336	IBM	Hybrid	1,042	6	43	3	3.4	2.1	3.0	12.3	6.4	14.4	20.8	158	19,933	Yes	0.44	8.24	27
400533	BOYNTON	Hybrid	1,493	16	28	4	3.4	1.2	3.5	3.2	6.9	4.4	11.3	1,706	81,341	Yes	0.13	5.53	34
705634	COPANS	Hybrid	4,050	0	31	1	2.6	2.2	0.1	17.0	2.7	19.2	21.9	26	916	Yes	-0.15	8.75	6
508861	PANACEA	OH	3,599	99	10	8	11.8	0.8	128.8	2.3	140.6	3.1	143.7	5,268	179,197	Yes	-0.13	14.87	102
104833	TAYLOR	Hybrid	1,237	2	11	4	1.4	1.2	4.9	14.9	6.3	16.1	22.4	889	33,602	Yes	-0.23	3.67	23
500532	CLARK	Hybrid	2,327	8	29	8	2.6	-	9.3	3.3	11.9	3.3	15.2	281	27,070	Yes	0.09	8.69	25
402837	LANTANA	Hybrid	3,221	15	20	3	3.5	0.4	7.7	8.5	11.2	8.9	20.1	632	190,126	Yes	2.62	8.22	38
106462	SPRUCE	Hybrid	2,652	4	50	1	3.1	3.4	0.9	42.7	4.0	46.1	50.1	73	9,739	Yes	-0.47	10.63	7
110362	PRINGLE	UG	7	0	4	0	-	0.3	-	2.6	-	2.9	2.9	-	-	Yes	-0.36	0.44	0
809841	DUMFOUNDLING	UG	2,314	0	8	0	-	1.9	-	3.5	-	5.4	5.4	412	48,794	Yes	-0.37	7.43	6
205534	DAIRY	Hybrid	2,505	3	41	0	4.2	0.3	0.3	24.6	4.5	24.9	29.4	1,612	88,959	Yes	0.35	10.45	22
807536	DADELAND	Hybrid	767	23	12	4	2.5	0.3	5.5	1.3	8.0	1.6	9.6	993	68,061	Yes	-0.26	6.34	40
410031	MARYMOUNT	Hybrid	1,522	0	29	1	1.8	1.7	0.4	7.0	2.2	8.7	10.9	1,538	4,703	Yes	0.01	6.71	3
702233	MARGATE	Hybrid	1,388	12	9	2	1.0	0.5	3.7	4.3	4.7	4.8	9.5	300	44,445	Yes	0.12	4.42	25
503262	COCOPLUM	Hybrid	3,254	45	46	6	9.6	0.1	62.3	10.3	71.9	10.4	82.3	3,323	257,000	Yes	0.19	16.59	111
702737	MCARTHUR	Hybrid	1,390	2	20	2	2.7	0.9	1.9	3.9	4.6	4.8	9.4	618	54,524	Yes	0.02	5.62	15
706161	HOLLYBROOK	Hybrid	4,666	0	62	0	3.9	2.7	-	15.9	3.9	18.6	22.5	285	23,514	Yes	0.25	9.95	11
701131	LYONS	Hybrid	2,372	7	26	4	1.7	1.3	5.0	4.1	6.7	5.4	12.1	7,254	196,932	Yes	0.33	7.03	37
700831	BEVERLY	Hybrid	901	15	1	1	1.6	0.7	6.8	0.1	8.4	0.8	9.2	1,165	28,806	Yes	-0.60	5.30	28
500837	WHITFIELD	Hybrid	1,693	23	18	8	3.0	1.1	9.1	2.3	12.1	3.4	15.5	127	18,055	Yes	-0.09	6.01	25
404139	GOLF	Hybrid	2,489	1	68	0	3.6	0.6	0.1	14.8	3.7	15.4	19.1	207	10,292	Yes	-0.24	7.26	13
200833	LAUREL	Hybrid	819	21	5	3	3.7	0.5	5.3	0.6	9.0	1.1	10.1	869	14,012	Yes	0.71	4.21	9
400535	BOYNTON	Hybrid	1,885	28	24	2	3.2	0.6	4.1	5.4	7.3	6.0	13.3	232	42,146	Yes	0.25	6.55	29
500636	CORTEZ	Hybrid	2,189	11	27	5	2.9	0.6	5.0	10.1	7.9	10.7	18.6	470	73,927	Yes	-0.33	7.67	33
409231	OSCEMILL	Hybrid	23	2	12	0	2.4	0.2	1.4	1.3	3.8	1.5	5.3	4	1,391	Yes	-0.04	1.26	4
505166	PROCTOR	Hybrid	2,065	5	43	7	3.8	1.6	6.0	12.5	9.8	14.1	23.9	1,371	52,432	Yes	-0.30	7.80	17
401135	STUART	Hybrid	1,285	22	23	6	4.8	3.3	5.8	3.5	10.6	6.8	17.4	648	39,206	Yes	-0.20	4.30	14
201935	COURTENAY	Hybrid	1,233	13	27	8	3.8	0.5	7.3	17.1	11.1	17.6	28.7	424	56,798	Yes	-0.03	6.37	25
404838	GERMANTOWN	Hybrid	2,502	9	41	11	3.3	0.6	2.7	9.5	6.0	10.1	16.1	1,374	36,102	Yes	0.46	9.46	20
800937	40TH ST	UG	665	0	6	0	-	2.6	-	0.8	-	3.4	3.4	-	-	Yes	0.01	3.51	0
402637	JUNO BEACH	Hybrid	528	0	13	3	1.0	1.2	0.9	4.1	1.9	5.3	7.2	593	23,822	Yes	0.18	4.18	9
402832	LANTANA	Hybrid	1,724	27	11	4	3.1	1.5	6.0	3.0	9.1	4.5	13.6	157	25,223	Yes	0.09	6.09	27
810863	MONTGOMERY	Hybrid	2,341	0	28	3	1.9	3.0	1.2	25.2	3.1	28.2	31.3	1,966	157,768	Yes	-0.20	12.10	45
806141	DOUGLAS	Hybrid	1,498	4	12	2	1.3	0.3	2.2	0.4	3.5	0.7	4.2	1,106	38,760	Yes	0.03	6.43	15
101462	FLAGLER BEACH	Hybrid	1,625	31	35	6	8.1	1.8	8.2	10.7	16.3	12.5	28.8	1,205	48,965	Yes	-1.18	9.62	36
501534	PUNTA GORDA	Hybrid	1,878	19	26	5	3.7	0.1	7.8	5.2	11.5	5.3	16.8	395	58,125	Yes	0.12	5.52	19
100632	CRESCENT CITY	OH	1,575	93	20	5	18.9	0.2	35.4	1.5	54.3	1.7	56.0	2,239	201,086	Yes	-0.30	5.70	73
700844	BEVERLY	Hybrid	1,623	30	2	1	2.1	1.4	9.8	1.0	11.9	2.4	14.3	1,560	93,973	Yes	-0.12	6.68	56
503037	PHILLIPPI	Hybrid	1,355	21	14	3	3.4	1.5	9.1	4.4	12.5	5.9	18.4	1,703	132,812	Yes	0.08	6.68	34
403240	ATLANTIC	UG	0	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.16	1.36	0
400536	BOYNTON	Hybrid	2,243	24	15	3	4.1	0.3	7.0	1.7	11.1	2.0	13.1	3,004	110,081	Yes	-0.41	6.39	58
806033	GOLDEN GLADES	Hybrid	1,165	15	5	2	4.3	2.0	5.2	1.4	9.5	3.4	12.9	1,660	159,225	Yes	0.47	5.57	68
809531	VIRGINIA KEY	UG	1	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	1.48	6.48	0
506769	VANDERBILT	Hybrid	2,097	3	52	1	3.6	2.3	1.5	18.5	5.1	20.8	25.9	5,191	118,218	Yes	-0.02	8.08	26
207062	COX	Hybrid	920	24	13	3	3.7	0.8	6.4	4.2	10.1	5.0	15.1	3,795	341,798	Yes	-1.89	9.21	58
409963	PINEWOOD	Hybrid	459	7	22	5	5.1	1.1	4.6	7.9	9.7	9.0	18.7	262	12,150	Yes	-10.56	6.44	23
806839	RED ROAD	Hybrid	602	3	25	0	2.6	1.1	0.2	5.0	2.8	6.1	8.9	1,207	116,573	Yes	0.98	5.68	5

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
706662	NOBHILL	Hybrid	1,707	0	27	0	1.3	1.2	-	19.2	1.3	20.4	21.7	231	52,815	Yes	-0.95	9.25	11
505261	RUBONIA	Hybrid	2,026	22	47	11	8.3	3.1	9.2	15.4	17.5	18.5	36.0	7,350	244,430	Yes	0.76	12.96	37
707663	CROSSBOW	Hybrid	2,478	0	36	0	1.4	2.3	-	22.0	1.4	24.3	25.7	1,474	139,629	Yes	-0.26	11.74	15
810166	SEAGULL	UG	2,372	0	26	0	-	3.6	-	17.1	-	20.7	20.7	86	38,919	Yes	-0.13	9.27	8
704569	MALLARD	Hybrid	3,708	7	52	1	5.6	1.0	2.1	18.6	7.7	19.6	27.3	1,412	34,320	Yes	-1.09	12.61	21
706666	NOBHILL	Hybrid	2,143	0	35	0	2.3	1.6	-	11.9	2.3	13.5	15.8	848	51,238	Yes	-1.42	6.98	8
402132	TERMINAL	Hybrid	1,913	6	23	4	1.4	3.4	3.1	7.3	4.5	10.7	15.2	125	23,921	Yes	-0.43	6.67	14
808733	BOULEVARD	Hybrid	1,248	20	14	2	2.6	0.1	5.4	2.1	8.0	2.2	10.2	1,432	112,100	Yes	0.09	4.89	44
201637	PALM BAY	Hybrid	2,225	33	19	5	5.3	0.2	16.8	6.4	22.1	6.6	28.7	353	51,068	Yes	-3.53	5.77	42
420062	CORBETT	Hybrid	5	0	2	0	2.7	0.4	-	0.3	2.7	0.7	3.4	-	-	Yes	0.17	5.67	0
808067	FLAGAMI	Hybrid	2,096	1	23	0	1.1	2.4	0.5	12.3	1.6	14.7	16.3	3,915	95,600	Yes	-2.31	7.19	20
808731	BOULEVARD	Hybrid	2,601	17	24	2	2.4	2.0	3.7	2.8	6.1	4.8	10.9	2,237	180,664	Yes	-0.61	8.09	47
404432	PURDY LANE	Hybrid	2,344	18	37	2	4.3	-	3.9	8.0	8.2	8.0	16.2	2,544	122,637	Yes	-0.18	6.32	30
402538	BELVEDERE	Hybrid	1,484	31	7	4	2.7	0.8	5.0	2.2	7.7	3.0	10.7	182	18,845	Yes	-0.32	5.18	23
702535	DAVIE	Hybrid	2,429	6	39	1	2.2	3.0	1.2	17.1	3.4	20.1	23.5	528	60,951	Yes	-0.38	8.82	18
404438	PURDY LANE	Hybrid	2,109	10	33	5	3.5	0.5	4.3	7.7	7.8	8.2	16.0	2,394	126,629	Yes	-0.25	7.65	28
507363	ORANGETREE	Hybrid	3,531	42	50	7	12.1	1.8	40.7	31.4	52.8	33.2	86.0	1,695	146,432	Yes	1.01	16.71	38
504661	CASTLE	Hybrid	3,627	16	70	8	6.1	1.8	7.5	23.4	13.6	25.2	38.8	1,185	56,585	Yes	-0.70	10.60	40
503562	ALLIGATOR	Hybrid	3,999	30	71	17	7.1	1.6	11.1	15.5	18.2	17.1	35.3	705	110,635	Yes	1.03	13.03	62
408261	COVE	Hybrid	1,058	2	23	0	2.5	1.2	0.3	16.4	2.8	17.6	20.4	83	17,926	Yes	-1.27	4.63	4
504764	ALVA	OH	2,560	122	0	2	19.9	0.6	112.6	0.5	132.5	1.1	133.6	1,355	81,521	Yes	0.14	10.34	55
707934	TWINLAKES	Hybrid	982	12	14	1	1.9	0.5	5.4	1.9	7.3	2.4	9.7	793	74,984	Yes	-0.32	5.58	26
803535	MARKET	UG	19	0	1	0	-	1.6	-	0.1	-	1.7	1.7	-	-	Yes	0.57	2.17	0
704135	MOFFETT	Hybrid	3,028	14	29	2	3.2	0.8	4.0	1.2	7.2	2.0	9.2	350	48,891	Yes	0.33	8.13	48
806735	IVES	Hybrid	2,699	2	29	0	1.9	1.4	0.2	7.3	2.1	8.7	10.8	3,514	197,401	Yes	-0.36	5.54	13
403033	MILITARY TRAIL	Hybrid	2,715	4	34	1	3.2	0.1	1.3	13.6	4.5	13.7	18.2	44	6,581	Yes	-0.05	8.05	8
810366	NEWTON	Hybrid	1,015	17	35	5	27.0	16.7	18.4	24.0	45.4	40.7	86.1	3,001	504,928	Yes	-0.33	10.67	30
410464	GATLIN	UG	3,186	0	66	0	-	12.8	-	41.8	-	54.6	54.6	473	82,894	Yes	0.31	12.11	11
814034	BRICKELL	UG	516	0	4	0	-	2.9	-	0.5	-	3.4	3.4	-	-	Yes	-0.10	4.70	0
406767	ACREAGE	OH	2,530	57	2	0	8.9	0.3	54.4	1.0	63.3	1.3	64.6	1,180	110,118	Yes	-0.12	13.48	75
705562	SOUTHSIDE	UG	513	0	3	0	-	7.5	-	-	-	7.5	7.5	-	-	Yes	1.24	6.74	0
405335	BEEHIVE	Hybrid	1,957	1	30	4	3.1	1.5	1.1	10.8	4.2	12.3	16.5	119	10,497	Yes	-0.52	6.68	11
404237	BOCA TECCA	Hybrid	461	0	25	0	1.5	1.8	-	6.4	1.5	8.2	9.7	113	10,399	Yes	-0.11	5.89	9
808170	MILAM	UG	1	0	0	0	-	1.5	-	-	-	1.5	1.5	-	-	Yes	0.19	2.39	0
809132	TAMIAMI	Hybrid	1,391	6	15	5	1.2	0.2	1.8	0.6	3.0	0.8	3.8	127	21,215	Yes	-0.11	1.29	9
201631	PALM BAY	Hybrid	1,936	7	21	10	2.5	-	3.6	6.3	6.1	6.3	12.4	925	100,399	Yes	-0.26	5.64	29
802535	GREYNOLDS	UG	-	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	-0.23	4.17	0
801031	NORMANDY BEACH	Hybrid	1,932	0	33	0	0.9	2.7	-	2.6	0.9	5.3	6.2	1,204	75,869	Yes	-0.40	6.40	5
800733	HIALEAH	Hybrid	1,603	8	6	2	1.4	1.5	1.8	0.5	3.2	2.0	5.2	987	53,022	Yes	-0.08	4.72	21
500336	VENICE	Hybrid	2,435	15	29	8	3.0	0.6	10.0	9.1	13.0	9.7	22.7	1,455	66,479	Yes	0.00	7.70	35
806841	RED ROAD	Hybrid	1,217	10	2	0	1.6	0.6	9.2	0.1	10.8	0.7	11.5	1,444	180,581	Yes	-0.25	6.95	27
802137	MIRAMAR	UG	155	0	12	0	-	5.6	-	1.6	-	7.2	7.2	15	1,770	Yes	-0.14	2.76	1
804340	KENDALL	Hybrid	266	8	8	0	1.0	0.8	1.5	0.9	2.5	1.7	4.2	92	15,815	Yes	-5.63	1.37	13
800435	COCONUT GROVE	Hybrid	1,526	26	9	1	1.9	0.5	4.2	0.4	6.1	0.9	7.0	320	66,729	Yes	0.12	5.92	40
800834	RAILWAY	UG	0	0	0	0	-	2.8	-	-	-	2.8	2.8	-	-	Yes	1.81	6.31	0
700964	HALLANDALE	UG	2,279	0	11	0	-	3.1	-	1.9	-	5.0	5.0	1,371	519,988	Yes	-0.18	7.02	3
703831	HIGHLANDS	Hybrid	2,441	23	25	12	4.1	0.2	5.8	3.4	9.9	3.6	13.5	410	74,738	Yes	-0.04	9.56	39
500431	HYDE PARK	Hybrid	1,459	21	13	3	2.5	0.2	7.3	3.7	9.8	3.9	13.7	208	43,902	Yes	0.18	4.88	24
807631	KILLIAN	Hybrid	1,211	5	29	1	3.1	1.1	0.5	8.5	3.6	9.6	13.2	212	35,112	Yes	1.90	6.00	18
804232	PERRINE	Hybrid	2,291	22	33	4	5.5	-	5.6	7.9	11.1	7.9	19.0	540	79,641	Yes	-2.19	8.71	55
811064	PALMETTO	Hybrid	3,077	1	66	0	3.3	1.1	-	17.9	3.3	19.0	22.3	254	56,764	Yes	-0.34	12.66	10
506562	GRANADA	Hybrid	3,549	7	69	1	4.8	7.0	1.1	45.0	5.9	52.0	57.9	2,577	193,515	Yes	-0.37	13.63	27

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
407234	JOG	Hybrid	1,357	13	30	2	3.7	1.0	3.1	13.4	6.8	14.4	21.2	2,255	74,563	Yes	1.24	7.54	19
502633	COLONIAL	Hybrid	313	4	10	5	1.1	0.3	0.9	1.7	2.0	2.0	4.0	88	15,789	Yes	0.21	4.21	7
500136	SARASOTA	Hybrid	767	2	20	4	1.9	1.9	0.3	1.8	2.2	3.7	5.9	12	714	Yes	0.18	4.58	3
807340	GOULDS	Hybrid	1,744	0	28	1	0.6	1.8	1.1	14.1	1.7	15.9	17.6	3,119	179,428	Yes	0.47	7.47	20
200733	COCOA BEACH	Hybrid	2,401	22	28	7	3.0	-	6.8	3.5	9.8	3.5	13.3	644	81,132	Yes	-0.31	6.69	39
704567	MALLARD	UG	1,903	0	13	0	-	3.9	-	13.7	-	17.6	17.6	127	15,157	Yes	-0.72	7.98	12
401632	OKEECHOBEE	Hybrid	1,931	70	19	16	12.0	0.2	39.0	3.9	51.0	4.1	55.1	1,814	169,181	Yes	-0.35	9.35	66
400240	DATURA ST	Hybrid	544	1	14	0	0.1	0.8	-	0.8	0.1	1.6	1.7	-	-	Yes	0.20	3.20	0
704062	MOTOROLA	Hybrid	4,827	15	38	7	5.6	0.4	7.6	11.2	13.2	11.6	24.8	6,648	210,066	Yes	-0.34	12.16	43
410032	MARYMOUNT	Hybrid	82	2	15	0	0.8	1.8	0.2	1.5	1.0	3.3	4.3	2	216	Yes	0.09	4.29	1
703934	WESTINGHOUSE	Hybrid	463	0	26	0	3.5	1.3	-	4.8	3.5	6.1	9.6	301	2,581	Yes	0.01	6.81	7
308064	MILLS	Hybrid	1,950	54	18	14	9.0	0.1	34.9	11.1	43.9	11.2	55.1	4,842	512,219	Yes	-0.30	9.10	58
506564	GRANADA	Hybrid	2,018	4	45	2	3.6	8.6	1.7	35.3	5.3	43.9	49.2	36	3,956	Yes	0.00	0.00	4
205361	GENEVA	Hybrid	998	88	11	17	14.3	-	45.1	4.9	59.4	4.9	64.3	3,915	105,089	Yes	-0.62	5.18	56
202132	INDIAN RIVER	Hybrid	1,775	5	13	6	2.4	0.8	10.1	6.1	12.5	6.9	19.4	1,130	213,562	Yes	-0.61	6.59	48
709932	ELLER	UG	-	0	0	0	-	3.0	-	-	-	3.0	3.0	-	-	Yes	0.08	0.08	0
102361	ST JOE	Hybrid	1,798	14	32	1	3.7	0.5	10.7	8.1	14.4	8.6	23.0	2,110	90,936	Yes	0.71	8.91	34
506861	NOTRE DAME	Hybrid	2,641	23	35	6	6.1	0.9	15.7	15.5	21.8	16.4	38.2	3,863	813,277	Yes	-0.33	7.97	37
408765	SABAL	Hybrid	939	7	34	4	12.9	4.0	12.6	22.6	25.5	26.6	52.1	2,626	220,290	Yes	1.30	5.80	21
707268	FLAMINGO	Hybrid	2,475	0	56	1	3.4	4.3	0.1	13.7	3.5	18.0	21.5	1	645	Yes	0.44	6.24	1
504835	SORRENTO	Hybrid	2,316	17	18	9	3.0	1.9	16.0	8.8	19.0	10.7	29.7	218	35,255	Yes	-0.16	7.44	35
100139	DAYTONA BEACH	Hybrid	704	9	7	0	0.8	2.4	1.5	0.6	2.3	3.0	5.3	272	37,391	Yes	-0.20	4.30	13
203232	INDIALANTIC	Hybrid	1,128	25	23	6	1.9	1.0	7.1	6.8	9.0	7.8	16.8	1,417	81,030	Yes	-0.20	6.10	24
705538	SOUTHSIDE	Hybrid	2,019	18	23	11	2.9	1.2	2.9	2.3	5.8	3.5	9.3	534	80,771	Yes	-0.26	5.34	36
706964	CHAPEL	Hybrid	2,599	5	49	5	11.0	2.6	3.4	20.7	14.4	23.3	37.7	2,778	88,315	Yes	-0.51	14.09	30
505866	BUCKEYE	UG	1	0	0	0	-	1.1	-	-	-	1.1	1.1	-	-	Yes	10.52	10.52	0
402232	PRATT & WHITNEY	OH	-	0	0	0	1.6	-	-	-	-	1.6	-	1.6	-	Yes	0.36	2.96	0
209934	LIGHTHOUSE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.10	1.20	0
814132	BAUER	Hybrid	1,836	17	10	4	3.5	0.6	9.8	5.8	13.3	6.4	19.7	589	139,021	Yes	0.12	9.02	61
300632	LIVE OAK	Hybrid	712	33	10	7	8.4	-	16.9	2.6	25.3	2.6	27.9	29	5,251	Yes	-0.51	5.09	17
807839	WESTON VILLAGE	UG	6	0	1	0	-	5.7	-	-	-	5.7	5.7	-	-	Yes	-0.21	1.99	0
309461	GUMSWAMP	UG	1	0	0	0	-	0.9	-	-	-	0.9	0.9	-	-	Yes	0.10	2.50	0
802433	SOUTH MIAMI	Hybrid	1,485	32	13	6	3.2	-	12.3	2.1	15.5	2.1	17.6	775	167,713	Yes	-0.03	7.57	85
702835	PERRY	Hybrid	2,311	1	35	1	3.6	0.7	0.3	8.9	3.9	9.6	13.5	27	2,383	Yes	0.14	7.54	8
105062	SCOTTSMOOR	Hybrid	1,709	55	8	13	11.4	0.1	46.0	10.3	57.4	10.4	67.8	2,480	160,472	Yes	0.37	5.67	77
802233	GLADEVIEW	Hybrid	759	11	14	4	3.4	1.7	2.4	2.3	5.8	4.0	9.8	762	99,687	Yes	-0.25	3.15	15
502935	ONECO	Hybrid	1,608	15	26	4	3.8	1.2	4.4	4.6	8.2	5.8	14.0	109	6,901	Yes	-0.54	6.16	9
801034	NORMANDY BEACH	Hybrid	2,112	14	7	0	2.6	0.2	3.5	0.2	6.1	0.4	6.5	346	59,830	Yes	-0.18	5.92	22
702736	MCARTHUR	Hybrid	2,316	15	20	2	3.3	0.7	8.3	3.9	11.6	4.6	16.2	1,980	309,747	Yes	0.77	8.77	40
501133	FT MYERS	Hybrid	2,090	14	29	9	2.8	1.0	2.8	3.4	5.6	4.4	10.0	481	39,861	Yes	0.49	5.99	15
804937	OJUS	UG	1,438	0	13	0	-	2.3	-	4.2	-	6.5	6.5	1	302	Yes	-0.25	6.05	1
413531	VIOLET	Hybrid	1,734	19	30	7	5.2	0.6	8.8	9.8	14.0	10.4	24.4	5,870	255,270	Yes	-0.35	6.45	44
404633	PLATT	Hybrid	14	1	8	1	1.6	1.0	0.4	0.2	2.0	1.2	3.2	-	-	Yes	0.59	3.79	0
702836	PERRY	Hybrid	1,419	1	17	0	1.2	0.8	0.1	7.2	1.3	8.0	9.3	547	105,515	Yes	-0.24	7.76	27
808161	MILAM	UG	3,591	0	40	0	0.6	4.5	-	10.5	0.6	15.0	15.6	2,121	125,123	Yes	1.17	12.47	6
404037	WESTWARD	Hybrid	3,991	9	28	0	2.8	3.0	1.6	12.6	4.4	15.6	20.0	663	43,835	Yes	-0.05	8.15	11
700439	OAKLAND PARK	Hybrid	1,842	26	9	9	2.5	0.3	8.9	1.5	11.4	1.8	13.2	532	115,008	Yes	0.23	7.13	53
702740	MCARTHUR	Hybrid	2,310	3	21	2	1.8	0.8	2.1	7.1	3.9	7.9	11.8	4,307	97,955	Yes	-0.16	6.24	27
705236	TIMBERLAKE	Hybrid	2,100	6	53	3	4.5	1.3	0.5	13.6	5.0	14.9	19.9	2,312	132,051	Yes	-0.35	9.15	17
701036	SAMPLE ROAD	Hybrid	798	19	5	5	2.3	-	3.5	0.9	5.8	0.9	6.7	133	19,331	Yes	-0.16	3.14	17
704136	MOFFETT	Hybrid	1,028	13	5	2	2.5	1.5	4.9	0.6	7.4	2.1	9.5	1,154	102,990	Yes	-3.85	4.95	32
400831	PAHOKEE	Hybrid	325	8	3	1	5.8	-	2.8	0.9	8.6	0.9	9.5	65	9,270	Yes	-0.06	0.94	11

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
407032	RIO	Hybrid	2,367	15	59	6	6.0	3.5	3.9	17.9	9.9	21.4	31.3	158	23,272	Yes	0.06	8.56	34
701133	LYONS	Hybrid	1,712	11	18	6	1.9	0.3	4.3	4.6	6.2	4.9	11.1	178	25,777	Yes	0.10	7.20	18
105133	COMO	Hybrid	1,671	121	7	9	14.6	2.0	53.1	2.4	67.7	4.4	72.1	1,160	168,797	Yes	-0.11	4.89	92
703132	RAVENSWOOD	Hybrid	1,313	2	20	4	1.5	0.2	0.8	8.3	2.3	8.5	10.8	131	17,652	Yes	-2.52	4.48	16
406162	TURMPIKE	Hybrid	1,953	37	14	1	5.9	0.4	20.0	1.1	25.9	1.5	27.4	418	49,682	Yes	0.24	9.94	40
502168	BONITA SPRINGS	Hybrid	2,446	21	26	2	1.7	5.7	5.6	12.4	7.5	18.1	25.6	332	34,562	Yes	-0.35	8.05	31
706261	VALENCIA	Hybrid	2,453	4	44	2	5.4	2.6	1.7	14.0	7.1	16.6	23.7	2,720	60,384	Yes	0.40	9.70	26
703131	RAVENSWOOD	Hybrid	734	5	12	1	1.0	0.1	0.5	7.3	1.5	7.4	8.9	160	17,718	Yes	-0.29	4.01	12
405863	DELTRAIL	Hybrid	3,050	0	42	0	3.7	4.6	-	30.5	3.7	35.1	38.8	1,570	80,036	Yes	-0.15	10.85	14
101136	ORMOND	Hybrid	1,476	8	37	2	3.3	0.1	2.3	10.3	5.6	10.4	16.0	601	54,419	Yes	-0.26	5.84	25
709032	SPANGLER	UG	10	0	0	0	-	4.1	-	-	-	4.1	4.1	-	-	Yes	-2.42	3.08	0
405467	CLINTMOORE	Hybrid	1,739	1	36	1	2.4	3.5	0.2	24.8	2.6	28.3	30.9	1,592	82,977	Yes	0.11	13.31	25
800941	40TH ST	Hybrid	870	13	4	5	2.6	0.7	3.4	1.1	6.0	1.8	7.8	240	57,905	Yes	0.24	6.94	29
301332	TRAIL RIDGE	UG	0	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.06	2.66	0
807935	MIAMI LAKES	Hybrid	1,955	0	28	0	1.0	2.9	-	9.7	1.0	12.6	13.6	1,663	19,801	Yes	0.06	6.96	9
100836	PORT ORANGE	Hybrid	1,311	5	33	4	2.7	0.3	1.3	10.4	4.0	10.7	14.7	197	27,164	Yes	-0.03	6.47	18
802438	SOUTH MIAMI	UG	1	0	0	0	-	2.8	-	-	-	2.8	2.8	-	-	Yes	0.06	1.46	0
508862	PANACEA	Hybrid	2,162	3	31	0	5.2	7.5	6.6	18.9	11.8	26.4	38.2	389	63,479	Yes	-0.01	6.19	18
804636	INDUSTRIAL	Hybrid	1,051	12	14	3	2.3	0.3	5.5	0.7	7.8	1.0	8.8	2,237	198,847	Yes	-0.14	7.66	56
800538	REVERSID	Hybrid	1,835	26	23	5	3.9	1.7	5.5	2.1	9.4	3.8	13.2	214	35,344	Yes	-0.25	6.75	23
811163	SPOONBILL	Hybrid	1,914	0	46	0	5.6	8.3	-	19.1	5.6	27.4	33.0	6	3,414	Yes	-1.37	10.83	1
406538	OSBORNE	Hybrid	1,776	6	27	2	3.5	1.3	1.0	20.0	4.5	21.3	25.8	224	24,165	Yes	-0.59	7.51	14
800933	40TH ST	Hybrid	673	15	4	1	2.8	0.3	2.5	0.1	5.3	0.4	5.7	653	132,271	Yes	-0.02	4.88	37
409361	SWEATT	Hybrid	957	74	9	17	34.6	2.6	114.9	14.6	149.5	17.2	166.7	2,553	318,819	Yes	0.11	4.61	88
401762	OLYMPIA	Hybrid	2,439	35	38	5	7.9	0.1	18.2	16.0	26.1	16.1	42.2	4,147	139,453	Yes	-0.37	10.83	63
800833	RAILWAY	UG	186	0	6	0	-	4.3	-	0.8	-	5.1	5.1	-	-	Yes	0.86	5.76	0
804131	GARDEN	Hybrid	1,307	34	8	1	3.8	0.2	8.8	0.8	12.6	1.0	13.6	2,031	57,895	Yes	-0.20	6.00	75
208162	HIELD	Hybrid	2,526	52	35	5	5.7	2.2	19.3	20.4	25.0	22.6	47.6	2,179	52,039	Yes	-0.37	11.63	27
705467	PHOENIX	UG	2,333	0	17	0	-	7.1	-	26.6	-	33.7	33.7	2,674	48,582	Yes	-0.89	11.81	27
401937	LINTON	Hybrid	1,423	1	32	5	2.9	1.1	1.0	2.8	3.9	3.9	7.8	81	11,276	Yes	-1.10	6.60	18
411862	EVERNIA	Hybrid	710	1	19	2	1.8	3.1	0.1	1.5	1.9	4.6	6.5	566	43,028	Yes	-0.93	4.57	4
500768	ENGLEWOOD	Hybrid	2,116	30	29	5	8.2	0.8	9.9	15.4	18.1	16.2	34.3	322	75,847	Yes	-0.18	6.82	35
208861	WINDOVER	Hybrid	3,309	21	41	8	4.5	1.1	8.7	18.8	13.2	19.9	33.1	417	72,332	Yes	-1.23	12.47	40
802739	MARION	Hybrid	1,680	3	26	1	1.2	2.2	1.0	8.3	2.2	10.5	12.7	2,538	123,761	Yes	0.13	5.03	15
405531	PRIMA VISTA	Hybrid	2,403	26	13	3	5.4	0.7	21.7	5.8	27.1	6.5	33.6	349	35,003	Yes	-0.06	9.54	46
404739	HILLSBORO	Hybrid	2,155	10	30	9	2.1	1.6	5.4	4.6	7.5	6.2	13.7	387	61,667	Yes	-0.30	7.40	31
810932	LATIN QUARTER	Hybrid	2,504	8	15	3	3.0	0.1	1.4	0.5	4.4	0.6	5.0	6,177	166,018	Yes	-0.06	5.74	22
804632	INDUSTRIAL	Hybrid	826	12	24	1	4.7	-	3.3	0.7	8.0	0.7	8.7	2,193	173,771	Yes	0.02	8.52	44
806332	ULETA	Hybrid	253	3	4	2	0.8	0.6	0.7	0.3	1.5	0.9	2.4	39	7,672	Yes	-0.08	2.42	5
200735	COCOA BEACH	Hybrid	2,066	8	30	7	2.3	0.2	1.7	2.5	4.0	2.7	6.7	290	42,266	Yes	0.10	4.90	17
403432	JENSEN	Hybrid	692	1	24	0	2.7	-	0.1	12.9	2.8	12.9	15.7	468	20,896	Yes	-0.15	5.55	8
800442	COCONUT GROVE	Hybrid	1,228	30	2	4	2.8	1.0	8.3	0.6	11.1	1.6	12.7	2,629	167,242	Yes	-0.03	7.37	68
500664	CORTEZ	Hybrid	3,123	29	81	18	7.1	6.4	10.6	16.1	17.7	22.5	40.2	2,290	92,134	Yes	0.01	12.31	52
402636	JUNO BEACH	Hybrid	1,439	2	27	2	1.3	2.2	0.5	5.8	1.8	8.0	9.8	18	2,361	Yes	-0.21	5.79	4
508863	PANACEA	Hybrid	3,832	55	19	0	8.2	0.6	62.7	5.8	70.9	6.4	77.3	512	29,559	Yes	0.25	15.65	57
502562	PALMA SOLA	Hybrid	2,942	58	30	9	5.7	3.7	12.4	10.8	18.1	14.5	32.6	338	59,807	Yes	-0.22	9.78	41
504533	TUTTLE	Hybrid	2,766	19	54	7	4.8	0.4	7.7	8.9	12.5	9.3	21.8	257	28,467	Yes	-0.23	8.57	23
701233	PLAYLAND	Hybrid	2,723	35	23	6	4.2	1.1	10.8	6.3	15.0	7.4	22.4	1,564	164,710	Yes	-0.18	6.32	64
805333	KEY BISCAYNE	Hybrid	908	0	11	1	0.3	2.5	-	2.1	0.3	4.6	4.9	1,840	47,864	Yes	0.97	5.07	5
414033	GRACEWOOD	Hybrid	363	2	16	2	0.8	0.2	1.1	5.3	1.9	5.5	7.4	37	2,846	Yes	-0.77	1.83	11
506161	METRO	Hybrid	1,568	20	6	7	3.0	0.1	9.5	3.4	12.5	3.5	16.0	367	40,999	Yes	-0.58	7.02	41
503636	EDISON	Hybrid	2,061	5	47	2	2.6	1.1	1.8	12.7	4.4	13.8	18.2	32	2,708	Yes	-0.36	6.94	6

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
100932	SOUTH DAYTONA	Hybrid	1,222	1	18	2	0.3	3.3	0.3	6.2	0.6	9.5	10.1	1,188	37,867	Yes	0.02	5.62	4
405764	SEBASTIAN	Hybrid	1,504	17	9	2	5.0	0.3	14.3	5.4	19.3	5.7	25.0	977	173,175	Yes	-1.23	5.87	29
507763	RATTLESNAKE	Hybrid	1,864	0	22	2	1.3	2.4	3.9	12.9	5.2	15.3	20.5	286	49,582	Yes	-0.26	5.84	17
407735	SQUARE LAKE	Hybrid	1,742	11	15	2	2.9	1.0	5.7	7.9	8.6	8.9	17.5	421	74,891	Yes	-0.33	8.37	36
812833	WILCOX	UG	16	0	0	0	-	3.5	-	-	-	3.5	3.5	-	-	Yes	0.19	5.59	0
204632	COLLEGE	Hybrid	2,022	4	48	1	4.4	0.5	0.2	13.5	4.6	14.0	18.6	645	20,911	Yes	-0.25	6.55	10
505463	WINKLER	Hybrid	3,212	6	54	8	4.5	3.2	4.6	32.5	9.1	35.7	44.8	3,296	195,349	Yes	-0.07	10.73	19
506863	NOTRE DAME	OH	1,776	41	5	2	10.3	0.3	62.0	0.7	72.3	1.0	73.3	442	65,468	Yes	-1.76	6.44	47
413932	TULIP	Hybrid	733	6	14	7	4.9	0.1	1.8	3.2	6.7	3.3	10.0	1,686	73,461	Yes	-0.01	2.29	19
413632	BONANZA	Hybrid	2,285	30	5	4	2.7	0.1	9.5	0.9	12.2	1.0	13.2	1,062	119,676	Yes	-0.21	3.99	44
414131	CANAL	Hybrid	733	8	26	5	4.7	-	1.8	4.4	6.5	4.4	10.9	108	27,460	Yes	-0.01	4.29	17
503033	PHILLIPPI	Hybrid	1,016	14	27	5	2.5	2.1	4.6	5.0	7.1	7.1	14.2	706	10,868	Yes	-1.73	5.27	24
807633	KILLIAN	Hybrid	1,186	2	45	1	3.3	2.8	0.4	11.4	3.7	14.2	17.9	241	44,153	Yes	-0.06	7.64	31
802831	ARCH CREEK	Hybrid	982	13	16	1	2.5	0.1	3.0	0.9	5.5	1.0	6.5	787	74,078	Yes	0.34	6.64	24
503633	EDISON	Hybrid	2,162	0	51	1	2.9	0.6	1.1	11.1	4.0	11.7	15.7	185	28,031	Yes	-0.06	5.84	16
406863	KIMBERLY	Hybrid	2,118	0	39	0	2.8	3.1	-	30.2	2.8	33.3	36.1	401	60,538	Yes	-0.59	12.11	21
201534	CITY POINT	Hybrid	1,486	8	14	7	2.2	1.0	7.6	4.4	9.8	5.4	15.2	426	63,075	Yes	0.00	6.80	36
403236	ATLANTIC	Hybrid	606	0	22	0	1.0	1.7	-	5.5	1.0	7.2	8.2	1,384	31,823	Yes	0.41	6.11	12
203535	HIBISCUS	Hybrid	405	15	17	4	3.9	0.3	3.0	1.6	6.9	1.9	8.8	14	1,309	Yes	1.12	7.62	3
308063	MILLS	Hybrid	628	32	8	9	7.7	-	13.5	3.1	21.2	3.1	24.3	1,196	14,501	Yes	-2.43	2.37	15
700734	FAIRMONT	Hybrid	2,641	31	10	8	3.8	-	9.9	2.6	13.7	2.6	16.3	1,302	102,677	Yes	-0.03	6.87	44
703032	ROHAN	Hybrid	1,274	20	10	4	3.2	0.1	6.6	1.9	9.8	2.0	11.8	746	131,009	Yes	-0.03	6.97	61
201633	PALM BAY	Hybrid	2,014	32	17	7	4.6	0.8	13.0	3.7	17.6	4.5	22.1	323	47,877	Yes	0.12	6.82	48
814261	MANGO	Hybrid	326	31	6	5	7.2	1.5	17.7	1.2	24.9	2.7	27.6	126	22,842	Yes	-6.93	2.37	28
801736	62ND AVE	Hybrid	1,045	33	2	4	4.8	0.2	6.0	0.4	10.8	0.6	11.4	2,557	127,870	Yes	-0.02	7.08	66
800739	HIALEAH	Hybrid	2,689	15	7	4	3.1	0.8	4.8	0.5	7.9	1.3	9.2	3,200	169,167	Yes	-0.72	8.18	35
706463	HOLMBERG	Hybrid	1,569	8	37	3	2.5	0.5	6.4	17.5	8.9	18.0	26.9	557	73,553	Yes	-0.40	10.10	30
204264	BABCOCK	Hybrid	2,430	47	13	5	6.6	0.2	25.9	2.9	32.5	3.1	35.6	5,908	127,623	Yes	-5.25	10.05	64
106365	REGIS	Hybrid	3,011	25	21	3	8.4	0.2	26.0	6.7	34.4	6.9	41.3	3,808	193,829	Yes	-0.33	11.37	50
101131	ORMOND	Hybrid	1,331	43	3	6	4.1	0.9	12.0	1.2	16.1	2.1	18.2	862	105,042	Yes	-0.06	6.74	66
502461	LABELLE	Hybrid	3,259	52	42	14	18.6	3.0	109.4	23.8	128.0	26.8	154.8	7,639	394,366	Yes	0.58	12.48	72
705163	JACARANDA	Hybrid	1,783	2	42	1	4.0	0.6	0.3	13.0	4.3	13.6	17.9	245	71,807	Yes	0.04	8.54	19
510932	ITALY	Hybrid	1,362	6	12	9	1.1	0.9	5.1	1.6	6.2	2.5	8.7	1,480	99,266	Yes	7.03	7.03	22
405635	FOUNTAIN	Hybrid	2,363	6	32	0	3.6	0.1	0.5	10.2	4.1	10.3	14.4	202	16,525	Yes	0.06	4.56	11
800244	MIAMI BEACH	UG	683	0	12	3	-	4.9	0.1	2.9	0.1	7.8	7.9	17	357	Yes	-0.38	3.92	1
507663	GLADIOLUS	Hybrid	2,677	1	36	1	2.0	1.4	0.1	17.4	2.1	18.8	20.9	599	53,654	Yes	-0.63	14.67	19
808933	OLYMPIA HEIGHTS	Hybrid	1,332	24	6	3	3.1	0.1	6.9	0.8	10.0	0.9	10.9	225	34,082	Yes	-0.26	6.84	39
800850	RAILWAY	UG	383	0	2	1	-	3.2	0.1	1.0	0.1	4.2	4.3	16	3,469	Yes	-0.14	2.56	3
210133	DERBY	Hybrid	1,120	23	18	4	3.5	1.3	9.0	6.1	12.5	7.4	19.9	1,048	110,679	Yes	-0.25	5.75	45
400139	WEST PALM BEACH	Hybrid	1,344	1	11	0	0.2	2.4	-	0.1	0.2	2.5	2.7	-	-	Yes	0.04	3.34	0
204065	DELTONA	Hybrid	2,611	38	20	2	5.1	0.7	22.6	9.6	27.7	10.3	38.0	2,044	71,184	Yes	-0.38	10.32	48
501132	FT MYERS	Hybrid	1,044	5	5	1	0.8	2.1	0.3	0.3	1.1	2.4	3.5	-	-	Yes	-0.18	3.12	0
701431	PORT	Hybrid	478	6	12	1	1.6	1.0	0.8	1.1	2.4	2.1	4.5	7	823	Yes	0.38	4.98	3
508633	LIME	UG	-	1	7	1	0.1	3.6	-	1.3	0.1	4.9	5.0	-	-	Yes	0.00	0.00	0
702263	MARGATE	UG	1,698	0	22	0	0.5	3.4	-	15.0	0.5	16.4	18.9	476	103,321	Yes	-0.01	7.59	26
400433	HILLCREST	Hybrid	1,412	30	4	0	3.5	0.7	5.8	0.6	9.3	1.3	10.6	219	30,704	Yes	-0.24	5.36	28
413537	VIOLET	Hybrid	1,364	12	24	5	3.7	0.6	12.9	15.7	16.6	16.3	32.9	1,117	33,950	Yes	-0.12	4.88	26
802032	CUTLER	Hybrid	1,068	23	19	3	3.8	0.2	9.2	5.5	13.0	5.7	18.7	1,597	130,956	Yes	-0.23	7.37	67
801839	BISCAYNE	Hybrid	2,180	25	25	8	3.9	0.2	6.8	3.1	10.7	3.3	14.0	7,910	408,006	Yes	-0.23	6.47	89
809343	RONEY	Hybrid	3,465	5	6	4	1.0	1.6	1.0	0.4	2.0	2.0	4.0	401	73,542	Yes	0.20	5.30	8
809432	SAGA	UG	1	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.69	3.79	0
408966	PLUMOSUS	Hybrid	1,131	0	24	2	1.7	2.3	0.2	5.2	1.9	7.5	9.4	155	10,014	Yes	-0.71	5.49	10

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
707734	GOOLSBY	UG	1	0	2	0	-	0.5	-	-	-	0.5	0.5	-	-	Yes	0.60	2.10	0
804432	VENETIAN	Hybrid	1,737	7	18	1	2.0	0.4	0.6	1.7	2.6	2.1	4.7	316	65,390	Yes	-0.54	5.76	18
701738	STIRLING	Hybrid	1,223	4	25	0	2.1	0.5	0.7	8.1	2.8	8.6	11.4	134	17,579	Yes	-0.72	6.68	18
509863	ANGLER	Hybrid	2,563	22	43	10	4.2	2.5	11.5	8.7	15.7	11.2	26.9	2,770	192,639	Yes	0.14	15.64	58
504535	TUTTLE	Hybrid	1,665	17	16	9	3.1	0.3	11.6	4.1	14.7	4.4	19.1	1,207	98,153	Yes	-0.47	7.63	35
101534	GENERAL ELECTRIC	Hybrid	400	3	20	5	3.1	-	0.8	2.7	3.9	2.7	6.6	172	23,371	Yes	0.00	3.60	5
405032	SANDALFOOT	Hybrid	2,307	5	31	2	2.6	0.9	0.5	12.2	3.1	13.1	16.2	346	56,477	Yes	0.32	8.72	30
707265	FLAMINGO	Hybrid	3,094	0	40	0	2.3	2.9	-	18.5	2.3	21.4	23.7	56	2,821	Yes	-0.17	12.03	5
801232	OPA LOCKA	Hybrid	1,361	17	37	1	4.7	2.8	2.4	8.8	7.1	11.6	18.7	163	26,357	Yes	-0.13	11.27	20
205531	DAIRY	Hybrid	1,375	1	25	1	1.4	2.0	0.3	14.5	1.7	16.5	18.2	389	58,092	Yes	-0.54	5.26	18
301562	WIREMILL	Hybrid	423	31	5	3	10.9	1.6	12.9	0.6	23.8	2.2	26.0	165	28,343	Yes	-0.35	2.15	14
507665	GLADIOLUS	Hybrid	2,984	1	52	2	2.6	1.9	1.0	28.8	3.6	30.7	34.3	1,462	33,128	Yes	-0.55	9.65	11
806031	GOLDEN GLADES	Hybrid	1,448	22	10	6	2.7	2.6	8.4	4.1	11.1	6.7	17.8	1,433	141,598	Yes	0.61	6.91	75
803538	MARKET	Hybrid	2,518	13	19	8	3.7	0.8	2.5	2.8	6.2	3.6	9.8	3,191	149,617	Yes	0.21	9.61	19
704561	MALLARD	Hybrid	3,788	0	40	0	2.0	1.8	-	22.2	2.0	24.0	26.0	1,272	138,773	Yes	-0.73	10.97	35
402763	PORT MAYACA	Hybrid	555	55	18	10	33.3	1.7	41.7	20.7	75.0	22.4	97.4	300	32,884	Yes	0.31	3.31	25
800446	COCONUT GROVE	UG	637	0	5	0	-	2.4	-	0.3	-	2.7	2.7	-	-	Yes	-0.21	5.29	0
503436	SOUTH VENICE	Hybrid	1,898	17	28	5	3.5	0.1	7.6	12.4	11.1	12.5	23.6	1,227	171,730	Yes	-0.56	7.34	22
809832	DUMFOUNDLING	UG	728	0	3	0	-	2.1	-	2.2	-	4.3	4.3	80	4,800	Yes	-1.91	1.39	1
505763	AUBURN	Hybrid	2,732	0	36	1	5.1	2.5	0.2	27.5	5.3	30.0	35.3	247	47,891	Yes	-0.22	11.38	12
506164	METRO	Hybrid	2,460	22	43	10	6.4	1.3	4.9	9.7	11.3	11.0	22.3	3,165	148,541	Yes	0.29	11.29	44
506768	VANDERBILT	Hybrid	3,417	11	56	1	3.5	6.1	2.3	31.6	5.8	37.7	43.5	320	71,554	Yes	-0.45	12.15	20
701933	HOLY CROSS	Hybrid	1,476	7	19	3	1.3	1.1	2.3	1.1	3.6	2.2	5.8	1,652	81,432	Yes	-1.08	4.32	15
700134	SISTRUNK	Hybrid	1,326	9	18	9	2.3	3.0	4.6	1.7	6.9	4.7	11.6	705	127,346	Yes	-0.14	7.46	33
703133	RAVENSWOOD	Hybrid	1,600	3	27	0	2.5	0.2	0.5	10.9	3.0	11.1	14.1	59	9,084	Yes	0.08	5.28	6
210131	DERBY	Hybrid	1,933	7	30	2	2.7	0.8	2.0	11.5	4.7	12.3	17.0	802	46,129	Yes	-0.30	8.00	15
805032	UNIVERSITY	UG	13	0	10	0	-	3.2	-	0.5	-	3.7	3.7	-	-	Yes	0.75	3.95	0
403438	JENSEN	Hybrid	1,503	2	35	3	3.3	2.9	3.0	18.1	6.3	21.0	27.3	68	8,404	Yes	-0.05	6.45	16
413831	CHAMBERS	UG	219	0	1	0	-	0.6	-	10.8	-	11.4	11.4	714	139,004	Yes	-0.06	2.04	9
701631	PLANTATION	Hybrid	693	7	12	3	2.3	0.2	2.0	1.6	4.3	1.8	6.1	801	57,565	Yes	0.13	3.93	15
807831	WESTON VILLAGE	OH	1,494	26	6	1	3.1	0.1	10.9	0.5	14.0	0.6	14.6	1,095	146,570	Yes	0.38	8.18	100
402762	PORT MAYACA	Hybrid	3	0	6	1	1.6	8.5	1.7	9.8	3.3	18.3	21.6	3	520	Yes	0.05	1.45	2
807961	MIAMI LAKES	UG	1,614	1	31	0	0.7	3.1	0.2	18.6	0.9	21.7	22.6	242	16,940	Yes	-0.81	10.99	15
208164	HIELD	Hybrid	2,622	66	39	8	8.9	1.3	28.8	11.7	37.7	13.0	50.7	824	173,600	Yes	-2.25	15.35	57
102032	BULOW	Hybrid	1,063	13	10	6	5.7	0.5	4.7	5.2	10.4	5.7	16.1	1,003	79,382	Yes	-1.61	2.19	38
701039	SAMPLE ROAD	Hybrid	1,127	20	7	0	2.8	0.7	4.4	1.2	7.2	1.9	9.1	259	50,138	Yes	-0.01	2.79	30
403634	SOUTH BAY	OH	169	12	10	4	63.6	0.9	24.7	3.0	88.3	3.9	92.2	764	94,954	Yes	0.13	2.03	43
505067	JETPORT	Hybrid	3,777	15	55	7	6.4	5.9	7.8	36.7	14.2	42.6	56.8	3,437	57,221	Yes	16.01	16.01	24
704563	MALLARD	Hybrid	2,159	0	50	0	3.4	0.4	-	14.8	3.4	15.2	18.6	2,997	165,631	Yes	-0.31	8.29	37
400432	HILLCREST	Hybrid	2,643	27	22	3	5.5	1.3	10.2	7.2	15.7	8.5	24.2	1,517	134,733	Yes	0.20	9.20	51
702234	MARGATE	Hybrid	1,457	4	28	2	3.1	0.2	1.7	10.5	4.8	10.7	15.5	1,197	99,850	Yes	0.70	7.80	19
503131	SOLANA	Hybrid	2,055	0	37	3	2.0	2.7	1.0	14.4	3.0	17.1	20.1	4,398	51,142	Yes	-0.73	5.87	22
301139	COLUMBIA	Hybrid	819	45	4	11	9.0	2.0	30.1	4.0	39.1	6.0	45.1	1,243	162,620	Yes	-0.30	3.90	47
408333	MONTEREY	Hybrid	1,413	7	38	7	3.1	4.0	2.7	9.4	5.8	13.4	19.2	82	25,385	Yes	-0.43	5.97	7
807832	MIAMI LAKES	Hybrid	1,686	3	20	1	0.9	2.6	1.0	14.6	1.9	17.2	19.1	539	41,516	Yes	-0.56	6.74	18
408666	HOMELAND	Hybrid	2,019	14	36	1	7.2	3.4	18.7	23.9	25.9	27.3	53.2	561	112,238	Yes	-1.32	10.18	40
407931	QUANTUM	Hybrid	2,442	22	36	8	4.2	0.1	7.5	5.7	11.7	5.8	17.5	3,208	191,850	Yes	-1.69	8.71	49
701161	LYONS	UG	1,692	1	10	0	0.1	5.2	0.1	0.7	0.2	5.9	6.1	415	1,675	Yes	-0.26	5.94	2
705468	PHOENIX	Hybrid	3,143	0	41	0	2.7	4.6	-	22.6	2.7	27.2	29.9	15,922	293,641	Yes	-1.47	15.03	29
109962	PACETTI	Hybrid	653	22	18	0	3.6	2.0	5.1	9.8	8.7	11.8	20.5	630	30,662	Yes	6.17	6.17	15
807166	PENNSUCO	Hybrid	60	5	14	1	4.7	2.1	0.7	1.6	5.4	3.7	9.1	11	1,054	Yes	0.55	13.85	3
703739	CRYSTAL	Hybrid	1,391	3	34	0	2.1	1.0	0.2	6.5	2.3	7.5	9.8	814	11,876	Yes	-0.31	5.39	16

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
102131	DELAND	Hybrid	429	19	13	14	9.6	10.4	41.6	11.2	51.2	21.6	72.8	221	34,288	Yes	0.35	2.35	22
403738	MONET	Hybrid	2,003	1	33	0	1.7	3.1	-	15.8	1.7	18.9	20.6	1,234	62,700	Yes	0.04	6.64	12
410162	PLAZA	Hybrid	1,628	0	31	0	4.3	1.6	-	16.7	4.3	18.3	22.6	2,015	36,374	Yes	-0.42	7.48	10
407936	QUANTUM	Hybrid	2,353	26	14	9	4.8	0.4	10.1	2.0	14.9	2.4	17.3	552	80,276	Yes	0.35	7.75	39
502061	MURDOCK	Hybrid	1,753	12	29	4	4.5	0.9	4.7	4.8	9.2	5.7	14.9	2,038	95,871	Yes	-2.23	5.57	6
702231	MARGATE	Hybrid	1,765	35	8	2	3.7	0.6	10.7	1.4	14.4	2.0	16.4	1,163	98,291	Yes	-0.34	7.86	74
107163	HIGHRIDGE	UG	2	0	0	0	-	4.9	-	-	-	4.9	4.9	-	-	Yes	1.44	9.94	0
504061	CAPRI	Hybrid	2,955	11	40	6	4.4	2.0	5.3	23.0	9.7	25.0	34.7	236	35,783	Yes	-0.55	7.55	27
802534	GREYNOLDS	Hybrid	2,172	2	23	6	2.6	0.9	2.1	1.9	4.7	2.8	7.5	248	24,047	Yes	0.18	6.18	14
408332	MONTEREY	Hybrid	2,428	8	37	4	4.5	1.7	2.8	11.3	7.3	13.0	20.3	53	11,559	Yes	-0.42	6.78	6
201832	MINUTEMAN	Hybrid	930	14	7	3	1.9	0.1	4.5	4.1	6.4	4.2	10.6	635	26,151	Yes	0.11	4.91	13
408335	MONTEREY	Hybrid	594	2	21	1	1.8	0.9	0.7	2.8	2.5	3.7	6.2	473	18,342	Yes	0.05	3.25	6
701041	SAMPLE ROAD	Hybrid	1,008	1	21	1	1.1	3.2	0.5	1.7	1.6	4.9	6.5	47	4,685	Yes	-0.04	2.26	4
804833	COUNTY LINE	Hybrid	1,279	7	17	3	2.0	0.7	5.0	5.7	7.0	6.4	13.4	472	59,201	Yes	-0.22	5.68	33
400233	DATURA ST	Hybrid	266	7	9	4	1.8	2.0	1.0	1.3	2.6	3.3	5.9	39	5,589	Yes	-0.16	7.24	9
502837	PAYNE	Hybrid	331	6	12	3	2.0	3.6	1.6	2.3	3.6	5.9	9.5	535	14,028	Yes	0.28	4.18	10
813235	KNOWLTON	UG	1,729	1	6	0	-	3.2	-	-	1.2	-	4.4	4.4	-	Yes	-0.45	7.95	0
200132	SANFORD	Hybrid	1,079	23	25	12	5.3	0.2	9.1	5.3	14.4	5.5	19.9	344	26,816	Yes	0.15	8.95	26
500331	VENICE	Hybrid	2,284	12	43	7	2.9	0.6	5.4	5.4	8.3	6.0	14.3	258	34,886	Yes	-0.21	5.99	24
104837	TAYLOR	Hybrid	859	1	20	0	1.0	0.3	-	9.0	1.0	9.3	10.3	134	16,525	Yes	0.02	3.12	13
407863	TARTAN	Hybrid	3,044	4	46	3	3.1	1.0	1.2	23.0	4.3	24.0	28.3	1,225	52,519	Yes	-2.84	11.26	17
811935	OVERTOWN	UG	1,936	0	13	1	-	3.0	-	2.2	-	5.2	5.2	1	292	Yes	-0.09	6.41	1
500334	VENICE	Hybrid	710	7	15	2	2.5	0.1	0.9	2.9	3.4	3.0	6.4	721	41,030	Yes	-0.13	2.77	7
404832	GERMANTOWN	Hybrid	2,683	3	56	3	4.7	2.0	0.8	17.7	5.5	19.7	25.2	5,059	71,197	Yes	-0.09	8.31	16
700438	OAKLAND PARK	Hybrid	1,476	17	13	7	2.9	0.4	5.1	0.9	8.0	1.3	9.3	676	103,575	Yes	-0.09	5.61	27
502204	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-0.73	1.87	0
203541	HIBISCUS	Hybrid	1,880	22	34	8	3.5	0.2	4.7	16.0	8.2	16.2	24.4	598	47,147	Yes	0.22	8.12	33
810363	NEWTON	Hybrid	2,677	0	68	2	2.8	4.9	0.9	29.2	3.7	34.1	37.8	558	91,975	Yes	-0.32	16.18	18
102234	MADISON	Hybrid	1,318	23	6	5	3.1	2.0	6.3	1.8	9.4	3.8	13.2	2,106	58,003	Yes	-0.18	5.32	24
700242	HOLLYWOOD	UG	1	0	1	0	-	1.6	-	-	-	1.6	1.6	-	-	Yes	-0.07	4.53	0
411462	WESTLAKE	UG	1,349	1	40	1	-	6.5	0.3	19.8	0.3	26.3	26.6	28	1,811	Yes	1.93	4.93	7
411963	TESORO	Hybrid	2,767	40	15	0	5.8	0.4	31.0	6.9	36.8	7.3	44.1	630	90,701	Yes	-0.61	13.19	40
803934	SUNNY ISLES	UG	1,099	0	7	0	-	3.9	-	0.8	-	4.7	4.7	397	23,933	Yes	0.21	4.11	6
402234	PRATT & WHITNEY	OH	-	0	0	0	1.6	-	-	-	1.6	-	1.6	-	-	Yes	0.00	2.80	0
809662	COURT	Hybrid	3,543	1	79	0	5.0	3.5	0.2	27.3	5.2	30.8	36.0	3,516	261,972	Yes	0.39	14.99	25
806739	IVES	Hybrid	691	12	5	0	1.2	1.1	4.6	2.1	5.8	3.2	9.0	392	88,082	Yes	-0.13	4.27	49
505163	PROCTOR	Hybrid	1,952	10	51	4	4.7	0.3	2.6	16.3	7.3	16.6	23.9	203	21,144	Yes	-0.36	8.74	15
202234	MIMS	Hybrid	1,638	34	8	7	6.6	0.3	23.3	3.4	29.9	3.7	33.6	10,534	293,592	Yes	-0.30	6.90	65
804934	OJUS	UG	1,169	0	6	0	-	2.1	-	1.2	-	3.3	3.3	410	17,960	Yes	0.77	3.37	1
506962	WOODS	Hybrid	2,977	23	69	8	6.8	2.1	5.9	25.2	12.7	27.3	40.0	473	67,008	Yes	-0.77	10.73	33
701837	ROCK ISLAND	Hybrid	1,841	18	11	2	3.7	-	9.6	1.9	13.3	1.9	15.2	3,072	122,481	Yes	-0.30	7.80	50
703833	HIGHLANDS	Hybrid	1,284	12	18	1	2.5	0.2	2.2	5.1	4.7	5.3	10.0	171	30,211	Yes	0.58	6.38	27
405931	BUTTS	Hybrid	1,047	1	27	0	1.5	1.6	0.1	13.8	1.6	15.4	17.0	653	41,021	Yes	-0.16	7.04	12
807433	VILLAGE GREEN	Hybrid	1,438	13	16	0	3.6	0.4	7.7	1.6	11.3	2.0	13.3	142	32,232	Yes	-0.30	7.00	32
806532	SUNILAND	Hybrid	812	18	12	5	3.7	0.1	7.1	3.1	10.8	3.2	14.0	203	29,701	Yes	-0.29	4.81	32
800102	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	2.22	2.22	0
401635	OKEECHOBEE	Hybrid	1,596	35	9	6	5.7	0.2	16.0	4.2	21.7	4.4	26.1	1,894	53,076	Yes	0.08	6.28	31
702232	MARGATE	Hybrid	1,658	0	24	0	2.0	1.2	-	12.2	2.0	13.4	15.4	1,180	19,096	Yes	0.31	7.41	10
700238	HOLLYWOOD	Hybrid	-	0	0	0	0.1	0.7	-	-	0.1	0.7	0.8	-	-	Yes	-0.03	1.37	0
204531	BARWICK	Hybrid	2,212	23	49	9	6.8	1.9	16.9	19.4	23.7	21.3	45.0	207	49,601	Yes	-0.29	9.61	30
404235	BOCA TEECA	Hybrid	544	1	24	1	2.8	0.7	0.1	2.5	2.9	3.2	6.1	582	1,901	Yes	-0.08	5.32	8
507166	POLO	Hybrid	1,416	31	31	9	14.6	32.5	33.9	37.7	48.5	70.2	118.7	687	93,906	Yes	7.42	7.42	49
706864	CONSERVATION	Hybrid	2,774	0	27	3	2.4	5.6	1.5	13.7	3.9	19.3	23.2	29	10,489	Yes	8.36	8.36	10
100937	SOUTH DAYTONA	Hybrid	1,600	21	12	8	3.4	0.1	8.1	3.7	11.5	3.8	15.3	277	29,286	Yes	-0.15	5.95	32
403038	MILITARY TRAIL	Hybrid	2,194	12	29	3	3.0	1.5	7.4	11.7	10.4	13.2	23.6	687	177,887	Yes	-0.16	7.54	48

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
109035	WRIGHT	Hybrid	1,735	6	34	1	4.6	0.6	0.5	10.9	5.1	11.5	16.6	49	7.163	Yes	0.61	6.71	4
202131	INDIAN RIVER	Hybrid	1,940	30	35	6	4.9	0.4	6.9	3.8	11.8	4.2	16.0	1,164	93,880	Yes	-0.09	6.91	38
802633	AIRPORT	UG	3	0	5	0	-	2.3	-	0.3	-	2.6	2.6	-	-	Yes	-0.06	1.44	0
200731	COCOA BEACH	Hybrid	1,490	19	9	11	2.2	0.1	4.1	1.8	6.3	1.9	8.2	1,803	59,930	Yes	0.01	5.01	27
503764	HARBOR	Hybrid	3,569	34	65	13	10.7	1.0	17.6	30.3	28.3	31.3	59.6	1,598	148,964	Yes	1.26	12.96	32
503561	ALLIGATOR	Hybrid	3,353	7	42	7	3.3	0.4	4.5	17.8	7.8	18.2	26.0	186	29,471	Yes	-0.60	7.10	12
406167	TURNPIKE	Hybrid	2,524	62	2	0	5.6	0.6	26.1	1.8	31.7	2.4	34.1	2,962	45,105	Yes	-0.33	10.67	40
811633	LUMMUS	UG	138	1	10	0	-	5.9	-	1.1	-	7.0	7.0	-	-	Yes	-0.43	2.07	0
403737	MONET	Hybrid	525	1	30	0	1.2	3.8	-	6.4	1.2	10.2	11.4	-	-	Yes	0.10	5.80	0
405033	SANDALFOOT	Hybrid	769	0	19	0	3.1	0.3	-	9.5	3.1	9.8	12.9	770	2,772	Yes	-0.09	4.21	3
207861	OSTEEN	Hybrid	1,590	70	17	18	12.8	0.9	51.3	12.4	64.1	13.3	77.4	3,543	106,116	Yes	-0.21	7.69	50
703536	DEERFIELD BEACH	Hybrid	2,527	26	21	8	2.4	2.0	6.9	3.1	9.3	5.1	14.4	1,806	70,079	Yes	0.29	8.89	31
703834	HIGHLANDS	Hybrid	536	4	5	2	1.4	1.2	2.5	3.3	3.9	4.5	8.4	195	19,508	Yes	-0.25	3.95	30
500665	CORTEZ	Hybrid	3,514	24	58	10	8.2	1.5	9.5	19.5	17.7	21.0	38.7	2,246	167,252	Yes	-0.34	10.46	48
201734	SYKES CREEK	Hybrid	1,223	24	13	6	3.9	0.7	5.6	1.8	9.5	2.5	12.0	2,261	26,182	Yes	-0.10	6.60	26
813135	FIREHOUSE	Hybrid	1,824	7	22	2	2.0	1.3	0.8	0.7	2.8	2.0	4.8	7	1,329	Yes	0.27	5.17	5
201034	EAU GALLIE	Hybrid	2,302	13	35	5	4.0	0.4	2.4	17.8	6.4	18.2	24.6	236	27,466	Yes	-0.25	7.55	15
140466	GATLIN	UG	1,602	1	62	0	-	10.9	1.3	22.5	1.3	33.4	34.7	70	10,358	Yes	-2.52	11.98	8
803640	SEABOARD	UG	1	0	0	0	-	0.9	-	-	-	0.9	0.9	-	-	Yes	-0.55	1.55	0
209761	VIERA	UG	2,216	1	42	0	1.2	8.0	0.4	38.6	1.6	46.6	48.2	2	298	Yes	1.61	9.81	2
807335	GOULDS	Hybrid	825	4	11	1	1.8	0.5	1.3	5.6	3.1	6.1	9.2	2,376	140,088	Yes	0.02	3.92	23
800110	MIAMI	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	1.88	1.88	0
502533	PALMA SOLA	Hybrid	1,039	21	15	5	2.6	0.5	8.5	4.4	11.1	4.9	16.0	634	42,222	Yes	-0.02	5.68	39
502208	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-3.66	5.04	0
413232	WHEELER	Hybrid	674	33	11	3	20.9	1.8	16.5	1.3	37.4	3.1	40.5	62	8,246	Yes	0.42	5.02	14
501135	FT MYERS	Hybrid	1,029	22	6	4	3.2	0.5	9.5	1.2	12.7	1.7	14.4	788	56,796	Yes	0.63	6.13	28
505064	JETPORT	Hybrid	2,409	1	44	2	5.3	4.5	0.6	25.8	5.9	30.3	36.2	1,124	101,963	Yes	-0.68	10.72	9
702534	DAVIE	Hybrid	2,009	2	46	2	2.6	1.6	0.3	11.6	2.9	13.2	16.1	3,377	67,347	Yes	0.44	9.64	10
700340	PINEHURST	UG	-	0	0	0	-	2.2	-	-	-	2.2	2.2	-	-	Yes	1.59	4.19	0
408032	CALDWELL	Hybrid	1,215	10	8	6	2.6	0.1	3.2	1.1	5.8	1.2	7.0	269	36,259	Yes	-0.10	5.00	18
702140	CYPRESS CREEK	Hybrid	1,845	0	12	0	1.1	2.1	-	9.3	1.1	11.4	12.5	152	37,685	Yes	0.07	3.77	3
807542	DADELAND	Hybrid	2,233	0	22	1	0.7	2.1	0.3	5.1	1.0	7.2	8.2	834	44,704	Yes	-0.34	3.86	10
814262	MANGO	Hybrid	13	1	7	0	1.0	5.1	0.1	1.0	1.1	6.1	7.2	10	308	Yes	11.62	11.62	2
802532	GREYNOLDS	Hybrid	1,693	5	19	4	2.1	0.6	0.9	1.2	3.0	1.8	4.8	75	12,038	Yes	-0.30	5.40	9
502534	PALMA SOLA	Hybrid	1,371	6	23	5	2.2	0.3	7.1	7.7	9.3	8.0	17.3	694	136,581	Yes	-1.09	5.72	41
408668	HOMELAND	Hybrid	3,078	17	59	2	5.1	2.2	6.5	34.7	11.6	36.9	48.5	289	36,217	Yes	-0.11	15.59	29
807040	ROSELAWN	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.00	0.00	0
503136	SOLANA	Hybrid	1,215	0	25	0	1.0	3.8	-	7.8	1.0	11.6	12.6	835	27,623	Yes	-0.04	3.16	12
804536	GRATIGNY	Hybrid	1,611	3	11	5	1.8	1.3	3.1	2.9	4.9	4.2	9.1	1,028	116,168	Yes	-0.17	5.73	27
805732	GALLOWAY	Hybrid	812	29	9	8	4.8	0.4	11.6	1.7	16.4	2.1	18.5	781	174,545	Yes	-0.20	6.00	53
506462	FRANKLIN	Hybrid	3,980	55	45	12	12.3	6.0	41.2	33.5	53.5	39.5	93.0	2,981	252,105	Yes	0.15	11.75	60
800835	RAILWAY	Hybrid	1,886	11	13	0	1.5	1.0	1.2	1.2	2.7	2.2	4.9	119	14,270	Yes	0.64	3.64	11
203934	MCDONNELL	Hybrid	122	4	34	1	4.2	0.4	0.3	2.2	4.5	2.6	7.1	3	672	Yes	-1.16	5.14	2
207362	WYOMING	Hybrid	3,407	155	7	2	14.5	0.5	60.8	6.7	75.3	7.2	82.5	7,664	177,602	Yes	-0.32	13.38	105
504064	CAPRI	Hybrid	4,305	19	56	3	3.9	12.7	9.0	47.5	12.9	60.2	73.1	8,013	269,851	Yes	0.85	11.55	46
703832	HIGHLANDS	Hybrid	1,543	26	13	7	3.1	0.1	6.6	0.9	9.7	1.0	10.7	184	29,132	Yes	-0.01	6.29	30
704064	MOTOROLA	Hybrid	1,839	0	28	1	1.1	3.5	0.2	18.4	1.3	21.9	23.2	327	52,815	Yes	-0.52	9.48	25
813731	BOXCAR	UG	-	0	0	0	-	0.1	-	-	-	0.1	0.1	-	-	Yes	0.00	0.50	0
702738	MCARTHUR	Hybrid	2,166	13	25	3	2.9	1.3	5.5	5.5	8.4	6.8	15.2	3,079	239,458	Yes	0.12	7.22	49
104934	MOULTRIE	Hybrid	1,436	8	27	3	3.4	1.3	4.6	10.9	8.0	12.2	20.2	667	12,948	Yes	-0.19	4.61	15
102435	FLEMING	Hybrid	1,055	32	16	4	4.3	0.6	5.5	2.3	9.8	2.9	12.7	64	8,784	Yes	-0.12	3.98	15
203931	MCDONNELL	Hybrid	1,336	45	19	6	9.7	0.1	10.9	6.3	20.6	6.4	27.0	137	34,004	Yes	-0.27	5.43	29
803547	MARKET	UG	-	0	0	0	-	1.2	-	-	-	-	1.2	-	-	Yes	0.29	5.59	0
704669	SPRINGTREE	Hybrid	2,241	2	32	1	1.3	1.9	0.3	13.7	1.6	15.6	17.2	2,665	125,944	Yes	-1.72	8.78	22
803542	MARKET	UG	1	0	0	0	-	4.5	-	-	-	4.5	4.5	-	-	Yes	0.66	2.26	0

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
811261	EUREKA	Hybrid	2,071	26	41	1	6.2	2.0	10.3	22.4	16.5	24.4	40.9	631	107.188	Yes	-0.47	11.13	45
701932	HOLY CROSS	Hybrid	660	2	16	2	2.4	0.6	1.3	0.9	3.7	1.5	5.2	309	34.123	Yes	-0.07	3.83	8
407736	SQUARE LAKE	Hybrid	1,049	8	14	4	1.9	0.7	4.0	4.3	5.9	5.0	10.9	661	29.335	Yes	0.30	5.30	25
506662	LIVINGSTON	Hybrid	2,691	34	39	4	6.2	1.9	9.1	18.0	15.3	19.9	35.2	2,183	80.932	Yes	-0.02	11.28	41
504763	ALVA	OH	2,099	227	0	2	15.1	0.3	142.0	0.7	157.1	1.0	158.1	2,597	173.168	Yes	0.23	9.23	87
100138	DAYTONA BEACH	Hybrid	370	2	4	1	0.5	3.3	0.5	1.2	1.0	4.5	5.5	17	2,052	Yes	0.28	5.08	3
701534	DANIA	Hybrid	2,016	28	19	5	3.3	0.6	5.8	2.7	9.1	3.3	12.4	241	36.724	Yes	-0.06	7.44	38
508465	GATEWAY	UG	2,974	4	39	0	1.0	10.2	0.3	23.9	1.3	34.1	35.4	162	24,993	Yes	-4.26	8.14	9
209861	YORKE	Hybrid	870	21	37	8	4.7	0.5	7.0	7.2	11.7	7.7	19.4	2,388	64.441	Yes	0.85	10.05	26
402032	CLEWISTON	Hybrid	1,400	37	18	6	17.6	0.1	11.1	6.7	28.7	6.8	35.5	568	85.418	Yes	0.32	6.32	30
802738	MARION	Hybrid	1,075	2	23	0	1.4	1.9	0.3	7.1	1.7	9.0	10.7	1,271	50.095	Yes	-0.37	6.23	10
102365	ST JOE	Hybrid	2,884	16	68	3	4.2	18.2	3.1	39.2	7.3	57.4	64.7	3,637	112.768	Yes	0.11	11.41	33
807434	VILLAGE GREEN	Hybrid	1,120	12	21	2	2.6	0.2	5.8	2.9	8.4	3.1	11.5	568	24.465	Yes	-0.32	7.38	32
800740	HIALEAH	Hybrid	1,994	21	1	3	2.2	1.3	4.8	0.3	7.0	1.6	8.6	703	96.022	Yes	-0.10	6.30	43
407564	GLENDALE	Hybrid	2,502	12	40	9	5.1	1.9	6.2	18.3	11.3	20.2	31.5	942	40,346	Yes	-0.46	8.84	29
800441	COCONUT GROVE	UG	651	0	3	0	-	2.9	-	0.6	-	3.5	3.5	-	-	Yes	-0.62	2.48	0
403035	MILITARY TRAIL	Hybrid	1,813	18	27	0	4.2	-	6.9	4.6	11.1	4.6	15.7	2,162	147.162	Yes	-0.22	7.28	46
301132	COLUMBIA	Hybrid	828	26	11	3	5.2	0.2	7.9	1.4	13.1	1.6	14.7	121	21,968	Yes	-0.33	7.57	28
811931	OVERTOWN	UG	1,096	0	10	0	-	3.6	-	1.6	-	5.2	5.2	1	290	Yes	-0.43	7.87	1
403933	LAKE PARK	Hybrid	1,723	9	26	3	2.0	1.7	2.0	3.3	4.0	5.0	9.0	1,762	95.866	Yes	0.28	5.48	16
205363	GENEVA	Hybrid	909	36	8	11	9.2	2.6	39.0	4.7	48.2	7.3	55.5	3,618	161,916	Yes	-0.25	3.95	52
704767	STONEBRIDGE	Hybrid	2,730	14	40	4	4.6	0.8	5.9	21.8	10.5	22.6	33.1	403	76.662	Yes	-0.48	13.62	33
706362	BASSCREEK	Hybrid	1,858	2	28	2	2.5	2.1	0.6	18.9	3.1	21.0	24.1	1,655	19,848	Yes	-0.66	10.64	9
703637	PALM AIRE	Hybrid	208	1	21	1	1.8	0.3	0.2	2.1	2.0	2.4	4.4	20	2,655	Yes	0.04	3.44	5
502206	FRUIT INDUSTRIES	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-5.08	4.32	0
404332	IBM	UG	-	0	0	0	-	0.2	-	-	-	0.2	0.2	-	-	Yes	-0.10	3.70	0
701939	HOLY CROSS	Hybrid	2,268	15	25	4	4.1	0.5	3.9	1.5	8.0	2.0	10.0	4,496	229.113	Yes	-0.39	6.91	42
800935	40TH ST	UG	133	0	5	1	-	3.8	-	0.7	-	4.5	4.5	256	3,652	Yes	0.78	3.48	4
807931	MIAMI LAKES	Hybrid	1,179	2	29	1	2.1	2.6	0.9	13.1	3.0	15.7	18.7	1,103	40,655	Yes	-0.87	8.83	14
407865	TARTAN	Hybrid	3,393	0	45	0	3.8	0.4	-	20.2	3.8	20.6	24.4	502	49,587	Yes	-2.41	8.49	17
801133	FRONTON	Hybrid	1,155	22	9	2	4.1	0.4	3.9	0.6	8.0	1.0	9.0	1,599	72,316	Yes	-0.01	6.99	40
703542	DEERFIELD BEACH	Hybrid	1,278	9	15	3	1.8	0.4	4.6	5.3	6.4	5.7	12.1	150	19,165	Yes	-0.10	5.10	22
705867	REMSBURG	Hybrid	2,201	0	41	0	3.0	2.1	-	11.9	3.0	14.0	17.0	1,932	188,898	Yes	0.87	7.87	17
400734	BOCA RATON	Hybrid	1,244	1	21	0	0.5	1.0	-	0.7	0.5	1.7	2.2	11	1,692	Yes	-0.19	4.51	2
400735	BOCA RATON	Hybrid	1,652	15	24	4	3.3	0.2	2.9	2.8	6.2	3.0	9.2	102	22,900	Yes	0.12	5.52	13
201435	GRANDVIEW	Hybrid	2,346	42	19	3	4.6	-	14.3	10.0	18.9	10.0	28.9	1,337	68,761	Yes	-0.45	8.95	61
410863	SOUTHFORK	Hybrid	189	5	7	4	6.1	0.4	13.1	20.8	19.2	21.2	40.4	82	10,936	Yes	-0.25	2.05	11
404431	PURDY LANE	Hybrid	1,175	11	15	7	1.9	-	3.5	4.2	5.4	4.2	9.6	1,938	37,706	Yes	0.03	4.73	25
805734	GALLOWAY	UG	1	0	0	0	-	0.9	-	-	-	0.9	0.9	-	-	Yes	-0.03	1.67	0
211064	GARVEY	Hybrid	1,865	34	22	1	3.9	1.3	19.5	5.8	23.4	7.1	30.5	281	37,736	Yes	7.18	7.18	40
508262	RYE	Hybrid	3,244	4	66	3	5.5	8.2	1.4	38.2	6.9	46.4	53.3	177	25,382	Yes	0.73	12.23	11
809767	SWEETWATER	Hybrid	2,542	0	25	0	1.4	1.8	-	19.2	1.4	21.0	22.4	243	32,573	Yes	-0.61	11.99	16
804033	LE JEUNE	UG	16	0	10	0	0.2	7.2	-	1.9	0.2	9.1	9.3	-	-	Yes	-1.00	3.20	0
810934	LATIN QUARTER	Hybrid	2,448	20	11	5	2.9	0.2	3.0	0.4	5.9	0.6	6.5	745	59,779	Yes	-0.30	6.20	19
803434	MIAMI SHORES	Hybrid	1,480	18	1	1	1.7	1.1	7.2	1.9	8.9	3.0	11.9	480	72,689	Yes	0.20	6.00	44
101935	EDGEWATER	Hybrid	1,875	42	8	3	6.3	0.2	30.0	5.8	36.3	6.0	42.3	464	76,426	Yes	0.37	7.67	65
104836	TAYLOR	Hybrid	1,119	1	26	3	3.9	1.6	3.0	16.7	6.9	18.3	25.2	444	25,901	Yes	-0.17	4.73	17
701636	PLANTATION	Hybrid	2,027	23	21	4	4.6	0.2	8.0	5.1	12.6	5.3	17.9	589	74,129	Yes	-0.13	8.27	47
405262	ACME	Hybrid	2,551	2	38	1	4.9	2.5	0.9	25.4	5.8	27.9	33.7	169	20,017	Yes	-0.67	10.03	26
500234	BRADENTON	Hybrid	1,367	17	12	11	3.0	1.2	8.9	1.6	11.9	2.8	14.7	284	40,608	Yes	0.28	6.48	31
809934	SIMPSON	UG	496	0	6	0	-	1.9	-	0.8	-	2.7	2.7	-	-	Yes	-0.73	5.47	0
505065	JETPORT	UG	4,557	0	74	0	-	11.7	-	53.1	-	64.8	64.8	7,312	334,652	Yes	-1.53	14.67	18
204364	SUNTREE	Hybrid	678	2	19	3	1.9	1.0	0.4	10.6	2.3	11.6	13.9	30	2,946	Yes	-0.14	4.56	7
510162	HERCULES	UG	954	0	17	0	-	8.7	-	15.5	-	24.2	24.2	1,468	54,276	Yes	1.16	2.86	4
404337	IBM	Hybrid	281	2	31	0	1.8	3.0	0.9	2.6	2.7	5.6	8.3	21	2,421	Yes	0.63	6.73	6

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
402633	JUNO BEACH	Hybrid	1,667	5	33	1	2.1	1.8	2.0	11.8	4.1	13.6	17.7	809	27,664	Yes	-0.06	7.64	15
100231	ST AUGUSTINE	Hybrid	1,398	21	17	6	4.2	1.0	9.9	5.8	14.1	6.8	20.9	345	37,490	Yes	-0.23	5.77	50
804936	OJUS	UG	764	0	5	0	-	2.7	-	1.1	-	3.8	3.8	38	114	Yes	-0.11	4.09	1
102638	LEWIS	Hybrid	919	10	15	2	2.4	2.1	3.0	5.9	5.4	8.0	13.4	89	12,426	Yes	-0.14	4.46	15
814036	BRICKELL	Hybrid	2,229	17	16	0	2.6	2.5	1.0	0.3	3.6	2.8	6.4	2,631	155,148	Yes	-0.02	5.78	11
403936	LAKE PARK	Hybrid	1,462	8	27	1	2.5	0.8	5.3	3.9	7.8	4.7	12.5	2,053	131,293	Yes	-0.15	6.05	30
508062	COOPER	Hybrid	1,993	25	4	3	2.9	2.9	12.1	2.3	15.0	5.2	20.2	268	37,388	Yes	-0.45	6.95	43
408664	HOMELAND	Hybrid	1,636	7	52	11	10.6	0.6	10.7	33.9	21.3	34.5	55.8	3,512	247,990	Yes	-0.64	7.36	39
404033	WESTWARD	Hybrid	1,609	0	37	0	2.6	0.1	-	7.1	2.6	7.2	9.8	156	19,722	Yes	-0.08	6.22	6
804435	VENETIAN	UG	373	0	9	1	-	3.6	-	0.7	-	4.3	4.3	-	-	Yes	0.44	3.44	0
802440	SOUTH MIAMI	UG	104	0	1	0	-	0.9	-	0.2	-	1.1	1.1	-	-	Yes	0.16	4.26	0
405834	FOUNTAIN	Hybrid	3,045	11	40	3	5.0	0.5	7.4	7.5	12.4	8.0	20.4	253	31,438	Yes	-0.15	8.15	35
504965	GOLDEN GATE	Hybrid	3,073	26	15	8	6.3	0.3	21.7	6.4	28.0	6.7	34.7	571	64,106	Yes	-0.16	9.84	49
407233	JOG	Hybrid	1,806	7	27	1	2.5	1.1	1.2	13.3	3.7	14.4	18.1	112	16,758	Yes	0.38	7.38	10
404236	BOCA TEECA	Hybrid	565	9	12	1	1.9	1.8	2.2	2.3	4.1	4.1	8.2	121	8,566	Yes	0.10	3.40	15
702139	CYPRESS CREEK	Hybrid	175	0	46	0	2.3	0.1	-	3.4	2.3	3.5	5.8	24	1,767	Yes	0.14	6.84	4
813140	FIREHOUSE	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	0.02	0.02	0
201033	EAU GALLIE	Hybrid	1,836	34	11	4	2.7	-	12.2	3.7	14.9	3.7	18.6	452	79,910	Yes	0.01	6.41	30
807834	WESTON VILLAGE	Hybrid	131	1	15	2	1.4	0.1	0.5	1.5	1.9	1.6	3.5	82	11,152	Yes	0.12	4.82	6
801837	BISCAYNE	Hybrid	1,124	14	5	3	2.8	0.8	6.3	0.3	9.1	1.1	10.2	894	71,874	Yes	-0.15	5.65	54
500236	BRADENTON	Hybrid	217	3	14	4	1.3	1.2	0.5	1.0	1.8	2.2	4.0	50	4,943	Yes	-1.63	3.97	4
413834	CHAMBERS	UG	837	0	17	1	-	2.7	0.1	4.6	0.1	7.3	7.4	4	348	Yes	-0.13	2.07	2
102434	FLEMING	Hybrid	1,506	13	19	7	2.7	0.3	6.1	5.6	8.8	5.9	14.7	1,450	296,674	Yes	-0.23	4.67	32
400931	BELLE GLADE	Hybrid	275	7	6	2	1.3	-	2.1	0.3	3.4	0.3	3.7	85	7,499	Yes	-0.07	2.73	11
503966	ESTERO	Hybrid	2,188	10	49	2	4.2	5.3	5.4	16.7	9.6	22.0	31.6	164	24,760	Yes	0.30	11.00	22
405762	SEBASTIAN	Hybrid	3,312	60	20	19	8.7	0.6	26.7	8.9	35.4	9.5	44.9	6,094	495,638	Yes	-0.25	8.95	53
508264	RYE	Hybrid	2,748	35	48	7	8.7	7.8	12.1	43.9	20.8	51.7	72.5	896	56,743	Yes	-1.39	13.81	28
801836	BISCAYNE	Hybrid	1,284	17	5	8	3.0	0.2	5.7	1.5	8.7	1.7	10.4	685	126,460	Yes	0.07	6.67	69
700642	VERENA	Hybrid	2,969	28	24	5	3.5	0.6	6.0	4.1	9.5	4.7	14.2	941	131,268	Yes	-0.18	7.22	56
805937	COUNTRY CLUB	UG	2,140	0	22	0	0.1	2.6	-	12.0	0.1	14.6	14.7	149	24,546	Yes	-1.09	7.51	12
505665	ROTONDA	Hybrid	2,726	19	35	15	7.5	8.2	9.4	27.9	16.9	36.1	53.0	5,965	369,578	Yes	0.19	10.19	48
203532	HIBISCUS	Hybrid	800	18	8	2	3.0	0.3	6.0	2.3	9.0	2.6	11.6	97	30,834	Yes	-0.21	3.39	13
809536	VIRGINIA KEY	UG	1	0	2	0	-	2.4	-	-	-	2.4	2.4	-	-	Yes	-1.62	0.18	0
207364	WYOMING	Hybrid	1,716	116	11	1	12.9	4.8	41.4	8.6	54.3	13.4	67.7	182	20,520	Yes	-1.14	6.56	43
500531	CLARK	Hybrid	1,725	19	39	5	3.2	0.1	4.0	7.9	7.2	8.0	15.2	169	16,479	Yes	-0.07	2.63	22
809834	DUMFOUNDLING	Hybrid	1,357	7	17	1	1.0	2.5	2.1	1.3	3.1	3.8	6.9	2,093	153,749	Yes	-1.25	6.05	22
804831	COUNTY LINE	Hybrid	2,662	2	25	0	3.3	2.3	1.7	10.6	5.0	12.9	17.9	5,469	355,869	Yes	-0.03	6.77	21
404334	IBM	Hybrid	819	1	27	0	1.6	1.6	-	7.0	1.6	8.6	10.2	-	-	Yes	0.26	5.76	0
407867	TARTAN	Hybrid	2,960	2	44	2	3.3	1.2	0.4	15.5	3.7	16.7	20.4	294	28,719	Yes	8.78	8.78	12
701536	DANIA	Hybrid	2,985	10	35	5	3.5	0.4	2.2	8.3	5.7	8.7	14.4	183	22,490	Yes	-0.49	6.81	16
802531	GREYNOLDS	Hybrid	1,491	4	10	11	2.7	0.5	2.0	0.9	4.7	1.4	6.1	618	27,500	Yes	-0.14	4.56	13
301331	TRAIL RIDGE	Hybrid	936	51	9	5	17.8	0.3	26.5	3.3	44.3	3.6	47.9	425	68,767	Yes	-0.39	6.81	34
704937	LAKEVIEW	Hybrid	1,938	0	38	0	2.8	0.7	-	12.0	2.8	12.7	15.5	1,854	111,740	Yes	-0.34	7.86	15
506033	WALKER	Hybrid	1,561	21	11	5	2.9	-	9.7	3.7	12.6	3.7	16.3	320	32,677	Yes	-0.01	6.39	41
501832	TICE	Hybrid	2,470	34	19	12	4.8	0.6	22.9	6.8	27.7	7.4	35.1	977	122,107	Yes	-0.13	8.97	64
101937	EDGEWATER	Hybrid	2,131	32	9	1	2.3	1.2	17.8	2.6	20.1	3.8	23.9	399	50,640	Yes	0.03	7.93	53
808265	LINDGREN	UG	2,518	0	20	0	-	5.7	-	19.2	-	24.9	24.9	89	11,334	Yes	-1.01	9.99	20
507662	GLADIOLUS	Hybrid	4,255	2	56	7	4.7	1.3	6.7	24.4	11.4	25.7	37.1	434	60,443	Yes	-0.91	13.79	33
703432	RESERVATION	Hybrid	1,886	28	10	3	3.8	0.2	7.8	3.8	11.6	4.0	15.6	826	79,358	Yes	-0.10	8.40	49
307461	MINING	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-2.61	6.29	0
806133	DOUGLAS	Hybrid	600	0	7	2	0.5	2.2	0.1	0.6	0.6	2.8	3.4	1,173	20,902	Yes	0.34	3.04	5
700832	BEVERLY	Hybrid	1,533	31	6	4	3.0	1.0	7.2	0.6	10.2	1.6	11.8	5,467	232,319	Yes	0.15	7.35	46
803634	SEABOARD	Hybrid	1,040	19	9	1	2.8	0.8	3.2	0.6	6.0	1.4	7.4	1,166	97,331	Yes	-0.12	5.28	22
502934	ONECO	Hybrid	2,178	23	24	6	3.7	0.1	7.9	7.9	11.6	8.0	19.6	4,682	49,475	Yes	0.08	9.58	25
203035	FRONTENAC	OH	829	16	3	0	2.4	0.4	7.9	0.1	10.3	0.5	10.8	552	22,938	Yes	0.01	3.71	21

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
404132	GOLF	Hybrid	2,578	9	34	8	2.9	0.9	3.4	5.7	6.3	6.6	12.9	856	162,577	Yes	0.05	7.25	15
707531	COLLINS	UG	189	0	19	0	0.2	2.6	-	3.8	0.2	6.4	6.6	32	20,470	Yes	0.12	4.22	1
408033	CALDWELL	Hybrid	1,066	7	21	6	3.6	0.2	2.6	1.9	6.2	2.1	8.3	206	15,808	Yes	0.16	6.36	18
809037	AVENTURA	UG	1,874	0	12	0	-	4.6	-	3.0	-	7.6	7.6	704	68,050	Yes	-0.67	5.63	4
102033	BULOW	Hybrid	2,424	16	35	11	5.4	3.3	9.6	7.1	15.0	10.4	25.4	4,540	199,852	Yes	-0.66	6.54	63
413634	BONANZA	Hybrid	52	15	41	7	5.8	0.2	4.5	4.1	10.3	4.3	14.6	200	23,837	Yes	0.02	7.12	25
704761	STONEBRIDGE	Hybrid	2,809	58	52	5	8.5	1.2	11.0	21.1	19.5	22.3	41.8	5,175	71,986	Yes	-0.35	13.95	57
807332	GOULDS	Hybrid	291	1	11	0	0.7	2.0	-	0.6	0.7	2.6	3.3	11	1,320	Yes	-0.86	2.24	1
701162	LYONS	UG	3,724	0	19	0	-	7.6	-	1.4	-	9.0	9.0	1,797	98,623	Yes	-3.26	6.24	6
808831	SNAPPER CREEK	Hybrid	945	27	16	9	5.0	0.4	8.8	10.4	13.8	10.8	24.6	282	42,600	Yes	-0.08	8.72	57
705862	REMSBURG	Hybrid	2,951	6	41	1	2.9	0.3	2.9	8.1	5.8	8.4	14.2	629	116,191	Yes	-0.65	6.05	18
804236	PERRINE	Hybrid	1,557	20	29	9	4.5	0.6	7.1	2.5	11.6	3.1	14.7	242	70,078	Yes	0.12	6.52	41
803035	TROPICAL	Hybrid	1,448	21	2	1	2.0	0.2	10.2	0.6	12.2	0.8	13.0	544	104,444	Yes	-0.30	7.80	65
804133	GARDEN	Hybrid	1,376	6	21	9	2.7	1.6	6.2	4.8	8.9	6.4	15.3	400	47,019	Yes	0.59	8.49	46
701634	PLANTATION	Hybrid	1,015	19	10	4	4.6	0.2	6.9	3.9	11.5	4.1	15.6	499	88,549	Yes	0.03	8.13	32
707465	SAWGRASS	UG	5	0	2	0	-	3.0	-	0.6	-	3.6	3.6	-	-	Yes	-0.05	1.35	0
504137	BENEVA	Hybrid	1,489	23	20	11	2.9	1.0	9.9	3.4	12.8	4.4	17.2	2,340	113,216	Yes	-0.64	6.46	51
500438	HYDE PARK	Hybrid	330	5	7	0	1.0	0.6	2.5	0.2	3.5	0.8	4.3	161	26,912	Yes	-0.16	1.44	17
700965	HALLANDALE	UG	1,491	0	3	0	-	2.9	-	0.6	-	3.5	3.5	67	4,489	Yes	1.08	4.28	1
406531	OSBORNE	Hybrid	1,743	4	32	0	2.4	0.8	0.3	13.9	2.7	14.7	17.4	2	356	Yes	0.01	7.61	2
700633	VERENA	Hybrid	2,981	13	30	8	3.4	0.7	3.2	2.5	6.6	3.2	9.8	2,833	116,216	Yes	0.55	8.85	42
805935	COUNTRY CLUB	UG	3,767	0	28	0	0.2	2.9	-	10.4	0.2	13.3	13.5	42	24,736	Yes	0.77	3.97	2
500439	HYDE PARK	UG	2	0	1	0	-	1.7	-	-	-	1.7	1.7	-	-	Yes	0.68	8.78	0
800638	LITTLE RIVER	Hybrid	1,478	31	5	3	3.7	0.3	6.2	0.6	9.9	0.9	10.8	2,088	152,781	Yes	0.01	6.11	65
208634	TULSA	Hybrid	1,613	28	7	3	5.2	1.0	16.2	1.5	21.4	2.5	23.9	205	42,416	Yes	-0.01	6.89	26
402932	OSLO	Hybrid	2,884	52	24	2	6.6	-	15.2	12.0	21.8	12.0	33.8	2,984	178,475	Yes	-0.08	10.52	65
803038	TROPICAL	Hybrid	1,597	5	21	2	3.2	0.2	1.9	7.5	5.1	7.7	12.8	402	39,501	Yes	0.29	6.29	19
411861	PEACOCK	Hybrid	1,728	37	38	4	10.6	2.9	14.3	15.4	24.9	18.3	43.2	1,555	100,391	Yes	-0.06	9.24	19
405134	HUTCHINSON ISL	Hybrid	3,400	0	52	3	2.7	16.3	1.5	9.7	4.2	26.0	30.2	35	5,585	Yes	-0.30	6.40	17
308065	MILLS	Hybrid	1,867	36	13	12	8.4	1.0	36.7	19.2	45.1	20.2	65.3	4,650	212,895	Yes	-0.49	8.21	54
701231	PLAYLAND	Hybrid	470	5	15	4	2.7	1.9	1.1	2.5	3.8	4.4	8.2	51	7,607	Yes	0.28	3.78	7
502939	ONECO	Hybrid	2,639	22	21	7	2.8	0.6	6.9	8.1	9.7	8.7	18.4	826	145,856	Yes	-0.16	7.84	35
801935	DEAUVILLE	Hybrid	2,006	4	9	2	1.9	1.1	1.2	0.3	3.1	1.4	4.5	1,309	94,743	Yes	-0.03	4.17	18
504066	CAPRI	Hybrid	2,978	17	46	2	3.3	13.0	4.7	22.8	8.0	35.8	43.8	5,002	208,770	Yes	-0.35	9.35	19
401131	STUART	Hybrid	1,964	28	20	9	6.0	-	9.8	3.9	15.8	3.9	19.7	163	26,829	Yes	-0.29	7.11	31
207263	CHULUOTA	Hybrid	2,151	13	39	3	3.7	3.8	3.6	29.7	7.3	33.5	40.8	351	52,360	Yes	-1.34	12.36	15
207935	RINEHART	Hybrid	781	0	21	1	0.7	7.3	0.3	4.8	1.0	12.1	13.1	2	876	Yes	-0.44	5.36	2
101931	EDGEWATER	Hybrid	942	19	8	8	5.7	0.1	7.8	5.9	13.5	6.0	19.5	54	9,695	Yes	0.06	3.66	12
809833	DUMFOUNDLING	Hybrid	1,783	2	24	0	0.9	0.9	-	4.4	0.9	5.3	6.2	1,897	8,628	Yes	0.10	7.60	7
700840	BEVERLY	Hybrid	1,412	14	7	3	2.5	0.7	4.5	4.7	7.0	5.4	12.4	155	31,605	Yes	0.10	5.30	20
205932	SYLVAN	Hybrid	744	2	19	4	1.5	5.5	1.5	16.9	3.0	22.4	25.4	890	86,621	Yes	-0.07	3.33	17
705632	COPANS	UG	3,546	0	15	0	-	2.0	-	8.5	-	10.5	10.5	5,065	241,724	Yes	-0.20	5.20	8
707735	GOOLSBY	UG	1	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	-0.06	8.04	0
703134	RAVENSWOOD	Hybrid	931	2	41	1	1.8	4.3	0.6	5.1	2.4	9.4	11.8	49	11,702	Yes	0.48	6.38	3
706462	HOLMBERG	Hybrid	816	9	32	1	7.3	2.2	3.4	15.6	10.7	17.8	28.5	1,380	64,786	Yes	-2.64	5.26	28
409633	RAINBERRY	Hybrid	1,490	1	24	3	1.4	1.2	0.9	10.1	2.3	11.3	13.6	1,646	166,434	Yes	0.28	9.08	30
804932	OJUS	Hybrid	956	16	12	6	2.3	0.7	6.3	2.3	8.6	3.0	11.6	421	60,882	Yes	-0.53	5.87	62
700236	HOLLYWOOD	Hybrid	1,619	12	10	6	2.4	1.0	2.6	1.1	5.0	2.1	7.1	1,793	131,625	Yes	-0.38	4.42	24
807163	PENNSUCO	Hybrid	493	1	46	5	4.4	4.2	1.0	12.2	5.4	16.4	21.8	41	9,581	Yes	0.93	14.03	14
101863	ORANGEGALE	Hybrid	2,114	15	32	3	4.5	4.9	5.0	25.7	9.5	30.6	40.1	1,317	97,062	Yes	-7.59	6.31	18
507365	ORANGETREE	OH	2,195	174	3	7	22.9	0.9	68.2	1.5	91.1	2.4	93.5	2,961	141,731	Yes	0.00	10.40	66
101541	GENERAL ELECTRIC	Hybrid	169	1	13	1	1.8	2.1	0.5	3.1	2.3	5.2	7.5	339	19,961	Yes	-0.02	6.08	3
805931	COUNTRY CLUB	Hybrid	2,536	1	27	1	1.1	0.4	0.1	6.1	1.2	6.5	7.7	330	47,073	Yes	-0.18	7.22	5
103831	WILLOW	Hybrid	2,238	5	54	2	4.5	0.1	2.2	18.0	6.7	18.1	24.8	649	80,404	Yes	-0.18	9.02	22
406163	TURNPIKE	Hybrid	2,906	43	2	2	5.5	0.3	29.6	1.6	35.1	1.9	37.0	669	103,842	Yes	-2.39	12.81	66

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR	
701032	SAMPLE ROAD	Hybrid	1,120	14	13	3	3.0	0.4	4.8	1.1	7.8	1.5	9.3	1,421	110,552	Yes	-0.37	6.93	48	
501137	FT MYERS	Hybrid	397	12	8	4	2.2	0.4	1.7	0.4	3.9	0.8	4.7	503	27,740	Yes	-0.14	5.36	14	
701836	ROCK ISLAND	Hybrid	2,026	8	34	0	2.0	0.7	1.3	7.3	3.3	8.0	11.3	1,715	11,086	Yes	-1.78	3.52	10	
705162	JACARANDA	UG	478	0	13	0	-	4.1	-	0.9	-	5.0	5.0	47	2,098	Yes	-0.09	7.61	5	
404136	GOLF	Hybrid	4,621	34	38	11	4.9	1.1	8.9	11.1	13.8	12.2	26.0	6,368	325,963	Yes	0.35	8.95	63	
505167	PROCTOR	Hybrid	2,415	20	47	7	4.5	4.5	9.9	32.8	14.4	37.3	51.7	449	70,986	Yes	12.85	12.85	30	
402533	BELVEDERE	Hybrid	889	14	30	10	2.7	2.3	2.8	5.9	5.5	8.2	13.7	3,854	102,237	Yes	-0.26	7.54	40	
503435	SOUTH VENICE	OH	2,138	44	1	2	3.6	0.2	22.3	0.2	25.9	0.4	26.3	310	40,718	Yes	-1.49	7.51	59	
503967	ESTERO	Hybrid	2,746	32	28	9	4.6	4.2	15.9	13.5	20.5	17.7	38.2	508	55,189	Yes	-0.06	11.34	51	
413534	VIOLET	Hybrid	1,133	0	19	1	1.6	2.7	0.2	6.7	1.8	9.4	11.2	1,640	107,548	Yes	0.15	3.35	6	
505365	PARK	Hybrid	3,790	0	67	1	2.6	7.2	0.6	41.4	3.2	48.6	51.8	2,611	112,086	Yes	2.60	15.90	30	
811262	EUREKA	Hybrid	2,774	3	40	1	3.2	2.2	0.9	23.8	4.1	26.0	30.1	1,792	49,441	Yes	-0.09	13.51	21	
800938	40TH ST	Hybrid	853	14	9	1	3.1	0.4	1.7	0.5	4.8	0.9	5.7	1,263	65,890	Yes	-0.26	5.04	26	
703033	ROHAN	Hybrid	936	18	5	3	2.5	0.3	5.8	1.0	8.3	1.3	9.6	185	35,821	Yes	-0.41	5.19	36	
403801	QUAKER OATS	UG	-	0	0	0	-	-	-	-	-	-	-	-	-	Yes	-1.30	1.80	0	
300732	LAWTEY	OH	1,771	118	6	7	17.4	0.1	89.3	2.4	106.7	2.5	109.2	3,352	204,651	Yes	-1.04	6.66	69	
701437	PORT	Hybrid	74	1	22	2	0.9	2.4	0.6	3.7	1.5	6.1	7.6	47	4,027	Yes	-0.16	4.04	5	
703037	ROHAN	Hybrid	282	6	18	3	2.2	0.4	2.0	2.5	4.2	2.9	7.1	24	4,981	Yes	-0.14	5.46	13	
410534	GRAMERCY	UG	-	0	0	0	-	1.1	-	-	-	1.1	1.1	-	-	Yes	0.65	0.75	0	
104931	MOULTRIE	Hybrid	1,427	0	33	0	2.9	-	0.3	15.8	3.2	15.8	19.0	473	30,127	Yes	-2.34	4.56	16	
508361	TERRY	Hybrid	1,713	24	14	5	9.0	0.4	10.9	7.6	19.9	8.0	27.9	259	38,344	Yes	-0.08	3.82	20	
505161	PROCTOR	Hybrid	1,773	3	30	8	2.8	0.5	5.3	12.0	8.1	12.5	20.6	584	66,084	Yes	-0.13	8.37	40	
706531	TRAIN	Hybrid	819	7	19	2	3.1	1.3	2.9	1.9	6.0	3.2	9.2	707	20,194	Yes	-1.03	4.77	17	
805337	KEY BISCAYNE	UG	1,028	0	7	0	-	3.7	-	3.3	-	7.0	7.0	38	1,406	Yes	0.04	5.04	1	
200534	MELBOURNE	Hybrid	2,043	23	23	7	3.5	0.1	6.4	6.3	9.9	6.4	16.3	901	52,616	Yes	0.13	6.93	34	
702832	PERRY	Hybrid	2,371	0	22	0	1.7	-	-	10.4	1.7	10.4	12.1	170	8,132	Yes	-0.09	5.41	6	
207063	COX	Hybrid	2	0	0	0	0.8	1.3	-	-	-	0.8	1.3	21	2	15	Yes	4.60	5.00	2
507162	POLO	Hybrid	1,621	72	26	23	34.1	0.6	80.4	21.2	114.5	21.8	136.3	1,185	199,380	Yes	-1.89	7.51	112	
405862	DELTRAIL	Hybrid	3,720	0	44	1	3.2	1.5	2.2	22.2	5.4	23.7	29.1	10,193	318,096	Yes	-1.91	8.39	19	
508463	GATEWAY	Hybrid	2,073	52	7	7	10.3	0.3	42.8	3.3	53.1	3.6	56.7	394	64,716	Yes	0.26	9.06	62	
504433	CLEVELAND	Hybrid	1,389	50	23	14	19.0	1.1	52.5	10.0	71.5	11.1	82.6	308	36,525	Yes	-0.02	9.18	39	
507664	GLADIOLUS	Hybrid	3,225	6	54	7	5.4	0.7	2.3	25.2	7.7	25.9	33.6	448	51,367	Yes	-0.36	11.24	29	
503132	SOLANA	Hybrid	2,640	16	40	12	2.8	1.7	5.9	8.9	8.7	10.6	19.3	143	44,106	Yes	-0.45	8.25	22	
803941	SUNNY ISLES	UG	1,746	0	6	1	-	4.2	0.1	2.2	0.1	6.4	6.5	44	11,960	Yes	0.26	4.56	3	
707267	FLAMINGO	Hybrid	3,568	9	41	0	3.4	1.8	6.4	14.9	9.8	16.7	26.5	788	193,959	Yes	0.85	10.85	51	
507167	POLO	UG	2,521	0	18	0	0.9	4.6	-	18.7	0.9	23.3	24.2	11	602	Yes	5.46	5.46	2	
405034	SANDALFOOT	Hybrid	1,095	0	21	1	2.4	1.0	0.8	12.9	3.2	13.9	17.1	61	12,429	Yes	-0.19	6.01	10	
410463	GATLIN	Hybrid	3,173	47	15	0	6.6	0.8	32.3	1.9	38.9	2.7	41.6	3,861	94,837	Yes	-0.15	13.95	76	
814033	BRICKELL	UG	795	0	5	0	-	3.4	-	0.1	-	3.5	3.5	1	221	Yes	-2.24	3.26	1	
404741	HILLSBORO	UG	898	0	18	0	0.1	4.0	-	1.0	0.1	5.0	5.1	865	22,966	Yes	0.05	3.75	1	
808832	SNAPPER CREEK	Hybrid	606	17	10	10	3.2	0.6	8.6	10.0	11.8	10.6	22.4	527	77,219	Yes	-0.86	7.34	47	
503835	EDISON	Hybrid	2,364	0	42	2	2.5	0.4	0.8	10.0	3.3	10.4	13.7	223	18,885	Yes	-0.32	6.18	14	
810361	NEWTON	Hybrid	2,043	0	27	0	2.5	2.7	-	21.1	2.5	23.8	26.3	117	22,674	Yes	-0.15	11.95	7	
408461	ADAMS	Hybrid	1,379	82	39	7	19.2	2.8	49.0	15.8	68.2	18.6	86.8	2,892	122,053	Yes	-0.29	8.41	74	
106235	GERONA	Hybrid	584	11	15	2	1.7	0.7	2.2	6.1	3.9	6.8	10.7	808	27,020	Yes	-6.97	2.13	7	
706263	VALENCIA	Hybrid	2,677	8	53	5	4.6	0.8	3.8	19.5	8.4	20.3	28.7	1,626	155,391	Yes	-2.49	10.11	40	
404738	HILLSBORO	Hybrid	595	4	21	2	1.6	1.4	0.5	0.7	2.1	2.1	4.2	123	13,725	Yes	0.04	4.14	4	
810568	JASMINE	UG	26	0	6	0	-	2.4	-	4.3	-	6.7	6.7	-	-	Yes	0.05	3.75	0	
413631	BONANZA	Hybrid	30	0	9	0	2.0	0.9	0.1	0.7	2.1	1.6	3.7	32	5,446	Yes	0.34	4.24	3	
803543	MARKET	UG	1	0	1	0	-	1.2	-	0.1	-	1.3	1.3	-	-	Yes	-0.40	6.80	0	
806038	GOLDEN GLADES	Hybrid	1,619	32	14	2	3.8	0.3	11.4	1.3	15.2	1.6	16.8	1,344	145,301	Yes	-0.26	8.94	96	
701831	ROCK ISLAND	Hybrid	2,351	19	20	4	4.0	0.6	9.3	5.9	13.3	6.5	19.8	2,299	156,369	Yes	0.04	9.54	49	
506765	VANDERBILT	Hybrid	3,228	9	45	11	4.9	1.7	5.3	22.6	10.2	24.3	34.5	584	54,738	Yes	-0.77	13.83	36	
406331	ROEBUCK	Hybrid	1,454	1	29	0	2.5	0.1	-	10.0	2.5	10.1	12.6	9	489	Yes	-0.03	4.37	2	
803936	SUNNY ISLES	UG	957	0	5	0	-	3.7	-	0.6	-	4.3	4.3	-	-	Yes	0.01	2.61	0	

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
405865	DELTRAIL	Hybrid	3,930	20	59	2	7.0	2.5	3.0	29.1	10.0	31.6	41.6	2,038	62,558	Yes	-0.13	11.77	26
706863	CONSERVATION	Hybrid	2,255	8	54	6	4.3	2.1	4.0	15.0	8.3	17.1	25.4	1,638	57,620	Yes	-4.30	11.00	24
812062	WILLIAMS	Hybrid	2,010	0	43	0	1.7	3.4	-	26.3	1.7	29.7	31.4	4,475	112,621	Yes	0.17	12.47	10
806834	RED ROAD	Hybrid	960	1	23	3	1.4	3.5	0.8	8.0	2.2	11.5	13.7	2,031	157,309	Yes	-1.20	4.40	15
706061	HIATUS	UG	193	0	8	0	-	4.7	-	1.9	-	6.6	6.6	51	9,996	Yes	0.29	6.69	1
802240	GLADEVIEW	Hybrid	1,280	14	8	4	2.6	0.8	4.2	0.7	6.8	1.5	8.3	242	47,705	Yes	-0.20	4.60	23
703541	DEERFIELD BEACH	Hybrid	1,122	14	23	2	2.5	1.6	3.0	4.4	5.5	6.0	11.5	190	17,978	Yes	0.16	6.66	19
406865	KIMBERLY	Hybrid	1,988	0	36	0	3.3	6.6	-	26.3	3.3	32.9	36.2	2,857	31,588	Yes	-0.47	11.73	14
400736	BOCA RATON	Hybrid	1,067	24	10	2	2.9	0.3	5.3	2.0	8.2	2.3	10.5	2,814	45,288	Yes	-0.04	4.56	26
413832	CHAMBERS	Hybrid	1,572	4	43	7	3.9	0.9	3.1	14.2	7.0	15.1	22.1	3,464	127,522	Yes	-0.23	6.57	21
810833	BELL	Hybrid	2,103	1	29	0	1.1	1.2	0.1	5.1	1.2	6.3	7.5	80	3,635	Yes	-0.55	4.95	3
806140	DOUGLAS	Hybrid	1,936	9	18	6	2.6	0.3	2.3	1.6	4.9	1.9	6.8	1,434	55,683	Yes	0.11	6.01	28
805938	COUNTRY CLUB	Hybrid	2,081	8	24	0	1.1	2.8	3.9	15.0	5.0	17.8	22.8	307	77,709	Yes	0.35	10.15	27
803237	HOMESTEAD	Hybrid	2,259	8	35	4	8.9	2.1	9.4	20.2	18.3	22.3	40.6	5,096	289,592	Yes	1.13	8.93	28
802533	GREYNOLDS	Hybrid	1,135	3	29	1	2.9	0.5	2.6	5.4	5.5	5.9	11.4	95	21,557	Yes	-0.04	5.36	9
804534	GRATIGNY	Hybrid	1,981	14	26	1	2.4	0.2	3.5	3.6	5.9	3.8	9.7	171	8,715	Yes	-0.64	6.26	17
804235	PERRINE	Hybrid	1,310	9	29	4	3.4	0.2	3.6	4.2	7.0	4.4	11.4	2,214	175,941	Yes	-0.66	6.34	44
505164	PROCTOR	Hybrid	2,819	10	45	3	3.7	0.2	3.4	18.8	7.1	19.0	26.1	1,188	31,794	Yes	-0.91	9.99	28
401532	FT PIERCE	Hybrid	1,981	15	36	4	7.0	3.9	7.8	8.1	14.8	12.0	26.8	566	74,001	Yes	-0.38	5.62	34
805736	GALLOWAY	UG	-	0	0	0	-	0.8	-	-	-	0.8	0.8	-	-	Yes	-0.03	2.97	0
411662	PEACOCK	Hybrid	415	38	14	10	18.5	0.9	34.2	11.7	52.7	12.6	65.3	371	70,902	Yes	-0.81	2.19	22
503762	HARBOR	Hybrid	2,418	26	15	6	5.4	0.3	21.8	1.8	27.2	2.1	29.3	353	33,796	Yes	1.10	9.90	55
706066	HIATUS	Hybrid	1,534	5	19	4	2.7	0.2	2.7	11.7	5.4	11.9	17.3	483	76,774	Yes	-0.22	7.68	35
500762	ENGLEWOOD	Hybrid	2,613	72	34	11	6.7	0.8	12.7	3.3	19.4	4.1	23.5	1,203	64,740	Yes	-1.03	7.67	39
404240	BOCA TEEDA	UG	1,413	0	30	0	0.3	3.5	-	13.3	0.3	16.8	17.1	2	384	Yes	-2.63	5.07	2
200261	CELERY	Hybrid	856	44	5	10	9.9	1.4	31.7	4.3	41.6	5.7	47.3	1,014	65,476	Yes	-0.18	3.62	41
300634	LIVE OAK	Hybrid	851	30	25	5	5.9	0.1	8.6	2.1	14.5	2.2	16.7	118	21,166	Yes	-0.27	5.33	27
108261	LPGA	Hybrid	774	1	43	0	3.8	8.4	-	14.6	3.8	23.0	26.8	152	33,822	Yes	0.84	13.44	5
800107	MIAMI	UG	417	0	1	0	-	-	-	0.3	-	0.3	0.3	1	230	Yes	2.38	2.38	1
809133	TAMIAMI	Hybrid	1,266	22	5	1	2.4	0.2	4.5	0.2	6.9	0.4	7.3	162	30,121	Yes	-0.27	5.43	29
805939	COUNTRY CLUB	UG	2,334	0	24	0	0.4	3.0	-	8.9	0.4	11.9	12.3	15	450	Yes	-0.38	8.72	3
811565	KOGER	Hybrid	527	5	41	1	3.3	0.4	0.5	2.9	3.8	3.3	7.1	54	15,794	Yes	0.25	6.35	9
700941	HALLANDALE	UG	389	0	20	0	-	3.6	-	9.9	-	13.5	13.5	23	5,973	Yes	-0.15	4.35	11
504367	PINE RIDGE	Hybrid	1,830	2	42	2	2.7	0.5	1.0	14.8	3.7	15.3	19.0	35	9,003	Yes	-0.35	8.55	7
803532	MARKET	Hybrid	2,453	13	18	9	2.3	0.2	2.7	1.0	5.0	1.2	6.2	646	46,325	Yes	0.78	8.28	18
808167	MILAM	Hybrid	2,363	2	36	6	2.2	2.1	1.7	7.8	3.9	9.9	13.8	2,015	161,225	Yes	3.29	13.79	13
704762	STONEBRIDGE	Hybrid	1,842	0	21	1	2.0	2.2	0.3	12.3	2.3	14.5	16.8	495	66,845	Yes	-0.27	12.23	17
811362	ANHINGA	Hybrid	1,986	14	16	6	5.3	0.2	6.8	10.2	12.1	10.4	22.5	1,624	208,363	Yes	0.40	9.40	35
814049	BRICKELL	UG	1,259	0	2	0	-	1.8	-	-	-	1.8	1.8	-	-	Yes	0.50	1.70	0
804433	VENETIAN	UG	35	0	3	0	-	3.4	-	0.3	-	3.7	3.7	-	-	Yes	-0.35	2.55	0
705534	SOUTHSIDE	UG	521	0	5	0	-	2.1	-	0.2	-	2.3	2.3	2	453	Yes	-2.84	4.56	2
100232	ST AUGUSTINE	Hybrid	790	8	22	1	2.0	0.3	1.2	3.3	3.2	3.6	6.8	909	68,747	Yes	-0.14	7.06	11
800932	40TH ST	UG	634	0	10	0	-	1.9	-	0.6	-	2.5	2.5	-	-	Yes	0.57	3.27	0
104731	KACIE	Hybrid	1,971	47	27	12	10.5	1.7	36.0	13.9	46.5	15.6	62.1	3,891	136,864	Yes	-0.63	7.57	54
803037	TROPICAL	Hybrid	990	21	13	1	3.3	0.3	4.3	1.8	7.6	2.1	9.7	898	62,716	Yes	0.16	6.16	43
707032	SHERIDAN	Hybrid	1,533	3	39	4	3.2	2.7	2.6	11.3	5.8	14.0	19.8	64	7,922	Yes	0.65	8.05	7
702634	ELY	Hybrid	2,039	14	32	6	3.1	2.8	3.9	3.5	7.0	6.3	13.3	355	37,233	Yes	0.62	8.12	21
800247	MIAMI BEACH	UG	862	0	2	1	-	3.1	0.1	0.4	0.1	3.5	3.6	-	-	Yes	-0.39	4.21	0
400431	HILLCREST	Hybrid	1,568	40	8	6	3.3	0.1	12.7	4.2	16.0	4.3	20.3	2,383	105,437	Yes	-0.01	7.89	51
204633	COLLEGE	Hybrid	1,469	8	31	4	3.9	0.5	2.4	7.2	6.3	7.7	14.0	1,397	83,619	Yes	0.03	5.33	22
800249	MIAMI BEACH	UG	-	0	0	0	-	1.9	-	-	-	1.9	1.9	-	-	Yes	-0.03	0.07	0
101932	EDGEWATER	OH	2,537	56	0	0	4.1	0.1	22.8	-	26.9	0.1	27.0	856	118,825	Yes	-0.20	9.20	98
704564	MALLARD	Hybrid	1,768	0	67	0	4.4	1.2	0.2	14.5	4.6	15.7	20.3	1,450	90,894	Yes	-2.52	11.78	24
204131	SATELLITE	Hybrid	1,383	9	9	9	1.8	0.9	7.8	7.8	9.6	8.7	18.3	459	58,662	Yes	-0.26	6.24	22
701834	ROCK ISLAND	Hybrid	270	6	14	1	1.7	0.3	0.7	1.3	2.4	1.6	4.0	89	5,481	Yes	0.45	3.25	2

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
501235	NAPLES	Hybrid	1,665	13	36	3	4.3	0.2	2.6	7.2	6.9	7.4	14.3	120	18,119	Yes	-0.31	6.39	16
701435	PORT	UG	33	1	11	0	-	4.7	-	1.8	-	6.5	6.5	3	418	Yes	-0.34	5.16	3
200336	TITUSVILLE	Hybrid	1,535	30	8	4	3.6	0.3	14.9	1.3	18.5	1.6	20.1	1,157	66,125	Yes	-1.36	5.94	37
807431	VILLAGE GREEN	Hybrid	536	0	23	0	1.3	0.2	-	2.8	1.3	3.0	4.3	39	8,710	Yes	-0.47	3.83	3
809762	SWEETWATER	Hybrid	2,795	3	33	1	3.6	1.4	2.6	17.8	6.2	19.2	25.4	2,198	113,757	Yes	-0.12	12.98	42
700738	FAIRMONT	Hybrid	1,156	18	12	1	2.6	1.2	5.3	3.2	7.9	4.4	12.3	2,675	176,643	Yes	-0.88	5.02	62
700131	SISTRUNK	Hybrid	734	3	17	6	2.2	2.0	2.4	1.2	4.6	3.2	7.8	1,635	85,201	Yes	0.13	5.23	13
405534	PRIMA VISTA	Hybrid	1,713	9	28	3	4.0	0.4	2.6	6.9	6.6	7.3	13.9	153	28,428	Yes	-0.24	5.46	10
505563	VAMO	Hybrid	1,364	0	37	0	2.6	1.5	-	8.1	2.6	9.6	12.2	81	6,791	Yes	-0.61	7.69	6
404731	HILLSBORO	Hybrid	996	13	25	4	1.8	2.7	4.0	7.0	5.8	9.7	15.5	210	51,427	Yes	0.40	6.70	24
409433	SKYPASS	Hybrid	445	14	11	0	2.2	0.5	3.4	1.5	5.6	2.0	7.6	28	3,258	Yes	0.07	2.87	11
100837	PORT ORANGE	Hybrid	1,975	26	20	6	4.3	0.3	8.1	7.2	12.4	7.5	19.9	360	36,601	Yes	0.04	6.44	29
706168	HOLLYBROOK	Hybrid	1,232	1	39	0	3.3	1.8	0.3	7.5	3.6	9.3	12.9	181	23,816	Yes	-0.25	8.95	6
503039	PHILLIPPI	Hybrid	2,583	8	38	12	2.7	3.0	4.8	8.4	7.5	11.4	18.9	6,650	197,532	Yes	-0.12	8.58	37
414333	COBIA	Hybrid	752	0	25	1	2.7	0.9	0.2	8.5	2.9	9.4	12.3	853	58,609	Yes	3.76	3.76	7
801834	BISCAYNE	Hybrid	1,774	20	19	2	3.4	1.0	7.9	1.7	11.3	2.7	14.0	2,212	303,685	Yes	-0.15	6.75	94
407932	QUANTUM	Hybrid	2,152	0	25	1	1.3	2.2	0.4	9.9	1.7	12.1	13.8	54	11,665	Yes	0.11	5.91	7
804038	LE JEUNE	UG	1	0	2	0	-	1.1	-	-	-	1.1	1.1	-	-	Yes	-0.42	3.08	0
700443	OAKLAND PARK	OH	2,089	27	3	0	4.4	0.3	7.6	0.1	12.0	0.4	12.4	1,167	188,118	Yes	-0.39	5.81	92
203131	ROCKLEDGE	Hybrid	2,074	32	20	10	4.3	0.3	9.4	5.2	13.7	5.5	19.2	713	85,241	Yes	0.10	7.80	17
702036	DRIFTWOOD	Hybrid	1,472	4	9	6	2.4	0.7	3.1	7.0	5.5	7.7	13.2	384	70,622	Yes	-0.15	6.55	28
704763	STONEBRIDGE	Hybrid	2,591	12	56	5	5.3	1.2	8.1	32.0	13.4	33.2	46.6	1,191	68,964	Yes	-0.4	16.0	58
404137	GOLF	Hybrid	2,004	2	46	2	4.8	1.3	1.5	17.2	6.3	18.5	24.8	119	16,441	Yes	0.0	7.6	16
201639	PALM BAY	Hybrid	-	0	0	0	0.1	0.4	-	-	0.1	0.4	0.5	-	-	Yes	-0.2	4.1	0
807032	ROSELAWN	Hybrid	1,078	3	43	0	2.1	0.3	0.1	5.6	2.2	5.9	8.1	113	16,045	Yes	-0.5	7.6	5
404834	GERMANTOWN	Hybrid	1,687	1	35	3	2.8	0.4	0.6	9.6	3.4	10.0	13.4	580	65,307	Yes	-0.4	5.9	19
405036	SANDALFOOT	Hybrid	2,529	0	45	0	3.6	0.1	-	18.9	3.6	19.0	22.6	241	32,614	Yes	0.3	8.2	11
804634	INDUSTRIAL	Hybrid	1,321	35	11	2	3.0	0.1	6.5	0.8	9.5	0.9	10.4	4,398	259,962	Yes	-0.1	7.8	67
702262	MARGATE	Hybrid	1,740	0	43	0	2.4	2.6	-	11.9	2.4	14.5	16.9	101	15,825	Yes	-0.7	9.0	8
501138	FT MYERS	Hybrid	221	0	6	2	0.5	0.4	0.1	0.4	0.6	0.8	1.4	32	1,668	Yes	0.0	1.6	2
803131	FLORIDA CITY	Hybrid	1,296	8	14	1	28.1	0.1	7.5	6.1	35.6	6.2	41.8	922	70,455	Yes	0.0	4.5	12
807937	MIAMI LAKES	Hybrid	645	2	24	1	2.2	1.0	0.2	1.2	2.4	2.2	4.6	3	1,224	Yes	0.1	3.5	1
808165	MILAM	Hybrid	819	0	38	0	1.8	4.6	-	7.4	1.8	12.0	13.8	75	15,212	Yes	5.0	13.1	5
106532	REED	Hybrid	1,533	28	12	5	2.8	0.9	9.9	4.3	12.7	5.2	17.9	545	76,509	Yes	0.0	3.2	50
807331	GOULDS	Hybrid	2,691	20	30	2	2.7	3.1	5.4	14.1	8.1	17.2	25.3	2,702	75,906	Yes	0.4	8.3	35
801234	OPA LOCKA	Hybrid	1,501	11	24	3	3.8	0.7	6.0	5.6	9.8	6.3	16.1	1,736	139,421	Yes	0.9	10.2	61
703937	WESTINGHOUSE	Hybrid	1,643	0	63	1	4.2	0.1	0.4	10.0	4.6	10.1	14.7	106	14,474	Yes	-0.1	8.7	8
802439	SOUTH MIAMI	UG	-	0	0	0	-	3.1	-	-	-	3.1	3.1	-	-	Yes	0.0	1.9	0
100934	SOUTH DAYTONA	Hybrid	1,185	37	27	6	2.3	1.3	4.2	2.7	6.5	4.0	10.5	1,364	56,463	Yes	0.0	4.3	24
809670	COURT	Hybrid	3,222	0	48	0	1.8	3.4	-	25.6	1.8	29.0	30.8	348	66,791	Yes	0.5	14.5	14
700341	PINEHURST	UG	2	0	0	0	-	0.6	-	-	-	0.6	0.6	-	-	Yes	-1.0	3.2	0
507762	RATTLESNAKE	Hybrid	4,113	10	66	1	2.7	10.3	5.1	42.9	7.8	53.2	61.0	3,916	262,784	Yes	-0.9	15.1	17
400135	WEST PALM BEACH	UG	137	0	9	0	0.1	1.4	-	0.9	0.1	2.3	2.4	2	355	Yes	-0.1	2.0	2
809761	SWEETWATER	Hybrid	1,094	10	27	1	3.8	0.3	2.4	10.4	6.2	10.7	16.9	152	35,377	Yes	-0.3	7.3	25
800109	MIAMI	UG	63	0	1	0	-	0.2	-	1.7	-	1.9	1.9	-	-	Yes	2.1	2.1	0
807837	WESTON VILLAGE	Hybrid	108	2	5	0	0.6	0.4	0.9	0.1	1.5	0.5	2.0	23	3,849	Yes	-1.1	2.1	11
808534	SEMINOLA	Hybrid	709	13	16	1	2.0	0.6	1.4	1.8	3.4	2.4	5.8	157	28,063	Yes	0.5	6.0	16
705234	TIMBERLAKE	Hybrid	1,813	2	45	3	4.4	1.2	0.7	13.6	5.1	14.8	19.9	4,891	70,971	Yes	-0.6	7.6	26
702437	PEMBROKE	Hybrid	1,988	23	3	4	4.4	0.1	11.7	0.9	16.1	1.0	17.1	1,277	100,456	Yes	-0.4	8.2	63
701936	HOLY CROSS	Hybrid	1,877	13	27	4	2.5	1.5	3.5	1.6	6.0	3.1	9.1	994	72,098	Yes	0.1	6.9	19
105132	COMO	Hybrid	1,084	63	8	9	11.2	-	42.0	4.1	53.2	4.1	57.3	1,031	97,654	Yes	-0.1	3.2	51
700434	OAKLAND PARK	Hybrid	1,522	25	5	6	2.3	0.5	6.0	1.7	8.3	2.2	10.5	563	81,342	Yes	-0.4	5.1	50
808836	SNAPPER CREEK	UG	237	0	5	0	-	4.9	-	0.6	-	5.5	5.5	-	-	Yes	0.2	4.3	0
704570	MALLARD	Hybrid	4,495	0	75	1	6.6	2.2	0.2	20.7	6.8	22.9	29.7	13,724	255,822	Yes	1.0	11.8	35
504364	PINE RIDGE	UG	1,286	0	17	0	0.1	5.0	-	12.2	0.1	17.2	17.3	85	16,974	Yes	-0.4	5.0	7

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR CI	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
406935	DELMAR	Hybrid	2,407	0	23	0	0.7	2.0	-	10.9	0.7	12.9	13.6	37	2,709	Yes	-0.5	5.6	6
205934	SYLVAN	UG	858	0	12	0	-	4.8	-	3.1	-	7.9	7.9	881	41,193	Yes	0.0	5.2	1
803133	FLORIDA CITY	Hybrid	1,902	4	16	3	2.3	0.7	1.4	9.0	3.7	9.7	13.4	393	89,760	Yes	-0.9	6.3	22
501234	NAPLES	Hybrid	635	0	16	3	1.0	0.6	1.7	3.4	2.7	4.0	6.7	28	3,627	Yes	-4.7	4.1	3
400133	WEST PALM BEACH	Hybrid	1,141	0	23	3	1.8	2.1	0.4	3.0	2.2	5.1	7.3	3,290	233,812	Yes	-0.3	5.2	23
300961	MACCLENNY	OH	1,342	47	15	12	7.5	0.2	30.0	1.7	37.5	1.9	39.4	752	57,186	Yes	-0.6	9.9	36
810267	INTERNATIONAL	UG	23	0	7	0	-	3.6	-	0.8	-	4.4	4.4	-	-	Yes	-0.1	8.8	0
410762	ROSEDALE	Hybrid	2,120	71	16	7	5.8	0.1	22.6	8.7	28.4	8.8	37.2	426	64,699	Yes	-0.4	9.3	59
703537	DEERFIELD BEACH	Hybrid	1,951	19	18	3	4.0	0.1	8.5	3.1	12.5	3.2	15.7	860	51,991	Yes	-0.1	9.3	50
809341	RONEY	Hybrid	1,332	4	3	1	0.4	3.0	0.5	0.4	0.9	3.4	4.3	2,265	341,586	Yes	-0.1	3.1	13
505263	RUBONIA	Hybrid	1,638	15	28	6	5.3	0.7	13.4	10.8	18.7	11.5	30.2	2,613	70,316	Yes	-1.3	3.5	42
802536	GREYNOLDS	UG	419	0	13	0	-	4.5	-	2.6	-	7.1	7.1	-	-	Yes	0.4	6.6	0
802932	GRAPELAND	Hybrid	1,393	15	10	2	1.9	-	3.1	0.6	5.0	0.6	5.6	932	104,272	Yes	0.4	6.6	23
408331	MONTEREY	Hybrid	2,372	8	38	6	3.7	0.3	2.5	13.1	6.2	13.4	19.6	916	66,028	Yes	-0.5	9.8	9
309331	WELLBORN	Hybrid	1080	83	10	14	17.7	3.6	65.8	6.3	83.5	9.9	93.4	944	121,065	Yes	-0.2	5.5	73
803638	SEABOARD	OH	1743	28	2	3	3.7	0.4	10.4	0.2	14.1	0.6	14.7	3884	323,433	Yes	-0.1	8.3	81
502066	MURDOCK	Hybrid	2643	49	5	6	5.9	0.3	36.2	2.8	42.1	3.1	45.2	3489	201,287	Yes	-1.7	9.2	72
701232	PLAYLAND	Hybrid	880	7	14	2	1.9	1.2	3.1	0.8	5.0	2.0	7.0	251	42,652	Yes	1.8	6.5	36
404238	BOCA TEECA	UG	390	0	20	0	0.1	1.9	0.0	3.7	0.1	5.6	5.7	1	46	Yes	0.4	6.2	1
414334	COBIA	Hybrid	910	0	26	5	1.2	0.6	0.9	7.1	2.1	7.7	9.8	170	17,473	Yes	4.2	4.2	10
803932	SUNNY ISLES	Hybrid	669	1	17	0	0.6	3.2	0.0	2.0	0.6	5.2	5.8	4	729	Yes	-0.3	3.6	2
805439	DADE	Hybrid	169	1	8	2	1.0	0.3	0.4	0.9	1.4	1.2	2.6	12	4,380	Yes	-0.4	3.5	1
800147	MIAMI	UG	3	0	2	0	0.0	3.7	0.0	0.0	0.0	3.7	3.7	0	0	Yes	0.3	4.0	0
809036	AVENTURA	Hybrid	1323	4	17	2	1.1	0.9	0.5	3.6	1.6	4.5	6.1	1314	43,313	Yes	0.0	4.4	5
809135	TAMAMI	Hybrid	1579	22	10	4	3.0	1.2	4.7	0.7	7.7	1.9	9.6	1295	53,187	Yes	-1.1	6.4	41
702638	ELY	Hybrid	1013	14	19	5	2.9	1.3	4.0	1.9	6.9	3.2	10.1	164	23,348	Yes	0.3	5.9	16
807234	MERCHANDISE	Hybrid	1924	13	28	2	2.4	0.2	5.3	2.5	7.7	2.7	10.4	1316	117,157	Yes	-0.3	6.6	38
106862	FOREST GROVE	Hybrid	2153	25	12	3	2.8	5.7	12.8	10.4	15.6	16.1	31.7	398	78,245	Yes	0.0	6.7	32
804338	KENDALL	Hybrid	502	7	19	2	2.0	0.5	4.0	1.6	6.0	2.1	8.1	313	62,002	Yes	0.7	4.6	24
808532	SEMINOLA	Hybrid	2514	19	19	8	3.3	0.3	3.7	1.4	7.0	1.7	8.7	2,298	204,543	Yes	0.2	7.0	34
408567	ALEXANDER	UG	0	0	0	0	0.0	1.6	0.0	0.0	0.0	1.6	1.6	0	0	Yes	-0.1	0.7	0
407934	QUANTUM	UG	1291	0	18	0	0.0	2.0	0.0	2.9	0.0	4.9	4.9	0	0	Yes	-0.1	3.5	0
100434	PALATKA	OH	914	37	10	3	5.1	0.1	8.3	0.5	13.4	0.6	14.0	1120	31,372	Yes	-0.2	4.1	29
800732	HIALEAH	Hybrid	1235	17	12	1	3.0	0.1	5.8	3.2	8.8	3.3	12.1	1527	80,149	Yes	0.0	5.4	28
706067	HIATUS	Hybrid	3672	0	29	0	1.8	1.7	0.0	10.6	1.8	12.3	14.1	87	12,339	Yes	0.8	8.4	4
209932	LIGHTHOUSE	UG	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	Yes	-0.5	1.1	0
506163	METRO	Hybrid	3955	23	45	6	7.2	0.6	10.5	23.6	17.7	24.2	41.9	2691	49,813	Yes	-0.7	13.5	26
803939	SUNNY ISLES	UG	3067	0	9	0	0.0	2.5	0.0	1.8	0.0	4.3	4.3	1	36	Yes	0.0	8.0	1
102536	MATANZAS	Hybrid	1455	0	0	0	2.4	1.5	3.0	14.7	5.4	16.2	21.6	44	5,288	Yes	5.1	5.1	4
106063	TOMOKA	Hybrid	3300	33	61	5	7.6	2.5	13.9	50.6	21.5	53.1	74.6	285	50,566	Yes	-0.1	14.1	48
709432	ANDREWS	Hybrid	376	5	19	3	2.3	0.6	1.0	3.3	3.3	3.9	7.2	46	2,505	Yes	0.0	4.7	4
811365	ANHINGA	Hybrid	1134	18	21	2	7.6	0.7	4.8	10.9	12.4	11.6	24.0	1017	25,437	Yes	-0.1	9.3	14
808333	WHISPERING PINES	Hybrid	1050	4	40	4	3.1	1.1	2.0	15.2	5.1	16.3	21.4	2032	153,639	Yes	-0.3	7.9	35
504663	CASTLE	Hybrid	1980	4	36	2	4.1	3.9	2.2	18.4	6.3	22.3	28.6	6761	101,010	Yes	-0.2	11.9	24
500163	SARASOTA	UG	411	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	Yes	0.2	3.8	0
401134	STUART	Hybrid	1390	26	23	7	3.8	0.9	7.7	3.0	11.5	3.9	15.4	770	67,462	Yes	-0.2	6.2	20
104431	NOVA	Hybrid	1563	21	18	5	3.1	0.2	6.4	5.3	9.5	5.5	15.0	382	33,733	Yes	0.0	5.3	22
505762	AUBURN	Hybrid	3288	16	38	3	6.4	1.0	9.7	26.0	16.1	27.0	43.1	1150	159,625	Yes	-0.6	12.2	74
414133	CANAL	Hybrid	524	15	3	3	1.3	0.0	5.2	1.2	6.5	1.2	7.7	706	14,0514	Yes	-0.1	2.6	28
703931	WESTINGHOUSE	Hybrid	875	6	31	2	3.5	0.1	1.0	11.1	4.5	11.2	15.7	3549	94,485	Yes	0.0	5.8	20
700843	BEVERLY	Hybrid	1346	26	1	2	2.6	1.1	6.1	1.1	8.7	2.2	10.9	154	30,764	Yes	0.5	6.1	42
801138	FRONTON	UG	1	0	0	0	0.0	5.9	0.0	0.0	0.0	5.9	5.9	0	0	Yes	2.2	2.6	0
201932	COURTENAY	Hybrid	1762	23	18	7	3.9	1.0	9.2	10.7	13.1	11.7	24.8	481	45,600	Yes	0.6	8.6	39
413738	RUNWAY	Hybrid	1066	1	24	1	1.6	2.3	0.5	7.8	2.1	10.1	12.2	1056	61,080	Yes	0.2	3.0	5
803545	MARKET	UG	11	0	1	0	0.0	2.5	0.0	0.0	0.0	2.5	2.5	0	0	Yes	0.1	1.7	0

Feeder Specific Data and Attached Laterals

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T
Feeder ID#	Sub Region	FDR Type	Custs	OH Lat	UG Lat	Hybrid Lat	OH Fdr & OCR Miles	UG Fdr Miles	OH Lat Miles	UG Lat Miles	Total OH Miles	Total UG Miles	Total Miles	FDR Ci	FDR CMI	Is the Feeder Circuit Looped?	Load growth (MVA D pk CY- pk Prior)	Peak Load (MVA)	Number of N on FDR
703136	RAVENSWOOD	Hybrid	355	3	28	4	1.8	0.4	0.9	3.1	2.7	3.5	6.2	974	50876	Yes	-0.3	7.5	9
504361	PINE RIDGE	Hybrid	3315	0	52	1	1.4	4.1	0.2	17.8	1.6	21.9	23.5	190	56181	Yes	-0.7	9.8	7
809931	SIMPSON	UG	1899	0	15	0	0.0	2.4	0.0	0.9	0.0	3.3	3.3	700	530620	Yes	0.0	6.9	2
201933	COURTENAY	Hybrid	1171	7	14	6	2.4	1.4	4.0	9.2	6.4	10.6	17.0	145	13846	Yes	-0.1	5.3	17
704066	MOTOROLA	Hybrid	2836	0	23	1	1.3	2.3	0.3	15.3	1.6	17.6	19.2	1913	107001	Yes	-0.7	8.9	13
405462	CLINTMOORE	Hybrid	2772	0	35	0	2.4	3.7	0.0	23.6	2.4	27.3	29.7	289	37930	Yes	0.1	8.7	22
407937	QUANTUM	UG	886	0	30	0	0.3	3.8	0.0	4.4	0.3	8.2	8.5	0	0	Yes	0.0	4.7	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	1/1/2021	30,530	0	0
Transmission / Substation	1/2/2021	4,075	0	0
Transmission / Substation	1/3/2021	0	0	0
Transmission / Substation	1/4/2021	0	0	0
Transmission / Substation	1/4/2021	18,810	0	0
Transmission / Substation	1/4/2021	7,950	67,553	6,991
Transmission / Substation	1/5/2021	822	20,763	822
Transmission / Substation	1/5/2021	9,018	0	0
Transmission / Substation	1/6/2021	0	0	0
Transmission / Substation	1/7/2021	12,103	0	0
Transmission / Substation	1/8/2021	0	0	0
Transmission / Substation	1/10/2021	1,037	9,713	1,037
Transmission / Substation	1/11/2021	25,810	0	0
Transmission / Substation	1/12/2021	2,327	0	0
Transmission / Substation	1/13/2021	3,552	0	0
Transmission / Substation	1/14/2021	20,394	0	0
Transmission / Substation	1/16/2021	2,990	0	0
Transmission / Substation	1/18/2021	0	0	0
Transmission / Substation	1/19/2021	14,001	0	0
Transmission / Substation	1/20/2021	2,752	42,096	2,752
Transmission / Substation	1/20/2021	21,657	111,539	19,293
Transmission / Substation	1/20/2021	0	0	0
Transmission / Substation	1/23/2021	57,566	0	0
Transmission / Substation	1/25/2021	1,823	13,876	1,823
Transmission / Substation	1/26/2021	33,101	0	0
Transmission / Substation	1/27/2021	400	68,589	400
Transmission / Substation	1/28/2021	17,147	0	0
Transmission / Substation	1/30/2021	230	9,587	230
Transmission / Substation	2/2/2021	18,487	0	0
Transmission / Substation	2/3/2021	7,312	0	0
Transmission / Substation	2/4/2021	6,576	10,804	6,030
Transmission / Substation	2/6/2021	12,466	0	0
Transmission / Substation	2/6/2021	12,466	0	0
Transmission / Substation	2/6/2021	0	0	0
Transmission / Substation	2/6/2021	7,460	0	0
Transmission / Substation	2/6/2021	2,886	0	0
Transmission / Substation	2/8/2021	3,221	0	0
Transmission / Substation	2/9/2021	14,634	0	0
Transmission / Substation	2/9/2021	147,207	0	0
Transmission / Substation	2/10/2021	8,957	77,526	7,901
Transmission / Substation	2/11/2021	9,303	80,673	8,042
Transmission / Substation	2/11/2021	0	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	2/13/2021	0	0	0
Transmission / Substation	2/13/2021	2,539	0	0
Transmission / Substation	2/14/2021	1,508	0	0
Transmission / Substation	2/14/2021	722	50,364	722
Transmission / Substation	2/15/2021	5,780	0	0
Transmission / Substation	2/15/2021	9,700	0	0
Transmission / Substation	2/15/2021	5,577	0	0
Transmission / Substation	2/16/2021	952	37,794	952
Transmission / Substation	2/16/2021	2,905	87,005	2,905
Transmission / Substation	2/17/2021	4,618	0	0
Transmission / Substation	2/18/2021	0	0	0
Transmission / Substation	2/19/2021	1,903	0	0
Transmission / Substation	2/19/2021	4,730	0	0
Transmission / Substation	2/19/2021	2,996	0	0
Transmission / Substation	2/20/2021	27,896	0	0
Transmission / Substation	2/21/2021	43,164	0	0
Transmission / Substation	2/22/2021	14,724	0	0
Transmission / Substation	2/22/2021	0	0	0
Transmission / Substation	2/23/2021	0	0	0
Transmission / Substation	2/23/2021	0	0	0
Transmission / Substation	2/24/2021	37,278	0	0
Transmission / Substation	2/24/2021	774	13,351	774
Transmission / Substation	2/24/2021	1,737	77,078	1,737
Transmission / Substation	2/24/2021	0	0	0
Transmission / Substation	2/24/2021	3,741	416,729	3,741
Transmission / Substation	2/24/2021	834	79,758	834
Transmission / Substation	2/26/2021	0	0	0
Transmission / Substation	2/27/2021	4,118	0	0
Transmission / Substation	2/27/2021	0	0	0
Transmission / Substation	2/27/2021	153	5,722	153
Transmission / Substation	3/1/2021	0	0	0
Transmission / Substation	3/1/2021	0	0	0
Transmission / Substation	3/1/2021	0	0	0
Transmission / Substation	3/2/2021	0	0	0
Transmission / Substation	3/2/2021	0	0	0
Transmission / Substation	3/2/2021	0	0	0
Transmission / Substation	3/3/2021	1	0	0
Transmission / Substation	3/3/2021	22,635	0	0
Transmission / Substation	3/3/2021	5,930	0	0
Transmission / Substation	3/4/2021	0	0	0
Transmission / Substation	3/6/2021	3,243	0	0
Transmission / Substation	3/7/2021	553	17,993	553

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	3/7/2021	2,910	0	0
Transmission / Substation	3/7/2021	5,105	0	0
Transmission / Substation	3/13/2021	826	10,656	826
Transmission / Substation	3/13/2021	0	0	0
Transmission / Substation	3/15/2021	0	0	0
Transmission / Substation	3/16/2021	14,012	0	0
Transmission / Substation	3/17/2021	0	0	0
Transmission / Substation	3/17/2021	880	27,837	880
Transmission / Substation	3/18/2021	19,148	36,381	19,148
Transmission / Substation	3/18/2021	1,749	0	0
Transmission / Substation	3/19/2021	0	0	0
Transmission / Substation	3/19/2021	6,306	0	0
Transmission / Substation	3/20/2021	2,926	461,607	2,926
Transmission / Substation	3/20/2021	5,790	1,456,024	5,790
Transmission / Substation	3/21/2021	0	0	0
Transmission / Substation	3/22/2021	0	0	0
Transmission / Substation	3/22/2021	0	0	0
Transmission / Substation	3/22/2021	0	0	0
Transmission / Substation	3/22/2021	0	0	0
Transmission / Substation	3/22/2021	0	0	0
Transmission / Substation	3/22/2021	2,921	0	0
Transmission / Substation	3/23/2021	0	0	0
Transmission / Substation	3/23/2021	0	0	0
Transmission / Substation	3/23/2021	0	0	0
Transmission / Substation	3/23/2021	6,079	0	0
Transmission / Substation	3/24/2021	5,927	0	0
Transmission / Substation	3/25/2021	409	108,044	409
Transmission / Substation	3/25/2021	324	2,624	324
Transmission / Substation	3/26/2021	0	0	0
Transmission / Substation	3/27/2021	1,500	0	0
Transmission / Substation	3/29/2021	0	0	0
Transmission / Substation	3/29/2021	0	0	0
Transmission / Substation	3/30/2021	33,572	0	0
Transmission / Substation	3/30/2021	28,904	0	0
Transmission / Substation	3/31/2021	51,977	0	0
Transmission / Substation	3/31/2021	1,631	29,456	1,631
Transmission / Substation	4/1/2021	22,069	0	0
Transmission / Substation	4/1/2021	0	0	0
Transmission / Substation	4/2/2021	1,060	1,378	1,060
Transmission / Substation	4/3/2021	422	28,882	422
Transmission / Substation	4/4/2021	38,235	0	0
Transmission / Substation	4/4/2021	245	11,457	245

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	4/5/2021	0	0	0
Transmission / Substation	4/5/2021	1,633	0	0
Transmission / Substation	4/6/2021	1,233	0	0
Transmission / Substation	4/6/2021	16,994	36,739	13,280
Transmission / Substation	4/6/2021	3,046	0	0
Transmission / Substation	4/6/2021	6,437	0	0
Transmission / Substation	4/7/2021	14,406	21,145	12,581
Transmission / Substation	4/8/2021	2,536	0	0
Transmission / Substation	4/8/2021	0	0	0
Transmission / Substation	4/9/2021	0	0	0
Transmission / Substation	4/10/2021	14,090	0	0
Transmission / Substation	4/10/2021	3,696	0	0
Transmission / Substation	4/11/2021	1,351	46,375	1,351
Transmission / Substation	4/11/2021	7,029	0	0
Transmission / Substation	4/11/2021	4,915	31,581	4,915
Transmission / Substation	4/11/2021	438	64,896	438
Transmission / Substation	4/11/2021	1,069	3,694	1,069
Transmission / Substation	4/11/2021	987	6,184	987
Transmission / Substation	4/11/2021	438	3,872	438
Transmission / Substation	4/11/2021	0	0	0
Transmission / Substation	4/11/2021	0	0	0
Transmission / Substation	4/13/2021	31,457	0	0
Transmission / Substation	4/13/2021	15,555	0	0
Transmission / Substation	4/13/2021	30,385	0	0
Transmission / Substation	4/14/2021	2,190	4,198	2,190
Transmission / Substation	4/14/2021	2,463	0	0
Transmission / Substation	4/14/2021	2,190	2,336	2,190
Transmission / Substation	4/18/2021	0	0	0
Transmission / Substation	4/18/2021	2,367	0	0
Transmission / Substation	4/19/2021	5,635	0	0
Transmission / Substation	4/19/2021	0	0	0
Transmission / Substation	4/19/2021	2,190	4,052	2,190
Transmission / Substation	4/20/2021	1,450	2,320	1,450
Transmission / Substation	4/20/2021	3,232	0	0
Transmission / Substation	4/21/2021	5,545	0	0
Transmission / Substation	4/21/2021	4,250	0	0
Transmission / Substation	4/21/2021	14,065	0	0
Transmission / Substation	4/21/2021	4,250	0	0
Transmission / Substation	4/22/2021	4,591	0	0
Transmission / Substation	4/23/2021	16,012	16,400	10,631
Transmission / Substation	4/23/2021	23,087	0	0
Transmission / Substation	4/24/2021	3,071	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	4/25/2021	8,342	0	0
Transmission / Substation	4/26/2021	32,567	104,016	29,285
Transmission / Substation	4/27/2021	0	0	0
Transmission / Substation	4/27/2021	0	0	0
Transmission / Substation	4/28/2021	0	0	0
Transmission / Substation	4/30/2021	56,030	186,957	10,115
Transmission / Substation	5/2/2021	0	0	0
Transmission / Substation	5/2/2021	3,194	0	0
Transmission / Substation	5/2/2021	0	0	0
Transmission / Substation	5/2/2021	0	0	0
Transmission / Substation	5/3/2021	0	0	0
Transmission / Substation	5/3/2021	3,683	0	0
Transmission / Substation	5/3/2021	978	20,102	978
Transmission / Substation	5/3/2021	460	12,350	460
Transmission / Substation	5/5/2021	0	0	0
Transmission / Substation	5/5/2021	28,783	0	0
Transmission / Substation	5/5/2021	7,259	0	0
Transmission / Substation	5/5/2021	0	0	0
Transmission / Substation	5/6/2021	4,493	0	0
Transmission / Substation	5/6/2021	678	22,442	678
Transmission / Substation	5/6/2021	22,064	0	0
Transmission / Substation	5/6/2021	51,459	65,782	51,459
Transmission / Substation	5/7/2021	111,910	0	0
Transmission / Substation	5/8/2021	1,712	7,904	1,712
Transmission / Substation	5/8/2021	1,712	51,788	1,712
Transmission / Substation	5/8/2021	3,071	0	0
Transmission / Substation	5/9/2021	0	0	0
Transmission / Substation	5/11/2021	787	25,853	787
Transmission / Substation	5/12/2021	0	0	0
Transmission / Substation	5/12/2021	0	0	0
Transmission / Substation	5/12/2021	4,619	0	0
Transmission / Substation	5/13/2021	0	0	0
Transmission / Substation	5/13/2021	322	9,563	322
Transmission / Substation	5/15/2021	40,736	0	0
Transmission / Substation	5/17/2021	2,536	14,624	2,536
Transmission / Substation	5/19/2021	0	0	0
Transmission / Substation	5/20/2021	14,040	34,353	14,040
Transmission / Substation	5/20/2021	22,781	55,472	19,698
Transmission / Substation	5/20/2021	7,833	0	0
Transmission / Substation	5/20/2021	7,833	0	0
Transmission / Substation	5/21/2021	0	0	0
Transmission / Substation	5/21/2021	2,600	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	5/22/2021	46,668	0	0
Transmission / Substation	5/22/2021	1,720	0	0
Transmission / Substation	5/23/2021	5,872	0	0
Transmission / Substation	5/23/2021	1	68	1
Transmission / Substation	5/24/2021	785	785	785
Transmission / Substation	5/24/2021	18,676	0	0
Transmission / Substation	5/24/2021	0	0	0
Transmission / Substation	5/24/2021	14,046	0	0
Transmission / Substation	5/25/2021	0	0	0
Transmission / Substation	5/25/2021	0	0	0
Transmission / Substation	5/25/2021	0	0	0
Transmission / Substation	5/25/2021	0	0	0
Transmission / Substation	5/27/2021	0	0	0
Transmission / Substation	5/27/2021	7,575	9,651	5,079
Transmission / Substation	5/27/2021	14,634	0	0
Transmission / Substation	5/27/2021	0	0	0
Transmission / Substation	5/28/2021	0	0	0
Transmission / Substation	5/28/2021	45,009	16,924	12,596
Transmission / Substation	5/28/2021	1,800	2,821	1,800
Transmission / Substation	5/28/2021	0	0	0
Transmission / Substation	5/30/2021	18,847	0	0
Transmission / Substation	5/30/2021	3,106	0	0
Transmission / Substation	5/30/2021	6,856	0	0
Transmission / Substation	5/30/2021	2,354	27,811	2,354
Transmission / Substation	5/30/2021	2,462	0	0
Transmission / Substation	5/30/2021	775	25,497	775
Transmission / Substation	5/30/2021	1,427	0	0
Transmission / Substation	6/1/2021	7,259	0	0
Transmission / Substation	6/1/2021	22,859	0	0
Transmission / Substation	6/1/2021	41,671	0	0
Transmission / Substation	6/1/2021	22,859	0	0
Transmission / Substation	6/2/2021	5,405	0	0
Transmission / Substation	6/2/2021	2,724	0	0
Transmission / Substation	6/4/2021	2,536	0	0
Transmission / Substation	6/6/2021	19,994	0	0
Transmission / Substation	6/7/2021	10,890	0	0
Transmission / Substation	6/7/2021	7,502	0	0
Transmission / Substation	6/7/2021	258	0	0
Transmission / Substation	6/8/2021	12,206	4,724	1,905
Transmission / Substation	6/9/2021	1,506	0	0
Transmission / Substation	6/9/2021	4,591	0	0
Transmission / Substation	6/9/2021	3,071	10,309	3,071

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	6/10/2021	104	377	104
Transmission / Substation	6/10/2021	4,958	7,602	4,958
Transmission / Substation	6/11/2021	1,950	0	0
Transmission / Substation	6/11/2021	603	1,025	603
Transmission / Substation	6/11/2021	0	0	0
Transmission / Substation	6/12/2021	13,865	0	0
Transmission / Substation	6/13/2021	1,369	6,594	1,369
Transmission / Substation	6/13/2021	1,219	2,031	1,219
Transmission / Substation	6/13/2021	0	0	0
Transmission / Substation	6/13/2021	1,219	1,259	1,219
Transmission / Substation	6/13/2021	1,219	4,387	1,219
Transmission / Substation	6/13/2021	1,219	29,207	1,219
Transmission / Substation	6/13/2021	1,139	28,319	1,139
Transmission / Substation	6/14/2021	0	0	0
Transmission / Substation	6/14/2021	1,505	15,402	1,505
Transmission / Substation	6/15/2021	2,390	15,419	2,390
Transmission / Substation	6/16/2021	0	0	0
Transmission / Substation	6/17/2021	5,407	161,010	5,407
Transmission / Substation	6/18/2021	13,865	0	0
Transmission / Substation	6/19/2021	7,692	0	0
Transmission / Substation	6/20/2021	5,408	0	0
Transmission / Substation	6/20/2021	388	6,336	388
Transmission / Substation	6/21/2021	1,747	7,336	1,747
Transmission / Substation	6/21/2021	0	0	0
Transmission / Substation	6/21/2021	26,232	0	0
Transmission / Substation	6/21/2021	4,271	0	0
Transmission / Substation	6/21/2021	0	0	0
Transmission / Substation	6/22/2021	3,194	0	0
Transmission / Substation	6/22/2021	1,186	5,574	1,186
Transmission / Substation	6/22/2021	24,297	6,127	3,097
Transmission / Substation	6/22/2021	0	0	0
Transmission / Substation	6/22/2021	13,765	0	0
Transmission / Substation	6/23/2021	0	0	0
Transmission / Substation	6/23/2021	0	0	0
Transmission / Substation	6/24/2021	41,595	0	0
Transmission / Substation	6/24/2021	170	5,960	170
Transmission / Substation	6/24/2021	570	2,099	570
Transmission / Substation	6/24/2021	5,189	0	0
Transmission / Substation	6/24/2021	4,251	0	0
Transmission / Substation	6/24/2021	637	0	0
Transmission / Substation	6/25/2021	248	908	248
Transmission / Substation	6/26/2021	1,460	10,252	1,460

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	6/26/2021	1,254	25,623	1,254
Transmission / Substation	6/28/2021	3,684	0	0
Transmission / Substation	6/28/2021	1,500	0	0
Transmission / Substation	6/28/2021	29,540	0	0
Transmission / Substation	6/28/2021	4,472	0	0
Transmission / Substation	6/28/2021	827	1,130	827
Transmission / Substation	6/29/2021	6,121	0	0
Transmission / Substation	6/29/2021	25,773	0	0
Transmission / Substation	6/29/2021	0	0	0
Transmission / Substation	6/29/2021	0	0	0
Transmission / Substation	6/29/2021	4,591	0	0
Transmission / Substation	6/30/2021	3,256	0	0
Transmission / Substation	7/3/2021	4,523	0	0
Transmission / Substation	7/3/2021	25,690	0	0
Transmission / Substation	7/4/2021	5,533	0	0
Transmission / Substation	7/5/2021	0	0	0
Transmission / Substation	7/7/2021	0	0	0
Transmission / Substation	7/8/2021	129,446	0	0
Transmission / Substation	7/10/2021	0	0	0
Transmission / Substation	7/10/2021	44,482	0	0
Transmission / Substation	7/10/2021	807	27,048	807
Transmission / Substation	7/12/2021	2,592	0	0
Transmission / Substation	7/12/2021	724	2,606	724
Transmission / Substation	7/12/2021	13,163	0	0
Transmission / Substation	7/12/2021	3,389	0	0
Transmission / Substation	7/12/2021	0	0	0
Transmission / Substation	7/13/2021	1,153	119,812	1,153
Transmission / Substation	7/13/2021	920	0	0
Transmission / Substation	7/13/2021	920	19,418	920
Transmission / Substation	7/13/2021	550	17,472	550
Transmission / Substation	7/14/2021	17,819	497,048	15,032
Transmission / Substation	7/14/2021	55	992	55
Transmission / Substation	7/14/2021	12,466	0	0
Transmission / Substation	7/15/2021	0	0	0
Transmission / Substation	7/17/2021	671	6,156	184
Transmission / Substation	7/18/2021	0	0	0
Transmission / Substation	7/19/2021	5,635	0	0
Transmission / Substation	7/20/2021	672	3,349	672
Transmission / Substation	7/20/2021	309	9,208	309
Transmission / Substation	7/20/2021	0	0	0
Transmission / Substation	7/20/2021	0	0	0
Transmission / Substation	7/21/2021	15,215	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	7/21/2021	0	0	0
Transmission / Substation	7/21/2021	17,595	0	0
Transmission / Substation	7/21/2021	5,085	2,941	466
Transmission / Substation	7/21/2021	0	0	0
Transmission / Substation	7/22/2021	6,079	0	0
Transmission / Substation	7/22/2021	12,466	0	0
Transmission / Substation	7/23/2021	692	786	692
Transmission / Substation	7/23/2021	25,690	0	0
Transmission / Substation	7/24/2021	1,798	3,326	1,798
Transmission / Substation	7/25/2021	19,393	0	0
Transmission / Substation	7/26/2021	6,342	0	0
Transmission / Substation	7/26/2021	2,606	0	0
Transmission / Substation	7/26/2021	29,708	0	0
Transmission / Substation	7/26/2021	39,930	0	0
Transmission / Substation	7/26/2021	724	19,065	724
Transmission / Substation	7/27/2021	29,540	0	0
Transmission / Substation	7/28/2021	532	11,979	532
Transmission / Substation	7/28/2021	12,116	0	0
Transmission / Substation	7/28/2021	0	0	0
Transmission / Substation	7/29/2021	29,181	0	0
Transmission / Substation	7/29/2021	1,265	43,727	1,265
Transmission / Substation	7/30/2021	9,247	0	0
Transmission / Substation	7/31/2021	0	0	0
Transmission / Substation	8/1/2021	536	5,266	536
Transmission / Substation	8/2/2021	126	6,103	126
Transmission / Substation	8/2/2021	785	0	0
Transmission / Substation	8/3/2021	33,154	0	0
Transmission / Substation	8/5/2021	0	0	0
Transmission / Substation	8/5/2021	7,889	0	0
Transmission / Substation	8/6/2021	2,512	54,845	2,512
Transmission / Substation	8/6/2021	4	0	0
Transmission / Substation	8/6/2021	0	0	0
Transmission / Substation	8/7/2021	29,775	0	0
Transmission / Substation	8/8/2021	0	0	0
Transmission / Substation	8/8/2021	0	0	0
Transmission / Substation	8/9/2021	1,457	4,711	1,457
Transmission / Substation	8/9/2021	0	0	0
Transmission / Substation	8/11/2021	907	1,512	907
Transmission / Substation	8/12/2021	6,504	0	0
Transmission / Substation	8/12/2021	0	0	0
Transmission / Substation	8/12/2021	16,146	0	0
Transmission / Substation	8/18/2021	13,600	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	8/19/2021	1,329	7,221	1,329
Transmission / Substation	8/20/2021	0	0	0
Transmission / Substation	8/20/2021	0	0	0
Transmission / Substation	8/20/2021	1,880	0	0
Transmission / Substation	8/21/2021	562	1,012	562
Transmission / Substation	8/21/2021	0	0	0
Transmission / Substation	8/21/2021	8,052	220,555	7,180
Transmission / Substation	8/22/2021	21,280	0	0
Transmission / Substation	8/23/2021	0	0	0
Transmission / Substation	8/24/2021	1	0	0
Transmission / Substation	8/24/2021	19,997	0	0
Transmission / Substation	8/25/2021	4	0	0
Transmission / Substation	8/26/2021	0	0	0
Transmission / Substation	8/26/2021	25,817	0	0
Transmission / Substation	8/27/2021	6,646	0	0
Transmission / Substation	8/27/2021	4,472	0	0
Transmission / Substation	8/28/2021	1,776	19,071	1,776
Transmission / Substation	8/29/2021	1,404	0	0
Transmission / Substation	8/31/2021	3,597	31,488	3,597
Transmission / Substation	9/4/2021	0	0	0
Transmission / Substation	9/5/2021	547	547	547
Transmission / Substation	9/5/2021	10,564	106,315	5,282
Transmission / Substation	9/6/2021	236	338	236
Transmission / Substation	9/7/2021	43,524	0	0
Transmission / Substation	9/7/2021	43,524	0	0
Transmission / Substation	9/7/2021	678	881	678
Transmission / Substation	9/7/2021	2,265	15,090	2,265
Transmission / Substation	9/7/2021	18,354	0	0
Transmission / Substation	9/7/2021	18,354	0	0
Transmission / Substation	9/8/2021	0	0	0
Transmission / Substation	9/8/2021	1	5	1
Transmission / Substation	9/10/2021	3,520	0	0
Transmission / Substation	9/10/2021	2,548	16,645	2,548
Transmission / Substation	9/10/2021	2,201	86,791	2,201
Transmission / Substation	9/10/2021	7,602	0	0
Transmission / Substation	9/10/2021	0	0	0
Transmission / Substation	9/13/2021	22,183	0	0
Transmission / Substation	9/13/2021	19,211	0	0
Transmission / Substation	9/13/2021	1,506	0	0
Transmission / Substation	9/13/2021	0	0	0
Transmission / Substation	9/13/2021	5,533	0	0
Transmission / Substation	9/13/2021	8,888	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	9/17/2021	0	0	0
Transmission / Substation	9/17/2021	0	0	0
Transmission / Substation	9/17/2021	3,540	36,069	1,770
Transmission / Substation	9/18/2021	11,722	11,722	11,722
Transmission / Substation	9/19/2021	10,108	0	0
Transmission / Substation	9/20/2021	12,315	0	0
Transmission / Substation	9/20/2021	3,147	6,399	3,147
Transmission / Substation	9/21/2021	10,108	0	0
Transmission / Substation	9/22/2021	0	0	0
Transmission / Substation	9/22/2021	5,758	42,239	5,758
Transmission / Substation	9/23/2021	3,246	0	0
Transmission / Substation	9/23/2021	0	0	0
Transmission / Substation	9/24/2021	2,557	0	0
Transmission / Substation	9/24/2021	14,787	0	0
Transmission / Substation	9/24/2021	6,777	0	0
Transmission / Substation	9/25/2021	17,270	0	0
Transmission / Substation	9/25/2021	18,990	0	0
Transmission / Substation	9/25/2021	6,585	0	0
Transmission / Substation	9/25/2021	0	0	0
Transmission / Substation	9/25/2021	539	2,048	539
Transmission / Substation	9/26/2021	0	0	0
Transmission / Substation	9/26/2021	1,384	28,087	1,384
Transmission / Substation	9/26/2021	2,978	3,871	2,978
Transmission / Substation	9/26/2021	0	0	0
Transmission / Substation	9/26/2021	1,103	5,515	1,103
Transmission / Substation	9/28/2021	2,557	0	0
Transmission / Substation	10/1/2021	0	0	0
Transmission / Substation	10/1/2021	5,625	13,457	5,625
Transmission / Substation	10/5/2021	0	0	0
Transmission / Substation	10/6/2021	5,215	0	0
Transmission / Substation	10/6/2021	6,028	0	0
Transmission / Substation	10/8/2021	0	0	0
Transmission / Substation	10/8/2021	15,376	0	0
Transmission / Substation	10/9/2021	9,734	59,832	4,326
Transmission / Substation	10/9/2021	2,369	0	0
Transmission / Substation	10/9/2021	17,846	165,138	16,313
Transmission / Substation	10/10/2021	0	0	0
Transmission / Substation	10/11/2021	0	0	0
Transmission / Substation	10/11/2021	3,730	0	0
Transmission / Substation	10/12/2021	944	27,182	944
Transmission / Substation	10/12/2021	4,116	47,146	1,257
Transmission / Substation	10/12/2021	310	1,200	310

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	10/12/2021	310	383	310
Transmission / Substation	10/14/2021	459	19,676	459
Transmission / Substation	10/15/2021	1,528	2,496	1,528
Transmission / Substation	10/15/2021	5,046	0	0
Transmission / Substation	10/18/2021	302	327	302
Transmission / Substation	10/18/2021	538	6,707	538
Transmission / Substation	10/22/2021	0	0	0
Transmission / Substation	10/22/2021	1,312	46,180	1,312
Transmission / Substation	10/22/2021	1	71	1
Transmission / Substation	10/22/2021	6,458	80,536	6,458
Transmission / Substation	10/23/2021	1,010	19,189	1,010
Transmission / Substation	10/24/2021	22,212	0	0
Transmission / Substation	10/24/2021	14,142	0	0
Transmission / Substation	10/25/2021	15,376	0	0
Transmission / Substation	10/25/2021	15,376	0	0
Transmission / Substation	10/25/2021	959	29,377	959
Transmission / Substation	10/25/2021	0	0	0
Transmission / Substation	10/26/2021	1	0	0
Transmission / Substation	10/26/2021	3,050	48,422	3,050
Transmission / Substation	10/26/2021	4,776	17,268	4,776
Transmission / Substation	10/26/2021	1,053	40,119	1,053
Transmission / Substation	10/27/2021	19,350	0	0
Transmission / Substation	10/28/2021	18,392	0	0
Transmission / Substation	10/28/2021	1,740	0	0
Transmission / Substation	10/28/2021	0	0	0
Transmission / Substation	10/28/2021	2,217	8,963	2,217
Transmission / Substation	10/29/2021	22,555	0	0
Transmission / Substation	10/30/2021	0	0	0
Transmission / Substation	10/30/2021	4,339	0	0
Transmission / Substation	10/30/2021	6,625	0	0
Transmission / Substation	10/30/2021	1,473	36,064	1,473
Transmission / Substation	10/31/2021	0	0	0
Transmission / Substation	11/1/2021	1,791	6,717	1,791
Transmission / Substation	11/1/2021	860	12,824	860
Transmission / Substation	11/3/2021	1,518	0	0
Transmission / Substation	11/3/2021	2,006	46,805	2,006
Transmission / Substation	11/5/2021	2,415	81,506	2,415
Transmission / Substation	11/5/2021	2,832	26,854	1,784
Transmission / Substation	11/5/2021	131	823	131
Transmission / Substation	11/6/2021	18,910	229,346	18,910
Transmission / Substation	11/7/2021	13,069	0	0
Transmission / Substation	11/7/2021	0	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	11/8/2021	6,052	22,767	4,684
Transmission / Substation	11/9/2021	3,241	0	0
Transmission / Substation	11/9/2021	10,204	61,715	2,551
Transmission / Substation	11/10/2021	2,128	8,384	2,128
Transmission / Substation	11/11/2021	0	0	0
Transmission / Substation	11/11/2021	0	0	0
Transmission / Substation	11/11/2021	0	0	0
Transmission / Substation	11/11/2021	0	0	0
Transmission / Substation	11/13/2021	2,012	0	0
Transmission / Substation	11/14/2021	51,351	0	0
Transmission / Substation	11/14/2021	848	0	0
Transmission / Substation	11/15/2021	22,829	0	0
Transmission / Substation	11/15/2021	12,919	0	0
Transmission / Substation	11/16/2021	11,720	0	0
Transmission / Substation	11/18/2021	68,636	0	0
Transmission / Substation	11/19/2021	190	8,846	190
Transmission / Substation	11/19/2021	8,096	154,871	6,442
Transmission / Substation	11/19/2021	11,349	0	0
Transmission / Substation	11/19/2021	222	11,596	222
Transmission / Substation	11/19/2021	222	710	222
Transmission / Substation	11/20/2021	0	0	0
Transmission / Substation	11/20/2021	7,789	0	0
Transmission / Substation	11/20/2021	3,381	0	0
Transmission / Substation	11/20/2021	24,471	443,648	23,770
Transmission / Substation	11/20/2021	653	6,839	653
Transmission / Substation	11/21/2021	1,192	30,544	1,192
Transmission / Substation	11/21/2021	3,381	0	0
Transmission / Substation	11/21/2021	1	0	0
Transmission / Substation	11/21/2021	2,844	128,359	2,844
Transmission / Substation	11/21/2021	2,691	0	0
Transmission / Substation	11/21/2021	33,143	0	0
Transmission / Substation	11/22/2021	6,712	0	0
Transmission / Substation	11/23/2021	607	0	0
Transmission / Substation	11/25/2021	3,558	0	0
Transmission / Substation	11/25/2021	4,192	0	0
Transmission / Substation	11/25/2021	14,590	0	0
Transmission / Substation	11/26/2021	12,103	0	0
Transmission / Substation	11/27/2021	16,231	0	0
Transmission / Substation	11/28/2021	0	0	0
Transmission / Substation	11/30/2021	6,093	0	0
Transmission / Substation	11/30/2021	506	15,403	506
Transmission / Substation	12/1/2021	14,191	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	12/1/2021	1,569	0	0
Transmission / Substation	12/3/2021	0	0	0
Transmission / Substation	12/4/2021	0	0	0
Transmission / Substation	12/4/2021	1,517	0	0
Transmission / Substation	12/5/2021	19,350	0	0
Transmission / Substation	12/5/2021	0	0	0
Transmission / Substation	12/6/2021	23,150	0	0
Transmission / Substation	12/6/2021	0	0	0
Transmission / Substation	12/6/2021	0	0	0
Transmission / Substation	12/6/2021	0	0	0
Transmission / Substation	12/6/2021	0	0	0
Transmission / Substation	12/7/2021	1,397	0	0
Transmission / Substation	12/8/2021	8,576	0	0
Transmission / Substation	12/8/2021	0	0	0
Transmission / Substation	12/8/2021	1,505	0	0
Transmission / Substation	12/9/2021	50,071	23,887	19,011
Transmission / Substation	12/10/2021	85,844	0	0
Transmission / Substation	12/12/2021	40,237	0	0
Transmission / Substation	12/12/2021	686	17,470	686
Transmission / Substation	12/12/2021	4,568	0	0
Transmission / Substation	12/13/2021	32,139	645,341	18,978
Transmission / Substation	12/13/2021	18,978	207,493	18,978
Transmission / Substation	12/14/2021	8,130	77,486	3,281
Transmission / Substation	12/15/2021	8,911	37,615	6,575
Transmission / Substation	12/16/2021	0	0	0
Transmission / Substation	12/17/2021	4,866	0	0
Transmission / Substation	12/18/2021	262	0	0
Transmission / Substation	12/18/2021	2,854	44,308	2,854
Transmission / Substation	12/19/2021	14,142	0	0
Transmission / Substation	12/19/2021	39,381	0	0
Transmission / Substation	12/19/2021	8,979	9,578	8,979
Transmission / Substation	12/20/2021	20,231	0	0
Transmission / Substation	12/20/2021	10,555	0	0
Transmission / Substation	12/20/2021	9,012	0	0
Transmission / Substation	12/23/2021	4,547	0	0
Transmission / Substation	12/23/2021	1	0	0
Transmission / Substation	12/24/2021	8,383	0	0
Transmission / Substation	12/24/2021	17,967	0	0
Transmission / Substation	12/24/2021	0	0	0
Transmission / Substation	12/24/2021	0	0	0
Transmission / Substation	12/24/2021	6,199	0	0
Transmission / Substation	12/24/2021	11,059	0	0

Transmission/Substation Outage Data

Outage Event Description	Date of Event	# of Customers	Non-Storm Excluded CMI	Non-Storm Excluded CI
Transmission / Substation	12/26/2021	14,036	0	0
Transmission / Substation	12/26/2021	17,967	0	0
Transmission / Substation	12/26/2021	17,967	0	0
Transmission / Substation	12/27/2021	14,036	0	0
Transmission / Substation	12/27/2021	9,219	0	0
Transmission / Substation	12/27/2021	0	0	0
Transmission / Substation	12/29/2021	2,183	0	0
Transmission / Substation	12/31/2021	2	6	2