

# **ORLANDO UTILITIES COMMISSION**



## **CALENDAR 2014 STORM HARDENING REPORT**

**PURSUANT TO FLORIDA PUBLIC SERVICE  
COMMISSION RULE 25-6.0343**

# Orlando Utilities Commission

## Florida Public Service Commission Pursuant to

### Rule 25-6.0343, F.A.C.

### Calendar Year 2014

#### **1) Introduction**

City of Orlando, Orlando Utilities Commission

500 S. Orange Avenue, Orlando FL 32801

Contact information:

Clint Bullock, Vice-President, Electric Delivery Business Unit  
407-434-4186, [cbullock@ouc.com](mailto:cbullock@ouc.com)

Troy Morris, Director, Distribution Construction & Maintenance  
407-434-4199, [tmorris@ouc.com](mailto:tmorris@ouc.com)

#### **2) Number of meters served in calendar year 2014**

Orlando Utilities Commission served 222,319 electric meters in the Cities of Orlando and St. Cloud and surrounding Orange and Osceola counties as of December 31, 2014.

#### **3) Standards of Construction**

##### **a) National Electric Safety Code Compliance**

The Orlando Utilities Commission (OUC) complies with the construction standards, policies, guidelines, practices, and procedures directed within the National Electrical Safety Code (ANSI C-2) [NESC]. For electrical facilities constructed on or after February 1, 2007, the 2007 NESC applies. The edition of the NESC in effect at the time of the facility's initial construction governs electrical facilities constructed prior to February 1, 2007.

##### **b) Extreme Wind Loading Standards**

Construction standards, policies, guidelines, practices, and procedures at the Orlando Utilities Commission are guided by the extreme wind loading standards specified by

Figure 250-2(d) of the 2002 edition of the NESC for 1) new construction; 2) major planned work, including expansion, rebuild, or relocation of existing facilities, assigned on or after December 10, 2006; and 3) targeted critical infrastructure facilities and major thoroughfares.

OUC has verified that all future construction will meet the NESC requirements with particular focus on the extreme wind loading standards.

**c) Flooding and Storm Surges**

The Orlando Utilities Commission service area is in the middle of Florida. Therefore, flooding and storm surges do not apply.

**d) Safe and Efficient Access of New and Replacement Distribution Facilities**

Electrical construction standards, policies, guidelines, practices, and procedures at OUC provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance.

Since the 1980's, Orlando Utilities has been installing underground and overhead distribution along property frontage corridors. This gives efficient and safer access to these facilities. OUC provides vegetation maintenance and replacement of aged equipment to ensure an efficient, safe, & robust system for all OUC facilities including existing rear lot installations.

**e) Attachments by Others**

Electrical construction standards, policies, guidelines, practices, and procedures at the Orlando Utilities Commission include contractual agreement to enable attachment by others. These contracts state that attachments must adhere to the guidelines of the NESC and all governmental authorities that have jurisdiction.

**4. Facility Inspections**

*a) Policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures.*

**Summary**

Orlando Utilities Commission (OUC) has maintained an active pole inspection and replacement program with records dating back to 1990. We currently uphold an eight-year quadrant based inspection cycle along with annual inspections targeting essential distribution and transmission equipment. Shared transmission structures are inspected and maintained by OUC based on past inspection date.

Distribution and Transmission pole inspection replacements are tracked through an existing maintenance work order database to insure timely replacement.

### **Inspection Procedures**

Visual inspection shall be made of all poles from the ground line to the top before any other inspection. Visual inspection shall include: type of wood, original treatment, circumference, age of pole (if it can be determined), height, obvious splits, woodpecker holes, and any other physical damages to the pole. Also a visual check within the limitations of the inspector's expertise, is to be made at such time of the attachments to the pole being inspected for obvious conditions that appear improper, such as slack guy wires, slack overhead conductors, broken insulators, leaking transformers, missing guy guards, rotten cross arms, loose or faulty equipment, abandoned poles, etc.

### **Excavation**

Earth shall be removed from the entire circumference of the pole to a minimum depth of 18 inches below ground line. Width of the hole shall be 4 inches clearance for the pole surface at the bottom and 10 inches at the ground line.

Poles with electric risers should not be excavated, but should be inspected by sounding, bored and fumigated.

### **Sounding and Boring**

The pole must be sounded from the ground line to a minimum of six feet above the ground line. Sounding shall be done on all four sides of the pole to locate any shell rot or rot pockets on the side.

Sounding shall be done with an approved hammer that leaves a distinctive hammer pattern. If there is evidence of possible interior voids or rot, at least one boring shall be made where a void is indicated. If rot or voids are detected, several borings shall be made per rot or void location and a shell gauge shall be used to determine the extent of all voids or rot. In any event at least two borings shall be made at the ground line to check for rot.

Poles set in concrete or pavement shall be bored at least twice at opposite sides at the ground line down at a 45-degree angle into the pole and the boring sample checked for rot or voids.

### **Removal of Exterior Decay**

All exterior decay must be removed where possible, from 18 inches below the ground line to 3 inches above ground line. The rotted wood is to be removed from the premises and deposited of in a proper manner.

## Evaluation of Pole Condition

After the sounding and boring has been performed and all exterior decay has been removed, the effective circumference of the pole, from 18 inches below the ground line to 15 inches above the ground line, is to be determined.

## Internal Treatment

All sound poles are internally treated if any specific voids of specific internal decay pockets are found. This should involve a sufficient number of bored 3/8 inch holes and the preservative is applied under at least 50 psi of pressure. Internal pole treatment also utilizes MITC-Fume or and OUC approved fumigant.

## Ground Line Treatment

All poles not previously rejected are covered from 18 inches below the ground line to 3 inches above the ground line by an OUC approved preservative and moisture barrier film. Preservative treatment penetrates a minimum of two inches into the pole. Long-term treatment retention studies are kept to assure future review and results.

*b) Number and percentage of transmission and distribution inspections planned and completed for 2014.*

<b>Distribution and Transmission Planned Inspections</b>					
<b>Year</b>	<b>Total System Poles</b>	<b>Planned Inspection</b>	<b>Planned Percentage of System</b>	<b>Inspection Completed</b>	<b>Completed Percentage of System</b>
<b>2014</b>	<b>50582</b>	<b>6400</b>	<b>12%</b>	<b>6410</b>	<b>13%</b>
2013	50721	6400	12%	6415	13%
2012	50804	6400	12%	6400	12%
2011	50938	6400	12%	6730	13%
2010	51142	6400	12%	6534	13%
2009	51435	6400	12%	6411	12%
2008	51114	6400	12%	6124	12%
2007	50536	6400	12.5%	8124	16%
2006	51203	6400	12.5%	5118	10%

c) Number and percentage of transmission and distribution poles / structures failing inspection and the reason for the failure.

<b>Poles Failing Inspection</b>		
	<b>Percentage of Inspection Failure</b>	<b>Total Inspected Poles Failing Inspection</b>
<b>2014</b>	<b>2.3%</b>	<b>145</b>
2013	5.5%	352
2012	6.2%	396
2011	8.9 %	600
2010	9.8 %	642
2009	4.4%	280
2008	3.0 %	189

A detailed report with pole failure causes is attached.

*Attachment 1: (OUC 2014 Pole Report.pdf)*

d) Number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection, including a description of the remediation taken.

<b>Poles needing Remediation</b>					
<b>Year</b>	<b>Total Inspection Poles Failing Inspection</b>	<b>Priority Replacement (Complete)</b>	<b>Restoration (Complete) C-Truss</b>	<b>Work Orders Generated for Replacement</b>	<b>Work Orders Completed</b>
<b>2014</b>	<b>145</b>	<b>2</b>	<b>3</b>	<b>140</b>	<b>5</b>
2013	352	5	56	296	5
2012	396	8	10	386	8
2011	600	2	66	532	267
2010	642	7	121	514	435
2009	280	4	66	210	208
2008	189	9	82	98	98
2007	226	1	81	144	144
2006	208	10	146	52	52

A total of 145 poles failed inspection criteria, two poles deemed priority replacement along with three poles which restoration was deemed necessary using a reinforcing truss were completed in 2014. Work orders for the two priority non-restorable poles have been

completed. The remaining 140 poles are in progress of being generated for replacement in 2015 and 2016. A detailed report denoting the type and class structure is attached.

*Attachment 1: (OUC 2014 Pole Report.pdf)*

## 5. Vegetation Management

- a) *Utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.*

### Maintenance Guidelines and Procedures

The Orlando Utilities Commission (OUC) provides essential electrical service closely tied to our communities' safety, economy and welfare. In delivering reliable electrical service OUC manages the vegetation for approximately 1261 miles of overhead distribution lines and 200 miles of transmission lines within Orange and Osceola Counties. Vegetation line clearance of distribution facilities are trimmed on a four year maintenance cycle. Transmission right of ways' are maintained in two sub-divided regions, urban right of way's on an annual cycle, and rural on a three year cycle. Measures to insure our vegetation program is sufficient and remains on schedule, comprise of annual inspections of the distribution and transmission system.

OUC follows pruning and safety methods outlined in American National Standards Institute A300 and Z133.1. A four-year maintenance cycle of distribution facilities anticipates an average annual growth of 2.5 feet. Trees in close proximity of distribution facilities are trimmed to a minimum distance of 10 feet clearance from energized un-insulated conductors. Fast growing invasive species are targeted for removal during distribution pruning. This proactive measure relieves future trimming requirements and insures clearances within the cycle will be maintained.

The distribution four year cycle is divided into 198 distribution segments reviewed on a quarterly basis. The review is used to make adjustments to crew resources to remain on cycle. OUC currently procures vegetation maintenance labor and equipment through a contract with Davey Tree Experts. The contract comprises twelve to twenty production line trimming crews used in distribution and transmission line clearance.

Vegetation pruning requests are tracked using an internal CIS system available in the distribution operations, customer service and construction and maintenance area. Requests generated from a system outage are either trimmed immediately or given a work order priority for completion. The general foreman provides additional feedback if additional area trimming is needed.

## Appropriate Planting

OUC outlines appropriate planting through educational information presented by the Central Florida Urban Forestry Council. The council presents a theme "Right Tree in the Right Place" to insure proper distance between trees and power lines. By practicing proper planting our goals to insure safety, reliability and lowered maintenance costs become factors which all of our customers benefit.

Vegetation located outside of the right of way is pruned to a distance 10' from energized conductors. The "Right Tree Right Place" concept is reviewed in cases where removals may become prudent. OUC annually sponsors tree planting events during Arbor Day to promote proper planting.

## Measures to insure Sufficient Vegetation Management

OUC has applied a Reliability Centered Maintenance (RCM) approach from NFPA 70B to assure our vegetation management practices area sufficient. An annual inspection of all main feeder distribution lines is conducted to survey acceptable clearances in distribution system throughout the four-year treatment plan. The RCM inspections document vegetation to conductor distances with less than one year's anticipated growth (2.5'). Vegetation work orders are generated and completed during a seasonal non-peak times frame to insure electrical system is fully prepared for the Florida summer storm season.

Two measures are used to verify sufficient vegetation management in our maintenance cycle.

- The documented number of RCM clearances are compared against the trim cycle order. (A circuit about to be trimmed is expected to have more areas of clearance)
- Outage management system (OMS) indices relating to sustained and momentary outages are also compared to the trim cycle order.

### Example: Sufficient Vegetation Management

#### Reliability Centered Maintenance Inspections (RCM)

**Distribution Vegetation Maintenance Management Schedule**

**Four Year Treatment Cycle**

Last revised (2/21/2011)

**Line Segment Circuit Number Work Scheduled**

**Budgeted Costs Based from GIS Mileage**

Line Segment	Circuit Number	Work Scheduled	Budgeted Costs Based from GIS Mileage				Actual Costs vs. Right of Way Mileage	Budget Variance	Circuit Reliability Information			
			Non-Billable Miles	Truck Miles	Non Truck Miles	Budget Production Cost			Total Actual Miles	Actual Non Truck Miles	Actual Truck Miles	Actual Production Cost
GIS 1260147		Initiated Date Completion Date										

**Cycle Treatment Year 1**

**Fiscal Year 2010, previous treatment Year 2006**

First Quarter - October / December	Second Quarter - April / May	Third Quarter - July / August	Fourth Quarter - January / February	2007 Circuit Reliability Data															
				0	1	2	3	Total	Twists Complete	Rules Met	2007	6	1	2	3	Total	Tickets Complete		
1	3-14	July-09	October-09	0.47	2.07	7.40	\$32,895.04	9.21	1.99	7.22	\$32,893.35		1/1	200	1	3	4		
2	10-15	August-09	August-09	3.05	0.94	2.11	\$11,268.36	3.38	0.69	2.37	\$12,960.00		1/1	2	2	2	0		
3	14-21	Non Billable	Non Billable	0.00	0.00	0.34	\$0.00	0.00	0.00	0.00	\$0.00		1/1	7	7	7	0		
4	1-22	July-09	November-09	5.85	0.20	5.40	\$16,252.40	5.50	0.22	5.28	\$16,028.46		1/1	7	1105	7	0		
5	14-21	Non Billable	Non Billable	0.00	0.00	0.53	\$0.00	0.00	0.00	0.00	\$0.00		1/1	7	7	7	0		
6	3-25	August-09	September-09	0.21	1.47	1.84	\$1,024.24	0.20	0.59	1.13	\$1,044.02		1/1	7	85	1	1		
7	12-12	July-09	August-09	5.72	1.72	4.00	\$22,211.94	5.32	1.48	3.84	\$20,078.28		1/1	4	152	20	15	35	
8	28-215	September-09	December-09	45.98	11.48	33.80	\$157,620.06	43.56	13.80	29.76	\$162,373.13		2/3	15	30	2	4	5	18
9	10-11	August-09	December-09	7.93	0.65	7.27	\$24,429.42	7.85	1.04	5.91	\$25,579.44		1/1	11	152	1	8	8	
10	1-33	July-09	November-09	0.00	0.05	0.58	\$1,847.10	0.58	0.05	0.47	\$1,860.10		1/1	3	3	3	0		

- b) *Quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities.*

### **Annual Plan**

The 2014 annual budget for Distribution and Transmission Vegetation management was approximately three million dollars and will remain consistent for 2014. OUC plans to continue with treatment of 321 miles of distribution line clearance and 107 miles of transmission ROW to remain on established cycles. Treatment of distribution line clearance will consist of bucket and rear lot climbing crews. Treatment of the transmission rural corridors, conducted on a three-year cycle, maintained using a combination of integrated vegetation management (IVM). Transmission urban corridors are maintained annually with a more traditional pruning and removal maintenance methods.

<b>Vegetation Treatment</b>					
<b>Year</b>	<b>Distribution</b>		<b>Transmission</b>		
	<b>Total System Miles 1261 ( 4 Year Cycle)</b>	<b>Planned</b>	<b>Completed</b>	<b>Total System Miles 213 (Urban-Annual, Rural 3 Year Cycle)</b>	<b>Planned</b>
					<b>Completed</b>
<b>2014</b>	<b>328</b>	<b>100%</b>		<b>99</b>	<b>100%</b>
2013	287	100%		107	100%
2012	332	100%		127	100%
2011	312	100%		107	100%
2010	329	100%		99	100%
2009	328	100%		105	100%
2008	330	100%		99	100%
2007	330	100%		114	100%

\* OUC's Transmission Vegetation Management Plan (TVMP) allows until May 30th 2015 for completion.

## 2014 Distribution Maintenance Schedule

### Work Completed

Distribution Vegetation Maintenance Management Schedule							Budgeted Costs Based on GIS Mileage			
Line Segment	Circuit Number	Location	Work Scheduled		Quality Control	Budgeted Costs Based on GIS Mileage				
			Initiated Date	Completion Date		Circuit Total Miles	Limited Access	Non Truck Miles	Budget Production Cost	
	GIS 8/30/12									
<b>Cycle Treatment Year 1 - FISCAL YEAR 2014, Previous Treatment 2010 (Oct. 2009 to Oct. 2010)</b>										
Previous treatment Year 2006										
<b>First Quarter - October / December</b>										
1	3-14	Orlando	September-13	September-13	2 Refusals	9.35	2.02	7.33	\$36,756.99	
2	10-15	Orlando	September-13	October-13		3.39	0.99	2.40	1.16	\$14,512.41
3	14-21	Orlando				0.00				\$0.00
4	1-22	Orlando	October-13	December-2013		5.72	0.20	5.52		\$17,720.04
5	14-41	Orlando				0.00			0.20	\$0.00
6	3-23	Orlando	September-13	October-13		2.69	1.55	1.14	1.88	\$15,033.63
7	12-11, 12-12, 12-21	Orlando	October-13	December-13		5.50	1.81	3.69	0.82	\$24,483.12
8	28-213, 28-223, 29-224	St. Cloud	September-13	January-14	Ed St. Palms/Nova S	46.59	14.04	32.55	0.26	\$174,325.08
9	10-11	Orlando	September-13	November-13	nd McJordan - Av	7.98	0.66	7.30		\$26,415.84
10	1-33	Orlando	October-13	October-13		0.60	0.08	0.52	0.58	\$2,130.36
<b>Quarterly Mileage</b>										
						81.80	21.35	80.45	4.90	\$311,377.47
<b>Second Quarter - January / March</b>										
11	4-12	Orlando	December-13	December-13		5.54	0.18	5.36	0.28	\$17,099.34
12	1-32	Orlando	April-14	April-14		0.20	0.20			\$1,507.80
13	4-31	Orlando	February-14	March-14		2.23	1.43	0.80		\$13,130.37
14	12-11	Orlando	December-13	January-14	3 Refusals	13.68	3.15	10.53		\$54,674.46
15	28-221	St. Cloud	December-13	December-13		6.11	4.49	1.62	5.32	\$33,212.96
16	12-34, 12-311	Orlando	January-14	March-14		8.29	5.40	2.89	0.33	\$49,198.53
17	14-23	Orlando	November-13	January-14		6.58	5.76	0.82	0.70	\$45,832.98
18	12-31	Orlando	January-14	March-14		6.88	2.40	4.48		\$31,251.36
19	12-312	Orlando	December-13	January-14		4.43	1.61	2.82	4.70	\$20,420.13
20	27-222	St. Cloud	December-13	December-13		2.98	0.67	2.31	0.03	\$10,259.08
21	9-21	Orlando	October-13	March-14		5.02	2.92	2.10	1.26	\$28,181.58
22	3-21	Orlando	November-13	January-14		4.84	1.61	3.23		\$21,624.30
23	2-11, 2-34	Orlando	January-14	January-14		1.54	0.31	1.23	0.08	\$5,949.60
24	1-13	Orlando	January-14	March-14		7.08	1.60	5.48		\$28,157.16
25	2-31	Orlando	November-13	March-14		11.80	2.22	9.58		\$44,673.04
<b>Quarterly Total Mileage</b>										
						87.20	33.95	53.25	12.70	\$405,372.69
<b>Third Quarter - April / June</b>										
26	14-24	Orlando	March-14	March-14		0.31		0.31	1.23	\$910.47
27	9-11, 9-23	Orlando	February-14	June-14		8.94	2.11	6.83	1.11	\$35,967.00
28	29-223	St. Cloud	January-14	May-14	Lateral - No Conta	20.55	3.64	16.91	0.12	\$66,915.32
29	35-22	Orlando	NON BILLABLE	NON BILLABLE		0.00		0.50		\$0.00
30	2-41	Orlando	February-14	March-14		8.77	1.88	6.89	0.02	\$34,409.25
31	21-12	Orlando	March-14	March-14		1.38	0.36	1.02		\$5,709.78
32	1-34	Orlando	February-14	June-14		8.36	1.41	6.95	0.22	\$31,042.14
33	2-13	Orlando	February-14	June-14		8.87	4.65	4.22	1.04	\$47,450.49
34	35-11, 35-21	Orlando	March-14	April-14		2.18	1.05	1.13		\$11,234.76
35	1-14	Orlando	March-14	July-14		6.97	3.99	2.98		\$38,832.67
36	11-32	Orlando	March-14	March-14		1.92	0.58	1.34		\$8,308.20
37	9-32	Orlando	October-13	June-14		7.19	1.04	6.15		\$25,903.11
<b>Quarterly Total Mileage</b>										
						75.44	20.71	54.73	4.24	\$306,683.39
<b>Forth Quarter - July / September</b>										
38	10-42	Orlando	Apr-14	Sep-14		1.45	0.09	1.36		\$4,672.83
39	35-32	Orlando	May-14	May-14		6.72	4.32	2.40		\$39,617.28
40	1-43	Orlando	April-14	Jul-14	Lateral - Outage Re	2.95	0.33	2.62		\$10,182.81
41	12-22	Orlando	April-14	Jul-14		3.22	0.68	2.54		\$12,586.50
42	2-12	Orlando	April-14	Aug-14		6.71	4.31	2.40	0.57	\$39,541.89
43	27-214, 27-221, 27-231	St. Cloud	Feb-14	Jun-14	Q/C Work	14.00	1.84	12.16	0.10	\$43,086.72
44	9-23	Orlando	Apr-14	Sep-14	Q/C Work	6.56	0.49	6.07	0.50	\$21,521.70
45	5-22	Orlando	Apr-14	Sep-14		5.25	4.72	0.53	1.26	\$37,140.69
46	21-14	Orlando	Aug-14	Aug-14		0.04		0.04		\$117.48
47	12-12, 12-21	Orlando	April-14	Sep-14	Q/C Work	12.56	2.53	10.03		\$48,531.78
48	35-33	Orlando	May-14	Sep-14		12.14	4.39	7.75	0.06	\$55,857.96
49	11-21, 11-42	Orlando	May-14	Sep-14	Q/C Work	12.32	2.46	9.86		\$47,504.76
<b>Quarterly Total Mileage</b>										
						83.92	26.16	57.76	2.49	\$360,362.40
<b>Annual Total Miles</b>										
						328.36	102.17	226.19	24.33	\$1,383,795.95
<b>Total Annual Variance Amount</b>										



## 2015 Distribution Maintenance Schedule

### Work Plan

Distribution Vegetation Maintenance Management Schedule							Budgeted Costs Based on GIS Mileage				
Four Year Treatment Cycle							Last revised 1/14/2015				
Line Segment	Circuit Number	Location	Work Scheduled		Quality Control	Budgeted Costs Based on GIS Mileage					
			Initiated Date	Completion Date		Circuit Total Miles	Non Truck	Limited Acces	Truck	Non Billable Miles	Budget Production Cost
<b>Cycle Treatment Year 2 - FISCAL YEAR 2015 (Oct. 2014, to Oct. 2015)</b>											
Previous treatment Year 2007											
<b>First Quarter - October / December</b>											
50	2-24	Orlando	Jul-14		1.30 Climbing Miles	11.87	4.43		7.44		\$55,249.05
51	30-22	Orlando	Dec-14	Dec-14		1.34	1.18	0.16			\$9,365.94
52	16-22	Orlando	Jul-14	Dec-14	Need Q/C	9.92	5.93	3.99	0.59		\$56,424.90
53	14-16	Orlando	Dec-14	Dec-14		1.10	0.22	0.88	0.13		\$4,243.14
54	19-22	Orlando	Aug-14	Oct-14	Spray Work - O/C	12.84	6.84	6.00			\$69,188.76
55	27-221, 27-233	St. Cloud	May-14	Aug-14	O/C Inspection	17.45	2.87	14.58			\$55,957.76
56	11-41	Orlando	Dec-14		1.58 Climbing Miles	8.06	1.60	7.36	0.41		\$33,678.72
57	5-24	Orlando	Dec-14	Dec-14	Need Q/C	1.19	0.49	0.70			\$5,750.01
58	4-23, 14-11, 14-22	Orlando	Aug-14	Dec-14		8.85	1.97	6.88			\$35,058.39
59	21-24	Orlando	Aug-14	Aug-14		1.36	0.01	1.35			\$4,040.34
60	3-24	Orlando	Aug-14		1.18 Climbing Miles	8.12	3.49	4.63			\$39,899.42
61	14-34	Orlando	Dec-14	Dec-14	Jail Access Only	1.50	0.30	1.20	0.84		\$5,786.10
<b>Quarterly Total Mileage</b>							84.50	28.33	55.17	1.97	\$374,852.53
<b>Second Quarter - January / March</b>											
62	11-43	Orlando				7.08	1.19	5.89	0.45		\$26,270.34
63	28-214, 28-221, 28-222	St. Cloud				38.63	7.98	30.65	0.02		\$130,233.16
64	30-22, 30-36	Orlando				2.03	1.25	0.78	0.58		\$11,714.61
65	33-211	St. Cloud	Jan-15			4.94	0.32	4.62			\$13,916.72
66	9-33	Orlando				4.34	0.85	3.39	0.69		\$17,118.48
67	12-13, 12-34	Orlando				7.44	2.05	5.39	0.75		\$31,285.38
68	21-25	Orlando				1.58	0.18	1.40			\$5,468.82
69	4-21	Orlando				5.00	1.09	3.91	0.69		\$19,701.18
70	4-22	Orlando				6.72	0.79	5.93			\$23,372.22
71	6-311	Orlando	Jan-15	Jan-15		4.74	3.03	1.71			\$27,865.44
72	5-16	Orlando				1.61	1.48	0.13			\$11,539.53
73	19-12, 19-24	Orlando				4.80	3.61	0.99	0.34		\$30,123.42
74	14-31	Orlando				1.75	0.70	1.05	0.85		\$8,361.15
75	14-33, 14-43	Orlando				3.49	2.25	1.24			\$20,604.63
76	5-13, 5-43	Orlando				1.99	0.92	1.07	2.69		\$10,078.47
<b>Quarterly Total Mileage</b>							95.94	27.79	68.15	7.06	\$387,853.55
<b>Third Quarter - April / June</b>											
77	1-42	Orlando				4.34	0.03	4.31	0.01		\$12,884.64
78	14-12	Orlando				1.96		1.96	0.11		\$5,756.52
79	35-25	Orlando				11.77		11.77	0.74		\$34,568.49
80	2-332	Orlando				5.36	2.75	2.61	1.12		\$28,397.82
81	3-13	Orlando				8.83	5.74	3.09	0.19		\$52,349.19
82	1-21	Orlando				0.30		0.30			\$81.10
83	3-32	Orlando				8.87	1.55	7.32	0.01		\$33,184.29
84	21-22	Orlando				0.39	0.28	0.11	1.37		\$2,433.99
85	29-224	St. Cloud				0.48		0.48			\$1,230.72
86	32-221	St. Cloud				23.81	6.85	16.96			\$87,818.64
87	6-12	Orlando				2.09	0.41	1.68			\$8,025.15
88	5-11	Orlando				2.75	1.79	0.96			\$16,314.33
89	6-14	Orlando				0.00			0.03		\$0.00
90	30-14	Orlando				0.31	0.05	0.26	0.58		\$1,140.57
91	14-11, 14-42	Orlando				2.39	1.91	0.48			\$15,809.25
92	30-22, 30-31, 30-36	Orlando				0.64	0.60	0.04	1.27		\$4,640.68
93	11-42	Orlando				2.45	0.26	2.19			\$8,392.17
<b>Quarterly Total Mileage</b>							78.74	22.22	54.52	5.43	\$313,827.75
<b>Forth Quarter - July / September</b>											
94	21-35	Orlando				0.36	0.03	0.33			\$1,195.38
95	27-211	St. Cloud				37.74	17.52	20.22			\$165,233.52
96	14-32	Orlando				12.03	2.90	9.13	0.74		\$48,677.91
97	14-35	Orlando				0.00					\$0.00
98	35-13	Orlando				0.63	0.03	0.60	0.61		\$1,988.37
99	3-35	Orlando				0.00					\$0.00
100	19-13	Orlando				11.49	2.27	9.22			\$44,192.67
101	11-11	Orlando				0.88		0.88	1.20		\$2,584.56
102	4-14	Orlando				10.70	5.31	5.39			\$55,862.52
103	19-12, 19-21	Orlando				0.86	0.47	0.39	0.30		\$4,688.76
104	14-43	Orlando				1.28	0.64	0.64	1.17		\$6,704.64
105	6-321	Orlando				1.67	0.52	1.15	2.86		\$7,297.83
<b>Quarterly Total Mileage</b>							77.64	29.69	47.85	6.88	\$338,426.16
<b>Annual Total Miles</b>							334.82	109.03	225.79	21.34	\$1,414,559.99
<b>Total Annual Variance Amount</b>											



## 2014 Transmission Schedule

### Completed Work

#### Annual Maintenance Scehdule June 1, 2014 - May 30, 2015

Next Cycle Date: June 1, 2017 - May 30,2018

#### Treatment Cycle Year Two

ROW Corridor Segment (Map)	OUC Line	Description	Urban ROW Corridors 1 - 19		TREATMENT ON AN ANNUAL CYCLE					
			Structure Number Begin	Structure Number End	Miles Urban	Anticipated Date of Treatment	Date Assigned	Date Completed	Contractor Inventory Segment	Q/C Inspection
1	0212	Pine Hills to Country Club	1	48	3.2	07/19/14	06/01/14	11/15/14	11/15/14	
2	7-02FPC	Pine Hills to FPC at Dolores W/O Emeralda	1	27	1.1	08/11/14	06/01/14	11/20/14	11/20/14	
3	5-0214	Pine Hills to Turkey Lake	428	365	3.0	08/13/14	06/01/14	11/20/14	11/20/14	
4	5-1424	Turkey Lake to Southwood	362	343	1.8	08/06/14	06/01/14	11/20/14	11/20/14	
5	5-2405	South Term Sub 24 to Southwood	341	303	1.7	08/04/14	06/01/14	11/21/14	11/21/14	
6	5-0508 A	Southwood to Martin (KingsPointe)	260	201	2.8	08/04/14	06/01/14	11/22/14	11/22/14	
	7-05FPC	Southwood to Windemere				08/04/14	06/01/14			
7	5-0508 B	Southwood to Martin	1	14	1.8	08/10/14	06/01/14		REMOVED	REMOVED
8	5-08-30	Martin to Convention Center	14	16	0.4	08/18/14	06/01/14		REMOVED	REMOVED
9	5-0405	Holden to Southwood	506	586	3.6	07/29/14	06/01/14	11/26/14	11/26/14	
10	5-0409	Holden to Michigan	2	78	3.2	08/02/14	06/01/14	11/27/14	11/27/14	
11	5-0910	Michigan to America (On Division)	56	132	3.7	10/01/14	06/01/14	12/04/14	12/04/14	
12	5-1013	America to Kaley	1	26	1.4	10/01/14	06/01/14	12/05/14	12/05/14	
		Michigan and Gowen to Bumby and Jersey								
13	5-1618	Jersey	1	5	0.2	10/01/14	06/01/14	12/04/14	12/04/14	
14	5-0916	Michigan to Grant	1	52	2.3	01/01/15	06/01/14	12/05/14	12/05/14	
		Michigan to Pershing (Follows Raeford Rd)								
15	5-0609	Raeford Rd)	2	93	5.5	11/17/14	06/01/14	12/31/14	12/31/14	
16	5-0616	Grant to Pershing	1	27	2.1	10/14/14	06/01/14	12/29/14	12/29/14	
17	7-622	Pershing to Sub 22 Term Site	135	157	3.4	12/04/14	06/01/14	12/29/14	12/29/14	
	5-0306 A & B									
18	4-27KISS	Azalea to Pershing A & B	143	182	4.1	11/28/14	06/01/14	12/24/14	12/24/14	
19	4-27KISS	Shared W/ KUA	2	64	2.6	12/09/14	06/01/14	12/30/14	12/30/14	
						Total Urban Annual Treatment Miles	48.1			

OUC Line	Description	Rural ROW Corridors 22-27		TREATMENT ON A THREE YEAR CYCLE					
		Structure Number Begin	Structure Number End	Miles Rural	Anticipated Date of Treatment	Date Assigned	Date Completed	Contractor Inventory Segment	Q/C Inspection
22	5-3025	Convention Ctr to Orangewood North Term	17	29	2.5	4/1/14	06/01/14	6/28/2014	6/28/2014
23	7-2615	Orangewood South Term to Taft	34	66	6.1	4/1/14	06/01/14	6/28/2014	6/28/2014
24	7-15 / Cane Island	1/4 of the Lakeland Line Shared W/ KUA	258	220	6.4	4/1/14	06/01/14	6/28/2014	6/28/2014
25	Island / Osceola	1/4 of the Lake Land Line Shared W/ KUA	196	220	4.7	4/1/14	06/01/14	6/28/2014	6/28/2014
26	7-Osceola - Agnes-Teco	1/4 of the Lakeland Line Shared W/ TECO	196	66	21.5	4/1/14	06/01/14	08/23/14	08/23/14
27	Agnes-McIntosh	1/4 of the LakeLand Line Shared W/ TECO	65	1	9.7	4/1/14	06/01/14	09/20/14	09/20/14
						Total Proposed Annual Treatment Miles	50.9		
						Total Urban + Rural ROW Miles	99.0		

## 2015 Transmission Schedule

### Work Plan

#### Annual Maintenance Schedule    June 1, 2015- May 30, 2016

Next Cycle Date:

June 1, 2016 - May 30, 2017

##### Treatment Cycle

#### Urban ROW Corridors 1 - 19 TREATMENT ON AN ANNUAL CYCLE

ROW Corridor Segment (Map)	OUC Line	Description	Structure Number Begin	Structure Number End	Miles Urban
1	5-0212	Pine Hills to Country Club	1	48	3.2
2	7-02FPC	Pine Hills to FPC at Dolores W/O Emeralda	1	27	1.1
3	5-0214	Pine Hills to Turkey Lake	428	365	3.0
4	5-1424	Turkey Lake to Southwood	362	343	1.8
5	5-2405	South Term Sub 24 to Southwood Sub 5	341	303	1.7
6	5-0508 A	Southwood to Martin (KingsPointe) East Line	260	201	2.8
7	7-05FPC	Southwood to Windemere			
8	5-0508 B	Southwood to Martin	1	14	1.8
9	6-08-30	Martin to Convention Center	14	16	0.4
10	5-0405	Holden to Southwood	506	586	3.6
11	5-0409	Holden to Michigan	2	78	3.2
12	5-0910	Michigan to America (On Division)	56	132	3.7
13	5-1013	America to Kaley	1	26	1.4
14	5-1618	Michigan and Gowen to Burnby and Jersey	1	5	0.2
15	5-0916	Michigan to Grant	1	52	2.3
16	5-0609	Michigan to Pershing (Follows Raeford Rd)	2	93	5.5
17	5-0816	Grant to Pershing	1	27	2.1
18	7-622	Pershing to Sub 22 Term Site	135	157	3.4
19	5-0306 A & B	Azalea to Pershing A & B	143	182	4.1
20	4-27KISS	Shared W/ KUA	2	64	2.6
<b>Total Urban Annual Treatment Miles</b>					<b>48.1</b>

#### Rural ROW Corridors 20-33 TREATMENT ON AN ANNUAL CYCLE

	OUC Line	Description	Structure Number Begin	Structure Number End	Miles Rural
22	5-3025	Convention Ctr to Orangewood North Term	17	29	2.5
23	7-2615	Orangewood South Term to Taft	34	66	6.1
24	7-15 / Cane Island	Taft to KUA Cane Island tap	268	220	6.4
25	Island / Osceola	KUA Cane Island tap to TECO Osceola	106	220	4.7
26	1/4 of the Lakeland Line Shared W/ TECO	1/4 of the Lakeland Line Shared W/ TECO	196	66	21.5
27	7-Osceola - Agnes-	TECO Osceola to TECO Lake Agnes			
28	McIntosh	TECO Lake Agnes to LAK McIntosh	65	1	9.7
29	7-1517	Sub 15 to Sub 17	67	180	23.9
30	7-SEC-1	Stanton Unit 1 Generator			
31	7-SEC-2	Stanton unit 2 Generator			
32	7-17RAT2	SEC Reserve Aux Trans 2			
33	7-17RAT1	SEC Reserve Aux Trans 1			
34	7-1731	Sub 17 to SEC A			
35	7-1736	Sub 17 to SEC B	TBD	TBD	TBD
36	7-15 19	Taft to Airport Industrial Park	1A	14	
37	7-2332	Sub 32 to Sub 23 South Term Site	102A	109	
38	4-2728	Central to North	1	120	8.6
39	4-2829				7.6
40	7-29FPC	North to Holopaw	1	69	8.1
41	5-2933	Sub 29 to Sub 33			10.8
42	5-3327	Sub 33 to Sub 27 UG Termination			4.7
43	5-0607 A	Pershing to Indian River A	7	71	32.0
44			72	139	
45			140	209	
46			210	256	
47	5-0607 B	Pershing to Indian River B	0	130	
48	7-0717 A	Indian River to Stanton A&B	54E	54B	
49	7-0717 B	Indian River to Stanton A&B	135	156	
50	7-0617 A	Pershing to Stanton (Shares 5-0607 ) ROW	1	34	
51	7-0617 B	Pershing to Stanton (Shares 5-0607 ) ROW	1	34	
52	7-17 FPC A	Stanton to Curry Ford	23	53	
53	7-17 FPC B	Stanton to Rio Pines	23	53	
54	7-07FPL "A"	Indian River to FPL Canaveral "A"	125	127	
55	7-07FPL "B"	Indian River to FPL Canaveral "B"	125	127	
56	7- SEC PEF	Stanton to Progress Energy	1	60	8.0
57	4-28FPC-MR	Narcosse@ Kirby Smith to Sub 28	1	176	19.0
<b>Total Proposed Annual Treatment Miles</b>					<b>173.5</b>
<b>Total Urban + Rural ROW Miles</b>					<b>221.6</b>

## **6. Storm Hardening Research**

Orlando Utilities Commission is a member of the Florida Municipal Electric Association (FMEA), which is participating with all of Florida's electric utilities in storm hardening research through the Public Utility Research Center at the University of Florida. Under separate cover, FMEA is providing the FPSC with a report of research activities. For further information, contact Barry Moline, Executive Director, FMEA, 850-224-3314, ext.1, or [bmoline@publicpower.com](mailto:bmoline@publicpower.com).

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
57732	45	CCA Type C	Non Reject	
64082	45	CCA Type C	Non Reject	
45100	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46004	25	CCA Type C	Non Reject	Groundline Treatment
46001	25	Creosote	Non Restorable Reject	Rejected
59757	50	CCA Type C	Non Reject	
27063	30	CCA Type C	Non Reject	Groundline Treatment
23206	35	Penta	Non Reject	Groundline Treatment,Hollow Heart
12282	25	Penta	Non Reject	Groundline Treatment
12869	30	CCA Type C	Non Reject	Groundline Treatment
21400	45	CCA Type C	Non Reject	Groundline Treatment
54180	35	CCA Type C	Non Reject	
46680	50	CCA Type C	Non Reject	
28209	30	CCA Type C	Non Reject	
46010	25	Creosote	Non Restorable Reject	Rejected
12460	45	CCA Type C	Non Reject	
60913	45	CCA Type C	Non Reject	
46020	30	CCA Type C	Non Reject	Groundline Treatment
21482	40	CCA Type C	Non Reject	
27068	50	CCA Type C	Non Reject	Groundline Treatment
27067	50	CCA Type C	Non Reject	Groundline Treatment
20808	30	CCA Type C	Non Reject	Groundline Treatment
52972	35	CCA Type C	Non Reject	
29908	30	CCA Type C	Non Reject	Groundline Treatment
58887	35	CCA Type C	Non Reject	
46381	35	CCA Type C	Non Reject	Groundline Treatment
48400	40	CCA Type C	Non Reject	Groundline Treatment
65687	35	CCA Type C	Non Reject	
12288	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
48996	30	CCA Type C	Non Reject	Groundline Treatment
31133	35	CCA Type C	Non Reject	
67686	35	CCA Type C	Non Reject	
25218	45	CCA Type C	Non Reject	Groundline Treatment
20834	50	CCA Type C	Non Reject	Groundline Treatment
64026	45	CCA Type C	Non Reject	
34326	40	CCA Type C	Non Reject	Groundline Treatment
66823	50	CCA Type C	Non Reject	
45532	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45529	50	CCA Type C	Non Reject	
66243	45	CCA Type C	Non Reject	
68136	45	CCA Type C	Non Reject	
24834	35	CCA Type C	Non Reject	Groundline Treatment
60673	35	CCA Type C	Non Reject	
34348	40	CCA Type C	Non Reject	
49473	40	CCA Type C	Non Reject	Groundline Treatment
70585	45	CCA Type C	Non Reject	
18859	45	CCA Type C	Non Reject	Groundline Treatment
51245	30	CCA Type C	Non Reject	
49727	35	CCA Type C	Non Reject	Groundline Treatment
18709	35	Penta	Non Reject	Groundline Treatment
25077	40	CCA Type C	Non Reject	Groundline Treatment
48540	40	Penta	Non Reject	Groundline Treatment
55418	60		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
67685	60	CCA Type C	Non Reject	
46026	35	CCA Type C	Non Reject	Groundline Treatment
12356	30	CCA Type C	Non Reject	Groundline Treatment
72289	45	CCA Type C	Non Reject	
32691	40	CCA Type C	Non Reject	Groundline Treatment
20656	40	CCA Type C	Non Reject	Groundline Treatment
48695	45	CCA Type C	Non Reject	Groundline Treatment
50485	35	CCA Type C	Non Reject	
48372	35	CCA Type C	Non Reject	Groundline Treatment
57162	50	CCA Type C	Non Reject	
45459	35	CCA Type C	Non Reject	Groundline Treatment
20837	40	Creosote	Non Reject	Sound & Bore,MITC Fume
47490	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12314	35	CCA Type C	Non Reject	Groundline Treatment
48586	40	CCA Type C	Non Reject	Groundline Treatment
18715	35	CCA Type C	Non Reject	Groundline Treatment
45404	45	CCA Type C	Non Reject	
49856	30	CCA Type C	Non Reject	Groundline Treatment
49854	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20549	35	CCA Type C	Non Reject	Groundline Treatment
49121	40	CCA Type C	Non Reject	Groundline Treatment
20558	40	CCA Type C	Non Reject	Groundline Treatment
49182	35	CCA Type C	Non Reject	
54498	35	CCA Type C	Non Reject	
20770	30	CCA Type C	Non Reject	Groundline Treatment
52973	35	CCA Type C	Non Reject	
51239	30	CCA Type C	Non Reject	Groundline Treatment
49476	45	CCA Type C	Non Reject	
50838	40	Penta in Petroleum	Non Reject	Groundline Treatment
50839	40	Penta in Petroleum	Non Reject	Groundline Treatment
32729	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30155	30	CCA Type C	Non Reject	Groundline Treatment
30060	50	CCA Type C	Non Reject	
20520	50	CCA Type C	Non Reject	Groundline Treatment
49472	40	CCA Type C	Non Reject	Groundline Treatment
12977	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12975	30	CCA Type C	Non Reject	Groundline Treatment
20578	40	CCA Type C	Non Reject	Groundline Treatment
60049	50	CCA Type C	Non Reject	
60042	50	CCA Type C	Non Reject	
60041	50	CCA Type C	Non Reject	
59693	60	CCA Type C	Non Reject	
59691	60	CCA Type C	Non Reject	
59690	60	CCA Type C	Non Reject	
60990	35	CCA Type C	Non Reject	
55002	45	CCA Type C	Non Reject	
49138	35	CCA Type C	Non Reject	Groundline Treatment
49139	35	CCA Type C	Non Reject	Groundline Treatment
26001	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47272	30	CCA Type C	Non Reject	Groundline Treatment
21221	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20652	35	CCA Type C	Non Reject	Groundline Treatment
30043	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46060	30		Non Reject	
49810	30	CCA Type C	Non Reject	Groundline Treatment
49809	30	CCA Type C	Non Reject	Groundline Treatment
51228	40	CCA Type C	Non Reject	Groundline Treatment
72841	45	CCA Type C	Non Reject	
50135	45	CCA Type C	Non Reject	
58071	45	CCA Type C	Non Reject	
60966	45	CCA Type C	Non Reject	
60965	35	CCA Type C	Non Reject	
12956	40	CCA Type C	Non Reject	
12959	40	CCA Type C	Non Reject	Groundline Treatment
55834	45	CCA Type C	Non Reject	
55835	45	CCA Type C	Non Reject	
12574	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57639	45	CCA Type C	Non Reject	
79460	45	CCA Type C	Non Reject	
79461	45	CCA Type C	Non Reject	
48387	35	CCA Type C	Non Reject	Groundline Treatment
12582	45	CCA Type C	Non Reject	
12554	40	Penta	Non Reject	Groundline Treatment
79528	45	CCA Type C	Non Reject	
51236	30	CCA Type C	Non Reject	Groundline Treatment
67510	35	CCA Type C	Non Reject	Groundline Treatment
55144	30	CCA Type C	Non Reject	
20550	35	CCA Type C	Non Reject	Groundline Treatment
49845	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
32048	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31467	45	CCA Type C	Non Reject	Groundline Treatment
20588	40	Creosote	Non Reject	Groundline Treatment
54611	50	CCA Type C	Non Reject	
54698	50	CCA Type C	Non Reject	
20946	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55976	45	CCA Type C	Non Reject	
77205	55	CCA Type C	Non Reject	Groundline Treatment
20675	50	CCA Type C	Non Reject	Groundline Treatment
58394	45	CCA Type C	Non Reject	Groundline Treatment
46678	50	CCA Type C	Non Reject	
46676	50	CCA Type C	Non Reject	
46679	50	CCA Type C	Non Reject	
61547	35	CCA Type C	Non Reject	
12451	40	CCA Type C	Non Reject	Groundline Treatment
27066	50	CCA Type C	Non Reject	Groundline Treatment
12229	40	Penta	Restorable Reject	Sound & Bore,MITC Fume
30100	45	CCA Type C	Non Reject	Groundline Treatment
45399	30	CCA Type C	Non Reject	Groundline Treatment
30123	50	CCA Type C	Non Reject	
58888	35	CCA Type C	Non Reject	
48993	35	CCA Type C	Non Reject	
49155	40	CCA Type C	Non Reject	
49453	30		Non Reject	
47482	35	CCA Type C	Non Reject	
12531	45	CCA Type C	Non Reject	
47358	50		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
29876	30	CCA Type C	Non Reject	Groundline Treatment
46373	35	CCA Type C	Non Reject	Groundline Treatment
60789	45	CCA Type C	Non Reject	
25803	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46397	35	Untreated	Non Reject	
47325	30		Non Reject	
12248	40	Creosote	Non Reject	Sound & Bore,MITC Fume
20568	40	CCA Type C	Non Reject	Groundline Treatment
49714	30	Creosote	Non Reject	Groundline Treatment
30114	40	CCA Type C	Non Reject	Groundline Treatment
49477	30	CCA Type C	Non Reject	Groundline Treatment
18863	45	CCA Type C	Non Reject	Groundline Treatment
54697	50	CCA Type C	Non Reject	
47381	40	CCA Type C	Non Reject	Groundline Treatment
46057	35	CCA Type C	Non Reject	Groundline Treatment
25960	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
51308	35	CCA Type C	Non Restorable Reject	Groundline Treatment
51314	35	CCA Type C	Non Reject	Groundline Treatment
51312	35	CCA Type C	Non Reject	Groundline Treatment
46681	45	CCA Type C	Non Reject	
46723	50	CCA Type C	Non Reject	
57175	50	CCA Type C	Non Reject	
27085	40	CCA Type C	Non Reject	Groundline Treatment
45496	45	CCA Type C	Non Reject	Groundline Treatment
65689	45	CCA Type C	Non Reject	
35038	40	CCA Type C	Non Reject	
35037	35	CCA Type C	Non Reject	Groundline Treatment
53200	35	CCA Type C	Non Reject	
51032	40	CCA Type C	Non Reject	Groundline Treatment
54516	35	CCA Type C	Non Reject	
46011	20	Creosote	Non Reject	Groundline Treatment
45103	20	CCA Type C	Non Reject	Groundline Treatment
59784	60	CCA Type C	Non Reject	
26004	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31754	30	CCA Type C	Non Reject	
59090	40	CCA Type C	Non Reject	Groundline Treatment
59708	45	CCA Type C	Non Reject	
59717	35	CCA Type C	Non Reject	
55423	30	Creosote	Non Reject	Sound & Bore,MITC Fume
30934	35	CCA Type C	Non Reject	Groundline Treatment
68134	45	CCA Type C	Non Reject	
18837	40	CCA Type C	Non Reject	Groundline Treatment
58734	45	CCA Type C	Non Reject	
54139	35	CCA Type C	Non Reject	
28477	50	CCA Type C	Non Reject	Groundline Treatment
18682	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart
20797	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30916	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23799	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45564	30	CCA Type C	Non Reject	Groundline Treatment
23220	35	CCA Type C	Non Reject	Groundline Treatment
47498	40	CCA Type C	Non Reject	Groundline Treatment
12424	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
25404	50	CCA Type C	Non Reject	Groundline Treatment
26989	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49818	25	Creosote	Non Reject	Groundline Treatment
57118	35	CCA Type C	Non Reject	
45469	25	Penta	Non Reject	Groundline Treatment
50010	35	CCA Type C	Non Reject	
26985	30	CCA Type C	Non Reject	Groundline Treatment
48960	45	CCA Type C	Non Reject	Groundline Treatment
23413	35	Creosote	Non Reject	Groundline Treatment
30137	50	CCA Type C	Non Reject	Groundline Treatment
30138	30	CCA Type C	Non Reject	Groundline Treatment
30452	30	Creosote	Non Reject	Groundline Treatment
59821	50	CCA Type C	Non Reject	
70581	45	CCA Type C	Non Reject	
53204	35	CCA Type C	Non Reject	
30039	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46347	35	CCA Type C	Non Reject	Groundline Treatment
45516	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
26950	35	CCA Type C	Non Reject	Groundline Treatment
28678	40	CCA Type C	Non Reject	Groundline Treatment
46040	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
69920	45	CCA Type C	Non Reject	
47341	30	CCA Type C	Non Reject	Groundline Treatment
47340	30	CCA Type C	Non Reject	Groundline Treatment
18851	35	Creosote	Non Reject	Groundline Treatment
55978	45	CCA Type C	Non Reject	
45463	35	Creosote	Non Reject	Sound & Bore,MITC Fume
45462	35	CCA Type C	Non Reject	
12235	40	Penta	Non Reject	Sound & Bore,MITC Fume
12295	25	Penta	Non Reject	Groundline Treatment
12245	30	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
48538	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48398	30	CCA Type C	Non Reject	Groundline Treatment
12513	35	Penta	Non Restorable Reject	Groundline Treatment,Hollow Heart
48855	40		Non Reject	
30031	40	CCA Type C	Non Reject	Groundline Treatment
46087	40	CCA Type C	Non Reject	Groundline Treatment
55969	45	CCA Type C	Non Reject	
49108	35	CCA Type C	Non Reject	Groundline Treatment
48546	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18921	40	Penta in Petroleum	Non Reject	Groundline Treatment
18692	35		Non Reject	
12377	40	CCA Type C	Non Reject	Groundline Treatment
55078	35	CCA Type C	Non Reject	Groundline Treatment
67717	35	CCA Type C	Non Reject	
30125	40	CCA Type C	Non Reject	Groundline Treatment
70193	35	CCA Type C	Non Reject	
18821	40	CCA Type C	Non Reject	Groundline Treatment
51284	30	CCA Type C	Non Reject	Groundline Treatment
56854	50	CCA Type C	Non Reject	
30109	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45403	30	CCA Type C	Non Reject	Groundline Treatment
21024	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
54257	50	CCA Type C	Non Reject	
49739	30	CCA Type C	Non Reject	Groundline Treatment
49738	40	CCA Type C	Non Reject	
30477	35	CCA Type C	Non Reject	
55859	45	CCA Type C	Non Reject	
55860	45	CCA Type C	Non Reject	Groundline Treatment
58890	35	CCA Type C	Non Reject	
12797	55	CCA Type C	Non Reject	Groundline Treatment
60897	45	CCA Type C	Non Reject	
49618	50	CCA Type C	Non Reject	Groundline Treatment
23084	45	CCA Type C	Non Reject	Groundline Treatment
55993	35	CCA Type C	Non Reject	
64182	45	CCA Type C	Non Reject	
47203	30	CCA Type C	Non Reject	Groundline Treatment
21378	45	CCA Type C	Non Reject	Groundline Treatment
53195	50	CCA Type C	Non Reject	
53196	50	CCA Type C	Non Reject	
48859	40		Non Reject	
49175	30	CCA Type C	Non Reject	Groundline Treatment
21106	40	CCA Type C	Non Reject	Groundline Treatment
20721	45	Penta	Non Reject	Groundline Treatment,MITC Fume
27444	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30086	30	Creosote	Non Reject	Sound & Bore,MITC Fume
49105	30	CCA Type C	Non Reject	Groundline Treatment
66226	30	Creosote	Non Reject	Sound & Bore,MITC Fume
54483	45	CCA Type C	Non Reject	
50902	30	CCA Type C	Non Reject	Groundline Treatment
45545	30	CCA Type C	Non Reject	Groundline Treatment
45543	30	Creosote	Non Reject	Groundline Treatment
26980	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49834	35	CCA Type C	Non Reject	Groundline Treatment
49859	30	CCA Type C	Non Restorable Reject	Groundline Treatment
12184	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
61021	45	CCA Type C	Non Reject	
54240	35	CCA Type C	Non Reject	
49173	40	CCA Type C	Non Reject	Groundline Treatment
51023	40	CCA Type C	Non Reject	Groundline Treatment
51031	40	CCA Type C	Non Reject	Groundline Treatment
18805	35	Creosote	Non Reject	Groundline Treatment
59806	45	CCA Type C	Non Reject	
48486	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49819	50	CCA Type C	Non Reject	
45523	35	CCA Type C	Non Reject	Groundline Treatment
25989	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12278	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49482	35	CCA Type C	Non Reject	Groundline Treatment
49469	40	CCA Type C	Non Reject	Groundline Treatment
20658	40	CCA Type C	Non Reject	Groundline Treatment
20660	40	CCA Type C	Non Reject	Groundline Treatment
12188	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34925	35	CCA Type C	Non Reject	Groundline Treatment
20933	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57018	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
49465	40	CCA Type C	Non Reject	Groundline Treatment
49464	40	CCA Type C	Non Reject	Groundline Treatment
50007	50	CCA Type C	Non Reject	
29872	45	CCA Type C	Non Reject	
25996	30	Penta	Non Restorable Reject	Groundline Treatment,Hollow Heart
12436	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
12325	35	CCA Type C	Non Reject	Groundline Treatment
12402	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29458	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
20811	45	Penta	Non Reject	Groundline Treatment,MITC Fume
34981	40	CCA Type C	Non Reject	
51307	35	CCA Type C	Non Reject	
51306	35	CCA Type C	Non Reject	
50908	40	CCA Type C	Non Reject	
50909	35	Creosote	Non Reject	Groundline Treatment
55219	40	CCA Type C	Non Reject	
32712	30	CCA Type C	Non Reject	Groundline Treatment
27037	40	CCA Type C	Non Reject	Groundline Treatment
58720	60	CCA Type C	Non Reject	
47315	35	CCA Type C	Non Reject	Groundline Treatment
21391	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21390	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48404	35	CCA Type C	Non Reject	Groundline Treatment
48595	35	CCA Type C	Non Reject	Groundline Treatment
58414	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20753	45	CCA Type C	Non Reject	Groundline Treatment
20756	45	CCA Type C	Non Reject	Groundline Treatment
72206	50	CCA Type C	Non Reject	
45409	45	CCA Type C	Non Reject	
60552	45	CCA Type C	Non Reject	
76490	35	CCA Type C	Non Reject	
45499	30	CCA Type C	Non Reject	Groundline Treatment
57662	45	CCA Type C	Non Reject	
54572	50	CCA Type C	Non Reject	
54571	50	CCA Type C	Non Reject	
69994	55	CCA Type C	Non Reject	
67750	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58249	35	CCA Type C	Non Reject	Groundline Treatment
55925	45	CCA Type C	Non Reject	
31757	50	CCA Type C	Non Reject	Groundline Treatment
21224	45	CCA Type C	Non Reject	
54566	60	CCA Type C	Non Reject	
18668	35	CCA Type C	Non Reject	Groundline Treatment
21399	45	CCA Type C	Non Reject	Groundline Treatment
71806	45	CCA Type C	Non Reject	Sound Only
71803	45	CCA Type C	Non Reject	
33063	30	CCA Type C	Non Reject	Groundline Treatment
49719	40	CCA Type C	Non Reject	Groundline Treatment
49137	30	CCA Type C	Non Reject	
49136	30	CCA Type C	Non Reject	Groundline Treatment
18691	35		Non Reject	
30139	35	CCA Type C	Non Reject	Groundline Treatment
20823	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
48978	50	CCA Type C	Non Reject	
54127	50	CCA Type C	Non Reject	
52888	35	CCA Type C	Non Reject	
49835	35	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
49837	35	CCA Type C	Non Reject	Groundline Treatment
12706	35	CCA Type C	Non Reject	Groundline Treatment
19098	35	CCA Type C	Non Reject	Groundline Treatment
50827	35	Creosote	Non Restorable Reject	Groundline Treatment
50806	45	CCA Type C	Non Reject	
49237	35	CCA Type C	Non Reject	Groundline Treatment
12652	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47475	30		Non Reject	
12718	35	CCA Type C	Non Reject	Groundline Treatment
12719	35	CCA Type C	Non Reject	Groundline Treatment
49438	30	CCA Type C	Non Reject	Groundline Treatment
64454	35	CCA Type C	Non Reject	
49427	35	Penta	Non Reject	Groundline Treatment
50157	45	CCA Type C	Non Reject	
64575	50	CCA Type C	Non Reject	
47742	40	CCA Type C	Non Reject	
58583	45	CCA Type C	Non Reject	
70589	50	CCA Type C	Non Reject	
70410	35	CCA Type C	Non Reject	
22586	45	CCA Type C	Non Reject	Groundline Treatment
12997	40	Creosote	Non Reject	Sound & Bore,MITC Fume
49511	40	CCA Type C	Non Reject	Groundline Treatment
49514	35	CCA Type C	Non Reject	
49415	50	CCA Type C	Non Reject	Groundline Treatment
49208	40	Penta	Non Reject	Groundline Treatment
50803	45	CCA Type C	Non Reject	
49231	40	CCA Type C	Non Reject	Groundline Treatment
49708	30	CCA Type C	Non Reject	Groundline Treatment
18723	35	Creosote	Non Reject	Groundline Treatment
49442	35	Penta	Non Reject	Groundline Treatment
50000	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49993	35	CCA Type C	Non Reject	Groundline Treatment
50843	35	CCA Type C	Non Reject	
64013	45	CCA Type C	Non Reject	
49706	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48422	25	CCA Type C	Non Reject	Groundline Treatment
33031	30	CCA Type C	Non Reject	Groundline Treatment
19083	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
49258	25	Creosote	Non Reject	
13208	45	CCA Type C	Non Reject	Groundline Treatment
13212	40	CCA Type C	Non Restorable Reject	Groundline Treatment
47514	50		Non Reject	
64419	50	CCA Type C	Non Reject	
34693	35	CCA Type C	Non Reject	Groundline Treatment
19026	40	CCA Type C	Non Reject	Groundline Treatment
20005	35	Creosote	Non Reject	Groundline Treatment
22581	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19025	40	CCA Type C	Non Reject	Groundline Treatment
54676	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
70478	35	CCA Type C	Non Reject	
55846	45	CCA Type C	Non Reject	
55847	45	CCA Type C	Non Reject	
12651	30	CCA Type C	Non Reject	Groundline Treatment
54062	30	Creosote	Non Reject	Groundline Treatment
20007	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54344	45	CCA Type C	Non Reject	
49253	35	CCA Type C	Non Reject	Groundline Treatment
27308	40	CCA Type C	Non Restorable Reject	Rejected
18380	50	CCA Type C	Non Reject	Groundline Treatment
49418	35	Creosote	Non Reject	Groundline Treatment
49242	30	CCA Type C	Non Reject	Groundline Treatment
19012	40	Penta	Non Restorable Reject	Groundline Treatment
12679	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12691	40	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
25262	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
49206	50	CCA Type C	Non Reject	
67679	35	CCA Type C	Non Reject	
67681	45	CCA Type C	Non Reject	
12688	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12672	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49444	30		Non Reject	
47740	40	CCA Type C	Non Reject	
70186	35	CCA Type C	Non Reject	
49239	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
19130	35	CCA Type C	Non Reject	Groundline Treatment
49507	35	CCA Type C	Non Reject	Groundline Treatment
49233	35		Non Reject	
36248	50	CCA Type C	Non Reject	
49504	40	CCA Type C	Non Reject	Groundline Treatment
61361	35	CCA Type C	Non Reject	
49276	40	Creosote	Non Reject	Groundline Treatment,Hollow Heart
49277	35	Penta	Non Restorable Reject	Groundline Treatment
47515	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
22580	45	CCA Type C	Non Reject	Groundline Treatment
19055	40	CCA Type C	Non Reject	Groundline Treatment
49437	35	Creosote	Non Reject	Groundline Treatment
72837	45	CCA Type C	Non Reject	
50457	40	CCA Type C	Non Reject	
49498	45	CCA Type C	Non Reject	
27465	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46646	45	CCA Type C	Non Reject	Groundline Treatment
18644	50	CCA Type C	Non Reject	Groundline Treatment
48659	35	CCA Type C	Non Reject	
49434	40	CCA Type C	Non Reject	Groundline Treatment
61309	45	CCA Type C	Non Reject	
19049	40	CCA Type C	Non Reject	Groundline Treatment
49224	35	Creosote	Non Reject	Sound & Bore,MITC Fume
35813	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46623	30	Untreated	Non Reject	
79476	45	CCA Type C	Non Reject	
79477	35	CCA Type C	Non Reject	
79438	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18462	45	CCA Type C	Non Reject	Groundline Treatment
49230	40	CCA Type C	Non Reject	
47505	45	CCA Type C	Non Reject	
49741	35	CCA Type C	Non Reject	Groundline Treatment
50801	35	CCA Type C	Non Reject	Groundline Treatment
50822	35	Creosote	Non Reject	Rejected
49243	40	CCA Type C	Non Reject	Groundline Treatment
49245	35	CCA Type C	Non Reject	Groundline Treatment
19128	35	Penta	Non Reject	Groundline Treatment
34662	45	CCA Type C	Non Reject	
12650	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58810	50	CCA Type C	Non Reject	
67779	45	CCA Type C	Non Reject	
54534	50	CCA Type C	Non Reject	
19087	35	CCA Type C	Non Reject	Groundline Treatment
49451	40	CCA Type C	Non Reject	Groundline Treatment
49449	35	Penta	Non Reject	Groundline Treatment,MITC Fume
19090	35	Penta	Non Restorable Reject	Groundline Treatment
49488	40	CCA Type C	Non Reject	
47477	30	CCA Type C	Non Reject	Groundline Treatment
27053	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20452	50	CCA Type C	Non Reject	Groundline Treatment
48105	35	CCA Type C	Non Reject	Groundline Treatment
26705	40	Creosote	Non Reject	Groundline Treatment
12678	45	CCA Type C	Non Reject	
12495	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19194	35	Creosote	Non Reject	Groundline Treatment
55161	45	CCA Type C	Non Reject	Groundline Treatment
50809	35	Creosote	Non Reject	Groundline Treatment
22572	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
36251	50	CCA Type C	Non Reject	
20484	40	CCA Type C	Non Reject	Groundline Treatment
20472	45	CCA Type C	Non Reject	
20471	30	CCA Type C	Non Reject	Groundline Treatment
12729	35	CCA Type C	Non Reject	Groundline Treatment
55867	45	CCA Type C	Non Reject	
61308	45	CCA Type C	Non Reject	Groundline Treatment
46509	40	CCA Type C	Non Reject	Groundline Treatment
58809	50	CCA Type C	Non Reject	
59920	45	CCA Type C	Non Reject	
54679	50	CCA Type C	Non Reject	
79446	45	CCA Type C	Non Reject	
67762	35	CCA Type C	Non Reject	
31346	30	CCA Type C	Non Reject	
65693	35	CCA Type C	Non Reject	
24197	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45133	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
24948	35	CCA Type C	Non Reject	
55551	50	CCA Type C	Non Reject	
70559	35	CCA Type C	Non Reject	
53161	30	CCA Type C	Non Reject	Groundline Treatment
45823	50	CCA Type C	Non Reject	Groundline Treatment
70449	35	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
23064	50	CCA Type C	Non Reject	Groundline Treatment
45857	35	CCA Type C	Non Reject	Groundline Treatment
23452	45	Creosote	Non Reject	Sound & Bore,MITC Fume
47732	40	Penta	Non Reject	Groundline Treatment
47731	30	CCA Type C	Non Reject	Groundline Treatment
57625	35	CCA Type C	Non Reject	
24229	45	CCA Type C	Non Reject	
31068	45	CCA Type C	Non Reject	
45071	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60181	45	CCA Type C	Non Reject	
29653	35	CCA Type C	Non Reject	
23394	40	Penta	Non Reject	Sound & Bore,MITC Fume
45637	35	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
23520	45	CCA Type C	Non Reject	Groundline Treatment
34700	35	CCA Type C	Non Reject	Groundline Treatment
55409	50	CCA Type C	Non Reject	
62663	45	CCA Type C	Non Reject	
62736	35	CCA Type C	Non Reject	
24927	30	CCA Type C	Non Reject	Groundline Treatment
60661	35	CCA Type C	Non Reject	
24926	45	CCA Type C	Non Reject	Groundline Treatment
24925	35	Penta	Non Reject	Rejected
53403	45	CCA Type C	Non Reject	
28518	50	CCA Type C	Non Reject	Groundline Treatment
17166	45	CCA Type C	Non Reject	Groundline Treatment
17163	30	CCA Type C	Non Reject	Groundline Treatment
24415	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
64075	50	CCA Type C	Non Reject	
25678	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
12835	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24330	35	CCA Type C	Non Reject	Groundline Treatment
25770	40	CCA Type C	Non Reject	Groundline Treatment
25842	30	CCA Type C	Non Reject	Groundline Treatment
28802	40	Penta	Non Reject	Groundline Treatment
45069	30	CCA Type C	Non Reject	Groundline Treatment
54103	35	CCA Type C	Non Reject	
36348	45	CCA Type C	Non Reject	
22307	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
22308	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70267	35	CCA Type C	Non Reject	
45927	30	CCA Type C	Non Reject	Groundline Treatment
45940	60	CCA Type C	Non Reject	Groundline Treatment
46929	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
17234	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45799	50	CCA Type C	Non Reject	Groundline Treatment
45852	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23868	50	CCA Type C	Non Reject	Groundline Treatment
58221	35	CCA Type C	Non Reject	
47703	30	Penta	Non Restorable Reject	Rejected
17094	40	Penta	Non Reject	Groundline Treatment,MITC Fume
17088	40	Penta	Non Reject	Groundline Treatment
67749	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25868	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
58564	45	CCA Type C	Non Reject	
12871	30	CCA Type C	Non Reject	Groundline Treatment
12865	40	CCA Type C	Non Reject	Groundline Treatment
45831	30	CCA Type C	Non Reject	Groundline Treatment
72782	30	CCA Type C	Non Reject	Groundline Treatment
28696	35	Creosote	Non Reject	Groundline Treatment
24211	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24209	45	CCA Type C	Non Reject	
60666	35	CCA Type C	Non Reject	
28553	50	CCA Type C	Non Reject	Groundline Treatment
28552	45	Penta	Non Reject	Groundline Treatment,MITC Fume
33588	30	CCA Type C	Non Reject	Groundline Treatment
33589	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59139	45	CCA Type C	Non Reject	
47696	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28570	30	CCA Type C	Non Reject	Groundline Treatment
24353	35	Creosote	Non Reject	Groundline Treatment
28840	35	Penta	Non Reject	Groundline Treatment
28807	35	Creosote	Non Reject	Groundline Treatment
25760	35	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
45080	50	CCA Type C	Non Reject	Groundline Treatment
64042	35	CCA Type C	Non Reject	
54493	35	CCA Type C	Non Reject	
65434	30	CCA Type C	Non Reject	Groundline Treatment
22349	45	CCA Type C	Non Reject	Groundline Treatment
70159	35	CCA Type C	Non Reject	
17182	40	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
17177	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
45966	25	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
54895	45	CCA Type C	Non Reject	
48190	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12820	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
29603	40	CCA Type C	Non Reject	Groundline Treatment
29598	40	CCA Type C	Non Reject	Groundline Treatment
29645	35	Penta	Non Reject	Groundline Treatment
33023	30	CCA Type C	Non Reject	Groundline Treatment
58022	35	CCA Type C	Non Reject	
23104	45	CCA Type C	Non Reject	Groundline Treatment
23102	45	CCA Type C	Non Reject	Groundline Treatment
45821	35	CCA Type C	Non Reject	Groundline Treatment
24228	30	CCA Type C	Non Reject	Groundline Treatment
72294	35	CCA Type C	Non Reject	
45931	30	CCA Type C	Non Reject	Groundline Treatment
17364	40	CCA Type C	Non Reject	Groundline Treatment
17365	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
46921	30	CCA Type C	Non Reject	Groundline Treatment
45896	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23911	50	CCA Type C	Non Reject	Groundline Treatment
23907	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45981	30	CCA Type C	Non Reject	Groundline Treatment
17248	40	Penta	Non Reject	Sound & Bore,MITC Fume
17246	35	Penta	Non Reject	Groundline Treatment,MITC Fume
23923	45	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
54206	35	CCA Type C	Non Reject	
54415	45	CCA Type C	Non Reject	
54454	35	CCA Type C	Non Reject	
47692	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29449	30	CCA Type C	Non Reject	Groundline Treatment
61556	35	CCA Type C	Non Reject	
22318	30	CCA Type C	Non Reject	Groundline Treatment
29567	30	CCA Type C	Non Reject	Groundline Treatment
29642	30	CCA Type C	Non Reject	Groundline Treatment
54051	30	Creosote	Non Reject	Sound & Bore,MITC Fume
45863	30	Creosote	Non Reject	Rejected
46555	35	CCA Type C	Non Reject	
70438	35	CCA Type C	Non Reject	
24362	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
24343	35	CCA Type C	Non Reject	
29633	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29636	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
62683	35	CCA Type C	Non Reject	
10246	50	CCA Type C	Non Reject	Groundline Treatment
58629	35	Untreated	Non Reject	
69784	45	CCA Type C	Non Reject	
45370	30	CCA Type C	Non Reject	Groundline Treatment
60648	35	CCA Type C	Non Reject	
46243	30	CCA Type C	Non Reject	Groundline Treatment
28745	40	CCA Type C	Non Reject	
30249	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64798	45	CCA Type C	Non Reject	
48006	45	Penta	Non Reject	Sound & Bore,MITC Fume
45851	30	CCA Type C	Non Reject	Groundline Treatment
29542	35	Creosote	Non Reject	Groundline Treatment
28788	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29560	40	Penta	Non Reject	Groundline Treatment
10259	35	CCA Type C	Non Reject	Groundline Treatment
22322	30	Penta	Non Reject	Groundline Treatment,MITC Fume
46222	35	Creosote	Non Reject	Rejected
52474	45	CCA Type C	Non Reject	Groundline Treatment
24892	35	CCA Type C	Non Reject	Groundline Treatment
29487	30	CCA Type C	Non Reject	Groundline Treatment
52828	40	CCA Type C	Non Reject	Groundline Treatment
25759	35	Penta	Non Reject	Rejected
23525	40	Penta	Non Reject	Sound & Bore,MITC Fume
23461	35	Creosote	Non Reject	Groundline Treatment
45712	30	CCA Type C	Non Reject	Groundline Treatment
55511	45	CCA Type C	Non Reject	
60657	35	CCA Type C	Non Reject	
23899	50	CCA Type C	Non Reject	Groundline Treatment
45987	35	CCA Type C	Non Reject	Groundline Treatment
17354	40	CCA Type C	Non Reject	
17181	40	Penta	Non Reject	Groundline Treatment
17185	35	CCA Type C	Non Reject	Groundline Treatment
17188	30	CCA Type C	Non Reject	Groundline Treatment
12894	35	Penta	Non Reject	Groundline Treatment
17258	45	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
17164	40	CCA Type C	Non Reject	Groundline Treatment
36073	45	CCA Type C	Non Reject	
45789	35	CCA Type C	Non Reject	Groundline Treatment
24992	30	Creosote	Non Reject	Groundline Treatment
25717	45	CCA Type C	Non Reject	
28794	40	CCA Type C	Non Reject	Groundline Treatment
58622	45	CCA Type C	Non Reject	
29342	30	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
45839	50	CCA Type C	Non Reject	Groundline Treatment
62654	35	CCA Type C	Non Reject	
25708	45	CCA Type C	Non Reject	Groundline Treatment
23965	50	CCA Type C	Non Reject	
51064	35	CCA Type C	Non Reject	
25671	35	CCA Type C	Non Reject	Groundline Treatment
25668	35	CCA Type C	Non Reject	Groundline Treatment
45903	40	CCA Type C	Non Reject	Groundline Treatment
28836	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25037	30	Penta	Non Reject	Groundline Treatment
45834	30	CCA Type C	Non Reject	Groundline Treatment
76499	35	CCA Type C	Non Reject	
45882	45	CCA Type C	Non Reject	
45847	50	CCA Type C	Non Reject	Groundline Treatment
27318	40	CCA Type C	Non Reject	Groundline Treatment
45116	25	Creosote	Non Reject	Sound & Bore,MITC Fume
45104	25	CCA Type C	Non Reject	Groundline Treatment
76654	35	CCA Type C	Non Reject	
45110	25		Non Reject	
22306	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28819	30	CCA Type C	Non Reject	Groundline Treatment
53404	45	CCA Type C	Non Reject	
61575	35	CCA Type C	Non Reject	
24416	30	CCA Type C	Non Reject	Groundline Treatment
45963	35	CCA Type C	Non Reject	Groundline Treatment
29572	40	Creosote	Non Reject	Sound & Bore,MITC Fume
29657	40	CCA Type C	Non Reject	Groundline Treatment
59777	45	CCA Type C	Non Reject	
17170	35	Creosote	Non Reject	Sound & Bore,MITC Fume
60799	35	CCA Type C	Non Reject	
17173	40	Creosote	Non Reject	Sound & Bore,MITC Fume
29614	30	CCA Type C	Non Reject	Groundline Treatment
23706	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
62684	35	CCA Type C	Non Reject	
23919	35	Creosote	Non Reject	Groundline Treatment
29679	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23921	50	CCA Type C	Non Reject	Groundline Treatment
24385	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
69783	45	CCA Type C	Non Reject	
29443	40		Non Reject	
52872	35	CCA Type C	Non Reject	Groundline Treatment
26684	30	CCA Type C	Non Reject	Groundline Treatment
54854	35	CCA Type C	Non Reject	
56882	50	CCA Type C	Non Reject	
28731	45	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28733	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29416	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28764	30	CCA Type C	Non Reject	Groundline Treatment
24302	30	CCA Type C	Non Reject	Groundline Treatment
26703	35	Penta	Non Reject	Rejected
29833	35	CCA Type C	Non Reject	Groundline Treatment
10290	45	CCA Type C	Non Reject	Groundline Treatment
28556	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
57435	35	CCA Type C	Non Reject	
45879	40	Penta	Non Reject	Groundline Treatment,MITC Fume
60649	35	CCA Type C	Non Reject	
10224	50	CCA Type C	Non Reject	Groundline Treatment
24412	30	CCA Type C	Non Reject	Groundline Treatment
68086	50	CCA Type C	Non Reject	
24423	30	CCA Type C	Non Reject	Groundline Treatment
24413	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57411	50	CCA Type C	Non Reject	
27497	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45808	35	CCA Type C	Non Reject	
24239	45	CCA Type C	Non Reject	
50600	35	CCA Type C	Non Reject	Groundline Treatment
52837	35	CCA Type C	Non Reject	
70446	45	CCA Type C	Non Reject	
70441	35	CCA Type C	Non Reject	
70447	45	CCA Type C	Non Reject	
28704	35	Creosote	Non Reject	Sound & Bore,MITC Fume
24323	40	CCA Type C	Non Reject	Groundline Treatment
47726	35	CCA Type C	Non Reject	
29558	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12822	40	CCA Type C	Non Reject	Groundline Treatment
45961	40	CCA Type C	Non Reject	Groundline Treatment
48004	40	CCA Type C	Non Reject	Groundline Treatment
29585	35	Penta	Non Reject	Groundline Treatment
62759	35	CCA Type C	Non Reject	
25860	30	CCA Type C	Non Reject	Groundline Treatment
47642	35	CCA Type C	Non Reject	Groundline Treatment
69794	45	CCA Type C	Non Reject	
33937	35	CCA Type C	Non Reject	Groundline Treatment
69800	45	CCA Type C	Non Reject	
69866	50	CCA Type C	Non Reject	
17054	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28512	45	CCA Type C	Non Reject	Groundline Treatment
61411	45	CCA Type C	Non Reject	
29405	35	CCA Type C	Non Reject	Groundline Treatment
29391	35	CCA Type C	Non Reject	Groundline Treatment
45833	25	Penta	Non Restorable Reject	Groundline Treatment
69791	45	CCA Type C	Non Reject	
45826	30	CCA Type C	Non Reject	Groundline Treatment
45771	50	CCA Type C	Non Reject	Groundline Treatment
45772	50	CCA Type C	Non Reject	Groundline Treatment
47682	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70456	45	CCA Type C	Non Reject	
46245	35	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47601	30	CCA Type C	Non Reject	Groundline Treatment
29444	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45917	60	CCA Type C	Non Reject	Groundline Treatment
68033	35	CCA Type C	Non Reject	
52387	35	CCA Type C	Non Reject	
27388	35	CCA Type C	Non Reject	Groundline Treatment
30288	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46401	35	CCA Type C	Non Reject	Groundline Treatment
47646	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23959	35	CCA Type C	Non Reject	Groundline Treatment
29554	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
57501	35	CCA Type C	Non Reject	
47635	30	CCA Type C	Non Reject	Groundline Treatment
30250	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31342	30	CCA Type C	Non Reject	Groundline Treatment
68098	45	CCA Type C	Non Reject	
29562	35	Creosote	Non Reject	Groundline Treatment
34313	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28863	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28694	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29393	35	Creosote	Non Reject	Groundline Treatment
29601	35	Penta	Non Reject	Rejected
17259	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
30997	40	CCA Type C	Non Reject	Groundline Treatment
31337	30	CCA Type C	Non Reject	Groundline Treatment
24895	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58568	35	CCA Type C	Non Reject	
24204	30	CCA Type C	Non Reject	Groundline Treatment
25241	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25239	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46268	25	Penta	Non Restorable Reject	Groundline Treatment
29579	35	Penta	Non Reject	Sound & Bore,MITC Fume
29661	40	CCA Type C	Non Reject	Groundline Treatment
45962	35	CCA Type C	Non Reject	Groundline Treatment
52899	35	CCA Type C	Non Reject	
29651	40	CCA Type C	Non Reject	Groundline Treatment
17178	40	Creosote	Non Reject	Groundline Treatment
24368	40	CCA Type C	Non Reject	Groundline Treatment
53405	45	CCA Type C	Non Reject	
29568	30	Creosote	Non Reject	Rejected
45971	45	CCA Type C	Non Reject	Groundline Treatment
60656	35	CCA Type C	Non Reject	
29628	35	CCA Type C	Non Reject	Groundline Treatment
45964	35	CCA Type C	Non Reject	Groundline Treatment
64151	45	CCA Type C	Non Reject	
57727	40	CCA Type C	Non Reject	
45783	35	Creosote	Non Reject	Sound & Bore,MITC Fume
25702	35	Creosote	Non Reject	Groundline Treatment
10249	50	Creosote	Non Reject	Groundline Treatment
28550	35	Creosote	Non Reject	Groundline Treatment
58892	35	CCA Type C	Non Reject	
28699	35	Creosote	Non Reject	Groundline Treatment
25876	30		Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
60647	45	CCA Type C	Non Reject	
31335	30	CCA Type C	Non Reject	Groundline Treatment
53401	45	CCA Type C	Non Reject	
17165	35	Penta	Non Reject	Rejected
28718	35	Penta	Non Reject	Sound & Bore,MITC Fume
25729	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
23076	50	CCA Type C	Non Reject	Groundline Treatment
64073	45	CCA Type C	Non Reject	
64002	45	CCA Type C	Non Reject	
28683	30	CCA Type C	Non Reject	Groundline Treatment
47617	30	Creosote	Non Reject	Sound & Bore,MITC Fume
53137	30	CCA Type C	Non Reject	Groundline Treatment
28529	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29552	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
33066	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29550	40	CCA Type C	Non Reject	Groundline Treatment
24913	40	Creosote	Non Reject	Groundline Treatment
23926	50	Creosote	Non Reject	Groundline Treatment
48360	30	CCA Type C	Non Reject	Groundline Treatment
24439	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
24441	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
29549	40	CCA Type C	Non Reject	Groundline Treatment
68084	35	CCA Type C	Non Reject	
68093	45	CCA Type C	Non Reject	
30270	35	Creosote	Non Reject	Sound & Bore,MITC Fume
54321	45	CCA Type C	Non Reject	
29459	30	CCA Type C	Non Reject	Groundline Treatment
72141	50	CCA Type C	Non Reject	
54456	35	CCA Type C	Non Reject	
29541	30	CCA Type C	Non Reject	Groundline Treatment
47694	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47705	30		Non Reject	
17340	40	Penta	Non Reject	Groundline Treatment
36345	35	CCA Type C	Non Reject	Groundline Treatment
47673	35	Penta	Non Reject	Sound & Bore,MITC Fume
72154	50	CCA Type C	Non Reject	
46918	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60646	35	CCA Type C	Non Reject	
45656	30	Creosote	Non Reject	Sound & Bore,MITC Fume
51994	30	CCA Type C	Non Reject	Groundline Treatment
28573	30	CCA Type C	Non Reject	Groundline Treatment
28572	35	Creosote	Non Reject	Sound & Bore,MITC Fume
70167	35	CCA Type C	Non Reject	
31707	35	CCA Type C	Non Reject	Groundline Treatment
46230	35	CCA Type C	Non Reject	
29683	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
62737	35	CCA Type C	Non Reject	
29714	35	Penta	Non Reject	Groundline Treatment
48238	40	Penta	Non Reject	Rejected
46238	40	Penta	Non Reject	Sound & Bore,MITC Fume
17158	35	Penta	Non Reject	Groundline Treatment
12903	40	CCA Type C	Non Reject	Groundline Treatment
69781	45	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
69782	45	CCA Type C	Non Reject	
25006	35	Penta	Non Reject	Rejected
25002	40	CCA Type C	Non Reject	Groundline Treatment
29729	30	CCA Type C	Non Reject	Groundline Treatment
24375	35	Penta	Non Reject	Groundline Treatment
24383	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
10236	50	CCA Type C	Non Reject	Groundline Treatment
18049	50	CCA Type C	Non Reject	Groundline Treatment
61751	45	CCA Type C	Non Reject	
46911	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
17469	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29591	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17514	40	CCA Type C	Non Reject	Groundline Treatment
57217	40	CCA Type C	Non Reject	
25874	30	CCA Type C	Non Reject	Groundline Treatment
65768	35	CCA Type C	Non Reject	
61393	35	CCA Type C	Non Reject	
10347	40	Penta	Non Reject	Groundline Treatment
64033	45	CCA Type C	Non Reject	
25783	30	CCA Type C	Non Reject	Groundline Treatment
45893	30	CCA Type C	Non Reject	Groundline Treatment
45765	50	CCA Type C	Non Reject	Groundline Treatment
45079	45	CCA Type C	Non Reject	
46532	50	CCA Type C	Non Reject	Groundline Treatment
10262	40		Non Reject	
55555	50	CCA Type C	Non Reject	
64121	45	CCA Type C	Non Reject	
25867	35	CCA Type C	Non Reject	Groundline Treatment
64594	60	CCA Type C	Non Reject	
10376	40	Penta	Non Reject	Groundline Treatment
52925	50	CCA Type C	Non Reject	
10221	55	Untreated	Non Reject	
10279	40	Penta	Non Reject	Groundline Treatment
28833	35	Creosote	Non Reject	Groundline Treatment
24205	50	CCA Type C	Non Reject	
52590	35	CCA Type C	Non Reject	
54818	50	CCA Type C	Non Reject	
10387	45	CCA Type C	Non Reject	Groundline Treatment
50837	40	Penta in Petroleum	Non Reject	Groundline Treatment
29475	30	CCA Type C	Non Reject	Groundline Treatment
50849	35	CCA Type C	Non Reject	Groundline Treatment
25072	40	CCA Type C	Non Reject	Groundline Treatment
46857	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25347	35	CCA Type C	Non Reject	Groundline Treatment
54608	50	CCA Type C	Non Reject	
54594	50	CCA Type C	Non Reject	
48260	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45118	20	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29485	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45143	45	CCA Type C	Non Reject	Groundline Treatment
49478	40	CCA Type C	Non Reject	Groundline Treatment
77213	35		Non Reject	
25545	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
50916	35	CCA Type C	Non Reject	Groundline Treatment
55115	45	CCA Type C	Non Reject	Groundline Treatment
49466	40	CCA Type C	Non Reject	Groundline Treatment
25464	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25457	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47145	30		Non Reject	
10583	40	CCA Type C	Non Reject	Groundline Treatment
50912	35	Creosote	Non Reject	Groundline Treatment
72833	45	CCA Type C	Non Reject	
50842	30	Creosote	Non Reject	Sound & Bore,MITC Fume
70034	45	CCA Type C	Non Reject	
12891	40	CCA Type C	Non Reject	Groundline Treatment
18288	45	CCA Type C	Non Reject	
45139	35	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
45140	35	Creosote	Non Reject	Groundline Treatment
55970	45	CCA Type C	Non Reject	
50834	40	Penta in Petroleum	Non Reject	Groundline Treatment
75601	35		Non Reject	
60852	45	CCA Type C	Non Reject	
72386	50	CCA Type C	Non Reject	
54473	45	CCA Type C	Non Reject	
67775	45	CCA Type C	Non Reject	
34719	40	CCA Type C	Non Reject	
18696	30	CCA Type C	Non Reject	Groundline Treatment
49481	40	CCA Type C	Non Reject	Groundline Treatment
51011	40	CCA Type C	Non Reject	Groundline Treatment
18835	30	CCA Type C	Non Reject	Groundline Treatment
18793	35	CCA Type C	Non Reject	Groundline Treatment
62676	50	CCA Type C	Non Reject	Groundline Treatment
18744	45	CCA Type C	Non Reject	
58864	65	CCA Type C	Non Reject	Groundline Treatment
71805	45	CCA Type C	Non Reject	
10299	45	Creosote	Non Reject	Groundline Treatment,MITC Fume
69869	45	CCA Type C	Non Reject	
69868	45	CCA Type C	Non Reject	
52527	45		Non Reject	
45148	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45147	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25406	45	CCA Type C	Non Reject	Groundline Treatment
12675	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50891	40	CCA Type C	Non Reject	
46484	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31448	35	CCA Type C	Non Reject	Groundline Treatment
25993	35	Creosote	Non Reject	Groundline Treatment
45553	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
60676	45	CCA Type C	Non Reject	
59712	35	CCA Type C	Non Reject	
35076	40	CCA Type C	Non Reject	
20897	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
60860	45	CCA Type C	Non Reject	
46006	25	CCA Type C	Non Reject	Groundline Treatment
49846	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49850	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
50903	35	CCA Type C	Non Reject	Groundline Treatment
34338	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
26960	40	CCA Type C	Non Reject	Groundline Treatment
27071	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
20822	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59813	45	CCA Type C	Non Reject	
12721	30	CCA Type C	Non Reject	Groundline Treatment
46382	35	CCA Type C	Non Reject	Groundline Treatment
69734	45	CCA Type C	Non Reject	
12401	45	CCA Type C	Non Reject	Groundline Treatment
46090	35	CCA Type C	Non Reject	
21104	35	CCA Type C	Non Reject	Groundline Treatment
12390	45	CCA Type C	Non Reject	Groundline Treatment
20952	35	CCA Type C	Non Reject	
31048	40		Non Reject	
29897	40	Creosote	Non Reject	Groundline Treatment
48594	30	CCA Type C	Non Reject	Groundline Treatment
79522	45	CCA Type C	Non Reject	
64793	45	CCA Type C	Non Reject	
66977	45	CCA Type C	Non Reject	
23177	50	CCA Type C	Non Reject	Groundline Treatment
48539	40	Penta	Non Reject	Groundline Treatment
46028	30	CCA Type C	Non Reject	Groundline Treatment
12488	40	CCA Type C	Non Reject	Groundline Treatment
12637	50	CCA Type C	Non Reject	
12687	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50487	35	CCA Type C	Non Reject	
68133	45	CCA Type C	Non Reject	
26274	30		Non Reject	
55417	60	CCA Type C	Non Reject	
49857	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
45488	40	Penta	Non Reject	Groundline Treatment
46507	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20576	40	CCA Type C	Non Reject	Groundline Treatment
49150	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
16955	40	CCA Type C	Non Reject	Groundline Treatment
45467	35	CCA Type C	Non Reject	Groundline Treatment
48045	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
31464	40	CCA Type C	Non Reject	Groundline Treatment
70180	35	CCA Type C	Non Reject	Groundline Treatment
29863	45	CCA Type C	Non Reject	Groundline Treatment
20889	30	CCA Type C	Non Reject	Groundline Treatment
20891	30	CCA Type C	Non Reject	Groundline Treatment
20872	50	CCA Type C	Non Reject	
29881	30	CCA Type C	Non Reject	Groundline Treatment
33705	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45535	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45534	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57125	50	CCA Type C	Non Reject	
52595	35	CCA Type C	Non Reject	
21035	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21033	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59705	60	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
59743	60	CCA Type C	Non Reject	
20977	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20978	30	Penta	Non Reject	Groundline Treatment
12440	45	CCA Type C	Non Reject	Groundline Treatment
46021	35	CCA Type C	Non Reject	Groundline Treatment
49154	40	CCA Type C	Non Reject	Groundline Treatment
62846	35		Non Reject	
57424	50	Untreated	Non Reject	
60968	45	CCA Type C	Non Reject	
70228	45	CCA Type C	Non Reject	
12927	30	CCA Type C	Non Reject	Groundline Treatment
49995	40	CCA Type C	Non Reject	Groundline Treatment
32301	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51226	40	Creosote	Non Reject	Groundline Treatment
12950	40	Penta	Non Restorable Reject	Groundline Treatment
70505	35	CCA Type C	Non Reject	
51252	35	CCA Type C	Non Reject	
51254	45	CCA Type C	Non Reject	Groundline Treatment
51255	40	CCA Type C	Non Restorable Reject	Groundline Treatment
51258	30	CCA Type C	Non Reject	Groundline Treatment
61335	45	CCA Type C	Non Reject	
55833	45	CCA Type C	Non Reject	
47268	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48384	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48382	40	CCA Type C	Non Reject	Groundline Treatment
61336	45	CCA Type C	Non Reject	
61338	45	CCA Type C	Non Reject	
58482	35	CCA Type C	Non Reject	
12567	35	CCA Type C	Non Reject	Groundline Treatment
79429	45	CCA Type C	Non Reject	
64787	45	CCA Type C	Non Reject	
48381	40	CCA Type C	Non Reject	Groundline Treatment
55882	45	CCA Type C	Non Reject	Groundline Treatment
21148	40	CCA Type C	Non Reject	Groundline Treatment
25986	30	Creosote	Non Reject	Groundline Treatment
45470	45	CCA Type C	Non Reject	Groundline Treatment
20590	40	CCA Type C	Non Reject	Groundline Treatment
53985	35	CCA Type C	Non Reject	
49823	50	CCA Type C	Non Reject	
67593	35	CCA Type C	Non Reject	
55421	50	CCA Type C	Non Reject	
45498	35	CCA Type C	Non Reject	
45501	45	CCA Type C	Non Reject	Groundline Treatment
56838	50	CCA Type C	Non Reject	
55977	45	CCA Type C	Non Reject	
46675	50	CCA Type C	Non Reject	
45491	25	CCA Type C	Non Reject	Groundline Treatment
58812	50	CCA Type C	Non Reject	
53194	35	CCA Type C	Non Reject	
31456	40	Creosote	Non Restorable Reject	Groundline Treatment
12416	45	CCA Type C	Non Reject	Groundline Treatment
60036	45	CCA Type C	Non Reject	
27156	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47480	45	CCA Type C	Non Reject	Groundline Treatment
58469	35	CCA Type C	Non Reject	
28475	50	CCA Type C	Non Reject	Groundline Treatment
52887	35	CCA Type C	Non Reject	
20518	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49116	40	CCA Type C	Non Reject	Groundline Treatment
24712	40	CCA Type C	Non Reject	Groundline Treatment
30152	30	CCA Type C	Non Reject	Groundline Treatment
27081	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
62682	45	CCA Type C	Non Reject	
52912	50	CCA Type C	Non Reject	
20745	45	CCA Type C	Non Reject	Groundline Treatment
60667	45	CCA Type C	Non Reject	
12373	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51311	35	CCA Type C	Non Reject	Groundline Treatment
12649	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29886	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
60037	50	CCA Type C	Non Reject	
12512	35	CCA Type C	Non Reject	Groundline Treatment
12272	45	CCA Type C	Non Reject	Groundline Treatment
12269	55	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54343	45		Non Reject	
31459	40	CCA Type C	Non Reject	Groundline Treatment
45472	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12332	45	CCA Type C	Non Reject	Groundline Treatment
45102	20	CCA Type C	Non Reject	Groundline Treatment
45113	20	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
45487	45	Penta	Non Reject	Groundline Treatment
12442	45	CCA Type C	Non Reject	Groundline Treatment
24525	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59714	35	CCA Type C	Non Reject	
59814	45	CCA Type C	Non Reject	
46362	45	CCA Type C	Non Reject	Groundline Treatment
62616	35	CCA Type C	Non Reject	
46050	30	CCA Type C	Non Reject	Groundline Treatment
30095	50	CCA Type C	Non Reject	
47220	30	CCA Type C	Non Reject	Groundline Treatment
52907	45	CCA Type C	Non Reject	
12392	45	CCA Type C	Non Reject	Groundline Treatment
30159	45		Non Reject	
68135	45	CCA Type C	Non Reject	
54598	55	CCA Type C	Non Reject	
12645	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12643	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12644	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
61391	35	CCA Type C	Non Reject	
12689	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51302	40	CCA Type C	Non Reject	Groundline Treatment
61377	35	CCA Type C	Non Reject	
30521	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57205	45	CCA Type C	Non Reject	
48984	50	CCA Type C	Non Reject	Groundline Treatment
69901	35	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
57730	35	CCA Type C	Non Reject	
49816	50	CCA Type C	Non Reject	
45471	35	Penta	Non Reject	Groundline Treatment
23816	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20782	30	CCA Type C	Non Reject	Groundline Treatment
61394	50	CCA Type C	Non Reject	
21124	35	CCA Type C	Non Reject	Groundline Treatment
58706	60	CCA Type C	Non Reject	
48937	35	CCA Type C	Non Reject	
27082	45	CCA Type C	Non Reject	Groundline Treatment
33172	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31103	40	CCA Type C	Non Reject	Groundline Treatment
53197	50	CCA Type C	Non Reject	
12413	45	CCA Type C	Non Reject	Groundline Treatment
12374	50	CCA Type C	Non Reject	Groundline Treatment
49838	35	CCA Type C	Non Reject	Groundline Treatment
46481	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28677	40	CCA Type C	Non Reject	Groundline Treatment
12243	30	Creosote	Non Reject	Sound & Bore,MITC Fume
50032	50		Non Reject	
12298	30	CCA Type C	Non Reject	Sound & Bore
54223	45	CCA Type C	Non Reject	
55415	60	CCA Type C	Non Reject	
55416	60	CCA Type C	Non Reject	Groundline Treatment
12242	30	Creosote	Non Reject	Sound & Bore,MITC Fume
49181	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49710	35	CCA Type C	Non Reject	Groundline Treatment
60554	35	CCA Type C	Non Reject	
23149	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55776	35	CCA Type C	Non Reject	
59742	60	CCA Type C	Non Reject	
49115	30	CCA Type C	Non Reject	Groundline Treatment
18649	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20769	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25977	35	CCA Type C	Non Reject	Groundline Treatment
25976	30	CCA Type C	Non Reject	Groundline Treatment
12669	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
49114	30	CCA Type C	Non Reject	Groundline Treatment
12279	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54468	45	CCA Type C	Non Reject	
50160	35	CCA Type C	Non Reject	
32733	45	CCA Type C	Non Reject	
49786	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45445	35	Penta	Non Reject	Groundline Treatment,MITC Fume
46387	35	Penta	Non Reject	Groundline Treatment
61386	35	CCA Type C	Non Reject	
12380	40	CCA Type C	Non Reject	Groundline Treatment
12207	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55079	35	CCA Type C	Non Reject	
30127	35	CCA Type C	Non Reject	Groundline Treatment
67708	35	CCA Type C	Non Reject	
60674	50	CCA Type C	Non Reject	
48979	50	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
20826	40	CCA Type C	Non Reject	Groundline Treatment
18822	40	CCA Type C	Non Reject	
30107	40	CCA Type C	Non Reject	Groundline Treatment
54393	45	CCA Type C	Non Reject	
79415	45	CCA Type C	Non Reject	
48388	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20579	40	CCA Type C	Non Reject	Groundline Treatment
20794	35	CCA Type C	Non Reject	Groundline Treatment
12536	40	CCA Type C	Non Reject	Groundline Treatment
51154	50	CCA Type C	Non Reject	
58419	35	CCA Type C	Non Reject	
26281	40	CCA Type C	Non Reject	Groundline Treatment
26457	30	CCA Type C	Non Reject	Groundline Treatment
52459	40	CCA Type C	Non Reject	Groundline Treatment
20669	35	CCA Type C	Non Reject	Groundline Treatment
61366	35	CCA Type C	Non Reject	
23085	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25742	30	CCA Type C	Non Reject	Groundline Treatment
67798	50	CCA Type C	Non Reject	
30478	35	Creosote	Non Reject	Groundline Treatment
58207	50	CCA Type C	Non Reject	
12940	40	CCA Type C	Non Reject	Groundline Treatment
50200	35		Non Reject	
64470	35	CCA Type C	Non Reject	
12474	35	CCA Type C	Non Reject	Groundline Treatment
46499	35	CCA Type C	Non Reject	Groundline Treatment
27074	35	Penta	Non Reject	Groundline Treatment
47201	30	CCA Type C	Non Reject	Groundline Treatment
21381	45	CCA Type C	Non Reject	Groundline Treatment
49831	40	CCA Type C	Non Reject	Groundline Treatment
30085	45	CCA Type C	Non Reject	Groundline Treatment
25736	35	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
56772	25	Penta	Non Restorable Reject	Groundline Treatment
50006	50	CCA Type C	Non Reject	
45541	35	Penta	Non Reject	Sound & Bore,MITC Fume
61788	35	CCA Type C	Non Reject	
45515	50	CCA Type C	Non Reject	
12494	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49860	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51026	40	CCA Type C	Non Reject	
25090	40	CCA Type C	Non Reject	Groundline Treatment
30040	35	Penta	Non Reject	Rejected
59807	45	CCA Type C	Non Reject	
31101	50	CCA Type C	Non Reject	Groundline Treatment
26282	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
59811	45	CCA Type C	Non Reject	
30113	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
30083	50	CCA Type C	Non Reject	Groundline Treatment
53113	35	CCA Type C	Non Reject	
50783	30	CCA Type C	Non Reject	Groundline Treatment
21389	50	CCA Type C	Non Reject	Groundline Treatment
49125	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34153	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
20574	40	Penta	Non Restorable Reject	Groundline Treatment
70278	45	CCA Type C	Non Reject	
70277	35	CCA Type C	Non Reject	
49627	30	CCA Type C	Non Reject	Groundline Treatment
61379	35	CCA Type C	Non Reject	
34324	35	CCA Type C	Non Reject	Groundline Treatment
70571	45	CCA Type C	Non Reject	
30450	30	CCA Type C	Non Reject	Groundline Treatment
61544	35	CCA Type C	Non Reject	
49742	30	CCA Type C	Non Reject	Groundline Treatment
77267	35	CCA Type C	Non Reject	
25998	30	CCA Type C	Non Reject	Groundline Treatment
72840	45	CCA Type C	Non Reject	
13255	40	CCA Type C	Non Reject	Groundline Treatment
49824	50	CCA Type C	Non Reject	
57429	35	CCA Type C	Non Reject	
26013	45	CCA Type C	Non Reject	Groundline Treatment
48391	30	CCA Type C	Non Reject	Groundline Treatment
25988	30	CCA Type C	Non Reject	Groundline Treatment
12376	30	CCA Type C	Non Reject	Groundline Treatment
29457	35	CCA Type C	Non Reject	
29447	30	CCA Type C	Non Reject	Groundline Treatment
29469	40	CCA Type C	Non Reject	
49630	35	Penta	Non Reject	Groundline Treatment
52894	50	CCA Type C	Non Reject	
31463	40	CCA Type C	Non Reject	Groundline Treatment
20724	40	CCA Type C	Non Reject	Groundline Treatment
23185	30	CCA Type C	Non Reject	Groundline Treatment
57138	50	CCA Type C	Non Reject	
62604	35	CCA Type C	Non Reject	
79440	35	CCA Type C	Non Reject	
58816	50	CCA Type C	Non Reject	
49120	30	CCA Type C	Non Reject	Groundline Treatment
18654	50	CCA Type C	Non Reject	Groundline Treatment
48550	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31109	40	CCA Type C	Non Reject	Groundline Treatment
50782	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24877	50	CCA Type C	Non Reject	Groundline Treatment
61789	35	CCA Type C	Non Reject	
48405	30	CCA Type C	Non Reject	Groundline Treatment
24876	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25473	40	Penta	Non Reject	Groundline Treatment
79411	45	CCA Type C	Non Reject	
72203	50	CCA Type C	Non Reject	
47204	30	CCA Type C	Non Reject	Groundline Treatment
46505	50		Non Reject	
49828	40	Penta	Non Restorable Reject	Groundline Treatment
12195	50	Creosote	Non Reject	Groundline Treatment,MITC Fume
20542	35	CCA Type C	Non Reject	Groundline Treatment
57663	45	CCA Type C	Non Reject	
54575	50	CCA Type C	Non Reject	
54576	50	CCA Type C	Non Reject	
69996	55	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
72259	50	CCA Type C	Non Reject	
12638	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
49151	45	CCA Type C	Non Reject	
49086	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20547	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
65794	50	CCA Type C	Non Reject	
30087	30	CCA Type C	Non Reject	Groundline Treatment
30092	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
30089	45	CCA Type C	Non Reject	Groundline Treatment
46510	40	CCA Type C	Non Reject	Groundline Treatment
45528	50	CCA Type C	Non Reject	
29461	30		Non Reject	
49171	30	CCA Type C	Non Reject	Groundline Treatment
55037	35	CCA Type C	Non Reject	
49142	30	CCA Type C	Non Reject	Groundline Treatment
49733	30	CCA Type C	Non Reject	Groundline Treatment
54409	45	CCA Type C	Non Reject	
20824	30	CCA Type C	Non Reject	Groundline Treatment
45484	50	CCA Type C	Non Reject	Groundline Treatment
35024	50	CCA Type C	Non Reject	
67761	35	CCA Type C	Non Reject	
49836	35	Penta	Non Restorable Reject	Groundline Treatment
23063	45	Creosote	Non Reject	Groundline Treatment
49221	40	CCA Type C	Non Reject	Groundline Treatment
24255	30	CCA Type C	Non Reject	Groundline Treatment
61317	45	CCA Type C	Non Reject	
64416	50	CCA Type C	Non Reject	
36072	45	CCA Type C	Non Reject	
46602	50	CCA Type C	Non Reject	Groundline Treatment
69563	35	CCA Type C	Non Reject	
50819	40	CCA Type C	Non Reject	Groundline Treatment
46610	50	CCA Type C	Non Reject	
18474	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49484	35	CCA Type C	Non Reject	Groundline Treatment
70000	50	CCA Type C	Non Reject	
64586	50	CCA Type C	Non Reject	
12991	35	Creosote	Non Reject	Groundline Treatment
45861	50	CCA Type C	Non Reject	Groundline Treatment
45849	35	Creosote	Non Reject	Groundline Treatment
45775	50	CCA Type C	Non Reject	Groundline Treatment
26670	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60053	45	CCA Type C	Non Reject	
18382	50	CCA Type C	Non Reject	Groundline Treatment
45819	30	CCA Type C	Non Reject	Groundline Treatment
64406	50	CCA Type C	Non Reject	
54537	50	CCA Type C	Non Reject	
49513	35	CCA Type C	Non Reject	Groundline Treatment
49256	40	CCA Type C	Non Reject	
18992	45	CCA Type C	Non Reject	
56867	50	CCA Type C	Non Reject	
31686	40	CCA Type C	Non Reject	Groundline Treatment
19035	45	Penta	Restorable Reject	Groundline Treatment
45602	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18721	35	Penta	Non Restorable Reject	Groundline Treatment
13230	40	CCA Type C	Non Reject	Groundline Treatment
76729	45	CCA Type C	Non Reject	
76662	45	CCA Type C	Non Reject	
18529	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57632	45	CCA Type C	Non Reject	
23067	50	CCA Type C	Non Reject	Groundline Treatment
57631	45	CCA Type C	Non Reject	
65695	35	CCA Type C	Non Reject	
10234	50	CCA Type C	Non Reject	Groundline Treatment
36358	35	CCA Type C	Non Reject	
10235	50	CCA Type C	Non Reject	Groundline Treatment
19122	35	CCA Type C	Non Reject	Groundline Treatment
59829	45	CCA Type C	Non Reject	
45288	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54682	35	CCA Type C	Non Reject	
23588	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
69789	45	CCA Type C	Non Reject	
49238	40	CCA Type C	Non Reject	Groundline Treatment
52918	45	CCA Type C	Non Reject	
22582	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24713	35	CCA Type C	Non Reject	Groundline Treatment
23420	45	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
45740	35		Non Reject	
36070	45	CCA Type C	Non Reject	
19140	40	CCA Type C	Non Reject	Groundline Treatment
49284	40	CCA Type C	Non Reject	Groundline Treatment
23594	35	Creosote	Non Reject	Sound & Bore,MITC Fume
49296	40	CCA Type C	Non Reject	Groundline Treatment
61319	45	CCA Type C	Non Reject	
55844	45	CCA Type C	Non Reject	Groundline Treatment
24286	35	Creosote	Non Restorable Reject	Groundline Treatment
56848	45	CCA Type C	Non Reject	
45788	35	CCA Type C	Non Reject	Groundline Treatment
48248	50	Untreated	Non Reject	
23997	30	CCA Type C	Non Reject	Groundline Treatment
60770	35	CCA Type C	Non Reject	
52594	45	CCA Type C	Non Reject	
18539	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45835	30	CCA Type C	Non Reject	Groundline Treatment
72721	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
33029	30	CCA Type C	Non Reject	Groundline Treatment
19020	40	CCA Type C	Non Reject	Groundline Treatment
50816	30	CCA Type C	Non Reject	Groundline Treatment
64585	45	CCA Type C	Non Reject	
69907	35	CCA Type C	Non Reject	Groundline Treatment
31476	35	CCA Type C	Non Reject	Groundline Treatment
18059	30	CCA Type C	Non Reject	Groundline Treatment
69797	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46713	40	CCA Type C	Non Reject	
18983	25	Penta	Non Restorable Reject	
53990	45	CCA Type C	Non Reject	
49490	40	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
19125	35	CCA Type C	Non Reject	Groundline Treatment
64420	50	CCA Type C	Non Reject	
52530	45	CCA Type C	Non Reject	
49430	40	CCA Type C	Non Reject	Groundline Treatment
75694	45	CCA Type C	Non Reject	
49209	35	CCA Type C	Non Reject	Groundline Treatment
61310	45	CCA Type C	Non Reject	
49212	35	CCA Type C	Non Reject	Groundline Treatment
64451	60	CCA Type C	Non Reject	
49240	25	Creosote	Non Restorable Reject	Rejected
50153	45	CCA Type C	Non Reject	
49424	40	CCA Type C	Non Reject	
64422	45	CCA Type C	Non Reject	
49275	40	Penta	Non Reject	Groundline Treatment
49274	40	CCA Type C	Non Reject	Groundline Treatment
18431	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
69902	45	CCA Type C	Non Reject	
49219	30	CCA Type C	Non Reject	Groundline Treatment
23615	40	CCA Type C	Non Reject	Groundline Treatment
52827	35	CCA Type C	Non Reject	
70513	45	CCA Type C	Non Reject	
46637	45	CCA Type C	Non Reject	Groundline Treatment
34314	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49217	35	CCA Type C	Non Reject	Groundline Treatment
60004	35	CCA Type C	Non Reject	
18962	45	CCA Type C	Non Reject	
19005	35	CCA Type C	Non Reject	Groundline Treatment
18974	40	CCA Type C	Non Reject	Groundline Treatment
23419	40	CCA Type C	Non Reject	Groundline Treatment
49244	45	CCA Type C	Non Reject	
54542	35	CCA Type C	Non Reject	
25338	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
48354	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
79439	35	CCA Type C	Non Reject	
72648	50	CCA Type C	Non Reject	
76463	50	CCA Type C	Non Reject	
14463	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49501	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49499	40	CCA Type C	Non Reject	Groundline Treatment
49452	35	CCA Type C	Non Reject	Groundline Treatment
18473	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
27309	40	CCA Type C	Non Reject	Groundline Treatment
49205	45	CCA Type C	Non Reject	Groundline Treatment
22489	45	CCA Type C	Non Reject	Groundline Treatment
18979	45	CCA Type C	Non Reject	
50808	25	Creosote	Non Reject	Groundline Treatment
50821	45	CCA Type C	Non Reject	Groundline Treatment
69906	45	CCA Type C	Non Reject	
69908	45	CCA Type C	Non Reject	
69909	45	CCA Type C	Non Reject	
69911	45	CCA Type C	Non Reject	
49425	40	CCA Type C	Non Reject	
18392	35	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
60919	45	CCA Type C	Non Reject	
60918	45	CCA Type C	Non Reject	
28736	45	CCA Type C	Non Reject	Groundline Treatment
28739	35	Creosote	Non Reject	Groundline Treatment
28741	35	Penta	Non Restorable Reject	Groundline Treatment
57417	50	CCA Type C	Non Reject	
64753	35	CCA Type C	Non Reject	
46526	35	CCA Type C	Non Reject	Groundline Treatment
64035	45	CCA Type C	Non Reject	
45134	25	CCA Type C	Non Reject	Groundline Treatment
25805	35	Creosote	Non Reject	Sound & Bore,MITC Fume
45097	25	CCA Type C	Non Reject	Groundline Treatment
52580	35	CCA Type C	Non Reject	
58631	35	CCA Type C	Non Reject	Groundline Treatment
48275	30	CCA Type C	Non Reject	Groundline Treatment
25405	45	CCA Type C	Non Reject	Groundline Treatment
23981	35	CCA Type C	Non Reject	
70448	45	CCA Type C	Non Reject	
52535	50	CCA Type C	Non Reject	Groundline Treatment
24304	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
22350	45	CCA Type C	Non Reject	Groundline Treatment
56865	45	CCA Type C	Non Reject	
68130	35	CCA Type C	Non Reject	
64053	60	CCA Type C	Non Reject	
45967	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24928	30	CCA Type C	Non Reject	Groundline Treatment
60660	35	CCA Type C	Non Reject	
29625	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
27407	50	CCA Type C	Non Reject	Groundline Treatment
17244	45	CCA Type C	Non Reject	Groundline Treatment
28521	30	CCA Type C	Non Reject	Groundline Treatment
62645	35	CCA Type C	Non Reject	
57214	35	CCA Type C	Non Reject	
45054	50	CCA Type C	Non Reject	Groundline Treatment
24384	50	CCA Type C	Non Reject	Groundline Treatment
61747	45	CCA Type C	Non Reject	Groundline Treatment
24417	30	CCA Type C	Non Reject	Groundline Treatment
46930	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72877	45	CCA Type C	Non Reject	
12841	40	CCA Type C	Non Reject	Groundline Treatment
54421	35	CCA Type C	Non Reject	
22332	30	Penta	Non Reject	Rejected
45944	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46416	30	CCA Type C	Non Reject	Groundline Treatment
32847	30	CCA Type C	Non Reject	Groundline Treatment
45155	35		Non Reject	
28749	40	CCA Type C	Non Reject	Groundline Treatment
28751	35	Penta	Non Restorable Reject	Groundline Treatment
55521	35	CCA Type C	Non Reject	
70268	35	CCA Type C	Non Reject	
45941	35	CCA Type C	Non Reject	Groundline Treatment
47725	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47688	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47687	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45800	30	CCA Type C	Non Reject	Groundline Treatment
24291	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17198	50	CCA Type C	Non Reject	Groundline Treatment
23039	50	CCA Type C	Non Reject	Groundline Treatment
45884	35	CCA Type C	Non Reject	
28778	50	CCA Type C	Non Reject	Groundline Treatment
23079	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58567	35	CCA Type C	Non Reject	
24207	45	CCA Type C	Non Reject	
24299	40	CCA Type C	Non Reject	Groundline Treatment
29397	30	CCA Type C	Non Reject	Groundline Treatment
24213	35	CCA Type C	Non Reject	
46913	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45914	35	CCA Type C	Non Reject	
45076	35	CCA Type C	Non Reject	
28554	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64149	45	CCA Type C	Non Reject	
52380	45	CCA Type C	Non Reject	
29473	40	CCA Type C	Non Reject	Groundline Treatment
58948	35	CCA Type C	Non Reject	Groundline Treatment
45838	30		Non Reject	
53139	35	CCA Type C	Non Reject	Groundline Treatment
25830	45	CCA Type C	Non Reject	Groundline Treatment
10395	45	CCA Type C	Non Reject	Groundline Treatment
22326	30	CCA Type C	Non Reject	Groundline Treatment
47681	30	CCA Type C	Non Reject	Groundline Treatment
70160	35	CCA Type C	Non Reject	
10258	55	CCA Type C	Non Reject	Groundline Treatment
45084	50	CCA Type C	Non Reject	Groundline Treatment
29610	35	Penta	Non Reject	Sound & Bore,MITC Fume
29599	35	Penta	Non Reject	Sound & Bore,MITC Fume
29605	35	Penta	Non Reject	Groundline Treatment
68101	35	CCA Type C	Non Reject	
46229	35	CCA Type C	Non Reject	Groundline Treatment
64784	35	CCA Type C	Non Reject	
68082	35	CCA Type C	Non Reject	
23103	35	CCA Type C	Non Reject	Groundline Treatment
29664	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
46247	30	CCA Type C	Non Reject	Groundline Treatment
23906	50	CCA Type C	Non Reject	Groundline Treatment
45982	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27408	40	Penta	Non Reject	Groundline Treatment
45916	40	CCA Type C	Non Reject	Groundline Treatment
22293	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24339	30	Creosote	Non Reject	Groundline Treatment
27732	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29632	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25872	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
33933	35	CCA Type C	Non Reject	Groundline Treatment
45126	25	Creosote	Non Reject	Groundline Treatment
28743	30	CCA Type C	Non Reject	Groundline Treatment
77288	35	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
77290	50	CCA Type C	Non Reject	
28710	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
62611	45	CCA Type C	Non Reject	
10311	40	CCA Type C	Non Reject	Groundline Treatment
46220	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
23105	45	CCA Type C	Non Reject	Groundline Treatment
34639	45	CCA Type C	Non Reject	Groundline Treatment
29490	30	CCA Type C	Non Reject	Groundline Treatment
22348	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47622	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25764	35	CCA Type C	Non Reject	Groundline Treatment
25765	40	CCA Type C	Non Reject	Groundline Treatment
57043	45	CCA Type C	Non Reject	
45081	35	CCA Type C	Non Reject	
70464	35	CCA Type C	Non Reject	
45978	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
45986	35	Creosote	Non Reject	Groundline Treatment
29644	30	CCA Type C	Non Reject	Groundline Treatment
45952	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
32835	30	CCA Type C	Non Reject	Groundline Treatment
17150	35	Penta	Non Reject	Groundline Treatment
23818	35	Penta	Non Reject	Sound & Bore,MITC Fume
29440	30		Non Reject	
36068	35	CCA Type C	Non Reject	
45809	50	CCA Type C	Non Reject	Groundline Treatment
24991	30	Creosote	Non Reject	Groundline Treatment
46552	50	CCA Type C	Non Reject	Groundline Treatment
29470	45	CCA Type C	Non Reject	
25719	30	CCA Type C	Non Reject	Groundline Treatment
30280	35	Creosote	Non Reject	Groundline Treatment
28791	45	CCA Type C	Non Reject	
23996	35	CCA Type C	Non Reject	Groundline Treatment
12862	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23879	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
68148	35	CCA Type C	Non Reject	
70293	45	CCA Type C	Non Reject	
23848	40	CCA Type C	Non Reject	Groundline Treatment
31678	40	CCA Type C	Non Reject	Groundline Treatment
62693	35	CCA Type C	Non Reject	Groundline Treatment
24187	45	CCA Type C	Non Reject	
45881	45	CCA Type C	Non Reject	
46924	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
68151	35	CCA Type C	Non Reject	
45092	50	CCA Type C	Non Reject	
58329	40	CCA Type C	Non Reject	
12832	35	Penta	Non Reject	Groundline Treatment
12833	40	CCA Type C	Non Reject	Groundline Treatment
12902	40	CCA Type C	Non Reject	Groundline Treatment
17269	35	CCA Type C	Non Reject	Groundline Treatment
25458	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29418	40	Penta	Non Reject	Groundline Treatment
46794	45	CCA Type C	Non Reject	
24332	50	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
57611	35	CCA Type C	Non Reject	
28567	45	CCA Type C	Non Reject	Groundline Treatment
45106	25	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
28823	50	CCA Type C	Non Reject	Groundline Treatment
28818	35	Creosote	Non Reject	Groundline Treatment
17060	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23920	25	Penta	Non Restorable Reject	Groundline Treatment
23930	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
10223	50	CCA Type C	Non Reject	
57407	50	CCA Type C	Non Reject	
28705	40	Creosote	Non Reject	Sound & Bore,MITC Fume
29497	30	CCA Type C	Non Reject	Groundline Treatment
22340	30	CCA Type C	Non Reject	Groundline Treatment
10276	50	CCA Type C	Non Reject	Groundline Treatment
52880	35	CCA Type C	Non Reject	
28540	40	Creosote	Non Reject	Groundline Treatment
24240	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50599	35	CCA Type C	Non Reject	
70454	45	CCA Type C	Non Reject	
52392	45	CCA Type C	Non Reject	
25858	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
25849	40	CCA Type C	Non Reject	Groundline Treatment
28532	40	CCA Type C	Non Reject	Groundline Treatment
68149	35	CCA Type C	Non Reject	
60768	35	CCA Type C	Non Reject	
45075	35	CCA Type C	Non Reject	Groundline Treatment
28702	50	CCA Type C	Non Reject	Groundline Treatment
28767	40	CCA Type C	Non Reject	Groundline Treatment
64017	45	CCA Type C	Non Reject	
17154	30	CCA Type C	Non Reject	Groundline Treatment
29575	40	Creosote	Non Reject	Groundline Treatment
25786	45	CCA Type C	Non Reject	Groundline Treatment
12878	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48002	45	CCA Type C	Non Reject	Groundline Treatment
47700	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54055	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47664	60	Penta	Non Reject	Groundline Treatment
30993	30	CCA Type C	Non Reject	Groundline Treatment
55557	50	CCA Type C	Non Reject	
25887	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47661	50	CCA Type C	Non Reject	Groundline Treatment
72135	50	CCA Type C	Non Reject	
34306	40	CCA Type C	Non Reject	
10226	50	CCA Type C	Non Reject	Groundline Treatment
24217	45	CCA Type C	Non Reject	
70466	35	CCA Type C	Non Reject	
10380	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28565	40	Penta	Non Reject	Sound & Bore,MITC Fume
57452	35	CCA Type C	Non Reject	
12848	35	Creosote	Non Reject	Sound & Bore,MITC Fume
46795	45	CCA Type C	Non Reject	
54059	30	Creosote	Non Reject	Sound & Bore,MITC Fume
68090	35	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28571	30	CCA Type C	Non Reject	Groundline Treatment
28708	35	Penta	Non Reject	Groundline Treatment,MITC Fume
24305	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27490	40	CCA Type C	Non Reject	Groundline Treatment
68097	35	CCA Type C	Non Reject	
53846	45	CCA Type C	Non Reject	
46537	50	CCA Type C	Non Reject	Groundline Treatment
70453	45	CCA Type C	Non Reject	
47686	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29569	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24310	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
28759	30	CCA Type C	Non Reject	Groundline Treatment
28805	30	CCA Type C	Non Reject	Groundline Treatment
28804	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29720	45	CCA Type C	Non Reject	Groundline Treatment
24994	45	CCA Type C	Non Reject	Groundline Treatment
24993	40	CCA Type C	Non Reject	Groundline Treatment
70032	35	CCA Type C	Non Reject	
24950	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52838	35	CCA Type C	Non Reject	
46270	30	CCA Type C	Non Reject	Groundline Treatment
17174	45	CCA Type C	Non Reject	Groundline Treatment
56822	35	CCA Type C	Non Reject	
64843	35	CCA Type C	Non Reject	
12829	40	CCA Type C	Non Reject	Groundline Treatment
12830	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24924	40	Penta	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
45970	45	CCA Type C	Non Reject	Groundline Treatment
29629	30	CCA Type C	Non Reject	Groundline Treatment
34042	30	CCA Type C	Non Reject	
25735	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
29618	35	Penta	Non Reject	Groundline Treatment
23887	40	CCA Type C	Non Reject	Groundline Treatment
23888	40	CCA Type C	Non Reject	Groundline Treatment
23890	35	CCA Type C	Non Reject	
28789	35	Creosote	Non Reject	Groundline Treatment
28787	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25701	35	Penta	Non Reject	Groundline Treatment
25875	35	CCA Type C	Non Reject	Groundline Treatment
36283	50	CCA Type C	Non Reject	
67699	35	CCA Type C	Non Reject	
46550	50	CCA Type C	Non Reject	Groundline Treatment
25839	35	CCA Type C	Non Reject	Groundline Treatment
25831	35	Penta	Non Reject	Groundline Treatment,MITC Fume
29480	30	CCA Type C	Non Reject	Groundline Treatment
28548	35	Penta	Non Reject	Groundline Treatment
28716	30	CCA Type C	Non Reject	Groundline Treatment
64051	50	CCA Type C	Non Reject	
45921	60	CCA Type C	Non Reject	Groundline Treatment
53164	50	CCA Type C	Non Reject	Groundline Treatment
32249	30	CCA Type C	Non Reject	
24959	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
31727	35		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
25665	35	CCA Type C	Non Reject	Groundline Treatment
54459	35	CCA Type C	Non Reject	
17339	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
53915	35	CCA Type C	Non Reject	
47739	30		Non Reject	
36343	45	CCA Type C	Non Reject	
29425	30	CCA Type C	Non Reject	Groundline Treatment
55913	35	CCA Type C	Non Reject	
27409	40	Penta	Non Reject	Groundline Treatment
17253	35	Penta	Non Reject	Groundline Treatment,MITC Fume
25003	40	CCA Type C	Non Reject	Groundline Treatment
24372	50	CCA Type C	Non Reject	Groundline Treatment
70271	35	CCA Type C	Non Reject	
25465	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52879	45	CCA Type C	Non Reject	
29626	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17515	40	CCA Type C	Non Reject	Groundline Treatment
24318	35	Creosote	Non Reject	Groundline Treatment
46529	50	CCA Type C	Non Reject	Groundline Treatment
46417	50	CCA Type C	Non Reject	Groundline Treatment
47689	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29493	30	CCA Type C	Non Reject	Groundline Treatment
27731	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55827	35	CCA Type C	Non Reject	
10354	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
62657	45	CCA Type C	Non Reject	
72639	40	CCA Type C	Non Reject	Groundline Treatment
17012	35	Penta	Non Reject	Groundline Treatment
23086	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10220	35	Untreated	Non Reject	
46452	40	CCA Type C	Non Reject	Groundline Treatment
56213	35	CCA Type C	Non Reject	
24206	50	CCA Type C	Non Reject	
12412	45	CCA Type C	Non Reject	Groundline Treatment
12410	45	CCA Type C	Non Reject	Groundline Treatment
62743	50	CCA Type C	Non Reject	
64181	45	CCA Type C	Non Reject	
12414	50	CCA Type C	Non Reject	Groundline Treatment
61376	60	CCA Type C	Non Reject	
24832	35	CCA Type C	Non Reject	Groundline Treatment
48376	30	CCA Type C	Non Reject	Groundline Treatment
20900	35	CCA Type C	Non Reject	Groundline Treatment
46005	25	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12419	45	CCA Type C	Non Reject	Groundline Treatment
49851	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21145	40	CCA Type C	Non Reject	Groundline Treatment
46048	50	CCA Type C	Non Reject	
30122	50	CCA Type C	Non Reject	
49812	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48976	50	CCA Type C	Non Reject	
45798	30	CCA Type C	Non Reject	Groundline Treatment
58024	45	CCA Type C	Non Reject	
77266	35	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
35623	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29864	45	CCA Type C	Non Reject	Groundline Treatment
77238	35	CCA Type C	Non Reject	
12346	50	CCA Type C	Non Reject	Groundline Treatment
27069	50	CCA Type C	Non Reject	Groundline Treatment
27070	35	CCA Type C	Non Reject	Groundline Treatment
33904	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52891	45	CCA Type C	Non Reject	
46025	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46370	25	CCA Type C	Non Reject	Groundline Treatment
45530	50	CCA Type C	Non Reject	
61554	35	CCA Type C	Non Reject	
31403	40	CCA Type C	Non Reject	Groundline Treatment
20723	30	Creosote	Non Reject	Groundline Treatment
70420	35	CCA Type C	Non Reject	
34984	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49470	40	CCA Type C	Non Reject	Groundline Treatment
49455	40	CCA Type C	Non Reject	
67678	35	CCA Type C	Non Reject	
29847	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
32915	40		Non Reject	
49454	40	CCA Type C	Non Reject	Groundline Treatment
25076	40	CCA Type C	Non Reject	Groundline Treatment
32316	35	CCA Type C	Non Reject	Groundline Treatment
61387	45	CCA Type C	Non Reject	
35642	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27065	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12868	30	CCA Type C	Non Reject	Groundline Treatment
45581	35	CCA Type C	Non Reject	
64747	50	CCA Type C	Non Reject	
12315	35	CCA Type C	Non Reject	Groundline Treatment
61315	45	CCA Type C	Non Reject	
18674	40	CCA Type C	Non Reject	Groundline Treatment
48584	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
45493	40	CCA Type C	Non Reject	Groundline Treatment
28478	50	CCA Type C	Non Reject	Groundline Treatment
21135	35	CCA Type C	Non Reject	Groundline Treatment
31461	40	CCA Type C	Non Reject	Groundline Treatment
24831	45	CCA Type C	Non Reject	Groundline Treatment
54626	55	CCA Type C	Non Reject	
20926	30	CCA Type C	Non Reject	Groundline Treatment
50008	45	CCA Type C	Non Reject	
45442	30	CCA Type C	Non Reject	
61399	35	CCA Type C	Non Reject	
20768	40	CCA Type C	Non Reject	Groundline Treatment
45449	30	CCA Type C	Non Reject	Groundline Treatment
20886	40	CCA Type C	Non Reject	Groundline Treatment
20888	40	CCA Type C	Non Reject	Groundline Treatment
27079	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
24542	40	CCA Type C	Non Reject	Groundline Treatment
30158	50	CCA Type C	Non Reject	
79435	35	CCA Type C	Non Reject	
30157	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46043	40	Penta	Non Reject	Rejected
49460	40	CCA Type C	Non Reject	Groundline Treatment
34696	40	CCA Type C	Non Reject	
51275	40	CCA Type C	Non Reject	Groundline Treatment
60046	50	CCA Type C	Non Reject	
60045	50	CCA Type C	Non Reject	
60040	50	CCA Type C	Non Reject	
48988	50	CCA Type C	Non Reject	Groundline Treatment
21373	45	CCA Type C	Non Reject	Groundline Treatment
12335	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
12328	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49807	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12572	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12564	35	Creosote	Non Reject	Sound & Bore,MITC Fume
29840	35	CCA Type C	Non Reject	Groundline Treatment
47262	35	CCA Type C	Non Reject	Groundline Treatment
79436	45	CCA Type C	Non Reject	
48386	35	CCA Type C	Non Reject	
48379	40	CCA Type C	Non Reject	Groundline Treatment
12214	50	CCA Type C	Non Reject	
49480	40	CCA Type C	Non Reject	Groundline Treatment
51289	35	CCA Type C	Non Reject	Groundline Treatment
76868	35	CCA Type C	Non Reject	
12507	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
58843	50	CCA Type C	Non Reject	
54615	50	CCA Type C	Non Reject	
54613	50	CCA Type C	Non Reject	
20825	40	CCA Type C	Non Reject	Groundline Treatment
48987	35	CCA Type C	Non Reject	
58386	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49094	50	CCA Type C	Non Reject	
18825	30	CCA Type C	Non Reject	Groundline Treatment
31468	40	CCA Type C	Non Reject	Groundline Treatment
23169	45	CCA Type C	Non Reject	Groundline Treatment
20893	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
12367	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
30130	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12326	35	CCA Type C	Non Reject	Groundline Treatment
46788	50	CCA Type C	Non Reject	Groundline Treatment
29974	45	CCA Type C	Non Reject	Groundline Treatment
18773	35	Creosote	Non Reject	Groundline Treatment
49840	30	CCA Type C	Non Reject	Groundline Treatment
25974	25	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
25748	30	CCA Type C	Non Reject	Groundline Treatment
53087	50	CCA Type C	Non Reject	
25137	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58885	35	CCA Type C	Non Reject	
48598	45	CCA Type C	Non Reject	Groundline Treatment
29890	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51298	40	CCA Type C	Non Reject	
23215	30	CCA Type C	Non Reject	Groundline Treatment
46076	40	Creosote	Non Reject	Groundline Treatment,Hollow Heart
25959	45	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18779	35	CCA Type C	Non Reject	Groundline Treatment
61383	50	CCA Type C	Non Reject	
25723	35	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
25722	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20917	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27092	30		Non Reject	
58429	35	CCA Type C	Non Reject	
49820	50	CCA Type C	Non Reject	
30160	50	CCA Type C	Non Reject	
49197	30	CCA Type C	Non Reject	Groundline Treatment
48681	30	CCA Type C	Non Reject	Groundline Treatment
61000	35		Non Reject	
64084	45	CCA Type C	Non Reject	
25265	40	CCA Type C	Non Reject	Groundline Treatment
45473	40	CCA Type C	Non Reject	Groundline Treatment
65682	35	CCA Type C	Non Reject	
48397	30	CCA Type C	Non Reject	Groundline Treatment
45465	40	CCA Type C	Non Reject	Groundline Treatment
46013	25	Penta	Non Reject	Groundline Treatment
61364	45	CCA Type C	Non Reject	
45486	40	CCA Type C	Non Reject	Groundline Treatment
12441	45	CCA Type C	Non Reject	Groundline Treatment
48309	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59089	40	CCA Type C	Non Reject	Groundline Treatment
49870	40	CCA Type C	Non Reject	Groundline Treatment
59823	50	CCA Type C	Non Reject	
36261	45	CCA Type C	Non Reject	
55424	55	CCA Type C	Non Reject	Groundline Treatment
55425	30	Creosote	Non Reject	Groundline Treatment
12415	45	CCA Type C	Non Reject	Groundline Treatment
49463	40	CCA Type C	Non Reject	Groundline Treatment
49201	40	Penta in Petroleum	Non Reject	Groundline Treatment
58424	45	CCA Type C	Non Reject	
18838	40	CCA Type C	Non Reject	Groundline Treatment
71801	45	CCA Type C	Non Reject	
30142	30	CCA Type C	Non Reject	Groundline Treatment
53173	35	CCA Type C	Non Reject	
31458	50	CCA Type C	Non Reject	Groundline Treatment
18841	35	Penta	Non Reject	Groundline Treatment,MITC Fume
46715	40	CCA Type C	Non Reject	
48581	40		Non Reject	
30566	30	CCA Type C	Non Reject	Groundline Treatment
48981	50	CCA Type C	Non Reject	
55156	30	CCA Type C	Non Reject	Groundline Treatment
51304	25	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
18826	35	Penta	Non Restorable Reject	Groundline Treatment
29902	45	CCA Type C	Non Reject	Groundline Treatment
61784	50	CCA Type C	Non Reject	
56130	35	CCA Type C	Non Reject	
56093	35	CCA Type C	Non Reject	
20710	35	CCA Type C	Non Reject	Groundline Treatment
20814	40	CCA Type C	Non Reject	Groundline Treatment
57128	50	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
30061	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49817	50	CCA Type C	Non Reject	
27094	30	CCA Type C	Non Reject	Groundline Treatment
56749	50	CCA Type C	Non Reject	
27059	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
30136	45	CCA Type C	Non Reject	Groundline Treatment
55233	45	CCA Type C	Non Reject	
20908	35	CCA Type C	Non Reject	Groundline Treatment
50892	30	CCA Type C	Non Reject	
12407	45	CCA Type C	Non Reject	Groundline Treatment
27057	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
26025	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30048	25	CCA Type C	Non Reject	
25981	40	CCA Type C	Non Reject	Groundline Treatment
49864	30	CCA Type C	Non Reject	Groundline Treatment
49839	35	CCA Type C	Non Reject	Groundline Treatment
60975	50	CCA Type C	Non Reject	
45517	35	Creosote	Non Reject	Groundline Treatment
49090	50	CCA Type C	Non Reject	
46024	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12291	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12296	30		Non Reject	
45374	30	CCA Type C	Non Reject	Groundline Treatment
50850	35	Creosote	Non Reject	Sound & Bore,MITC Fume
58886	35	CCA Type C	Non Reject	
46068	40	Creosote	Non Reject	Sound & Bore,MITC Fume
29901	35	CCA Type C	Non Reject	Groundline Treatment
67909	50	CCA Type C	Non Reject	
64407	50	CCA Type C	Non Reject	
55843	45	CCA Type C	Non Reject	
51085	35	CCA Type C	Non Reject	
55964	45	CCA Type C	Non Reject	
58357	30	Penta	Non Reject	Groundline Treatment
48997	30	Creosote	Non Reject	Sound & Bore,MITC Fume
30026	35	CCA Type C	Non Reject	Groundline Treatment
20902	35	CCA Type C	Non Reject	Groundline Treatment
20899	35	CCA Type C	Non Reject	Groundline Treatment
20670	40	CCA Type C	Non Reject	Groundline Treatment
48547	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27161	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50832	40	CCA Type C	Non Reject	Groundline Treatment
48395	30	CCA Type C	Non Reject	Groundline Treatment
12510	40	CCA Type C	Non Reject	
52886	35	CCA Type C	Non Reject	
46375	25	Penta	Non Reject	Groundline Treatment
58201	50	CCA Type C	Non Reject	
30135	30	CCA Type C	Non Reject	Groundline Treatment
30103	40	Penta	Non Reject	Groundline Treatment
46110	35	Creosote	Non Reject	Groundline Treatment
51003	45	CCA Type C	Non Reject	
45569	25	Penta	Non Reject	Sound & Bore,MITC Fume
54651	35	CCA Type C	Non Reject	
72834	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
26938	30	CCA Type C	Non Reject	Groundline Treatment
30144	30	CCA Type C	Non Reject	Groundline Treatment
45519	35	Creosote	Non Reject	Sound & Bore,MITC Fume
27034	40	CCA Type C	Non Reject	Groundline Treatment
47075	30	CCA Type C	Non Reject	Groundline Treatment
47074	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12481	35	CCA Type C	Non Reject	Groundline Treatment
46492	35	Creosote	Non Reject	Groundline Treatment
12480	35	CCA Type C	Non Reject	Groundline Treatment
67741	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49456	35	Penta	Non Reject	Groundline Treatment
49458	30	CCA Type C	Non Reject	Groundline Treatment
55992	35	CCA Type C	Non Reject	
49089	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48972	50	CCA Type C	Non Reject	
61400	35	CCA Type C	Non Reject	
24833	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
48393	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
12281	45	CCA Type C	Non Reject	Groundline Treatment
20884	40	CCA Type C	Non Reject	Groundline Treatment
45540	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54700	50	CCA Type C	Non Reject	
21142	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30093	30	Creosote	Non Reject	Groundline Treatment
20962	35	CCA Type C	Non Reject	Groundline Treatment
51025	40	CCA Type C	Non Reject	Groundline Treatment
51029	40	CCA Type C	Non Reject	Groundline Treatment
51027	40	CCA Type C	Non Reject	Groundline Treatment
53199	50	CCA Type C	Non Reject	
18801	35		Non Reject	
18803	40	CCA Type C	Non Reject	Groundline Treatment
26279	35	CCA Type C	Non Reject	Groundline Treatment
27038	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45400	35	Penta	Non Reject	Groundline Treatment
45547	50	CCA Type C	Non Reject	
50118	35	CCA Type C	Non Reject	
30447	50	CCA Type C	Non Reject	
12280	45	CCA Type C	Non Reject	Groundline Treatment
51677	35	CCA Type C	Non Reject	
64531	50	CCA Type C	Non Reject	
45397	30	CCA Type C	Non Reject	Groundline Treatment
21043	40	CCA Type C	Non Reject	Groundline Treatment
49827	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
25069	40	CCA Type C	Non Reject	Groundline Treatment
30453	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49091	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25997	30	CCA Type C	Non Reject	Groundline Treatment
61389	45	CCA Type C	Non Reject	
45456	40	CCA Type C	Non Reject	Groundline Treatment
50009	55	CCA Type C	Non Reject	Groundline Treatment
18294	45	CCA Type C	Non Reject	
47055	50	CCA Type C	Non Reject	Groundline Treatment
25999	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28221	30	CCA Type C	Non Reject	Groundline Treatment
12221	50	CCA Type C	Non Reject	
12386	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
26271	40	CCA Type C	Non Reject	Groundline Treatment
18834	40	CCA Type C	Non Reject	Groundline Treatment
48390	40	CCA Type C	Non Reject	Groundline Treatment
21392	50	CCA Type C	Non Reject	Groundline Treatment
72251	45	CCA Type C	Non Reject	
45522	50	CCA Type C	Non Reject	
UNK	50	CCA Type C	Non Reject	
20754	45	CCA Type C	Non Reject	Groundline Treatment
54544	45	CCA Type C	Non Reject	
30567	30	CCA Type C	Non Reject	Groundline Treatment
21160	40	CCA Type C	Non Restorable Reject	Groundline Treatment,MITC Fume
33948	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48333	30	CCA Type C	Non Reject	Groundline Treatment
64413	50	CCA Type C	Non Reject	
54195	35	CCA Type C	Non Reject	
28480	50	CCA Type C	Non Reject	Groundline Treatment
32050	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12182	50	CCA Type C	Non Reject	
55988	45	CCA Type C	Non Reject	
67799	45	CCA Type C	Non Reject	
45524	50	CCA Type C	Non Reject	
46475	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53833	35	CCA Type C	Non Reject	
64401	45	CCA Type C	Non Reject	
58516	45	CCA Type C	Non Reject	
20841	40	Creosote	Non Reject	Sound & Bore,MITC Fume
20975	35	Penta	Non Restorable Reject	Groundline Treatment
25071	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25070	40	CCA Type C	Non Reject	Groundline Treatment
64580	50	CCA Type C	Non Reject	
69918	35	CCA Type C	Non Reject	
31019	40	CCA Type C	Non Reject	Groundline Treatment
34644	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21113	35	CCA Type C	Non Reject	Groundline Treatment
12601	50	CCA Type C	Non Reject	Groundline Treatment
53991	45	CCA Type C	Non Reject	
55985	35	CCA Type C	Non Reject	
26014	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59707	45	CCA Type C	Non Reject	
32740	40	CCA Type C	Non Reject	Groundline Treatment
50826	35	Creosote	Non Reject	Groundline Treatment
26959	40	CCA Type C	Non Reject	Groundline Treatment
47486	35	CCA Type C	Non Reject	Groundline Treatment
12656	30	CCA Type C	Non Reject	Groundline Treatment
12632	45	CCA Type C	Non Reject	
57474	60	CCA Type C	Non Reject	
55837	45	CCA Type C	Non Reject	
27303	40	CCA Type C	Non Reject	Groundline Treatment
49254	30	CCA Type C	Non Reject	Groundline Treatment
35812	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46609	50	CCA Type C	Non Reject	
67738	45	CCA Type C	Non Reject	
56999	45	CCA Type C	Non Reject	
49615	40	CCA Type C	Non Reject	Groundline Treatment
54674	50	CCA Type C	Non Reject	
69999	50	CCA Type C	Non Reject	
18460	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34319	40	CCA Type C	Non Reject	Groundline Treatment
51233	30		Non Reject	
51232	30	CCA Type C	Non Reject	Groundline Treatment
46508	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48917	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49290	35	CCA Type C	Non Reject	Groundline Treatment
20591	40	Penta	Non Reject	Groundline Treatment
18894	35	Creosote	Non Reject	Groundline Treatment
12715	45	CCA Type C	Non Reject	
23331	35	CCA Type C	Non Reject	
50820	40	CCA Type C	Non Reject	Groundline Treatment
49416	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18963	45	CCA Type C	Non Reject	Groundline Treatment
58582	45	CCA Type C	Non Reject	
19095	35	Creosote	Non Reject	Groundline Treatment
22571	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49131	30	CCA Type C	Non Reject	Groundline Treatment
49133	30	CCA Type C	Non Reject	Groundline Treatment
49620	35	CCA Type C	Non Reject	Groundline Treatment
49622	30	CCA Type C	Non Reject	Groundline Treatment
49730	40	CCA Type C	Non Reject	Groundline Treatment
26934	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49229	40	CCA Type C	Non Reject	Groundline Treatment
14465	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47599	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51243	40	CCA Type C	Non Reject	
51238	35	Penta	Non Reject	Rejected
12655	30	CCA Type C	Non Reject	Groundline Treatment
18904	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
20664	40	CCA Type C	Non Reject	Groundline Treatment
55141	40	CCA Type C	Non Reject	
49433	35	Penta	Non Restorable Reject	Groundline Treatment
19074	40	CCA Type C	Non Reject	Groundline Treatment
51274	25	CCA Type C	Non Reject	Groundline Treatment
20461	40	Penta	Non Reject	Groundline Treatment
20466	40	Penta	Non Restorable Reject	Groundline Treatment
49613	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59154	60	CCA Type C	Non Reject	
12914	30	Penta	Non Restorable Reject	Groundline Treatment
12915	30	CCA Type C	Non Reject	Groundline Treatment
59703	60	CCA Type C	Non Reject	
59701	60	CCA Type C	Non Reject	
49636	35	CCA Type C	Non Reject	Groundline Treatment
49441	35	Penta	Non Reject	Groundline Treatment
49443	25		Non Reject	
12994	40	Creosote	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
12996	35	CCA Type C	Non Reject	Groundline Treatment
12925	40	CCA Type C	Non Reject	Groundline Treatment
51261	30	CCA Type C	Non Reject	Groundline Treatment
27381	30	CCA Type C	Non Reject	Groundline Treatment
49999	30		Non Reject	
58065	45	CCA Type C	Non Reject	
76731	45	CCA Type C	Non Reject	
76728	45	CCA Type C	Non Reject	
32418	40	Penta	Non Reject	Groundline Treatment
12924	40	CCA Type C	Non Reject	Groundline Treatment
47525	30	CCA Type C	Non Reject	Groundline Treatment
72349	45	CCA Type C	Non Reject	
51272	40	CCA Type C	Non Reject	Groundline Treatment
26925	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23322	40	CCA Type C	Non Reject	Groundline Treatment
56715	60	CCA Type C	Non Reject	Groundline Treatment
57633	45	CCA Type C	Non Reject	
20655	40	CCA Type C	Non Reject	Groundline Treatment
12724	45	CCA Type C	Non Reject	
54238	35	CCA Type C	Non Reject	
30779	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64587	50	CCA Type C	Non Reject	
49446	30	Penta	Non Reject	Groundline Treatment
33935	45	CCA Type C	Non Reject	Groundline Treatment
16972	35	CCA Type C	Non Reject	Groundline Treatment
76658	50	CCA Type C	Non Reject	
49249	35	Creosote	Non Reject	Groundline Treatment
16971	40	CCA Type C	Non Reject	Groundline Treatment
34151	40	CCA Type C	Non Reject	Groundline Treatment
16966	40	CCA Type C	Non Reject	Groundline Treatment
49178	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49170	35	CCA Type C	Non Reject	Groundline Treatment
55962	35	CCA Type C	Non Reject	
12708	35	CCA Type C	Non Reject	Groundline Treatment
55926	45	CCA Type C	Non Reject	
20485	35	CCA Type C	Non Reject	Groundline Treatment
24789	40	CCA Type C	Non Reject	Groundline Treatment
49117	40	CCA Type C	Non Reject	Groundline Treatment
51240	35	CCA Type C	Non Reject	
64028	45	CCA Type C	Non Reject	
54441	50	CCA Type C	Non Reject	
64427	60	CCA Type C	Non Reject	
49432	35	CCA Type C	Non Reject	
58817	50	CCA Type C	Non Reject	
52911	50	CCA Type C	Non Reject	
24723	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18397	30	Creosote	Non Reject	Sound & Bore,MITC Fume
19082	40	CCA Type C	Non Reject	Groundline Treatment
46502	35	Creosote	Non Reject	Groundline Treatment
49285	40	CCA Type C	Non Reject	Groundline Treatment
49287	40	CCA Type C	Non Reject	Groundline Treatment
49286	40	CCA Type C	Non Reject	Groundline Treatment
55848	45	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
55849	45	CCA Type C	Non Reject	
12458	35		Non Reject	
70467	45	CCA Type C	Non Reject	
20686	40	CCA Type C	Non Reject	Groundline Treatment
51268	40	CCA Type C	Non Reject	Groundline Treatment
20006	30	Creosote	Non Reject	Groundline Treatment
64072	45	CCA Type C	Non Reject	
18394	35	CCA Type C	Non Reject	Groundline Treatment
18393	35	CCA Type C	Non Reject	Groundline Treatment
27306	40	CCA Type C	Non Reject	Groundline Treatment
34695	40	CCA Type C	Non Reject	
51225	30	CCA Type C	Non Reject	Groundline Treatment
59787	60	CCA Type C	Non Reject	
12674	40	CCA Type C	Non Reject	Groundline Treatment
12670	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49419	40	CCA Type C	Non Reject	Groundline Treatment
52817	45	CCA Type C	Non Reject	
52541	45	CCA Type C	Non Reject	
46712	40	CCA Type C	Non Reject	
52908	45	CCA Type C	Non Reject	
50802	30	CCA Type C	Non Reject	Groundline Treatment
55828	45	CCA Type C	Non Reject	
12692	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
36258	50	CCA Type C	Non Reject	
70074	45	CCA Type C	Non Reject	
52532	45	CCA Type C	Non Reject	
24715	35	CCA Type C	Non Reject	Groundline Treatment
49292	30	CCA Type C	Non Reject	Groundline Treatment
49291	35	CCA Type C	Non Reject	Groundline Treatment
54539	50	CCA Type C	Non Reject	
55986	35	CCA Type C	Non Reject	
72795	45	CCA Type C	Non Reject	Groundline Treatment
49512	40	CCA Type C	Non Reject	
49423	40	CCA Type C	Non Reject	Groundline Treatment
49509	35	Penta	Non Reject	Groundline Treatment
19112	35	Penta	Non Restorable Reject	Groundline Treatment
19036	40	CCA Type C	Non Reject	Groundline Treatment
49273	40	Penta	Non Restorable Reject	Groundline Treatment
59660	45	CCA Type C	Non Reject	
18648	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58027	40	CCA Type C	Non Reject	
22588	45	CCA Type C	Non Reject	Groundline Treatment
46506	50	CCA Type C	Non Reject	
58813	50	CCA Type C	Non Reject	
49614	35	CCA Type C	Non Reject	Groundline Treatment
48915	45	CCA Type C	Non Reject	Groundline Treatment
27495	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49109	30	CCA Type C	Non Reject	Groundline Treatment
20474	40	CCA Type C	Non Reject	Groundline Treatment
27304	40	CCA Type C	Non Reject	Groundline Treatment
19053	35	Creosote	Non Restorable Reject	Groundline Treatment,Hollow Heart
49225	30	CCA Type C	Non Reject	Groundline Treatment
19198	40	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18647	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
35009	35	CCA Type C	Non Reject	Groundline Treatment
60974	45	CCA Type C	Non Reject	
46608	45	CCA Type C	Non Reject	Groundline Treatment
27049	30	CCA Type C	Non Reject	Groundline Treatment
27052	35	CCA Type C	Non Reject	Groundline Treatment
49281	45	CCA Type C	Non Reject	
60840	50	CCA Type C	Non Reject	
32828	30	CCA Type C	Non Reject	
19015	40	CCA Type C	Non Reject	Groundline Treatment
52902	45	CCA Type C	Non Reject	
18932	40	CCA Type C	Non Reject	Groundline Treatment
64510	50	CCA Type C	Non Reject	
65430	45	CCA Type C	Non Reject	
64528	50	CCA Type C	Non Reject	
20562	40	CCA Type C	Non Reject	Groundline Treatment
70555	45	CCA Type C	Non Reject	
18909	45	CCA Type C	Non Reject	Groundline Treatment
49246	35	CCA Type C	Non Reject	Groundline Treatment
60988	50	CCA Type C	Non Reject	
12602	50	CCA Type C	Non Reject	Groundline Treatment
72352	45	CCA Type C	Non Reject	
24705	30	CCA Type C	Non Reject	Groundline Treatment
46722	30	CCA Type C	Non Reject	Groundline Treatment
51168	45	CCA Type C	Non Reject	
46512	30		Non Reject	
52581	45	CCA Type C	Non Reject	
46478	35	CCA Type C	Non Reject	Groundline Treatment
61305	45	CCA Type C	Non Reject	
72863	45	CCA Type C	Non Restorable Reject	
72823	45	CCA Type C	Non Reject	
32694	30	CCA Type C	Non Reject	
49130	30	CCA Type C	Non Reject	Groundline Treatment
55883	45	CCA Type C	Non Reject	
49123	40	CCA Type C	Non Reject	Groundline Treatment
51247	30	CCA Type C	Non Reject	Groundline Treatment
54448	50	CCA Type C	Non Reject	
20521	40	CCA Type C	Non Reject	Groundline Treatment
31582	30	CCA Type C	Non Reject	Groundline Treatment
20457	40	Penta	Non Reject	Groundline Treatment
58541	45	CCA Type C	Non Reject	
72839	45	CCA Type C	Non Reject	
49153	35	CCA Type C	Non Reject	Groundline Treatment
69973	35	CCA Type C	Non Reject	
62601	45	CCA Type C	Non Reject	
58773	60	CCA Type C	Non Reject	
58774	60	CCA Type C	Non Reject	
26028	35	CCA Type C	Non Reject	
31110	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
22490	45	CCA Type C	Non Reject	Groundline Treatment
20653	35	CCA Type C	Non Reject	Groundline Treatment
55139	40	CCA Type C	Non Reject	
72204	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
54627	50	CCA Type C	Non Reject	
51167	50	CCA Type C	Non Reject	
36256	50	CCA Type C	Non Reject	
77242	35	CCA Type C	Non Reject	
58317	45	CCA Type C	Non Reject	
54569	55	CCA Type C	Non Reject	
69992	55	CCA Type C	Non Reject	
47314	35	CCA Type C	Non Reject	Groundline Treatment
64529	50	CCA Type C	Non Reject	
18577	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54060	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18952	40	CCA Type C	Non Reject	Groundline Treatment
24810	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12605	50	CCA Type C	Non Reject	Groundline Treatment
49740	50	CCA Type C	Non Reject	Groundline Treatment
64819	35	CCA Type C	Non Reject	
27045	30	CCA Type C	Non Reject	Groundline Treatment
49732	40	CCA Type C	Non Reject	Groundline Treatment
26933	40	CCA Type C	Non Reject	Groundline Treatment
18550	45	CCA Type C	Non Reject	Groundline Treatment
59564	45	CCA Type C	Non Reject	
24195	45	CCA Type C	Non Reject	
45609	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45746	35	CCA Type C	Non Reject	Groundline Treatment
64752	35	CCA Type C	Non Reject	
24276	30	CCA Type C	Non Reject	Groundline Treatment
26993	50	CCA Type C	Non Reject	Groundline Treatment
45858	35	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
45856	50	CCA Type C	Non Reject	Groundline Treatment
48160	30	CCA Type C	Non Reject	Groundline Treatment
45820	30	CCA Type C	Non Reject	Groundline Treatment
22351	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24236	45	CCA Type C	Non Reject	
45866	30	CCA Type C	Non Reject	Groundline Treatment
45868	30	CCA Type C	Non Reject	Groundline Treatment
23592	40	CCA Type C	Non Reject	Groundline Treatment
55411	50	CCA Type C	Non Reject	
62750	35	CCA Type C	Non Reject	
60769	30	CCA Type C	Non Reject	
24919	40	CCA Type C	Non Reject	Groundline Treatment
29668	45	CCA Type C	Non Reject	Groundline Treatment
29672	40	Penta	Non Reject	Groundline Treatment
60801	35	CCA Type C	Non Reject	
24295	40	CCA Type C	Non Reject	Groundline Treatment
46549	45	Penta	Non Reject	Sound & Bore,MITC Fume
46542	45	Penta	Non Reject	Sound & Bore,MITC Fume
45797	45	CCA Type C	Non Reject	Groundline Treatment
45909	50	CCA Type C	Non Reject	Groundline Treatment
48018	45	CCA Type C	Non Reject	Groundline Treatment
69787	45	CCA Type C	Non Reject	
29617	40	CCA Type C	Non Reject	Groundline Treatment
22319	35	Creosote	Non Reject	Rejected
54691	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
24325	30	CCA Type C	Non Reject	Groundline Treatment
33021	30	CCA Type C	Non Reject	Groundline Treatment
36350	45	CCA Type C	Non Reject	
24283	50	Creosote	Non Reject	Sound & Bore,MITC Fume
45778	50	CCA Type C	Non Reject	
23853	35	CCA Type C	Non Reject	
69561	35	CCA Type C	Non Reject	Groundline Treatment
12864	50	CCA Type C	Non Reject	Groundline Treatment
12866	30	CCA Type C	Non Reject	Groundline Treatment
28236	50	CCA Type C	Non Reject	Groundline Treatment
10237	50	Creosote	Non Reject	Groundline Treatment
29643	45	CCA Type C	Non Reject	Groundline Treatment
45936	30	CCA Type C	Non Reject	Groundline Treatment
12821	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29604	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29707	35	CCA Type C	Non Reject	
64066	35	CCA Type C	Non Reject	
29680	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72688	45	CCA Type C	Non Reject	Groundline Treatment
33581	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24250	50	CCA Type C	Non Reject	Groundline Treatment
24980	30	CCA Type C	Non Reject	Groundline Treatment
12881	35	Penta	Non Reject	Groundline Treatment,MITC Fume
24912	35	Creosote	Non Reject	Groundline Treatment
31695	30	CCA Type C	Non Reject	Groundline Treatment
69969	35	CCA Type C	Non Reject	
45983	45	CCA Type C	Non Reject	Groundline Treatment
72395	45	CCA Type C	Non Reject	
64063	45	CCA Type C	Non Reject	
29684	35	Penta	Non Reject	Groundline Treatment
29687	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
64068	35	CCA Type C	Non Reject	
64067	45	CCA Type C	Non Reject	
48198	40	CCA Type C	Non Reject	Groundline Treatment
24381	40	CCA Type C	Non Reject	Groundline Treatment
57616	45	CCA Type C	Non Reject	
12885	40	Creosote	Non Reject	Groundline Treatment
45901	60	CCA Type C	Non Reject	Groundline Treatment
45367	35	Creosote	Non Reject	Sound & Bore,MITC Fume
70444	45	CCA Type C	Non Reject	
17156	45	CCA Type C	Non Reject	Groundline Treatment
23705	35	Creosote	Non Reject	Groundline Treatment
69799	45	CCA Type C	Non Reject	
23398	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45874	30	CCA Type C	Non Reject	Groundline Treatment
45875	30	CCA Type C	Non Reject	Groundline Treatment
22321	40	Creosote	Non Reject	Groundline Treatment
45954	35	Penta	Non Reject	Sound & Bore,MITC Fume
24890	30	CCA Type C	Non Reject	Groundline Treatment
23421	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
36069	30	CCA Type C	Non Reject	Groundline Treatment
45818	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
60616	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47606	35	CCA Type C	Non Reject	Groundline Treatment
55414	60	CCA Type C	Non Reject	
17180	40	CCA Type C	Non Reject	Groundline Treatment
17187	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45949	40	CCA Type C	Non Reject	Groundline Treatment
23916	55	CCA Type C	Non Reject	Groundline Treatment
12839	30	CCA Type C	Non Reject	Groundline Treatment
12850	40	CCA Type C	Non Reject	Groundline Treatment
65694	35	CCA Type C	Non Reject	
45817	50	CCA Type C	Non Reject	Groundline Treatment
46551	30	CCA Type C	Non Reject	Groundline Treatment
71821	35	CCA Type C	Non Reject	
24297	40	CCA Type C	Non Reject	Groundline Treatment
24957	30	CCA Type C	Non Reject	Groundline Treatment
62662	35	CCA Type C	Non Reject	
25031	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25713	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12863	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25669	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
36342	45	CCA Type C	Non Reject	
23862	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
24184	45	CCA Type C	Non Reject	
56203	35	Penta	Non Reject	Rejected
61405	45	CCA Type C	Non Reject	
31692	45	CCA Type C	Non Reject	Groundline Treatment
26460	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29613	30	Creosote	Non Reject	Groundline Treatment
24388	50	CCA Type C	Non Reject	Groundline Treatment
69790	45	CCA Type C	Non Reject	
24974	45	Penta	Non Reject	Sound & Bore,MITC Fume
24971	30	CCA Type C	Non Reject	Groundline Treatment
45811	25	Penta	Non Reject	Groundline Treatment
24341	35	Penta	Non Reject	Groundline Treatment
24230	45	CCA Type C	Non Reject	
45779	50	CCA Type C	Non Reject	Groundline Treatment
72270	35	CCA Type C	Non Reject	
55218	35	CCA Type C	Non Reject	
24262	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
31003	30		Non Reject	
60803	35	CCA Type C	Non Reject	
34321	30	CCA Type C	Non Reject	Groundline Treatment
45959	30	CCA Type C	Non Reject	Groundline Treatment
45960	40	CCA Type C	Non Reject	Groundline Treatment
70451	45	CCA Type C	Non Reject	
70450	45	CCA Type C	Non Reject	
46228	40	CCA Type C	Non Reject	Groundline Treatment
45796	35	CCA Type C	Non Reject	Groundline Treatment
24219	45	CCA Type C	Non Reject	
45769	30	CCA Type C	Non Reject	Groundline Treatment
68634	35	CCA Type C	Non Reject	
70455	45	CCA Type C	Non Reject	
23950	35	CCA Type C	Non Reject	Groundline Treatment
45900	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46541	40	Penta	Non Reject	Groundline Treatment,MITC Fume
53959	35	CCA Type C	Non Reject	
57413	50	CCA Type C	Non Reject	
22329	30	CCA Type C	Non Reject	Groundline Treatment
24309	45	CCA Type C	Non Reject	Groundline Treatment
64076	35	CCA Type C	Non Reject	
23960	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29555	40	CCA Type C	Non Reject	Groundline Treatment
45864	25	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17262	40	Penta	Non Reject	Groundline Treatment
25000	30	CCA Type C	Non Reject	Groundline Treatment
24893	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70036	35	CCA Type C	Non Reject	
61369	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25237	45	CCA Type C	Non Reject	Groundline Treatment
24369	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
30971	30	CCA Type C	Non Reject	Groundline Treatment
29570	45	CCA Type C	Non Reject	
23913	45	CCA Type C	Non Reject	Groundline Treatment
55520	35	CCA Type C	Non Reject	
55518	35	CCA Type C	Non Reject	
60805	35	CCA Type C	Non Reject	
60804	35	CCA Type C	Non Reject	
45891	35	CCA Type C	Non Reject	Groundline Treatment
68139	35	CCA Type C	Non Reject	
17006	45	CCA Type C	Non Reject	Groundline Treatment
24358	35	Penta	Non Reject	Groundline Treatment
45804	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12847	35	Creosote	Non Reject	Groundline Treatment
12842	35	Creosote	Non Reject	Sound & Bore,MITC Fume
29637	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54128	50	CCA Type C	Non Reject	
60962	35	CCA Type C	Non Reject	Groundline Treatment
45608	35	CCA Type C	Non Reject	Groundline Treatment
45928	60	CCA Type C	Non Reject	Groundline Treatment
24896	40	CCA Type C	Non Reject	Groundline Treatment
60670	35	CCA Type C	Non Reject	
60671	35	CCA Type C	Non Reject	
45926	40	CCA Type C	Non Reject	Groundline Treatment
45935	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29553	30	CCA Type C	Non Reject	Groundline Treatment
23606	45	CCA Type C	Non Reject	Groundline Treatment
45897	30		Non Reject	
29539	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
36344	45	CCA Type C	Non Reject	
17247	35	Penta	Non Reject	Groundline Treatment,MITC Fume
45889	35	CCA Type C	Non Reject	
60665	45	CCA Type C	Non Reject	
72293	35	CCA Type C	Non Reject	
29702	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
64061	45	CCA Type C	Non Reject	
52986	35	CCA Type C	Non Reject	
45951	40	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
31005	30	CCA Type C	Non Reject	Groundline Treatment
24371	35	Penta	Non Reject	Groundline Treatment
72292	35	CCA Type C	Non Reject	
29621	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24273	30	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
24271	40	Creosote	Non Reject	Groundline Treatment
46533	35	CCA Type C	Non Reject	Groundline Treatment
62757	35	CCA Type C	Non Reject	
22337	40	CCA Type C	Non Reject	Groundline Treatment
22336	35	Penta	Non Reject	Sound & Bore,MITC Fume
53162	40	CCA Type C	Non Reject	Groundline Treatment
52000	50	CCA Type C	Non Reject	Groundline Treatment
45894	30	Creosote	Non Reject	Rejected
58960	45	CCA Type C	Non Reject	
45096	30	CCA Type C	Non Reject	Groundline Treatment
25815	30	CCA Type C	Non Reject	Groundline Treatment
45122	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
47676	30	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
25780	40	Penta	Non Reject	Groundline Treatment
25773	40	CCA Type C	Non Reject	Groundline Treatment
60031	45	CCA Type C	Non Reject	
52534	50	CCA Type C	Non Reject	
46917	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52533	50	CCA Type C	Non Reject	
25813	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28520	35	Creosote	Non Reject	Groundline Treatment
28516	30	Creosote	Non Reject	Rejected
45085	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47190	35	Untreated	Non Reject	
29403	25	Creosote	Non Reject	Rejected
34637	45	CCA Type C	Non Reject	Groundline Treatment
25800	35	Creosote	Non Reject	Groundline Treatment
25352	35	CCA Type C	Non Reject	Groundline Treatment
55577	35	CCA Type C	Non Reject	
28748	40	CCA Type C	Non Reject	Groundline Treatment
53158	40	Penta	Non Reject	Groundline Treatment
70413	35	CCA Type C	Non Reject	
30273	40	CCA Type C	Non Reject	
46909	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47183	40	Penta	Non Restorable Reject	Groundline Treatment
17233	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28726	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47695	30	CCA Type C	Non Reject	Groundline Treatment
25740	30	Creosote	Non Reject	Groundline Treatment
10352	40	CCA Type C	Non Reject	
46969	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29477	40	CCA Type C	Non Reject	Groundline Treatment
56004	35	CCA Type C	Non Reject	
28545	30	Creosote	Non Reject	Groundline Treatment
10381	40	Penta	Non Reject	Groundline Treatment,MITC Fume
23078	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45082	35	CCA Type C	Non Reject	Groundline Treatment
29307	35	Penta	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28853	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45161	50	CCA Type C	Non Reject	Groundline Treatment
25439	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28835	40	Penta	Non Reject	Groundline Treatment
54210	45	CCA Type C	Non Reject	
47728	35	CCA Type C	Non Reject	Groundline Treatment
30265	40	Penta	Non Reject	Groundline Treatment
29380	45	CCA Type C	Non Reject	Groundline Treatment
36239	40	CCA Type C	Non Reject	
46952	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64037	45	CCA Type C	Non Reject	
29454	30	CCA Type C	Non Reject	Groundline Treatment
29451	25	Creosote	Non Reject	Groundline Treatment
47612	35	CCA Type C	Non Reject	Groundline Treatment
57610	45	CCA Type C	Non Reject	
10295	45	CCA Type C	Non Reject	Groundline Treatment
28515	35	Creosote	Non Reject	Groundline Treatment
56883	50	CCA Type C	Non Reject	
30283	35	Creosote	Non Reject	Groundline Treatment
10318	40	Penta	Non Reject	Sound & Bore,MITC Fume
47071	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58627	45	CCA Type C	Non Reject	
28747	35	Creosote	Non Reject	Sound & Bore,MITC Fume
10281	40	Creosote	Non Reject	Groundline Treatment
64001	45	CCA Type C	Non Reject	
45131	25	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
45132	25	CCA Type C	Non Reject	Groundline Treatment
28711	40	CCA Type C	Non Reject	Groundline Treatment
28712	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29486	30	CCA Type C	Non Reject	Groundline Treatment
47623	35	Untreated	Non Reject	
72212	35	CCA Type C	Non Reject	
30243	35	Penta	Non Reject	Sound & Bore,MITC Fume
33148	30	CCA Type C	Non Reject	Groundline Treatment
46811	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28801	40	Penta	Non Reject	Groundline Treatment
64097	50	CCA Type C	Non Reject	Groundline Treatment
45115	30	CCA Type C	Non Reject	Groundline Treatment
45120	25	Penta	Non Reject	Sound & Bore,MITC Fume
28816	50	CCA Type C	Non Reject	Groundline Treatment
28822	35	Penta	Non Reject	Groundline Treatment,MITC Fume
48310	40	CCA Type C	Non Reject	Groundline Treatment
72148	50	CCA Type C	Non Reject	
29421	25	Penta	Non Reject	Groundline Treatment
26856	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47721	25	Penta	Non Reject	Groundline Treatment
46792	45		Non Reject	
22342	35	CCA Type C	Non Reject	Groundline Treatment
76652	35	CCA Type C	Non Reject	
48010	35	Penta	Non Reject	Sound & Bore,MITC Fume
28824	45	CCA Type C	Non Reject	Groundline Treatment
17061	40	Creosote	Non Reject	Sound & Bore,MITC Fume
54052	30	Creosote	Non Reject	Rejected

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
52729	35	CCA Type C	Non Reject	
25459	45	CCA Type C	Non Reject	Groundline Treatment
28814	35	Penta	Non Reject	Groundline Treatment
28769	35	Penta	Non Reject	Groundline Treatment
17986	50	CCA Type C	Non Reject	
32722	50	CCA Type C	Non Reject	Groundline Treatment
56125	35	CCA Type C	Non Reject	
29498	30	CCA Type C	Non Reject	Groundline Treatment
29496	40	CCA Type C	Non Reject	Groundline Treatment
47129	30	Creosote	Non Reject	Rejected
55698	35	CCA Type C	Non Reject	
28561	50	CCA Type C	Non Reject	Groundline Treatment
28559	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28557	45	CCA Type C	Non Reject	Groundline Treatment
17200	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
61414	45	CCA Type C	Non Reject	
48348	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28528	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
25888	35	Creosote	Non Reject	Groundline Treatment
28551	30	Creosote	Non Reject	Groundline Treatment
68144	35	CCA Type C	Non Reject	
30263	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25886	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25847	40	CCA Type C	Non Reject	Groundline Treatment
47672	60	CCA Type C	Non Reject	Groundline Treatment
30301	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
60681	35	CCA Type C	Non Reject	
72147	50	CCA Type C	Non Reject	
64031	35	CCA Type C	Non Reject	
18345	50	CCA Type C	Non Reject	Groundline Treatment
60009	35	CCA Type C	Non Reject	
45142	30	Creosote	Non Restorable Reject	Groundline Treatment,Hollow Heart,MITC Fume
10391	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
28682	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
68142	35	CCA Type C	Non Reject	
72152	50	CCA Type C	Non Reject	
25885	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
59205	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28709	40	CCA Type C	Non Reject	Groundline Treatment
18289	45	CCA Type C	Non Reject	
18291	45	CCA Type C	Non Reject	
70158	45	CCA Type C	Non Reject	
30252	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28809	45	CCA Type C	Non Reject	Groundline Treatment
52975	35	CCA Type B	Non Reject	
64534	45	CCA Type C	Non Reject	
45089	35	CCA Type C	Non Reject	Groundline Treatment
55117	35	CCA Type C	Non Reject	
10291	45	CCA Type C	Non Reject	Groundline Treatment
28792	35	Penta	Non Reject	Groundline Treatment
10317	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45565	30	CCA Type C	Non Reject	Rejected
64776	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28698	50	CCA Type C	Non Reject	Groundline Treatment
25838	35	CCA Type C	Non Reject	
29387	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46852	50		Non Reject	
28681	45	CCA Type C	Non Reject	Groundline Treatment
29474	35	Creosote	Non Reject	Groundline Treatment
29309	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47706	40	Penta	Non Reject	Sound & Bore,MITC Fume
46907	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17874	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25353	40	CCA Type C	Non Reject	Groundline Treatment
17872	40	CCA Type C	Non Reject	Groundline Treatment
47690	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47691	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10268	45	CCA Type C	Non Reject	Groundline Treatment
72143	45	CCA Type C	Non Reject	
48292	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45144	35		Non Reject	
25854	35	CCA Type C	Non Reject	
28744	30	CCA Type C	Non Reject	Groundline Treatment
48250	40	CCA Type C	Non Reject	Groundline Treatment
45163	50	CCA Type C	Non Reject	Groundline Treatment
28830	30	Penta	Non Reject	Groundline Treatment,MITC Fume
10397	45	CCA Type C	Non Reject	Groundline Treatment
10300	45	Creosote	Non Reject	Sound & Bore,MITC Fume
12456	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45099	20	Creosote	Non Reject	Groundline Treatment
46003	25	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
46400	25	CCA Type C	Non Reject	Groundline Treatment
24522	40	CCA Type C	Non Reject	Groundline Treatment
58984	45	CCA Type C	Non Reject	
58593	50	CCA Type C	Non Reject	
58448	35	CCA Type C	Non Reject	
48377	30		Non Reject	
58446	35	CCA Type C	Non Reject	
46044	30	CCA Type C	Non Reject	Groundline Treatment
57472	60	CCA Type C	Non Reject	
58499	45	CCA Type C	Non Reject	
49852	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49847	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48582	40	CCA Type C	Non Reject	
50905	35	CCA Type C	Non Reject	Groundline Treatment
50904	35	CCA Type C	Non Reject	Groundline Treatment
58790	40	CCA Type C	Non Reject	
20809	30	CCA Type C	Non Reject	Groundline Treatment
12936	40	Creosote	Non Reject	Groundline Treatment
51222	30	Penta	Non Reject	Groundline Treatment
30025	30	CCA Type C	Non Reject	Groundline Treatment
29867	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
50854	45	CCA Type C	Non Reject	Groundline Treatment
48396	30	CCA Type C	Non Reject	Groundline Treatment
57473	60	CCA Type C	Non Reject	
69733	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
20906	50	CCA Type C	Non Reject	
48990	45	CCA Type C	Non Reject	
59123	35	CCA Type C	Non Reject	
54390	50	CCA Type C	Non Reject	
54121	35		Non Reject	
26005	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12276	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
57130	50	CCA Type C	Non Reject	
49871	35	CCA Type C	Non Reject	Groundline Treatment
34325	40	CCA Type C	Non Reject	Groundline Treatment
59115	50	CCA Type C	Non Reject	
64530	50	CCA Type C	Non Reject	
70421	50	CCA Type C	Non Reject	
12389	25	Penta	Non Reject	
31018	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59818	50	CCA Type C	Non Reject	
59820	50	CCA Type C	Non Reject	
25965	30	CCA Type C	Non Reject	Groundline Treatment
48392	30	CCA Type C	Non Reject	Groundline Treatment
12388	25	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
51102	35	CCA Type C	Non Reject	
20483	50	CCA Type C	Non Reject	Groundline Treatment
52901	45	CCA Type C	Non Reject	
48544	45	CCA Type C	Non Reject	Groundline Treatment
45662	30		Non Reject	
59710	45	CCA Type C	Non Reject	
58322	35	CCA Type C	Non Reject	
46016	40	CCA Type C	Non Reject	Groundline Treatment
30054	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57131	50	CCA Type C	Non Reject	
50899	40	CCA Type C	Non Reject	Groundline Treatment
46383	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
49731	40	CCA Type C	Non Reject	Groundline Treatment
53919	45	CCA Type C	Non Reject	
20800	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47491	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48585	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
51693	45	CCA Type C	Non Reject	
45458	40	CCA Type C	Non Reject	Groundline Treatment
62735	45	CCA Type C	Non Reject	
20565	40	CCA Type C	Non Reject	Groundline Treatment
49736	30	CCA Type C	Non Reject	Groundline Treatment
52900	35	CCA Type C	Non Reject	
46348	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49146	35	CCA Type C	Non Reject	Groundline Treatment
61397	35	CCA Type C	Non Reject	
61395	50	CCA Type C	Non Reject	
52974	35	CCA Type C	Non Reject	
55580	35	CCA Type C	Non Reject	
51241	45	CCA Type C	Non Reject	Groundline Treatment
20554	50	CCA Type C	Non Reject	Groundline Treatment
59842	45	CCA Type C	Non Reject	
49152	30	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
53209	35	CCA Type C	Non Reject	
58208	50	CCA Type C	Non Reject	
12236	40	Penta	Non Restorable Reject	Rejected
49459	40	CCA Type C	Non Reject	Groundline Treatment
58710	60	CCA Type C	Non Reject	
60047	50	CCA Type C	Non Reject	
60043	50	CCA Type C	Non Reject	
60039	50	CCA Type C	Non Reject	
20700	40	Penta	Non Reject	Sound & Bore,MITC Fume
59741	60	CCA Type C	Non Reject	
59694	60	CCA Type C	Non Reject	
59689	60	CCA Type C	Non Reject	
59688	60	CCA Type C	Non Reject	
56601	40	CCA Type C	Non Reject	Groundline Treatment
59704	60	CCA Type C	Non Reject	
59756	60	CCA Type C	Non Reject	
59755	60	CCA Type C	Non Reject	
21102	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20976	35	CCA Type C	Non Reject	Groundline Treatment
49637	30		Non Reject	
12439	35	Penta	Non Restorable Reject	Groundline Treatment
26000	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46349	30	CCA Type C	Non Reject	Groundline Treatment
12327	50	CCA Type C	Non Reject	Groundline Treatment
72835	35	CCA Type C	Non Reject	
12973	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51249	40	CCA Type C	Non Reject	
51251	35	Penta	Non Restorable Reject	Rejected
51253	30	Penta	Non Restorable Reject	Groundline Treatment
12958	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12966	40	CCA Type C	Non Reject	Groundline Treatment
54661	35	CCA Type C	Non Reject	
47330	30	CCA Type C	Non Reject	Groundline Treatment
57638	45	CCA Type C	Non Reject	
79462	35	CCA Type C	Non Reject	
49868	40		Non Reject	
12561	35	Penta	Non Reject	Groundline Treatment
54664	45	CCA Type C	Non Reject	
54149	45	CCA Type C	Non Reject	
UNK	30	CCA Type C	Non Reject	Groundline Treatment
47328	30	CCA Type C	Non Reject	Groundline Treatment
47302	30	CCA Type C	Non Reject	Groundline Treatment
12565	45	CCA Type C	Non Reject	
55832	45	CCA Type C	Non Reject	
79432	35	CCA Type C	Non Reject	
64786	45	CCA Type C	Non Reject	
64134	45	CCA Type C	Non Reject	
49629	30	CCA Type C	Non Reject	Groundline Treatment
54578	55	CCA Type C	Non Reject	
12213	50	CCA Type C	Non Reject	
49844	30	CCA Type C	Non Reject	Groundline Treatment
49842	40	CCA Type C	Non Reject	Groundline Treatment
61344	45	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
54614	50	CCA Type C	Non Reject	
52814	45	CCA Type C	Non Reject	
56768	25	Creosote	Non Reject	Sound & Bore,MITC Fume
60848	35	CCA Type C	Non Reject	Groundline Treatment
48986	50	CCA Type C	Non Reject	Groundline Treatment
48369	35	CCA Type C	Non Reject	Groundline Treatment
25970	40	CCA Type C	Non Reject	Groundline Treatment
46673	50	CCA Type C	Non Reject	
18824	35	CCA Type C	Non Reject	Groundline Treatment
70586	35	CCA Type C	Non Reject	
45490	40	CCA Type C	Non Reject	Groundline Treatment
12366	30	CCA Type C	Non Reject	Groundline Treatment
67774	45	CCA Type C	Non Reject	
30104	30	CCA Type C	Non Reject	Groundline Treatment
30129	40	Penta	Non Reject	Groundline Treatment,MITC Fume
58711	60	CCA Type C	Non Reject	Groundline Treatment
18716	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
51084	35	CCA Type C	Non Reject	
12498	35	Penta	Non Reject	Sound & Bore,MITC Fume
48693	40	CCA Type C	Non Reject	Groundline Treatment
12252	35		Non Reject	
34931	40	CCA Type C	Non Reject	
46398	30	CCA Type C	Non Reject	Groundline Treatment
46399	25	CCA Type C	Non Reject	Groundline Treatment
25802	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25806	30	Creosote	Non Reject	Groundline Treatment
49716	50	CCA Type C	Non Reject	Groundline Treatment
20524	40	CCA Type C	Non Reject	Groundline Treatment
30117	40	CCA Type C	Non Reject	Groundline Treatment
57037	45	CCA Type C	Non Reject	
45412	45	CCA Type C	Non Reject	
49199	40	CCA Type C	Non Reject	Groundline Treatment
47334	35	Creosote	Non Reject	Groundline Treatment
54225	35	CCA Type C	Non Reject	
58775	60	CCA Type C	Non Reject	
51300	40	CCA Type C	Non Reject	
51299	40	CCA Type C	Non Reject	Groundline Treatment
46073	30	CCA Type C	Non Reject	Groundline Treatment
64024	50	CCA Type C	Non Reject	
46072	35	CCA Type C	Non Reject	Groundline Treatment
46074	30	CCA Type C	Non Reject	Groundline Treatment
62665	35	CCA Type C	Non Reject	
27202	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
12353	50	CCA Type C	Non Reject	Groundline Treatment
51309	35	CCA Type C	Non Reject	Groundline Treatment
72324	45	CCA Type C	Non Reject	
61380	35	CCA Type C	Non Reject	
58881	35	CCA Type C	Non Reject	
29862	35	CCA Type C	Non Reject	
25720	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30514	30	CCA Type C	Non Reject	Groundline Treatment
64080	45	CCA Type C	Non Reject	
58430	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
60038	50	CCA Type C	Non Reject	
12511	35	Penta	Non Reject	Groundline Treatment,MITC Fume
54183	45	CCA Type C	Non Reject	
20793	45	Penta	Non Reject	Groundline Treatment
20880	50	CCA Type C	Non Reject	
25820	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58501	50	CCA Type C	Non Reject	
46042	35		Non Reject	
53986	45	CCA Type C	Non Reject	
59091	40	CCA Type C	Non Reject	Groundline Treatment
46494	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45447	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
77207	55	CCA Type C	Non Reject	
77206	55	CCA Type C	Non Reject	
58769	60	CCA Type C	Non Reject	
61384	35	CCA Type C	Non Reject	
30094	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47231	45	CCA Type C	Non Reject	Groundline Treatment
62708	45	CCA Type C	Non Reject	
55773	35	CCA Type C	Non Reject	
58716	60	CCA Type C	Non Reject	
58719	60	CCA Type C	Non Reject	
45410	45	CCA Type C	Non Reject	Groundline Treatment
58326	35	CCA Type C	Non Reject	
59917	35	CCA Type C	Non Reject	Groundline Treatment
48587	35	CCA Type C	Non Reject	Groundline Treatment
20839	50	CCA Type C	Non Reject	Groundline Treatment
48599	45	CCA Type C	Non Reject	Groundline Treatment
51305	35	CCA Type C	Non Reject	Groundline Treatment
45582	35	CCA Type C	Non Reject	
30056	30	CCA Type C	Non Reject	Groundline Treatment
31432	50	CCA Type C	Non Reject	Groundline Treatment
45554	30	CCA Type C	Non Reject	Groundline Treatment
30118	40	CCA Type C	Non Reject	Groundline Treatment
21044	40	CCA Type C	Non Reject	
20901	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
58708	60	CCA Type C	Non Reject	
70231	45	CCA Type C	Non Reject	
26901	45	CCA Type C	Non Reject	Groundline Treatment
46486	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18774	45		Non Reject	
23195	25	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
52904	45	CCA Type C	Non Reject	
30032	40	CCA Type C	Non Reject	Groundline Treatment
18854	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21120	35	CCA Type C	Non Reject	Groundline Treatment
45511	35	CCA Type C	Non Reject	Groundline Treatment
58713	60	CCA Type C	Non Reject	
12294	25	Penta	Non Reject	Groundline Treatment
47757	40	CCA Type C	Non Reject	Groundline Treatment
50852	35	Creosote	Non Reject	Groundline Treatment
50914	35	CCA Type C	Non Reject	Groundline Treatment
61343	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
23280	40	CCA Type C	Non Reject	Groundline Treatment
12244	30	Creosote	Non Reject	Sound & Bore,MITC Fume
18852	50	CCA Type C	Non Reject	Groundline Treatment
57628	45	CCA Type C	Non Reject	
57630	45	CCA Type C	Non Reject	
30058	30	CCA Type C	Non Reject	
26008	40	CCA Type C	Non Reject	Groundline Treatment
26011	30	CCA Type C	Non Reject	Groundline Treatment
21396	50	CCA Type C	Non Reject	Groundline Treatment
50835	40	Penta in Petroleum	Non Reject	Groundline Treatment
46053	30		Non Reject	
50005	35	CCA Type C	Non Reject	
54161	45	CCA Type C	Non Reject	
32739	40	CCA Type C	Non Reject	Groundline Treatment
54633	35	CCA Type C	Non Reject	
76655	35	CCA Type C	Non Reject	
61388	35	CCA Type C	Non Reject	
46041	35	CCA Type C	Non Reject	Groundline Treatment
12240	40	Creosote	Non Reject	Sound & Bore,MITC Fume
28474	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53916	35	CCA Type C	Non Reject	
58225	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27032	35	CCA Type C	Non Reject	
23800	45	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
54652	35	CCA Type C	Non Reject	
60780	35	CCA Type C	Non Reject	
79416	35	CCA Type C	Non Reject	
61351	35	CCA Type C	Non Reject	
29883	45	Penta	Non Reject	Groundline Treatment
29879	45	CCA Type C	Non Reject	
61346	35	CCA Type C	Non Reject	
30476	30	CCA Type C	Non Reject	Groundline Treatment
22368	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
12232	40	Penta	Non Reject	Rejected
48036	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49457	40	CCA Type C	Non Reject	Groundline Treatment
77243	35	CCA Type C	Non Reject	
67725	50	CCA Type C	Non Reject	
64085	45	CCA Type C	Non Reject	
67800	35	CCA Type C	Non Reject	
24531	30	CCA Type C	Non Reject	Groundline Treatment
72351	45	CCA Type C	Non Reject	
51265	40	CCA Type C	Non Reject	Groundline Treatment
60663	50	CCA Type C	Non Reject	
31682	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58878	35	CCA Type C	Non Reject	
46052	50	CCA Type C	Non Reject	Groundline Treatment
18786	40	CCA Type C	Non Reject	Groundline Treatment
54631	50	CCA Type C	Non Reject	
70579	30	CCA Type C	Non Reject	
12259	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30116	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
52582	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
12383	45	CCA Type C	Non Reject	Groundline Treatment
56829	35	CCA Type C	Non Reject	
51291	35	CCA Type C	Non Reject	Groundline Treatment
33145	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45542	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58776	60	CCA Type C	Non Reject	
61159	50	CCA Type C	Non Reject	
20835	50		Non Reject	
64025	45	CCA Type C	Non Reject	
20919	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60819	35	CCA Type C	Non Reject	
55861	45	CCA Type C	Non Reject	
52890	45	CCA Type C	Non Reject	
18781	40	CCA Type C	Non Reject	Groundline Treatment
33020	30	CCA Type C	Non Reject	Groundline Treatment
29889	35	CCA Type C	Non Reject	
55031	35	CCA Type C	Non Reject	
18804	35	CCA Type C	Non Reject	Groundline Treatment
26283	30	CCA Type C	Non Reject	Groundline Treatment
30101	30	CCA Type C	Non Reject	Groundline Treatment
30446	50	CCA Type C	Non Reject	Groundline Treatment
25990	30	CCA Type C	Non Reject	Groundline Treatment
20973	35	CCA Type C	Non Reject	Groundline Treatment
49624	35	CCA Type C	Non Reject	Groundline Treatment
34152	40	CCA Type C	Non Reject	Groundline Treatment
49725	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49722	40	CCA Type C	Non Reject	Groundline Treatment
49718	40	Penta	Non Reject	Groundline Treatment
12187	50	CCA Type C	Non Reject	Groundline Treatment
20780	35	Creosote	Non Reject	Groundline Treatment
20972	50	CCA Type C	Non Reject	
30451	30	CCA Type C	Non Reject	Groundline Treatment
20667	40	Penta	Non Reject	Groundline Treatment
48983	45	CCA Type C	Non Reject	
20714	40	Penta	Non Reject	Groundline Treatment
69972	50	CCA Type C	Non Reject	
45378	30	Creosote	Non Reject	
16958	40	CCA Type C	Non Reject	Groundline Treatment
45446	35	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
46498	35	CCA Type C	Non Reject	
49821	35	CCA Type C	Non Reject	
18830	40	CCA Type C	Non Reject	Groundline Treatment
18836	40	CCA Type C	Non Reject	Groundline Treatment
58722	60	CCA Type C	Non Reject	
58721	60	CCA Type C	Non Reject	
58772	60	CCA Type C	Non Reject	
47316	35	CCA Type C	Non Reject	Groundline Treatment
79458	45	CCA Type C	Non Reject	
45531	50	CCA Type C	Non Reject	
48529	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
79412	45	CCA Type C	Non Reject	
UNK	50	CCA Type C	Non Reject	
24523	40	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
51246	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49134	30	CCA Type C	Non Reject	Groundline Treatment
23211	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
49148	35	CCA Type C	Non Reject	Groundline Treatment
45555	30	CCA Type C	Non Reject	Groundline Treatment
59831	50	CCA Type C	Non Reject	
54568	55	CCA Type C	Non Reject	
54573	50	CCA Type C	Non Reject	
54574	50	CCA Type C	Non Reject	
69995	55	CCA Type C	Non Reject	
64135	45	CCA Type C	Non Reject	
20577	40	CCA Type C	Non Reject	Groundline Treatment
49863	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20905	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
30090	45	CCA Type C	Non Reject	Groundline Treatment
61555	35	CCA Type C	Non Reject	Groundline Treatment
45527	50	CCA Type C	Non Reject	
70507	45	CCA Type C	Non Reject	
45526	50	CCA Type C	Non Reject	
33231	40	CCA Type C	Non Reject	Groundline Treatment
46474	25		Non Reject	
27080	30	CCA Type C	Non Reject	Groundline Treatment
58717	35	CCA Type C	Non Reject	
71809	45	CCA Type C	Non Reject	
71808	45	CCA Type C	Non Reject	
71802	45	CCA Type C	Non Reject	
71804	45	CCA Type C	Non Reject	
12316	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
64027	45	CCA Type C	Non Reject	
30141	30		Non Reject	
12909	35	CCA Type C	Non Reject	Groundline Treatment
62744	50	CCA Type C	Non Reject	
56844	50	CCA Type C	Non Reject	
61365	35	CCA Type C	Non Reject	
52526	45		Non Reject	
60786	45	CCA Type C	Non Reject	
49222	40	CCA Type C	Non Reject	Groundline Treatment
18376	50		Non Reject	
64591	35	CCA Type C	Non Reject	
64598	50	CCA Type C	Non Reject	
12717	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
72213	50		Non Reject	
19100	40	Penta	Non Reject	Sound & Bore,MITC Fume
12702	50	Untreated	Non Reject	
57029	45	CCA Type C	Non Reject	
18530	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
35810	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49483	40	CCA Type C	Non Reject	Groundline Treatment
TEMP	25		Non Reject	
60920	45	CCA Type C	Non Reject	
64576	45	CCA Type C	Non Reject	
20469	30	CCA Type C	Non Reject	Groundline Treatment
50825	35		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
59830	45	CCA Type C	Non Reject	
55509	35	CCA Type C	Non Reject	
58584	45	CCA Type C	Non Reject	
58589	45	CCA Type C	Non Reject	
60054	45	CCA Type C	Non Reject	
48425	50	Untreated	Non Reject	
29816	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34174	35		Non Reject	
60052	45	CCA Type C	Non Reject	
19021	40	CCA Type C	Non Reject	Groundline Treatment
61307	35	CCA Type C	Non Reject	
20458	40	Penta	Non Reject	Groundline Treatment
60834	45	CCA Type C	Non Reject	
55840	35	CCA Type C	Non Reject	
33064	40	CCA Type C	Non Reject	Groundline Treatment
13228	40	Penta	Non Reject	Groundline Treatment
49998	30	CCA Type C	Non Reject	Groundline Treatment
18971	40	Creosote	Non Reject	Groundline Treatment
67684	35	CCA Type C	Non Reject	
18878	45	CCA Type C	Non Reject	
67683	35	CCA Type C	Non Reject	
67760	35	CCA Type C	Non Reject	
46612	35	CCA Type C	Non Reject	
19019	40	CCA Type C	Non Reject	Groundline Treatment
64456	50		Non Reject	
18993	40	CCA Type C	Non Reject	Groundline Treatment
57658	45	CCA Type C	Non Reject	
49250	30	Creosote	Non Reject	Groundline Treatment
50814	50	CCA Type C	Non Reject	
49994	30	CCA Type C	Non Reject	Groundline Treatment
31581	35	CCA Type C	Non Reject	Groundline Treatment
64569	50	CCA Type C	Non Reject	
19065	40	CCA Type C	Non Reject	Groundline Treatment
54681	35	CCA Type C	Non Reject	
19031	40	CCA Type C	Non Reject	Groundline Treatment
20004	35	Creosote	Non Reject	Groundline Treatment
52910	50	CCA Type C	Non Reject	
52913	50	CCA Type C	Non Reject	
52915	50	CCA Type C	Non Reject	
24724	30	CCA Type C	Non Reject	
62606	35	CCA Type C	Non Reject	
70479	35	CCA Type C	Non Reject	
70468	45	CCA Type C	Non Reject	
48156	40	CCA Type C	Non Reject	Groundline Treatment
46497	40	CCA Type C	Non Reject	Groundline Treatment
12493	40	CCA Type C	Non Reject	Groundline Treatment
76641	50	CCA Type C	Non Reject	
18419	35	CCA Type C	Non Reject	Groundline Treatment
27307	40	CCA Type C	Non Reject	Groundline Treatment
19080	40	Penta	Non Reject	Groundline Treatment
22575	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48415	30	CCA Type C	Non Reject	Groundline Treatment
70244	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
33030	30	CCA Type C	Non Reject	Groundline Treatment
18575	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
69904	45	CCA Type C	Non Reject	
69905	45	CCA Type C	Non Reject	
50815	50	CCA Type C	Non Reject	
54439	50	CCA Type C	Non Reject	
52531	45	CCA Type C	Non Reject	
54397	50	CCA Type C	Non Reject	
67680	45	CCA Type C	Non Reject	
18973	35	CCA Type C	Non Reject	Groundline Treatment
19104	40	Penta	Non Reject	Groundline Treatment
70075	45	CCA Type C	Non Reject	
54396	50	CCA Type C	Non Reject	
52967	35	CCA Type C	Non Reject	Groundline Treatment
49503	35	Penta	Non Reject	Groundline Treatment
49283	35	CCA Type C	Non Reject	
70514	45	CCA Type C	Non Reject	
72002	45	CCA Type C	Non Reject	
19050	40	CCA Type C	Non Reject	Groundline Treatment
49220	30	CCA Type C	Non Reject	Groundline Treatment
22576	45	CCA Type C	Non Reject	Groundline Treatment
49500	45	CCA Type C	Non Reject	
58597	35	CCA Type C	Non Reject	
18645	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57627	45	CCA Type C	Non Reject	
49252	35	CCA Type C	Non Reject	Groundline Treatment
76642	45	CCA Type C	Non Reject	
76644	35	CCA Type C	Non Reject	
20481	40	CCA Type C	Non Reject	Groundline Treatment
59827	45	CCA Type C	Non Reject	
49422	40	CCA Type C	Non Reject	Groundline Treatment
20463	40	CCA Type C	Non Reject	Groundline Treatment
79475	35	CCA Type C	Non Reject	
27051	35	CCA Type C	Non Reject	Groundline Treatment
27050	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49280	40	CCA Type C	Non Reject	Groundline Treatment
64425	60	CCA Type C	Non Reject	
20482	40	CCA Type C	Non Reject	Groundline Treatment
54675	50	CCA Type C	Non Reject	
18893	35	CCA Type C	Non Reject	Groundline Treatment
49248	35	CCA Type C	Non Reject	Groundline Treatment
27154	35	CCA Type C	Non Reject	Groundline Treatment
64417	50	CCA Type C	Non Reject	
54683	50	CCA Type C	Non Reject	
33137	50	Untreated	Non Reject	
49506	30	CCA Type C	Non Reject	Groundline Treatment
27310	30	CCA Type C	Non Reject	Groundline Treatment
18461	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18470	30	CCA Type C	Non Reject	Groundline Treatment
46614	50	CCA Type C	Non Reject	
46605	35	CCA Type C	Non Reject	Groundline Treatment
18391	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18390	50	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
24861	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27044	45	CCA Type C	Non Reject	Groundline Treatment
36255	50	Untreated	Non Reject	
50807	45	CCA Type C	Non Reject	Groundline Treatment
52396	45	CCA Type C	Non Reject	
54444	50	CCA Type C	Non Reject	
49705	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64424	60	CCA Type C	Non Reject	
64421	60	CCA Type C	Non Reject	
54680	50	CCA Type C	Non Reject	
18387	50	CCA Type C	Non Reject	Groundline Treatment
46611	50	CCA Type C	Non Reject	
46511	30	CCA Type C	Non Reject	Groundline Treatment
47500	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54678	50	CCA Type C	Non Reject	
54418	35	CCA Type C	Non Reject	
UNK	35		Non Reject	
49712	35	Penta	Non Reject	Groundline Treatment
48430	25	CCA Type C	Non Reject	Groundline Treatment
64455	45	CCA Type C	Non Reject	
45123	25	Creosote	Non Reject	Groundline Treatment
25797	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60191	45	CCA Type C	Non Reject	
55552	50	CCA Type C	Non Reject	
46908	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25683	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
67710	30	CCA Type C	Non Reject	
58851	35	CCA Type C	Non Reject	
23090	40	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
47637	35	CCA Type C	Non Reject	Groundline Treatment
47634	35	Penta	Non Reject	Groundline Treatment
45603	35	CCA Type C	Non Reject	
24233	35	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
26990	30	CCA Type C	Non Reject	Groundline Treatment
23397	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
45859	30	Creosote	Non Reject	Groundline Treatment
55410	35	CCA Type C	Non Reject	
29669	30	CCA Type C	Non Reject	Groundline Treatment
29647	35	Penta	Non Reject	Groundline Treatment
64069	35	CCA Type C	Non Reject	
23929	40	Creosote	Non Reject	Rejected
46652	50	CCA Type C	Non Reject	
17176	45	CCA Type C	Non Reject	Groundline Treatment
23860	50	CCA Type C	Non Reject	Groundline Treatment
28513	45	CCA Type C	Non Reject	Groundline Treatment
23087	55	CCA Type C	Non Reject	Groundline Treatment
53193	35	CCA Type C	Non Reject	
47735	30	Creosote	Non Reject	Groundline Treatment
60650	30	CCA Type C	Non Reject	Groundline Treatment
31658	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
69788	45	CCA Type C	Non Reject	
23101	30	CCA Type C	Non Reject	Groundline Treatment
24420	30	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
29595	45	CCA Type C	Non Reject	Groundline Treatment
29543	25	Penta	Non Reject	Sound & Bore,MITC Fume
12836	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12838	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
22330	40	CCA Type C	Non Reject	
32305	40	CCA Type C	Non Reject	Groundline Treatment
25799	45	CCA Type C	Non Reject	Groundline Treatment
24275	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23065	50	CCA Type C	Non Reject	Groundline Treatment
54514	35	CCA Type C	Non Reject	
45939	60	CCA Type C	Non Reject	Groundline Treatment
62653	35	CCA Type C	Non Reject	
30275	35	Creosote	Non Reject	Groundline Treatment
27499	30	CCA Type C	Non Reject	Groundline Treatment
46910	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72264	45	CCA Type C	Non Reject	
28723	40	CCA Type C	Non Reject	Groundline Treatment
28725	35	Creosote	Non Restorable Reject	Rejected
28721	30	CCA Type C	Non Reject	Groundline Treatment
24345	35	CCA Type C	Non Reject	
45853	50	CCA Type C	Non Reject	Groundline Treatment
45774	50	CCA Type C	Non Reject	
23915	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47720	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17201	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17199	45	CCA Type C	Non Reject	Groundline Treatment
47704	35	Penta	Non Reject	Groundline Treatment,MITC Fume
52863	35	CCA Type C	Non Reject	
46451	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31691	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
58488	50	CCA Type C	Non Reject	
45766	35	CCA Type C	Non Reject	Groundline Treatment
58565	45	CCA Type C	Non Reject	
72382	35	CCA Type C	Non Reject	
23620	50	CCA Type C	Non Reject	Groundline Treatment
24208	45	CCA Type C	Non Reject	
28697	30	Creosote	Non Reject	Groundline Treatment
46914	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
56709	45	CCA Type C	Non Reject	
28549	30	CCA Type C	Non Reject	Groundline Treatment
25785	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
10277	40	Penta	Non Reject	Groundline Treatment
12854	50	CCA Type C	Non Reject	Groundline Treatment
28544	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10282	50	CCA Type C	Non Reject	Groundline Treatment
28543	35	Creosote	Non Reject	Sound & Bore,MITC Fume
45083	35	CCA Type C	Non Reject	Groundline Treatment
28235	45	CCA Type C	Non Reject	Groundline Treatment
17203	45	CCA Type C	Non Reject	Groundline Treatment
29730	30	CCA Type C	Non Reject	Groundline Treatment
31408	35	CCA Type C	Non Reject	Groundline Treatment
12892	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
12896	40	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
69786	45	CCA Type C	Non Reject	
18091	40	Penta	Non Reject	Sound & Bore,MITC Fume
48239	40	Penta	Non Reject	Sound & Bore,MITC Fume
48249	45		Non Reject	
12827	40	CCA Type C	Non Reject	Groundline Treatment
45955	30	CCA Type C	Non Reject	Groundline Treatment
45956	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29609	40	CCA Type C	Non Reject	Groundline Treatment
29602	40	CCA Type C	Non Reject	Groundline Treatment
29705	40	CCA Type C	Non Reject	Groundline Treatment
64785	35	CCA Type C	Non Reject	
48013	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
62751	45	CCA Type C	Non Reject	
24405	45	CCA Type C	Non Reject	Groundline Treatment
29666	30	CCA Type C	Non Reject	Groundline Treatment
29667	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29663	30	CCA Type C	Non Reject	Groundline Treatment
29662	40	CCA Type C	Non Reject	Groundline Treatment
46920	30	CCA Type C	Non Reject	Groundline Treatment
27316	40	CCA Type C	Non Reject	Groundline Treatment
45973	35	Creosote	Non Reject	Rejected
69849	35	CCA Type C	Non Reject	
60655	45	CCA Type C	Non Reject	
17159	35	Penta	Non Reject	Sound & Bore,MITC Fume
45989	55	CCA Type C	Non Reject	Groundline Treatment
24374	50	CCA Type C	Non Reject	Groundline Treatment
24382	30	CCA Type C	Non Reject	Groundline Treatment
76491	35	Penta	Non Reject	Groundline Treatment
29686	30	CCA Type C	Non Reject	Groundline Treatment
17190	35	Penta	Non Reject	Groundline Treatment
45953	40	Penta	Non Reject	Groundline Treatment
45984	40	CCA Type C	Non Reject	Groundline Treatment
22316	40	CCA Type C	Non Reject	Groundline Treatment
62652	35	CCA Type C	Non Reject	
47613	35	Creosote	Non Reject	Groundline Treatment
23057	50	Creosote	Non Reject	Groundline Treatment,MITC Fume
23393	35	Creosote	Non Reject	Groundline Treatment
70445	45	CCA Type C	Non Reject	
70439	35	CCA Type C	Non Reject	
70440	45	CCA Type C	Non Reject	
65696	35	CCA Type C	Non Reject	
24322	35	CCA Type C	Non Reject	Groundline Treatment
23071	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31477	40	CCA Type C	Non Reject	Groundline Treatment
25857	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
28742	35	CCA Type C	Non Reject	
54054	35	Creosote	Non Reject	Rejected
64799	35	CCA Type C	Non Reject	
67724	45	CCA Type C	Non Reject	
54871	35	CCA Type C	Non Reject	
45871	35	CCA Type C	Non Reject	
29557	40	CCA Type C	Non Reject	Groundline Treatment
54056	30	Creosote	Non Reject	Rejected

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
27158	40	CCA Type C	Non Reject	Groundline Treatment
58569	35	CCA Type C	Non Reject	
24908	45	CCA Type C	Non Reject	Groundline Treatment
24906	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30442	30	CCA Type C	Non Reject	Groundline Treatment
70412	45	CCA Type C	Non Reject	
25758	40	CCA Type C	Non Reject	Groundline Treatment
25844	35	CCA Type C	Non Reject	
45642	30	CCA Type C	Non Reject	Groundline Treatment
45612	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
47605	35	CCA Type C	Non Reject	
47604	35	CCA Type C	Non Reject	
58452	35	CCA Type C	Non Reject	
64054	60	CCA Type C	Non Reject	
12899	35	Penta	Non Reject	Groundline Treatment
10327	40	CCA Type C	Non Reject	Groundline Treatment
59841	35	CCA Type C	Non Reject	Groundline Treatment
46557	50	CCA Type C	Non Reject	Groundline Treatment
57409	50	CCA Type C	Non Reject	
65798	35	CCA Type C	Non Reject	
70442	45	CCA Type C	Non Reject	
55914	35	CCA Type C	Non Reject	
24183	45	CCA Type C	Non Reject	
24188	45	CCA Type C	Non Reject	
24190	45	CCA Type C	Non Reject	
45886	45	CCA Type C	Non Reject	
45870	30	CCA Type C	Non Reject	Groundline Treatment
23602	50	Untreated	Non Reject	
45785	40	CCA Type C	Non Reject	Groundline Treatment
27317	40	CCA Type C	Non Reject	Groundline Treatment
45904	25	CCA Type C	Non Reject	Groundline Treatment
23869	50	Creosote	Non Reject	Rejected
46916	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45617	30	CCA Type C	Non Reject	
53192	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
45111	35	Creosote	Non Reject	
23952	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47602	30	CCA Type C	Non Reject	Groundline Treatment
70463	45	CCA Type C	Non Reject	
12904	30	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
61577	35	CCA Type C	Non Reject	
24414	30	CCA Type C	Non Reject	Groundline Treatment
29573	30	Creosote	Non Reject	Sound & Bore,MITC Fume
29652	40	CCA Type C	Non Reject	Groundline Treatment
23918	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23931	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
18032	35	CCA Type C	Non Reject	Groundline Treatment
24357	40	CCA Type C	Non Reject	Groundline Treatment
68197	50	CCA Type C	Non Reject	
24290	30	Penta	Non Reject	Groundline Treatment
24331	45	CCA Type C	Non Reject	Groundline Treatment
24333	30	CCA Type C	Non Reject	Groundline Treatment
45109	25	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
45108	25	CCA Type C	Non Reject	
45105	25	Penta	Non Reject	Groundline Treatment
24352	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
47654	60	Penta	Non Reject	Sound & Bore,MITC Fume
64038	45	CCA Type C	Non Reject	
60653	35	CCA Type C	Non Reject	
61412	45	CCA Type C	Non Reject	
47707	30	CCA Type C	Non Reject	Groundline Treatment
45763	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23404	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45855	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
72295	35	CCA Type C	Non Reject	
45620	25	Creosote	Non Reject	Rejected
45086	30	CCA Type C	Non Reject	Groundline Treatment
48003	30		Non Reject	
25853	30		Non Reject	
28535	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28533	40	CCA Type C	Non Reject	Groundline Treatment
28530	35	Penta	Non Reject	Groundline Treatment
29327	30	Creosote	Non Reject	Sound & Bore,MITC Fume
17153	45	CCA Type C	Non Reject	Groundline Treatment
27157	40	CCA Type C	Non Reject	Groundline Treatment
29578	35	Creosote	Non Reject	Rejected
45920	35	Penta	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
18061	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23989	30	CCA Type C	Non Reject	Groundline Treatment
47630	60	CCA Type C	Non Reject	Groundline Treatment
30300	35	CCA Type C	Non Reject	
47670	60	Creosote	Non Reject	Groundline Treatment
54057	35	Creosote	Non Reject	Sound & Bore,MITC Fume
47699	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47684	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47698	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47729	35	CCA Type C	Non Reject	Groundline Treatment
17011	30	Penta	Non Reject	Groundline Treatment
47671	30	CCA Type C	Non Reject	Groundline Treatment
46201	30	CCA Type C	Non Reject	Groundline Treatment
30994	40	CCA Type C	Non Reject	Groundline Treatment
25753	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25752	40	CCA Type C	Non Reject	Groundline Treatment
55561	50	CCA Type C	Non Reject	
70168	50	CCA Type C	Non Reject	
34335	35	CCA Type C	Non Reject	
24222	45	CCA Type C	Non Reject	
32264	30	CCA Type C	Non Reject	Groundline Treatment
64211	35	CCA Type C	Non Reject	
18043	30	CCA Type C	Non Reject	Groundline Treatment
28686	45	CCA Type C	Non Reject	Groundline Treatment
57451	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24428	35	Penta	Non Reject	Groundline Treatment
45862	30	CCA Type C	Non Reject	Groundline Treatment
26778	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28233	45	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
45895	60	CCA Type C	Non Reject	Groundline Treatment
54058	30	Creosote	Non Reject	Sound & Bore,MITC Fume
36346	50	CCA Type C	Non Reject	
10284	45	Penta	Non Restorable Reject	Groundline Treatment
28569	30	CCA Type C	Non Reject	Groundline Treatment
69796	45	CCA Type C	Non Reject	
53909	45	CCA Type C	Non Reject	
45947	35	CCA Type C	Non Reject	Groundline Treatment
22325	35	Penta	Non Reject	Groundline Treatment,MITC Fume
29589	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45088	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
67695	50	CCA Type C	Non Reject	
67697	50	CCA Type C	Non Reject	
28862	35		Non Reject	
17053	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46525	35	Creosote	Non Reject	Groundline Treatment
29561	40	CCA Type C	Non Reject	Groundline Treatment
29563	30	Creosote	Non Reject	Groundline Treatment
29564	30	CCA Type C	Non Reject	Groundline Treatment
45958	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24313	30	Creosote	Non Reject	Groundline Treatment
28758	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52976	35	CCA Type B	Non Reject	
17179	40	Creosote	Non Reject	Groundline Treatment
29691	40	CCA Type C	Non Reject	Groundline Treatment
17263	40	Penta	Non Reject	Groundline Treatment,MITC Fume
36133	35	CCA Type C	Non Reject	Groundline Treatment
24996	35	CCA Type C	Non Reject	Groundline Treatment
24995	30	CCA Type C	Non Reject	Groundline Treatment
68099	35	CCA Type C	Non Reject	
24972	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24202	30	CCA Type C	Non Reject	Groundline Treatment
25240	45	CCA Type C	Non Reject	Groundline Treatment
68129	35	CCA Type C	Non Reject	
24429	35	Penta	Non Reject	Groundline Treatment
24432	35	Penta	Non Reject	Groundline Treatment
27440	30	CCA Type C	Non Reject	Groundline Treatment
24426	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
17175	45	CCA Type C	Non Reject	Groundline Treatment
60654	35	CCA Type C	Non Reject	
65697	35	CCA Type C	Non Reject	
45968	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24923	40	Penta	Non Reject	Sound & Bore,MITC Fume
45980	45	CCA Type C	Non Reject	Groundline Treatment
64052	45	CCA Type C	Non Reject	
25772	35	CCA Type C	Non Reject	Groundline Treatment
61404	50	CCA Type C	Non Reject	
55075	35	CCA Type C	Non Reject	Groundline Treatment
53140	60	CCA Type C	Non Reject	Groundline Treatment
29622	30	CCA Type C	Non Reject	Groundline Treatment
29620	30	CCA Type C	Non Reject	Groundline Treatment
45994	35	CCA Type C	Non Reject	
45993	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
58534	35	CCA Type C	Non Reject	
28793	35	Penta	Non Reject	Sound & Bore,MITC Fume
46524	30	CCA Type C	Non Reject	Groundline Treatment
33046	30	CCA Type C	Non Reject	Groundline Treatment
28525	50	CCA Type C	Non Reject	Groundline Treatment
28526	50	CCA Type C	Non Reject	Groundline Treatment
45890	50	CCA Type C	Non Reject	
46556	35	CCA Type C	Non Reject	
25841	35	Penta	Non Reject	Groundline Treatment
45992	30	CCA Type C	Non Reject	Groundline Treatment
23940	30		Non Reject	
23939	25	CCA Type C	Non Reject	Groundline Treatment
23937	30	Creosote	Non Reject	Sound & Bore,MITC Fume
46531	50	CCA Type C	Non Reject	Groundline Treatment
46534	30	CCA Type C	Non Reject	Groundline Treatment
17226	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57412	50	CCA Type C	Non Reject	
24284	35	Creosote	Non Reject	Groundline Treatment
28547	50	CCA Type C	Non Reject	Groundline Treatment
61372	35	CCA Type C	Non Reject	
28719	30	CCA Type C	Non Reject	Groundline Treatment
25727	30	CCA Type C	Non Reject	Groundline Treatment
52826	35	CCA Type C	Non Reject	
58949	35	CCA Type C	Non Reject	Groundline Treatment
12845	40	CCA Type C	Non Reject	Groundline Treatment
57748	35	CCA Type C	Non Reject	
60961	35	CCA Type C	Non Reject	
45887	30	Creosote	Non Reject	Rejected
26686	45	CCA Type C	Non Reject	Groundline Treatment
45918	60	CCA Type C	Non Reject	Groundline Treatment
53138	35		Non Reject	
54025	50	CCA Type C	Non Reject	
29551	30	CCA Type C	Non Reject	Groundline Treatment
46967	30	CCA Type C	Non Reject	Groundline Treatment
45095	30	CCA Type C	Non Reject	Groundline Treatment
25869	35	CCA Type C	Non Reject	
24442	30	Penta	Non Restorable Reject	Groundline Treatment
32343	35	CCA Type C	Non Reject	Groundline Treatment
23053	50		Non Reject	
51995	50	CCA Type C	Non Reject	
25040	30	CCA Type C	Non Reject	Groundline Treatment
70241	35	CCA Type C	Non Reject	
47693	30	CCA Type C	Non Reject	Groundline Treatment
55512	35	CCA Type C	Non Reject	
30003	40	CCA Type C	Non Reject	Groundline Treatment
17186	45	CCA Type C	Non Reject	Groundline Treatment
23947	35	CCA Type C	Non Reject	Groundline Treatment
23935	35	CCA Type C	Non Reject	
45997	30	CCA Type C	Non Reject	Groundline Treatment
23942	55	CCA Type C	Non Reject	Groundline Treatment
64055	60	CCA Type C	Non Reject	
45790	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
60664	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
29607	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29606	35	Creosote	Non Reject	Groundline Treatment
45957	40	CCA Type C	Non Reject	Groundline Treatment
29697	40	CCA Type C	Non Reject	Groundline Treatment
29696	45	CCA Type C	Non Reject	Groundline Treatment
55086	35	CCA Type C	Non Reject	
68095	45	CCA Type C	Non Reject	
29724	30	Penta	Non Restorable Reject	Groundline Treatment
64062	45	CCA Type C	Non Reject	
17249	40	Penta	Non Reject	Groundline Treatment,MITC Fume
17261	40	Penta	Non Reject	Groundline Treatment
33938	35	CCA Type C	Non Reject	Groundline Treatment
25004	35	Creosote	Non Reject	Rejected
31006	30	CCA Type C	Non Reject	Groundline Treatment
69792	45	CCA Type C	Non Reject	
46923	30	CCA Type C	Non Reject	Groundline Treatment
27501	40	CCA Type C	Non Reject	Groundline Treatment
48290	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54241	45	CCA Type C	Non Reject	
29623	40	CCA Type C	Non Reject	Groundline Treatment
10239	50	Creosote	Non Reject	Groundline Treatment
10248	50	CCA Type C	Non Reject	Groundline Treatment
62749	35	CCA Type C	Non Reject	
68603	35	CCA Type C	Non Reject	
17235	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
79474	50	CCA Type C	Non Reject	
48201	30		Non Reject	
55559	50	CCA Type C	Non Reject	
45764	30	CCA Type C	Non Reject	Groundline Treatment
56870	35	CCA Type C	Non Reject	
68085	35	CCA Type C	Non Reject	
60169	60	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28829	40	CCA Type C	Non Reject	Groundline Treatment
28832	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55982	45	CCA Type C	Non Reject	
29377	35	CCA Type C	Non Reject	Groundline Treatment
57745	35	CCA Type C	Non Reject	
29402	35	Creosote	Non Reject	Groundline Treatment
12898	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57767	45	CCA Type C	Non Reject	
25349	35	CCA Type C	Non Reject	Groundline Treatment
60029	35	CCA Type C	Non Reject	
70194	45	CCA Type C	Non Reject	
70195	45	CCA Type C	Non Reject	
64801	35		Non Reject	
31731	35	CCA Type C	Non Reject	Groundline Treatment
68087	35	CCA Type C	Non Reject	
29395	30	CCA Type C	Non Reject	Groundline Treatment
45160	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
64041	45	CCA Type C	Non Reject	
28849	40	Penta	Non Reject	Groundline Treatment,MITC Fume
25348	35	CCA Type C	Non Reject	Groundline Treatment
59781	45		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
17895	40	CCA Type C	Non Reject	Groundline Treatment
28956	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31758	50	CCA Type C	Non Reject	Groundline Treatment
UNK	35		Non Reject	
34638	45	CCA Type C	Non Reject	Groundline Treatment
48336	25		Non Reject	
17866	40	CCA Type C	Non Reject	Groundline Treatment
68150	35	CCA Type C	Non Reject	
28800	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
28797	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
48271	40	CCA Type C	Non Reject	Groundline Treatment
72145	50	CCA Type C	Non Reject	
10289	45	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
61785	60	CCA Type C	Non Reject	
55791	35	CCA Type C	Non Reject	
28541	40	Creosote	Non Reject	Sound & Bore,MITC Fume
55061	35	CCA Type C	Non Reject	
55981	45	CCA Type C	Non Reject	
72336	50	CCA Type C	Non Reject	
27349	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72149	50	CCA Type C	Non Reject	
60765	45	CCA Type C	Non Reject	
62713	35	CCA Type C	Non Reject	
64408	50	CCA Type C	Non Reject	Groundline Treatment
12888	40	Penta	Non Reject	Sound & Bore,MITC Fume
57635	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34307	40	CCA Type C	Non Reject	
72140	35	CCA Type C	Non Reject	
29495	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46791	45	CCA Type C	Non Reject	
60179	45	CCA Type C	Non Reject	
52399	35	CCA Type C	Non Reject	
64775	45	CCA Type C	Non Reject	
58630	45	CCA Type C	Non Reject	
12890	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29392	35	Creosote	Non Reject	Groundline Treatment
56875	45	CCA Type C	Non Reject	
72144	50	CCA Type C	Non Reject	
10314	40	Penta in Petroleum	Non Reject	Groundline Treatment
58330	35	CCA Type C	Non Reject	
29388	30	Creosote	Non Reject	Groundline Treatment
52878	45	CCA Type C	Non Reject	
64409	50	CCA Type C	Non Reject	
57114	45	CCA Type C	Non Reject	
17873	40	CCA Type C	Non Reject	Rejected
25354	40	CCA Type C	Non Reject	Groundline Treatment
29368	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10324	35	CCA Type C	Non Reject	Groundline Treatment
54602	45	CCA Type C	Non Reject	
29404	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
62659	35	CCA Type C	Non Reject	
36315	45	CCA Type C	Non Reject	
61355	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
65698	50	CCA Type C	Non Reject	
56212	35	CCA Type C	Non Reject	
12676	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45509	50	CCA Type C	Non Reject	
58877	35	CCA Type C	Non Reject	
48973	50	CCA Type C	Non Reject	
58771	60	CCA Type C	Non Reject	
26006	30	CCA Type C	Non Reject	Groundline Treatment
64081	45	CCA Type C	Non Reject	
35665	35	CCA Type C	Non Reject	Groundline Treatment
27062	45	CCA Type C	Non Reject	Groundline Treatment
47497	35	CCA Type C	Non Reject	
12266	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49192	40	CCA Type C	Non Reject	
54168	45	CCA Type C	Non Reject	
60859	45	CCA Type C	Non Reject	
21155	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
71819	35	CCA Type C	Non Reject	
45466	35	Penta	Non Reject	Groundline Treatment,MITC Fume
77265	35	CCA Type C	Non Reject	
20801	45	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
12627	50	CCA Type C	Non Reject	
51224	30	CCA Type C	Non Reject	Groundline Treatment
48427	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29909	30	CCA Type C	Non Reject	Groundline Treatment
50853	35	Creosote	Non Reject	Groundline Treatment
50855	35	Creosote	Non Reject	Groundline Treatment
46380	45	Penta	Non Restorable Reject	Groundline Treatment
46714	40	CCA Type C	Non Reject	
20813	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
69978	35	CCA Type C	Non Reject	
59124	35	CCA Type C	Non Reject	
22488	45	CCA Type C	Non Reject	Groundline Treatment
55057	50	CCA Type C	Non Reject	
55420	50	CCA Type C	Non Reject	
22367	45	Penta	Non Restorable Reject	Groundline Treatment
12211	50	CCA Type C	Non Reject	
21371	45	CCA Type C	Non Reject	Groundline Treatment
57126	50	CCA Type C	Non Reject	
59819	50	CCA Type C	Non Reject	
21370	45	CCA Type C	Non Reject	Groundline Treatment
21369	45	CCA Type C	Non Reject	Groundline Treatment
24816	45	CCA Type C	Non Reject	Groundline Treatment
48394	35	Creosote	Non Reject	Sound & Bore,MITC Fume
12385	45	CCA Type C	Non Reject	Groundline Treatment
20743	45	CCA Type C	Non Reject	Groundline Treatment
58880	35	CCA Type C	Non Reject	
29898	40	CCA Type C	Non Reject	Groundline Treatment
50910	35	CCA Type C	Non Reject	Groundline Treatment
48593	35	CCA Type C	Non Reject	Groundline Treatment
49841	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
76524	30	CCA Type C	Non Reject	
18843	35	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18718	35	Penta	Non Reject	Groundline Treatment
12714	45	CCA Type C	Non Reject	
12805	50	CCA Type C	Non Reject	Groundline Treatment
46027	35	CCA Type C	Non Reject	Groundline Treatment
57729	35	CCA Type C	Non Reject	
23184	40	CCA Type C	Non Reject	Groundline Treatment
67773	45	CCA Type C	Non Reject	
12690	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48423	50	Untreated	Non Reject	
20572	40	CCA Type C	Non Reject	Groundline Treatment
50486	35	CCA Type C	Non Reject	
18797	40	CCA Type C	Non Reject	
61313	45	CCA Type C	Non Reject	
20557	50	CCA Type C	Non Reject	Groundline Treatment
33234	45	CCA Type C	Non Reject	Groundline Treatment
20544	40	CCA Type C	Non Reject	Groundline Treatment
20643	50	CCA Type C	Non Reject	Groundline Treatment
55588	40	CCA Type C	Non Reject	
49185	30	CCA Type C	Non Reject	Groundline Treatment
49143	30	CCA Type C	Non Reject	Groundline Treatment
45468	45	CCA Type C	Non Reject	Groundline Treatment
27056	45	CCA Type C	Non Reject	Groundline Treatment
12928	40	Creosote	Non Reject	Groundline Treatment
20890	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20531	40	CCA Type C	Non Reject	Groundline Treatment
49144	30	CCA Type C	Non Reject	Groundline Treatment
54311	35	CCA Type C	Non Reject	
35025	50	CCA Type C	Non Reject	
18704	40	CCA Type C	Non Reject	Groundline Treatment
50840	40	Penta	Non Reject	Groundline Treatment
49635	30	CCA Type C	Non Reject	Groundline Treatment
32728	40	CCA Type C	Non Reject	Groundline Treatment
53211	35	CCA Type C	Non Reject	
45546	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55784	35	CCA Type C	Non Reject	
12929	40	CCA Type C	Non Reject	Groundline Treatment
12976	40	CCA Type C	Non Reject	Groundline Treatment
46485	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60048	50	CCA Type C	Non Reject	
59702	60	CCA Type C	Non Reject	
59799	60	CCA Type C	Non Reject	
59754	60	CCA Type C	Non Reject	
59751	60	CCA Type C	Non Reject	
59750	60	CCA Type C	Non Reject	
46022	35	CCA Type C	Non Reject	Groundline Treatment
61791	45	CCA Type C	Non Reject	
60969	35	CCA Type C	Non Reject	
51262	30	CCA Type C	Non Reject	Groundline Treatment
12932	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
12974	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46777	40	CCA Type C	Non Reject	
34655	35	CCA Type C	Non Reject	Groundline Treatment
51264	30	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
53843	35	CCA Type C	Non Reject	
58069	45	CCA Type C	Non Reject	
58544	45	CCA Type C	Non Reject	
12963	40	CCA Type C	Non Reject	Groundline Treatment
12961	40	Creosote	Non Reject	Groundline Treatment
51256	45	CCA Type C	Non Reject	
69974	45	CCA Type C	Non Reject	
47267	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12553	40	CCA Type C	Non Reject	Groundline Treatment
12560	35	Creosote	Non Reject	Groundline Treatment
48380	35	Creosote	Non Reject	Groundline Treatment
12523	35	Penta	Non Reject	Groundline Treatment,MITC Fume
12571	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12528	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46776	40	CCA Type C	Non Reject	
51235	30	CCA Type C	Non Reject	Groundline Treatment
72350	45	CCA Type C	Non Reject	
12981	40	CCA Type C	Non Reject	Groundline Treatment
55772	35	CCA Type C	Non Reject	
61792	35	CCA Type C	Non Reject	
51278	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
25985	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46019	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53984	45	CCA Type C	Non Reject	
12506	35	CCA Type C	Non Reject	Groundline Treatment
54606	50	CCA Type C	Non Reject	
54609	50	CCA Type C	Non Reject	
54610	50	CCA Type C	Non Reject	
54612	50	CCA Type C	Non Reject	
12710	45	CCA Type C	Non Reject	
20966	35	CCA Type C	Non Reject	Groundline Treatment
20947	35	Creosote	Non Reject	Groundline Treatment
47492	40	CCA Type C	Non Reject	Groundline Treatment
25968	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
65692	35	CCA Type C	Non Reject	
20894	40	CCA Type C	Non Reject	Groundline Treatment
18713	35	Penta	Non Reject	Groundline Treatment
45492	35	Creosote	Non Reject	Sound & Bore,MITC Fume
65684	45	CCA Type C	Non Reject	Groundline Treatment
46018	30	CCA Type C	Non Reject	Groundline Treatment
58870	45	CCA Type C	Non Reject	
58493	45	CCA Type C	Non Reject	
25995	45	CCA Type C	Non Reject	Groundline Treatment
28595	30	CCA Type C	Non Reject	Groundline Treatment
12499	30		Non Reject	
48696	40	CCA Type C	Non Reject	Groundline Treatment
30066	35		Non Reject	
24822	40	CCA Type C	Non Restorable Reject	Groundline Treatment
24821	40	CCA Type C	Non Reject	Groundline Treatment
33611	40	Penta in Petroleum	Non Reject	Groundline Treatment
26003	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46007	25	CCA Type C	Non Restorable Reject	Groundline Treatment
25809	25	Penta	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
49735	40	CCA Type C	Non Reject	
49734	35	CCA Type C	Non Reject	
20641	50	CCA Type C	Non Reject	Groundline Treatment
49713	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55123	45	CCA Type C	Non Reject	
55003	35	CCA Type C	Non Reject	
30115	35	Penta	Non Reject	Groundline Treatment,MITC Fume
47383	40	CCA Type C	Non Reject	Groundline Treatment
46075	30	CCA Type C	Non Reject	Groundline Treatment
46501	35	CCA Type C	Non Reject	Groundline Treatment
49088	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25955	45	Penta	Non Reject	Groundline Treatment
51313	35	CCA Type C	Non Reject	Groundline Treatment
47763	35	CCA Type C	Non Reject	Groundline Treatment
47499	35		Non Reject	
25724	35	Creosote	Non Reject	Sound & Bore,MITC Fume
27089	30		Non Reject	
27090	30		Non Reject	
18795	40	CCA Type C	Non Reject	Groundline Treatment
59844	45	CCA Type C	Non Reject	
33004	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48703	30	CCA Type C	Non Reject	Groundline Treatment
64071	45	CCA Type C	Non Reject	
47478	35	CCA Type C	Non Reject	Groundline Treatment
25496	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
20833	35	Penta	Non Reject	Groundline Treatment,MITC Fume
46012	25	Creosote	Non Restorable Reject	Rejected
52815	45	CCA Type C	Non Reject	
25739	30	CCA Type C	Non Reject	Groundline Treatment
56793	35	CCA Type C	Non Reject	
64436	45	CCA Type C	Non Reject	
23372	35	CCA Type C	Non Reject	Groundline Treatment
59088	40	CCA Type C	Non Reject	Groundline Treatment
52816	45	CCA Type C	Non Reject	
59810	45	CCA Type C	Non Reject	
48860	40		Non Reject	
57428	35	CCA Type C	Non Reject	
65796	35	CCA Type C	Non Reject	
45406	45	CCA Type C	Non Reject	
30146	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30148	35	CCA Type C	Non Reject	
18695	40	CCA Type C	Non Reject	Groundline Treatment
18865	35	CCA Type C	Non Reject	Groundline Treatment
67719	50	CCA Type C	Non Reject	
72322	45	CCA Type C	Non Reject	
26012	45	CCA Type C	Non Reject	Groundline Treatment
49202	40	CCA Type C	Non Reject	Groundline Treatment
50890	35	CCA Type C	Non Reject	Groundline Treatment
18840	35	CCA Type C	Non Reject	Groundline Treatment
46364	35	Creosote	Non Reject	Groundline Treatment
29896	30	CCA Type C	Non Reject	Groundline Treatment
45596	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48580	35		Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
48980	50	CCA Type C	Non Reject	
67894	35	CCA Type C	Non Reject	
12673	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51303	40	CCA Type C	Non Reject	
29906	35	Creosote	Non Reject	Groundline Treatment
12425	45	CCA Type C	Non Reject	Groundline Treatment
12426	35	CCA Type C	Non Reject	Groundline Treatment
45549	35	Untreated	Non Reject	
50117	35	CCA Type C	Non Reject	
27075	35	CCA Type C	Non Reject	
48992	50	CCA Type C	Non Reject	
55775	35	CCA Type C	Non Reject	
30121	40	CCA Type C	Non Reject	Groundline Treatment
30119	30	CCA Type C	Non Reject	Groundline Treatment
20904	35	CCA Type C	Non Reject	Groundline Treatment
20903	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
20760	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
21122	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21094	35	CCA Type C	Non Reject	Groundline Treatment
30132	40	CCA Type C	Non Reject	Groundline Treatment
30131	30	Creosote	Non Reject	Groundline Treatment
30133	35	Creosote	Non Reject	Sound & Bore,MITC Fume
20752	45	CCA Type C	Non Reject	Groundline Treatment
46488	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50013	55	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51694	45	CCA Type C	Non Reject	
59651	45	CCA Type C	Non Reject	
12398	45	CCA Type C	Non Reject	Groundline Treatment
48597	30	CCA Type C	Non Reject	Groundline Treatment
48596	35	CCA Type C	Non Reject	Groundline Treatment
12338	50	CCA Type C	Non Reject	Groundline Treatment
60917	35	CCA Type C	Non Reject	
32851	50	CCA Type C	Non Reject	Groundline Treatment
30466	40	CCA Type C	Non Reject	Groundline Treatment
45510	50	CCA Type C	Non Reject	
49092	50	CCA Type C	Non Reject	
61312	45	CCA Type C	Non Reject	
47758	40	CCA Type C	Non Reject	Groundline Treatment
50851	35	Creosote	Non Reject	Groundline Treatment
18791	35	Creosote	Non Reject	Groundline Treatment
60553	35	CCA Type C	Non Reject	
20725	40	Penta	Non Reject	Sound & Bore,MITC Fume
58985	45	CCA Type C	Non Reject	
45452	45	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
20698	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12916	35	CCA Type C	Non Reject	Groundline Treatment
23281	40	CCA Type C	Non Reject	Groundline Treatment
25979	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46088	35	CCA Type C	Non Reject	Groundline Treatment
49110	30	CCA Type C	Non Reject	Groundline Treatment
18663	50	CCA Type C	Non Reject	Groundline Treatment
50836	35	Penta in Petroleum	Non Reject	Groundline Treatment
48545	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
77320	35	CCA Type C	Non Reject	
20915	30	CCA Type C	Non Reject	Groundline Treatment
12545	30	Penta	Non Reject	Groundline Treatment
67771	35	CCA Type C	Non Reject	
12379	40	CCA Type C	Non Reject	Groundline Treatment
24879	40	CCA Type C	Non Reject	Groundline Treatment
12204	50	CCA Type C	Non Reject	Groundline Treatment
26935	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
26937	30	CCA Type C	Non Reject	Groundline Treatment
30565	30	CCA Type C	Non Reject	Groundline Treatment
18752	40	CCA Type C	Non Reject	Groundline Treatment
49147	35	CCA Type C	Non Reject	Groundline Treatment
48389	30		Non Reject	
49623	30	Creosote	Non Reject	Groundline Treatment
27201	35	CCA Type C	Non Reject	Groundline Treatment
27153	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12535	40	CCA Type C	Non Reject	Groundline Treatment
45520	35	Creosote	Non Reject	Sound & Bore,MITC Fume
51153	50	CCA Type C	Non Reject	
30474	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
61385	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27028	35	Creosote	Non Reject	Groundline Treatment
12393	30	CCA Type C	Non Reject	Groundline Treatment
12394	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27054	45	CCA Type C	Non Reject	
20765	45	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
12482	40	CCA Type C	Non Reject	Groundline Treatment
46493	40	CCA Type C	Non Reject	Groundline Treatment
60497	35	CCA Type C	Non Reject	
62742	50	CCA Type C	Non Reject	
64183	45	CCA Type C	Non Reject	
35666	35	CCA Type C	Non Reject	Groundline Treatment
27072	50	CCA Type C	Non Reject	Groundline Treatment
27073	30	CCA Type C	Non Reject	Groundline Treatment
58811	50	CCA Type C	Non Reject	
49174	40	CCA Type C	Non Reject	Groundline Treatment
49176	30	CCA Type C	Non Reject	Groundline Treatment
20878	50	CCA Type C	Non Reject	
45405	45	CCA Type C	Non Reject	
29857	45	CCA Type C	Non Reject	Groundline Treatment
49103	35	CCA Type C	Non Reject	Groundline Treatment
32735	40	CCA Type C	Non Reject	Groundline Treatment
52583	45	CCA Type C	Non Reject	
58606	35	CCA Type C	Non Reject	
12384	45	CCA Type C	Non Reject	Groundline Treatment
24837	35	CCA Type C	Non Reject	Groundline Treatment
25992	30	CCA Type C	Non Reject	Groundline Treatment
20980	30	Penta	Non Reject	Groundline Treatment
30150	35	CCA Type C	Non Reject	
49085	50		Non Reject	
49861	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47320	35		Non Reject	
51010	40	CCA Type C	Non Restorable Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47762	40	CCA Type C	Non Reject	Groundline Treatment
45563	30	CCA Type C	Non Reject	Groundline Treatment
30448	40	CCA Type C	Non Reject	Groundline Treatment
30449	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58205	50	CCA Type C	Non Reject	
18684	35	CCA Type C	Non Reject	Groundline Treatment
49129	35	CCA Type C	Non Reject	Groundline Treatment
49723	35	CCA Type C	Non Reject	Groundline Treatment
49717	30	CCA Type C	Non Reject	Groundline Treatment
26268	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25067	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64078	45	CCA Type C	Non Reject	
45500	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51244	40	CCA Type C	Non Reject	Groundline Treatment
49128	30	CCA Type C	Non Reject	Groundline Treatment
12433	25	Penta	Non Restorable Reject	Groundline Treatment
65683	35	CCA Type C	Non Reject	
49179	40	CCA Type C	Non Reject	Groundline Treatment
12323	45	CCA Type C	Non Reject	Groundline Treatment
28222	30	CCA Type C	Non Reject	Groundline Treatment
12431	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21085	30	CCA Type C	Non Reject	Groundline Treatment
23178	40	CCA Type C	Non Reject	Groundline Treatment
12375	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45525	50	CCA Type C	Non Reject	
12677	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
49631	30	CCA Type C	Non Reject	Groundline Treatment
34138	40	CCA Type C	Non Reject	Groundline Treatment
34139	35	CCA Type C	Non Reject	Groundline Treatment
12420	30	Creosote	Non Reject	Groundline Treatment
27354	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49822	40	CCA Type C	Non Reject	Groundline Treatment
48995	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70279	45	CCA Type C	Non Reject	
45460	40	CCA Type C	Non Reject	Groundline Treatment
18831	40	CCA Type C	Non Reject	Groundline Treatment
70185	50	CCA Type C	Non Reject	
20986	45	CCA Type C	Non Reject	
12519	40	CCA Type C	Non Reject	Groundline Treatment
49119	30	CCA Type C	Non Reject	Groundline Treatment
49634	40	CCA Type C	Non Reject	
12668	40	CCA Type C	Non Reject	Groundline Treatment
52472	45	CCA Type C	Non Reject	Groundline Treatment
48982	45	CCA Type C	Non Reject	
72202	50	CCA Type C	Non Reject	
72207	50	CCA Type C	Non Reject	
49829	30	CCA Type C	Non Reject	Groundline Treatment
54625	55	CCA Type C	Non Reject	
12671	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50544	50	CCA Type C	Non Reject	
20722	35	Creosote	Non Reject	Rejected
54567	55	CCA Type C	Non Reject	
72201	50	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
20661	40	CCA Type C	Non Reject	Groundline Treatment
64029	45	CCA Type C	Non Reject	
31444	30	CCA Type C	Non Reject	Groundline Treatment
33610	40	Penta in Petroleum	Non Reject	Sound & Bore,MITC Fume
55163	50	CCA Type C	Non Reject	
29468	40	Creosote	Non Reject	Groundline Treatment
79459	45	CCA Type C	Non Reject	
53834	35	CCA Type C	Non Reject	
58420	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46374	35	Penta	Non Reject	Groundline Treatment,MITC Fume
45512	50	CCA Type C	Non Reject	
12317	35	CCA Type C	Non Reject	Groundline Treatment
20525	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48091	40	CCA Type C	Non Reject	Groundline Treatment
26746	30	CCA Type C	Non Reject	
18799	40	CCA Type C	Non Reject	Groundline Treatment
20974	35	Penta	Non Reject	Sound & Bore,MITC Fume
26979	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20647	50	CCA Type C	Non Reject	Groundline Treatment
59722	50	CCA Type C	Non Reject	
62765	50	CCA Type C	Non Reject	
72806	45		Non Reject	
12423	45	CCA Type C	Non Reject	Groundline Treatment
48429	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59752	60	CCA Type C	Non Reject	
54137	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
18876	45	CCA Type C	Non Reject	Groundline Treatment
57764	45	CCA Type C	Non Reject	
58348	30	CCA Type C	Non Reject	Groundline Treatment
19097	40	CCA Type C	Non Reject	Groundline Treatment
51223	30	CCA Type C	Non Reject	Groundline Treatment
65761	45	CCA Type C	Non Reject	
49485	40	CCA Type C	Non Reject	Groundline Treatment
19132	35	Penta	Non Reject	Groundline Treatment
58581	45	CCA Type C	Non Reject	
49228	30	CCA Type C	Non Reject	Groundline Treatment
19004	40	CCA Type C	Non Reject	Groundline Treatment
49510	30	CCA Type C	Non Reject	Groundline Treatment
25216	40	CCA Type C	Non Reject	Groundline Treatment
18906	45	CCA Type C	Non Reject	Groundline Treatment
18456	50	Penta	Non Reject	Groundline Treatment
18386	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
31662	40	CCA Type C	Non Reject	Groundline Treatment
34664	40	CCA Type C	Non Reject	Groundline Treatment
53107	40	CCA Type C	Non Reject	
51201	30	CCA Type C	Non Reject	Groundline Treatment
13043	40	Penta	Non Restorable Reject	Groundline Treatment
76730	45	CCA Type C	Non Reject	
76636	45	CCA Type C	Non Reject	
57634	45	CCA Type C	Non Reject	
19108	35	Penta	Non Reject	Groundline Treatment
46613	50	CCA Type C	Non Reject	
54541	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
57612	45	CCA Type C	Non Reject	
49259	35	CCA Type C	Non Reject	Groundline Treatment
18989	45	CCA Type C	Non Reject	
13213	40	Creosote	Non Reject	Sound & Bore,MITC Fume
48177	40	CCA Type C	Non Reject	Groundline Treatment
64418	50	CCA Type C	Non Reject	
49431	40	Creosote	Non Reject	Groundline Treatment
52919	45	CCA Type C	Non Reject	
UNK	35		Non Reject	
45268	35	CCA Type C	Non Reject	Groundline Treatment
35003	40	CCA Type C	Non Reject	
18997	40	CCA Type C	Non Reject	Groundline Treatment
55845	45	CCA Type C	Non Reject	
55850	45	CCA Type C	Non Reject	
18988	40	CCA Type C	Non Reject	Groundline Treatment
49508	40	CCA Type C	Non Reject	
27305	40	CCA Type C	Non Reject	Groundline Treatment
33056	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55052	45	CCA Type C	Non Reject	
49214	40	Penta	Non Restorable Reject	Groundline Treatment
47509	45	CCA Type C	Non Reject	Groundline Treatment
47516	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47506	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54449	50	CCA Type C	Non Reject	
19006	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18642	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70200	35	CCA Type C	Non Reject	
70187	35	CCA Type C	Non Reject	
54685	50	CCA Type C	Non Reject	
49232	35	CCA Type C	Non Reject	Groundline Treatment
49505	40	CCA Type C	Non Reject	Groundline Treatment
22579	45	CCA Type C	Non Reject	Groundline Treatment
49709	35	CCA Type C	Non Reject	Groundline Treatment
49435	35	Creosote	Non Reject	Groundline Treatment
46644	45	CCA Type C	Non Reject	Groundline Treatment
47138	50	CCA Type C	Non Reject	
48932	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
76645	35	CCA Type C	Non Reject	
59826	45	CCA Type C	Non Reject	
19051	40	CCA Type C	Non Reject	
49216	35	Creosote	Non Reject	Groundline Treatment
19057	40	CCA Type C	Non Reject	
49785	30	CCA Type C	Non Reject	
49784	35	CCA Type C	Non Reject	Groundline Treatment
49236	40	CCA Type C	Non Reject	Groundline Treatment
50812	35	Penta	Non Reject	Groundline Treatment
50810	45	CCA Type C	Non Reject	Groundline Treatment
54222	45	CCA Type C	Non Reject	
49293	35	Creosote	Non Reject	Groundline Treatment
59740	45	CCA Type C	Non Reject	
9017	50	CCA Type C	Non Reject	
67682	45	CCA Type C	Non Reject	
49289	45	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
20453	50	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
20454	50	CCA Type C	Non Reject	Groundline Treatment
50817	30	CCA Type C	Non Reject	Groundline Treatment
62782	35	CCA Type C	Non Reject	
34173	45	CCA Type C	Non Reject	Groundline Treatment
49247	35	CCA Type C	Non Reject	Groundline Treatment
76696	45	CCA Type C	Non Reject	
54684	50	CCA Type C	Non Reject	
49448	30	CCA Type C	Non Reject	Groundline Treatment
49450	35	Penta	Non Reject	Groundline Treatment
26671	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72325	45	CCA Type C	Non Reject	
49703	40	Penta	Non Reject	Groundline Treatment
49494	40	Penta in Petroleum	Non Reject	Groundline Treatment
22578	35	CCA Type C	Non Reject	
34720	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54443	55	CCA Type C	Non Reject	
54543	35	CCA Type C	Non Reject	
58023	35	CCA Type C	Non Reject	
70033	35	CCA Type C	Non Reject	
36347	45	CCA Type C	Non Reject	
45135	25	CCA Type C	Non Reject	Groundline Treatment
45101	25	CCA Type C	Non Reject	Groundline Treatment
25807	30	CCA Type C	Non Reject	
58883	35	CCA Type C	Non Reject	
45087	30	CCA Type C	Non Reject	Groundline Treatment
57450	50	CCA Type C	Non Reject	
23082	50	CCA Type C	Non Reject	Groundline Treatment
23037	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
67709	30	CCA Type C	Non Reject	
17058	40	Creosote	Non Reject	Sound & Bore,MITC Fume
24238	45	CCA Type C	Non Reject	
24237	35	CCA Type C	Non Reject	Groundline Treatment
45604	35	CCA Type C	Non Reject	
45072	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45867	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45865	30	CCA Type C	Non Reject	Groundline Treatment
52391	45	CCA Type C	Non Reject	
45990	40	Creosote	Non Reject	Sound & Bore,MITC Fume
53402	45	CCA Type C	Non Reject	
28517	30	CCA Type C	Non Reject	Groundline Treatment
25873	35	Penta	Non Reject	Groundline Treatment
67687	35	CCA Type C	Non Reject	
69867	50	CCA Type C	Non Reject	
45908	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25667	35	Penta	Non Reject	Groundline Treatment,MITC Fume
61576	45	CCA Type C	Non Reject	
34322	35	CCA Type C	Non Reject	
24324	40	CCA Type C	Non Reject	Groundline Treatment
24327	40	CCA Type C	Non Reject	Groundline Treatment
57679	30	CCA Type C	Non Reject	
45156	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28746	40	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28754	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
71224	35	CCA Type C	Non Reject	
45840	35	CCA Type C	Non Reject	
57449	35	CCA Type C	Non Reject	
57414	50	CCA Type C	Non Reject	
29638	45	CCA Type C	Non Reject	Groundline Treatment
29547	30	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
45948	60	CCA Type C	Non Reject	Groundline Treatment
67795	35	CCA Type C	Non Reject	
67796	45	CCA Type C	Non Reject	
72611	45	CCA Type C	Non Reject	
46912	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28724	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45801	50	CCA Type C	Non Reject	Groundline Treatment
23408	35	Creosote	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
45777	35	CCA Type C	Non Reject	Groundline Treatment
45807	35	CCA Type C	Non Reject	Groundline Treatment
31738	35	CCA Type C	Non Reject	Groundline Treatment
47660	30	CCA Type C	Non Reject	Groundline Treatment
45883	45	CCA Type C	Non Reject	
45854	50	CCA Type C	Non Reject	Groundline Treatment
45661	30		Non Reject	
64837	35	CCA Type C	Non Reject	
28876	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23278	50	CCA Type C	Non Reject	
10242	50	CCA Type C	Non Reject	Groundline Treatment
23384	50	CCA Type C	Non Reject	Groundline Treatment
60853	45	CCA Type C	Non Reject	
29398	30	CCA Type C	Non Reject	Groundline Treatment
67667	35	CCA Type C	Non Reject	
46970	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52924	45	CCA Type C	Non Reject	
29639	40	CCA Type C	Non Reject	Groundline Treatment
22328	40	CCA Type C	Non Reject	Groundline Treatment
27380	35	CCA Type C	Non Reject	Groundline Treatment
28695	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
10343	40	Penta	Non Reject	Groundline Treatment
56866	45	CCA Type C	Non Reject	
59138	35	CCA Type C	Non Reject	
29426	30	CCA Type C	Non Reject	Groundline Treatment
10386	45	CCA Type C	Non Reject	Groundline Treatment
45158	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58623	45	CCA Type C	Non Reject	
25754	35	CCA Type C	Non Reject	Groundline Treatment
52381	35	CCA Type C	Non Reject	
24354	45	CCA Type C	Non Reject	Groundline Treatment
29476	35	CCA Type C	Non Reject	
10238	50	CCA Type C	Non Reject	Groundline Treatment
23850	55	CCA Type C	Non Reject	
55558	50	CCA Type C	Non Reject	
45601	50	CCA Type C	Non Reject	
25882	30	CCA Type C	Non Reject	
10255	50	Creosote	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28850	40	Penta	Non Reject	Groundline Treatment
72354	50	CCA Type C	Non Reject	
28834	40	Penta	Non Reject	Sound & Bore,MITC Fume
28839	40	Penta	Non Reject	Groundline Treatment
52840	35	CCA Type C	Non Reject	
24403	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
30268	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
18136	40	Penta	Non Reject	Sound & Bore,MITC Fume
29608	40	CCA Type C	Non Reject	Groundline Treatment
17195	40	Penta	Non Reject	Sound & Bore,MITC Fume
62752	35	CCA Type C	Non Reject	
64064	45	CCA Type C	Non Reject	
24410	40	CCA Type C	Non Reject	Groundline Treatment
61368	35	CCA Type C	Non Reject	
24253	25	Penta	Non Restorable Reject	Groundline Treatment
24977	45	CCA Type C	Non Reject	
45974	30	Creosote	Non Reject	Groundline Treatment
45975	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
54455	35	CCA Type C	Non Reject	
31739	35	CCA Type C	Non Reject	Groundline Treatment
17213	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25673	30	Creosote	Non Reject	Groundline Treatment
22309	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47614	30	CCA Type C	Non Reject	Groundline Treatment
23056	50	CCA Type C	Non Reject	
46271	30	CCA Type C	Non Reject	Groundline Treatment
24267	40	Creosote	Non Reject	Groundline Treatment
57431	45	CCA Type C	Non Reject	
29627	50	CCA Type C	Non Reject	Groundline Treatment
10247	50	Creosote	Non Reject	Rejected
47629	60	CCA Type C	Non Reject	Groundline Treatment
62745	35	CCA Type C	Non Reject	Groundline Treatment
33932	35	CCA Type C	Non Reject	Groundline Treatment
76649	35	CCA Type C	Non Reject	
25856	35	Creosote	Non Reject	Sound & Bore,MITC Fume
24364	45	CCA Type C	Non Reject	Groundline Treatment
24367	35	CCA Type C	Non Reject	
45130	25	Penta	Priority Non Restorable Reject	Rejected
45128	20	CCA Type C	Non Reject	Groundline Treatment
45129	25	Penta	Non Restorable Reject	Rejected
30248	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45125	25	Penta	Non Restorable Reject	Rejected
45850	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52536	50	CCA Type C	Non Reject	
10345	35	Penta	Non Reject	Sound & Bore,MITC Fume
24907	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
70254	35	CCA Type C	Non Reject	
29728	35	CCA Type C	Non Reject	Groundline Treatment
22344	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72211	35	CCA Type C	Non Reject	
27435	30	CCA Type C	Non Reject	Groundline Treatment
27434	35	CCA Type C	Non Reject	Groundline Treatment
25768	30	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
25767	35	CCA Type C	Non Reject	Groundline Treatment
25861	35	CCA Type C	Non Reject	Groundline Treatment
36071	35	CCA Type C	Non Reject	
45837	50	CCA Type C	Non Reject	
45848	30	CCA Type C	Non Reject	Groundline Treatment
45836	35	CCA Type C	Non Reject	
24422	30	CCA Type C	Non Reject	Groundline Treatment
23894	50	CCA Type C	Non Reject	Groundline Treatment
45976	25	Penta	Non Restorable Reject	Groundline Treatment
32053	30	CCA Type C	Non Reject	Groundline Treatment
45985	35	CCA Type C	Non Reject	Groundline Treatment
45055	50	CCA Type C	Non Reject	Groundline Treatment
70176	35	CCA Type C	Non Reject	
46553	30	CCA Type C	Non Reject	Groundline Treatment
10243	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
68146	35	CCA Type C	Non Reject	
28798	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
28796	30	CCA Type C	Non Reject	
25033	25	Penta	Non Restorable Reject	Groundline Treatment
23905	35	CCA Type C	Non Reject	Groundline Treatment
25038	30	Creosote	Non Reject	Rejected
10377	40	Penta	Non Reject	Groundline Treatment
70294	35	CCA Type C	Non Reject	
24000	45	CCA Type C	Non Reject	
24189	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23481	30		Non Reject	
23418	40	CCA Type C	Non Reject	Groundline Treatment
55413	55	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45910	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45741	30	CCA Type C	Non Reject	Groundline Treatment
45114	25	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25821	30	CCA Type C	Non Reject	Groundline Treatment
45112	30	Creosote	Non Reject	Groundline Treatment
31753	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12831	35	Penta	Non Reject	Sound & Bore,MITC Fume
17172	35	Creosote	Non Reject	Groundline Treatment
17169	35	Creosote	Non Reject	Groundline Treatment
17167	35	Creosote	Non Reject	Groundline Treatment
58562	35	CCA Type C	Non Reject	
29612	50	CCA Type C	Non Reject	Groundline Treatment
29682	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29681	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29419	25	Penta	Non Reject	Groundline Treatment
60617	35	CCA Type C	Non Reject	
68094	35	CCA Type C	Non Reject	
24337	35	Penta	Non Reject	Groundline Treatment
45812	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
77294	45	CCA Type C	Non Reject	
28562	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
76651	45	CCA Type C	Non Reject	
28730	45	CCA Type C	Non Reject	Groundline Treatment
28732	25	Penta	Non Restorable Reject	Rejected
28727	40	Creosote	Non Reject	Groundline Treatment,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
71836	50	CCA Type C	Non Reject	
28772	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28771	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
57406	50	CCA Type C	Non Reject	
24227	50	CCA Type C	Non Reject	
24226	50	CCA Type C	Non Reject	Groundline Treatment
28707	30	CCA Type C	Non Reject	Groundline Treatment
10272	50	CCA Type C	Non Reject	Groundline Treatment
22339	45	CCA Type C	Non Reject	Groundline Treatment
25791	45	CCA Type C	Non Reject	Groundline Treatment
25870	50	CCA Type C	Non Reject	Groundline Treatment
25695	30	CCA Type C	Non Reject	Groundline Treatment
55412	35	CCA Type C	Non Reject	
28537	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
33243	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55562	50	CCA Type C	Non Reject	
23617	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55216	45	CCA Type C	Non Reject	
68137	35	CCA Type C	Non Reject	
25859	25	Penta	Non Restorable Reject	Groundline Treatment
25850	30	CCA Type C	Non Reject	Groundline Treatment
28511	40	Creosote	Non Reject	Groundline Treatment
28534	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
45074	35	CCA Type C	Non Reject	
64039	45	CCA Type C	Non Reject	
23817	35	CCA Type C	Non Reject	Groundline Treatment
47733	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29583	30	Penta	Non Reject	Groundline Treatment,MITC Fume
27346	30	CCA Type C	Non Reject	Groundline Treatment
35012	35	CCA Type C	Non Reject	Groundline Treatment
46540	30	CCA Type C	Non Reject	Groundline Treatment
30784	30	CCA Type C	Non Reject	Groundline Treatment
46530	25	Penta	Non Reject	Groundline Treatment
36357	50	CCA Type C	Non Reject	
45627	35	CCA Type C	Non Reject	
70452	45	CCA Type C	Non Reject	
70037	35	CCA Type C	Non Reject	
67793	35	CCA Type C	Non Reject	
47651	30	Creosote	Non Reject	Rejected
32696	35	CCA Type C	Non Reject	Groundline Treatment
47697	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47663	60	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47667	65	CCA Type C	Non Reject	Sound & Bore,MITC Fume
62712	35	CCA Type C	Non Reject	
72151	55	CCA Type C	Non Reject	
30998	40	CCA Type C	Non Reject	Groundline Treatment
31002	30	CCA Type C	Non Reject	Groundline Treatment
52819	35	CCA Type C	Non Reject	Groundline Treatment
45794	30	CCA Type C	Non Reject	Groundline Treatment
23616	40	CCA Type C	Non Reject	Groundline Treatment
45795	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28510	50	CCA Type C	Non Reject	Groundline Treatment
28514	35	Creosote	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
34336	35	CCA Type C	Non Reject	Groundline Treatment
56872	35	CCA Type C	Non Reject	
62656	45	CCA Type C	Non Reject	
28688	30	CCA Type C	Non Reject	Groundline Treatment
24245	40	CCA Type C	Non Reject	Groundline Treatment
72153	50	CCA Type C	Non Reject	
29412	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29445	40		Non Reject	
16979	60	CCA Type C	Non Reject	Groundline Treatment
45860	50	CCA Type C	Non Reject	Groundline Treatment
28568	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64019	45	CCA Type C	Non Reject	
25709	40	CCA Type C	Non Reject	Groundline Treatment
45744	35	CCA Type C	Non Reject	Groundline Treatment
29588	50	CCA Type C	Non Reject	Groundline Treatment
57419	50	CCA Type C	Non Reject	
46538	40	Penta	Non Reject	Groundline Treatment
68031	35	CCA Type C	Non Reject	
57502	35	CCA Type C	Non Reject	
30279	35	Penta	Non Reject	Groundline Treatment
28687	45	CCA Type C	Non Reject	Groundline Treatment
28691	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
29597	40	CCA Type C	Non Reject	Groundline Treatment
24997	35	CCA Type C	Non Reject	Groundline Treatment
24998	40	CCA Type C	Non Reject	Groundline Treatment
25020	30	CCA Type C	Non Reject	Groundline Treatment
25238	45	CCA Type C	Non Reject	Groundline Treatment
23991	35	CCA Type C	Non Reject	Groundline Treatment
64056	45	CCA Type C	Non Reject	
29611	35	Penta	Non Reject	Sound & Bore,MITC Fume
29648	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29581	35	Penta	Non Reject	Groundline Treatment,MITC Fume
24921	35	Penta	Non Reject	Groundline Treatment
24379	30	CCA Type C	Non Reject	Groundline Treatment
29631	25	Penta	Non Reject	Groundline Treatment
51169	35	CCA Type C	Non Reject	
23080	50	CCA Type C	Non Reject	Groundline Treatment
45091	30	CCA Type C	Non Reject	Groundline Treatment
29619	40	CCA Type C	Non Reject	Groundline Treatment
69870	35	CCA Type C	Non Reject	
45995	30	CCA Type C	Non Reject	Groundline Treatment
25826	40	CCA Type C	Non Reject	Groundline Treatment
56821	35	CCA Type C	Non Reject	Groundline Treatment
28527	30	CCA Type C	Non Reject	Groundline Treatment
33096	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24984	50	CCA Type C	Non Reject	Groundline Treatment
25834	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25840	35	CCA Type C	Non Reject	
45991	30	Creosote	Non Reject	Groundline Treatment
23938	40	Penta	Non Reject	Groundline Treatment
50123	35	CCA Type C	Non Reject	Groundline Treatment
34699	30	CCA Type C	Non Reject	Groundline Treatment
24361	40	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
22338	30	CCA Type C	Non Reject	Groundline Treatment
64826	35	CCA Type C	Non Reject	
57404	50	CCA Type C	Non Reject	
45925	60	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45923	60	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45938	60	CCA Type C	Non Reject	Groundline Treatment
47616	30	Creosote	Non Reject	Groundline Treatment
23456	35	CCA Type C	Non Reject	Groundline Treatment
53136	35	CCA Type C	Non Reject	Groundline Treatment
29471	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25787	45	CCA Type C	Non Reject	Groundline Treatment
23074	45	Penta	Non Reject	Rejected
46267	30	CCA Type C	Non Reject	Groundline Treatment
29306	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30441	30	CCA Type C	Non Reject	Groundline Treatment
55560	50	CCA Type C	Non Reject	
48038	30	CCA Type C	Non Reject	Groundline Treatment
31409	35	CCA Type C	Non Reject	Groundline Treatment
58535	35	CCA Type C	Non Reject	
24438	40	CCA Type C	Non Reject	Groundline Treatment
27637	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64122	45	CCA Type C	Non Reject	
22311	35	Penta	Non Reject	Groundline Treatment
24982	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
12873	40	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
55556	50	CCA Type C	Non Reject	
55514	45	CCA Type C	Non Reject	
55513	45	CCA Type C	Non Reject	
46242	35	Penta	Non Reject	Groundline Treatment
70182	35	CCA Type C	Non Reject	
23872	40	CCA Type C	Non Reject	Groundline Treatment
68096	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17271	35	Penta	Non Reject	Groundline Treatment
18098	40	Penta	Non Reject	Sound & Bore,MITC Fume
61578	35	CCA Type C	Non Reject	
17257	45	CCA Type C	Non Reject	Groundline Treatment
25005	35	Penta	Non Reject	Rejected
29592	45	CCA Type C	Non Reject	Groundline Treatment
29593	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
68633	45	CCA Type C	Non Reject	
29673	30	CCA Type C	Non Reject	Groundline Treatment
32507	40	CCA Type C	Non Reject	Groundline Treatment
24317	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24319	35	Penta	Non Reject	Groundline Treatment
10306	40	Penta	Non Reject	Groundline Treatment
64003	45	CCA Type C	Non Reject	
29441	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
57159	35	CCA Type C	Non Reject	
57163	35	CCA Type C	Non Reject	
29491	30	CCA Type C	Non Reject	Groundline Treatment
29411	35	Creosote	Non Reject	Sound & Bore,MITC Fume
25864	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23587	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
64032	45	CCA Type C	Non Reject	
25407	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53151	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57113	35	CCA Type C	Non Reject	
45162	50	CCA Type C	Non Reject	
60170	60	CCA Type C	Non Reject	
62773	35	CCA Type C	Non Reject	
12228	40	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
18761	40	CCA Type C	Non Reject	Groundline Treatment
23815	45	CCA Type C	Non Reject	Groundline Treatment
20881	35	Penta	Non Reject	Rejected
20850	40	CCA Type C	Non Reject	Groundline Treatment
56097	35	CCA Type C	Non Reject	
61548	45	CCA Type C	Non Reject	
18798	45	CCA Type C	Non Reject	
18683	40	CCA Type C	Non Reject	Groundline Treatment
50906	35	CCA Type C	Non Reject	Groundline Treatment
53114	35	CCA Type C	Non Reject	
58889	35	CCA Type C	Non Reject	
59812	45	CCA Type C	Non Reject	
18714	35	CCA Type C	Non Reject	Groundline Treatment
29910	30	CCA Type C	Non Reject	Groundline Treatment
70564	35	CCA Type C	Non Reject	
33905	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45557	35	Penta	Non Reject	Rejected
20883	50	CCA Type C	Non Reject	
53203	35	CCA Type C	Non Reject	
20907	50	CCA Type C	Non Reject	
72364	50	CCA Type C	Non Reject	
20767	40	CCA Type C	Non Reject	Groundline Treatment
27033	40	CCA Type C	Non Reject	Groundline Treatment
52893	45	CCA Type C	Non Reject	
31132	50	CCA Type C	Non Reject	Groundline Treatment
77204	50	CCA Type C	Non Reject	
47195	50	CCA Type C	Non Reject	Groundline Treatment
30045	50	CCA Type C	Non Reject	Groundline Treatment
54649	35	CCA Type C	Non Reject	
54624	50	CCA Type C	Non Reject	
49471	40	CCA Type C	Non Reject	Groundline Treatment
12250	45	CCA Type C	Non Reject	
58879	35	CCA Type C	Non Reject	
48605	45	CCA Type C	Non Reject	
64581	45	CCA Type C	Non Reject	
12223	50	CCA Type C	Non Reject	
46089	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46685	45		Non Reject	
18809	40	CCA Type C	Non Reject	
18361	50	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
18689	40	CCA Type C	Non Reject	Groundline Treatment
18690	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
31447	35	CCA Type C	Non Reject	Groundline Treatment
48694	45	CCA Type C	Non Reject	Groundline Treatment
48680	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
50484	35	CCA Type C	Non Reject	
54173	35	CCA Type C	Non Reject	
48583	35	CCA Type C	Non Reject	Groundline Treatment
58986	45	CCA Type C	Non Reject	
30112	30	CCA Type C	Non Reject	Groundline Treatment
49855	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49853	35	CCA Type C	Non Reject	Groundline Treatment
33024	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20924	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45455	30	CCA Type C	Non Reject	Groundline Treatment
30161	50	CCA Type C	Non Reject	
50841	40	Penta	Non Reject	Groundline Treatment
57192	50	CCA Type C	Non Reject	
58210	50	CCA Type C	Non Reject	
72042	45	CCA Type C	Non Reject	
61800	45	CCA Type C	Non Reject	
12575	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49866	30	CCA Type C	Non Reject	Groundline Treatment
21189	40	CCA Type C	Non Reject	Groundline Treatment
49867	30	CCA Type C	Non Reject	Groundline Treatment
24848	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46662	45	CCA Type C	Non Reject	
12573	40	CCA Type C	Non Reject	Groundline Treatment
26964	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12570	35	Creosote	Non Reject	Groundline Treatment
58731	50	CCA Type C	Non Reject	
58732	50	CCA Type C	Non Reject	
12246	30	Creosote	Non Reject	Sound & Bore,MITC Fume
54600	55	CCA Type C	Non Reject	
45489	40	Penta	Non Reject	Sound & Bore,MITC Fume
54607	50	CCA Type C	Non Reject	
70255	50	CCA Type C	Non Reject	
64533	50	CCA Type C	Non Reject	
48985	50	CCA Type C	Non Reject	Groundline Treatment
12231	40	Penta	Restorable Reject	Sound & Bore,MITC Fume
55774	35	CCA Type C	Non Reject	
30099	35	Creosote	Non Reject	Groundline Treatment
27039	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
48991	50	CCA Type C	Non Reject	
18915	40	CCA Type C	Non Reject	Groundline Treatment
23385	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24546	40		Non Reject	
50911	35	Creosote	Non Reject	Groundline Treatment
21118	40	CCA Type C	Non Reject	
50846	35	Creosote	Non Reject	Groundline Treatment
47382	40	CCA Type C	Non Reject	Groundline Treatment
18845	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12196	60	Creosote	Non Reject	Groundline Treatment,MITC Fume
51310	35	CCA Type C	Non Reject	Groundline Treatment
17881	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
30124	50	CCA Type C	Non Reject	
12201	50	CCA Type C	Non Reject	Groundline Treatment
33074	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
65797	35	CCA Type C	Non Reject	
27088	35	CCA Type C	Non Reject	Groundline Treatment
27091	30		Non Reject	
61378	35	CCA Type C	Non Reject	
50488	35	CCA Type C	Non Reject	
56091	35	CCA Type C	Non Reject	
53202	35	CCA Type C	Non Reject	
51033	40	CCA Type C	Non Reject	Groundline Treatment
24543	40	CCA Type C	Non Reject	Groundline Treatment
64748	50	CCA Type C	Non Reject	
32719	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64083	45	CCA Type C	Non Reject	
59816	45	CCA Type C	Non Reject	
45448	40	CCA Type C	Non Reject	Groundline Treatment
55426	50	CCA Type C	Non Reject	
49462	35	CCA Type C	Non Reject	Groundline Treatment
12247	35	Creosote	Non Reject	
48600	35	CCA Type C	Non Reject	Groundline Treatment
55422	60	CCA Type C	Non Reject	
12230	40	Penta	Non Reject	Sound & Bore,MITC Fume
60994	35	CCA Type C	Non Reject	
72319	50	CCA Type C	Non Reject	
26456	30	CCA Type C	Non Reject	Groundline Treatment
45411	45	CCA Type C	Non Reject	Groundline Treatment
29893	40	CCA Type C	Non Reject	Groundline Treatment
30914	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49814	50	CCA Type C	Non Reject	
49815	35	CCA Type C	Non Reject	
57731	50	CCA Type C	Non Reject	
31466	40	CCA Type C	Non Reject	Groundline Treatment
50197	35	CCA Type C	Non Reject	
61574	45	CCA Type C	Non Reject	
46106	40	Creosote	Non Reject	Groundline Treatment,Hollow Heart
24725	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
45289	30	CCA Type C	Non Reject	Groundline Treatment
27060	30	CCA Type C	Non Reject	Groundline Treatment
20761	45	CCA Type C	Non Reject	Groundline Treatment
27061	45	Penta	Non Reject	Groundline Treatment,MITC Fume
21123	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49806	35	CCA Type C	Non Reject	Groundline Treatment
30134	30	CCA Type C	Non Reject	Groundline Treatment
72388	50	CCA Type C	Non Reject	
72387	50	CCA Type C	Non Reject	
25266	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
21116	40	CCA Type C	Non Reject	
46091	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
26016	30		Non Reject	
49461	40	CCA Type C	Non Reject	Groundline Treatment
12216	50	CCA Type C	Non Reject	
48027	50	CCA Type C	Non Reject	
32307	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20887	30	CCA Type C	Non Reject	Groundline Treatment
50913	35	Creosote	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46069	30		Non Reject	
18871	45	CCA Type C	Non Reject	Groundline Treatment
61314	45	CCA Type C	Non Reject	
64077	45	CCA Type C	Non Reject	
12234	40	Penta	Non Reject	Rejected
55965	35	CCA Type C	Non Reject	
12542	30	Creosote	Non Reject	Groundline Treatment
30057	35	CCA Type C	Non Reject	Groundline Treatment
50159	35	CCA Type C	Non Reject	
50004	45	CCA Type C	Non Reject	
49475	40	CCA Type C	Non Reject	Groundline Treatment
45444	40	CCA Type C	Non Reject	Groundline Treatment
55777	35	CCA Type C	Non Reject	
12241	40	Creosote	Non Reject	Sound & Bore,MITC Fume
45402	35	Penta	Non Reject	Groundline Treatment
30105	30	CCA Type C	Non Reject	Groundline Treatment
30126	40	CCA Type C	Non Reject	Groundline Treatment
57112	45	CCA Type C	Non Reject	
51002	45	CCA Type C	Non Reject	
18823	35	Penta	Non Restorable Reject	Groundline Treatment
59204	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30108	40	CCA Type C	Non Reject	Groundline Treatment
48082	45	CCA Type C	Non Reject	Groundline Treatment
30475	35	Penta	Non Reject	Groundline Treatment
54474	45	CCA Type C	Non Reject	
25068	40	CCA Type C	Non Reject	Groundline Treatment
30163	50	CCA Type C	Non Reject	
48283	30	Creosote	Non Reject	Groundline Treatment
67777	35	CCA Type C	Non Reject	
18785	40	CCA Type C	Non Reject	Groundline Treatment
29858	45	CCA Type C	Non Reject	
20885	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
68131	45	CCA Type C	Non Reject	
45544	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55866	45	CCA Type C	Non Reject	
49858	35	CCA Type C	Non Restorable Reject	Groundline Treatment
30088	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
45536	35	CCA Type C	Non Reject	
50207	40	CCA Type C	Non Reject	Groundline Treatment
51024	40	CCA Type C	Non Reject	Groundline Treatment
34718	40	CCA Type C	Non Reject	Groundline Treatment
34717	45	CCA Type C	Non Reject	Groundline Treatment
31465	30	CCA Type C	Non Reject	Groundline Treatment
26278	40	CCA Type C	Non Reject	Groundline Treatment
68184	45	CCA Type C	Non Reject	
30078	50	CCA Type C	Non Reject	Groundline Treatment
28479	50	CCA Type C	Non Reject	Groundline Treatment
30164	35	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
21138	35	CCA Type C	Non Reject	Groundline Treatment
49862	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
18860	40	CCA Type C	Non Reject	Groundline Treatment
70276	35	CCA Type C	Non Reject	
65688	35	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
58206	50	CCA Type C	Non Reject	
68132	45	CCA Type C	Non Reject	
58733	50	CCA Type C	Non Reject	
27093	30	CCA Type C	Non Reject	Groundline Treatment
18293	45	CCA Type C	Non Reject	
18247	35	CCA Type C	Non Reject	Groundline Treatment
18832	40	CCA Type C	Non Reject	Groundline Treatment
18833	40	CCA Type C	Non Reject	Groundline Treatment
50907	35	Creosote	Non Reject	Groundline Treatment
72252	45	CCA Type C	Non Reject	
18792	35	CCA Type C	Non Reject	Groundline Treatment
49200	35	Creosote	Non Reject	Groundline Treatment
18768	35	CCA Type C	Non Reject	Groundline Treatment
45907	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
53917	45	CCA Type C	Non Reject	
64411	50	CCA Type C	Non Reject	
61398	35	CCA Type C	Non Reject	
30091	35	Penta	Non Reject	Groundline Treatment
45514	50	CCA Type C	Non Reject	
31127	30	Untreated	Non Reject	
49849	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49848	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46963	50	CCA Type C	Non Reject	Groundline Treatment
71810	45	CCA Type C	Non Reject	
18248	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
30140	30	CCA Type C	Non Reject	Groundline Treatment
27200	35	CCA Type C	Non Reject	Groundline Treatment
57140	50	CCA Type C	Non Reject	
45098	30	CCA Type C	Non Reject	Groundline Treatment
46002	30	CCA Type C	Non Reject	Groundline Treatment
49502	40	CCA Type C	Non Reject	Groundline Treatment
12283	45	CCA Type C	Non Reject	Groundline Treatment
76727	45	CCA Type C	Non Reject	
58447	35	CCA Type C	Non Reject	
35075	40	CCA Type C	Non Reject	
60787	45	CCA Type C	Non Reject	
46353	30	CCA Type C	Non Reject	Groundline Treatment
23193	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
50828	35	Creosote	Non Reject	Groundline Treatment
18959	40	CCA Type C	Non Reject	Groundline Treatment
60912	45	CCA Type C	Non Reject	
61318	45	CCA Type C	Non Reject	
64600	35	CCA Type C	Non Reject	
12628	20		Non Reject	
12648	40	CCA Type C	Non Reject	Groundline Treatment
56910	45	CCA Type C	Non Reject	
19099	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
24819	40	CCA Type C	Non Reject	Groundline Treatment
49167	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18551	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
55838	35	CCA Type C	Non Reject	
12271	45	CCA Type C	Non Reject	Groundline Treatment
50119	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
47210	30	CCA Type C	Non Reject	Groundline Treatment
21376	45	CCA Type C	Non Reject	Groundline Treatment
48485	40	CCA Type C	Non Reject	Groundline Treatment
50158	45	CCA Type C	Non Reject	
34327	35	CCA Type C	Non Reject	Groundline Treatment
51234	30	CCA Type C	Non Reject	Groundline Treatment
25966	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12270	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
34985	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46029	30	CCA Type C	Non Reject	Groundline Treatment
23319	40	CCA Type C	Non Reject	Groundline Treatment
18540	50	CCA Type C	Non Reject	
18976	35	CCA Type C	Non Reject	Groundline Treatment
57657	45	CCA Type C	Non Reject	
52457	30	CCA Type C	Non Reject	Groundline Treatment
20470	40	Creosote	Non Reject	Groundline Treatment
49257	40	CCA Type C	Non Reject	
61390	35	CCA Type C	Non Reject	
58585	45	CCA Type C	Non Reject	
59721	50	CCA Type C	Non Reject	
54398	50	CCA Type C	Non Reject	
27405	30	CCA Type C	Non Reject	Groundline Treatment
67772	35	CCA Type C	Non Reject	
18446	35	Creosote	Non Reject	Groundline Treatment
72870	45	CCA Type C	Non Reject	
18381	50	Creosote	Non Reject	Sound & Bore,MITC Fume
52475	50	CCA Type C	Non Reject	
76723	35	CCA Type C	Non Reject	
48426	50	Untreated	Non Reject	
65616	50	CCA Type C	Non Reject	
60980	45	CCA Type C	Non Reject	
18533	50	CCA Type C	Non Reject	Groundline Treatment
49132	30	CCA Type C	Non Reject	Groundline Treatment
34697	40	CCA Type C	Non Reject	
49122	30	CCA Type C	Non Reject	Groundline Treatment
49621	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49183	40	CCA Type C	Non Reject	Groundline Treatment
12337	50	CCA Type C	Non Reject	Groundline Treatment
49726	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49145	30	CCA Type C	Non Reject	Groundline Treatment
76791	35		Non Reject	
72838	45	CCA Type C	Non Reject	
47597	50	CCA Type C	Non Reject	Groundline Treatment
29264	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46604	35	CCA Type C	Non Reject	Groundline Treatment
12993	40	CCA Type C	Non Reject	Groundline Treatment
51227	30	Creosote	Non Reject	Rejected
72842	45	CCA Type C	Non Reject	
70512	45	CCA Type C	Non Reject	
59700	60	CCA Type C	Non Reject	
12438	45	CCA Type C	Non Reject	Groundline Treatment
49440	25	Penta	Non Reject	Groundline Treatment
33065	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
46785	40	CCA Type C	Non Reject	
72843	45	CCA Type C	Non Reject	
72830	45	CCA Type C	Non Reject	
12934	30	CCA Type C	Non Reject	Groundline Treatment
48108	40	CCA Type C	Non Reject	Groundline Treatment
51263	30	CCA Type C	Non Reject	Groundline Treatment
58070	45	CCA Type C	Non Reject	
51266	30	CCA Type C	Non Reject	
49992	35	Penta	Non Reject	Groundline Treatment
13214	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51250	35	Penta	Non Restorable Reject	Groundline Treatment
12953	40	CCA Type C	Non Reject	
51259	30	CCA Type C	Non Reject	Groundline Treatment
51260	30	CCA Type C	Non Reject	Groundline Treatment
51257	30	CCA Type C	Non Reject	Groundline Treatment
24847	40	CCA Type C	Non Reject	Groundline Treatment
79430	35	CCA Type C	Non Reject	
47266	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55836	35	CCA Type C	Non Reject	
12569	35	Penta	Non Reject	Groundline Treatment
66819	45	CCA Type C	Non Reject	
79530	35	CCA Type C	Non Reject	
60425	45	CCA Type C	Non Reject	
12555	40	Creosote	Non Reject	Groundline Treatment
67763	35		Non Reject	
72836	45	CCA Type C	Non Reject	
49997	30	CCA Type C	Non Reject	Groundline Treatment
23321	40	CCA Type C	Non Reject	Groundline Treatment
20709	35	CCA Type C	Non Reject	Groundline Treatment
49628	40	CCA Type C	Non Reject	Groundline Treatment
49707	30	CCA Type C	Non Reject	Groundline Treatment
48402	45		Non Reject	
54447	50	CCA Type C	Non Reject	Groundline Treatment
60006	50	CCA Type C	Non Reject	
46677	50	CCA Type C	Non Reject	
46674	50	CCA Type C	Non Reject	
49095	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49447	40	CCA Type C	Non Reject	Groundline Treatment
12362	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12364	30	CCA Type C	Non Reject	Groundline Treatment
12363	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
61304	45	CCA Type C	Non Reject	
46489	35	CCA Type C	Non Reject	Groundline Treatment
23194	35	CCA Type C	Non Reject	Groundline Treatment
35001	40	CCA Type C	Non Reject	
49251	45	CCA Type C	Non Reject	
12642	40	CCA Type C	Non Reject	Groundline Treatment
47481	35	CCA Type C	Non Reject	Groundline Treatment
23189	30	Creosote	Non Reject	Groundline Treatment
35811	50	CCA Type C	Non Reject	Groundline Treatment
49737	30	CCA Type C	Non Reject	Groundline Treatment
20564	40	CCA Type C	Non Reject	Groundline Treatment
34932	40	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
12707	40	Penta	Non Reject	Groundline Treatment
25972	40	CCA Type C	Non Reject	Groundline Treatment
26002	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20649	35	CCA Type C	Non Reject	Groundline Treatment
20648	40	CCA Type C	Non Reject	Groundline Treatment
47321	35		Non Reject	
20567	40	CCA Type C	Non Reject	Groundline Treatment
49783	30	CCA Type C	Non Reject	Groundline Treatment
49715	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
20451	50	CCA Type C	Non Reject	Groundline Treatment
49118	30	CCA Type C	Non Reject	Groundline Treatment
51139	35	CCA Type C	Non Reject	
49720	30	CCA Type C	Non Reject	Groundline Treatment
64568	50	CCA Type C	Non Reject	
58062	50	CCA Type C	Non Reject	
20002	35	CCA Type C	Non Reject	Groundline Treatment
64841	45	CCA Type C	Non Reject	
58770	60	CCA Type C	Non Reject	
62605	35	CCA Type C	Non Reject	
62603	45	CCA Type C	Non Reject	
31114	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28588	40	CCA Type C	Non Reject	Groundline Treatment
25963	30	CCA Type C	Non Reject	Groundline Treatment
49420	40	CCA Type C	Non Reject	Groundline Treatment
35002	40	CCA Type C	Non Reject	
49298	30	CCA Type C	Non Reject	Groundline Treatment
55851	45	CCA Type C	Non Reject	
25721	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47202	30	CCA Type C	Non Reject	Groundline Treatment
47479	45	CCA Type C	Non Reject	
48919	50	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
49491	40	CCA Type C	Non Reject	Groundline Treatment
12639	50	CCA Type C	Non Reject	
12514	35	CCA Type C	Non Reject	Groundline Treatment
27047	50	CCA Type C	Non Reject	Groundline Treatment
49241	30	CCA Type C	Non Reject	Groundline Treatment
18934	40	CCA Type C	Non Reject	Groundline Treatment
24524	40	CCA Type C	Non Reject	Groundline Treatment
46495	40	CCA Type C	Non Reject	Groundline Treatment
54226	50	CCA Type C	Non Reject	
49489	40	CCA Type C	Non Reject	
33579	35	CCA Type C	Non Reject	Groundline Treatment
46017	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58358	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
48399	30	CCA Type C	Non Reject	Groundline Treatment
51283	30		Non Reject	
12347	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19081	35	Creosote	Non Restorable Reject	Groundline Treatment
76929	45	CCA Type C	Non Reject	
12461	35	Penta	Non Restorable Reject	Groundline Treatment
12409	45	CCA Type C	Non Reject	Groundline Treatment
60856	35	CCA Type C	Non Reject	
19022	35	Creosote	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
49417	30	CCA Type C	Non Reject	Groundline Treatment
12382	45	CCA Type C	Non Reject	Groundline Treatment
12408	50	CCA Type C	Non Reject	
18995	40	Penta in Petroleum	Non Reject	Groundline Treatment
65685	35	CCA Type C	Non Reject	
49093	50	CCA Type C	Non Reject	
12292	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46039	30	CCA Type C	Non Reject	Groundline Treatment
69919	45	CCA Type C	Non Reject	
12515	40	CCA Type C	Non Reject	Groundline Treatment
72832	45	CCA Type C	Non Reject	
18646	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47339	35	CCA Type C	Non Reject	Groundline Treatment
49711	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49436	35	Creosote	Non Reject	Groundline Treatment
18440	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49497	45	CCA Type C	Non Reject	
32850	50	CCA Type C	Non Reject	Groundline Treatment
47549	45	CCA Type C	Non Reject	Groundline Treatment
46638	45	CCA Type C	Non Reject	Groundline Treatment
22573	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
22574	45	CCA Type C	Non Reject	Groundline Treatment
12422	45	CCA Type C	Non Reject	Groundline Treatment
57629	45	CCA Type C	Non Reject	
72794	25	Penta	Non Restorable Reject	Groundline Treatment
26010	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
18399	45	Untreated	Non Reject	
76643	35	CCA Type C	Non Reject	
49113	30	CCA Type C	Non Reject	Groundline Treatment
27043	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49218	30	CCA Type C	Non Reject	Groundline Treatment
18643	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19196	40	CCA Type C	Non Reject	
49226	25	Creosote	Non Reject	Groundline Treatment
49112	40	CCA Type C	Non Reject	Groundline Treatment
49111	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18656	50	CCA Type C	Non Reject	Groundline Treatment
18917	40	CCA Type C	Non Reject	Groundline Treatment
59713	45	CCA Type C	Non Reject	
12290	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
24830	35	CCA Type C	Non Reject	Groundline Treatment
56835	45	CCA Type C	Non Reject	
54432	50	CCA Type C	Non Reject	
49235	40	CCA Type C	Non Reject	Groundline Treatment
25502	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
35397	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12378	40	CCA Type C	Non Reject	Groundline Treatment
58815	50	CCA Type C	Non Reject	
49282	40	CCA Type C	Non Reject	Groundline Treatment
49288	40	CCA Type C	Non Reject	Groundline Treatment
29815	40	CCA Type C	Non Reject	Groundline Treatment
58418	45	CCA Type C	Non Reject	
54677	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
72831	45	CCA Type C	Non Reject	
50824	30	CCA Type C	Non Reject	Groundline Treatment
50823	30	Creosote	Non Reject	Groundline Treatment
48148	30	CCA Type C	Non Reject	Sound & Bore
12372	30	CCA Type C	Non Reject	Groundline Treatment
53181	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49616	50	CCA Type C	Non Reject	Groundline Treatment
49617	50	CCA Type C	Non Reject	Groundline Treatment
12603	50	CCA Type C	Non Reject	
51267	40	CCA Type C	Non Reject	Groundline Treatment
35667	40	CCA Type C	Non Reject	Groundline Treatment
12473	45	CCA Type C	Non Reject	Groundline Treatment
12475	35	Penta	Non Reject	Groundline Treatment
55862	45	CCA Type C	Non Reject	
51030	40	CCA Type C	Non Reject	Groundline Treatment
51028	40	CCA Type C	Non Reject	Groundline Treatment
45287	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58818	50	Untreated	Non Reject	
49487	40	CCA Type C	Non Reject	
49486	35	CCA Type C	Non Reject	Groundline Treatment
49124	30	CCA Type C	Non Reject	Groundline Treatment
24771	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
33041	40	CCA Type C	Non Reject	Groundline Treatment
52465	30	CCA Type C	Non Reject	Groundline Treatment
76770	45	CCA Type C	Non Reject	
72327	45	CCA Type C	Non Reject	
72326	45	CCA Type C	Non Reject	
58540	45	CCA Type C	Non Reject	
12417	25	Penta	Non Reject	Groundline Treatment,MITC Fume
49180	35	CCA Type C	Non Reject	Groundline Treatment
46479	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12641	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
58709	60	CCA Type C	Non Reject	Groundline Treatment
58712	60	CCA Type C	Non Reject	Groundline Treatment
34980	40	CCA Type C	Non Reject	
20551	40	CCA Type C	Non Reject	Groundline Treatment
31102	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12418	30	CCA Type C	Non Reject	Groundline Treatment
62602	45	CCA Type C	Non Reject	
49633	40	CCA Type C	Non Reject	Groundline Treatment
49632	30	CCA Type C	Non Reject	Groundline Treatment
48916	50	CCA Type C	Non Reject	
55145	35	CCA Type C	Non Reject	
18653	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12640	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
27046	50	Creosote	Non Reject	Groundline Treatment,MITC Fume
72205	50	CCA Type C	Non Reject	
51248	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49729	30	CCA Type C	Non Reject	Groundline Treatment
34630	40	CCA Type C	Non Reject	
49149	30	CCA Type C	Non Reject	Groundline Treatment
77240	45	CCA Type C	Non Reject	
69991	50	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
59832	50	CCA Type C	Non Reject	
69993	55	CCA Type C	Non Reject	
28597	30	CCA Type C	Non Reject	Groundline Treatment
67715	45	CCA Type C	Non Reject	
47317	35	CCA Type C	Non Reject	Groundline Treatment
49087	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49140	40	CCA Type C	Non Reject	
33235	35	CCA Type C	Non Reject	Groundline Treatment
20657	40	CCA Type C	Non Reject	Groundline Treatment
20548	40	Penta	Non Reject	Groundline Treatment
49493	40	Penta in Petroleum	Non Reject	Groundline Treatment
12606	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46473	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
64423	60	CCA Type C	Non Reject	
54412	35	CCA Type C	Non Reject	
50479	50	CCA Type C	Non Reject	
12265	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64820	35	CCA Type C	Non Reject	
18534	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
49141	30	CCA Type C	Non Reject	Groundline Treatment
20580	40	Creosote	Non Restorable Reject	Groundline Treatment
69917	35	CCA Type C	Non Reject	
76616	50	CCA Type C	Non Reject	
0	35		Non Reject	
12884	35	Creosote	Non Reject	Rejected
24201	30	CCA Type C	Non Reject	Groundline Treatment
46554	25	Penta	Non Reject	Groundline Treatment
55406	50	CCA Type C	Non Reject	
55405	35		Non Reject	
24281	40	Penta	Non Reject	Groundline Treatment
24280	35		Non Reject	
61392	35	CCA Type C	Non Reject	
25681	40	Creosote	Non Reject	Groundline Treatment
46402	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25680	30	Creosote	Non Reject	Groundline Treatment
23403	30	Creosote	Non Reject	
24259	35	Creosote	Non Reject	Groundline Treatment
61403	50	CCA Type C	Non Reject	
23416	35	Creosote	Non Reject	Sound & Bore,MITC Fume
24885	30	CCA Type C	Non Reject	Groundline Treatment
45606	30	CCA Type C	Non Reject	Groundline Treatment
58882	35	CCA Type C	Non Reject	
23627	30	CCA Type C	Non Reject	Groundline Treatment
25666	35	CCA Type C	Non Reject	Groundline Treatment
29846	35	CCA Type C	Non Reject	Groundline Treatment
23665	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
36351	35	CCA Type C	Non Reject	
45945	30	CCA Type C	Non Reject	Groundline Treatment
47619	60	CCA Type C	Non Reject	Groundline Treatment
45942	60	CCA Type C	Non Reject	Groundline Treatment
45802	35	CCA Type C	Non Reject	Groundline Treatment
45776	30	CCA Type C	Non Reject	Sound Only
50131	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
23846	55	CCA Type C	Non Reject	
58222	35	CCA Type C	Non Reject	
45885	45	CCA Type C	Non Reject	
45767	35	CCA Type C	Non Reject	Groundline Treatment
23618	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
24257	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24256	30	CCA Type C	Non Reject	Groundline Treatment
32240	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12872	30	CCA Type C	Non Reject	Groundline Treatment
58874	35	CCA Type C	Non Reject	
24216	45	CCA Type C	Non Reject	
24212	40	CCA Type C	Non Reject	Groundline Treatment
26470	30	CCA Type C	Non Reject	Groundline Treatment
45814	30	CCA Type C	Non Reject	Groundline Treatment
72174	50	CCA Type C	Non Reject	
24897	45	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
18096	40	Penta	Non Reject	Groundline Treatment
69785	45	CCA Type C	Non Reject	
12828	35	Penta	Non Reject	Groundline Treatment
33565	35	CCA Type C	Non Reject	Groundline Treatment
12825	40	CCA Type C	Non Reject	Groundline Treatment
29709	30	CCA Type C	Non Reject	Groundline Treatment
29708	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
62746	45	CCA Type C	Non Reject	
52524	35	CCA Type C	Non Reject	
45822	45	Creosote	Non Reject	Groundline Treatment,MITC Fume
24252	30	CCA Type C	Non Reject	Groundline Treatment
24911	45	Penta	Non Reject	Groundline Treatment,MITC Fume
24915	40	CCA Type C	Non Reject	Groundline Treatment
50124	35	CCA Type C	Non Reject	Groundline Treatment
69968	30	CCA Type C	Non Reject	
70266	35	CCA Type C	Non Reject	
24387	45	Creosote	Non Reject	Rejected
64065	35	CCA Type C	Non Reject	
68100	35	CCA Type C	Non Reject	
12889	40	Creosote	Non Reject	Sound & Bore,MITC Fume
25674	30	Penta	Non Reject	Groundline Treatment
45913	60	CCA Type C	Non Reject	Groundline Treatment
24917	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
24340	50	CCA Type C	Non Reject	
29635	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29634	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72022	35	CCA Type C	Non Reject	
60614	50	CCA Type C	Non Reject	
72353	35	CCA Type C	Non Reject	
46413	50	CCA Type C	Non Reject	
57405	50	CCA Type C	Non Reject	
69798	45	CCA Type C	Non Reject	
45872	30	CCA Type C	Non Reject	Groundline Treatment
29559	40	CCA Type C	Non Reject	Groundline Treatment
48005	30	Penta	Non Restorable Reject	Groundline Treatment
48199	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45988	30	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
12895	40	CCA Type C	Non Reject	Groundline Treatment
45950	40	CCA Type C	Non Reject	Groundline Treatment
23632	30	Creosote	Non Reject	Rejected
36074	35	CCA Type C	Non Reject	
57410	50	CCA Type C	Non Reject	
24312	30	Creosote	Non Reject	Groundline Treatment
24296	35	Creosote	Non Reject	Groundline Treatment
57418	50	CCA Type C	Non Reject	
57408	50	CCA Type C	Non Reject	
25710	35	CCA Type C	Non Reject	Groundline Treatment
45999	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
55516	50	CCA Type C	Non Reject	
45902	40	CCA Type C	Non Reject	Groundline Treatment
23861	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
58875	35	CCA Type C	Non Reject	
24192	45	CCA Type C	Non Reject	
45786	50	CCA Type C	Non Reject	
45787	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23847	35		Non Reject	
45905	35	Creosote	Non Reject	Groundline Treatment
23877	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
23687	30	Creosote	Non Reject	
64093	45	CCA Type C	Non Reject	
52873	35	CCA Type C	Non Reject	
32715	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24335	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
45813	30	CCA Type C	Non Reject	Groundline Treatment
45803	25	Creosote	Non Reject	Groundline Treatment
45828	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55408	50	CCA Type C	Non Reject	
64156	40	Creosote	Priority Non Restorable Reject	Rejected
45830	35	CCA Type C	Non Reject	Groundline Treatment
10225	50	Creosote	Non Reject	Groundline Treatment
56868	35		Non Reject	
55401	60	CCA Type C	Non Reject	
55217	45	CCA Type C	Non Reject	
70443	45	CCA Type C	Non Reject	
62791	35	CCA Type C	Non Reject	
70465	35	CCA Type C	Non Reject	
47603	35	CCA Type C	Non Reject	Groundline Treatment
55404	50	CCA Type C	Non Reject	
46226	30	CCA Type C	Non Reject	Groundline Treatment
61572	35	CCA Type C	Non Reject	
12824	25	Creosote	Non Reject	
12879	30	CCA Type C	Non Reject	Groundline Treatment
62445	35	CCA Type C	Non Reject	
69795	45	CCA Type C	Non Reject	
45793	35	CCA Type C	Non Reject	
24223	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
57416	50	CCA Type C	Non Reject	
55930	45	CCA Type C	Non Reject	
55929	45	CCA Type C	Non Reject	
45827	25	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
24242	35	Creosote	Non Reject	Groundline Treatment
55554	50	CCA Type C	Non Reject	
23963	30	CCA Type C	Non Reject	Groundline Treatment
46000	35	Penta	Non Reject	Groundline Treatment
45911	60	CCA Type C	Non Reject	Groundline Treatment
24937	35		Non Reject	
23070	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25711	40	Creosote	Non Reject	Groundline Treatment
46539	40	CCA Type C	Non Reject	Groundline Treatment
46528	35	CCA Type C	Non Reject	
24314	25	Penta	Non Restorable Reject	Groundline Treatment
24315	40	CCA Type C	Non Reject	Groundline Treatment
60779	35	CCA Type C	Non Reject	
29600	35	Penta	Non Reject	Sound & Bore,MITC Fume
29596	40	CCA Type C	Non Reject	Groundline Treatment
17260	40	Penta	Non Reject	Rejected
69887	35	CCA Type C	Non Reject	
25019	30	CCA Type C	Non Reject	Groundline Treatment
25236	45	CCA Type C	Non Reject	Groundline Treatment
24424	30	CCA Type C	Non Reject	Groundline Treatment
45969	25	CCA Type C	Non Reject	Groundline Treatment
60668	35	CCA Type C	Non Reject	
48353	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29571	25	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
29580	35	Penta	Non Restorable Reject	Groundline Treatment
31654	30	CCA Type C	Non Reject	Groundline Treatment
55517	45	CCA Type C	Non Reject	
55519	35	CCA Type C	Non Reject	
34041	35	CCA Type C	Non Reject	Groundline Treatment
23883	40	CCA Type C	Non Reject	Groundline Treatment
76500	35	CCA Type C	Non Reject	
24983	35	Creosote	Non Reject	Sound & Bore,MITC Fume
17160	45	CCA Type C	Non Reject	Groundline Treatment
57415	50	CCA Type C	Non Reject	
57432	50	CCA Type C	Non Reject	
60963	35	CCA Type C	Non Reject	
24359	40	Creosote	Non Reject	Groundline Treatment
12846	30	Penta	Non Reject	Sound & Bore,MITC Fume
57734	35	CCA Type C	Non Reject	Groundline Treatment
46223	35	CCA Type C	Non Reject	
24440	30	CCA Type C	Non Reject	Groundline Treatment
24898	30	Creosote	Non Reject	Groundline Treatment
58536	35	CCA Type C	Non Reject	
24434	30	CCA Type C	Non Reject	Groundline Treatment
24247	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45623	35	CCA Type C	Non Reject	Groundline Treatment
45622	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58561	35	CCA Type C	Non Reject	
45898	30		Non Reject	
60613	35	CCA Type C	Non Reject	
55515	35	CCA Type C	Non Reject	
17183	35		Non Reject	
45998	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
45888	45	CCA Type C	Non Reject	
24264	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
68138	35	CCA Type C	Non Reject	
51996	50	CCA Type C	Non Reject	
31708	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29703	25	CCA Type C	Non Reject	Groundline Treatment
29718	35	Penta	Non Reject	Sound & Bore,MITC Fume
29594	35	CCA Type C	Non Reject	Groundline Treatment
12900	35	CCA Type C	Non Reject	Groundline Treatment
34698	35	CCA Type C	Non Reject	Groundline Treatment
45965	35	CCA Type C	Non Reject	Groundline Treatment
23598	50	Untreated	Non Reject	
24268	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
24249	35	CCA Type C	Non Reject	Groundline Treatment
45773	50	CCA Type C	Non Reject	Groundline Treatment
28592	35	CCA Type C	Non Reject	Groundline Treatment
23069	30	Creosote	Non Reject	Groundline Treatment
62756	35	CCA Type C	Non Reject	
62758	35	CCA Type C	Non Reject	
65190	45	CCA Type C	Non Reject	
25035	35	Penta	Non Reject	Rejected
26737	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28738	30	CCA Type C	Non Reject	Groundline Treatment
28737	40	CCA Type C	Non Reject	Groundline Treatment
28740	35	Penta	Non Reject	Sound & Bore,MITC Fume
29438	25	Penta	Non Restorable Reject	Rejected
64150	45	CCA Type C	Non Reject	
45121	25	Creosote	Non Reject	Groundline Treatment,MITC Fume
25808	30	CCA Type C	Non Reject	
47701	35	CCA Type C	Non Reject	Groundline Treatment
47702	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
47677	30	Penta	Non Restorable Reject	Groundline Treatment
55983	35	CCA Type C	Non Reject	
25775	30	CCA Type C	Non Reject	Groundline Treatment
25774	35	CCA Type C	Non Reject	Groundline Treatment
25777	30	CCA Type C	Non Reject	Groundline Treatment
25784	35	CCA Type C	Non Reject	Groundline Treatment
25779	40	CCA Type C	Non Reject	Groundline Treatment
25794	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25796	30	CCA Type C	Non Reject	Groundline Treatment
57453	35	CCA Type C	Non Reject	
25828	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55568	40	CCA Type C	Non Reject	
52591	35	CCA Type C	Non Reject	
62612	45	CCA Type C	Non Reject	
64034	50	CCA Type C	Non Reject	
28519	50	CCA Type C	Non Reject	Groundline Treatment
28522	30	CCA Type C	Non Reject	Groundline Treatment
47053	35	Penta	Non Reject	Sound & Bore,MITC Fume
25771	40	CCA Type C	Non Reject	Groundline Treatment
25350	35	CCA Type C	Non Reject	Groundline Treatment
25351	35	CCA Type C	Non Reject	Groundline Treatment
28803	35	Penta	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28753	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45934	60	CCA Type C	Non Reject	Groundline Treatment
70196	45	CCA Type C	Non Reject	
47632	35	Penta	Non Reject	Groundline Treatment
47633	35	Penta	Non Reject	Groundline Treatment
23794	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17420	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10280	35	Creosote	Non Reject	Groundline Treatment
67698	35	CCA Type C	Non Reject	
60008	35	CCA Type C	Non Reject	
29382	35	CCA Type C	Non Reject	Groundline Treatment
28777	50	CCA Type C	Non Reject	Groundline Treatment
52978	45	CCA Type C	Non Reject	
64838	35	CCA Type C	Non Reject	
45090	35	Penta	Non Reject	Groundline Treatment
25863	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28693	45	CCA Type C	Non Reject	Groundline Treatment
52400	35	CCA Type C	Non Reject	
46915	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17468	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47009	50	Penta	Non Reject	Groundline Treatment,MITC Fume
28582	35	CCA Type C	Non Reject	
28555	35	Penta	Non Reject	Groundline Treatment
10325	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
25757	35	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47683	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47631	60	CCA Type C	Non Reject	Groundline Treatment
45053	40	CCA Type C	Non Reject	
25761	35	Creosote	Non Reject	Groundline Treatment
23077	50	CCA Type C	Non Reject	Groundline Treatment
75667	45	CCA Type C	Non Reject	
28851	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45149	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47680	30	CCA Type C	Non Reject	Groundline Treatment
10263	35	CCA Type C	Non Reject	Groundline Treatment
47736	35	Penta	Non Reject	Sound & Bore,MITC Fume
12861	50	CCA Type C	Non Reject	Groundline Treatment
47714	30	CCA Type C	Non Reject	Groundline Treatment
29383	35	Penta	Non Reject	Sound & Bore,MITC Fume
45117	25	Creosote	Non Reject	Groundline Treatment
45119	25	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29453	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
55220	50	CCA Type C	Non Reject	
45094	30	CCA Type C	Non Reject	Groundline Treatment
25871	35	Penta	Non Reject	Groundline Treatment
47611	60	CCA Type C	Non Reject	Groundline Treatment
25848	40	CCA Type C	Non Reject	Groundline Treatment
45127	25	Creosote	Non Restorable Reject	Rejected
25801	35	CCA Type C	Non Reject	
45124	25	Penta	Non Restorable Reject	Rejected
28713	40	Penta	Non Reject	Groundline Treatment
29484	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
25425	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
34323	35	CCA Type C	Non Reject	Groundline Treatment
25795	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
25769	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
52836	35	CCA Type C	Non Reject	
17876	45		Non Reject	
30005	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
29439	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10266	50	CCA Type C	Non Reject	Groundline Treatment
68089	45	CCA Type C	Non Reject	
68147	35	CCA Type C	Non Reject	
29308	30	CCA Type C	Non Reject	Groundline Treatment
76653	35	CCA Type C	Non Reject	
60180	45	CCA Type C	Non Reject	
64756	35	CCA Type C	Non Reject	
47722	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46793	45	CCA Type C	Non Reject	
29355	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
25818	35	Creosote	Non Reject	Sound & Bore,MITC Fume
45107	25	CCA Type C	Non Reject	Groundline Treatment
64795	35	CCA Type C	Non Reject	
28782	40	CCA Type C	Non Reject	Groundline Treatment
54053	35	Creosote	Non Restorable Reject	Rejected
29415	40	Penta	Non Reject	Groundline Treatment
32721	50	CCA Type C	Non Reject	Groundline Treatment
32723	50	CCA Type C	Non Reject	Groundline Treatment
46651	50	CCA Type C	Non Reject	
29335	25	Penta	Non Reject	Groundline Treatment
46960	50	CCA Type C	Non Reject	
55707	35	CCA Type C	Non Reject	
28560	35	Creosote	Non Restorable Reject	Sound & Bore,MITC Fume
17202	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
33242	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
61413	45	CCA Type C	Non Reject	
28714	30	CCA Type C	Non Reject	Groundline Treatment
28837	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
52388	45	CCA Type C	Non Reject	
62717	35	Untreated	Non Reject	
77287	35	CCA Type C	Non Reject	
58862	35	CCA Type C	Non Reject	
10303	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72640	35	CCA Type C	Non Reject	
67794	35	CCA Type C	Non Reject	
72641	35	CCA Type C	Non Reject	
72612	35	CCA Type C	Non Reject	
72150	55	CCA Type C	Non Reject	
66772	35	CCA Type C	Non Reject	
48263	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45141	35	CCA Type C	Non Reject	Groundline Treatment
50121	45	CCA Type C	Non Reject	
25268	30	CCA Type C	Non Reject	Groundline Treatment
45152	45	CCA Type C	Non Reject	Groundline Treatment
29420	35		Non Reject	
28703	35	Creosote	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28701	50	CCA Type C	Non Reject	Groundline Treatment
47638	40	Penta	Non Reject	Groundline Treatment
57782	35	CCA Type C	Non Reject	
67776	45	CCA Type C	Non Reject	
30251	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47615	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47685	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
68091	45	CCA Type C	Non Reject	
76465	45	CCA Type C	Non Reject	
28760	35	Penta	Non Reject	Groundline Treatment
28757	40	CCA Type C	Non Reject	Groundline Treatment
28761	35	Penta	Non Reject	Sound & Bore,MITC Fume
28692	45	CCA Type C	Non Reject	Groundline Treatment
29399	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart
53159	35	CCA Type C	Non Reject	Groundline Treatment
28790	40	CCA Type C	Non Reject	Groundline Treatment
52896	35	CCA Type C	Non Reject	
52897	35	CCA Type C	Non Reject	
67714	50	CCA Type C	Non Reject	
10252	50	CCA Type C	Non Reject	Groundline Treatment
25880	35	Creosote	Non Reject	Sound & Bore,MITC Fume
25138	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45073	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47620	60	CCA Type C	Non Reject	Groundline Treatment
28763	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58891	35	CCA Type C	Non Reject	
25837	50	CCA Type C	Non Reject	Groundline Treatment
55070	35	CCA Type C	Non Reject	
25836	45	CCA Type C	Non Reject	Groundline Treatment
28546	45	Penta	Non Restorable Reject	Groundline Treatment,Hollow Heart
28715	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28717	35	Penta	Non Reject	Sound & Bore,MITC Fume
25762	30	CCA Type C	Non Reject	Groundline Treatment
22408	50		Non Reject	
28684	35	Penta	Non Reject	Groundline Treatment
64536	50	CCA Type C	Non Reject	
28531	30	CCA Type C	Non Reject	Groundline Treatment
29472	40	CCA Type C	Non Reject	Groundline Treatment
72139	50	CCA Type C	Non Reject	
72137	35	CCA Type C	Non Reject	
72146	45	CCA Type C	Non Reject	
46919	30	CCA Type C	Non Reject	Groundline Treatment
17373	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48203	30		Non Reject	
46922	30	CCA Type C	Non Reject	Groundline Treatment
33632	35	CCA Type C	Non Reject	Groundline Treatment
64412	50	CCA Type C	Non Reject	
47179	50	Untreated	Non Reject	
48287	30		Non Reject	
46886	45	CCA Type C	Non Reject	Groundline Treatment
17516	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
17212	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25877	30	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
29442	30	CCA Type C	Non Reject	Groundline Treatment
29464	35	CCA Type C	Non Reject	Groundline Treatment
29492	30	CCA Type C	Non Reject	Groundline Treatment
72142	45	CCA Type C	Non Reject	
45159	30	CCA Type C	Non Reject	
72134	50	CCA Type C	Non Reject	
29400	30	CCA Type C	Non Reject	Groundline Treatment
60177	45	CCA Type C	Non Reject	
10296	50	CCA Type C	Non Reject	Groundline Treatment
29437	35	Creosote	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
10288	45	Creosote	Non Reject	Sound & Bore,MITC Fume
55089	35	CCA Type C	Non Reject	
29544	35	Creosote	Non Reject	Groundline Treatment
10390	45	Creosote	Non Reject	Groundline Treatment,MITC Fume
45153	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart
54605	50	CCA Type C	Non Reject	
26007	30	CCA Type C	Non Reject	Groundline Treatment
12454	45	CCA Type C	Non Reject	Groundline Treatment
12411	25	Creosote	Non Reject	Groundline Treatment
50011	55	CCA Type C	Non Reject	Groundline Treatment
64036	45	CCA Type C	Non Reject	
19110	40	CCA Type C	Non Reject	Groundline Treatment
31749	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48276	30	CCA Type C	Non Reject	
20898	35	CCA Type C	Non Reject	Groundline Treatment
60788	45	CCA Type C	Non Reject	
18960	40	CCA Type C	Non Reject	Groundline Treatment
58857	50	CCA Type C	Non Reject	
62608	45	CCA Type C	Non Reject	
64599	50	CCA Type C	Non Reject	
20806	30	CCA Type C	Non Reject	Groundline Treatment
58421	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60967	45	CCA Type C	Non Reject	
19101	40	CCA Type C	Non Reject	Groundline Treatment
24820	40	CCA Type C	Non Reject	Groundline Treatment
48989	45	CCA Type C	Non Reject	
69903	45	CCA Type C	Non Reject	
52892	45	CCA Type C	Non Reject	
25042	40	CCA Type C	Non Reject	Groundline Treatment
54104	35	CCA Type C	Non Reject	
34040	35	CCA Type C	Non Reject	Groundline Treatment
12978	40	CCA Type C	Non Reject	Groundline Treatment
12387	45	CCA Type C	Non Reject	Groundline Treatment
52466	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12404	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
51301	40	CCA Type C	Non Reject	Groundline Treatment
55553	50	CCA Type C	Non Reject	
31705	30	CCA Type C	Non Reject	
31131	50	CCA Type C	Non Reject	Groundline Treatment
48428	50	Untreated	Non Reject	
58566	35	CCA Type C	Non Reject	
12867	30	CCA Type C	Non Reject	Groundline Treatment
24214	45	CCA Type C	Non Reject	

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
58407	35	CCA Type C	Non Reject	
45933	50	CCA Type C	Non Reject	Groundline Treatment
30111	45	Penta	Non Reject	Groundline Treatment
70469	35	CCA Type C	Non Reject	
64074	50	CCA Type C	Non Reject	
51242	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54310	45	CCA Type C	Non Reject	
76790	35		Non Reject	
52818	45	CCA Type C	Non Reject	
12654	30	CCA Type C	Non Reject	Groundline Treatment
55138	40	CCA Type C	Non Reject	
25730	35	Penta	Non Reject	Rejected
12912	40	CCA Type C	Non Reject	Groundline Treatment
62650	50	CCA Type C	Non Reject	
59692	60	CCA Type C	Non Reject	
59698	60	CCA Type C	Non Reject	
59753	60	CCA Type C	Non Reject	
18722	35	CCA Type C	Non Reject	Groundline Treatment
55839	45	CCA Type C	Non Reject	
34663	40	CCA Type C	Non Reject	
50155	45	CCA Type C	Non Reject	
49808	30	CCA Type C	Non Reject	Groundline Treatment
12979	40	CCA Type C	Non Reject	Groundline Treatment
49996	40	CCA Type C	Non Reject	Groundline Treatment
70161	35	CCA Type C	Non Reject	
12926	40	CCA Type C	Non Reject	Groundline Treatment
12939	40	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
12960	35	CCA Type C	Non Reject	Groundline Treatment
79466	50		Non Reject	
79529	35	CCA Type C	Non Reject	
UNK	35	CCA Type C	Non Reject	
79531	35	CCA Type C	Non Reject	
61340	35	CCA Type C	Non Reject	
58714	60	CCA Type C	Non Reject	Groundline Treatment
47362	50		Non Reject	
18569	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25983	40	CCA Type C	Non Reject	Groundline Treatment
12725	40	Penta	Non Reject	Sound & Bore,MITC Fume
54699	50	CCA Type C	Non Reject	
64453	50		Non Reject	
45899	60	CCA Type C	Non Reject	Groundline Treatment
57613	45	CCA Type C	Non Reject	
54165	35	CCA Type C	Non Reject	
20911	40	CCA Type C	Non Reject	Groundline Treatment
60659	35	CCA Type C	Non Reject	
58252	35	CCA Type C	Non Reject	Groundline Treatment
54126	35	CCA Type C	Non Reject	
12284	40	CCA Type C	Non Reject	Groundline Treatment
28237	50	CCA Type C	Non Reject	Groundline Treatment
25971	40	CCA Type C	Non Reject	Groundline Treatment
67716	35	CCA Type C	Non Reject	
20468	50	CCA Type C	Non Reject	Groundline Treatment
51138	45	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
51140	35	CCA Type C	Non Reject	
64800	35	CCA Type C	Non Reject	
18753	40	CCA Type C	Non Reject	Groundline Treatment
54442	55	CCA Type C	Non Reject	
50845	45	CCA Type C	Non Reject	Groundline Treatment
72394	35	CCA Type C	Non Reject	
65186	30	CCA Type C	Non Reject	Groundline Treatment
52914	50	CCA Type C	Non Reject	
33485	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
52984	35	CCA Type C	Non Reject	
49297	40	CCA Type C	Non Reject	Groundline Treatment
50151	45	CCA Type C	Non Reject	
18778	35	CCA Type C	Non Reject	Groundline Treatment
62792	35	CCA Type C	Non Reject	
72323	45	CCA Type C	Non Reject	
53179	25	Creosote	Non Reject	Groundline Treatment
24988	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
45497	45	CCA Type C	Non Reject	
35077	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25712	30	CCA Type C	Non Reject	Groundline Treatment
64040	45	CCA Type C	Non Reject	
58590	35	CCA Type C	Non Reject	
49468	40	CCA Type C	Non Reject	Groundline Treatment
48413	35	CCA Type C	Non Reject	
12334	35	CCA Type C	Non Reject	Groundline Treatment
25822	25	Penta	Non Restorable Reject	Rejected
60074	50	CCA Type C	Non Reject	
64749	35	CCA Type C	Non Reject	
28817	50	CCA Type C	Non Reject	Groundline Treatment
18559	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59870	50	CCA Type C	Non Reject	
55407	50	CCA Type C	Non Reject	
64754	35	CCA Type C	Non Reject	
59092	40	CCA Type C	Non Reject	Groundline Treatment
59716	45	CCA Type C	Non Reject	
72798	45	CCA Type C	Non Reject	
59815	45	CCA Type C	Non Reject	
54227	50	CCA Type C	Non Reject	
60916	35	CCA Type C	Non Reject	
45791	55	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60652	35	CCA Type C	Non Reject	
28770	30	CCA Type C	Non Reject	Groundline Treatment
29891	40	CCA Type C	Non Reject	Groundline Treatment
19009	40	Penta	Non Reject	Groundline Treatment
49428	35	Penta	Non Reject	Groundline Treatment
12190	45	Creosote	Non Reject	Groundline Treatment
18686	35	CCA Type C	Non Reject	Groundline Treatment
19007	35	CCA Type C	Non Reject	Groundline Treatment
70199	55	CCA Type C	Non Reject	
46603	35	CCA Type C	Non Reject	Groundline Treatment
29413	35	CCA Type C	Non Reject	
27058	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53163	35	Penta	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
48961	30		Non Reject	
28766	40	CCA Type C	Non Reject	Groundline Treatment
10378	40	Penta	Non Reject	Groundline Treatment
67747	40	Penta	Non Reject	Groundline Treatment
57000	45	CCA Type C	Non Reject	
10304	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
57177	50	CCA Type C	Non Reject	
54224	45	CCA Type C	Non Reject	
69793	45	CCA Type C	Non Reject	
47652	60	Penta	Non Reject	Groundline Treatment
76089	35	CCA Type C	Non Reject	
30145	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19067	35	Penta	Non Restorable Reject	Groundline Treatment,MITC Fume
54538	50	CCA Type C	Non Reject	
63348	45	CCA Type C	Non Reject	
63349	45	CCA Type C	Non Reject	
55771	35	CCA Type C	Non Reject	
27055	40	CCA Type C	Non Reject	Groundline Treatment
12543	35	Penta	Non Reject	Groundline Treatment
58323	35	CCA Type C	Non Reject	
12455	40	CCA Type C	Non Restorable Reject	Groundline Treatment
23066	50	CCA Type C	Non Reject	Groundline Treatment
24704	30	CCA Type C	Non Reject	Groundline Treatment
76869	35	CCA Type C	Non Reject	
24862	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64452	50	CCA Type C	Non Reject	
60403	35	CCA Type C	Non Reject	
56834	45	CCA Type C	Non Reject	
79478	35	CCA Type C	Non Reject	
12397	35	CCA Type C	Non Reject	
46480	35	CCA Type C	Non Reject	
12395	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54531	35	CCA Type C	Non Reject	
58814	50	CCA Type C	Non Reject	
64426	60	CCA Type C	Non Reject	
57785	35	CCA Type C	Non Reject	
59809	35	CCA Type C	Non Reject	
50150	45		Non Reject	
45401	35	CCA Type C	Non Reject	Groundline Treatment
54540	50	CCA Type C	Non Reject	
67726	50	CCA Type C	Non Reject	
67696	35	CCA Type C	Non Reject	
64792	35	CCA Type C	Non Reject	
52841	35	CCA Type C	Non Reject	
50199	45	CCA Type C	Non Reject	
28762	35	Penta	Non Reject	Groundline Treatment
29401	30	CCA Type C	Non Reject	Groundline Treatment
61557	35	CCA Type C	Non Reject	
12194	60	CCA Type C	Non Reject	
64139	45	CCA Type C	Non Reject	
49833	35	CCA Type C	Non Reject	Groundline Treatment
61194	50	CCA Type C	Non Reject	
46523	35	Creosote	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
28523	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10275	45	Penta	Non Reject	Groundline Treatment,MITC Fume
10274	50	CCA Type C	Non Reject	Groundline Treatment
26267	30	CCA Type C	Non Reject	Groundline Treatment
23814	45	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
33042	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
58223	35	CCA Type C	Non Reject	
64079	45	CCA Type C	Non Reject	
65780	45	CCA Type C	Non Reject	
12434	40	CCA Type C	Non Reject	Groundline Treatment
49127	30	CCA Type C	Non Reject	Groundline Treatment
46361	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
12391	45	CCA Type C	Non Reject	Groundline Treatment
62794	45	CCA Type C	Non Reject	
19085	40	CCA Type C	Non Reject	Groundline Treatment
61288	40	CCA Type C	Non Reject	Groundline Treatment
70181	35	CCA Type C	Non Reject	
25672	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
25039	35	Penta	Non Reject	Sound & Bore,MITC Fume
79441	35	CCA Type C	Non Reject	
55140	40	CCA Type C	Non Reject	
59843	50	CCA Type C	Non Reject	
24266	30	CCA Type C	Non Reject	Groundline Treatment
10285	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28574	30	CCA Type C	Non Reject	Groundline Treatment
70191	45	CCA Type C	Non Reject	
57680	35	CCA Type C	Non Reject	
50012	50	CCA Type C	Non Reject	
20942	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
77241	45	CCA Type C	Non Reject	
72311	50	CCA Type C	Non Reject	
69990	50	CCA Type C	Non Reject	
54570	55	CCA Type C	Non Reject	
49704	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12730	35	CCA Type C	Non Reject	Groundline Treatment
55142	40	CCA Type C	Non Reject	Groundline Treatment
45396	35	Penta	Non Reject	Groundline Treatment
29460	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
62658	35	CCA Type C	Non Reject	
71807	45	CCA Type C	Non Reject	Sound Only
54410	45	CCA Type C	Non Reject	
57199	35	CCA Type C	Non Reject	
50844	45	CCA Type C	Non Reject	Groundline Treatment
72679	50	CCA Type C	Non Reject	
61799	45	CCA Type C	Non Reject	
57717	35	CCA Type C	Non Reject	
72389	50	CCA Type C	Non Reject	
72390	50	CCA Type C	Non Reject	
10394	35		Non Reject	
27489	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
64574	45	CCA Type C	Non Reject	
60035	35	CCA Type C	Non Reject	
UNK	35		Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
50139	35	CCA Type C	Non Reject	
62675	50	CCA Type C	Non Reject	
64410	50	CCA Type C	Non Reject	
54194	35	CCA Type C	Non Reject	
56113	35	CCA Type C	Non Reject	
58080	45	CCA Type C	Non Reject	
47749	35	Penta	Non Reject	Groundline Treatment
19150	35	Penta	Non Reject	Groundline Treatment
58091	45	CCA Type C	Non Reject	
49262	40	CCA Type C	Non Reject	Groundline Treatment
47743	40	CCA Type C	Non Reject	Groundline Treatment
19045	35	Penta	Non Reject	Groundline Treatment
49215	40	CCA Type C	Non Reject	Groundline Treatment
64613	50	CCA Type C	Non Reject	
52518	45	CCA Type C	Non Reject	
52519	35	CCA Type C	Non Reject	Groundline Treatment
58076	45	CCA Type C	Non Reject	
47748	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
49272	35	CCA Type C	Non Reject	Groundline Treatment
52801	45	CCA Type C	Non Reject	
46275	35		Non Reject	
64611	50	CCA Type C	Non Reject	
77387	50	CCA Type C	Non Reject	
64615	50	CCA Type C	Non Reject	
58077	35	CCA Type C	Non Reject	
47754	40	Penta	Non Reject	
61363	45	CCA Type C	Non Reject	
54037	50	CCA Type C	Non Reject	
54038	45	CCA Type C	Non Reject	
58072	35	CCA Type C	Non Reject	
49263	30	CCA Type C	Non Reject	Groundline Treatment
46276	35		Non Reject	
46277	30		Non Reject	
59695	60	CCA Type C	Non Reject	
64620	50	CCA Type C	Non Reject	
64723	50	CCA Type C	Non Reject	
58085	45	CCA Type C	Non Reject	
58079	45	CCA Type C	Non Reject	
49266	25	Creosote	Non Reject	Groundline Treatment
58089	45	CCA Type C	Non Reject	
19165	35	Penta	Non Reject	Groundline Treatment
47744	40	Creosote	Non Restorable Reject	Groundline Treatment
51231	30	CCA Type C	Non Reject	
64726	50	CCA Type C	Non Reject	
64728	50	CCA Type C	Non Reject	
58092	45	CCA Type C	Non Reject	
58078	45	CCA Type C	Non Reject	
61362	45	CCA Type C	Non Reject	
47752	35	Penta	Non Restorable Reject	Groundline Treatment
58086	45	CCA Type C	Non Reject	
58090	45	CCA Type C	Non Reject	
49278	35	Penta	Non Reject	Groundline Treatment
47745	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
58081	45	CCA Type C	Non Reject	
58083	45	CCA Type C	Non Reject	
64617	50	CCA Type C	Non Reject	
47746	40	Penta	Non Reject	Groundline Treatment
47753	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
58082	45	CCA Type C	Non Reject	
47178	40		Non Reject	
64618	50	CCA Type C	Non Reject	
53926	45	CCA Type C	Non Reject	
79447	45	CCA Type C	Non Reject	
53929	45	CCA Type C	Non Reject	
12783	40	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
53927	45	CCA Type C	Non Reject	
57617	45	CCA Type C	Non Reject	
53936	45	CCA Type C	Non Reject	
12775	40	CCA Type C	Non Reject	Groundline Treatment
12776	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
53930	45	CCA Type C	Non Reject	
12777	40	CCA Type C	Non Reject	Groundline Treatment
12778	40	CCA Type C	Non Reject	Groundline Treatment
53934	45	CCA Type C	Non Reject	
52214	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12780	35		Non Reject	
53933	45	CCA Type C	Non Reject	
53935	45	CCA Type C	Non Reject	Groundline Treatment
57496	45	CCA Type C	Non Reject	
12772	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53932	45	CCA Type C	Non Reject	
12791	40	CCA Type C	Non Reject	Groundline Treatment
52215	40	CCA Type C	Non Reject	Groundline Treatment
23761	40	CCA Type C	Non Reject	Groundline Treatment
23762	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
79907	45	CCA Type C	Non Reject	
18801	35	Penta	Non Reject	Groundline Treatment
79914	45	CCA Type C	Non Reject	
79908	45	CCA Type C	Non Reject	
79910	45	CCA Type C	Non Reject	
79912	45	CCA Type C	Non Reject	
79906	45	CCA Type C	Non Reject	
79903	45	CCA Type C	Non Reject	
79904	45	CCA Type C	Non Reject	
79905	45	CCA Type C	Non Reject	
79889	45	CCA Type C	Non Reject	
79926	45	CCA Type C	Non Reject	
79925	45	CCA Type C	Non Reject	
79924	45	CCA Type C	Non Reject	
79954	35	CCA Type C	Non Reject	
79955	35	CCA Type C	Non Reject	
77429	35	CCA Type C	Non Reject	
77428	35	CCA Type C	Non Reject	
70417	45	CCA Type C	Non Reject	
62698	45	CCA Type C	Non Reject	
12750	35	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION**



**2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
70245	45	CCA Type C	Non Reject	
12759	40	CCA Type C	Non Reject	
70247	45	CCA Type C	Non Reject	
48419	40	CCA Type C	Non Reject	Groundline Treatment
12740	35	Penta	Non Reject	Groundline Treatment
48414	30	CCA Type C	Non Reject	Groundline Treatment
48407	30	CCA Type C	Non Reject	Groundline Treatment
12763	40	CCA Type C	Non Reject	Groundline Treatment
12744	35	Penta	Non Reject	Groundline Treatment
12762	40	CCA Type C	Non Reject	Groundline Treatment
64140	45	CCA Type C	Non Reject	
57012	35	CCA Type C	Non Reject	
12773	30	CCA Type C	Non Reject	Groundline Treatment
12615	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
23126	50	CCA Type C	Non Reject	Groundline Treatment
72368	50	CCA Type C	Non Reject	
23122	50	CCA Type C	Non Reject	Groundline Treatment
34921	50	CCA Type C	Non Reject	Groundline Treatment
46601	30	CCA Type C	Non Reject	Groundline Treatment
12611	50	CCA Type C	Non Reject	Groundline Treatment
23140	50	CCA Type C	Non Reject	Groundline Treatment
53842	55	CCA Type C	Non Reject	
70286	50	CCA Type C	Non Reject	
60995	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
32248	30	CCA Type C	Non Reject	Groundline Treatment
54579	35	CCA Type C	Non Reject	
13999	45	CCA Type C	Non Reject	Groundline Treatment
58251	35	CCA Type C	Non Reject	
53845	40	CCA Type C	Non Reject	
51062	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
25467	45	Creosote	Non Reject	Groundline Treatment
13997	45	CCA Type C	Non Reject	Groundline Treatment
12609	50	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
34923	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34922	50	CCA Type C	Non Reject	
23124	55	CCA Type C	Non Reject	
60818	50	CCA Type C	Non Reject	
58250	35	CCA Type C	Non Reject	
72172	60	CCA Type C	Non Reject	
34606	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12607	50	CCA Type C	Non Reject	Groundline Treatment
13995	45	CCA Type C	Non Reject	Groundline Treatment
12613	50	CCA Type C	Non Reject	Groundline Treatment
23125	45		Non Reject	
13998	45	CCA Type C	Non Reject	Groundline Treatment
33618	45	Penta in Petroleum	Non Reject	Groundline Treatment
23132	50	CCA Type C	Non Reject	Groundline Treatment
54583	35	CCA Type C	Non Reject	
54582	35	CCA Type C	Non Reject	
12621	50	CCA Type C	Non Reject	Groundline Treatment
23138	45	Penta in Petroleum	Non Reject	Groundline Treatment
46518	40	CCA Type C	Non Reject	Groundline Treatment
53898	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
25248	40	CCA Type C	Non Reject	Groundline Treatment
54580	50	CCA Type C	Non Reject	
54581	50	CCA Type C	Non Reject	
25246	30	CCA Type C	Non Reject	Groundline Treatment
46516	35	Creosote	Non Reject	Groundline Treatment
12661	30	CCA Type C	Non Reject	Groundline Treatment
56826	45	CCA Type C	Non Reject	
12682	40	CCA Type C	Non Reject	Groundline Treatment
12653	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12662	40	CCA Type C	Non Reject	Groundline Treatment
62771	45	CCA Type C	Non Reject	
12667	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12665	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12683	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
72822	45	CCA Type C	Non Reject	
58276	45	Creosote	Non Reject	Sound & Bore,MITC Fume
12681	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12658	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
72824	45	CCA Type C	Non Reject	
12660	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54009	40	CCA Type C	Non Reject	
72816	35	CCA Type C	Non Reject	
56827	45	CCA Type C	Non Reject	
12666	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12757	40	CCA Type C	Non Reject	
58471	45	CCA Type C	Non Reject	
60151	35	CCA Type C	Non Reject	
64187	45	CCA Type C	Non Reject	
60841	45	CCA Type C	Non Reject	
70249	35	CCA Type C	Non Reject	
58473	35	CCA Type C	Non Reject	
12732	35	Penta	Non Restorable Reject	Sound & Bore,MITC Fume
48410	25	Penta	Non Reject	Sound & Bore,MITC Fume
64186	45	CCA Type C	Non Reject	
64185	45	CCA Type C	Non Reject	
12755	35	Penta	Non Reject	Sound & Bore,MITC Fume
60842	35	CCA Type C	Non Reject	
12739	35	Penta	Non Reject	Sound & Bore,MITC Fume
60843	35	CCA Type C	Non Reject	
60240	45	CCA Type C	Non Reject	
47278	35	CCA Type C	Non Reject	
79489	45	CCA Type C	Non Reject	
79500	45	CCA Type C	Non Reject	
20044	45	CCA Type C	Non Reject	
79444	35	CCA Type C	Non Reject	
67764	35	CCA Type C	Non Reject	
79487	45	CCA Type C	Non Reject	
23326	45	CCA Type C	Non Reject	
12700	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12696	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
12694	30	CCA Type C	Non Reject	Groundline Treatment
12699	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18397	30	CCA Type C	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
77324	30	CCA Type C	Non Reject	
47682	30		Non Reject	
72868	45	CCA Type C	Non Reject	
22482	40	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
72227	50	CCA Type C	Non Reject	
22480	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
56784	50	CCA Type C	Non Reject	
72180	50	CCA Type C	Non Reject	
72229	50	CCA Type C	Non Reject	
72218	50	CCA Type C	Non Reject	
64813	35	CCA Type C	Non Reject	
46992	40		Non Reject	
22483	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
22470	35	Penta	Non Reject	Groundline Treatment
72232	50	CCA Type C	Non Reject	
46991	30	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
22481	40	CCA Type C	Non Reject	Groundline Treatment
55569	45	CCA Type C	Non Reject	
72223	50	CCA Type C	Non Reject	
46994	30	CCA Type C	Non Reject	Groundline Treatment
64814	45	CCA Type C	Non Reject	
51089	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46989	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46993	20		Non Reject	
45138	35	Penta	Non Restorable Reject	Groundline Treatment
56823	35	CCA Type C	Non Reject	
25424	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
56825	45	CCA Type C	Non Reject	
26453	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28219	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45003	45	CCA Type C	Non Reject	
10414	50		Non Reject	
10401	40	CCA Type C	Non Reject	Groundline Treatment
54670	35	CCA Type C	Non Reject	
25409	40	CCA Type C	Non Reject	Groundline Treatment
34588	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45010	50	CCA Type C	Non Reject	Groundline Treatment
10402	40	Penta	Non Restorable Reject	Groundline Treatment
32177	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34594	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34598	50	CCA Type C	Non Reject	Groundline Treatment
34597	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
35381	45		Non Reject	
54671	50	CCA Type C	Non Reject	
54712	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54668	50	CCA Type C	Non Reject	
34589	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10413	45		Non Reject	
34592	50	CCA Type C	Non Reject	Groundline Treatment
25270	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34595	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34600	50		Non Reject	
72859	35	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
54667	50	CCA Type C	Non Reject	
45014	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
10400	50	CCA Type C	Non Reject	Groundline Treatment
10412	40		Non Reject	
54669	50	CCA Type C	Non Reject	
26454	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45004	45	CCA Type C	Non Reject	
54715	45	CCA Type C	Non Reject	
54665	50	CCA Type C	Non Reject	
34590	50	CCA Type C	Non Reject	Groundline Treatment
74240	35	CCA Type C	Non Reject	
49270	35	Penta	Non Restorable Reject	Groundline Treatment
58075	45	CCA Type C	Non Reject	
49268	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
19183	35	CCA Type C	Non Reject	Groundline Treatment
49264	35	CCA Type C	Non Reject	Groundline Treatment
58088	45	CCA Type C	Non Reject	
64604	50	CCA Type C	Non Reject	
64606	50	CCA Type C	Non Reject	
64725	50	CCA Type C	Non Reject	
58084	45	CCA Type C	Non Reject	
49271	30	CCA Type C	Non Reject	Groundline Treatment
49267	35	CCA Type C	Non Reject	Groundline Treatment
58093	45	CCA Type C	Non Reject	
34145	40	CCA Type C	Non Reject	Groundline Treatment
58074	45	CCA Type C	Non Reject	
59828	45	CCA Type C	Non Reject	
58087	45	CCA Type C	Non Reject	
18180	40		Non Reject	
18176	35		Non Reject	
64609	50	CCA Type C	Non Reject	
64608	50	CCA Type C	Non Reject	
77286	45	CCA Type C	Non Reject	
53931	45	CCA Type C	Non Reject	
12782	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
53928	45	CCA Type C	Non Reject	
12786	45	CCA Type C	Non Reject	Groundline Treatment
12781	40	CCA Type C	Non Reject	Sound & Bore,Hollow Heart,MITC Fume
12789	45	CCA Type C	Non Reject	Groundline Treatment
50344	40	CCA Type C	Non Reject	Groundline Treatment
12790	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12793	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12794	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
79913	45	CCA Type C	Non Reject	
77389	45	CCA Type C	Non Reject	
79909	45	CCA Type C	Non Reject	
77388	45	CCA Type C	Non Reject	
79980	35	CCA Type C	Non Reject	
79890	45	CCA Type C	Non Reject	
79831	45	CCA Type C	Non Reject	
79820	50	CCA Type C	Non Reject	
79821	50	CCA Type C	Non Reject	
79822	50	CCA Type C	Non Reject	

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
79823	50	CCA Type C	Non Reject	
79956	35	CCA Type C	Non Reject	
70415	45	CCA Type C	Non Reject	
12752	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
12751	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48408	40	CCA Type C	Non Reject	
12774	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
32246	35	CCA Type C	Non Reject	
12612	45	CCA Type C	Non Reject	Groundline Treatment
51114	50	CCA Type C	Non Reject	
12610	50	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
32247	35	CCA Type C	Non Reject	
12608	50	CCA Type C	Non Reject	Groundline Treatment
51113	50	CCA Type C	Non Reject	
23131	50	CCA Type C	Non Reject	Groundline Treatment
46517	35	CCA Type C	Non Reject	
25247	50	CCA Type C	Non Reject	Groundline Treatment
33617	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12684	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
47474	30	CCA Type C	Non Reject	Groundline Treatment
12664	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12680	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
56828	45	CCA Type C	Non Reject	
12685	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12758	40	CCA Type C	Non Reject	
58470	45	CCA Type C	Non Reject	
58472	45	CCA Type C	Non Reject	
60239	45	CCA Type C	Non Reject	
31729	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
79443	30	CCA Type C	Non Reject	Groundline Treatment
12695	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12698	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12693	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
60496	45	CCA Type C	Non Reject	
75601	35		Non Reject	
54648	45	CCA Type C	Non Reject	
72228	35	CCA Type C	Non Reject	
72231	50	CCA Type C	Non Reject	
72234	50	CCA Type C	Non Reject	
46990	30	CCA Type C	Non Reject	Groundline Treatment
72219	50	CCA Type C	Non Reject	
10410	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34593	50	CCA Type C	Non Reject	
45013	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28217	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28220	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54663	50	CCA Type C	Non Reject	
10415	45		Non Reject	
34601	40		Non Reject	
45005	40	CCA Type C	Non Reject	Groundline Treatment
54666	50	CCA Type C	Non Reject	
34591	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
34596	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
18448	35	Creosote	Non Reject	Sound & Bore,MITC Fume
18850	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
59817	50	CCA Type C	Non Reject	
26899	45	CCA Type C	Non Reject	Groundline Treatment
45929	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
29649	35	Penta	Non Reject	Groundline Treatment,MITC Fume
72628	30	Creosote	Non Restorable Reject	Rejected
72681	40	CCA Type C	Non Reject	Groundline Treatment
81325	35	Penta	Non Reject	Groundline Treatment
76491	35	CCA Type C	Non Reject	
29721	35	Creosote	Non Reject	Sound & Bore,MITC Fume
29722	35	Penta	Non Reject	Groundline Treatment,MITC Fume
68096	35	CCA Type C	Non Reject	
81324	35	Penta	Non Reject	Groundline Treatment,MITC Fume
29693	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
81322	35	Penta	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
81321	35	Creosote	Non Reject	Rejected
72601	35	Penta	Non Reject	Rejected
72662	50	CCA Type C	Non Reject	Groundline Treatment
72632	35	Creosote	Non Reject	Rejected
72633	50	CCA Type C	Non Reject	Groundline Treatment
81316	35	Creosote	Non Reject	Groundline Treatment
72634	35	Creosote	Non Reject	Sound & Bore,MITC Fume
81317	40	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
81318	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
81313	40	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
30990	40	Creosote	Non Reject	Groundline Treatment
30989	40	Creosote	Non Reject	Groundline Treatment
30987-1	40	Creosote	Non Reject	Groundline Treatment
46224	40	Creosote	Non Reject	Groundline Treatment,MITC Fume
72660	40	CCA Type C	Non Reject	Groundline Treatment
81309	35	Creosote	Non Reject	Groundline Treatment,Hollow Heart,MITC Fume
72661	35	Creosote	Non Reject	Groundline Treatment
29671	35	Creosote	Non Reject	Sound & Bore,MITC Fume
72663	35	Creosote	Non Reject	Sound & Bore,MITC Fume
72657	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
47203	60	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24903	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
24904	35	Penta	Non Reject	Groundline Treatment
72667	35	CCA Type C	Non Reject	
24999	45	CCA Type C	Non Reject	Groundline Treatment
24891	35	CCA Type C	Non Reject	Groundline Treatment
24888	35	CCA Type C	Non Reject	Groundline Treatment
24887	35	Creosote	Non Reject	Groundline Treatment
72693	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
81312	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
18040	35	Penta	Non Reject	Sound & Bore,MITC Fume
51063	35	CCA Type C	Non Reject	
79326	35	CCA Type C	Non Reject	
79325	35	CCA Type C	Non Reject	
24435	40	CCA Type C	Non Reject	Groundline Treatment
24436	35	CCA Type C	Non Reject	Groundline Treatment
24437	40	CCA Type C	Non Reject	Groundline Treatment

## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
60658	35	CCA Type C	Non Reject	
24425	30	Creosote	Non Reject	Sound & Bore,MITC Fume
24914	40	Creosote	Non Reject	Groundline Treatment
50129	50	CCA Type C	Non Reject	
72785	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
81297	35	CCA Type C	Non Reject	
81294	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
81290	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
81289	35	Creosote	Non Reject	Sound & Bore,MITC Fume
23962	40	Penta	Non Reject	Sound & Bore,MITC Fume
81288	35	Penta	Non Reject	Groundline Treatment
72696	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
81284	35	CCA Type C	Non Reject	
59567	45	CCA Type C	Non Reject	
59566	45	CCA Type C	Non Reject	
24968	35	Creosote	Non Reject	Groundline Treatment
72720	35	CCA Type C	Non Reject	
72728	35	CCA Type C	Non Reject	
45660	30	CCA Type C	Non Reject	Groundline Treatment
72719	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
46535	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
72753	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
72752	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
45770	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
24329	40	CCA Type C	Non Reject	Groundline Treatment
62610	45	CCA Type C	Non Reject	
81269	35	CCA Type C	Non Reject	
46412	35	Penta	Non Reject	Groundline Treatment
24303	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
25684	40	Creosote	Non Reject	Groundline Treatment
25679	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
28784	35	Penta	Non Reject	Groundline Treatment,MITC Fume
28785	35	Penta	Non Reject	Groundline Treatment
28825	35	Penta	Non Reject	Sound & Bore,MITC Fume
28826	50	CCA Type C	Non Reject	Groundline Treatment
28827	35	Penta	Non Reject	Groundline Treatment
79174	35	CCA Type C	Non Reject	
79175	35	CCA Type C	Non Reject	
29334	35	Creosote	Non Reject	Groundline Treatment
28821	35	Creosote	Non Reject	Groundline Treatment
28820	35	Creosote	Non Reject	Groundline Treatment
28780	35	Creosote	Non Reject	Groundline Treatment
25745	30	Creosote	Non Restorable Reject	Groundline Treatment,MITC Fume
53182	25	CCA Type C	Non Reject	Groundline Treatment
28774	35	Creosote	Non Restorable Reject	
28813	35	Creosote	Non Reject	Groundline Treatment
28812	35	Creosote	Non Reject	Groundline Treatment
28810	50	CCA Type C	Non Reject	Sound & Bore,MITC Fume
28815	35	Creosote	Non Reject	Groundline Treatment
28808	35	Creosote	Non Reject	Groundline Treatment
29298	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
28806	40	Creosote	Non Reject	Groundline Treatment
28811	35	Creosote	Non Reject	Groundline Treatment,MITC Fume

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
72774	30	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
72773	30	CCA Type C	Non Reject	Groundline Treatment
72766	40	CCA Type C	Non Reject	Groundline Treatment
28765	30	CCA Type C	Non Reject	Groundline Treatment
28722	30	CCA Type C	Non Reject	Groundline Treatment
67713	35	CCA Type C	Non Reject	
25781	30	Creosote	Non Reject	Rejected
28786	40	CCA Type C	Non Reject	Groundline Treatment
72771	25	Penta	Non Reject	Groundline Treatment
72479	35	CCA Type C	Non Reject	Groundline Treatment
81227	35	CCA Type C	Non Reject	
79621	45	CCA Type C	Non Reject	
53858	45	CCA Type C	Non Reject	
61311	45	CCA Type C	Non Reject	
127208	25	Penta	Non Restorable Reject	Rejected
28755	30	CCA Type C	Non Reject	Groundline Treatment
28752	45	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
28756	30	CCA Type C	Non Reject	
72136	50	CCA Type C	Non Reject	
72138	50	CCA Type C	Non Reject	
10305	45	Penta	Non Reject	Groundline Treatment
22472	35	Penta	Non Reject	Groundline Treatment,MITC Fume
81208	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
57773	35	CCA Type C	Non Reject	
127215	30	CCA Type C	Non Reject	Groundline Treatment
81203	25	CCA Type C	Non Reject	Groundline Treatment
79147	45	CCA Type C	Non Reject	
79143	45	CCA Type C	Non Reject	
79142	45	CCA Type C	Non Reject	
70650	35	CCA Type C	Non Reject	
79845	45	CCA Type C	Non Reject	
79148	45	CCA Type C	Non Reject	
79149	45	CCA Type C	Non Reject	
79150	45	CCA Type C	Non Reject	
79151	45	CCA Type C	Non Reject	
79152	45	CCA Type C	Non Reject	
79044	45	CCA Type C	Non Reject	
79153	45	CCA Type C	Non Reject	
79154	45	CCA Type C	Non Reject	
79155	45	CCA Type C	Non Reject	
79156	45	CCA Type C	Non Reject	
79157	45	CCA Type C	Non Reject	
79158	45	CCA Type C	Non Reject	
79159	45	CCA Type C	Non Reject	
79160	45	CCA Type C	Non Reject	
79161	45	CCA Type C	Non Reject	
79162	45	CCA Type C	Non Reject	
79163	45	CCA Type C	Non Reject	
79165	45	CCA Type C	Non Reject	
79164	45	CCA Type C	Non Reject	
79166	45	CCA Type C	Non Reject	
79167	45	CCA Type C	Non Reject	
79168	45	CCA Type C	Non Reject	

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
55150	45	CCA Type C	Non Reject	
79186	50	CCA Type C	Non Reject	
79187	45	CCA Type C	Non Reject	
79188	45	CCA Type C	Non Reject	
70651	30	CCA Type C	Non Reject	
59808	35	CCA Type C	Non Reject	
59648	45	CCA Type C	Non Reject	
27086	40	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
27087	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45570	45	CCA Type C	Non Reject	
20920	35	Creosote	Non Restorable Reject	Groundline Treatment
30033	35	CCA Type C	Non Reject	Groundline Treatment,MITC Fume
70710	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12192	45	Creosote	Non Reject	Sound & Bore,MITC Fume
70708	35	Creosote	Non Reject	Rejected
29865	35	CCA Type C	Non Reject	Groundline Treatment
70714	30	Creosote	Non Reject	Groundline Treatment,MITC Fume
70723	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46070	35	CCA Type C	Non Reject	Sound & Bore,MITC Fume
45071	35	CCA Type C	Non Reject	Groundline Treatment
70709	30	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
29870	35	Penta	Non Reject	Rejected
70657	25	CCA Type C	Non Reject	Groundline Treatment,Hollow Heart
23205	45	CCA Type C	Non Reject	Groundline Treatment
62664	35	CCA Type C	Non Reject	
72726	35	Penta	Non Reject	Groundline Treatment
61020	35	CCA Type C	Non Reject	
72725	40	CCA Type C	Non Reject	Groundline Treatment
70707	35	CCA Type C	Non Reject	Groundline Treatment
30047	35	Penta	Non Reject	Sound & Bore,MITC Fume
30046	35	Penta	Non Reject	Groundline Treatment
70706	35	Creosote	Non Reject	Sound & Bore,MITC Fume
29882	30	CCA Type C	Non Reject	Groundline Treatment
12205	40	CCA Type C	Non Reject	Groundline Treatment
12206	40	CCA Type C	Non Reject	Groundline Treatment
12202	50	CCA Type C	Non Reject	Groundline Treatment
23200	35	Penta	Non Reject	Groundline Treatment,MITC Fume
70703	35	Creosote	Non Reject	Groundline Treatment,MITC Fume
70696	45	CCA Type C	Non Reject	Groundline Treatment
46388	35	CCA Type C	Non Reject	Groundline Treatment
72776	35	CCA Type C	Non Reject	
25969	35	Penta	Non Restorable Reject	Groundline Treatment
12318	45	CCA Type C	Non Reject	Groundline Treatment
46363	35	Creosote	Non Reject	Groundline Treatment
25508	45	CCA Type C	Non Reject	Groundline Treatment
72748	25	CCA Type C	Non Reject	Groundline Treatment
12437	35	Penta	Non Reject	Groundline Treatment
12443	40	CCA Type C	Non Reject	Groundline Treatment
25975	40	CCA Type C	Non Reject	Groundline Treatment
25978	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
46378	40	Penta	Non Reject	Sound & Bore,MITC Fume
46360	35	Penta	Non Reject	Rejected
46379	35	Penta	Non Reject	Groundline Treatment

## ORLANDO UTILITIES COMMISSION



## 2014 Pole Inspection Report

OUC Asset	Length	Original Treatment	Inspection Result	Additional
70697	35	Creosote	Non Reject	Groundline Treatment
25980	40	CCA Type C	Non Reject	Groundline Treatment
70721	30	CCA Type C	Non Reject	
70720	35	CCA Type C	Non Reject	
79620	50	CCA Type C	Non Reject	
79196	35	CCA Type C	Non Reject	
24868	45	CCA Type C	Non Reject	Sound & Bore,MITC Fume
54906	45	CCA Type C	Non Reject	
70173	45	CCA Type C	Non Reject	
46345	35	CCA Type C	Non Reject	Groundline Treatment
12381	45	CCA Type C	Non Reject	Groundline Treatment
26009	25	Penta	Non Reject	Groundline Treatment
70677	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
48374	30	CCA Type C	Non Reject	Sound & Bore,MITC Fume
70676	45	CCA Type C	Non Reject	Groundline Treatment
52990	50	CCA Type C	Non Reject	
70659	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
79018	35	CCA Type C	Non Reject	
79020	35	CCA Type C	Non Reject	
79662	55	CCA Type C	Non Reject	
77413	50	CCA Type C	Non Reject	
69617	50	CCA Type C	Non Reject	
13962	35	CCA Type C	Non Reject	Groundline Treatment
81805	30	CCA Type C	Non Reject	
81806	35	CCA Type C	Non Reject	
16963	40	Penta	Non Reject	Groundline Treatment,MITC Fume
81807	40	CCA Type C	Non Reject	Groundline Treatment
20569	40	CCA Type C	Non Reject	Groundline Treatment
79484	45	CCA Type C	Non Reject	
81938	35	CCA Type C	Non Reject	
47485	35	Penta	Non Restorable Reject	Groundline Treatment
72769	35	Creosote	Non Reject	Sound & Bore,MITC Fume
64180	45	CCA Type C	Non Reject	
64179	45	CCA Type C	Non Reject	
12405	45	CCA Type C	Non Reject	Groundline Treatment
79081	50	CCA Type C	Non Reject	
79082	50	CCA Type C	Non Reject	
79083	50	CCA Type C	Non Reject	
79084	35	CCA Type C	Non Reject	
59715	35	CCA Type C	Non Reject	
12489	40	CCA Type C	Non Reject	Groundline Treatment
57209	45	CCA Type C	Non Reject	Groundline Treatment
12491	40	CCA Type C	Non Reject	Sound & Bore,MITC Fume
12492	40	CCA Type C	Non Reject	Groundline Treatment
81804	50	CCA Type C	Non Reject	Groundline Treatment
12476	35	CCA Type C	Non Reject	Groundline Treatment
60266	35	CCA Type C	Non Reject	Groundline Treatment
79078	45	CCA Type C	Non Reject	
79611	45	CCA Type C	Non Reject	
79612	45	CCA Type C	Non Reject	
79613	45	CCA Type C	Non Reject	
81918	30	CCA Type C	Non Reject	Groundline Treatment
81917	30	CCA Type C	Non Reject	Groundline Treatment

**ORLANDO UTILITIES COMMISSION****2014 Pole Inspection Report**

OUC Asset	Length	Original Treatment	Inspection Result	Additional
81818	30	CCA Type C	Non Reject	
60777	40	CCA Type C	Non Reject	
49619	35	Creosote	Non Reject	Groundline Treatment
81817	30	CCA Type C	Non Reject	Groundline Treatment
20532	40	Creosote	Non Reject	Groundline Treatment
64030	45	CCA Type C	Non Reject	
79624	35	CCA Type C	Non Reject	
79625	35	CCA Type C	Non Reject	
79626	35	CCA Type C	Non Reject	
79627	35	CCA Type C	Non Reject	
81930	30	CCA Type C	Non Reject	
81928	30	Penta	Non Reject	Groundline Treatment
51290	45	CCA Type C	Non Reject	Groundline Treatment
81828	40	Penta	Non Reject	Groundline Treatment
79302	35	CCA Type C	Non Reject	