



Gulf Coast  
Electric Cooperative

A Touchstone Energy® Cooperative 

---

---

February 27, 2007

Ms. Penelope Buys  
Engineering Specialist  
Division of Engineering  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850

RE: Report for Rule 25-6.0343, F.A.C.

Attached please find Gulf Coast Electric Cooperative's (GCEC) 2016 report for Rule 25-6.0343, F.A.C. due March 1, 2017.

Should you require additional information not included in this report, please let me know.

Respectfully



C. Peyton Gleaton Jr., PE  
Vice President of Engineering

CC: Michael White, Chief Executive Officer, GCEC  
Francis Hinson, Chief Operating Officer, GCEC  
Michelle Hershel, FECA


---

722 W. Highway 22 ~ P.O. Box 220 ~ Wewahitchka, Florida 32465  
9434 Highway 77 ~ P.O. Box 8370 ~ Southport, Florida 32409  
6243 E. Highway 98 ~ Panama City, Florida 32404

(850) 639-2216 Fax (850) 639-5061  
(850) 265-3631 Fax (850) 265-3634  
(850) 481-1188 Fax (850) 265-1184



# Gulf Coast Electric Cooperative

A Touchstone Energy® Cooperative 

---

---

## **Gulf Coast Electric Cooperative, Inc. Report to the Florida Public Service Commission Pursuant to Rule 25-6.0343, F.A.C. Calendar Year 2016**

### 1) Introduction:

Gulf Coast Electric Cooperative, Inc. (GCEC) main office is located within the city limits of Wewahitchka, Gulf County, Florida seventeen miles inland from the Gulf of Mexico. The Cooperative's district offices are located with the communities of Southport, Bay County, Florida and Parker, Bay County, Florida approximately thirteen miles and four miles inland from the Gulf of Mexico respective. The cooperative serves electricity to 20,560 active customers in Gulf, Calhoun, Bay, Walton, Jackson and Washington counties. GCEC's distribution system is composed of both aerial and underground power distribution lines operating at 14.4/24.94kV. GCEC purchases energy from PowerSouth Energy Cooperative in Andalusia, Alabama, and receives power at eight 115kV substations and two 46kV substations.

Main Office: Gulf Coast Electric Cooperative, Inc.  
722 West Highway 22  
PO Box 220  
Wewahitchka, FL 32465  
(850) 639-2216

Contacts: C. Peyton Gleaton Jr., PE  
VP of Engineering  
Gulf Coast Electric Coop  
PO Box 8370  
Southport, FL 32409  
(850) 2665-3631 ext. 3053  
[pgleaton@gcec.com](mailto:pgleaton@gcec.com)

Francis Hinson  
Chief Operating Officer  
Gulf Coast Electric Coop  
PO Box 8370  
Southport, FL 32409  
(850) 266-3631 ext. 3052  
[fhinson@gcec.com](mailto:fhinson@gcec.com)

---

722 W. Highway 22 ~ P.O. Box 220 ~ Wewahitchka, Florida 32465  
9434 Highway 77 ~ P.O. Box 8370 ~ Southport, Florida 32409  
6243 E. Highway 98 ~ Panama City, Florida 32404

(850) 639-2216 Fax (850) 639-5061  
(850) 265-3631 Fax (850) 265-3634  
(850) 481-1188 Fax (850) 265-1184

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2016**

---

2) In calendar year 2016, GCEC served:

19,175 Residential Consumers  
911 Small Commercial Consumers  
11 Large Commercial Consumers  
463 Other Sales to Public Authorities  
20,560 Total Active Consumers (Meters)

3) Standards of Construction:

a. National Electric Safety Code Compliance

Gulf Coast Electric Cooperative, Inc. complies with the National Electric Safety Code (ANSI C-2) [NESC]. As of January 1, 2017, Gulf Coast Electric Cooperative's construction standards comply with the NESC 2015 Edition. For electrical facilities constructed prior to this date are in compliance with and governed by the edition of the NESC in effect at the time of the facilities' initial construction.

Through both internal and external quality controls, Gulf Coast Electric Cooperative ensures that our distribution system is designed, constructed, operated, and maintained in accordance with all applicable provisions of the most current and accepted criteria of the NESC and all applicable and current electrical and safety requirements of any state and local governmental entity.

b. Extreme Wind Loading Standards

At this time, Gulf Coast Electric Cooperative, Inc. facilities are not bound by the extreme loading standards as our system is 99.9% under the 60ft 'extreme wind loading' requirements. The method of construction used by GCEC does, however, meet the 'design to withstand, without conductors, extreme wind loading in Rule 250C applied in any direction on the structure'. GCEC continues to self-audit and evaluate our system to determine any immediate needs for system upgrades and hardening in isolated areas.

"RUS (Rural Utilities Service) electrical standard requirements are in addition to, and not in substitution for or a modification of, the most current and accepted criteria of the NESC and any applicable electrical or safety requirements of any state or local government entity."

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2016**

---

c. Flooding and Storm Surges

Gulf Coast Electric Cooperative, Inc. standards policies, guidelines, practices, and processes address the effects of flooding and storm surges on underground facilities and supporting overhead facilities. As required by RUS (Rural Utilities Services), high voltage cables are connected to padmounted underground facilities, such as transformers, switchgears, junction boxes, etc., with sealed “dead front” elbow connections rather than exposed, “live front” terminations that could be faulted by flood waters.

Gulf Coast Electric Cooperative participated in the Public Utility Research Center’s (PURC) study on the conversion of overhead electric facilities to underground and the effectiveness of undergrounding facilities in preventing storm damage and outages. An update of activates from PURC to its Steering Committee regarding Hurricane Hardening is included as an attachment to this report.

d. Safe and Efficient Access of New and Replacement Distribution Facilities

Electrical construction standards, policies, guidelines, practices, and procedures at Gulf Coast Electric Cooperative, Inc. provide for replacement of new and replacement distribution facilities to facilitate safe and efficient access for installation and maintenance. Wherever new facilities are placed (i.e. front, back, or side of property), all facilities are install so that the GCEC facilities are accessible by its crews and vehicles to ensure proper maintenance/repair is performed as expeditiously and safely as possible. GCEC decides on a case-by-case basis whether existing facilities need to be relocated. If it is determined that facilities need to be relocated, they are placed in the safest, most accessible area available.

e. Attachments by Others

Electrical construction standards, policies, guidelines, practices, and procedures at Gulf Coast Electric Cooperative, Inc. include written safety, pole reliability, pole loading capacity, and engineering standards and procedures for attachments by others to the utility’s distribution poles. Routine pole line inspections of ‘work-orders’ are performed by GCEC’s consulting engineer for newly constructed jobs. These inspections encompass all pole line construction criteria. General inspections are currently done on an eight year cycle.

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2016**

---

4) Facilities Inspection:

- a. Describe the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.

Gulf Coast Electric Cooperative, Inc. has no transmission lines.

Gulf Coast Electric Cooperative, Inc. conforms to RUS Bulletin 1730B-12 for Pole Inspection and Maintenance, and performs general pole inspections on its distribution lines on an eight-year cycle. Poles that do not pass inspection are changed out to satisfy service and safety reliability and to meet the requirements of the National Electrical Safety Code in effect at the current time. The pole selection process is by substation and distribution feeder.

In accordance with RUS Bulletin 1730-1, Electric System Operation and Maintenance (O&M), GCEC visually inspects underground transformers and other padmount equipment on a four-year cycle for safety compliance and physical condition. Items found out of compliance or in need of maintenance are corrected in the same year. The selection area is determined by substation and feeder density.

GCEC also inspects with the PSC, a percentage of new completed pole line construction called for by the PSC. The section process is done by the PSC.

GCEC also inspects a percentage of new pole line construction chosen routinely on its own. The section process is done by random choice.

- b. Describe the number and percentage of transmission and distribution inspections planned and completed for 2016.

Gulf Coast Electric Cooperative, Inc. has no transmission lines.

Gulf Coast Electric Cooperative, Inc. inspected 7,054 poles in 2016 with 118 rejects. This number reflects 14.5% of the poles owned by GCEC and 97.1% of poles planned for inspection for the year 2016.

Also in 2016, Gulf Coast Electric Cooperative, Inc. inspected 255 padmount transformers, 227 pull box cabinets, and 187 secondary pedestals; these 669 devices accounted for approximately 35.5% of the Cooperative's padmount equipment.

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2016**

---

- c. Describe the number and percentage of distribution poles failing inspection and the reason for the failure.

7,054 poles were inspected in 2016 with 118 poles rejected, for a rejection rate of 1.7%.

The reasons for failure were:

Decay Pockets (15)	12.7%	Mechanical Damage (7)	5.9%
Decayed/Split Top (41)	34.7%	Punk Wood (1)	0.8%
Butt Rot (47)	39.8%	Heart Rot (7)	5.9%

- d. Remedial action taken.

Gulf Coast Electric Cooperative, Inc. has a continually active work order program for maintenance and replacement of its wood poles and structures. In 2016, GCEC's changed out 185 poles under its pole inspection program.

5) Vegetation Management

Gulf Coast Electric Cooperative, Inc. owns and operates approximately 2,158 miles of overhead and 435 miles of underground electrical distribution lines. GCEC strives to clear all of the right-of-way (ROW) on a five year cycle. Presently, GCEC is on a definitive five year program. GCEC's line construction specifications are to clear between twenty (20) and thirty (30) foot width, "from ground to sky". Certified arborist personnel manage GCEC's ROW program. GCEC utilizes in-house ROW crews for clear-cut ROW maintenance program.

Estimated ROW clearing costs are approximately \$1,070,000 annually to cut 100% on a four-year program. At this time, it is cost prohibitive for GCEC to cut 100% on a three-year cycle. GCEC cuts on a geographic and substation selective basis to maintain a respectful and systematic program.

GCEC is actively reclaiming all ROW, this includes the removal of all trees that fall in GCEC ROW. This is being accomplished by taking the time to educate property owners on the importance of clear ROW and the instruction as to what trees or plants can be planted around the ROW.

GCEC cut 375 miles of ROW in 2014 and 2015. GCEC plans to continue on this rotation to keep ROW on a 5 year rotation. We feel that this 5 year rotation along

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2016**

---

with aggressively reclaiming GCEC ROW will reduce outages and provide better safety and awareness for the public.

GCEC works closely with the Florida DOT and the various county governments regarding vegetation management along road right-of-ways. GCEC also works closely with property owners for danger tree removal and in select cases, for plantings and landscaping.

## **Report on Collaborative Research for Hurricane Hardening**

Provided by

The Public Utility Research Center  
University of Florida

To the

Utility Sponsor Steering Committee

February 2017

### **I. Introduction**

The Florida Public Service Commission (FPSC) issued Order No. PSC-06-00351-PAA-EI on April 25, 2006 (Order 06-0351) directing each investor-owned electric utility (IOU) to establish a plan that increases collaborative research to further the development of storm resilient electric utility infrastructure and technologies that reduce storm restoration costs and outages to customers. This order directed IOUs to solicit participation from municipal electric utilities and rural electric cooperatives in addition to available educational and research organizations. As a means of accomplishing this task, the IOUs joined with the municipal electric utilities and rural electric cooperatives in the state (collectively referred to as the Project Sponsors) to form a Steering Committee of representatives from each utility and entered into a Memorandum of Understanding (MOU) with the University of Florida's Public Utility Research Center (PURC). The third extension of this MOU was approved last year by the Research Collaboration Partners and now extends through December 31, 2018.

PURC manages the work flow and communications, develops work plans, serves as a subject matter expert, conducts research, facilitates the hiring of experts, coordinates with research vendors, advises the Project Sponsors, and provides reports for Project activities. The collaborative research has focused on undergrounding, vegetation management, hurricane-wind speeds at granular levels, and improved materials for distribution facilities.

This report provides an update on the activities of the Steering Committee since the previous report dated February 2016.



## **II. Steering Committee Workshop**

On September 29, the Steering Committee organized a workshop for 26 participants from the Project Sponsors at TECO Plaza in Tampa. The workshop was held to orient new members on the work that the cooperative has accomplished, and to serve as a forum for new ideas in the field of storm preparedness and outage response.

The opening speaker was Matt Corey from Weatherflow, Inc. who discussed their wind monitoring network "HurrNet." The network consists of approximately 90 wind monitoring stations, 44 in Florida, and 21 on utility property. This data is available at no charge to the Project Sponsors. He also outlined Weatherflow's new capabilities, specifically their StormTrack/StormPrint model (on which he displayed, ironically, Hurricane Matthew) and their new line of Smart Weather weather stations for domestic to commercial users.

Next was Ted Kury from PURC with an update on the undergrounding model developed by the Project Sponsors. The current capabilities, which include both probabilistic and deterministic modeling, were reviewed.

The next item on the agenda was a roundtable on vegetation management. Participants discussed current procedures and best practices. All noted that utilities continue to face challenges regarding access to facilities that need to be managed, particularly within municipal boundaries due primarily to municipal codes. Some noted that municipalities may not be aware of the impact that their codes may have on system reliability, and that education is critical in these areas. Each utility then outlined their current trim cycle and approach. Finally, the participants discussed the evolution of customer expectations regarding communications with their utilities.

Next on the agenda was a discussion on the collection and usage of forensic storm damage data. Participants reviewed the existing platform and data framework.

Finally, the participants engaged in a roundtable discussion of topics that might be explored further in future workshops, and discussed the importance and the form of follow-up efforts.

Overall, the participants left the workshop with a greater appreciation and understanding of the work conducted at the various transmission and distribution segments of the Florida utilities.

## **III. Undergrounding**

The collaborative research on undergrounding has been focused on understanding the existing research on the economics and effects of hardening strategies, including undergrounding, so that informed decisions can be made about undergrounding policies and specific undergrounding projects.

The collaborative has refined the computer model developed by Quanta Technologies and there has been a collective effort to learn more about the function and functionality of the computer code. PURC and the Project Sponsors have worked to fill information gaps for model inputs and significant efforts have been invested in the area of forensics data collection. Since the state has not been affected by any hurricanes since the database software was completed, there is currently no data. Therefore, future efforts to refine the undergrounding model will occur when such data becomes available.

In addition, PURC has worked with doctoral and master's candidates in the University of Florida Department of Civil and Coastal Engineering to assess some of the inter-relationships between wind speed and other environmental factors on utility equipment damage. PURC has also been contacted by engineering researchers at the University of Wisconsin and North Carolina State University with an interest in the model, though no additional relationships have been established. In addition to universities, PURC

**Gulf Coast Electric Cooperative, Inc.**  
**Report to the Florida Public Service Commission**  
**Pursuant to Rule 25-6.0343, F.A.C.**  
**Calendar Year 2015**

**Attachment**

was again contacted by researchers at the Argonne National Laboratory who expressed interest in modeling the effects of storm damage. The researchers developed a deterministic model, rather than a probabilistic one, but did use many of the factors that the Collaborative have attempted to quantify. They are currently working to incorporate stochastic elements into their model and have consulted PURC for guidance. Every researcher that contacts PURC cites the model as the only non-proprietary model of its kind.

The research discussed in previous years' reports on the relationship between wind speed and rainfall is still under review by the engineering press. Further results of this and related research can likely be used to further refine the model.

#### **IV. Wind Data Collection**

The Project Sponsors entered into a wind monitoring agreement with WeatherFlow, Inc., in 2007. Under the agreement, Florida Sponsors agreed to provide WeatherFlow with access to their properties and to allow WeatherFlow to install, maintain and operate portions of their wind monitoring network facilities on utility-owned properties under certain conditions in exchange for access to wind monitoring data generated by WeatherFlow's wind monitoring network in Florida. WeatherFlow's Florida wind monitoring network includes 50 permanent wind monitoring stations around the coast of Florida, including one or more stations located on utility-owned property. The wind monitoring agreement expired in early 2012; however, the wind, temperature, and barometric pressure data being collected at these stations is being made available to the Project Sponsors on a complimentary basis.

#### **V. Public Outreach**

In last year's report we discussed the impact of increasingly severe storms on greater interest in storm preparedness. PURC researchers continue to discuss the collaborative effort in Florida with the engineering departments of the state regulators in Connecticut, New York, and New Jersey, Pennsylvania, and regulators in Jamaica, Grenada, Curacao, Samoa, and the Philippines. While all of the regulators and policymakers showed great interest in the genesis of the collaborative effort, and the results of that effort, they have not, at this point, shown further interest in participating in the research effort.

#### **VI. Conclusion**

In response to the FPSC's Order 06-0351, IOUs, municipal electric utilities, and rural electric cooperatives joined together and retained PURC to coordinate research on electric infrastructure hardening. The steering committee has taken steps to extend the research collaboration MOU so that the industry will be in a position to focus its research efforts on undergrounding research, granular wind research and vegetation management when significant storm activity affects the stat

