

Report
02/27/2023

ORLANDO UTILITIES COMMISSION



CALENDAR YEAR 2022

FACILITY INSPECTION AND VEGETATION MANAGEMENT REPORT

**Orlando Utilities Commission
Florida Public Service Commission Pursuant to
Rule 25-6.0343, F.A.C.
Calendar Year 2022**

1) Introduction

Orlando Utilities Commission

100 West Anderson Street, Orlando, FL 32801

Contact information:

LeMoyne Adams, Vice President, Electric & Water Distribution
407-434-4137, LAdams@ouc.com

Troy Morris, Director, Distribution Construction & Maintenance
407-434-4199, TMorris@ouc.com

2) Number of meters served in calendar year 2022

Orlando Utilities Commission served 271,739 electric meters in the cities of Orlando and St. Cloud and surrounding Orange and Osceola counties as of December 31, 2022.

3) Standards of Construction

a) National Electric Safety Code Compliance

The Orlando Utilities Commission (OUC) complies with the construction standards, policies, guidelines, practices, and procedures directed within the National Electrical Safety Code (ANSI C-2) [NESC]. For electrical facilities constructed on or after February 1, 2007, the 2007 NESC applies. The edition of the NESC in effect at the time of the facility's initial construction governs electrical facilities constructed prior to February 1, 2007.

b) Extreme Wind Loading Standards

Construction standards, policies, guidelines, practices, and procedures at the Orlando Utilities Commission are guided by the extreme wind loading standards specified by Figure 250-2(d) of the 2002 edition of the NESC for 1) new construction; 2) major planned work, including expansion, rebuild, or relocation of existing facilities, assigned on or after December 10, 2006; and 3) targeted critical infrastructure facilities and major thoroughfares.

OUC has verified that all future construction will meet the NESC requirements with particular focus on the extreme wind loading standards.

c) Flooding and Storm Surges

The Orlando Utilities Commission service territory is not within a coastal area, and therefore, not subject to storm surges or wide-spread significant flooding.

d) Safe and Efficient Access of New and Replacement Distribution Facilities

Electrical construction standards, policies, guidelines, practices, and procedures at OUC provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance.

Since the 1980's, the Orlando Utilities Commission has been installing underground and overhead distribution along property frontage corridors. This gives efficient and safer access to these facilities. OUC provides vegetation maintenance and replacement of aged equipment to ensure an efficient, safe, & robust system for all OUC facilities including existing rear lot installations.

e) Attachments by Others

Electrical construction standards, policies, guidelines, practices, and procedures at the Orlando Utilities Commission include contractual agreement to enable attachment by others. These contracts state that attachments must adhere to the guidelines of the NESC and all governmental authorities that have jurisdiction.

4) Facility Inspections

a) Policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures.

Summary

Orlando Utilities Commission (OUC) has maintained an active pole inspection and replacement program with records dating back to 1990. We currently uphold an eight-year quadrant based inspection cycle along with annual inspections targeting essential distribution and transmission equipment. Shared transmission structures are inspected and maintained by OUC based on past inspection date.

Distribution and Transmission pole inspection replacements are tracked through an existing maintenance work order database to insure timely replacement.

Inspection Procedures

Visual inspection shall be made of all poles from the ground line to the top before any other inspection. Visual inspection shall include: type of wood, original treatment, circumference, and age of pole, (if it can be determined), height, obvious splits, woodpecker holes, and any other physical damages to the pole. Also a visual check within the limitations of the inspector's expertise, is to be made at such time of the attachments to the pole being inspected for obvious conditions that appear improper, such as slack guy wires, slack overhead conductors, broken insulators, leaking transformers, missing guy guards, rotten cross arms, loose or faulty equipment, abandoned poles, etc.

Excavation

Earth shall be removed from the entire circumference of the pole to a minimum depth of 18 inches below ground line. Width of the hole shall be 4 inches clearance for the pole surface at the bottom and 10 inches at the ground line.

Poles with electric risers should not be excavated, but should be inspected by sounding, boring and fumigating.

Sounding and Boring

The pole must be sounded from the ground line to a minimum of six feet above the ground line. Sounding shall be done on all four sides of the pole to locate any shell rot or rot pockets on the side.

Sounding shall be done with an approved hammer that leaves a distinctive hammer pattern. If there is evidence of possible interior voids or rot, at least one boring shall be made where a void is indicated. If rot or voids are detected, several borings shall be made per rot or void location and a shell gauge shall be used to determine the extent of all voids or rot. In any event at least two borings shall be made at the ground line to check for rot.

Poles set in concrete or pavement shall be bored at least twice at opposite sides at the ground line down at a 45-degree angle into the pole and the boring sample checked for rot or voids.

Removal of Exterior Decay

All exterior decay must be removed where possible, from 18 inches below the ground line to 3 inches above ground line. The rotted wood is to be removed from the premises and deposited in a proper manner.

Evaluation of Pole Condition

After the sounding and boring has been performed and all exterior decay has been removed, the effective circumference of the pole, from 18 inches below the ground line to 15 inches above the ground line, is to be determined.

Internal Treatment

All sound poles are internally treated if any specific voids or specific internal decay pockets are found. This should involve a sufficient number of bored 3/8 inch holes and the preservative is applied under at least 50 psi of pressure. Internal pole treatment also utilizes MITC-Fume or and OUC approved fumigant.

Ground Line Treatment

All poles not previously rejected are covered from 18 inches below the ground line to 3 inches above the ground line by an OUC approved preservative and moisture barrier film. Preservative treatment penetrates a minimum of two inches into the pole. Long-term treatment retention studies are kept to assure future review and results.

b) Note: Number and percentage of transmission and distribution inspections planned and completed for 2022.

Distribution and Transmission Planned Inspections					
Year	Total System Poles	Planned Inspection	Planned Percentage of System	Inspection Completed	Completed Percentage of System
2022	51200	6696	13%	6684	13%
2020-2021	51900	16579	32%	16532	32%
2019	51200	2998	6%	2990	6%
2018	51200	6512	13%	6411	13%
2017	49643	6200	12%	6389	13%
2016	50049	6400	12%	6419	13%
2015	50915	6400	12%	6758	13%
2014	50582	6400	12%	6410	13%
2013	50721	6400	12%	6415	13%
2012	50804	6400	12%	6400	12%
2011	50938	6400	12%	6730	13%
2010	51142	6400	12%	6534	13%

c) Number and percentage of transmission and distribution poles / structures failing inspection and the reason for the failure.

Poles Failing Inspection		
	Percentage of Inspection Failure	Total Inspected Poles Failing Inspection
2022	0.4%	24
2020-2021	2.3%	377
2019	12.4%	372
2018	2.6%	167
2017	0.4%	27
2016	0.9%	58
2015	1.3%	97
2014	2.3%	145
2013	5.5%	352
2012	6.2%	396
2011	8.9 %	600
2010	9.8 %	642

d) Number of transmission poles, structures and distribution poles, replaced or for which remediation was taken after inspection, including a description of the remediation taken.

Poles needing Remediation					
Year	Total Inspection Poles Failing Inspection	Priority Replacement (Complete)	Restoration (Complete) C-Truss	Work Orders Generated for Replacement	Work Orders Completed
2022	24	24	0	24	538
2020-2021	377	4	16	361	316
2019	372	17	29	343	32
2018	167	4	29	138	72
2017	27	2	0	27	35
2016	58	3	7	51	72
2015	97	15	9	88	195
2014	145	2	3	142	479
2013	352	5	56	296	282
2012	396	8	10	386	456
2011	600	2	66	532	267
2010	642	7	121	514	435

OUC changed out 538 wood poles that were identified on previous years' inspections during 2022 time period.

5) Vegetation Management

- a) *Utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.*

Maintenance Guidelines and Procedures

The Orlando Utilities Commission (OUC) provides essential electrical service closely tied to our communities' safety, economy and welfare. In delivering reliable electrical service OUC manages the vegetation for approximately 1323 miles of overhead distribution lines and 222 miles of transmission lines within Orange and Osceola Counties. Vegetation line clearance of distribution facilities are trimmed on a three year maintenance cycle. Transmission right of ways' are maintained in two sub-divided regions, urban right of way on an annual cycle, and rural on a three year cycle. Measures to ensure our vegetation program is sufficient and remains on schedule, comprise of annual inspections of the distribution and transmission system.

OUC follows pruning and safety methods outlined in American National Standards Institute A300 and Z133.1. A three-year maintenance cycle of distribution facilities anticipates an average annual growth of 2.5 feet. Trees in close proximity of distribution facilities are trimmed to a minimum distance of 10 feet clearance from energized un-insulated conductors. Fast growing invasive species are trimmed to a greater distance of 15 feet or targeted for removal during distribution pruning. This proactive measure relieves future trimming requirements and ensures clearances within the cycle will be maintained.

The distribution three year cycle is divided into over 197 distribution segments reviewed on a quarterly basis. The review is used to make adjustments to crew resources to remain on cycle. OUC currently procures vegetation maintenance labor and equipment through a contract with Davey Tree Experts and Asplundh Tree Experts. The contract comprises ten to twenty production line trimming crews used in distribution and transmission line clearance.

Vegetation pruning requests are tracked using an internal CIS (customer information system) available in the distribution operations, customer service, construction and maintenance area. Requests generated from a system outage are either trimmed immediately or given a work order priority for completion. The general foreman provides additional feedback if additional area trimming is needed.

Appropriate Planting

OUC outlines appropriate planting through educational information presented by the Florida Urban Forestry Council. The council presents a theme “Right Tree in the Right Place” to ensure proper distance between trees and power lines. By practicing proper planting our goals to ensure safety, reliability and lowered maintenance costs become factors which all of our customers benefit.

Vegetation located outside of the right of way is pruned to a distance 10’ from energized conductors. The “Right Tree Right Place” concept is reviewed in cases where removals may become prudent. OUC annually sponsors tree planting events during Arbor Day to promote proper planting.

Measures to Ensure Sufficient Vegetation Management

OUC has applied a Reliability Centered Maintenance (RCM) approach from NFPA 70B to assure our vegetation management practices area sufficient. An annual inspection of all main feeder distribution lines is conducted to survey acceptable clearances in distribution system throughout the three-year treatment plan. The RCM inspections document vegetation to conductor distances with less than one year’s anticipated growth (2.5’). Vegetation work orders are generated and completed during seasonal non-peak time frame to ensure electrical system is fully prepared for the Florida summer storm season.

Two measures are used to verify sufficient vegetation management in our maintenance cycle.

1. The documented number of RCM clearances are compared against the trim cycle order. (A circuit about to be trimmed is expected to have more areas of clearance.)
2. Outage Management System (OMS) indices relating to sustained and momentary outages are also compared to the trim cycle order.

b) Quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities.

Vegetation Management Annual Plan

The 2022 annual plan was to trim 418 miles of distribution and 107 miles of transmission ROW. OUC had two suppliers at the beginning of 2022. In May 2022 one supplier left system due falling behind on the distribution trimming schedule and performance issues. OUC’s remaining supplier assumed the additional distribution mileage and brought additional resources on system and has completed 94% of the 2022 distribution mileage.

OUC plans to continue with treatment of 425 miles of distribution line clearance and 99 miles of transmission ROW to remain on established cycles in 2023. Treatment of distribution line clearance will consist of bucket and rear lot climbing crews. Treatment of the transmission rural corridors, conducted on a three-year cycle, are maintained using a combination of integrated vegetation management (IVM). Transmission urban corridors are maintained annually with a more traditional pruning and removal maintenance methods.

* OUC's Transmission Vegetation Management Plan (TVMP) allows until May 30th 2023 for completion.

Vegetation Treatment				
Year	Distribution Total System Miles 1323		Transmission Total System Miles 213 (Urban-Annual, Rural 3 Year Cycle)	
	Planned	Completed	Planned	Completed
2022	418	94%	107	100%
2021	193	100%	112	100%
2020	446	78%	99	100%
2019	426	94%	107	100%
2018	421	100%	112	100%
2017	450	100%	99	100%
2016	333	100%	107	100%
2015	335	100%	88	100%
2014	328	100%	99	100%
2013	287	100%	107	100%
2012	332	100%	127	100%
2011	312	100%	107	100%
2010	329	100%	99	100%
2009	328	100%	105	100%
2008	330	100%	99	100%
2007	330	100%	114	100%

6) Storm Hardening Research

Orlando Utilities Commission is a member of the Florida Municipal Electric Association (FMEA), which is participating with all of Florida's electric utilities in storm hardening research through the Public Utility Research Center at the University of Florida. Under separate cover, FMEA is providing the FPSC with a report of research activities. For further information, contact Amy Zubaly, Executive Director, FMEA, 850-224-3314, ext.1001, or azubaly@publicpower.com.