

(Name of City/Utility)
Report to the Florida Public Service Commission Pursuant to
Rule 25-6.0343, F.A.C.
Calendar Year 2022

1. Introduction

- a) Reedy Creek Improvement District
- b) 1900 Hotel Plaza Blvd., Lake Buena Vista, FL 32830
- c) John H. Classe, Jr., District Administrator, 407-934-7480, Fax: 407-934-6200, jclasse@rcid.org
- d) For information regarding this submission please contact Paul Chen, Team Lead Power Delivery & Electric Operations, Reedy Creek Energy Services, 407-824-7127, paul.x.chen@disney.com

2. Number of meters served in calendar year 2022

Reedy Creek Improvement District had 1,529 electric meters served in 2022.

3. Facility Inspections

The Reedy Creek Improvement District's 69kV "transmission system" (Note: For the purposes of this report, transmission is defined as 69kV and distribution is defined as 12.5kV. RCID is not a Transmission Owner or Transmission Operator as defined by NERC.) has no wooden poles in service. All 69kV "transmission system" poles are constructed of concrete or steel. The system includes approximately 14 miles of overhead transmission right-of-ways. The District's 12.5kV "distribution system" is essentially an underground system with a very limited amount of overhead. The overhead distribution includes only 7 wood poles with the remainder of the distribution overhead on concrete or steel poles.

- a) **Describe the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.**

The District's overhead transmission system is ridden monthly by Utility Division personnel for the purpose of performing a basic visual inspection of the condition of the poles, lines and right-of-ways. Distribution wood poles are inspected every 8 years.

- b) **Describe the number and percentage of transmission and distribution inspections planned and completed for 2022.**

All distribution wood poles were inspected and treated by an outside contractor in 2021.

- c) Describe the number and percentage of transmission poles and structures and distribution poles failing inspection in 2022 and the reason for the failure.**

All distribution poles passed inspection.

- d) Describe the number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection in 2022, including a description of the remediation taken.**

Based on the 2021 condition assessment and the lack of any wood transmission poles, the next wood pole inspections are not scheduled until 2029.

4. Vegetation Management

- a) Describe the utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.**

The Reedy Creek Improvement District's approximately 14 miles of overhead transmission right-of-ways are ridden monthly by Utility Division personnel for the purpose of visual inspection, including vegetation issues. The District contracts tree trimming services (as required) to clear any issues existing on District right-of-ways. The District also proactively contracts tree trimming services to perform long-term vegetation cutbacks within District right-of-ways. Limited vegetation areas exist within the District distribution system and these limited areas on the distribution system are maintained along with the transmission system program.

- b) Describe the quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities in 2022.**

Monthly inspections conducted in 2022 of the District's right-of-ways yielded minimal instances of vegetation encroachment upon District transmission or distribution assets. In each scenario, tree trimming services were engaged to remove any concerns. The District continues to perform long-term vegetation cutbacks within District right-of-ways to ensure all clearances remain within acceptable tolerances.