

This filing is submitted in response to Commission Rule 25-6.0343 Municipal Electric Utility and Rural Electric Cooperative Reporting Requirements on behalf of Central Florida Tourism Oversight District. The electronic file is in Adobe Acrobat format and is a total of 4 pages in length. The report responds to each of the required subsections of the previously stated rule.

Respectfully,

Paul Chen  
Team Lead, Power Delivery & Electric Operations  
Reedy Creek Energy Services  
5300 Center Drive  
Lake Buena Vista, FL 32803  
Office: 407-824-7127  
e-mail: paul.x.chen@disney.com

# **Central Florida Tourism Oversight District Report to the Florida Public Service Commission Pursuant to Rule 25-6.0343, F.A.C. Calendar Year 2023**

## **1) Introduction**

- a) Central Florida Tourism Oversight District
- b) 1900 Hotel Plaza Blvd., Lake Buena Vista, FL 32830
- c) Glenton Gilzean, Jr., District Administrator, 407-934-7480, Fax: 407-934-6200
- d) For information regarding this submission please contact Paul Chen, Team Lead of Power Delivery & Electric Operations, Reedy Creek Energy Services, 407-824-7127, paul.x.chen@disney.com

## **2) Number of customers served in calendar year 2023**

Central Florida Tourism Oversight District had 1,422 electric customers in 2023.

## **3) Standards of Construction**

- a) National Electric Safety Code Compliance

Construction standards, policies, guidelines, practices, and procedures at the Central Florida Tourism Oversight District (the “District”) comply with the National Electrical Safety Code (ANSI C-2) [NESC]. For electrical facilities constructed on or after January 1, 2017, the 2017 NESC applies. The edition of the NESC in effect at the time of the facility’s initial construction governs electrical facilities constructed prior to January 1, 2017.

- b) Extreme Wind Loading Standards

Construction standards, policies, guidelines, practices, and procedures at the Central Florida Tourism Oversight District are guided by the extreme wind loading standards specified by <http://windspeed.atcouncil.org> as recommended by the 2017 NESC for 1) new construction; 2) major planned work, including expansion, rebuild, or relocation of existing facilities, assigned on or after December 10, 2006; and 3) targeted critical infrastructure facilities and major thoroughfares. The District is primarily an underground utility by standard design with less than 2 miles of overhead distribution lines and approximately 297 total miles of distribution lines.

c) Flooding and Storm Surges

Electrical construction standards, policies, guidelines, practices, and procedures at the Central Florida Tourism Oversight District address the effects of flooding on underground distribution facilities and supporting overhead facilities. Storm surges do not apply to the District as it is located in Central Florida 60 miles away from the nearest coastal areas. The District has no underground vault switchgear.

d) Safe and Efficient Access of New and Replacement Distribution Facilities

Electrical construction standards, policies, guidelines, practices, and procedures at the Central Florida Tourism Oversight District provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance. Wherever new facilities are placed (i.e., front, back or side of property), all facilities are installed so that the District's facilities are accessible by its crews and vehicles to ensure proper maintenance/repair is performed as expeditiously and safely as possible. The District decides on a case-by-case basis whether existing facilities need to be relocated. If it is determined that facilities need to be relocated, they will be placed in the safest, most accessible area available.

e) Attachments by Others

Central Florida Tourism Oversight District does not have any foreign attachments on its facilities.

#### 4) Facility Inspections

The Central Florida Tourism Oversight District's 69kV "transmission system" (Note: For the purposes of this report, transmission is defined as 69kV and distribution is defined as 12.5kV. The District is not a Transmission Owner or Transmission Operator as defined by NERC.) has no wooden poles in service. All 69kV "transmission system" poles are constructed of concrete or steel. The system includes approximately 14 miles of overhead transmission right-of-way. The District's 12.5kV "distribution system" is essentially an underground system with a very limited amount of overhead. The overhead distribution includes only 7 wood poles with the remainder of the distribution overhead on concrete or steel poles.

- a) The District's overhead transmission system is ridden monthly by Utility Division personnel for the purpose of performing a basic visual inspection of the condition of the poles, lines and rights-of-way. Distribution wood poles are inspected every 8 years.
- b) All distribution wood poles were inspected and treated by an outside contractor in 2021.
- c) All distribution poles passed inspection.
- d) Based on the 2021 condition assessment and the lack of any wood transmission poles, the next wood pole inspections are not scheduled until 2029.

## 5) Vegetation Management

- a) The Central Florida Tourism Oversight District's approximately 14 miles of overhead transmission rights-of-way are ridden monthly by Utility Division personnel for the purpose of visual inspection, including vegetation issues. The District contracts tree trimming services (as required) to clear any issues existing on District rights-of-way. The District also proactively contracts tree trimming services to perform long-term vegetation cutbacks within District rights-of-ways. Limited vegetation areas exist within the District distribution system and these limited areas on the distribution system are maintained along with the transmission system program.
- b) Monthly inspections conducted in 2023 of the District's rights-of-way yielded minimal instances of vegetation encroachment upon District transmission or distribution assets. In each scenario, tree trimming services were engaged to remove any concerns. The District continues to perform long-term vegetation cutbacks within District rights-of-way to ensure all clearances remain within acceptable tolerances.

The Public Utility Research Center has held two vegetation management workshops in 2007 and 2009. Through FEMA, Central Florida Tourism Oversight District has a copy of their reports and will use the information to continually improve vegetation management practices. We will participate in future best-practice workshops if there is interest.

## 6) Storm Hardening Research

Central Florida Tourism Oversight District is a member of the Florida Municipal Electric Association (FMEA), which is participating with all of Florida's electric utilities in storm hardening research through the Public Utility Research Center at the University of Florida. Under separate cover, FMEA is providing the FPSC with a report of research activities. For further information, contact Amy Zubaly, Executive Director, FMEA, 850-224-3314, ext. 1001, or [azubaly@flpublicpower.com](mailto:azubaly@flpublicpower.com).