

**(Name of City/Utility)**  
**Report to the Florida Public Service Commission Pursuant to**  
**Rule 25-6.0343, F.A.C.**  
**Calendar Year 2025**

**1. Introduction**

- a) Name of city/utility  
City of Fort Meade
  
- b) Address, street, city, zip  
521 NW 4<sup>th</sup> Street Fort Meade Fl 33841
  
- c) Contact information: Name, title, phone, fax, email  
Steve Doyle, Electric Director, 863-344-0693, sdoyle@cityoffortmeade.org

**2. Number of meters served in calendar year 2025**

3025

**3. Facility Inspections**

- a) **Describe the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.**

Yearly Pole inspections no transmissions

- b) **Describe the number and percentage of transmission and distribution inspections planned and completed for 2025.**

2 circuits every year

Roughly 500 pole inspections 30% of the system

No transmission

- c) **Describe the number and percentage of transmission poles and structures and distribution poles failing inspection in 2025 and the reason for the failure.**

4 locations changed in 2025

No transmission

Age or end of life

- d) Describe the number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection in 2025, including a description of the remediation taken.**

All replaced that were found

#### **4. Vegetation Management**

- a) Describe the utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.**

All maintained with 6' clearance on both sides of the ground to sky where needed.

- d) Describe the quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities in 2025.**

Completed all distributions circuits and safety trimmed – completed for 2025-2026