

Ten-Year Site Plan: 2015-2024

City of Tallahassee Utilities



Photo: Substation 4

Report prepared by: City of Tallahassee Electric System Integrated Planning



CITY OF TALLAHASSEE
TEN YEAR SITE PLAN FOR ELECTRICAL GENERATING FACILITIES
AND ASSOCIATED TRANSMISSION LINES
2015-2024
TABLE OF CONTENTS

I. Description of Existing Facilities

1.0	Introduction	1
1.1	System Capability	1
1.2	Purchased Power Agreements	2
Figure A	Service Territory Map.....	3
Table 1.1	FPSC Schedule 1 Existing Generating Facilities.....	4

II. Forecast of Energy/Demand Requirements and Fuel Utilization

2.0	Introduction	5
2.1	System Demand and Energy Requirements.....	5
2.1.1	System Load and Energy Forecasts	5
2.1.2	Load Forecast Uncertainty & Sensitivities	8
2.1.3	Energy Efficiency and Demand Side Management Programs.....	9
2.2	Energy Sources and Fuel Requirements	12
Table 2.1	FPSC Schedule 2.1 History/Forecast of Energy Consumption (Residential and Commercial Classes).....	13
Table 2.2	FPSC Schedule 2.2 History/Forecast of Energy Consumption (Industrial and Street Light Classes).....	14
Table 2.3	FPSC Schedule 2.3 History/Forecast of Energy Consumption (Utility Use and Net Energy for Load)	15
Figure B1	Energy Consumption by Customer Class (2005-2024)	16
Figure B2	Energy Consumption: Comparison by Customer Class (2015 and 2024)	17
Table 2.4	FPSC Schedule 3.1.1 History/Forecast of Summer Peak Demand – Base Forecast.....	18
Table 2.5	FPSC Schedule 3.1.2 History/Forecast of Summer Peak Demand – High Forecast	19
Table 2.6	FPSC Schedule 3.1.3 History/Forecast of Summer Peak Demand – Low Forecast	20
Table 2.7	FPSC Schedule 3.2.1 History/Forecast of Winter Peak Demand – Base Forecast.....	21
Table 2.8	FPSC Schedule 3.2.2 History/Forecast of Winter Peak Demand – High Forecast.....	22
Table 2.9	FPSC Schedule 3.2.3 History/Forecast of Winter Peak Demand – Low Forecast	23
Table 2.10	FPSC Schedule 3.3.1 History/Forecast of Annual Net Energy for Load – Base Forecast	24
Table 2.11	FPSC Schedule 3.3.2 History/Forecast of Annual Net Energy for Load – High Forecast	25
Table 2.12	FPSC Schedule 3.3.3 History/Forecast of Annual Net Energy for Load – Low Forecast.....	26
Table 2.13	FPSC Schedule 4 Previous Year Actual and Two Year Forecast Demand/Energy by Month.....	27
Table 2.14	Load Forecast: Key Explanatory Variables	28
Table 2.15	Load Forecast: Sources of Forecast Model Input Information	29
Figure B3	Banded Summer Peak Load Forecast vs. Supply Resources	30
Table 2.16	Projected DSM Energy Reductions	31
Table 2.17	Projected DSM Seasonal Demand Reductions	32
Table 2.18	FPSC Schedule 5.0 Fuel Requirements	33
Table 2.19	FPSC Schedule 6.1 Energy Sources (GWh)	34
Table 2.20	FPSC Schedule 6.2 Energy Sources (%)	35
Figure B4	Generation by Fuel Type (2015 and 2024)	36

III. Projected Facility Requirements

3.1	Planning Process.....	37
3.2	Projected Resource Requirements	37
3.2.1	Transmission Limitations.....	37
3.2.2	Reserve Requirements	38
3.2.3	Recent and Near Term Resource Additions	38
3.2.4	Power Supply Diversity.....	39
3.2.5	Renewable Resources	41
3.2.6	Future Power Supply Resources.....	42
Figure C	System Peak Demands and Summer Reserve Margins	44
Table 3.1	FPSC Schedule 7.1 Forecast of Capacity, Demand and Scheduled Maintenance at Time of Summer Peak ...	45
Table 3.2	FPSC Schedule 7.2 Forecast of Capacity, Demand and Scheduled Maintenance at Time of Winter Peak.....	46
Table 3.3	FPSC Schedule 8 Planned and Prospective Generating Facility Additions and Changes	47
Table 3.4	Generation Expansion Plan	48

IV. Proposed Plant Sites and Transmission Lines

4.1	Proposed Plant Site.....	49
4.2	Transmission Line Additions/Upgrades	49
Table 4.1	FPSC Schedule 9 Status Report and Specifications of Proposed Generating Facilities.....	51
Figure D1	Hopkins Plant Site	52
Figure D2	Purdom Plant Site	52
Table 4.2	Planned Transmission Projects 2015-2024.....	53
Table 4.3	FPSC Schedule 10 Status Report and Spec. of Proposed Directly Associated Transmission Lines	54

Chapter I

Description of Existing Facilities

1.0 INTRODUCTION

The City of Tallahassee (“City”) owns, operates, and maintains an electric generation, transmission, and distribution system that supplies electric power in and around the corporate limits of the City. The City was incorporated in 1825 and has operated since 1919 under the same charter. The City began generating its power requirements in 1902 and the City's Electric Utility presently serves approximately 116,700 customers located within a 221 square mile service territory (see Figure A). The Electric Utility operates three generating stations with a total summer season net generating capacity of 746 megawatts (MW).

The City has two fossil-fueled generating stations, which contain combined cycle (CC), steam and combustion turbine (CT) electric generating facilities. The Sam O. Purdom Generating Station, located in the City of St. Marks, Florida has been in operation since 1952; and the Arvah B. Hopkins Generating Station, located on Geddie Road west of the City, has been in commercial operation since 1970. The City has also been generating electricity at the C.H. Corn Hydroelectric Station, located on Lake Talquin west of Tallahassee, since August of 1985.

1.1 SYSTEM CAPABILITY

The City maintains seven points of interconnection with Duke Energy Florida (“Duke”, formerly Progress Energy Florida); three at 69 kV, three at 115 kV, and one at 230 kV; and a 230 kV interconnection with Georgia Power Company (a subsidiary of the Southern Company (“Southern”)).

As shown in Table 1.1 (Schedule 1), 222 MW (net summer rating) of CC generation and 20 MW (net summer rating) of CT generation facilities are located at the City's Sam O. Purdom Generating Station. The Arvah B. Hopkins Generating Station includes 300 MW (net summer rating) of CC generation, 76 MW (net summer rating) of steam generation and 128 MW (net summer rating) of CT generation facilities.

The City's Hopkins 1 steam generating unit can be fired with natural gas. The CC and CT units can be fired on either natural gas or diesel oil but cannot burn these fuels concurrently. The total capacity of the three units at the C.H. Corn Hydroelectric Station is 11 MW. However, because the hydroelectric generating units are effectively run-of-river (dependent upon rainfall, reservoir and downstream conditions), the City considers these units as “energy only” and not as dependable capacity for planning purposes.


The City’s current total net summer installed generating capability is 746 MW. The corresponding winter net peak installed generating capability is 822 MW. Table 1.1 contains the details of the individual generating units.

1.2 PURCHASED POWER AGREEMENTS

The City has no long-term firm capacity and energy purchase agreements. Firm retail electric service is purchased from and provided by the Talquin Electric Cooperative (“Talquin”) to City customers served by the Talquin electric system. The projected amounts of electric service to be purchased from Talquin is included in the “Annual Firm Interchange” values provided in Table 2.19 (Schedule 6.1) Reciprocal service is provided to Talquin customers served by the City electric system. Payments for electric service provided to and received from Talquin and the transfer of customers and electric facilities is governed by a territorial agreement between the City and Talquin.

City of Tallahassee, Electric Utility

Service Territory Map



City Of Tallahassee

Schedule 1
Existing Generating Facilities
As of December 31, 2014

(1) Plant	(2) Unit No.	(3) Location	(4) Unit Type	(5) Fuel Pri	(6) Fuel Alt	(7) Fuel Transport Primary	(8) Fuel Transport Alternate	(9) Alt. Fuel Days Use	(10) Commercial In-Service Month/Year	(11) Expected Retirement Month/Year	(12) Gen. Max. Nameplate (kW)	(13) Net Capacity Summer (MW)	(14) Net Capacity Winter (MW)
Sam O. Purdom	8	Wakulla	CC	NG	FO2	PL	TK	[1, 2]	7/00	12/40	247,743	222	258 [7]
	GT-1		GT	NG	FO2	PL	TK	[1, 2]	12/63	10/16	15,000	10	10
	GT-2		GT	NG	FO2	PL	TK	[1, 2]	5/64	10/16	15,000	10	10
											Plant Total	242	278
A. B. Hopkins	1	Leon	ST	NG	NA	PL	NA	[3]	5/71	1/21	75,000	76	78
	2		CC	NG	FO2	PL	TK	[2]	6/08 [4]	Unknown	358,200 [5]	300	330 [7]
	GT-1		GT	NG	FO2	PL	TK	[2]	2/70	3/16	16,320	12	14
	GT-2		GT	NG	FO2	PL	TK	[2]	9/72	3/17	27,000	24	26
	GT-3		GT	NG	FO2	PL	TK	[2]	9/05	Unknown	60,500	46	48
	GT-4		GT	NG	FO2	PL	TK	[2]	11/05	Unknown	60,500	46	48
											Plant Total	504	544
C. H. Corn Hydro Station [6]	1	Leon	HY	WAT	WAT	WAT	WAT	NA	9/85	Unknown	4,440	0	0
	2		HY	WAT	WAT	WAT	WAT	NA	8/85	Unknown	4,440	0	0
	3		HY	WAT	WAT	WAT	WAT	NA	1/86	Unknown	3,430	0	0
											Plant Total	0	0
											Total System Capacity as of December 31, 2014	746	822

Notes

- [1] Due to the Purdom facility-wide emissions caps, utilization of liquid fuel at this facility is limited.
- [2] The City maintains a minimum distillate fuel oil storage capacity sufficient to operate the Purdom plant approximately 9 days and the Hopkins plant and approximately 3 days at maximum output.
- [3] Hopkins 1 is a "Gas Only" unit.
- [4] Reflects the commercial operations date of Hopkins 2 repowered to a combined cycle generating unit with a new General Electric Frame 7A combustion turbine. The original commercial operations date of the existing steam turbine generator was October 1977.
- [5] Hopkins 2 nameplate rating is based on combustion turbine generator (CTG) nameplate and modeled steam turbine generator (STG) output in a 1x1 combined cycle (CC) configuration with supplemental duct firing.
- [6] Because the C. H. Corn hydroelectric generating units are effectively run-of-river (dependent upon rainfall, reservoir and downstream conditions), the City considers these units as "energy only" and not as dependable capacity for planning purposes.
- [7] Summer and winter ratings are based on 95 °F and 29 °F ambient temperature, respectively.

CHAPTER II

Forecast of Energy/Demand Requirements and Fuel Utilization

2.0 INTRODUCTION

Chapter II includes the City's forecasts of demand and energy requirements, energy sources and fuel requirements. This chapter also explains the impacts attributable to the City's current Demand Side Management (DSM) plan. The City is not subject to the requirements of the Florida Energy Efficiency and Conservation Act (FEECA) and, therefore, the Florida Public Service Commission (FPSC) does not set numeric conservation goals for the City. However, the City expects to continue its commitment to the DSM programs that prove beneficial to the City's ratepayers.

2.1 SYSTEM DEMAND AND ENERGY REQUIREMENTS

Historical and forecast energy consumption and customer information are presented in Tables 2.1, 2.2 and 2.3 (Schedules 2.1, 2.2, and 2.3). Figure B1 shows the historical total energy sales and forecast energy sales by customer class. Figure B2 shows the percentage of energy sales by customer class (excluding the impacts of DSM) for the base year of 2015 and the horizon year of 2024. Tables 2.4 through 2.12 (Schedules 3.1.1 - 3.3.3) contain historical and base, high, and low forecasts of seasonal peak demands and net energy for load. Table 2.13 (Schedule 4) compares actual and two-year forecast peak demand and energy values by month for the 2014-2016 period.

2.1.1 SYSTEM LOAD AND ENERGY FORECASTS

The peak demand and energy forecasts contained in this plan are the results of the load and energy forecasting study performed by the City. The forecast is developed utilizing a methodology that the City first employed in 1980, and has since been updated and revised every one or two years. The methodology consists of nine multi-variable linear regression models and four models that utilize subjective escalation assumptions and known incremental additions. All

models are based on detailed examination of the system's historical growth, usage patterns and population statistics. Several key regression formulas utilize econometric variables.

Table 2.14 lists the econometric-based linear regression forecasting models that are used as predictors. Note that the City uses regression models with the capability of separately predicting commercial customers and consumption by rate sub-class: general service non-demand (GS), general service demand (GSD), and general service large demand (GSLD). These, along with the residential class, represent the major classes of the City's electric customers. In addition to these customer class models, the City's forecasting methodology also incorporates into the demand and energy projections estimated reductions from interruptible and curtailable customers. The key explanatory variables used in each of the models are indicated by an "X" on the table.

Table 2.15 documents the City's internal and external sources for historical and forecast economic, weather and demographic data. These tables summarize the details of the models used to generate the system customer, consumption and seasonal peak load forecasts. In addition to those explanatory variables listed, a component is also included in the models that reflect the acquisition of certain Talquin Electric Cooperative (Talquin) customers over the study period consistent with the territorial agreement negotiated between the City and Talquin and approved by the FPSC.

The customer models are used to predict the number of customers by customer class, which in turn serve as input into the customer class consumption models. The customer class consumption models are aggregated to form a total base system sales forecast. The effects of DSM programs and system losses are incorporated in this base forecast to produce the system net energy for load (NEL) requirements.

Since 1992, the City has used two econometric models to separately predict summer and winter peak demand. Table 2.14 also shows the key explanatory variables used in the demand models. The seasonal peak demand forecasts are developed first by forecasting expected system load factor. Based on the historical relationship of seasonal peaks to annual NEL, system load factors are projected separately relative to both summer and winter peak demand. The predictive variables for projected load factors versus summer peak demand include maximum summer temperature, maximum temperature on the day prior to the peak, annual degree-days cooling and real residential price of electricity. For projected load factors versus winter peak demand

minimum winter temperature, degree-days heating the day prior to the winter peak day, deviation from a base minimum temperature of 22 degrees and annual degree-days cooling are used as input. The projected load factors are then applied to the forecast of NEL to obtain the summer and winter peak demand forecasts.

Some of the most significant input assumptions for the forecast are the incremental load modifications at Florida State University (FSU), Florida A&M University (FAMU), Tallahassee Memorial Hospital (TMH) and the State Capitol Center. These four customers represented approximately 15% of the City's 2014 energy sales. Their incremental additions are highly dependent upon annual economic and budget constraints, which would cause fluctuations in their demand projections if they were projected using a model. Therefore, each entity submits their proposed incremental additions/reductions to the City and these modifications are included as submitted in the load and energy forecast.

The rate of growth in residential and commercial customers is driven by the projected growth in Leon County population. While population growth projections decreased in the years immediately following the 2008-2009 recession the current projection shows a slightly higher growth in population versus last year. Leon County population is projected to grow from 2015-2034 at an average annual growth rate (AAGR) of 0.80%. This growth rate is below that for the state of Florida (1.13%) but is higher than that for the United States (0.72%).

Total and per customer demand and energy requirements have also decreased in recent years. There are several reasons for this decrease including but not limited to the issuance of new or updated federal appliance and equipment efficiency standards since 2009 and the 2010 modifications to the State of Florida Energy Efficiency Code for Building Construction. The City's energy efficiency and demand-side management (DSM) programs (discussed in Section 2.1.3) and the economic conditions during and following the 2008-2009 recession have also contributed to these decreases. The decreases in per customer residential and commercial demand and energy requirements are projected to offset the increased growth rate in residential and commercial customers. Therefore, it is not expected that base demand and energy growth will return to pre-recession levels in the near future.

The City believes that the routine update of forecast model inputs, coefficients and other minor model refinements continue to improve the accuracy of its forecast so that they are more consistent with the historical trend of growth in seasonal peak demand and energy consumption.

The changes made to the forecast models for load and energy requirements have resulted in 2015 base forecasts for summer peak demand and annual sales/net energy for load that are generally the same as the corresponding 2014 base forecasts. The winter peak demand forecast has been increased so that the projection is more consistent with the historical trend of actual winter peak demands.

2.1.2 LOAD FORECAST UNCERTAINTY & SENSITIVITIES

To provide a sound basis for planning, forecasts are derived from projections of the driving variables obtained from reputable sources. However, there is significant uncertainty in the future level of such variables. To the extent that economic, demographic, weather, or other conditions occur that are different from those assumed or provided, the actual load can be expected to vary from the forecast. For various purposes, it is important to understand the amount by which the forecast can be in error and the sources of error.

To capture this uncertainty, the City produces high and low range results that address potential variance in driving population and economic variables from the values assumed in the base case. The base case forecast relies on a set of assumptions about future population and economic activity in Leon County. However, such projections are unlikely to exactly match actual experience.

Population and economic uncertainty tends to result in a deviation from the trend over the long term. Accordingly, separate high and low forecast results were developed to address population and economic uncertainty. These ranges are intended to capture approximately 80% of occurrences (i.e., +/- 1.3 standard deviations). The high and low forecasts shown in this year's report use statistics provided by Woods & Poole Economics, Inc. (Woods & Poole) to develop a range of potential outcomes. Woods & Poole publishes several statistics that define the average amount by which various projections they have provided in the past are different from actual results. The City's load forecasting consultant, Leidos Engineering, interpreted these statistics to develop ranges of the trends of economic activity and population representing approximately 80% of potential outcomes. These statistics were then applied to the base case to develop the high and low load forecasts presented in Tables 2.5, 2.6, 2.8, 2.9, 2.11 and 2.12 (Schedules 3.1.2, 3.1.3, 3.2.2, 3.2.3, 3.3.2 and 3.3.3).

Sensitivities on the peak demand forecasts are useful in planning for future power supply resource needs. The graph shown in Figure B3 compares summer peak demand (multiplied by 117% for reserve margin requirements) for the three forecast sensitivity cases with reductions from proposed DSM portfolio and the base forecast without proposed DSM reductions against the City's existing and planned power supply resources. This graph allows for the review of the effect of load growth and DSM performance variations on the timing of new resource additions. The highest probability weighting, of course, is placed on the base case assumptions, and the low and high cases are given a smaller likelihood of occurrence.

2.1.3 ENERGY EFFICIENCY AND DEMAND SIDE MANAGEMENT PROGRAMS

The City currently offers a variety of conservation and DSM measures to its residential and commercial customers, which are listed below:

<u>Residential Measures</u>	<u>Commercial Measures</u>
Energy Efficiency Loans	Energy Efficiency Loans
Gas New Construction Rebates	Demonstrations
Gas Appliance Conversion Rebates	Information and Energy Audits
Information and Energy Audits	Commercial Gas Conversion Rebates
Ceiling Insulation Grants	Ceiling Insulation Grants
Low Income Ceiling Insulation Grants	Solar Water Heater Rebates
Low Income HVAC/Water Heater Repair Grants	Solar PV Net Metering
Neighborhood REACH Weatherization Assistance	Demand Response (PeakSmart)
Energy Star Appliance Rebates	
High Efficiency HVAC Rebates	
Energy Star New Home Rebates	
Solar Water Heater Rebates	
Solar PV Net Metering	
Duct Leak Repair Grants	
Variable Speed Pool Pump Rebates	
Nights & Weekends Pricing Plan	

The City has a goal to improve the efficiency of customers' end-use of energy resources when such improvements provide a measurable economic and/or environmental benefit to the customers and the City utilities. During the City's last Integrated Resource Planning (IRP) Study potential DSM measures (conservation, energy efficiency, load management, and demand response) were tested for cost-effectiveness utilizing an integrated approach that is based on projections of total achievable load and energy reductions and their associated annual costs developed specifically for the City. The measures were combined into bundles affecting similar end uses and /or having similar costs per kWh saved.

In 2012 the City contracted with a consultant to review its efforts with DSM and renewable resources with a focus on adjusting resource costs for which additional investment and overall market changes impacted the estimates used in the IRP Study. DSM and renewable resource alternatives were evaluated on a levelized cost basis and prioritized on geographic and demographic suitability, demand savings potential and cost. From this prioritized list the consultant identified a combination of DSM and renewable resources that could be cost-effectively placed into service by 2016. The total demand savings potential for the resources identified compared well with that identified in the IRP Study providing some assurance that the City's ongoing DSM and renewable efforts remained cost-effective.

An energy services provider (ESP) is under contract to assist staff in deploying a portion of the City's DSM program. This contract was renewed for an additional nine-month term in September 2014 and the ESP's work continues. Staff has worked with consultants and the ESP to develop operational and pricing parameters, craft rate tariffs and solicit participants for a commercial DR/DLC program. This measure is currently at about 40% of targeted enrollment and the system is online. Implementation of the City's residential demand response/direct load control (DR/DLC) measures has been delayed as some of the technology to be employed is still evolving. Otherwise, work continues with the City's Neighborhood REACH measure and participation in the City's other existing DSM measures continues to increase. Future activities include development of residential DR/DLC and expanding commercial demand reduction and energy efficiency measure offerings.

As discussed in Section 2.1.1 the growth in customers and energy use has slowed in recent years due in part to the economic conditions observed during and following the 2008-2009 recession as well as due to changes in the federal appliance/equipment efficiency standards and state building efficiency code. It appears that many customers have taken steps on their own to

reduce their energy use and costs in response to the changing economy - without taking advantage of the incentives provided through the City's DSM program – as well as in response to the aforementioned standards and code changes. These “free drivers” effectively reduce potential participation in the DSM program in the future. And it is questionable whether these customers' energy use reductions will persist beyond the economic recovery. History has shown that post-recession energy use generally rebounds to pre-recession levels. In the meantime, however, demand and energy reductions achieved as a result of these voluntary customer actions as well as those achieved by customer participation in City-sponsored DSM measures appear to have had a considerable impact on forecasts of future demand and energy requirements.

Estimates of the actual demand and energy savings realized from 2007-2014 attributable to the City's DSM efforts are below those projected in the last IRP study. Due to reduced load and energy forecasts and based on the City's experience to date DSM program participation and thus associated demand and energy savings are not expected to increase as rapidly as originally projected, at least not in the near term. The latest projections reflect DSM savings increasing at a steady rate that is more consistent with historical experience and level of annual program expenditures to date.

Staff will continue to periodically review and, where appropriate, update technical and economic assumptions, expected demand and energy savings and re-evaluate the cost-effectiveness of current and prospective DSM measures. The City will provide further updates regarding its progress with and any changes in future expectations of its DSM program in subsequent TYSP reports.

Energy and demand reductions attributable to the DSM portfolio have been incorporated into the future load and energy forecasts. Tables 2.16 and 2.17 display, respectively, the cumulative potential impacts of the proposed DSM portfolio on system annual energy and seasonal peak demand requirements. Based on the anticipated limits on annual control events it is expected that DR/DLC will be predominantly utilized in the summer months. Therefore, Tables 2.7-2.9 and 2.17 reflect no expected utilization of DR/DLC capability to reduce winter peak demand.

2.2 ENERGY SOURCES AND FUEL REQUIREMENTS

Tables 2.18 (Schedule 5), 2.19 (Schedule 6.1), and 2.20 (Schedule 6.2) present the projections of fuel requirements, energy sources by resource/fuel type in gigawatt-hours, and energy sources by resource/fuel type in percent, respectively, for the period 2015-2024. Figure B4 displays the percentage of energy by fuel type in 2015 and 2024.

The City's generation portfolio includes combustion turbine/combined cycle, combustion turbine/simple cycle, conventional steam and hydroelectric units. The City's combustion turbine/combined cycle and combustion turbine/simple cycle units are capable of generating energy using natural gas or distillate fuel oil. This mix of generation types coupled with opportunities for firm and economy purchases from neighboring systems provides allows the City to satisfy its total energy requirements consistent with our energy policies that seek to balance the cost of power with the environmental quality of our community.

The projections of fuel requirements and energy sources are taken from the results of computer simulations using the PROSYM production simulation model (provided by Ventyx) and are based on the resource plan described in Chapter III.

City Of Tallahassee

**Schedule 2.1
History and Forecast of Energy Consumption and
Number of Customers by Customer Class**

Base Load Forecast

(1) Year	(2) Population [1]	(3) Members Per Household	Rural & Residential			(6) Average kWh Consumption Per Customer	(7) (GWh) [2]	Commercial [3]		(9) Average kWh Consumption Per Customer
			(4) (GWh) [2]	(5) Average No. of Customers	(8) Average No. of Customers					
2005	269,619	-	1,088	89,468	12,161	1,622	18,312	88,576		
2006	272,648	-	1,097	92,017	11,922	1,602	18,533	86,440		
2007	273,684	-	1,099	93,569	11,745	1,657	18,583	89,168		
2008	274,926	-	1,054	94,640	11,137	1,625	18,597	87,380		
2009	275,059	-	1,050	94,827	11,073	1,611	18,478	87,185		
2010	275,783	-	1,136	95,268	11,924	1,618	18,426	87,811		
2011	276,799	-	1,113	95,794	11,619	1,598	18,418	86,763		
2012	277,935	-	1,021	96,479	10,583	1,572	18,445	85,226		
2013	279,468	-	1,014	97,145	10,438	1,544	18,558	83,199		
2014	282,006	-	1,089	97,985	11,119	1,548	18,723	82,690		
2015	284,199	-	1,087	98,811	10,996	1,563	18,858	82,869		
2016	286,877	-	1,090	99,815	10,923	1,576	19,018	82,866		
2017	289,578	-	1,094	100,828	10,851	1,597	19,178	83,249		
2018	292,309	-	1,098	101,853	10,782	1,613	19,340	83,393		
2019	295,067	-	1,102	102,887	10,714	1,623	19,504	83,214		
2020	297,728	-	1,106	103,886	10,647	1,629	19,662	82,860		
2021	300,216	-	1,109	104,819	10,582	1,641	19,810	82,814		
2022	302,723	-	1,112	105,761	10,518	1,648	19,959	82,583		
2023	305,251	-	1,116	106,709	10,455	1,656	20,110	82,349		
2024	307,798	-	1,119	107,665	10,394	1,664	20,261	82,112		

[1] Population data represents Leon County population.

[2] Values include DSM Impacts.

[3] As of 2007 "Commercial" includes General Service Non-Demand, General Service Demand, General Service Large Demand, Interruptible (FSU and Goose Pond), Curtable (TMH), Traffic Control, Security Lights and Street & Highway Lights.

Table 2.1

City Of Tallahassee

**Schedule 2.2
History and Forecast of Energy Consumption and
Number of Customers by Customer Class**

Base Load Forecast

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
		Industrial					
<u>Year</u>	<u>(GWh)</u>	<u>Average No. of Customers</u> <u>[1]</u>	<u>Average kWh Consumption Per Customer</u>	<u>Railroads and Railways (GWh)</u> <u>[2]</u>	<u>Street & Highway Lighting (GWh)</u> <u>[2]</u>	<u>Other Sales to Public Authorities (GWh)</u> <u>[3]</u>	<u>Total Sales to Ultimate Consumers (GWh)</u> <u>[3]</u>
2005	-	-	-		14		2,724
2006	-	-	-		15		2,714
2007	-	-	-		0		2,756
2008	-	-	-		0		2,679
2009	-	-	-		0		2,661
2010	-	-	-		0		2,754
2011	-	-	-		0		2,711
2012	-	-	-		0		2,593
2013	-	-	-		0		2,558
2014	-	-	-		0		2,638
2015	-	-	-		0		2,649
2016	-	-	-		0		2,666
2017	-	-	-		0		2,691
2018	-	-	-		0		2,711
2019	-	-	-		0		2,725
2020	-	-	-		0		2,735
2021	-	-	-		0		2,750
2022	-	-	-		0		2,761
2023	-	-	-		0		2,772
2024	-	-	-		0		2,783

[1] Average end-of-month customers for the calendar year.

[2] As of 2007 Security Lights and Street & Highway Lighting use is included with Commercial on Schedule 2.1.


[3] Values include DSM Impacts.

City Of Tallahassee**Schedule 2.3
History and Forecast of Energy Consumption and
Number of Customers by Customer Class****Base Load Forecast**

(1) Year	(2) Sales for Resale (GWh)	(3) Utility Use & Losses (GWh)	(4) Net Energy for Load (GWh) [1]	(5) Other Customers (Average No.)	(6) Total No. of Customers [2]
2005	0	163	2,887	0	107,780
2006	0	154	2,868	0	110,550
2007	0	158	2,914	0	112,152
2008	0	155	2,834	0	113,237
2009	0	140	2,801	0	113,305
2010	0	177	2,931	0	113,694
2011	0	88	2,799	0	114,212
2012	0	117	2,710	0	114,924
2013	0	126	2,684	0	115,703
2014	0	114	2,751	0	116,708
2015	0	145	2,795	0	117,669
2016	0	146	2,812	0	118,833
2017	0	148	2,838	0	120,007
2018	0	149	2,860	0	121,193
2019	0	149	2,875	0	122,391
2020	0	150	2,885	0	123,548
2021	0	151	2,901	0	124,630
2022	0	151	2,912	0	125,720
2023	0	152	2,924	0	126,819
2024	0	153	2,935	0	127,926


[1] Values include DSM Impacts.

[2] Average number of customers for the calendar year.




Energy Consumption By Customer Class (Excluding DSM Impacts)

Calendar Year 2015



Total 2015 Sales = 2,659 GWh

Calendar Year 2024



Total 2024 Sales = 2,919 GWh

- | | | |
|----------------|---------------------|----------------------------------|
| □ Residential | ▣ Non-Demand | ▤ Demand |
| ▥ Large Demand | ▦ Curtail/Interrupt | ■ Traffic/Street/Security Lights |

City Of Tallahassee

**Schedule 3.1.1
History and Forecast of Summer Peak Demand
Base Forecast
(MW)**

(1) <u>Year</u>	(2) <u>Total</u>	(3) <u>Wholesale</u>	(4) <u>Retail</u>	(5) <u>Interruptible</u>	(6) Residential Load Management <u>[2]</u>	(7) Residential Conservation <u>[2], [3]</u>	(8) Comm./Ind Load Management <u>[2]</u>	(9) Comm./Ind Conservation <u>[2], [3]</u>	(10) Net Firm Demand <u>[1]</u>
2005	598		598						598
2006	577		577						577
2007	621		621						621
2008	587		587						587
2009	605		605						605
2010	601		601						601
2011	590		590						590
2012	557		557						557
2013	543		543						543
2014	567		567		0	1	0	0	565
2015	575		575		0	2	4	1	568
2016	581		581		3	4	6	3	566
2017	589		589		11	5	8	5	560
2018	596		596		16	7	10	8	556
2019	602		602		21	9	12	10	551
2020	608		608		23	11	12	13	551
2021	614		614		24	12	12	14	552
2022	620		620		24	13	12	16	554
2023	625		625		24	14	12	18	556
2024	631		631		24	16	13	20	558

[1] Values include DSM Impacts.

[2] Reduction estimated at busbar. 2014 DSM is actual at peak.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee
Schedule 3.1.2
History and Forecast of Summer Peak Demand
High Forecast
(MW)

(1) <u>Year</u>	(2) <u>Total</u>	(3) <u>Wholesale</u>	(4) <u>Retail</u>	(5) <u>Interruptible</u>	(6) Residential Load Management <u>[2]</u>	(7) Residential Conservation <u>[2], [3]</u>	(8) Comm./Ind Load Management <u>[2]</u>	(9) Comm./Ind Conservation <u>[2], [3]</u>	(10) Net Firm Demand <u>[1]</u>
2005	598		598						598
2006	577		577						577
2007	621		621						621
2008	587		587						587
2009	605		605						605
2010	601		601						601
2011	590		590						590
2012	557		557						557
2013	543		543						543
2014	567		567		0	1	0	0	565
2015	588		588		0	2	4	1	582
2016	598		598		3	4	6	3	583
2017	609		609		11	5	8	5	580
2018	620		620		16	7	10	8	580
2019	630		630		21	9	12	10	579
2020	640		640		23	11	12	13	582
2021	650		650		24	12	12	14	588
2022	659		659		24	13	12	16	593
2023	669		669		24	14	12	18	599
2024	678		678		24	16	13	20	606

[1] Values include DSM Impacts.

[2] Reduction estimated at busbar. 2014 DSM is actual at peak.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee
Schedule 3.1.3
History and Forecast of Summer Peak Demand
Low Forecast
(MW)

(1) <u>Year</u>	(2) <u>Total</u>	(3) <u>Wholesale</u>	(4) <u>Retail</u>	(5) <u>Interruptible</u>	(6) Residential Load Management <u>[2]</u>	(7) Residential Conservation <u>[2], [3]</u>	(8) Comm./Ind Load Management <u>[2]</u>	(9) Comm./Ind Conservation <u>[2], [3]</u>	(10) Net Firm Demand <u>[1]</u>
2005	598		598						598
2006	577		577						577
2007	621		621						621
2008	587		587						587
2009	605		605						605
2010	601		601						601
2011	590		590						590
2012	557		557						557
2013	543		543						543
2014	567		567	0	0	1	0	0	565
2015	561		561		0	2	4	1	555
2016	564		564		3	4	6	3	549
2017	568		568		11	5	8	5	539
2018	572		572		16	7	10	8	532
2019	574		574		21	9	12	10	523
2020	577		577		23	11	12	13	519
2021	579		579		24	12	12	14	517
2022	581		581		24	13	12	16	515
2023	582		582		24	14	12	18	513
2024	584		584		24	16	13	20	511

[1] Values include DSM Impacts.

[2] Reduction estimated at busbar. 2014 DSM is actual at peak.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee

**Schedule 3.2.1
History and Forecast of Winter Peak Demand
Base Forecast
(MW)**

(1) <u>Year</u>	(2) <u>Total</u>	(3) <u>Wholesale</u>	(4) <u>Retail</u>	(5) <u>Interruptible</u>	(6) Residential Load Management <u>[2], [3]</u>	(7) Residential Conservation <u>[2], [4]</u>	(8) Comm./Ind Load Management <u>[2], [3]</u>	(9) Comm./Ind Conservation <u>[2], [4]</u>	(10) Net Firm Demand <u>[1]</u>
2005 -2006	537		537						537
2006 -2007	528		528						528
2007 -2008	526		526						526
2008 -2009	579		579						579
2009 -2010	633		633						633
2010 -2011	584		584						584
2011 -2012	516		516						516
2012 -2013	480		480						480
2013 -2014	574		574						574
2014 -2015	558		558	0	0	2	0	0	556
2015 -2016	561		561	0	0	6	0	1	553
2016 -2017	568		568	0	0	9	0	3	557
2017 -2018	575		575	0	0	12	0	4	559
2018 -2019	581		581	0	0	15	0	5	561
2019 -2020	587		587	0	0	17	0	7	563
2020 -2021	593		593	0	0	19	0	8	566
2021 -2022	598		598	0	0	21	0	9	568
2022 -2023	604		604	0	0	23	0	11	570
2023 -2024	609		609	0	0	25	0	12	572
2024 -2025	614		614	0	0	27	0	13	574

[1] Values include DSM Impacts.

[2] Reduction estimated at busbar. 2014 DSM is actual at peak.

[3] Reflects no expected utilization of demand response (DR) resources in winter.

[4] 2014-2015 values reflect incremental increase from 2013-2014.

City Of Tallahassee
Schedule 3.2.2
History and Forecast of Winter Peak Demand
High Forecast
(MW)

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
<u>Year</u>	<u>Total</u>	<u>Wholesale</u>	<u>Retail</u>	<u>Interruptible</u>	Residential Load Management [2], [3]	Residential Conservation [2], [4]	Comm./Ind Load Management [2], [3]	Comm./Ind Conservation [2], [4]	Net Firm Demand [1]
2005 -2006	537		537						537
2006 -2007	528		528						528
2007 -2008	526		526						526
2008 -2009	579		579						579
2009 -2010	633		633						633
2010 -2011	584		584						584
2011 -2012	516		516						516
2012 -2013	480		480						480
2013 -2014	574		574						574
2014 -2015	558		558	0	0	2	0	0	556
2015 -2016	577		577	0	0	6	0	1	570
2016 -2017	588		588	0	0	9	0	3	576
2017 -2018	598		598	0	0	12	0	4	583
2018 -2019	608		608	0	0	15	0	5	588
2019 -2020	618		618	0	0	17	0	7	594
2020 -2021	627		627	0	0	19	0	8	600
2021 -2022	636		636	0	0	21	0	9	606
2022 -2023	645		645	0	0	23	0	11	612
2023 -2024	655		655	0	0	25	0	12	618
2024 -2025	664		664	0	0	27	0	13	624

[1] Values include DSM Impacts.

[2] Reduction estimated at customer meter. 2014 DSM is actual.

[3] Reflects no expected utilization of demand response (DR) resources in winter.

[4] 2014-2015 values reflect incremental increase from 2013-2014.

City Of Tallahassee
Schedule 3.2.3
History and Forecast of Winter Peak Demand
Low Forecast
(MW)

(1) <u>Year</u>	(2) <u>Total</u>	(3) <u>Wholesale</u>	(4) <u>Retail</u>	(5) <u>Interruptible</u>	(6) Residential Load Management <u>[2], [3]</u>	(7) Residential Conservation <u>[2], [4]</u>	(8) Comm./Ind Load Management <u>[2], [3]</u>	(9) Comm./Ind Conservation <u>[2], [4]</u>	(10) Net Firm Demand <u>[1]</u>
2005 -2006	537		537						537
2006 -2007	528		528						528
2007 -2008	526		526						526
2008 -2009	579		579						579
2009 -2010	633		633						633
2010 -2011	584		584						584
2011 -2012	516		516						516
2012 -2013	480		480						480
2013 -2014	574		574						574
2014 -2015	558		558	0	0	2	0	0	556
2015 -2016	544		544	0	0	6	0	1	537
2016 -2017	549		549	0	0	9	0	3	537
2017 -2018	552		552	0	0	12	0	4	536
2018 -2019	555		555	0	0	15	0	5	534
2019 -2020	557		557	0	0	17	0	7	533
2020 -2021	559		559	0	0	19	0	8	532
2021 -2022	561		561	0	0	21	0	9	530
2022 -2023	562		562	0	0	23	0	11	529
2023 -2024	563		563	0	0	25	0	12	527
2024 -2025	565		565	0	0	27	0	13	525

[1] Values include DSM Impacts.

[2] Reduction estimated at customer meter. 2014 DSM is actual.

[3] Reflects no expected utilization of demand response (DR) resources in winter.

[4] 2014-2015 values reflect incremental increase from 2013-2014.

City Of Tallahassee

**Schedule 3.3.1
History and Forecast of Annual Net Energy for Load
Base Forecast
(GWh)**

(1) <u>Year</u>	(2) <u>Total Sales</u>	(3) Residential Conservation <u>[2], [3]</u>	(4) Comm./Ind Conservation <u>[2], [3]</u>	(5) Retail Sales <u>[1]</u>	(6) <u>Wholesale</u>	(7) <u>Utility Use & Losses</u>	(8) Net Energy for Load <u>[1]</u>	(9) Load Factor % <u>[1]</u>
2005	2,724			2,724		163	2,887	55
2006	2,714			2,714		154	2,868	57
2007	2,756			2,756		158	2,914	54
2008	2,679			2,679		155	2,834	55
2009	2,661			2,661		140	2,801	53
2010	2,754			2,754		177	2,931	53
2011	2,711			2,711		88	2,799	54
2012	2,593			2,593		117	2,710	56
2013	2,558			2,558		126	2,684	56
2014	2,646	9	0	2,638		114	2,751	55
2015	2,659	9	2	2,649		145	2,795	56
2016	2,688	17	4	2,666		146	2,812	57
2017	2,724	26	8	2,691		148	2,838	58
2018	2,758	34	13	2,711		149	2,860	58
2019	2,787	43	19	2,725		149	2,875	58
2020	2,815	51	29	2,735		150	2,885	59
2021	2,843	60	34	2,750		151	2,901	59
2022	2,868	68	39	2,761		151	2,912	59
2023	2,894	77	45	2,772		152	2,924	59
2024	2,919	85	51	2,783		153	2,935	59

[1] Values include DSM Impacts.

[2] Reduction estimated at customer meter. 2014 DSM is actual.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee

**Schedule 3.3.2
History and Forecast of Annual Net Energy for Load
High Forecast
(GWh)**

(1) <u>Year</u>	(2) <u>Total Sales</u>	(3) <u>Residential Conservation [2], [3]</u>	(4) <u>Comm./Ind Conservation [2], [3]</u>	(5) <u>Retail Sales [1]</u>	(6) <u>Wholesale</u>	(7) <u>Utility Use & Losses</u>	(8) <u>Net Energy for Load [1]</u>	(9) <u>Load Factor % [1]</u>
2005	2,724			2,724		163	2,887	55
2006	2,714			2,714		154	2,868	57
2007	2,756			2,756		158	2,914	54
2008	2,679			2,679		155	2,834	55
2009	2,661			2,661		140	2,801	53
2010	2,754			2,754		177	2,931	53
2011	2,711			2,711		88	2,799	54
2012	2,593			2,593		117	2,710	56
2013	2,558			2,558		126	2,684	56
2014	2,646	9	0	2,638		114	2,751	55
2015	2,721	9	2	2,711		149	2,860	56
2016	2,766	17	4	2,745		151	2,895	57
2017	2,819	26	8	2,785		153	2,938	58
2018	2,869	34	13	2,822		155	2,977	58
2019	2,916	43	19	2,855		157	3,011	58
2020	2,962	51	29	2,882		158	3,040	58
2021	3,009	60	34	2,915		160	3,075	58
2022	3,051	68	39	2,943		161	3,105	58
2023	3,095	77	45	2,973		163	3,136	59
2024	3,140	85	51	3,003		165	3,168	59

[1] Values include DSM Impacts.

[2] Reduction estimated at customer meter. 2014 DSM is actual.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee

**Schedule 3.3.3
History and Forecast of Annual Net Energy for Load
Low Forecast
(GWh)**

(1) <u>Year</u>	(2) <u>Total Sales</u>	(3) <u>Residential Conservation [2], [3]</u>	(4) <u>Comm./Ind Conservation [2], [3]</u>	(5) <u>Retail Sales [1]</u>	(6) <u>Wholesale</u>	(7) <u>Utility Use & Losses</u>	(8) <u>Net Energy for Load [1]</u>	(9) <u>Load Factor % [1]</u>
2005	2,724			2,724		163	2,887	55
2006	2,714			2,714		154	2,868	57
2007	2,756			2,756		158	2,914	54
2008	2,679			2,679		155	2,834	55
2009	2,661			2,661		140	2,801	53
2010	2,754			2,754		177	2,931	53
2011	2,711			2,711		88	2,799	54
2012	2,593			2,593		117	2,710	56
2013	2,558			2,558		126	2,684	56
2014	2,646	9	0	2,638		114	2,751	55
2015	2,598	9	2	2,588		142	2,730	56
2016	2,610	17	4	2,588		142	2,730	57
2017	2,631	26	8	2,597		142	2,740	58
2018	2,648	34	13	2,601		143	2,744	58
2019	2,659	43	19	2,597		142	2,740	59
2020	2,670	51	29	2,590		142	2,732	59
2021	2,680	60	34	2,586		142	2,728	59
2022	2,688	68	39	2,581		142	2,722	59
2023	2,695	77	45	2,573		141	2,715	59
2024	2,702	85	51	2,565		141	2,706	59

[1] Values include DSM Impacts.

[2] Reduction estimated at customer meter. 2014 DSM is actual.

[3] 2014 values reflect incremental increase from 2013.

City Of Tallahassee**Schedule 4****Previous Year and 2-Year Forecast of Retail Peak Demand and Net Energy for Load by Month**

(1)	(2)	(3)	(4)	(5)	(6)	(7)
<u>Month</u>	2014 Actual		2015 Forecast [1][2]		2016 Forecast [1]	
	<u>Peak Demand</u> (MW)	<u>NEL</u> (GWh)	<u>Peak Demand</u> (MW)	<u>NEL</u> (GWh)	<u>Peak Demand</u> (MW)	<u>NEL</u> (GWh)
January	574	253	551	230	553	231
February	470	191	520	202	523	203
March	410	198	449	205	452	206
April	410	198	433	205	435	206
May	478	228	507	236	510	237
June	563	256	566	265	566	267
July	562	269	568	279	566	280
August	565	282	568	285	566	287
September	565	251	540	257	543	259
October	460	213	477	221	480	223
November	500	206	423	197	426	198
December	436	205	477	213	480	215
TOTAL		2,751		2,795		2,812

[1] Peak Demand and NEL include DSM Impacts.

[2] Represents forecast values for 2015.

City of Tallahassee, Florida
2015 Electric System Load Forecast

Key Explanatory Variables

Ln. No.	Model Name	Leon County Population	Residential Customers	Tallahassee			State of Florida Population	Minimum Maximum		Appliance Saturation	R Squared ^[1]
				Cooling Degree Days	Heating Degree Days	Per Capita Taxable Sales		Winter Peak day Temp.	Summer Peak day Temp.		
1	Residential Customers	X									0.998
2	Residential Consumption		X	X	X	X	X			X	0.936
3	General Service Non-Demand Customers		X								0.965
4	General Service Demand Customers		X								0.959
5	General Service Non-Demand Consumption	X		X	X	X					0.932
6	General Service Demand Consumption	X		X	X						0.956
7	General Service Large Demand Consumption	X		X	X						0.862
8	Summer Peak Demand						X		X		0.914
9	Winter Peak Demand			X	X			X			0.910

[1] R Squared, sometimes called the coefficient of determination, is a commonly used measure of goodness of fit of a linear model. If the observations fall on the model regression line, R Squared is 1. If there is no linear relationship between the dependent and independent variable, R Squared is 0. A reasonably good R Squared value could be anywhere from 0.6 to 1.


City of Tallahassee

2015 Electric System Load Forecast

Sources of Forecast Model Input Information

<u>Energy Model Input Data</u>	<u>Source</u>
1. Leon County Population	Bureau of Economic and Business Research
2. Talquin Customers Transferred	City Power Engineering
3. Cooling Degree Days	NOAA reports
4. Heating Degree Days	NOAA reports
5. AC Saturation Rate	Appliance Saturation Study
6. Heating Saturation Rate	Appliance Saturation Study
7. Real Tallahassee Taxable Sales	Florida Department of Revenue, CPI
8. Florida Population	Bureau of Economic and Business Research
9. State Capitol Incremental	Department of Management Services
10. FSU Incremental Additions	FSU Planning Department
11. FAMU Incremental Additions	FAMU Planning Department
12. GSLD Incremental Additions	City Utility Services
13. Other Commercial Customers	City Utility Services
14. Tall. Memorial Curtailable	System Planning/ Utilities Accounting.
15. System Peak Historical Data	City System Planning
16. Historical Customer Projections by Class	System Planning & Customer Accounting
17. Historical Customer Class Energy	System Planning & Customer Accounting
18. GDP Forecast	Blue Chip Economic Indicators
19. CPI Forecast	Blue Chip Economic Indicators
20. Interruptible, Traffic Light Sales, & Security Light Additions	System Planning & Customer Accounting
21. Historical Residential Real Price of Electricity	Calculated from Revenues, kWh sold, CPI
22. Historical Commercial Real Price Of Electricity	Calculated from Revenues, kWh sold, CPI

**Banded Summer Peak Load Forecast Vs. Supply Resources
(Load Includes 17% Reserve Margin)**



City Of Tallahassee

2015 Electric System Load Forecast

**Projected Demand Side Management
Energy Reductions [1]**

Calendar Year Basis

<u>Year</u>	Residential Impact <u>(MWh)</u>	Commercial Impact <u>(MWh)</u>	Total Impact <u>(MWh)</u>
2015	9,008	1,582	10,591
2016	18,017	4,537	22,554
2017	27,025	8,595	35,620
2018	36,034	13,633	49,667
2019	45,042	19,651	64,693
2020	54,051	30,077	84,128
2021	63,059	35,756	98,815
2022	72,068	41,600	113,668
2023	81,076	47,609	128,685
2024	90,084	53,783	143,868

[1] Reductions estimated at generator busbar.

City Of Tallahassee

2015 Electric System Load Forecast

**Projected Demand Side Management
Seasonal Demand Reductions [1]**

Year	Residential		Commercial		Residential		Commercial		Demand Side	
	<u>Summer</u>	<u>Winter</u>	<u>Summer</u>	<u>Winter</u>	<u>Summer</u>	<u>Winter</u>	<u>Summer</u>	<u>Winter</u>	<u>Summer</u>	<u>Winter</u>
	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)
	<u>Energy Efficiency</u>		<u>Energy Efficiency</u>		<u>Demand Response</u>		<u>Demand Response</u>		<u>Total</u>	
	<u>Impact</u>		<u>Impact</u>		<u>Impact</u>		<u>Impact</u>		<u>Impact</u>	
	2015-2016	2016-2017	2017-2018	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023	2023-2024	2024-2025
2015	2	6	1	1	0	0	4	0	6	7
2016	4	9	3	3	3	0	6	0	15	12
2017	5	12	5	4	11	0	8	0	29	16
2018	7	15	8	5	16	0	10	0	40	20
2019	9	17	10	7	21	0	12	0	51	24
2020	11	19	13	8	23	0	12	0	58	27
2021	12	21	14	9	24	0	12	0	63	30
2022	13	23	16	11	24	0	12	0	66	34
2023	14	25	18	12	24	0	12	0	69	37
2024	16	27	20	13	24	0	13	0	73	40

[1] Reductions estimated at busbar.

[2] Represents projected winter peak reduction capability associated with demand response (DR) resource. However, as reflected on Schedules 3.1.1-3.2.3 (Tables 2.4-2.9), DR utilization expected to be predominantly in the summer months.

City Of Tallahassee**Schedule 5
Fuel Requirements**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
	<u>Fuel Requirements</u>		<u>Units</u>	<u>Actual 2013</u>	<u>Actual 2014</u>	<u>2015</u>	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>
(1)	Nuclear		Billion Btu	0	0	0	0	0	0	0	0	0	0	0	0
(2)	Coal		1000 Ton	0	0	0	0	0	0	0	0	0	0	0	0
(3)	Residual	Total	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(4)		Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(5)		CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(7)		Diesel	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(8)	Distillate	Total	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(9)		Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(10)		CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(11)		CT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(12)		Diesel	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(13)	Natural Gas	Total	1000 MCF	21,648	22,250	20,928	20,972	21,016	21,191	21,216	21,321	21,285	21,337	21,397	21,503
(14)		Steam	1000 MCF	2,263	1,829	672	530	400	553	542	310	0	0	0	0
(15)		CC	1000 MCF	18,756	19,669	19,402	19,735	20,173	19,979	19,989	20,604	20,028	20,576	20,826	20,808
(16)		CT	1000 MCF	629	752	854	707	443	658	686	407	1,257	761	571	694
(17)		Diesel	1000 MCF	0	0	0	0	0	0	0	0	0	0	0	0
(18)	Other (Specify)		Trillion Btu	0	0	0	0	0	0	0	0	0	0	0	0

City Of Tallahassee

**Schedule 6.1
Energy Sources**


(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
	Energy Sources		Units	Actual 2013	Actual 2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
(1)	Annual Firm Interchange		GWh	1	0	25	26	26	26	27	28	28	27	28	29
(2)	Coal		GWh	0	0	0	0	0	0	0	0	0	0	0	0
(3)	Nuclear		GWh	0	0	0	0	0	0	0	0	0	0	0	0
(4)	Residual	Total	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(5)		Steam	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(7)		CT	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(8)		Diesel	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(9)	Distillate	Total	GWh	2	0	0	0	0	0	0	0	0	0	0	0
(10)		Steam	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(11)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(12)		CT	GWh	2	0	0	0	0	0	0	0	0	0	0	0
(13)		Diesel	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(14)	Natural Gas	Total	GWh	2,662	2,788	2,787	2,806	2,829	2,845	2,856	2,875	2,880	2,894	2,906	2,917
(15)		Steam	GWh	177	150	57	45	34	47	46	27	0	0	0	0
(16)		CC	GWh	2,433	2,566	2,646	2,687	2,748	2,729	2,737	2,805	2,747	2,814	2,846	2,844
(17)		CT	GWh	52	72	85	73	47	70	73	43	132	80	60	73
(18)		Diesel	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(19)	Hydro		GWh	23	20	14	14	14	14	14	14	14	14	14	14
(20)	Economy Interchange[1]		GWh	-3	-56	-31	-33	-30	-26	-23	-31	-21	-23	-24	-24
(21)	Renewables		GWh	0	0	0	0	0	0	0	0	0	0	0	0
(22)	Net Energy for Load		GWh	2,684	2,751	2,795	2,812	2,838	2,860	2,875	2,885	2,901	2,912	2,924	2,935

[1] Negative values reflect expected need to sell off-peak power to satisfy generator minimum load requirements, primarily in winter and shoulder months.


City Of Tallahassee

**Schedule 6.2
Energy Sources**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
	Energy Sources		Units	Actual 2013	Actual 2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
(1)	Annual Firm Interchange		%	0.0	0.0	0.9	0.9	0.9	0.9	0.9	1.0	1.0	0.9	0.9	1.0
(2)	Coal		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	Nuclear		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4)	Residual	Total	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)		Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)		CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)		CT	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)		Diesel	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9)	Distillate	Total	%	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(10)		Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(11)		CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(12)		CT	%	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(13)		Diesel	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(14)	Natural Gas	Total	%	99.2	101.3	99.7	99.8	99.7	99.5	99.4	99.6	99.3	99.4	99.4	99.4
(15)		Steam	%	6.6	5.5	2.0	1.6	1.2	1.6	1.6	0.9	0.0	0.0	0.0	0.0
(16)		CC	%	90.6	93.3	94.7	95.5	96.8	95.4	95.2	97.2	94.7	96.6	97.3	96.9
(17)		CT	%	1.9	2.6	3.0	2.6	1.6	2.4	2.5	1.5	4.6	2.8	2.1	2.5
(18)		Diesel	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(19)	Hydro		%	0.8	0.7	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
(20)	Economy Interchange		%	-0.1	-2.0	-1.1	-1.2	-1.1	-0.9	-0.8	-1.1	-0.7	-0.8	-0.8	-0.8
(21)	Renewables		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(22)	Net Energy for Load		%	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Generation By Resource/Fuel Type**Calendar Year 2015**

Total 2015 NEL = 2,795 GWh

Calendar Year 2024

Total 2024 NEL = 2,935 GWh

□ CC - Gas ■ Steam - Gas ■ CT/Diesel - Gas ■ Net Interchange ■ Hydro

Chapter III

Projected Facility Requirements

3.1 PLANNING PROCESS

In December 2006 the City completed its last comprehensive IRP Study. The purpose of this study was to review future DSM and power supply options that are consistent with the City's policy objectives. Included in the IRP Study was a detailed analysis of how the DSM and power supply alternatives perform under base and alternative assumptions.

The preferred resource plan identified in the IRP Study included the repowering of Hopkins Unit 2 to combined cycle operation, renewable energy purchases, a commitment to an aggressive DSM portfolio and the latter year addition of peaking resources to meet future energy demand.

Based on more recent information including but not limited to the updated forecast of the City's demand and energy requirements (discussed in Chapter II) the City has made revisions to its resource plan. These revisions will be discussed in this chapter.

3.2 PROJECTED RESOURCE REQUIREMENTS

3.2.1 TRANSMISSION LIMITATIONS

The City's projected transmission import capability continues to be a major determinant of the need for future power supply resource additions. The City's internal transmission studies have reflected a gradual deterioration of the system's transmission import (and export) capability into the future, due in part to the lack of investment in the regional transmission system around Tallahassee as well as the impact of unscheduled power flow-through on the City's transmission system. The City has worked with its neighboring utilities, Duke and Southern, to plan and maintain, at minimum, sufficient transmission import capability to allow the City to make emergency power purchases in the event of the most severe single contingency, the loss of the system's largest generating unit.

The prospects for significant expansion of the regional transmission system around Tallahassee hinges on the City's ongoing discussions with Duke and Southern, the Florida Reliability Coordinating Council's (FRCC) regional transmission planning process, and the evolving set of mandatory reliability standards issued by the North American Electric Reliability Corporation (NERC). Unfortunately, none of these efforts is expected to produce substantive improvements to the City's transmission import/export capability in the short-term. In consideration of the City's limited transmission import capability the results of the IRP Study and other internal analysis of options tend to favor local generation alternatives as the means to satisfy future power supply requirements. To satisfy load, planning reserve and operational requirements in the reporting period, the City may need to advance the in-service date of new power supply resources to complement available transmission import capability.

3.2.2 RESERVE REQUIREMENTS

For the purposes of this year's TYSP report the City uses a load reserve margin of 17% as its resource adequacy criterion. This margin was established in the 1990s then re-evaluated via a loss of load probability (LOLP) analysis of the City's system performed in 2002. The City periodically conducts LOLP analyses to determine if conditions warrant a change to its resource adequacy criteria. The results of recent LOLP analyses suggest that reserve margin may no longer be suitable as the City's sole resource adequacy criterion. This issue is discussed further in Section 3.2.4.

3.2.3 RECENT AND NEAR TERM RESOURCE ADDITIONS

At their October 17, 2005 meeting the City Commission gave the Electric Utility approval to proceed with the repowering of Hopkins Unit 2 to combined cycle operation. The repowering was completed and the unit began commercial operation in June 2008. The former Hopkins Unit 2 boiler was retired and replaced with a combustion turbine generator (CTG) and a heat recovery steam generator (HRSG). The Hopkins 2 steam turbine and generator is now powered by the steam generated in the HRSG. Duct burners have been installed in the HRSG to provide additional peak generating capability. The repowering project provides additional capacity as well as increased efficiency versus the unit's capabilities prior to the repowering

project. The repowered unit has achieved official seasonal net capacities of 300 MW in the summer and 330 MW in the winter.

No new resource additions are expected to be needed in the near term (2015-2019). Resource additions expected in the longer term (2020-2024) are discussed in Section 3.2.6, “Future Power Supply Resources”.

3.2.4 POWER SUPPLY DIVERSITY

Resource diversity, particularly with regard to fuels, has long been a priority concern for the City because of the system’s heavy reliance on natural gas as its primary fuel source. This issue has received even greater emphasis due to the historical volatility in natural gas prices. The City has addressed this concern in part by implementing an Energy Risk Management (ERM) program to limit the City’s exposure to energy price fluctuations. The ERM program established an organizational structure of interdepartmental committees and working groups and included the adoption of an Energy Risk Management Policy. This policy identifies acceptable risk mitigation products to prevent asset value losses, ensure price stability and provide protection against market volatility for fuels and energy to the City’s electric and gas utilities and their customers.

Other important considerations in the City’s planning process are the diversity of power supply resources in terms of their number, sizes and expected duty cycles as well as expected transmission import capabilities. To satisfy expected electric system requirements the City currently assesses the adequacy of its power supply resources versus the 17% load reserve margin criterion. But the evaluation of reserve margin is made only for the annual electric system peak demand and assuming all power supply resources are available. Resource adequacy must also be evaluated during other times of the year to determine if the City is maintaining the appropriate amount and mix of power supply resources.

Currently, about two-thirds of the City’s power supply comes from two generating units, Purdom 8 and Hopkins 2. The outage of either of these units can present operational challenges especially when coupled with transmission limitations (as discussed in Section 3.2.1). Further, the projected retirement of older generating units will reduce the number of power supply resources available to ensure resource adequacy throughout the reporting period. For these

reasons the City has evaluated alternative and/or supplemental probabilistic metrics to its current load reserve margin criterion, such as loss of load expectation (LOLE), that may better balance resource adequacy and operational needs with utility and customer costs. The results of this evaluation confirmed that the City's current capacity mix and limited transmission import capability are the biggest determinants of the City's resource adequacy and suggest that there are risks of potential resource shortfalls during periods other than at the time of the system peak demand. Therefore, the City's current deterministic load reserve margin criterion may need to be increased and/or supplemented by a probabilistic criterion that takes these issues into consideration. Toward this end the City began work on an economic resource adequacy study and this work is on-going. The study will give consideration to the capital carrying costs and potential production cost savings associated with new generating units, the costs associated with power purchases from the external bulk power market (including potential investments to improve transmission import transfer capability) during normal operations, emergencies and during periods of scarcity, and the cost of unserved energy from the customer's perspective. From the results the level of reserves that best balances resource adequacy and economics consistent with the City's risk tolerance will be identified. An update of the City's efforts in this regard will be provided in a future TYSP report(s).

Purchase contracts can provide some of the diversity desired in the City's power supply resource portfolio. The City's last IRP Study evaluated both short and long-term purchased power options based on conventional sources as well as power offers based on renewable resources. A consultant-assisted study completed in 2008 evaluated the potential reliability and economic benefits of prospectively increasing the City's transmission import (and export) capabilities. The results of this study indicate the potential for some electric reliability improvement resulting from the addition of facilities to achieve more transmission import capability. However, the study's model of the Southern and Florida markets reflects, as with the City's generation fleet, natural gas-fired generation on the margin the majority of the time. Therefore, the cost of increasing the City's transmission import capability would not likely be offset by the potential economic benefit from increased power purchases from conventional sources.

As an additional strategy to address the City's lack of power supply diversity, planning staff has investigated options for a significantly enhanced DSM portfolio. Commitment to this expanded DSM effort (see Section 2.1.3) and an increase in customer-sited renewable energy projects (primarily solar panels) improve the City's overall resource diversity. However, due to

limited availability and uncertain performance, studies indicate that DSM and solar projects would not improve resource adequacy (as measured by LOLE) as much as the addition of conventional generation resources.

3.2.5 RENEWABLE RESOURCES

The City believes that offering green power alternatives to its customers is a sound business strategy: it will provide for a measure of supply diversification, reduce dependence on fossil fuels, promote cleaner energy sources, and enhance the City's already strong commitment to protecting the environment and the quality of life in Tallahassee. As part of its continuing commitment to explore clean energy alternatives, the City has continued to invest in opportunities to develop viable solar photovoltaic (PV) projects as part of our efforts to offer "green power" to our customers.

The City continues to seek out suitable projects that utilize the renewable fuels available within the big bend and panhandle of Florida. Most recently the City has issued a request for proposals (RFP) for a purchase power agreement (PPA) for a 10 MW_{ac} utility scale solar PV project. It is expected that the project will be located within the City's service territory or adjacent to a City-owned facility. Due to the intermittent nature of solar PV the PPA will be for energy only and will not be considered firm capacity.

Although there are ongoing concerns regarding the potential impact on service reliability associated with reliance on a significant amount of intermittent resources like PV on the City's relatively small electric system, the City will continue to monitor the proliferation of PV and other intermittent resources and work to integrate them so that service reliability is not jeopardized.

As of the end of calendar year 2014 the City has a portfolio of 232 kW of solar PV operated and maintained by the Electric Utility and a cumulative total of 1,550 kW of solar PV has been installed by customers. The City promotes and encourages environmental responsibility in our community through a variety of programs available to citizens. The commitment to renewable energy sources (and particularly to solar PV) by its customers is made possible through the Go Green Tallahassee initiative, that includes many options related to becoming a greener community such as the City's Solar PV Net Metering offer. Solar PV Net

Metering promotes customer investment in renewable energy generation by allowing residential and commercial customers with small to moderate sized PV installations to return excess generated power back to the City at the full retail value.

In 2011, the City of Tallahassee signed contracts with SunnyLand Solar and Solar Developers of America (SDA) for over 3 MWs of solar PV. These demonstration projects are to be built within the City's service area and will utilize new technology pioneered by Florida State University. As of December 31, 2014 both of these projects continue to face delays due to manufacturing and development issues associated with the technology. Such delays are to be expected with projects involving the demonstration of emerging technologies. While the project developers have not announced a revised commercial operations date (COD), the City remains optimistic that the technology will mature into a viable energy resource. Until a new COD is announced, this will be the last reporting of these projects.



3.2.6 FUTURE POWER SUPPLY RESOURCES

The City currently projects that additional power supply resources will be needed to maintain electric system adequacy and reliability through the 2024 horizon year. The City has identified the need for additional capacity in the summer of 2021 following the retirement of Hopkins 1 (which has been delayed by one year) in order to satisfy its 17% reserve margin criterion. The timing, site, type and size of any new power supply resource may vary dependent upon the metric(s) used to determine resource adequacy and as the nature of the need becomes better defined. Any proposed addition could be a generator or a peak season purchase. Alternatively, the planned retirement of Hopkins 1 could be further postponed. The suitability of this resource plan is dependent on the performance of the City's DSM portfolio (described in Section 2.1.3 of this report) and the City's projected transmission import capability. If only 50% of the projected annual DSM peak demand reductions are achieved, the City would require about 3 MW of additional power supply resources to meet its planning reserve requirements in the summer of 2019.

The City continues to monitor closely the performance of the DSM portfolio and, as mentioned in Section 2.1.3, will be revisiting and, where appropriate, updating assumptions

regarding and re-evaluating cost-effectiveness of our current and prospective DSM measures. This will also allow a reassessment of expected demand and energy savings attributable to DSM.

Tables 3.1 and 3.2 (Schedules 7.1 and 7.2) provide information on the resources and reserve margins during the next ten years for the City's system. The City has specified its planned capacity changes on Table 3.3 (Schedule 8). These capacity resources have been incorporated into the City's dispatch simulation model in order to provide information related to fuel consumption and energy mix (see Tables 2.18, 2.19 and 2.20). Figure C compares seasonal net peak load and the system reserve margin based on summer peak load requirements. Table 3.4 provides the City's generation expansion plan for the period from 2015 through 2024.



City Of Tallahassee

Schedule 7.1

Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak [1]

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
Year	Total Installed Capacity (MW)	Firm Capacity Import (MW)	Firm Capacity Export (MW)	QF (MW)	Total Capacity Available (MW)	System Firm Summer Peak Demand (MW)	Reserve Margin Before Maintenance (MW)	Reserve Margin % of Peak	Scheduled Maintenance (MW)	Reserve Margin After Maintenance (MW)	Reserve Margin % of Peak
2015	746	0	0	0	746	568	178	31	0	178	31
2016	734	0	0	0	734	566	168	30	0	168	30
2017	690	0	0	0	690	560	130	23	0	130	23
2018	690	0	0	0	690	556	134	24	0	134	24
2019	690	0	0	0	690	551	139	25	0	139	25
2020	690	0	0	0	690	551	139	25	0	139	25
2021	660	0	0	0	660	552	108	20	0	108	20
2022	660	0	0	0	660	554	106	19	0	106	19
2023	660	0	0	0	660	556	104	19	0	104	19
2024	660	0	0	0	660	558	102	18	0	102	18

[1] All installed and firm import capacity changes are identified in the proposed generation expansion plan (Table 3.4).

City Of Tallahassee

Schedule 7.2

Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak [1]

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
<u>Year</u>	<u>Total Installed Capacity (MW)</u>	<u>Firm Capacity Import (MW)</u>	<u>Firm Capacity Export (MW)</u>	<u>QF (MW)</u>	<u>Total Capacity Available (MW)</u>	<u>System Firm Winter Peak Demand (MW)</u>	<u>Reserve Margin Before Maintenance (MW)</u>	<u>Reserve Margin After Maintenance (MW)</u>	<u>Scheduled Maintenance (MW)</u>	<u>Reserve Margin After Maintenance (MW)</u>	<u>% of Peak</u>
2015/16	808	0	0	0	808	553	255	46	0	255	46
2016/17	762	0	0	0	762	557	205	37	0	205	37
2017/18	762	0	0	0	762	559	203	36	0	203	36
2018/19	762	0	0	0	762	561	201	36	0	201	36
2019/20	762	0	0	0	762	563	199	35	0	199	35
2020/21	684	0	0	0	684	566	118	21	0	118	21
2021/22	732	0	0	0	732	568	164	29	0	164	29
2022/23	732	0	0	0	732	570	162	28	0	162	28
2023/24	732	0	0	0	732	572	160	28	0	160	28
2024/25	732	0	0	0	732	574	158	27	0	158	27

[1] All installed and firm import capacity changes are identified in the proposed generation expansion plan (Table 3.4).

City Of Tallahassee

**Schedule 8
Planned and Prospective Generating Facility Additions and Changes**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
<u>Plant Name</u>	<u>Unit No.</u>	<u>Location</u>	<u>Unit Type</u>	<u>Fuel Pri</u>	<u>Fuel Alt</u>	<u>Fuel Transportation Pri</u>	<u>Alt</u>	<u>Const. Start Mo/Yr</u>	<u>Commercial In-Service Mo/Yr</u>	<u>Expected Retirement Mo/Yr</u>	<u>Gen. Max. Nameplate (kW)</u>	<u>Net Capacity Summer (MW)</u>	<u>Net Capacity Winter (MW)</u>	<u>Status</u>
Hopkins	CT-1	Leon	GT	NG	DFO	PL	TK	NA	2/70	3/16	16,320	-12	-14	RT
Purdom	CT-1	Wakulla	GT	NG	DFO	PL	TK	NA	12/63	10/16	15,000	-10	-10	RT
Purdom	CT-2	Wakulla	GT	NG	DFO	PL	TK	NA	5/64	10/16	15,000	-10	-10	RT
Hopkins	CT-2	Leon	GT	NG	DFO	PL	TK	NA	9/72	3/17	27,000	-24	-26	RT
Hopkins	1	Leon	ST	NG	NA	PL	NA	NA	5/71	1/21	75,000	-76	-78	RT
Hopkins	5 [1]	Leon	CT	NG	DFO	PL	TK	5/17	3/21	NA	50,000	46	48	P

Acronyms

GT	Gas Turbine	Pri	Primary Fuel	kW	Kilowatts
ST	Steam Turbine	Alt	Alternate Fuel	MW	Megawatts
		NG	Natural Gas	RT	Existing generator scheduled for retirement.
		DFO	Diesel Fuel Oil	P	Planned for installation but not utility authorized. Not under construction.
		RFO	Residual Fuel Oil		
		PL	Pipeline		
		TK	Truck		

[1]

For the purposes of this report, the City has identified the addition of a GE LM 6000 combustion turbine generator (similar to the City's existing Hopkins CT3 and CT4) at its existing Hopkins Plant site. The timing, site, type and size of this new power supply resource may vary as the nature of the need becomes better defined. Alternatively, this proposed addition could be a generator(s) of a different type/size at the same or different location or a peak season purchase or the planned retirement of Hopkins 1 could be postponed.

City Of Tallahassee
Generation Expansion Plan

Year	Load Forecast & Adjustments				Existing Capacity Net (MW)	Firm Imports (MW)	Firm Exports (MW)	Resource Additions (Cumulative) (MW)	Total Capacity (MW)	Res %
	Forecast Peak Demand (MW)	DSM [1] (MW)	Peak Demand (MW)	Net (MW)						
2015	575	6	568	746		0			746	31
2016	581	15	566	734	[2,3]	0			734	30
2017	589	29	560	690	[4]	0			690	23
2018	596	40	556	690		0			690	24
2019	602	51	551	690		0			690	25
2020	608	58	551	690		0			690	25
2021	614	63	552	614	[5]	0		46	660	20
2022	620	66	554	614		0		46	660	19
2023	625	69	556	614		0		46	660	19
2024	631	73	558	614		0		46	660	18

Notes

[1] Demand Side Management includes energy efficiency and demand response/control measures.

[2] Hopkins CT 1 official retirement currently scheduled for March 2016.

[3] Purdom CTs 1 and 2 official retirement currently scheduled for October 2016.

[4] Hopkins CT 2 official retirement currently scheduled for March 2017.

[5] Hopkins ST 1 official retirement currently scheduled for January 2021.

[6] For the purposes of this report, the City has identified the addition of a GE LM 6000 combustion turbine generator (similar to the City's existing Hopkins CT3 and CT4) at existing Hopkins Plant site. The timing, site, type and size of this new power supply resource may vary as the nature of the need becomes better defined. Alternatively, this proposed addition could be a generator(s) of a different type/size at the same or different location or a peak season purchase or the planned retirement of Hopkins 1 could be postponed.

Chapter IV

Proposed Plant Sites and Transmission Lines

4.1 PROPOSED PLANT SITE

As discussed in Chapter 3 the City currently expects that additional power supply resources will be required in the reporting period to meet future system needs (see Table 4.1). For the purposes of this report, the City has identified the addition of a combustion turbine generator (similar to the City's existing Hopkins CT3 and CT4) at its existing Hopkins Plant site. The timing, site, type and size of this new power supply resource may vary as the nature of the need becomes better defined. Alternatively, this proposed addition could be a generator(s) of a different type/size at the same or different location or a peak season purchase or the planned retirement of Hopkins Unit 1 could be postponed.

4.2 TRANSMISSION LINE ADDITIONS/UPGRADES

Internal studies of the transmission system have identified a number of system improvements and additions that will be required to reliably serve future load. The majority of these improvements are planned for the City's 115 kV transmission network.

As discussed in Section 3.2, the City has been working with its neighboring utilities, Duke and Southern, to identify improvements to assure the continued reliability and commercial viability of the transmission systems in and around Tallahassee. At a minimum, the City attempts to plan for and maintain sufficient transmission import capability to allow for emergency power purchases in the event of the most severe single contingency, the loss of the system's largest generating unit. The City's internal transmission studies have reflected a gradual deterioration of the system's transmission import (and export) capability into the future. This reduction in capability is driven in part by the lack of investment in facilities in the panhandle region as well as the impact of unscheduled power flow-through on the City's transmission system. The City is committed to continue to work with Duke and Southern as well as existing and prospective regulatory bodies in an effort to pursue improvements to the regional transmission systems that will allow the City to continue to provide reliable and affordable

electric service to the citizens of Tallahassee in the future. The City will provide the FPSC with information regarding any such improvements as it becomes available.

Beyond assessing import and export capability, the City also conducts annual studies of its transmission system to identify further improvements and expansions to provide increased reliability and respond more effectively to certain critical contingencies both on the system and in the surrounding grid in the panhandle. These evaluations indicate that additional infrastructure projects are needed to address (i) improvements in capability to deliver power from the Hopkins Plant (on the west side of the City's service territory) to the load center, and (ii) the strengthening of the system on the east side of the City's service territory to improve the voltage profile in that area and enhance response to contingencies.

The City's transmission expansion plan includes a 230 kV loop around the City to be completed by Fall 2015 to address these needs and ensure continued reliable service consistent with current and anticipated FERC and NERC requirements. As the first phase of this transmission project, the City tapped its existing Hopkins-Duke Crawfordville 230 kV transmission line and extended a 230 kV transmission line to the east terminating at the existing Substation BP-5. The City next upgraded existing 115 kV line to 230 kV from Substation BP-5 to Substation BP-4 as the second phase of the project. As part of the second phase additional 230/115 kV transformation was placed in service at BP-4. The final phase of the project will be to upgrade the existing 115 kV line from Substation BP-4 to Substation BP-7 to 230 kV thereby completing the loop by Fall 2015. This new 230 kV loop would address a number of potential line overloads for the single contingency loss of other key transmission lines in the City's system. Table 4.2 summarizes the proposed new facilities or improvements from the transmission planning study that are within this Ten Year Site Plan reporting period.

The City's budget planning cycle for FY 2016 is currently ongoing, and any revisions to project budgets in the electric utility will not be finalized until the summer of 2015. Some of the construction of the aforementioned 230 kV transmission projects is currently underway. If these improvements do not remain on schedule the City has prepared operating solutions to mitigate adverse system conditions that might occur as a result of the delay in the in-service date of these improvements.

City Of Tallahassee**Schedule 9
Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number:	Hopkins 5	[1]
(2)	Capacity		
	a.) Summer:	46	
	b.) Winter:	48	
(3)	Technology Type:	CT	
(4)	Anticipated Construction Timing		
	a.) Field Construction start - date:	May-18	
	b.) Commercial in-service date:	Jan-21	
(5)	Fuel		
	a.) Primary fuel:	NG	
	b.) Alternate fuel:	DFO	
(6)	Air Pollution Control Strategy:	BACT compliant	
(7)	Cooling Status:	Unknown	
(8)	Total Site Area:	Unknown	
(9)	Construction Status:	Not started	
(10)	Certification Status:	Not started	
(11)	Status with Federal Agencies:	Not started	
(12)	Projected Unit Performance Data		
	Planned Outage Factor (POF):	5.77	
	Forced Outage Factor:	3.33	
	Equivalent Availability Factor (EAF):	89.57	
	Resulting Capacity Factor (%):	2.7	[2]
	Average Net Operating Heat Rate (ANOHR):	9,871	[3]
(13)	Projected Unit Financial Data		
	Book Life (Years)	30	
	Total Installed Cost (In-Service Year \$/kW)	1,248	[4]
	Direct Construction Cost (\$/kW):	1,076	[5]
	AFUDC Amount (\$/kW):	NA	
	Escalation (\$/kW):	172	
	Fixed O & M (\$kW-Yr):	7.70	[5]
	Variable O & M (\$/MWH):	16.23	[5]
	K Factor:	NA	

Notes

- [1] For the purposes of this report, the City has identified the addition of a GE LM 6000 combustion turbine generator (similar to the City's existing Hopkins CT3 and CT4) at its existing Hopkins Plant site. The timing, site, type and size of this new power supply resource may vary as the nature of the need becomes better defined. Alternatively, this proposed addition could be a generator(s) of a different type/size at the same or different location or a peak season purchase or the planned retirement of Hopkins 1 could be postponed.
- [2] Expected first year capacity factor.
- [3] Expected first year net average heat rate.
- [4] Estimated 2021 dollars.
- [5] Estimated 2015 dollars.

Figure D-1 – Hopkins Plant Site



Figure D-2 – Purdom Plant Site



City Of Tallahassee

Planned Transmission Projects, 2015-2024

<u>Project Type</u>	<u>Project Name</u>	<u>From Bus</u>		<u>To Bus</u>		<u>Expected In-Service Date</u>	<u>Voltage (kV)</u>	<u>Line Length (miles)</u>
New Lines	Line 55	Sub 14	7514	Sub 7	7507	10/31/16	115	6.0
	Line 17 [1]	Sub 4	7604	Sub 7	7607	10/31/15	230	3.8
Substations	Sub 22 (Bus 7522)	NA	NA	NA	NA	7/31/17	115	NA
	Sub 23 (Bus 7523)	NA	NA	NA	NA	7/31/16	115	NA

[1] The final phase of the 230 kV loop project. Current 115 kV line 17 will be operated at 230 kV after the respective in-service date.

City Of Tallahassee

**Schedule 10
Status Report and Specifications of Proposed
Directly Associated Transmission Lines**

(1)	Point of Origin and Termination:	Substation 5 - Substation 4 - Substation 7 [1]
(2)	Number of Lines:	1
(3)	Right-of -Way:	TAL Owned
(4)	Line Length:	12.8 miles
(5)	Voltage:	230 kV
(6)	Anticipated Capital Timing:	See note [2]; target in service 10/31/2015
(7)	Anticipated Capital Investment:	See note [2]
(8)	Substations:	See note [3]
(9)	Participation with Other Utilities:	None

Notes

- [1] Rebuilding/reconductoring existing Line 15A and Line 17 and changing operating voltage from 115 kV to 230 kV.
- [2] Anticipated capital investment associated with rebuilding/reconductoring associated existing transmission and substation facilities has not been segregated from that related to other improvements being made to these facilities for purposes other than that of establishing this 230 kV transmission line.
- [3] North terminus will be existing Substation 7; south terminus will be existing Substation 5; intermediate terminus will be existing Substation 4.