

# **Florida Public Service Commission 2017 Ten-Year Site Plan Workshop FRCC Presentation**

**Stacy Dochoda  
President and CEO**

**September 12, 2017**

# Agenda

## **FRCC Load & Resource Plan**

- Integrated Resource Planning Process
- Load Forecast and Demand-Side Management (DSM)
- Generation Additions and Reserve Margins
- Fuel Mix
- Renewable Resources
- Natural Gas Infrastructure in Florida

## **Reliability Assurance Process – FRCC**

- April 2017 Energy Alert

# Florida Reliability Coordinating Council

**Vision:** To maintain a highly reliable and secure  
bulk power system for peninsular Florida

## **2017 Load & Resource Plan Executive Summary**

- Firm peak demand forecasts slightly lower than 2016 TYSP
- Forecasted energy sales comparable to 2016 TYSP
- 9,200 MW of new firm generation planned over the forecast horizon
- Planned Reserve Margins at or above 20%
- Demand Side Management (DSM) projected to be a significant component of projected reserves


## **2017 Load & Resource Plan Executive Summary (cont.)**

- Changes to FRCC Region's fuel mix over the next ten years (as a % of total energy served):
  - Natural Gas increases from 63% to 67%
  - Renewable increases from 2% to 5%
  - Coal decreases from 19% to 12%
- Solar energy increases 7,600 GWh
- Third major natural gas pipeline in-service July 2017

# **FRCC Load & Resource Plan**


# Utility Integrated Resource Planning (IRP)

## Process Overview





## FRCC Planning Process Overview





## **Load Forecast and Demand-Side Management (DSM)**

- Firm peak demand forecasts slightly lower than 2016 TYSPs
  - Firm summer and winter peak demands grow 1.1% and 0.9% per year; respectively
- Forecasted energy sales comparable to 2016 TYSPs
  - Net Energy for Load grows 0.9% per year


## **Load Forecast and DSM (cont.)**

- Demand Response (DR) reduces firm summer peak (MW) by 6.3% on average
- Utility-sponsored Energy Efficiency/Energy Conservation (EE/EC) programs reduce summer peak (MW) by 1.4% by 2026
- Energy Efficiency delivered through mandated codes and standards reduces summer peak (MW) by at least 4.1% by 2026
- DSM is made up of DR and Utility-sponsored EE/EC
- Projected impacts of Energy Efficiency codes and standards included in all utilities' forecasts

## **Load Forecast Factors**

- Florida unemployment (actual) continues to decrease
- Population growth is projected to remain strong
- Actual employment growth remains healthy, but wage and income growth have not kept pace
- Increasing impacts from codes and standards and also (to a lesser extent) from customer-owned distributed generation (solar)
- Commercial customer base is being monitored due to challenges presented by online commerce

## Estimated Cumulative Impacts of Energy Efficiency Codes and Standards<sup>1/ 2/</sup>




	2017	2021	2026
Summer Peak Reduction (MW)	300	1,300	2,100
Winter Peak Reduction (MW)	100	700	1,300
Energy Use Reduction (GWh)	1,200	4,800	9,000

<sup>1/</sup> Two utilities provide estimates on the incremental (2017-on) impacts of Energy Efficiency codes and standards. These impacts were compared against peak and NEL for all utilities. The amounts above likely understate the full impact of code and standards – since not all utilities were able to estimate impacts.


<sup>2/</sup> For data and charts shown after this slide, Energy Efficiency codes and standards are embedded within utility load forecasts

## Comparison of 2016 vs. 2017 Firm Peak Demand Forecast<sup>1/</sup> (Summer)



<sup>1/</sup> Firm Peak Demand includes impacts of DSM (cumulative Demand Response and incremental (2017-on) utility sponsored Energy Efficiency/Energy Conservation) as well as Energy Efficiency Codes and Standards


## Comparison of 2016 vs. 2017 Firm Peak Demand Forecast<sup>1/</sup> (Winter)



<sup>1/</sup>Firm Peak Demand includes impacts of DSM (cumulative Demand Response and incremental (2017-on) utility sponsored Energy Efficiency/Energy Conservation) as well as Energy Efficiency Codes and Standards




## Comparison of 2016 vs. 2017 Net Energy for Load (NEL) Forecast



<sup>1/</sup> Firm Peak Demand includes impacts of DSM (cumulative Demand Response and incremental (2017-on) utility sponsored Energy Efficiency/Energy Conservation) as well as Energy Efficiency Codes and Standards



## Summer Peak Demands Actual and Forecasted<sup>1/</sup>




<sup>1/</sup> Projected impacts of Energy Efficiency codes and standards are included in all projections.

<sup>2/</sup> Impacts from cumulative Demand Response (DR) and incremental (2017-on) utility-sponsored Energy Efficiency/Energy Conservation (EE/EC) programs are excluded.

<sup>3/</sup> Linear trend based on actual peak demand from 1997 to 2016.


## Forecasted Summer Peak Demand<sup>1/</sup>



<sup>1/</sup> Projected impacts of Energy Efficiency codes and standards are included in all projections.

<sup>2/</sup> Impacts from cumulative Demand Response (DR) and incremental (2017-on) utility-sponsored Energy Efficiency/Energy Conservation (EE/EC) programs are excluded.

## Historical Compound Average Annual Growth Rate<sup>1/</sup> for Firm Peak Demand (MW)




<sup>1/</sup>Projected growth rate from prior forecasts

## **Generation Additions and Reserve Margins**

- 9,200 MW of new generation planned over the forecast horizon
- Planned Reserve Margins at or above 20%
- DSM projected to be a significant component of projected reserves

## Projected Total Available Capacity (Summer)



# Nuclear Outlook is Stable in 10-yr Horizon

## Existing<sup>1/</sup> Nuclear Capacity (Summer)

St. Lucie 1	981 MW
St. Lucie 2	986 MW
Turkey Point 3	811 MW
Turkey Point 4	<u>821 MW</u>
	<b>3,599 MW</b>


## Planned Nuclear Capacity (Summer)

Turkey Point 3 Upgrade (10/2018)	20 MW
Turkey Point 4 Upgrade (5/2019)	<u>20 MW</u>
	<b>40 MW</b>

<sup>1/</sup>Existing generation as of December 31, 2016



## Planned Reserve Margin<sup>1/2/</sup> (Based on Firm Load)




<sup>1/</sup> Projected impacts of Energy Efficiency codes and standards are included in all projections.

<sup>2/</sup> Impacts from cumulative Demand Response (DR) and incremental (2017-on) utility sponsored Energy Efficiency/Energy Conservation (EE/EC) programs are included.



# Planned Reserve Margin<sup>1/</sup>

(Excluding projected DR and Utility EE/EC Impacts)<sup>2/</sup>




<sup>1/</sup> Projected impacts of Energy Efficiency codes and standards are included in all projections.

<sup>2/</sup> Impacts from cumulative Demand Response (DR) and incremental (2017-on) utility sponsored Energy Efficiency/Energy Conservation (EE/EC) programs are excluded.

<sup>3/</sup> PSC stipulation and FRCC criteria are based on firm load as per slide 22. The values shown on this slide are solely for illustrative purposes.

# Demand Response as a Percentage of Peak Demand


## Summer 2017




Source: North American Electric Reliability Corporation's (NERC) 2017 Summer Reliability Assessment  
<http://www.nerc.com/pa/RAPA/ra/Reliability%20Assessments%20DL/2017%20Summer%20Assessment.pdf>

# Forecasted Fuel Mix

Summer Capacity<sup>1/</sup> (MW)



**2017**  
**55,120 MW**




**2026**  
**59,028 MW**


<sup>1/</sup> Only accounts for firm capacity

# Forecasted Fuel Mix

Net Energy for Load (GWh)




**2017**  
**230,868 GWh**




**2026**  
**250,948 GWh**

# Forecasted Renewable Mix

## Firm Summer Capacity (MW)




**2017**  
**713 MW**




**2026**  
**1,813 MW**

# Forecasted Renewable Mix

## Net Energy for Load (GWh)



**2017**  
**3,594 GWh**



**2026**  
**11,179 GWh**



## Natural Gas Infrastructure in Florida


- Three major pipelines supply natural gas to the region
  - Florida Gas Transmission
  - Gulfstream
  - Sabal Trail/Florida Southeast Connection
    - Commercial Operation Date: July 2017
- Gas infrastructure expansion and capabilities on pace with generation additions
- Over the 10-year forecast, natural gas generation with alternate fuel capabilities remains between 64-68%



## **2017 FRCC Fuel Reliability**

- **Fuel Reliability Working Group (FRWG)**
  - Reviews existing interdependencies of fuel availability and electric reliability
  - Coordinate regional responses to fuel issues and emergencies
  - Commission periodic studies and analysis on FRCC gas infrastructure
  - Report findings to FRCC Operating Committee


# Energy Production from Natural Gas<sup>1/</sup>



<sup>1/</sup>Extended nuclear outages for uprate work resulted in higher gas usage in 2012

# Natural Gas Alternate Fuel Capability

## Summer Capacity (MW)




# Third Gas Pipeline

(Commercial Operation Date: July 2017)

## Sabal Trail



## Florida Southeast Connection



# Natural Gas Storage Outside of Florida

- Florida utilities have contracts with NG storage facilities out of state
  - Currently have rights to approximately 9.4 Bcf of NG storage which can generate a total of 936 GWh of energy
  - Able to withdraw approximately 0.94 Bcf per day which can generate 93 GWh per day
  - Important tool to manage supply disruptions

# **Reliability Assurance Processes – FRCC**

**April 2017 Energy Alert**



# FRCC Generating Capacity Shortage Plan

- Revised Plan was transmitted to Commission staff in November 2016
  - Implemented by FRCC on April 1, 2017 and adopted by Commission rule April 19, 2017
  - Included conceptual and terminology changes regarding generating capacity shortages
  - Incorporated NERC Reliability Standard concept of “Energy Emergency Alerts”
  - Replaced previous plan phases on “Alerts” and “Emergency” declarations and focused “Advisory” declarations on winter conditions only

## Generating Capacity Advisory

- Declared by the FRCC RC when:
  - a) Low temperatures (Jacksonville  $\leq 21^{\circ}\text{F}$ , Tampa  $\leq 31^{\circ}\text{F}$ , or Miami  $\leq 40^{\circ}\text{F}$ ) or
  - b) Operating Margin  $< 2$  times the largest generating unit running or
  - c) State-wide fuel supply or delivery issues
- Note: A Generating Capacity Advisory does not indicate an imminent threat of an Energy Emergency

## **Energy Emergency Alerts (EEA)**

- EEA range in levels from low (1) to high (3)
- FRCC Operating Entities (OE) may implement the following during an Advisory or EEA to maintain reliability:
  - Awareness programs and public appeals to reduce demand
  - Demand Response (non-firm load)
  - Load conservation measures
  - Firm Load Interruption imminent or in progress to maintain load to generation balance and transmission system integrity
- Other OEs within the region communicate available generation capacity to assist

## **EEA Alert Levels**

- EEA – 1: All available resources in use
- EEA – 2: Load management procedures in effect
- EEA – 3: Firm load interruption imminent or in-progress

## **April 28, 2017 EEA-1 Declaration**

- At 12:43, FRCC RC declared an EEA-1 on behalf of one FRCC entity due to unexpected loss of generation and higher than normal forecasted peak loads
- Although additional generation became available prior to peak, the FRCC RC maintained the EEA-1 declaration over the peak
- At 17:00, the FRCC RC announced a return to normal operations

## Conclusion

- Based on 2017 TYSPs, planned Reserve Margins at or above 20% for all peak periods for the next ten years
  - DSM projected to be a significant component of projected reserves
  - Energy Efficiency codes and standards continue to affect demand and energy forecasts



## **Conclusion (cont.)**

- Changes to FRCC's fuel mix over the next ten years (as a % of total energy served):
  - Natural Gas increases from approximately 63% to 67%
  - Renewable increases from approximately 2% to 5%
  - Coal decreases from approximately 19% to 12%
- Gas infrastructure expansion and capabilities on pace with generation additions
- Peninsular Florida's natural gas pipeline capacity has increased to support electric generation

# Questions ?