



Matthew R. Bernier
ASSOCIATE GENERAL COUNSEL

April 1, 2019

VIA ELECTRONIC MAIL

Mr. Adam Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *2019 TYSP Supplemental Data Request #1*

Dear Mr. Teitzman:

Please find attached for filing on behalf of Duke Energy Florida, LLC, its response to question number 1 of the 2019 TYSP Supplemental Data Request #1 issued on February 1, 2019.

Thank you for your assistance in this matter. Please feel free to call me at (850) 521-1428 should you have any questions concerning this matter.

Respectfully,

/s/ Matthew R. Bernier

Matthew R. Bernier

MRB/mw
Attachment

cc: Doug Wright

**Duke Energy Florida, LLC's Response to Staff's
Supplemental Data Request #1 (No. 1)
re. Review of 2019 Ten-Year Site Plans for Florida's Electric Utilities**

General Items

1. Please provide an electronic copy of the Company's 2019–2028 Ten-Year Site Plan (2019 TYSP) in PDF format and the accompanying Schedules 1–10 in Microsoft Excel format.

Response: Please see the attached 2019 Ten Year Site Plan in pdf format and the accompanying schedules in Excel format.

Duke Energy Florida, LLC Ten-Year Site Plan

April 2019

2019-2028

**Submitted to:
Florida Public Service Commission**



TABLE OF CONTENTS

	Page
List of Required Schedules.....	iii
List of Tables and Figures.....	iv
Code Identification Sheet.....	v
Introduction.....	1
 <u>CHAPTER 1 DESCRIPTION OF EXISTING FACILITIES</u>	
Existing Facilities Overview.....	1-1
Service Area Map	1-2
Existing Generating Facilities (Schedule 1).....	1-3
 <u>CHAPTER 2 FORECAST OF ELECTRIC POWER DEMAND AND ENERGY CONSUMPTION</u>	
Overview.....	2-1
Energy Consumption and Demand Forecast Schedules.....	2-3
History and Forecast of Energy Consumption & Number of Customers by Customer Class (Sch. 2.1.1-2.3.3)..	2-4
History and Forecast of Base Summer Peak Demand (MW) (Sch. 3.1.1/3.1.2/3.1.3)... ..	2-13
History and Forecast of Base Winter Peak Demand (MW) (Sch. 3.2.1/3.2.2/3.2.3).....	2-16
History and Forecast of Base Annual Net Energy for Load (GWh) (Sch. 3.3.1/3.3.2/3.3.3)... ..	2-19
Previous Year Actual/Two-Year Forecast of Peak Demand/Net Energy for Load by Month (Sch. 4.1/4.2/4.3)...	2-22
Fuel Requirements and Energy Sources.....	2-25
Fuel Requirements (Sch. 5).....	2-26
Energy Sources (GWh) (Sch. 6.1).....	2-27
Energy Sources (Percent) (Sch. 6.2).....	2-28
Forecasting Methods and Procedures.....	2-29
Introduction.....	2-29
Forecast Assumptions.....	2-29
Customer, Energy, and Demand Forecast.....	2-30
General Assumptions.....	2-31
Economic Assumptions.....	2-33
Forecast Methodology.....	2-35
Energy and Customer Forecast.....	2-35
Peak Demand Forecast.....	2-39
High & Low Scenarios.....	2-40

TABLE OF CONTENTS (Continued)

Conservation	2-41
Residential Conservation Programs.....	2-41
Commercial/Industrial (C/I) Conservation Programs.....	2-43
Other DSM Programs	2-45

CHAPTER 3 FORECAST OF FACILITIES REQUIREMENTS

Resource Planning Forecast.....	3-1
Overview of Current Forecast.....	3-1
Total Capacity Resources Of Power Plants and Purchased Power Contracts (Table 3.1).....	3-4
Qualifying Facility Generation Contracts (Table 3.2).....	3-5
Forecast of Capacity, Demand and Scheduled Maintenance at Time of Summer Peak (Sch. 7.1).....	3-6
Forecast of Capacity, Demand and Scheduled Maintenance at Time of Winter Peak (Sch. 7.2).....	3-7
Planned and Prospective Generating Facility Additions and Changes (Sch. 8).....	3-8
Status Report and Specifications of Proposed Generating Facilities (Sch. 9).....	3-9
Status Report and Specifications of Proposed Directly Associated Transmission Lines (Sch. 10).....	3-31
Integrated Resource Planning Overview.....	3-32
Integrated Resource Planning (IRP) Process Overview	3-33
The Integrated Resource Planning (IRP) Process.....	3-34
Key Corporate Forecasts.....	3-36
Ten-year Site Plan (TYSP) Resource Additions.....	3-37
Renewable Energy.....	3-38
Plan Considerations.....	3-42
Transmission Planning.....	3-42

CHAPTER 4 ENVIRONMENTAL AND LAND USE INFORMATION

Preferred Sites.....	4-1
Debary Solar Power Plant.....	4-1
Trenton Solar Power Plant.....	4-3
Lake Placid Solar Power Plant.....	4-4
Columbia Solar Power Plant.....	4-5
St Petersburg Pier Solar Energy Center.....	4-6

LIST OF REQUIRED SCHEDULES

<u>Schedule</u>	<u>Page</u>
1 Existing Generating Facilities.....	1-3
2.1 History and Forecast of Energy Consumption and Number of Customers by Customer Class (Rural and Residential and Commercial) (B/H/L)	2-4
2.2 History and Forecast of Energy Consumption & Number of Customers by Customer Class (Industrial and Other) (B/H/L).....	2-7
2.3 History and Forecast of Energy Consumption & Number of Customers by Customer Class (Net Energy for Load) (B/H/L).....	2-10
3.1 History and Forecast of Summer Peak Demand (MW) – (B/H/L).....	2-13
3.2 History and Forecast of Winter Peak Demand (MW) – (B/H/L).....	2-16
3.3 History and Forecast of Annual Net Energy for Load (GWh) – (B/H/L).....	2-19
4 Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month (B/H/L)...	2-22
5 Fuel Requirements.....	2-26
6.1 Energy Sources (GWh).....	2-27
6.2 Energy Sources (Percent).....	2-28
7.1 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak.....	3-6
7.2 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak.....	3-7
8 Planned and Prospective Generating Facility Additions and Changes.....	3-8
9 Status Report and Specifications of Proposed Generating Facilities.....	3-9
10 Status Report and Specifications of Proposed Directly Associated Transmission Lines.....	3-31

LIST OF

TABLES AND FIGURES

<u>Tables</u>	<u>Page</u>
2.1 Residential DSM MW & GWH Savings	2-42
2.2 Commercial/Industrial DSM MW & GWH Savings.....	2-44
3.1 Total Capacity Resources of Power Plants and Purchased Power Contracts.....	3-4
3.2 Total Qualifying Facility Generation Contracts.....	3-5

<u>Figures</u>	<u>Page</u>
1.1 Service Area Map.....	1-2
2.1 Customer, Energy, and Demand Forecast.....	2-30
3.1 Integrated Resource Planning (IRP) Process Overview.....	3-33
3.2 Osceola Solar Site	3-40
3.3 Perry Solar Site	3-40
3.4 Suwannee Solar Site.....	3-41
3.5 Hamilton Solar Site.....	3-42
4.1 Debary Solar Project.....	4-2
4.2 Trenton Solar Power Plant.....	4-3
4.3 Lake Placid Solar Power Plant.....	4-4
4.4 Columbia Solar Power Plant.....	4-5
4.5 St Petersburg Pier Solar Energy Center.....	4-6

CODE IDENTIFICATION SHEET

Generating Unit Type

ST - Steam Turbine - Non-Nuclear
NP - Steam Power - Nuclear
GT - Gas Turbine
CT - Combustion Turbine
CC - Combined Cycle
SPP - Small Power Producer
COG - Cogeneration Facility
PV - Photovoltaic

Fuel Type

NUC - Nuclear (Uranium)
NG - Natural Gas
RFO - No. 6 Residual Fuel Oil
DFO - No. 2 Distillate Fuel Oil
BIT - Bituminous Coal
MSW - Municipal Solid Waste
WH - Waste Heat
BIO – Biomass
SO – Solar PV

Fuel Transportation

WA - Water
TK - Truck
RR - Railroad
PL - Pipeline
UN - Unknown

Future Generating Unit Status

A - Generating unit capability increased
D – Generating unit capability decreased
FC - Existing generator planned for conversion to another fuel or energy source
P - Planned for installation but not authorized; not under construction
RP - Proposed for repowering or life extension
RT - Existing generator scheduled for retirement
T - Regulatory approval received but not under construction
U - Under construction, less than or equal to 50% complete
V - Under construction, more than 50% complete

INTRODUCTION

Section 186.801 of the Florida Statutes requires electric generating utilities to submit a Ten-Year Site Plan (TYSP) to the Florida Public Service Commission (FPSC). The TYSP includes historical and projected data pertaining to the utility's load and resource needs as well as a review of those needs. Duke Energy Florida, LLC's (DEF)'s TYSP is compiled in accordance with FPSC Rules 25-22.070 through 22.072, Florida Administrative Code.

DEF's TYSP is based on the projections of long-term planning requirements that are dynamic in nature and subject to change. These planning documents should be used for general guidance concerning DEF's planning assumptions and projections, and should not be taken as an assurance that particular events discussed in the TYSP will materialize or that particular plans will be implemented. Information and projections pertinent to periods further out in time are inherently subject to greater uncertainty.

This TYSP document contains four chapters as indicated below:

- **CHAPTER 1 - DESCRIPTION OF EXISTING FACILITIES**

This chapter provides an overview of DEF's generating resources as well as the transmission and distribution system.

- **CHAPTER 2 - FORECAST OF ELECTRICAL POWER DEMAND AND ENERGY CONSUMPTION**

Chapter 2 presents the history and forecast for load and peak demand as well as the forecast methodology used. Demand-Side Management (DSM) savings and fuel requirement projections are also included.

- **CHAPTER 3 - FORECAST OF FACILITIES REQUIREMENTS**

The resource planning forecast, transmission planning forecast as well as the proposed generating facilities and bulk transmission line additions status are discussed in Chapter 3.

- **CHAPTER 4 - ENVIRONMENTAL AND LAND USE INFORMATION**

Preferred and potential site locations along with any environmental and land use information are presented in this chapter.

(Blank Page)

CHAPTER 1

DESCRIPTION OF EXISTING FACILITIES



CHAPTER 1

DESCRIPTION OF EXISTING FACILITIES

EXISTING FACILITIES OVERVIEW

OWNERSHIP

Duke Energy Florida, LLC (DEF or the Company) is a wholly owned subsidiary of Duke Energy Corporation (Duke Energy).

AREA OF SERVICE

DEF has an obligation to serve approximately 1.8 million customers in Florida. Its service area covers approximately 20,000 square miles in west central Florida and includes the densely populated areas around Orlando, as well as the cities of Saint Petersburg and Clearwater. DEF is interconnected with 21 municipal and nine rural electric cooperative systems who serve additional customers in Florida. DEF is subject to the rules and regulations of the Federal Energy Regulatory Commission (FERC), the Nuclear Regulatory Commission (NRC), and the FPSC. DEF's Service Area is shown in Figure 1.1.

TRANSMISSION/DISTRIBUTION

The Company is part of a nationwide interconnected power network that enables power to be exchanged between utilities. The DEF transmission system includes approximately 5,200 circuit miles of transmission lines. The distribution system includes approximately 18,000 circuit miles of overhead distribution conductors and approximately 14,000 circuit miles of underground distribution cable.


ENERGY MANAGEMENT and ENERGY EFFICIENCY

The Company's residential Energy Management program represents a demand response type of program where participating customers help manage future growth and costs. Approximately 435,000 customers participated in the residential Energy Management program during 2018, contributing about 699 MW of winter peak-shaving capacity for use during high load periods. DEF's currently approved DSM programs consist of five residential programs, six commercial and industrial programs and one research and development program.

TOTAL CAPACITY RESOURCE

As of December 31, 2018, DEF had total summer capacity resources of 11,789 MW consisting of installed capacity of 9,794 MW and 1,995 MW of firm purchased power. Additional information on DEF's existing generating resources can be found in Schedule 1 and Table 3.1 (Chapter 3).

FIGURE 1.1
DUKE ENERGY FLORIDA
County Service Area Map



DUKE ENERGY FLORIDA

SCHEDULE 1
EXISTING GENERATING FACILITIES

AS OF DECEMBER 31, 2018

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
<u>PLANT NAME</u>	<u>UNIT NO.</u>	<u>LOCATION (COUNTY)</u>	<u>UNIT TYPE</u>	<u>FUEL PRI.</u>	<u>FUEL ALT.</u>	<u>FUEL TRANSPORT PRI.</u>	<u>ALT. FUEL ALT.</u>	<u>DAYS USE</u>	<u>COM'L IN-SERVICE MO./YEAR</u>	<u>EXPECTED RETIREMENT MO./YEAR</u>	<u>GEN. MAX. NAMEPLATE KW</u>	<u>NET CAPABILITY SUMMER MW</u>	<u>WINTER MW</u>
<u>STEAM</u>													
ANCLOTE	1	PASCO	ST	NG		PL			10/74		556,200	498	511
ANCLOTE	2	PASCO	ST	NG		PL			10/78		556,200	505	514
CRYSTAL RIVER	4	CITRUS	ST	BIT		WA	RR		12/82		739,260	712	721
CRYSTAL RIVER	5	CITRUS	ST	BIT		WA	RR		10/84		739,260	710	721
Steam Total												2,425	2,467
<u>COMBINED-CYCLE</u>													
P L BARTOW	4	PINELLAS	CC	NG	DFO	PL	TK	*	6/09		1,254,200	1,104	1,187
CITRUS COUNTY COMBINED CYCLE	PB1	CITRUS	CC	NG		PL			10/18		985,150	816	931
CITRUS COUNTY COMBINED CYCLE	PB2	CITRUS	CC	NG		PL			11/18		985,150	816	931
HINES ENERGY COMPLEX	1	POLK	CC	NG		PL			4/99		546,500	490	528
HINES ENERGY COMPLEX	2	POLK	CC	NG	DFO	PL	TK	*	12/03		548,250	524	563
HINES ENERGY COMPLEX	3	POLK	CC	NG	DFO	PL	TK	*	11/05		561,000	515	564
HINES ENERGY COMPLEX	4	POLK	CC	NG	DFO	PL	TK	*	12/07		610,500	516	544
OSPREY ENERGY CENTER POWER PI	1	POLK	CC	NG		PL			5/04		644,300	245	245
TIGER BAY	1	POLK	CC	NG		PL			8/97		278,100	200	231
CC Total												5,226	5,724
<u>COMBUSTION TURBINE</u>													
AVON PARK	P1	HIGHLANDS	GT	NG	DFO	PL	TK	*	12/68	6/2020 **	33,750	24	25
AVON PARK	P2	HIGHLANDS	GT	DFO		TK		*	12/68	6/2020 **	33,750	24	25
BARTOW	P1	PINELLAS	GT	DFO		WA		*	5/72	6/2027 **	55,400	41	52
BARTOW	P2	PINELLAS	GT	NG	DFO	PL	WA	*	6/72		55,400	41	57
BARTOW	P3	PINELLAS	GT	DFO		WA		*	6/72	6/2027 **	55,400	41	53
BARTOW	P4	PINELLAS	GT	NG	DFO	PL	WA	*	6/72		55,400	45	61
BAYBORO	P1	PINELLAS	GT	DFO		WA		*	4/73	12/2025 **	56,700	44	61
BAYBORO	P2	PINELLAS	GT	DFO		WA		*	4/73	12/2025 **	56,700	41	58
BAYBORO	P3	PINELLAS	GT	DFO		WA		*	4/73	12/2025 **	56,700	43	60
BAYBORO	P4	PINELLAS	GT	DFO		WA		*	4/73	12/2025 **	56,700	43	59
DEBARY	P2	VOLUSIA	GT	DFO		TK		*	12/75-4/76	6/2027 **	73,440	48	64
DEBARY	P3	VOLUSIA	GT	DFO		TK		*	12/75-4/76	6/2027 **	73,440	50	65
DEBARY	P4	VOLUSIA	GT	DFO		TK		*	12/75-4/76	6/2027 **	73,440	50	65
DEBARY	P5	VOLUSIA	GT	DFO		TK		*	12/75-4/76	6/2027 **	73,440	50	65
DEBARY	P6	VOLUSIA	GT	DFO		TK		*	12/75-4/76	6/2027 **	73,440	51	65
DEBARY	P7	VOLUSIA	GT	NG	DFO	PL	TK	*	10/92		103,500	79	99
DEBARY	P8	VOLUSIA	GT	NG	DFO	PL	TK	*	10/92		103,500	78	96
DEBARY	P9	VOLUSIA	GT	NG	DFO	PL	TK	*	10/92		103,500	80	98
DEBARY	P10	VOLUSIA	GT	DFO		TK		*	10/92		103,500	75	95
HIGGINS ***	P1	PINELLAS	GT	NG		PL			3/69	6/2020 **	33,750	0	0
HIGGINS ***	P2	PINELLAS	GT	NG		PL			4/69	6/2020 **	33,750	0	0
HIGGINS ***	P3	PINELLAS	GT	NG		PL			12/70	6/2020 **	42,925	0	0
HIGGINS ***	P4	PINELLAS	GT	NG		PL			1/71	6/2020 **	42,925	0	0
INTERCESSION CITY	P1	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	47	64
INTERCESSION CITY	P2	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	46	63
INTERCESSION CITY	P3	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	46	63
INTERCESSION CITY	P4	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	46	63
INTERCESSION CITY	P5	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	45	62
INTERCESSION CITY	P6	OSCEOLA	GT	DFO		PL,TK		*	5/74		56,700	47	64
INTERCESSION CITY	P7	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	10/93		103,500	78	95
INTERCESSION CITY	P8	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	10/93		103,500	79	96
INTERCESSION CITY	P9	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	10/93		103,500	79	96
INTERCESSION CITY	P10	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	10/93		103,500	78	96
INTERCESSION CITY	P11	OSCEOLA	GT	DFO		PL,TK		*	1/97		148,500	140	161
INTERCESSION CITY	P12	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	12/00		98,260	73	94
INTERCESSION CITY	P13	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	12/00		98,260	75	93
INTERCESSION CITY	P14	OSCEOLA	GT	NG	DFO	PL	PL,TK	*	12/00		98,260	72	92
SUWANNEE RIVER	P1	SUWANNEE	GT	NG	DFO	PL	TK	*	10/80		65,999	49	68
SUWANNEE RIVER	P2	SUWANNEE	GT	DFO		TK		*	10/80		65,999	50	67
SUWANNEE RIVER	P3	SUWANNEE	GT	NG	DFO	PL	TK	*	11/80		65,999	50	68
UNIVERSITY OF FLORIDA	P1	ALACHUA	GT	NG		PL			1/94		65,999	44	46
CT Total												2,092	2,674
<u>SOLAR</u>													
OSCEOLA SOLAR FACILITY	PV1	OSCEOLA	PV	SO					5/16		3,800	2	0
PERRY SOLAR FACILITY	PV1	TAYLOR	PV	SO					8/16		5,000	2	0
SUWANNEE RIVER SOLAR FACILITY	PV1	SUWANNEE	PV	SO					11/16		8,800	4	0
HAMILTON SOLAR FACILITY	PV1	HAMILTON	PV	SO					12/18		74,900	43	0
SOLAR Total												51	0
TOTAL RESOURCES (MW)												9,794	10,865

* APPROXIMATELY 2 TO 8 DAYS OF OIL USE TYPICALLY TARGETED FOR ENTIRE PLANT.

** DATES FOR RETIREMENT ARE APPROXIMATE AND SUBJECT TO CHANGE

*** HIGGINS P1 20 MW, P2 25 MW, P3 31 MW & P4 31 MW (SUMMER MW) IS NON-FIRM CAPACITY AND SHOWN AS 0 MW EACH DUE TO SINGLE NON-FIRM FUEL SOURCE.

CHAPTER 2

FORECAST OF ELECTRIC POWER DEMAND AND ENERGY CONSUMPTION



CHAPTER 2
FORECAST OF ELECTRIC POWER DEMAND
AND
ENERGY CONSUMPTION

OVERVIEW

The information presented in Schedules 2, 3, and 4 represents DEF's history and forecast of customers, energy sales (GWh), and peak demand (MW). In general, this discussion refers to DEF's base forecast. Economic data from 2018 showed a continuation and expansion of the ongoing economic recovery that began in approximately 2012 and has continued to strengthen since. 2018 Economic growth stepped into higher gear fueled by the 2017 Tax Cut & Jobs Act. The U.S. unemployment rate dropped to a fifty year low with the Florida rate even lower. The 2019 outlook calls for slower U.S. economic growth as the boost from the tax cuts wear off. Looking ahead, the projections incorporated in this site plan forecast a moderation of growth rates in population and economic activity within the U.S and DEF service territory as assumed in the Moody's Analytics July 2018 projection. DEF continues to provide alternate "high" and "low" forecasts for energy and demand growth, recognizing that the current economic expansion may continue to accelerate as it has in the last year or could unwind just as it becomes the longest expansions on record.

Over the course of the ten years of history in this Site Plan (2009-2018), the nation and the State of Florida have endured the worst economic downturn in eighty years and have emerged to signs of a strong, sustainable recovery. Nearly all economic measures appear to have returned to normal post-crisis levels for both the U.S and Florida economies. A strong recovery has taken place in the past few years and the Florida economy can be expected to experience more normal rates of growth as the current economic expansion nears the record for longest expansion in U.S. history. County population growth rate projections from the University of Florida's Bureau of Economic and Business Research (BEBR) were incorporated into this projection. The DEF service area population has been estimated to have grown at an average ten-year growth of 1.16 percent from 2009 – 2018 (Schedule 2.1.1 Column 2). Demographic conditions going forward look amenable to sustaining a level of growth closer to 1.3% over the 2019-2028 period. The rate of residential

customer growth, which averaged 1.15% per year over the historical ten-year period, is expected to improve to an average of 1.45% for the projected ten years. A projected decline in average household size will result in a higher rate of household growth. By looking at Schedule 2.3.1 Column 6, we find that total DEF customers grew from 1.630 million in 2009 to 1.802 million in 2018, an increase of 171,369 or 1.12% annual growth rate. The projected number of total customers between 2019 and 2028 is 245,991 or 1.41% annual growth rate.

From 2009 to 2018 net energy for load (NEL) was essentially unchanged at 0.03% (Schedule 2.3.1 Column 4), primarily due to terminated contracts in the Sales for Resale or Wholesale jurisdiction (Schedule 2.3.1 Column 2). Historically, the 2018 Sales for Resale value has fallen 1,372 GWh from its 2009 level. The level of Wholesale NEL over the ten-year forecast is projected to decline an additional 1,426 GWh from the 2018 level. This decline is offset by a steady increase in the retail load sector which has increased by roughly 4% over the last ten years, an amount equal to the wholesale decline, and is projected to grow approximately 10% over the next decade, almost double the total energy decline in the wholesale sector. Total DEF customer growth in 2018 reached 1.12%, lower than the 2017 growth rate but still slightly higher than the 5-year average growth of 1.47%. The forecast over the next ten years calls for an average annual customer growth rate of 1.41%. Florida population growth is expected to remain elevated through most of the 2020s as the large baby-boom age cohort retire to sunny Florida.

During the 2009 to 2018 historical period the DEF Summer net firm demand (Schedule 3.1 column 10) declined from 9,624 MW to 8,545 MW, an average -1.3% per year. Once again, most of the decline came from the DEF wholesale load sector (Column 3), which dropped from a level of 1,618 MW in 2009 to 812 MW in 2018, a total drop of 806 MW or -50%. A secondary reason for the decline is continued growth in conservation and demand response participation. The projected ten-year period total DEF summer net firm demand growth of only 8 MW or 0.0% per year over the 10-year horizon is due to continued projected declines in wholesale peak demand.

ENERGY CONSUMPTION AND DEMAND FORECAST SCHEDULES

The below schedules have been provided to represent DEF's expectations for a Base Case as well as reasonable High and Low forecast scenarios for resource planning purposes. (Base-B, High-H and Low-L):

<u>SCHEDULE</u>	<u>DESCRIPTION</u>
2.1, 2.2 and 2.3	History and Forecast of Energy Consumption and Number of Customers by Customer Class (B, H and L)
3.1	History and Forecast of Base Summer Peak Demand (MW) (B, H and L)
3.2	History and Forecast of Base Winter Peak Demand (MW) (B, H and L)
3.3	History and Forecast of Base Annual Net Energy for Load (GWh) (B, H and L)
4	Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month (B, H and L)

DUKE ENERGY FLORIDA

SCHEDULE 2.1.1

**HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS
BASE CASE FORECAST**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
RURAL AND RESIDENTIAL						COMMERCIAL		
YEAR	DEF POPULATION	MEMBERS PER HOUSEHOLD	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER
HISTORY:								
2009	3,564,937	2.473	19,399	1,441,325	13,459	11,883	161,390	73,632
2010	3,621,407	2.495	20,524	1,451,466	14,140	11,896	161,674	73,579
2011	3,625,558	2.496	19,238	1,452,454	13,245	11,892	162,071	73,374
2012	3,641,179	2.496	18,251	1,458,690	12,512	11,723	163,297	71,792
2013	3,713,013	2.495	18,508	1,488,159	12,437	11,718	165,936	70,617
2014	3,747,160	2.492	19,003	1,503,758	12,637	11,789	167,253	70,485
2015	3,794,138	2.489	19,932	1,524,605	13,074	12,070	169,147	71,359
2016	3,837,436	2.485	20,265	1,543,967	13,126	12,094	170,999	70,724
2017	3,906,975	2.483	19,791	1,573,260	12,579	11,918	173,695	68,612
2018	3,954,499	2.476	20,636	1,597,132	12,920	12,172	175,848	69,216
FORECAST:								
2019	4,013,466	2.470	20,343	1,624,690	12,521	12,067	178,557	67,579
2020	4,070,191	2.471	20,637	1,647,440	12,527	12,208	181,015	67,440
2021	4,129,577	2.467	20,887	1,673,995	12,477	12,327	183,346	67,236
2022	4,182,767	2.460	21,076	1,700,215	12,396	12,425	185,608	66,944
2023	4,233,800	2.452	21,275	1,726,425	12,323	12,529	187,771	66,726
2024	4,283,713	2.445	21,438	1,752,362	12,234	12,619	189,913	66,445
2025	4,334,883	2.439	21,796	1,777,519	12,262	12,814	192,031	66,728
2026	4,387,123	2.434	21,874	1,802,497	12,135	12,824	194,078	66,075
2027	4,441,443	2.431	22,134	1,826,913	12,116	12,930	196,028	65,960
2028	4,494,486	2.429	22,585	1,850,092	12,207	13,124	197,900	66,316

DUKE ENERGY FLORIDA

SCHEDULE 2.1.2

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS
HIGH CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
RURAL AND RESIDENTIAL						COMMERCIAL		
YEAR	DEF POPULATION	MEMBERS PER HOUSEHOLD	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER
HISTORY:								
2009	3,564,937	2.473	19,399	1,441,325	13,459	11,883	161,390	73,632
2010	3,621,407	2.495	20,524	1,451,466	14,140	11,896	161,674	73,579
2011	3,625,558	2.496	19,238	1,452,454	13,245	11,892	162,071	73,374
2012	3,641,179	2.496	18,251	1,458,690	12,512	11,723	163,297	71,792
2013	3,713,013	2.495	18,508	1,488,159	12,437	11,718	165,936	70,617
2014	3,747,160	2.492	19,003	1,503,758	12,637	11,789	167,253	70,485
2015	3,794,138	2.489	19,932	1,524,605	13,074	12,070	169,147	71,359
2016	3,837,436	2.485	20,265	1,543,967	13,126	12,094	170,999	70,724
2017	3,906,975	2.483	19,791	1,573,260	12,579	11,918	173,695	68,612
2018	3,954,499	2.476	20,636	1,597,132	12,920	12,172	175,848	69,216
FORECAST:								
2019	4,026,822	2.470	22,599	1,630,097	13,864	12,489	178,871	69,822
2020	4,097,996	2.471	23,043	1,658,694	13,893	12,766	181,670	70,272
2021	4,172,377	2.467	23,474	1,691,345	13,879	13,022	184,356	70,634
2022	4,241,097	2.460	23,858	1,723,925	13,839	13,276	186,987	71,000
2023	4,308,201	2.452	24,239	1,756,764	13,797	13,542	189,537	71,446
2024	4,374,718	2.445	24,592	1,789,590	13,742	13,771	192,079	71,692
2025	4,443,039	2.439	25,109	1,821,868	13,782	14,100	194,613	72,454
2026	4,512,937	2.434	25,432	1,854,189	13,716	14,254	197,086	72,322
2027	4,585,434	2.431	25,900	1,886,142	13,732	14,515	199,475	72,768
2028	4,657,134	2.429	26,525	1,917,044	13,837	14,851	201,797	73,595

DUKE ENERGY FLORIDA

SCHEDULE 2.1.3

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND

NUMBER OF CUSTOMERS BY CUSTOMER CLASS

LOW CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
RURAL AND RESIDENTIAL					COMMERCIAL			
YEAR	DEF POPULATION	MEMBERS PER HOUSEHOLD	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER
HISTORY:								
2009	3,564,937	2.473	19,399	1,441,325	13,459	11,883	161,390	73,632
2010	3,621,407	2.495	20,524	1,451,466	14,140	11,896	161,674	73,579
2011	3,625,558	2.496	19,238	1,452,454	13,245	11,892	162,071	73,374
2012	3,641,179	2.496	18,251	1,458,690	12,512	11,723	163,297	71,792
2013	3,713,013	2.495	18,508	1,488,159	12,437	11,718	165,936	70,617
2014	3,747,160	2.492	19,003	1,503,758	12,637	11,789	167,253	70,485
2015	3,794,138	2.489	19,932	1,524,605	13,074	12,070	169,147	71,359
2016	3,837,436	2.485	20,265	1,543,967	13,126	12,094	170,999	70,724
2017	3,906,975	2.483	19,791	1,573,260	12,579	11,918	173,695	68,612
2018	3,954,499	2.476	20,636	1,597,132	12,920	12,172	175,848	69,216
FORECAST:								
2019	4,000,123	2.470	17,923	1,619,289	11,069	11,567	178,242	64,894
2020	4,042,516	2.471	18,044	1,636,239	11,028	11,606	180,363	64,346
2021	4,087,151	2.467	18,135	1,656,797	10,946	11,614	182,346	63,692
2022	4,125,189	2.460	18,166	1,676,811	10,834	11,610	184,245	63,015
2023	4,160,667	2.452	18,219	1,696,604	10,739	11,617	186,035	62,447
2024	4,194,640	2.445	18,246	1,715,924	10,633	11,588	187,792	61,706
2025	4,229,473	2.439	18,418	1,734,295	10,620	11,647	189,516	61,458
2026	4,265,026	2.434	18,392	1,752,332	10,496	11,551	191,158	60,424
2027	4,302,304	2.431	18,487	1,769,681	10,447	11,541	192,697	59,893
2028	4,337,992	2.429	18,723	1,785,674	10,485	11,598	194,151	59,740

DUKE ENERGY FLORIDA

SCHEDULE 2.2.1

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS

BASE CASE

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
	INDUSTRIAL						
		AVERAGE	AVERAGE KWh	RAILROADS	STREET &	OTHER SALES	TOTAL SALES
		NO. OF	CONSUMPTION	AND RAILWAYS	HIGHWAY	TO PUBLIC	TO ULTIMATE
YEAR	GWh	CUSTOMERS	PER CUSTOMER	GWh	LIGHTING	AUTHORITIES	CONSUMERS
					GWh	GWh	GWh
HISTORY:							
2009	3,285	2,487	1,320,869	0	26	3,230	37,824
2010	3,219	2,481	1,297,461	0	26	3,260	38,925
2011	3,243	2,408	1,346,761	0	25	3,200	37,598
2012	3,160	2,372	1,332,209	0	25	3,221	36,381
2013	3,206	2,343	1,368,331	0	25	3,159	36,616
2014	3,267	2,280	1,432,895	0	25	3,157	37,240
2015	3,293	2,243	1,468,123	0	24	3,234	38,553
2016	3,197	2,178	1,467,860	0	24	3,194	38,774
2017	3,120	2,137	1,459,991	0	24	3,171	38,023
2018	3,107	2,080	1,493,750	0	24	3,206	39,144
FORECAST:							
2019	3,325	2,045	1,625,580	0	24	3,209	38,968
2020	3,517	2,028	1,733,824	0	24	3,219	39,604
2021	3,671	2,013	1,823,343	0	24	3,227	40,135
2022	3,694	2,000	1,846,982	0	23	3,238	40,457
2023	3,690	1,989	1,855,504	0	23	3,254	40,771
2024	3,683	1,978	1,861,527	0	23	3,271	41,034
2025	3,690	1,970	1,873,519	0	23	3,289	41,612
2026	3,670	1,962	1,870,687	0	23	3,307	41,696
2027	3,666	1,955	1,875,398	0	22	3,325	42,078
2028	3,677	1,949	1,886,807	0	22	3,346	42,754

DUKE ENERGY FLORIDA

SCHEDULE 2.2.2
HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS
HIGH CASE

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
	INDUSTRIAL						
		AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER	RAILROADS AND RAILWAYS GWh	STREET & HIGHWAY LIGHTING GWh	OTHER SALES TO PUBLIC AUTHORITIES GWh	TOTAL SALES TO ULTIMATE CONSUMERS GWh
YEAR	GWh						
HISTORY:							
2009	3,285	2,487	1,320,869	0	26	3,230	37,824
2010	3,219	2,481	1,297,461	0	26	3,260	38,925
2011	3,243	2,408	1,346,761	0	25	3,200	37,598
2012	3,160	2,372	1,332,209	0	25	3,221	36,381
2013	3,206	2,343	1,368,331	0	25	3,159	36,616
2014	3,267	2,280	1,432,895	0	25	3,157	37,240
2015	3,293	2,243	1,468,123	0	24	3,234	38,553
2016	3,197	2,178	1,467,860	0	24	3,194	38,774
2017	3,120	2,137	1,459,991	0	24	3,171	38,023
2018	3,107	2,080	1,493,750	0	24	3,206	39,144
FORECAST:							
2019	3,349	2,045	1,637,254	0	24	3,300	41,761
2020	3,547	2,028	1,748,905	0	24	3,321	42,702
2021	3,708	2,013	1,841,827	0	24	3,341	43,569
2022	3,738	2,000	1,868,892	0	23	3,366	44,261
2023	3,740	1,989	1,880,828	0	23	3,394	44,938
2024	3,740	1,978	1,890,292	0	23	3,426	45,551
2025	3,753	1,970	1,905,665	0	23	3,456	46,442
2026	3,739	1,962	1,906,235	0	23	3,489	46,936
2027	3,742	1,955	1,914,307	0	22	3,521	47,701
2028	3,759	1,949	1,928,706	0	22	3,555	48,713

DUKE ENERGY FLORIDA

SCHEDULE 2.2.3
HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS
LOW CASE

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
	INDUSTRIAL				STREET & HIGHWAY LIGHTING	OTHER SALES TO PUBLIC AUTHORITIES	TOTAL SALES TO ULTIMATE CONSUMERS
YEAR	GWh	AVERAGE NO. OF CUSTOMERS	AVERAGE KWh CONSUMPTION PER CUSTOMER	RAILROADS AND RAILWAYS GWh	GWh	GWh	GWh
HISTORY:							
2009	3,285	2,487	1,320,869	0	26	3,230	37,824
2010	3,219	2,481	1,297,461	0	26	3,260	38,925
2011	3,243	2,408	1,346,761	0	25	3,200	37,598
2012	3,160	2,372	1,332,209	0	25	3,221	36,381
2013	3,206	2,343	1,368,331	0	25	3,159	36,616
2014	3,267	2,280	1,432,895	0	25	3,157	37,240
2015	3,293	2,243	1,468,123	0	24	3,234	38,553
2016	3,197	2,178	1,467,860	0	24	3,194	38,774
2017	3,120	2,137	1,459,991	0	24	3,171	38,023
2018	3,107	2,080	1,493,750	0	24	3,206	39,144
FORECAST:							
2019	3,294	2,045	1,610,511	0	24	3,100	35,909
2020	3,479	2,028	1,715,390	0	24	3,097	36,250
2021	3,627	2,013	1,801,680	0	24	3,092	36,492
2022	3,645	2,000	1,822,196	0	23	3,092	36,536
2023	3,634	1,989	1,827,704	0	23	3,094	36,589
2024	3,622	1,978	1,830,815	0	23	3,100	36,579
2025	3,624	1,970	1,839,969	0	23	3,104	36,816
2026	3,599	1,962	1,834,507	0	23	3,109	36,674
2027	3,590	1,955	1,836,644	0	22	3,114	36,755
2028	3,597	1,949	1,845,514	0	22	3,121	37,062

DUKE ENERGY FLORIDA

SCHEDULE 2.3.1

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND
NUMBER OF CUSTOMERS BY CUSTOMER CLASS

BASE CASE

(1)	(2)	(3)	(4)	(5)	(6)
YEAR	SALES FOR RESALE GWh	UTILITY USE & LOSSES GWh	NET ENERGY FOR LOAD GWh	OTHER CUSTOMERS (AVERAGE NO.)	TOTAL NO. OF CUSTOMERS
-----	-----	-----	-----	-----	-----
HISTORY:					
2009	3,696	2,604	44,124	24,993	1,630,195
2010	3,493	3,742	46,160	25,212	1,640,833
2011	2,712	2,180	42,490	25,228	1,642,161
2012	1,768	3,065	41,214	25,480	1,649,839
2013	1,488	2,668	40,772	25,759	1,682,197
2014	1,333	2,402	40,975	25,800	1,699,091
2015	1,243	2,484	42,280	25,866	1,721,861
2016	1,803	2,277	42,854	26,005	1,743,149
2017	2,196	2,700	42,919	26,248	1,775,340
2018	2,324	2,756	44,224	26,504	1,801,564
FORECAST:					
2019	1,653	2,585	43,206	26,740	1,832,032
2020	1,489	2,527	43,620	26,872	1,857,355
2021	1,377	2,437	43,949	27,037	1,886,392
2022	1,609	2,452	44,519	27,199	1,915,022
2023	1,264	2,431	44,466	27,361	1,943,546
2024	1,239	2,540	44,813	27,515	1,971,768
2025	898	2,222	44,732	27,665	1,999,184
2026	898	2,463	45,057	27,807	2,026,344
2027	898	2,429	45,405	27,947	2,052,843
2028	898	2,264	45,916	28,083	2,078,024

DUKE ENERGY FLORIDA

SCHEDULE 2.3.2

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND NUMBER OF CUSTOMERS BY CUSTOMER CLASS

HIGH CASE

(1)	(2)	(3)	(4)	(5)	(6)
YEAR	SALES FOR RESALE GWh	UTILITY USE & LOSSES GWh	NET ENERGY FOR LOAD GWh	OTHER CUSTOMERS (AVERAGE NO.)	TOTAL NO. OF CUSTOMERS
HISTORY:					
2009	3,696	2,604	44,124	24,993	1,630,195
2010	3,493	3,742	46,160	25,212	1,640,833
2011	2,712	2,180	42,490	25,228	1,642,161
2012	1,768	3,065	41,214	25,480	1,649,839
2013	1,488	2,668	40,772	25,759	1,682,197
2014	1,333	2,402	40,975	25,800	1,699,091
2015	1,243	2,484	42,280	25,866	1,721,861
2016	1,803	2,277	42,854	26,005	1,743,149
2017	2,196	2,700	42,919	26,248	1,775,340
2018	2,324	2,756	44,224	26,504	1,801,564
FORECAST:					
2019	1,653	2,760	46,175	26,740	1,837,753
2020	1,489	2,736	46,927	26,872	1,869,264
2021	1,377	2,685	47,630	27,037	1,904,752
2022	1,609	2,717	48,588	27,199	1,940,112
2023	1,264	2,718	48,919	27,361	1,975,650
2024	1,239	2,828	49,617	27,515	2,011,163
2025	898	2,570	49,910	27,665	2,046,115
2026	898	2,791	50,625	27,807	2,081,045
2027	898	2,783	51,382	27,947	2,115,519
2028	898	2,660	52,270	28,083	2,148,872

DUKE ENERGY FLORIDA

SCHEDULE 2.3.3

HISTORY AND FORECAST OF ENERGY CONSUMPTION AND NUMBER OF CUSTOMERS BY CUSTOMER CLASS

LOW CASE

(1)	(2)	(3)	(4)	(5)	(6)
YEAR	SALES FOR RESALE GWh	UTILITY USE & LOSSES GWh	NET ENERGY FOR LOAD GWh	OTHER CUSTOMERS (AVERAGE NO.)	TOTAL NO. OF CUSTOMERS
-----	-----	-----	-----	-----	-----
HISTORY:					
2009	3,696	2,604	44,124	24,993	1,630,195
2010	3,493	3,742	46,160	25,212	1,640,833
2011	2,712	2,180	42,490	25,228	1,642,161
2012	1,768	3,065	41,214	25,480	1,649,839
2013	1,488	2,668	40,772	25,759	1,682,197
2014	1,333	2,402	40,975	25,800	1,699,091
2015	1,243	2,484	42,280	25,866	1,721,861
2016	1,803	2,277	42,854	26,005	1,743,149
2017	2,196	2,700	42,919	26,248	1,775,340
2018	2,324	2,756	44,224	26,504	1,801,564
FORECAST:					
2019	1,653	2,409	39,972	26,740	1,826,316
2020	1,489	2,350	40,089	26,872	1,845,501
2021	1,377	2,264	40,133	27,037	1,868,193
2022	1,609	2,260	40,406	27,199	1,890,255
2023	1,264	2,225	40,078	27,361	1,911,989
2024	1,239	2,289	40,106	27,515	1,933,210
2025	898	2,016	39,730	27,665	1,953,445
2026	898	2,175	39,746	27,807	1,973,259
2027	898	2,126	39,780	27,947	1,992,280
2028	898	1,982	39,942	28,083	2,009,856

DUKE ENERGY FLORIDA

SCHEDULE 3.1.1

HISTORY AND FORECAST OF SUMMER PEAK DEMAND (MW)

BASE CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
					RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE						
HISTORY:										
2009	10,853	1618	9,235	262	291	271	84	211	110	9,624
2010	10,242	1272	8,970	271	304	298	96	234	110	8,929
2011	9,972	934	9,038	227	317	329	97	256	110	8,636
2012	9,788	1080	8,708	262	328	358	98	280	124	8,337
2013	9,581	581	9,000	317	341	382	101	298	124	8,017
2014	10,067	814	9,253	232	355	404	108	313	132	8,523
2015	10,058	772	9,286	303	360	435	124	324	80	8,431
2016	10,530	893	9,637	235	366	466	100	339	80	8,946
2017	10,220	808	9,412	203	342	498	95	349	80	8,653
2018	10,271	812	9,459	257	386	532	83	387	80	8,545
FORECAST:										
2019	10,812	979	9,833	273	387	563	91	400	80	9,019
2020	10,865	939	9,926	356	393	584	95	403	80	8,953
2021	10,969	963	10,006	356	399	603	99	406	80	9,026
2022	11,063	963	10,100	366	405	619	103	408	80	9,082
2023	10,843	662	10,181	366	411	633	108	409	80	8,836
2024	10,938	662	10,276	366	417	647	112	410	80	8,907
2025	10,823	461	10,362	366	423	662	116	410	80	8,766
2026	10,921	461	10,460	366	429	676	120	411	80	8,839
2027	11,026	461	10,565	366	435	689	124	411	80	8,920
2028	11,157	461	10,695	366	441	702	129	412	80	9,027

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.1.2
HISTORY AND FORECAST OF SUMMER PEAK DEMAND (MW)
HIGH CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
					RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE						
HISTORY:										
2009	10,853	1,618	9,235	262	291	271	84	211	110	9,624
2010	10,242	1,272	8,970	271	304	298	96	234	110	8,929
2011	9,972	934	9,038	227	317	329	97	256	110	8,636
2012	9,788	1,080	8,708	262	328	358	98	280	124	8,337
2013	9,581	581	9,000	317	341	382	101	298	124	8,017
2014	10,067	814	9,253	232	355	404	108	313	132	8,523
2015	10,058	772	9,286	303	360	435	124	324	80	8,431
2016	10,530	893	9,637	235	366	466	100	339	80	8,946
2017	10,220	808	9,412	203	342	498	95	349	80	8,653
2018	10,271	812	9,459	257	386	532	83	349	80	8,545
FORECAST:										
2019	11,569	979	10,590	273	387	563	91	400	80	9,776
2020	11,700	939	10,761	356	393	584	95	403	80	9,788
2021	11,884	963	10,922	356	399	603	99	406	80	9,941
2022	12,061	963	11,099	366	405	619	103	408	80	10,080
2023	11,927	662	11,266	366	411	633	108	409	80	9,920
2024	12,105	662	11,443	366	417	647	112	410	80	10,074
2025	12,072	461	11,611	366	423	662	116	410	80	10,015
2026	12,259	461	11,797	366	429	676	120	411	80	10,177
2027	12,456	461	11,995	366	435	689	124	411	80	10,350
2028	12,675	461	12,213	366	441	702	129	412	80	10,545

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.1.3

HISTORY AND FORECAST OF SUMMER PEAK DEMAND (MW)

LOW CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
					RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE						
HISTORY:										
2009	10,853	1,618	9,235	262	291	271	84	211	110	9,624
2010	10,242	1,272	8,970	271	304	298	96	234	110	8,929
2011	9,972	934	9,038	227	317	329	97	256	110	8,636
2012	9,788	1,080	8,708	262	328	358	98	280	124	8,337
2013	9,581	581	9,000	317	341	382	101	298	124	8,017
2014	10,067	814	9,253	232	355	404	108	313	132	8,523
2015	10,058	772	9,286	303	360	435	124	324	80	8,431
2016	10,530	893	9,637	235	366	466	100	339	80	8,946
2017	10,220	808	9,412	203	342	498	95	349	80	8,653
2018	10,271	812	9,459	257	386	532	83	387	80	8,545
FORECAST:										
2019	10,013	979	9,034	273	387	563	91	400	80	8,220
2020	10,003	939	9,063	356	393	584	95	403	80	8,091
2021	10,045	963	9,082	356	399	603	99	406	80	8,101
2022	10,073	963	9,110	366	405	619	103	408	80	8,092
2023	9,792	662	9,130	366	411	633	108	409	80	7,785
2024	9,819	662	9,157	366	417	647	112	410	80	7,787
2025	9,636	461	9,175	366	423	662	116	410	80	7,579
2026	9,666	461	9,205	366	429	676	120	411	80	7,584
2027	9,701	461	9,240	366	435	689	124	411	80	7,596
2028	9,756	461	9,294	366	441	702	129	412	80	7,626

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.2.1
HISTORY AND FORECAST OF WINTER PEAK DEMAND (MW)
BASE CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE	RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
HISTORY:										
2008/09	12,089	2,229	9,860	268	759	518	71	148	291	10,034
2009/10	13,694	2,189	11,505	246	651	563	80	163	322	11,670
2010/11	11,343	1,625	9,718	271	661	628	94	180	221	9,288
2011/12	9,721	905	8,816	186	643	686	96	203	206	7,701
2012/13	9,109	831	8,278	287	652	747	97	220	213	6,893
2013/14	9,467	658	8,809	257	654	785	101	229	219	7,222
2014/15	10,648	1,035	9,613	273	669	815	109	236	237	8,308
2015/16	9,678	1,275	8,403	207	681	845	113	240	170	7,421
2016/17	8,739	701	8,038	191	687	878	78	243	165	6,497
2017/18	11,559	1,071	10,488	244	699	913	79	246	196	9,183
FORECAST:										
2018/19	11,448	1,225	10,223	243	711	943	86	250	191	9,023
2019/20	11,731	1,381	10,350	270	723	965	91	251	193	9,239
2020/21	11,185	713	10,472	316	735	983	95	252	194	8,611
2021/22	11,574	1,014	10,560	324	747	999	99	252	195	8,958
2022/23	11,344	713	10,631	324	759	1,014	103	253	196	8,696
2023/24	11,447	713	10,734	324	771	1,027	107	253	197	8,768
2024/25	11,294	512	10,782	324	783	1,043	112	253	197	8,583
2025/26	11,376	512	10,863	324	795	1,057	116	253	198	8,633
2026/27	11,461	512	10,948	324	807	1,070	120	253	199	8,688
2027/28	11,544	462	11,082	324	819	1,083	124	253	200	8,741

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.2.2

HISTORY AND FORECAST OF WINTER PEAK DEMAND (MW)

HIGH CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
					RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE						
HISTORY:										
2008/09	12,089	2,229	9,860	268	759	518	71	148	291	10,034
2009/10	13,694	2,189	11,505	246	651	563	80	163	322	11,670
2010/11	11,343	1,625	9,718	271	661	628	94	180	221	9,288
2011/12	9,721	905	8,816	186	643	686	96	203	206	7,701
2012/13	9,109	831	8,278	287	652	747	97	220	213	6,893
2013/14	9,467	658	8,809	257	654	785	101	229	219	7,222
2014/15	10,648	1,035	9,613	273	669	815	109	236	237	8,308
2015/16	9,678	1,275	8,403	207	681	845	113	240	170	7,421
2016/17	8,739	701	8,038	191	687	878	78	243	165	6,497
2017/18	11,559	1,071	10,488	244	699	913	79	246	196	9,183
FORECAST:										
2018/19	13,187	1,225	11,962	243	711	943	86	250	191	10,762
2019/20	13,569	1,381	12,188	270	723	965	91	251	193	11,077
2020/21	13,143	713	12,430	316	735	983	95	252	194	10,568
2021/22	13,631	1,014	12,617	324	747	999	99	252	195	11,014
2022/23	13,495	713	12,782	324	759	1,014	103	253	196	10,846
2023/24	13,667	713	12,954	324	771	1,027	107	253	197	10,987
2024/25	13,626	512	13,114	324	783	1,043	112	253	197	10,915
2025/26	13,804	512	13,291	324	795	1,057	116	253	198	11,061
2026/27	13,990	512	13,477	324	807	1,070	120	253	199	11,217
2027/28	14,150	462	13,688	324	819	1,083	124	253	200	11,346

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.2.3
HISTORY AND FORECAST OF WINTER PEAK DEMAND (MW)
LOW CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)
YEAR	TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE	RESIDENTIAL LOAD MANAGEMENT	RESIDENTIAL CONSERVATION	COMM. / IND. LOAD MANAGEMENT	COMM. / IND. CONSERVATION	OTHER DEMAND REDUCTIONS	NET FIRM DEMAND
HISTORY:										
2008/09	12,089	2,229	9,860	268	759	518	71	148	291	10,034
2009/10	13,694	2,189	11,505	246	651	563	80	163	322	11,670
2010/11	11,343	1,625	9,718	271	661	628	94	180	221	9,288
2011/12	9,721	905	8,816	186	643	686	96	203	206	7,701
2012/13	9,109	831	8,278	287	652	747	97	220	213	6,893
2013/14	9,467	658	8,809	257	654	785	101	229	219	7,222
2014/15	10,648	1,035	9,613	273	669	815	109	236	237	8,308
2015/16	9,678	1,275	8,403	207	681	845	113	240	170	7,421
2016/17	8,739	701	8,038	191	687	878	78	243	165	6,497
2017/18	11,559	1,071	10,488	244	699	913	79	246	196	9,183
FORECAST:										
2018/19	9,693	1,225	8,468	243	711	943	86	250	170	7,290
2019/20	9,884	1,381	8,503	270	723	965	91	251	170	7,415
2020/21	9,289	713	8,576	316	735	983	95	252	170	6,738
2021/22	9,613	1,014	8,599	324	747	999	99	252	170	7,021
2022/23	9,326	713	8,613	324	759	1,014	103	253	170	6,703
2023/24	9,345	713	8,632	324	771	1,027	107	253	171	6,692
2024/25	9,154	512	8,641	324	783	1,043	112	253	170	6,469
2025/26	9,172	512	8,659	324	795	1,057	116	253	170	6,457
2026/27	9,192	512	8,680	324	807	1,070	120	253	171	6,448
2027/28	9,184	462	8,721	324	819	1,083	124	253	171	6,410

Historical Values (2009 - 2018):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2019 - 2028):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.3.1

HISTORY AND FORECAST OF ANNUAL NET ENERGY FOR LOAD (GWh)

BASE CASE FORECAST

(1)	(2)	(3)	(4)	(5TH)	(5)	(6)	(7)	(8)	(9)
		RESIDENTIAL	COMM. / IND.	OTHER			UTILITY USE	NET ENERGY	LOAD
YEAR	TOTAL	CONSERVATION	CONSERVATION	ENERGY	RETAIL	WHOLESALE	& LOSSES	FOR LOAD	FACTOR
				REDUCTIONS					(%) *
HISTORY:									
2009	45,978	583	492	779	37,824	3,696	2,604	44,124	44.5
2010	48,135	638	558	779	38,925	3,493	3,742	46,160	45.3
2011	44,580	687	624	779	37,597	2,712	2,181	42,490	46.7
2012	43,396	733	669	780	36,381	1,768	3,065	41,214	52.0
2013	43,142	772	734	864	36,616	1,488	2,668	40,772	53.0
2014	43,442	812	791	864	37,240	1,333	2,402	40,975	50.7
2015	44,552	848	829	595	38,553	1,243	2,484	42,280	50.9
2016	45,199	892	857	596	38,774	1,803	2,277	42,854	50.6
2017	45,318	933	871	595	38,024	2,196	2,699	42,919	50.8
2018	46,729	977	933	595	39,145	2,324	2,755	44,224	48.9
FORECAST:									
2019	45,708	991	915	595	38,968	1,653	2,585	43,206	54.7
2020	46,153	1,014	923	596	39,604	1,489	2,527	43,620	53.7
2021	46,509	1,036	929	595	40,135	1,377	2,437	43,949	55.6
2022	47,104	1,057	934	595	40,457	1,609	2,452	44,519	56.0
2023	47,076	1,077	937	595	40,771	1,264	2,431	44,466	57.4
2024	47,446	1,097	940	596	41,034	1,239	2,540	44,813	57.3
2025	47,387	1,116	944	595	41,612	898	2,222	44,732	58.3
2026	47,735	1,135	948	595	41,696	898	2,463	45,057	58.2
2027	48,104	1,152	952	595	42,078	898	2,429	45,405	58.1
2028	48,636	1,169	955	596	42,754	898	2,264	45,916	57.9

* Load Factors are calculated using the actual and projected annual peak.

DUKE ENERGY FLORIDA

SCHEDULE 3.3.2
HISTORY AND FORECAST OF ANNUAL NET ENERGY FOR LOAD (GWh)
HIGH LOAD FORECAST

(1)	(2)	(3)	(4)	(OTH)	(5)	(6)	(7)	(8)	(9)
YEAR	TOTAL	RESIDENTIAL CONSERVATION	COMM. / IND. CONSERVATION	OTHER ENERGY REDUCTIONS	RETAIL	WHOLESALE	UTILITY USE & LOSSES	NET ENERGY FOR LOAD	LOAD FACTOR (%) *
HISTORY:									
2009	45,978	583	492	779	37,824	3,696	2,604	44,124	44.5
2010	48,135	638	558	779	38,925	3,493	3,742	46,160	45.3
2011	44,580	687	624	779	37,597	2,712	2,181	42,490	46.7
2012	43,396	733	669	780	36,381	1,768	3,065	41,214	52.0
2013	43,142	772	734	864	36,616	1,488	2,668	40,772	53.0
2014	43,442	812	791	864	37,240	1,333	2,402	40,975	50.7
2015	44,552	848	829	595	38,553	1,243	2,484	42,280	50.9
2016	45,199	892	857	596	38,774	1,803	2,277	42,854	50.6
2017	45,318	933	871	595	38,024	2,196	2,699	42,919	50.8
2018	46,729	977	933	595	39,145	2,324	2,755	44,224	48.9
FORECAST:									
2019	48,676	991	915	595	41,761	1,653	2,760	46,175	49.0
2020	49,460	1,014	923	596	42,702	1,489	2,736	46,927	48.2
2021	50,190	1,036	929	595	43,569	1,377	2,685	47,630	51.4
2022	51,148	1,036	929	595	44,261	1,377	2,950	48,588	52.5
2023	51,505	1,057	934	595	44,938	1,609	2,372	48,919	50.7
2024	52,251	1,097	940	596	45,551	1,239	2,828	49,617	51.4
2025	52,565	1,116	944	595	46,442	898	2,570	49,910	52.2
2026	53,302	1,135	948	595	46,936	898	2,791	50,625	52.2
2027	54,081	1,152	952	595	47,701	898	2,783	51,382	52.3
2028	54,991	1,169	955	596	48,713	898	2,660	52,270	52.4

* Load Factors are calculated using the actual and projected annual peak.

DUKE ENERGY FLORIDA

SCHEDULE 3.3.3
HISTORY AND FORECAST OF ANNUAL NET ENERGY FOR LOAD (GWh)
LOW LOAD FORECAST

(1)	(2)	(3)	(4)	(OTH)	(5)	(6)	(7)	(8)	(9)
YEAR	TOTAL	RESIDENTIAL CONSERVATION	COMM. / IND. CONSERVATION	OTHER ENERGY REDUCTIONS	RETAIL	WHOLESALE	UTILITY USE & LOSSES	NET ENERGY FOR LOAD	LOAD FACTOR (%) *
HISTORY:									
2009	45,978	583	492	779	37,824	3,696	2,604	44,124	44.5
2010	48,135	638	558	779	38,925	3,493	3,742	46,160	45.3
2011	44,580	687	624	779	37,597	2,712	2,181	42,490	46.7
2012	43,396	733	669	780	36,381	1,768	3,065	41,214	52.0
2013	43,142	772	734	864	36,616	1,488	2,668	40,772	53.0
2014	43,442	812	791	864	37,240	1,333	2,402	40,975	50.7
2015	44,552	848	829	595	38,553	1,243	2,484	42,280	50.9
2016	45,199	892	857	596	38,774	1,803	2,277	42,854	50.6
2017	45,318	933	871	595	38,024	2,196	2,699	42,919	50.8
2018	46,729	977	933	595	39,145	2,324	2,755	44,224	48.9
FORECAST:									
2019	42,473	991	915	595	35,909	1,653	2,409	39,972	62.6
2020	42,622	1,014	923	596	36,250	1,489	2,350	40,089	61.5
2021	42,693	1,036	929	595	36,492	1,377	2,264	40,133	68.0
2022	42,991	1,057	934	595	36,536	1,609	2,260	40,406	65.7
2023	42,687	1,077	937	595	36,589	1,264	2,225	40,078	68.3
2024	42,739	1,097	940	596	36,579	1,239	2,289	40,106	68.2
2025	42,386	1,116	944	595	36,816	898	2,016	39,730	70.1
2026	42,424	1,135	948	595	36,674	898	2,175	39,746	70.3
2027	42,479	1,152	952	595	36,755	898	2,126	39,780	70.4
2028	42,662	1,169	955	596	37,062	898	1,982	39,942	70.9

* Load Factors are calculated using the actual and projected annual peak.

DUKE ENERGY FLORIDA

SCHEDULE 4.1
PREVIOUS YEAR ACTUAL AND TWO-YEAR FORECAST OF PEAK DEMAND
AND NET ENERGY FOR LOAD BY MONTH
BASE CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)
	ACTUAL		FORECAST		FORECAST	
	2018		2019		2020	
MONTH	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh
JANUARY	10,320	3,734	10,174	3,311	10,435	3,295
FEBRUARY	6,980	2,899	9,098	2,893	9,369	2,967
MARCH	6,462	3,016	7,831	3,112	8,054	3,095
APRIL	6,524	3,158	7,328	3,130	7,538	3,186
MAY	8,094	3,660	8,468	3,835	8,701	3,877
JUNE	8,894	4,252	9,481	4,233	9,448	4,209
JULY	8,740	4,407	9,440	4,369	9,588	4,508
AUGUST	9,271	4,497	9,770	4,386	9,797	4,430
SEPTEMBER	9,147	4,372	9,151	4,118	9,244	4,170
OCTOBER	8,656	3,914	8,606	3,555	8,667	3,589
NOVEMBER	7,361	3,169	6,956	3,028	7,019	3,025
<u>DECEMBER</u>	<u>7,621</u>	<u>3,146</u>	<u>8,396</u>	<u>3,236</u>	<u>8,480</u>	<u>3,269</u>
TOTAL		44,224		43,206		43,620

NOTE: Recorded Net Peak demands and NEL include off-system wholesale contracts.

DUKE ENERGY FLORIDA

SCHEDULE 4.2
PREVIOUS YEAR ACTUAL AND TWO-YEAR FORECAST OF PEAK DEMAND
AND NET ENERGY FOR LOAD BY MONTH
HIGH CASE FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)
	ACTUAL		FORECAST		FORECAST	
	2018		2019		2020	
MONTH	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh
JANUARY	10,320	3,734	11,936	3,690	12,296	3,695
FEBRUARY	6,980	2,899	10,733	3,014	11,096	3,094
MARCH	6,462	3,016	9,357	3,499	9,664	3,508
APRIL	6,524	3,158	8,127	3,419	8,408	3,499
MAY	8,094	3,660	9,260	4,038	9,573	4,107
JUNE	8,894	4,252	10,280	4,380	10,325	4,386
JULY	8,740	4,407	10,197	4,489	10,439	4,661
AUGUST	9,271	4,497	10,527	4,490	10,632	4,567
SEPTEMBER	9,147	4,372	9,951	4,254	10,127	4,339
OCTOBER	8,656	3,914	9,465	3,820	9,603	3,888
NOVEMBER	7,361	3,169	8,193	3,364	8,329	3,393
<u>DECEMBER</u>	<u>7,621</u>	<u>3,146</u>	<u>10,064</u>	<u>3,719</u>	<u>10,225</u>	<u>3,790</u>
TOTAL		44,224		46,175		46,927

NOTE: Recorded Net Peak demands and NEL include off-system wholesale contracts.

DUKE ENERGY FLORIDA

SCHEDULE 4.3 PREVIOUS YEAR ACTUAL AND TWO-YEAR FORECAST OF PEAK DEMAND AND NET ENERGY FOR LOAD BY MONTH LOW LOAD FORECAST

(1)	(2)	(3)	(4)	(5)	(6)	(7)
	ACTUAL		FORECAST		FORECAST	
	2018		2019		2020	
MONTH	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh	PEAK DEMAND MW	NEL GWh
JANUARY	10,320	3,734	8,420	3,006	8,588	2,964
FEBRUARY	6,980	2,899	7,551	2,653	7,747	2,691
MARCH	6,462	3,016	6,486	2,818	6,655	2,779
APRIL	6,524	3,158	6,670	2,871	6,832	2,904
MAY	8,094	3,660	7,747	3,595	7,923	3,610
JUNE	8,894	4,252	8,697	3,931	8,597	3,878
JULY	8,740	4,407	8,658	4,141	8,745	4,251
AUGUST	9,271	4,497	8,971	4,107	8,935	4,123
SEPTEMBER	9,147	4,372	8,384	3,851	8,415	3,878
OCTOBER	8,656	3,914	7,888	3,321	7,885	3,336
NOVEMBER	7,361	3,169	6,105	2,784	6,105	2,765
<u>DECEMBER</u>	<u>7,621</u>	<u>3,146</u>	<u>6,884</u>	<u>2,894</u>	<u>6,897</u>	<u>2,911</u>
TOTAL		44,224		39,972		40,089

NOTE: Recorded Net Peak demands and NEL include off-system wholesale contracts.

FUEL REQUIREMENTS AND ENERGY SOURCES

DEF's two-year actual and ten-year projected nuclear, coal, oil, and gas requirements (by fuel unit) are shown in Schedule 5. DEF's two-year actual and ten-year projected energy sources by fuel type are presented in Schedules 6.1 and 6.2, in GWh and percent (%) respectively. Although DEF's fuel mix continues to rely on an increasing amount of natural gas to meet its generation needs, DEF continues to maintain alternate fuel supplies including long term operation of some coal fired facilities, adequate supplies of oil for dual fuel back up and increasing amounts of renewable generation particularly from solar generation. Projections shown in Schedules 5 and 6 reflect the Base Load and Energy Forecasts.

DUKE ENERGY FLORIDA

**SCHEDULE 5
FUEL REQUIREMENTS**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				-ACTUAL-											
		<u>FUEL REQUIREMENTS</u>	<u>UNITS</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>
(1)	NUCLEAR		TRILLION BTU	0	0	0	0	0	0	0	0	0	0	0	0
(2)	COAL		1,000 TON	4,023	3,746	2,437	1,644	1,458	1,318	1,500	1,815	1,838	1,951	1,901	1,950
(3)	RESIDUAL	TOTAL	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(4)		STEAM	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(5)		CC	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CT	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(7)		DIESEL	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(8)	DISTILLATE	TOTAL	1,000 BBL	136	198	27	74	56	49	45	114	208	124	189	180
(9)		STEAM	1,000 BBL	62	55	13	22	24	26	26	24	24	20	21	22
(10)		CC	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(11)		CT	1,000 BBL	74	143	14	51	31	23	19	91	185	104	168	158
(12)		DIESEL	1,000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(13)	NATURAL GAS	TOTAL	1,000 MCF	212,681	222,083	228,807	237,460	241,708	237,507	233,158	240,416	239,242	238,990	246,022	247,009
(14)		STEAM	1,000 MCF	30,663	29,207	10,777	7,888	9,150	9,675	9,396	10,732	9,546	10,260	11,401	10,788
(15)		CC	1,000 MCF	175,869	184,419	213,440	225,622	228,502	223,902	219,986	224,353	224,539	223,191	223,657	225,148
(16)		CT	1,000 MCF	6,147	8,456	4,590	3,951	4,057	3,931	3,776	5,331	5,157	5,539	10,963	11,073
	OTHER (SPECIFY)														
(17)	OTHER, DISTILLATE	ANNUAL FIRM INTERCHANGE	1,000 BBL	N/A	N/A	0	0	0	0	0	0	0	0	0	0
(18)	OTHER, NATURAL GAS	ANNUAL FIRM INTERCHANGE, CC	1,000 MCF	N/A	N/A	8,890	7,373	1,444	0	0	0	0	0	0	0
(18.1)	OTHER, NATURAL GAS	ANNUAL FIRM INTERCHANGE, CT	1,000 MCF	N/A	N/A	8,518	7,850	12,633	18,545	17,586	9,761	6,170	7,017	1,036	0
(19)	OTHER, COAL	ANNUAL FIRM INTERCHANGE, STEAM	1,000 TON	N/A	N/A	0	0	0	0	0	0	0	0	0	0

DUKE ENERGY FLORIDA

SCHEDULE 6.1
ENERGY SOURCES (GWh)

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				-ACTUAL-											
	<u>ENERGY SOURCES</u>		<u>UNITS</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>
(1)	ANNUAL FIRM INTERCHANGE ^{1/}		GWh	2,037	2,244	838	778	1,241	1,810	1,718	963	653	700	145	56
(2)	NUCLEAR		GWh	0	0	0	0	0	0	0	0	0	0	0	0
(3)	COAL		GWh	8,722	8,422	5,373	3,495	3,074	2,752	3,123	3,675	3,697	3,916	3,824	3,930
(4)	RESIDUAL	TOTAL	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(5)		STEAM	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(7)		CT	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(8)		DIESEL	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(9)	DISTILLATE	TOTAL	GWh	62	90	5	19	12	9	7	34	74	38	67	63
(10)		STEAM	GWh	33	30	0	0	0	0	0	0	0	0	0	0
(11)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(12)		CT	GWh	29	61	5	19	12	9	7	34	74	38	67	63
(13)		DIESEL	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(14)	NATURAL GAS	TOTAL	GWh	27,307	28,687	32,820	34,735	35,251	34,575	33,920	34,847	34,657	34,585	35,223	35,377
(15)		STEAM	GWh	2,869	2,714	859	614	713	761	735	851	754	810	905	854
(16)		CC	GWh	23,974	25,360	31,534	33,713	34,120	33,406	32,788	33,481	33,413	33,249	33,294	33,500
(17)		CT	GWh	464	612	428	407	417	408	397	515	490	526	1,024	1,024
(18)	OTHER ^{2/}														
	QF PURCHASES		GWh	1,754	1,826	1,921	1,929	1,922	1,920	1,922	814	496	2	2	2
	RENEWABLES OTHER		GWh	0	0	0	0	0	0	0	0	0	0	0	0
	RENEWABLES MSW		GWh	896	845	755	757	755	755	755	757	755	755	755	757
	RENEWABLES BIOMASS		GWh	584	399	0	0	0	0	0	0	0	0	0	0
	RENEWABLES SOLAR		GWh	16	26	249	875	1,496	2,698	3,022	3,723	4,400	5,061	5,389	5,731
	IMPORT FROM OUT OF STATE		GWh	1,545	1,685	1,245	1,031	199	0	0	0	0	0	0	0
	EXPORT TO OUT OF STATE		GWh	-4	0	0	0	0	0	0	0	0	0	0	0
(19)	NET ENERGY FOR LOAD		GWh	42,919	44,224	43,206	43,620	43,949	44,519	44,466	44,813	44,732	45,057	45,405	45,916

1/ NET ENERGY PURCHASED (+) OR SOLD (-) WITHIN THE FRCC REGION.

2/ NET ENERGY PURCHASED (+) OR SOLD (-).

DUKE ENERGY FLORIDA

SCHEDULE 6.2

ENERGY SOURCES (PERCENT)

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				-ACTUAL-											
	<u>ENERGY SOURCES</u>		<u>UNITS</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>
(1)	ANNUAL FIRM INTERCHANGE 1/		%	4.7%	5.1%	1.9%	1.8%	2.8%	4.1%	3.9%	2.1%	1.5%	1.6%	0.3%	0.1%
(2)	NUCLEAR		%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(3)	COAL		%	20.3%	19.0%	12.4%	8.0%	7.0%	6.2%	7.0%	8.2%	8.3%	8.7%	8.4%	8.6%
(4)	RESIDUAL	TOTAL	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(5)		STEAM	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(6)		CC	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(7)		CT	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(8)		DIESEL	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(9)	DISTILLATE	TOTAL	%	0.1%	0.2%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.2%	0.1%	0.1%	0.1%
(10)		STEAM	%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(11)		CC	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(12)		CT	%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.2%	0.1%	0.1%	0.1%
(13)		DIESEL	%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(14)	NATURAL GAS	TOTAL	%	63.6%	64.9%	76.0%	79.6%	80.2%	77.7%	76.3%	77.8%	77.5%	76.8%	77.6%	77.0%
(15)		STEAM	%	6.7%	6.1%	2.0%	1.4%	1.6%	1.7%	1.7%	1.9%	1.7%	1.8%	2.0%	1.9%
(16)		CC	%	55.9%	57.3%	73.0%	77.3%	77.6%	75.0%	73.7%	74.7%	74.7%	73.8%	73.3%	73.0%
(17)		CT	%	1.1%	1.4%	1.0%	0.9%	0.9%	0.9%	0.9%	1.1%	1.1%	1.2%	2.3%	2.2%
(18)	OTHER 2/														
	QF PURCHASES		%	4.1%	4.1%	4.4%	4.4%	4.4%	4.3%	4.3%	1.8%	1.1%	0.0%	0.0%	0.0%
	RENEWABLESOTHER		%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	RENEWABLESMW		%	2.1%	1.9%	1.7%	1.7%	1.7%	1.7%	1.7%	1.7%	1.7%	1.7%	1.7%	1.6%
	RENEWABLESBIOMASS		%	1.4%	0.9%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	RENEWABLESOLAR		%	0.0%	0.1%	0.6%	2.0%	3.4%	6.1%	6.8%	8.3%	9.8%	11.2%	11.9%	12.5%
	IMPORT FROM OUT OF STATE		%	3.6%	3.8%	2.9%	2.4%	0.5%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	EXPORT TO OUT OF STATE		%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(19)	NET ENERGY FOR LOAD		%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

1/ NET ENERGY PURCHASED (+) OR SOLD (-) WITHIN THE FRCC REGION.

2/ NET ENERGY PURCHASED (+) OR SOLD (-).

FORECASTING METHODS AND PROCEDURES

INTRODUCTION


Accurate forecasts of long-range electric energy consumption, customer growth, and peak demand are essential elements in electric utility planning. Accurate projections of a utility's future load growth require a forecasting methodology with the ability to account for a variety of factors influencing electric consumption over the planning horizon. DEF's forecasting framework utilizes a set of econometric models as well as the Itron statistically adjusted end-use (SAE) approach to achieve this end. This section will describe the underlying methodology of the customer, energy, and peak demand forecasts including the principal assumptions incorporated within each. Also included is a description of how DSM impacts the forecast and a review of DEF's DSM programs.

Figure 2.1, entitled "Customer, Energy and Demand Forecast," gives a general description of DEF's forecasting process. Highlighted in the diagram is a disaggregated modeling approach that blends the impacts of average class usage, as well as customer growth, based on a specific set of assumptions for each class. Also accounted for is some direct contact with large customers. These inputs provide the tools needed to frame the most likely scenario of the Company's future demand.

FORECAST ASSUMPTIONS

The first step in any forecasting effort is the development of assumptions upon which the forecast is based. A collaborative internal Company effort develops these assumptions including the research efforts of several external sources. These assumptions specify major factors that influence the level of customers, energy sales, or peak demand over the forecast horizon. The following set of assumptions forms the basis for the forecast presented in this document.

FIGURE 2.1
Customer, Energy, and Demand Forecast



GENERAL ASSUMPTIONS

1. Normal weather conditions for energy sales are assumed over the forecast horizon using a sales-weighted 30-year average of conditions at the St Petersburg, Orlando, and Tallahassee weather stations. For billed kilowatt-hour (kWh) sales projections, the normal weather calculation begins with a historical 30-year average of calendar and billing cycle weighted monthly heating and cooling degree-days (HDD and CDD). The expected consumption period read dates for each projected billing cycle determines the exact historical dates for developing the 30-year average weather condition each month. Each class displays different weather-sensitive base temperatures from which degree day (DD) values begin to accumulate. Seasonal and monthly peak demand projections are based on a 30-year historical average of system-weighted degree days using the “Itron Rank-Sort Normal” approach which takes annual weather extremes into account as well as the date and hour of occurrence.
2. DEF customer forecast is based upon historical population estimates and produced by the BEBR at the University of Florida (as published in “Florida Population Studies”, Bulletin No. 180 January 2018) and provides the basis for the population forecast used in the development of the DEF customer forecast. National and Florida economic projections produced by Moody’s Analytics in their July 2018 forecast, along with EIA 2018 surveys of residential appliance saturation and average appliance efficiency levels provided the basis for development of the DEF energy forecast.
3. Within the DEF service area, the phosphate mining industry is the dominant sector in the industrial sales class. Three major customers accounted for 28 percent of the industrial class MWh sales in 2018, slightly less than 2017. These energy intensive “crop nutrient” producers mine and process phosphate-based fertilizer products for the global marketplace. The supply and demand (price) for their products are dictated by global conditions that include, but are not limited to, foreign competition, national/international agricultural industry conditions, exchange-rate fluctuations, and international trade pacts. The market price of the raw mined commodity often dictates production levels. Load and energy consumption at the DEF-served mining or chemical processing sites depend heavily on plant operations, which are heavily influenced by these global as well as the local conditions, including environmental regulations. A major rock-mining site

closed in September 2018 due to an environmental issue at another site that processes this rock. Going forward, global currency fluctuations and global stockpiles of farm commodities will determine the demand for fertilizers. The DEF forecast calls for another year of lower electric consumption from this sector as the current strength of U.S. dollar makes all domestic crop-nutrient production less price competitive at home and abroad. Also, an increase in self-service generation will drag down energy requirements from DEF. The U.S. farm sector continues to be hit by sanctions on Russia which imports U.S. farm products. The forecast does account for one customer's intention to open a new mine in phases between the years 2019 and 2022. An upside risk to this projection lies in the price of energy, especially natural gas, which is a major cost in mining and producing phosphoric fertilizers. Once currency and trade issues stabilize and demand for farm products improve, one would expect a favorable environment for this industry.

4. DEF supplies load and energy service to wholesale customers on a “full” and “partial” requirement basis. Full requirements (FR) customers demand and energy are assumed to grow at a rate that approximates their historical trend. Contracts for this service include the cities of Chattahoochee, Mt. Dora and Williston. Partial requirements (PR) customers load is assumed to reflect the current contractual obligations reflected by the nature of the stratified load they have contracted for, plus their ability to receive dispatched energy from power marketers any time it is more economical for them to do so. Contracts for PR service included in this forecast are with the Reedy Creek Improvement District (RCID), Seminole Electric Cooperative, Inc. (SECI), and the city of Homestead. Many contracts are projected to “term out” in various years in this projection.
5. This forecast assumes that DEF will successfully renew all future franchise agreements.
6. This forecast incorporates demand and energy reductions expected to be realized through currently FPSC approved DSM goals as stated in Docket No. 20130200-EI.
7. This forecast reflects impacts from both Plug-in Hybrid Electric Vehicle (PHEV) and behind the meter (customer owned) Photo Voltaic (PV) units on energy and peak demand. PHEV customer penetration levels, which are expected to be a small share of the total DEF service area vehicle

stock over the planning horizon, incorporates an EPRI Model view that includes gasoline price expectations. DEF customer PV penetration levels are expected to continue to grow over the planning horizon and the forecast incorporates a view on equipment and electric price impacts on customer use.

8. Expected energy and demand reductions from customer-owned self-service cogeneration facilities are also included in this forecast. DEF will supply the supplemental load of self-service cogeneration customers. While DEF offers “standby” service to all cogeneration customers, the forecast does not assume an unplanned need for power at time of peak.
9. This forecast assumes that the regulatory environment and the obligation to serve our retail customers will continue throughout the forecast horizon. Regarding wholesale customers, the forecast does not plan for generation resources unless a long-term contract is in place. FR customers are typically assumed to renew their contracts with DEF except those who have termination provisions and have given their notice to terminate.

ECONOMIC ASSUMPTIONS

The economic outlook for this forecast was developed in the Summer of 2018 as the nation’s economy continued an upward rebound from the Great Recession. Most economic indicators pointed to significant year-over-year improvements in the near term. These included strong employment growth and declining unemployment, minimal home foreclosures, much improved home construction levels and consumer confidence. Nationally, energy prices and interest rates are low and relatively stable. Consumers were spending (and borrowing) again. More recently there are signs of marginal improvement in median household incomes (after inflation) and improvement in the rate of homeownership. As the reported rate of national unemployment is now at or below 4 percent, the tightening of the labor supply typically leads to wage increases. Increased consumer confidence, along with higher but still reasonable mortgage rates has revived the desire to own homes but home price affordability measures now limit many from entering the single-family market. While the nation’s manufacturing sector is enjoying a somewhat favorable environment, it must continue to navigate an environment with uncertain trade policy and stronger global competition. The U.S.

service sector is also riding a wave of favorable conditions. Stable interest rates and energy prices have invigorated the American consumer, and are now being reflected in higher consumer sentiment surveys. This forecast does consider policies laid out in the first six months of the Trump administration, including the 2017 Tax Cuts and Jobs Act passed in 2018. Stimulus supplied by this policy is expected to boost the economy primarily during 2018 and only marginally in 2019.

The Florida economy continues to expand at a good clip, although the level of consumer sentiment, as measured by the University of Florida-BEBR, has fallen from its mid-2018 peak. Preliminary estimates of Florida population show an increase in resident population of 356,426 from 2017's level. This amounts to 976 new residents a day or a 1.74% increase. This creates a healthy demand for housing and services throughout the State. Nationally, the U.S. census Bureau has reported that baby-boomers are retiring at a rate of 10,000 per day. Duke Energy load forecasts have been expecting for years that Florida will benefit from an on-rush of retirees. After some delay created by the financial crisis, one can safely say this trend has begun. This impact is expected to peak in 2025 but continue through most of the 2020s.

The Florida unemployment rate dropped to 3.3 percent in December 2018, down from 4.1 percent a year earlier. The State's employment picture has continued to be strong, adding 231,000 jobs over the year. Only the government sector lost jobs in 2018.

Throughout the ten-year forecast horizon, risks and uncertainties are always recognized and handled on a "highest probability of outcome" basis. General rules of economic theory, namely, supply and demand equilibrium are maintained in the long run. This notion is applied to energy/commodity prices, currency levels, the housing market, wage rates, birth rates, inflation and interest rates. Uncertainty surrounding specific weather anomalies (hurricanes or earthquakes), international crises, such as wars or terrorist acts, are not explicitly designed into this projection. Thus, any situations of this variety will result in a deviation from this forecast.

FORECAST METHODOLOGY

The DEF forecast of customers, energy sales, and peak demand applies both an econometric and end-use methodology. The residential and commercial energy projections incorporate Itron's SAE approach while other classes use customer-class specific econometric models. These models are expressly designed to capture class-specific variation over time. Peak demand models are projected on a disaggregated basis as well. This allows for appropriate handling of individual assumptions in the areas of wholesale contracts, demand response, interruptible service and changes in self-service generation capacity.

ENERGY AND CUSTOMER FORECAST

In the retail jurisdiction, customer class models have been specified showing a historical relationship to weather and economic/demographic indicators using monthly data for sales models and customer models. Sales are regressed against "driver" variables that best explain monthly fluctuations over the historical sample period. Forecasts of these input variables are either derived internally or come from a review of the latest projections made by several independent forecasting concerns. The external sources of data include Moody's Analytics and the University of Florida's BEBR. Internal company forecasts are used for projections of electricity price, weather conditions, and the length of the billing month. The incorporation of residential and commercial "end-use" energy have been modeled as well. Surveys of residential appliance saturation and average efficiency performed by the company's Market Research department and the Energy Information Agency (EIA), along with trended projections of both by Itron capture a significant piece of the changing future environment for electric energy consumption. Specific sectors are modeled as follows:

Residential Sector

Residential kWh usage per customer is modeled using the SAE framework. This approach explicitly introduces trends in appliance saturation and efficiency, dwelling size and thermal efficiency. It allows for an easier explanation of usage levels and changes in weather-sensitivity over time. The "bundling" of 19 residential appliances into "heating", "cooling" and "other" end uses form the basis of equipment-oriented drivers that interact with typical exogenous factors such as real median household income, average household size, cooling degree-days, heating degree-days, the real price of electricity to the residential class and the average number of billing days in each sales month. This

structure captures significant variation in residential usage caused by changing appliance efficiency and saturation levels, economic cycles, weather fluctuations, electric price, and sales month duration. Projections of kWh usage per customer combined with the customer forecast provide the forecast of total residential energy sales. The residential customer forecast is developed by correlating monthly residential customers with county level population projections for counties in which DEF serves residential customers are provided by the BEBR.

Commercial Sector

Commercial MWh energy sales are forecast based on commercial sector (non-agricultural, non-manufacturing and non-governmental) employment, the real price of electricity to the commercial class, the average number of billing days in each sales month and heating and cooling degree-days. As in the residential sector, these variables are interacted with the commercial end-use equipment (listed below) after trends in equipment efficiency and saturation rates have been projected.

- Heating
- Cooling
- Ventilation
- Water heating
- Cooking
- Refrigeration
- Outdoor Lighting
- Indoor Lighting
- Office Equipment (PCs)
- Miscellaneous

The SAE model contains indices that are based on end-use energy intensity projections developed from EIA's commercial end-use forecast database. Commercial energy intensity is measured in terms of end-use energy use per square foot. End-use energy intensity projections are based on end-use efficiency and saturation estimates that are in turn driven by assumptions in available technology and costs, energy prices, and economic conditions. Energy intensities are calculated from the EIA's Annual Energy Outlook (AEO) commercial database. End-use intensity projections are derived for eleven building types. The energy intensity (EI) is derived by dividing end-use electricity consumption projections by square footage:

$$EI_{bet} = Energy_{bet} / sqft_{bt}$$

Where:

$Energy_{bet}$ = energy consumption for building type b, end-use e, year t

$Sqft_{bt}$ = square footage for building type b in year t

Commercial customers are modeled using the projected level of residential customers.

Industrial Sector

Energy sales to this sector are separated into two sub-sectors. A significant portion of industrial energy use is consumed by the phosphate mining industry. Because this one industry is such a large share of the total industrial class, it is separated and modeled apart from the rest of the class. The term "non-phosphate industrial" is used to refer to those customers who comprise the remaining portion of total industrial class sales. Both groups are impacted significantly by changes in economic activity. However, adequately explaining sales levels requires separate explanatory variables. Non-phosphate industrial energy sales are modeled using Florida manufacturing employment interacted with the Florida industrial production index, and the average number of sales month billing days.

The industrial phosphate mining industry is modeled using customer-specific information with respect to expected market conditions. Since this sub-sector is comprised of only three customers, the forecast is dependent upon information received from direct customer contact. DEF Large Account Management employees provide specific phosphate customer information regarding customer production schedules, inventory levels, area mine-out and start-up predictions, and changes in self-service generation or energy supply situations over the forecast horizon. These Florida mining companies compete globally into a global market where farming conditions dictate the need for "crop nutrients". The projection of industrial accounts is expected to continue its historic decline. The decline in manufacturing nationwide, the increased competitiveness between the states, mergers between companies within the state, all have resulted in a continued decline in customer growth for this class.

Street Lighting

Electricity sales to the street and highway lighting class have now declined for several years. A continued decline is expected as improvements in lighting efficiency are projected. The number of

accounts, which has dropped by more than one-third since 1995 due to most transferring to public authority ownership, is expected to decline further before leveling off in the intermediate term. A simple time-trend was used to project energy consumption and customer growth in this class.

Public Authorities

Energy sales to public authorities (SPA), comprised of federal, state and local government operated services, is also projected to grow within the DEF's service area. The level of government services, and thus energy, can be tied to the population base, as well as the amount of tax revenue collected to pay for these services. Factors affecting population growth will affect the need for additional governmental services (i.e. public schools, city services, etc.) thereby increasing SPA energy consumption. Government employment has been determined to be the best indicator of the level of government services provided. This variable, along with cooling degree-days and the sales month billing days, results in a significant level of explained variation over the historical sample period. Adjustments are also included in this model to account for the large change in school-related energy use throughout the year. The SPA customer forecast is projected linearly as a function of a time-trend. Recent budget issues have also had an impact on the near-term pace of growth.

Sales for Resale Sector

The Sales for Resale sector encompasses all firm sales to other electric power entities. This includes sales to other utilities (municipal or investor-owned) as well as power agencies (rural electric authority or municipal).

SECI is a wholesale, or sales for resale, customer of DEF that contracts for both seasonal and stratified loads over the forecast horizon. The municipal sales for resale class includes a number of customers, divergent not only in scope of service (i.e., full or partial requirement), but also in composition of ultimate consumers. Each customer is modeled separately in order to accurately reflect its individual profile. Three customers in this class, Chattahoochee, Mt. Dora, and Williston, are municipalities whose full energy requirements are supplied by DEF. Energy projections for full requirement customers grow at a rate that approximates their historical trend with additional information coming from the respective city officials. DEF serves partial requirement service (PR) to municipalities such as Homestead, and another power provider, RCID. In each case, these

customers contract with DEF for a specific level and type of stratified capacity needed to provide their particular electrical system with an appropriate level of reliability. The energy forecast for each contract is derived using its historical load factors where enough history exists, or typical load factors for a given type of contracted stratified load and expected fuel prices. Electric energy growth and competitive market prices will dictate the amount of wholesale demand and energy throughout the forecast horizon.

PEAK DEMAND FORECAST

The forecast of peak demand also employs a disaggregated econometric methodology. For seasonal (winter and summer) peak demands, as well as each month of the year, DEF's coincident system peak is separated into five major components. These components consist of total retail load, interruptible and curtailable tariff non-firm load, conservation and demand response program capability, wholesale demand, and company use demand.

Total retail load refers to projections of DEF retail monthly net peak demand before any activation of DEF's General Load Reduction Plan. The historical values of this series are constructed to show the size of DEF's retail net peak demand assuming no utility activated load control had ever taken place. The value of constructing such a "clean" series enables the forecaster to observe and correlate the underlying trend in retail peak demand to retail customer levels and coincident weather conditions at the time of the peak and the amounts of Base-Heating-Cooling load estimated by the monthly Itron models without the impacts of year-to-year variation in utility-sponsored DR programs. Monthly peaks are projected using the Itron SAE generated use patterns for both weather sensitive (cooling & heating) appliances and base load appliances calculated by class in the energy models. Daily and hourly models of applying DEF class-of-business load research survey data lead to class and total retail hourly load profiles when a 30-year normal weather template replaces actual weather. The projections of retail peak are the result of a monthly model driven by the summation of class base, heating and cooling energy interpolated 30-year normal weather pattern-driven load profile. The projection for the months of January (winter) and August (summer) are typically when the seasonal peaks occur. Energy conservation and direct load control estimates consistent with DEF's DSM goals that have been established by the FPSC are applied to the MW forecast. Projections of dispatchable and cumulative non-dispatchable DSM impacts are subtracted from the projection of potential firm

retail demand resulting in a projected series of firm retail monthly peak demand figures. The Interruptible and Curtailable service (IS and CS) tariff load projection is developed from historic monthly trends, as well as the incorporation of specific projected information obtained from DEF's large industrial accounts on these tariffs by account executives. Developing this piece of the demand forecast allows for appropriate firm retail demand results in the total retail coincident peak demand projection.

Sales for Resale demand projections represent load supplied by DEF to other electric suppliers such as SECI, RCID, and other electric transmission and distribution entities. For Partial Requirement demand projections, contracted MW levels dictate the level of seasonal demands. The Full Requirement municipal demand forecast is estimated for individual cities using historically trended growth rates adjusted for current economic conditions.

DEF "company use" at the time of system peak is estimated using load research metering studies similar to potential firm retail. It is assumed to remain stable over the forecast horizon as it has historically.

Each of the peak demand components described above is a positive value except for the DSM program MW impacts and IS and CS load. These impacts represent a reduction in peak demand and are assigned a negative value. Total system firm peak demand is then calculated as the arithmetic sum of the five components.

HIGH & LOW SCENARIOS

DEF has developed high and low scenarios around the base case energy sales and peak demand projections. The overall results reflect a one standard deviation probability of outcome, or 67 percent of all possible outcomes between the high case and low case. Of course, the base case represents the 50/50 probability of all expected outcomes.

Both scenarios incorporate historical variation in weather and economic conditions. First, a calculation of twenty-nine years of historical variation for economic driver variables selected in the base case energy sales models. High & Low case series were developed by determining the one standard deviation level of outcome - both high and Low - around each respective base case economic variable for each class. Similarly, high and low weather variables were determined for the energy and peak weather variables (HDDs, CDDs, and monthly peak DDs) using actual 30-year weather conditions. Each weather variable used in the modeling process is ranked monthly from “high-to-low” degree days. The high (hottest) one-third of each variable is averaged and becomes a normal “High Case” weather condition. Similarly, the mildest one-third of each weather variable’s 30 observations are averaged and become the normal “Low Case” weather condition.

This procedure captures the most influential variables around energy sales and peak demand by estimating high and low cases for economics and weather conditions.

CONSERVATION

On August 20, 2015, the PSC issued Order No. PSC-15-0332-PAA-EG, approving the DEF’s Demand Side Management Plan for 2015 through 2024.

DEF’s currently approved DSM programs consist of five residential programs, six commercial and industrial programs and one research and development program that will continue to be offered through 2024. DEF also offers a Qualifying Facilities Program as discussed in Chapter 3. The programs are subject to periodic monitoring and evaluation in order to ensure that all demand-side resources are acquired in a cost-effective manner and that the program savings are durable. A brief description of each of the currently offered DSM programs is provided below.

RESIDENTIAL CONSERVATION PROGRAMS

Table 2.1 depicts the expected residential DSM savings for 2015 through 2024. The 2015 through 2018 savings reflect the actual achievements as reported on DEF’s 2018 Annual DSM Report to

the FPSC and the savings for 2019 through 2024 reflect the impacts of the residential goals as approved in the 2014 Goals Proceeding (Order PSC 14-0696-FOF-EU).

TABLE 2.1
Residential DSM MW and GWH Savings

Year	Annual Summer MW	Cumulative Summer MW	Annual Winter MW	Cumulative Winter MW	Annual GWH	Cumulative GWH
2015	25.3	25.3	41.5	41.5	39.4	39.4
2016	30.0	55.4	52.4	93.9	47.3	86.7
2017	30.6	86.0	54.3	148.2	46.4	133.1
2018	25.6	111.5	45.0	193.2	43.4	176.5
2019	17.7	129.2	37.5	230.7	13.0	189.5
2020	15.5	144.7	32.2	262.9	9.3	198.8
2021	13.7	158.4	27.8	290.7	6.2	205.0
2022	12.2	170.6	24.5	315.2	3.8	208.8
2023	11.3	181.9	22.3	337.5	2.2	211.0
2024	10.7	192.6	20.9	358.4	1.2	212.2

The following provides an overview of each Residential Program:

Home Energy Check – This is DEF’s home energy audit program as required by Rule 25-17.003(3) (b). DEF offers a variety of options to customers for home energy audits including walk-through audits, phone assisted audits, and web enabled on-line audits. At the completion of the audit, DEF also provides kits that contain energy saving measures that may be easily installed by the customer.

Residential Incentive Program – This program provides incentives on a variety of cost-effective measures designed to provide energy savings. DEF expects to provide incentives to customers for the installation of approximately 90,000 energy saving measures over the ten-year FEECA goal period. These measures primarily include heating and cooling, duct repair, insulation, and energy efficient windows. The measures and incentive levels included in this program have been updated to reflect the impacts of new codes and standards.

Neighborhood Energy Saver – This program is designed to provide energy saving education and assistance to low income customers. This program targets neighborhoods that meet certain income

eligibility requirements. DEF installs energy saving measures in approximately 4500 homes and provides home energy reports to approximately 15,000 customers annually through this program. These home energy reports provide information about energy efficiency and remind customers about low cost energy saving measures.

Low Income Weatherization Assistance Program – DEF partners with local agencies to provide funding for energy efficiency and weatherization measures to low income customers through this program. DEF expects to provide assistance to approximately 500 customers annually through this program.

EnergyWise – EnergyWise is a voluntary residential demand response program that provides monthly bill credits to customers who allow DEF to reduce peak demand by controlling service to selected electric equipment through various devices and communication options installed on the customer's premises. These interruptions are at DEF's option, during specified time periods, and coincident with hours of peak demand. Customers must have a minimum average monthly usage of 600 kwh's to be eligible to participate in this program.

COMMERCIAL/INDUSTRIAL CONSERVATION PROGRAMS

Table 2.2 depicts the expected commercial/industrial DSM savings for 2015 through 2024. The 2015 through 2018 savings reflect the actual achievements as reported on DEF's 2018 Annual DSM Report to the FPSC and the projected savings for 2019 through 2024 reflect the impacts of the commercial/industrial goals as approved in the 2014 Goals Proceeding (Order PSC 14-0696-FOF-EU).

TABLE 2.2
Commercial/Industrial DSM MW and GWH Savings

Year	Annual Summer MW	Cumulative Summer MW	Annual Winter MW	Cumulative Winter MW	Annual GWH	Cumulative GWH
2015	34.9	34.9	27.6	27.6	36.3	36.3
2016	85.3	120.2	71.9	99.5	27.6	63.9
2017	51.8	172.0	26.3	125.8	35.4	99.3
2018	60.3	232.3	43.4	169.2	39.0	138.3
2019	9.1	241.4	5.0	174.2	8.0	146.3
2020	8.2	249.6	5.2	179.4	5.9	152.2
2021	6.9	256.5	4.8	184.2	3.9	156.1
2022	6.0	262.5	4.7	188.9	2.4	158.5
2023	5.6	268.1	5.0	193.9	1.4	159.9
2024	5.0	273.1	4.6	198.5	0.8	160.7

The following provides a list of the Commercial programs along with a brief overview of each program:

Business Energy Check – This is a commercial energy audit program that provides commercial customers with an analysis of their energy usage and information about energy-saving practices and cost-effective measures that they can implement at their facilities.

Better Business – This program provides incentives to commercial customers on a variety of cost-effective energy efficiency measures. These measures include chillers, cool roof, insulation, and DX systems.

Florida Custom Incentive – The objective of this program is to encourage customers to make capital investments for the installation of energy efficiency measures which reduce energy and peak demand. This program provides incentives for customized energy efficiency projects and measures that are cost effective and are not otherwise included in DEF’s prescriptive commercial programs.

Interruptible Service – This program is available to non-residential customers with a minimum billing demand of 500 KW or more who are willing to have their power interrupted. DEF has remote control access to the switch providing power to the customer’s equipment. Customers participating in the Interruptible Service program receive a monthly interruptible demand credit based on their billing demand and billing load factor.

Curtailable Service - This program is an indirect load control program that reduces DEF's energy demand at times of capacity shortage during peak or emergency conditions.

Standby Generation - This program is a demand control program that reduces DEF's demand based upon the control of the customer equipment. The program is a voluntary program available to all commercial and industrial customers who have on-site stand-by generation capacity of at least 50 kW and are willing to reduce their DEF demand when deemed necessary.

OTHER DSM PROGRAMS

The following provides an overview of other DSM programs:

Technology Development – This program is used to fund research and development of new energy efficiency and demand response opportunities. DEF will use this program to investigate new technologies and support the development of new energy efficiency and demand response programs.

Qualifying Facilities – This program supports the administration and management of interconnection and purchased power agreements from potential and current DEF portfolio of qualifying cogeneration and small power production facilities, including renewables. The program supports meetings with interested parties or potential Qualified Facility (QF) developers interested in providing renewable capacity or energy deliveries within our service territory. Project, interconnection, and avoided cost discussions with renewable and combined heat and power developers who are also exploring distributed generation options continue to increase. Most of the interest is coming from solar photovoltaic developers as the price of photovoltaic panels has decreased over time. The cost of this technology continues to decrease and subsidies remain in place. This increase in solar activity is evident in the number of interconnection requests which now represent over 6,100 MW of solar PV projects representing 80 active projects. As the technologies advance and the market evolves, the Company's policies will continue to be refined and compliant.

CHAPTER 3

FORECAST OF FACILITIES REQUIREMENTS



CHAPTER 3

FORECAST OF FACILITIES REQUIREMENTS

RESOURCE PLANNING FORECAST

OVERVIEW OF CURRENT FORECAST

Supply-Side Resources

As of December 31, 2018, DEF had a summer total capacity resource of 11,789 MW (see Table 3.1). This capacity resource includes fossil steam generators (2,425 MW), combined cycle plants (5,226 MW), combustion turbines (2,092 MW), solar power plants (51 MW), utility purchased power (424 MW), independent power purchases (1,120 MW), and non-utility purchased power (451 MW). Table 3.2 presents DEF's firm capacity contracts with Renewable and Cogeneration Facilities.

Demand-Side Programs

Total DSM resources are presented in Schedules 3.1 and 3.2 of Chapter 2. These programs include Non-Dispatchable DSM, Interruptible Load, and Dispatchable Load Control resources.

Capacity and Demand Forecast

DEF's forecasts of capacity and demand for the projected summer and winter peaks can be found in Schedules 7.1 and 7.2, respectively. Demand forecasts shown in these schedules are based on Schedules 3.1.1 and 3.2.1, the base summer and winter forecasts. DEF's forecasts of capacity and demand are based on serving expected growth in retail requirements in its regulated service area and meeting commitments to wholesale power customers who have entered into supply contracts with DEF. In its planning process, DEF balances its supply plan for the needs of retail and wholesale customers and endeavors to ensure that cost-effective resources are available to meet the needs across the customer base.

Base Expansion Plan

DEF's planned supply resource additions and changes are shown in Schedule 8 and are referred to as DEF's Base Expansion Plan. This plan includes a net addition of 1,448 MW of Solar PV generation with an expected equivalent summer firm capacity contribution of 803 MW and 452 MW of new

natural gas fired generation consisting of two planned combustion turbine units in year 2027 at undesignated sites as well as the incorporation of the full firm capacity of the Osprey Energy Center. DEF continues to seek market supply-side resource alternatives to enhance DEF's resource plan. In this plan, DEF has assigned this DEF owned solar PV generation an equivalent summer capacity value equal to 57% of the nameplate capacity of the planned installations. This assignment assumes that the projects developed over the period of this plan will be of equivalent design to the recently completed Hamilton Solar Energy Center. Given the small amount of PV solar currently present on the DEF system, DEF plans to evaluate this assignment over time and may revise this value in future Site Plans based on changes in project designs and the data received from actual operation of these facilities once they are installed.

The promulgation of the Mercury and Air Toxics Standards (MATS) by the EPA in April of 2012 presented new environmental requirements for the DEF units at Anclote, Suwannee and Crystal River. As discussed in previous TYSPs, DEF has implemented steps at the affected sites to reach compliance with these requirements. The key step in completing this compliance plan in 2018 was the retirement of Crystal River Units 1 and 2 which became effective December 31, 2018. Additional details regarding DEF's compliance strategies in response to the MATS rule are provided in DEF's annual update to the Integrated Clean Air Compliance Plan filed in Docket No. 180007-EI.

On August 3, 2015, the EPA released final New Source Performance Standards (NSPS) for CO₂ emissions from existing fossil fuel-fired Electric Generating Units or EGUs (also known as the Clean Power Plan or CPP). In 2018, EPA proposed to replace the CPP with the Affordable Clean Energy (ACE) rule. It is anticipated that the ACE rule will be promulgated toward the end of the second quarter of 2019. Following promulgation, states will have three years to develop plans and two additional years to achieve compliance. It is also anticipated that there may be delays to the schedule due to litigation. Although there continues to be significant uncertainty about the specific form of regulation, DEF continues to expect that CO₂ emissions limitations in one form or another will be part of the regulatory future and has postulated a CO₂ emission price forecast as a placeholder for the impacts of such regulation.

DEF continues to modernize its generation resources with the retirement and projected retirements of several of the older units in the fleet, particularly combustion turbines at Higgins, Avon Park, Bayboro, Debary P2 - P6 and Bartow P1 & P3. Continued operations of the peaking units at Higgins and Avon Park are planned until the year 2020 while Bayboro is planned until the year 2025. The Debary P2 - P6 and Bartow P1 & P3 are planned to retire in 2027. There are many factors which may impact these retirements including environmental regulations and permitting, the unit's age and maintenance requirements, local operational needs, their relatively small capacity size and system requirement needs.

DEF's Base Expansion Plan projects the need for additional capacity with proposed in-service dates during the ten-year period from 2019 through 2028. The planned capacity additions, together with purchases from Qualifying Facilities (QF), Investor Owned Utilities, and Independent Power Producers help the DEF system meet the energy requirements of its customer base. The capacity needs identified in this plan may be impacted by DEF's ability to extend or replace existing purchase power, cogeneration and QF contracts and to secure new renewable purchased power resources in their respective projected timeframes. The additions in the Base Expansion Plan depend, in part, on projected load growth, and obtaining all necessary state and federal permits under current schedules. Changes in these or other factors could impact DEF's Base Expansion Plan. DEF has examined the high and low load scenarios presented in Schedules 3.1 and 3.2. As discussed in Chapter 2, these scenarios were developed to present and test a range of likely outcomes in peak load and energy demand. DEF found that the Base Expansion Plan was robust under the range of conditions examined. Current planned capacity is sufficient to meet the demand including reserve margin in these cases through 2023 allowing DEF sufficient time to plan additional generation capacity either through power purchase or new generation construction as needed if higher than baseline conditions emerge. If lower than baseline conditions emerge, DEF can defer future generation alternatives.

Status reports and specifications for the planned new generation facilities are included in Schedule 9. The planned transmission lines associated with DEF Bulk Electric System (BES) are shown in Schedule 10.

TABLE 3.1

DUKE ENERGY FLORIDA

TOTAL CAPACITY RESOURCES OF

POWER PLANTS AND PURCHASED POWER CONTRACTS

AS OF DECEMBER 31, 2018

PLANTS	SUMMER NET DEPENDABLE CAPABILITY (MW)
Fossil Steam	2,425
Combined Cycle	5,226
Combustion Turbine	2092
Solar	51
Total Net Dependable Generating Capability	9,794
Dependable Purchased Power	1,995
Firm Qualifying Facility Contracts (451 MW)	
Investor Owned Utilities (424 MW)	
Independent Power Producers (1,120 MW)	
TOTAL DEPENDABLE CAPACITY RESOURCES	11,789

TABLE 3.2

DUKE ENERGY FLORIDA

FIRM RENEWABLES

AND COGENERATION CONTRACTS

AS OF DECEMBER 31, 2018

Facility Name	Firm Capacity (MW)
Mulberry	115
Orange Cogen (CFR-Biogen)	104
Orlando Cogen	115
Pasco County Resource Recovery	23
Pinellas County Resource Recovery 1	40
Pinellas County Resource Recovery 2	14.8
Ridge Generating Station	39.6
TOTAL	451.4

DUKE ENERGY FLORIDA

**SCHEDULE 7.1
FORECAST OF CAPACITY, DEMAND AND SCHEDULED MAINTENANCE
AT TIME OF SUMMER PEAK**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
	TOTAL INSTALLED CAPACITY	FIRM ^a CAPACITY IMPORT	FIRM CAPACITY EXPORT		TOTAL CAPACITY AVAILABLE	SYSTEM FIRM SUMMER PEAK DEMAND	RESERVE MARGIN BEFORE MAINTENANCE		SCHEDULED MAINTENANCE	RESERVE MARGIN AFTER MAINTENANCE	
YEAR	MW	MW	MW	QF ^b MW	MW	MW	MW	% OF PEAK	MW	MW	% OF PEAK
2019	9,794	1,878	0	78	11,750	9,019	2,731	30%	0	2,731	30%
2020	9,955	1,878	0	78	11,911	8,953	2,958	33%	0	2,958	33%
2021	10,039	1,454	0	78	11,571	9,026	2,545	28%	0	2,545	28%
2022	10,240	1,454	0	78	11,772	9,082	2,690	30%	0	2,690	30%
2023	10,238	1,454	0	78	11,770	8,836	2,934	33%	0	2,934	33%
2024	10,657	859	0	78	11,594	8,907	2,687	30%	0	2,687	30%
2025	10,740	744	0	78	11,562	8,766	2,796	32%	0	2,796	32%
2026	10,651	640	0	78	11,369	8,839	2,530	29%	0	2,530	29%
2027	10,796	0	0	78	10,874	8,920	1,953	22%	0	1,953	22%
2028	10,835	0	0	78	10,913	9,027	1,885	21%	0	1,885	21%

Notes:

a. FIRM Capacity Import includes Cogeneration, Utility and Independent Power Producers, and Short Term Purchase Contracts.

b. QF includes Firm Renewables

DUKE ENERGY FLORIDA

SCHEDULE 7.2

**FORECAST OF CAPACITY, DEMAND AND SCHEDULED MAINTENANCE
AT TIME OF WINTER PEAK**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
	TOTAL INSTALLED CAPACITY	FIRM ^a CAPACITY IMPORT	FIRM CAPACITY EXPORT		TOTAL CAPACITY AVAILABLE	SYSTEM FIRM WINTER PEAK DEMAND		RESERVE MARGIN BEFORE MAINTENANCE	SCHEDULED MAINTENANCE	RESERVE MARGIN AFTER MAINTENANCE	
YEAR	MW	MW	MW	QF ^b MW	MW	MW	MW	% OF PEAK	MW	MW	% OF PEAK
2018/19	10,865	1,961	0	78	12,904	9,023	3,882	43%	0	3,882	43%
2019/20	10,987	1,961	0	78	13,026	9,239	3,787	41%	0	3,787	41%
2020/21	10,937	1,961	0	78	12,976	8,611	4,366	51%	0	4,366	51%
2021/22	10,937	1,537	0	78	12,552	8,958	3,595	40%	0	3,595	40%
2022/23	10,937	1,537	0	78	12,552	8,696	3,856	44%	0	3,856	44%
2023/24	10,937	1,422	0	78	12,437	8,768	3,670	42%	0	3,670	42%
2024/25	11,292	785	0	78	12,155	8,583	3,572	42%	0	3,572	42%
2025/26	11,054	681	0	78	11,813	8,633	3,180	37%	0	3,180	37%
2026/27	11,054	681	0	78	11,813	8,688	3,125	36%	0	3,125	36%
2027/28	11,092	0	0	78	11,169	8,741	2,429	28%	0	2,429	28%

Notes:

a. FIRM Capacity Import includes Cogeneration, Utility and Independent Power Producers, and Short Term Purchase Contracts.

b. QF includes Firm Renewables

DUKE ENERGY FLORIDA

**SCHEDULE 8
PLANNED AND PROSPECTIVE GENERATING FACILITY ADDITIONS AND CHANGES**

AS OF JANUARY 1, 2019 THROUGH DECEMBER 31, 2028

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
PLANT NAME	UNIT NO.	LOCATION (COUNTY)	UNIT TYPE	FUEL		FUEL TRANSPORT		CONST. START MO./YR	COMPL. IN-SERVICE MO./YR	EXPECTED RETIREMENT MO./YR	GEN. MAX. NAMEPLATE KW	FIRM NET CAPABILITY		STATUS ^a	NOTES ^b
				BBL	ALT.	BBL	ALT.					SUMMER MW	WINTER MW		
ST PETERSBURG PIER	1	PINELLAS	PV	SO				01/2019	12/2019		350	0	0	P	(1) and (2)
TRENTON	1	GILCHRIST	PV	SO				04/2019	12/2019		74,900	43	0	P	(1)
LAKE PLACID	1	HIGHLANDS	PV	SO				05/2019	12/2019		45,000	26	0	P	(1)
DEBARY	1	VOLUSIA	PV	SO				07/2019	03/2020		74,500	34	0	P	(1)
COLUMBIA	1	COLUMBIA	PV	SO				08/2019	03/2020		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2020	12/2020		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2020	12/2020		74,900	43	0	P	(1)
AVON PARK	P1	HIGHLANDS	GT	NG	DFO	PL	TK			06/2020		(24)	(25)	RT	(1)
AVON PARK	P2	HIGHLANDS	GT	DFO		TK				06/2020		(24)	(25)	RT	(1)
HIGGINS	P1-4	PINELLAS	GT	NG	DFO	PL	TK			06/2020		0	0	RT	(3)
UNKNOWN	1	UNKNOWN	PV	SO				04/2021	12/2021		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2021	12/2021		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2021	12/2021		55,000	31	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(1)			(4)
UNKNOWN	1	UNKNOWN	PV	SO				05/2021	01/2022		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				05/2021	01/2022		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(1)			(4)
UNKNOWN	1	UNKNOWN	PV	SO				04/2023	12/2023		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2023	12/2023		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(2)			(4)
OSPREY CC	1	POLK	CC	NG	DFO	PL	TK		05/2024			337	355	P	(5)
UNKNOWN	1	UNKNOWN	PV	SO				04/2024	12/2024		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2024	12/2024		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(2)			(4)
UNKNOWN	1	UNKNOWN	PV	SO				04/2025	12/2025		74,900	43	0	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2025	12/2025		74,900	43	0	P	(1)
BAYBORO	P1 - P4	PINELLAS	GT	DFO		WA				12/2025		(171)	(238)		
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(3)			(4)
UNKNOWN	1	UNKNOWN	PV	SO				04/2026	12/2026		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(3)			(4)
DEBARY	P2 - P6	VOLUSIA	GT	DFO		TK				06/2027		(249)	(324)		
BARTOW	PL P3	PINELLAS	GT	DFO		WA				06/2027		(82)	(105)		
UNKNOWN	P1	UNKNOWN	GT	NG	DFO	PL	TK	01/2025	06/2027		229,400	218	233	P	(1)
UNKNOWN	P2	UNKNOWN	GT	NG	DFO	PL	TK	01/2025	06/2027		229,400	218	233	P	(1)
UNKNOWN	1	UNKNOWN	PV	SO				04/2027	12/2027		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(4)			(4)
UNKNOWN	1	UNKNOWN	PV	SO				04/2028	12/2028		74,900	43	0	P	(1)
SOLAR DEGRADATION	N/A	N/A	N/A	N/A		N/A		N/A	N/A	N/A	N/A	(4)			(4)

a. See page v. for Code Legend of Future Generating Unit Status.

b. NOTES

- (1) Planned, Prospective, or Committed project.
- (2) St Petersburg Pier Firm Capacity is 0.16 Mw for the Summer and 0 for the Winter
- (3) Higgins P1 20 MW, P2 25 MW, P3 31 MW & P4 31 MW (Summer MW) is non-firm capacity and shown as 0 MW each due to non-firm fuel source.
- (4) Higgins P1 20 MW, P2 25 MW, P3 36 MW & P4 38 MW (Winter MW) is non-firm capacity and shown as 0 MW each due to non-firm fuel source.
- (5) Solar capacity degrades by 0.5% every year
- (6) Osprey CC Acquisition total capacity is available once Transmission Upgrades are in service, total Summer capacity goes up to 582MW and total Winter capacity goes up to 600MW

DUKE ENERGY FLORIDA

SCHEDULE 9 STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|---------------------------|----------------------|----------------|
| (1) Plant Name and Unit Number: | St Petersburg Pier | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | | 0.4 | |
| b. Summer Firm (MWac): | | 0.2 | |
| c. Winter Firm (MWac): | | - | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | | 1/2019 | |
| b. Commercial in-service date: | | 12/2019 | (EXPECTED) |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | 3 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~ 22 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | ⁽¹⁾ |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | 0.00 | |
| h. K Factor: | | NO CALCULATION | |

NOTES

⁽¹⁾ Average cost of projects to be filed together as specified in DEF's 2017 Second Revised and Restated Settlement Agreement

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|--|
| (1) Plant Name and Unit Number: | Trenton | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2019 | | |
| b. Commercial in-service date: | 12/2019 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | 0.00 | |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|--------------------|----------------------|---------|
| (1) Plant Name and Unit Number: | Lake Placid | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 45.0 | | |
| b. Summer Firm (MWac): | 25.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 5/2019 | | |
| b. Commercial in-service date: | 12/2019 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~400-450 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|-----------------|----------------------|---------|
| (1) Plant Name and Unit Number: | Columbia | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 8/2019 | | |
| b. Commercial in-service date: | 3/2020 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9 STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|---------|
| (1) Plant Name and Unit Number: | Debary | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.5 | | |
| b. Summer Firm (MWac): | 33.5 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 7/2019 | | |
| b. Commercial in-service date: | 3/2020 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~28 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2020 | | |
| b. Commercial in-service date: | 12/2020 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2020 | | |
| b. Commercial in-service date: | 12/2020 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|--|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2021 | | |
| b. Commercial in-service date: | 12/2021 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | 0.00 | |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2021 | | |
| b. Commercial in-service date: | 12/2021 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------------|--|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 55.0 | | |
| b. Summer Firm (MWac): | 31.4 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2021 | | |
| b. Commercial in-service date: | 12/2021 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~450-550 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | Less than \$1,650/Kw | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | Less than \$8/Kw | |
| g. Variable O&M (\$/MWh): | (\$2019) | 0.00 | |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 5/2021 | | |
| b. Commercial in-service date: | 01/2022 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 5/2021 | | |
| b. Commercial in-service date: | 01/2022 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2023 | | |
| b. Commercial in-service date: | 12/2023 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2024 | | |
| b. Commercial in-service date: | 12/2024 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2024 | | |
| b. Commercial in-service date: | 12/2024 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2025 | | |
| b. Commercial in-service date: | 12/2025 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2025 | | |
| b. Commercial in-service date: | 12/2025 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2026 | | |
| b. Commercial in-service date: | 12/2026 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9 STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

(1)	Plant Name and Unit Number:	Undesignated CT P1	
(2)	Capacity		
	a. Summer (MWs):	218	
	b. Winter (MWs):	233	
(3)	Technology Type:	COMBUSTION TURBINE	
(4)	Anticipated Construction Timing		
	a. Field construction start date:	1/2025	
	b. Commercial in-service date:	6/2027	(EXPECTED)
(5)	Fuel		
	a. Primary fuel:	NATURAL GAS	
	b. Alternate fuel:	DISTILLATE FUEL OIL	
(6)	Air Pollution Control Strategy:	Dry Low Nox Combustion	
(7)	Cooling Method:	N/A	
(8)	Total Site Area:	UNKNOWN	
(9)	Construction Status:	PLANNED	
(10)	Certification Status:	PLANNED	
(11)	Status with Federal Agencies:	PLANNED	
(12)	Projected Unit Performance Data		
	a. Planned Outage Factor (POF):	3.00 %	
	b. Forced Outage Factor (FOF):	2.00 %	
	c. Equivalent Availability Factor (EAF):	95.06 %	
	d. Resulting Capacity Factor (%):	7.2 %	
	e. Average Net Operating Heat Rate (ANOHR):	12,005 BTU/kWh	
(13)	Projected Unit Financial Data		
	a. Book Life (Years):	35	
	b. Total Installed Cost (In-service year \$/kW):	675.5	
	c. Direct Construction Cost (\$/kW):	(\$2019)	586.9
	d. AFUDC Amount (\$/kW):		31.1
	e. Escalation (\$/kW):		57.5
	f. Fixed O&M (\$/kW-yr):	(\$2019)	1.69
	g. Variable O&M (\$/MWh):	(\$2019)	7.16
	h. K Factor:	NO CALCULATION	

NOTES

Total Installed Cost includes gas expansion, transmission interconnection and integration

\$/kW values are based on Summer capacity

Fixed O&M cost does not include firm gas transportation costs

DUKE ENERGY FLORIDA

SCHEDULE 9 STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

(1) Plant Name and Unit Number:	Undesignated CT P2		
(2) Capacity			
a. Summer (MWs):		218	
b. Winter (MWs):		233	
(3) Technology Type:	COMBUSTION TURBINE		
(4) Anticipated Construction Timing			
a. Field construction start date:		1/2025	
b. Commercial in-service date:		6/2027	(EXPECTED)
(5) Fuel			
a. Primary fuel:		NATURAL GAS	
b. Alternate fuel:		DISTILLATE FUEL OIL	
(6) Air Pollution Control Strategy:	Dry Low Nox Combustion		
(7) Cooling Method:	N/A		
(8) Total Site Area:	UNKNOWN		
(9) Construction Status:	PLANNED		
(10) Certification Status:	PLANNED		
(11) Status with Federal Agencies:	PLANNED		
(12) Projected Unit Performance Data			
a. Planned Outage Factor (POF):		3.00 %	
b. Forced Outage Factor (FOF):		2.00 %	
c. Equivalent Availability Factor (EAF):		95.06 %	
d. Resulting Capacity Factor (%):		7.2 %	
e. Average Net Operating Heat Rate (ANOHR):		12,005 BTU/kWh	
(13) Projected Unit Financial Data			
a. Book Life (Years):		35	
b. Total Installed Cost (In-service year \$/kW):		675.5	
c. Direct Construction Cost (\$/kW):	(\$2019)	586.9	
d. AFUDC Amount (\$/kW):		31.1	
e. Escalation (\$/kW):		57.5	
f. Fixed O&M (\$/kW-yr):	(\$2019)	1.69	
g. Variable O&M (\$/MWh):	(\$2019)	7.16	
h. K Factor:		NO CALCULATION	

NOTES

Total Installed Cost includes gas expansion, transmission interconnection and integration
\$/kW values are based on Summer capacity
Fixed O&M cost does not include firm gas transportation costs

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2027 | | |
| b. Commercial in-service date: | 12/2027 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A % | |
| b. Forced Outage Factor (FOF): | | N/A % | |
| c. Equivalent Availability Factor (EAF): | | N/A % | |
| d. Resulting Capacity Factor (%): | | ~29 % | |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A BTU/kWh | |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 9

STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES AS OF JANUARY 1, 2019

- | | | | |
|--|----------------|----------------|---------|
| (1) Plant Name and Unit Number: | TBD | | |
| (2) Capacity | | | |
| a. Nameplate (MWac): | 74.9 | | |
| b. Summer Firm (MWac): | 42.7 | | |
| c. Winter Firm (MWac): | - | | |
| (3) Technology Type: | PHOTOVOLTAIC | | |
| (4) Anticipated Construction Timing | | | |
| a. Field construction start date: | 4/2028 | | |
| b. Commercial in-service date: | 12/2028 | (EXPECTED) | |
| (5) Fuel | | | |
| a. Primary fuel: | SOLAR | | |
| b. Alternate fuel: | N/A | | |
| (6) Air Pollution Control Strategy: | N/A | | |
| (7) Cooling Method: | N/A | | |
| (8) Total Site Area: | ~500-600 ACRES | | |
| (9) Construction Status: | PLANNED | | |
| (10) Certification Status: | | | |
| (11) Status with Federal Agencies: | | | |
| (12) Projected Unit Performance Data | | | |
| a. Planned Outage Factor (POF): | | N/A | % |
| b. Forced Outage Factor (FOF): | | N/A | % |
| c. Equivalent Availability Factor (EAF): | | N/A | % |
| d. Resulting Capacity Factor (%): | | ~29 | % |
| e. Average Net Operating Heat Rate (ANOHR): | | N/A | BTU/kWh |
| (13) Projected Unit Financial Data | | | |
| a. Book Life (Years): | | 30 | |
| b. Total Installed Cost (In-service year \$/kW): | | | |
| c. Direct Construction Cost (\$/kWac): | (\$2019) | | |
| d. AFUDC Amount (\$/kW): | | | |
| e. Escalation (\$/kW): | | | |
| f. Fixed O&M (\$/kWdc-yr): | (\$2019) | | |
| g. Variable O&M (\$/MWh): | (\$2019) | | 0.00 |
| h. K Factor: | | NO CALCULATION | |

DUKE ENERGY FLORIDA

SCHEDULE 10

STATUS REPORT AND SPECIFICATIONS OF PROPOSED DIRECTLY ASSOCIATED TRANSMISSION LINES

OSPREY

- | | |
|---|--------------------------------------|
| (1) POINT OF ORIGIN AND TERMINATION: | Kathleen - Osprey - Haines City East |
| (2) NUMBER OF LINES: | 1 |
| (3) RIGHT-OF-WAY: | New transmission line right-of-way |
| (4) LINE LENGTH: | 50 miles |
| (5) VOLTAGE: | 230 kV |
| (6) ANTICIPATED CONSTRUCTION TIMING: | 6/1/2024 |
| (7) ANTICIPATED CAPITAL INVESTMENT: | \$150,000,000 |
| (8) SUBSTATIONS: | Kathleen, Osprey, Haines City East |
| (9) PARTICIPATION WITH OTHER UTILITIES: | N/A |


INTEGRATED RESOURCE PLANNING OVERVIEW

DEF employs an Integrated Resource Planning (IRP) process to determine the most cost-effective mix of supply- and demand-side alternatives that will reliably satisfy our customers' future demand and energy needs. DEF's IRP process incorporates state-of-the-art computer models used to evaluate a wide range of future generation alternatives and cost-effective conservation and dispatchable demand-side management programs on a consistent and integrated basis.

An overview of DEF's IRP Process is shown in Figure 3.1. The process begins with the development of various forecasts, including demand and energy, fuel prices, and economic assumptions. Future supply- and demand-side resource alternatives are identified and extensive cost and operating data are collected to enable these to be modeled in detail. These alternatives are optimized together to determine the most cost-effective plan for DEF to pursue over the next ten years to meet the Company's reliability criteria. The resulting ten-year plan, the Integrated Optimal Plan, is then tested under different relevant sensitivity scenarios to identify variances, if any, which would warrant reconsideration of any of the base plan assumptions. If the plan is judged robust and works within the corporate framework, it evolves as the Base Expansion Plan. This process is discussed in more detail in the following section titled "The Integrated Resource Planning (IRP) Process".

The IRP provides DEF with substantial guidance in assessing and optimizing the Company's overall resource mix on both the supply side and the demand side. When a decision supporting a significant resource commitment is being developed (e.g. plant construction, power purchase, DSM program implementation), the Company will move forward with directional guidance from the IRP and delve much further into the specific levels of examination required. This more detailed assessment will typically address very specific technical requirements and cost estimates, detailed corporate financial considerations, and the most current dynamics of the business and regulatory environments.

FIGURE 3.1
Integrated Resource Planning (IRP) Process Overview



THE INTEGRATED RESOURCE PLANNING (IRP) PROCESS

Forecasts and Assumptions

The evaluation of possible supply- and demand-side alternatives, and development of the optimal plan, is an integral part of the IRP process. These steps together comprise the integration process that begins with the development of forecasts and collection of input data. Base forecasts that reflect DEF's view of the most likely future scenario are developed. Additional future scenarios along with high and low forecasts may also be developed. Computer models used in the process are brought up-to-date to reflect this data, along with the latest operating parameters and maintenance schedules for DEF's existing generating units. This establishes a consistent starting point for all further analysis.

Reliability Criteria

Utilities require a margin of generating capacity above the firm demands of their customers in order to provide reliable service. Periodic scheduled outages are required to perform maintenance and inspections of generating plant equipment. At any given time during the year, some capacity may be out of service due to unanticipated equipment failures resulting in forced outages of generation units. Adequate reserve capacity must be available to accommodate these outages and to compensate for higher than projected peak demand due to forecast uncertainty and abnormal weather. In addition, some capacity must be available for operating reserves to maintain the balance between supply and demand on a moment-to-moment basis.

DEF plans its resources in a manner consistent with utility industry planning practices, and employs both deterministic and probabilistic reliability criteria in the resource planning process. A Reserve Margin criterion is used as a deterministic measure of DEF's ability to meet its forecasted seasonal peak load with firm capacity. DEF plans its resources to satisfy a minimum 20 percent Reserve Margin criterion.

Loss of Load Probability (LOLP) is a probabilistic criterion that measures the probability that a company will be unable to meet its load throughout the year. While Reserve Margin considers the peak load and amount of installed resources, LOLP considers generating unit sizes, capacity mix, maintenance scheduling, unit availabilities, and capacity assistance available from other utilities. A

standard probabilistic reliability threshold commonly used in the electric utility industry, and the criterion employed by DEF, is a maximum of one day in ten years loss of load probability.

DEF has based its resource planning on the use of dual reliability criteria since the early 1990s, a practice that has been accepted by the FPSC. DEF's resource portfolio is designed to satisfy the 20 percent Reserve Margin requirement and probabilistic analyses are periodically conducted to ensure that the one day in ten years LOLP criterion is also satisfied. By using both the Reserve Margin and LOLP planning criteria, DEF's resource portfolio is designed to have sufficient capacity available to meet customer peak demand, and to provide reliable generation service under expected load conditions. DEF has found that resource additions are typically triggered to meet the 20 percent Reserve Margin thresholds before LOLP becomes a factor.

Supply-Side Screening

Potential supply-side resources are screened to determine those that are the most cost-effective. Data used for the screening analysis is compiled from various industry sources and DEF's experiences. The wide range of resource options is pre-screened to set aside those that do not warrant a detailed cost-effectiveness analysis. Typical screening criteria are costs, fuel source, technology maturity, environmental parameters (e.g. possible climate legislation), and overall resource feasibility.

Economic evaluation of generation alternatives is performed using the System Optimizer optimization program, a module of the Energy Portfolio Management software. This optimization tool evaluates revenue requirements for specific resource plans generated from multiple combinations of future resource additions that meet system reliability criteria and other system constraints. All resource plans are then ranked by system revenue requirements.

Demand-Side Screening

Like supply-side resources, the impacts of potential demand-side resources are also factored into the integrated resource plan. The projected MW and MWH impacts for demand-side management resources are based on the energy efficiency measures and load management programs included in DEF's 2015 DSM Plan and meet the goals established by the Florida Public Service Commission (FPSC) in December 2014 (Docket 130200-EI).

Resource Integration and the Integrated Optimal Plan

The cost-effective generation alternatives can then be optimized together with the demand-side portfolios developed in the screening process to formulate integrated optimal plans. The optimization program considers all possible future combinations of supply- and demand-side alternatives that meet the Company's reliability criteria in each year of the ten-year study period and reports those that provide both flexibility and reasonable revenue requirements (rates) for DEF's customers.

Developing the Base Expansion Plan

The integrated optimized plan that provides the lowest revenue requirements may then be further tested using sensitivity analysis, including High and Low Demand and Energy Forecasts (see Schedules 2 and 3). The economics of the plan may be evaluated under high and low forecast scenarios for fuel, load and financial assumptions, or any other sensitivities which the planner deems relevant. From the sensitivity assessment, the plan that is identified as achieving the best balance of flexibility and cost is then reviewed within the corporate framework to determine how the plan potentially impacts or is impacted by many other factors. If the plan is judged robust under this review, it would then be considered the Base Expansion Plan.

KEY CORPORATE FORECASTS

Load Forecast

The assumptions and methodology used to develop the base case load and energy forecast are described in Chapter 2 of this TYSP. The High and Low forecasts of load and energy were provided to Resource Planning to test the robustness of the base plan.

Fuel Forecast

The base case fuel price forecast was developed using short-term and long-term spot market price projections from industry-recognized sources. The base cost for coal is based on the existing contracts and spot market coal prices and transportation arrangements between DEF and its various suppliers. For the longer term, the prices are based on spot market forecasts reflective of expected market conditions. Oil and natural gas prices are estimated based on current and expected contracts and spot purchase arrangements as well as near-term and long-term market forecasts. Oil and natural gas

commodity prices are driven primarily by open market forces of supply and demand. Natural gas firm transportation cost is determined primarily by pipeline tariff rates.

Financial Forecast

The key financial assumptions used in DEF's most recent planning studies were 47 percent debt and 53 percent equity capital structure, projected cost of debt of 4.55 percent, and an equity return of 10.5 percent. The assumptions resulted on a weighted average cost of capital of 7.70 percent and an after-tax discount rate of 7.15 percent.

TEN-YEAR SITE PLAN (TYSP) RESOURCE ADDITIONS

DEF's planned supply resource additions and changes are shown in Schedule 8 and are referred to as DEF's Base Expansion Plan. This plan includes a net addition of 1,448 MW of Solar PV generation with an expected equivalent summer firm capacity contribution of 803 MW and 452 MW of new natural gas fired generation consisting of two planned combustion turbine units in year 2027 at undesignated sites as well as the incorporation of the full firm capacity of the Osprey Energy Center. DEF continues to seek market supply-side resource alternatives to enhance DEF's resource plan. In this plan, DEF has assigned this DEF owned solar PV generation an equivalent summer capacity value equal to 57% of the nameplate capacity of the planned installations. This assignment assumes that the projects developed over the period of this plan will be of equivalent design to the recently completed Hamilton Solar Energy Center. Given the small amount of PV solar currently present on the DEF system, DEF plans to evaluate this assignment over time and may revise this value in future Site Plans based on changes in project designs and the data received from actual operation of these facilities once they are installed.

DEF's Base Expansion Plan projects the need for additional capacity with proposed in-service dates during the ten-year period from 2019 through 2028. The planned capacity additions, together with purchases from Qualifying Facilities (QF), Investor Owned Utilities, and Independent Power Producers help the DEF system meet the energy requirements of its customer base. The capacity needs identified in this plan may be impacted by DEF's ability to extend or replace existing purchase power and QF contracts and to secure new renewable purchased power resources in their

respective projected timeframes. The additions in the Base Expansion Plan depend, in part, on projected load growth, and obtaining all necessary state and federal permits under current schedules. Changes in these or other factors could impact DEF's Base Expansion Plan.

Through its ongoing planning process, DEF will continue to evaluate the timetables for all projected resource additions and assess alternatives for the future considering, among other things, projected load growth, fuel prices, lead times in the construction marketplace, project development timelines for new fuels and technologies, and environmental compliance considerations. The Company will continue to examine the merits of new generation alternatives and adjust its resource plans accordingly to ensure optimal selection of resource additions based on the best information available.

RENEWABLE ENERGY

DEF continues to secure renewable energy from the following facilities listed by fuel type:

Purchases from Municipal Solid Waste Facilities:

- Pasco County Resource Recovery (23 MW)
- Pinellas County Resource Recovery (54.8 MW)
- Dade County Resource Recovery (As Available)
- Lake County Resource Recovery (As Available)
- Lee County Resource Recovery (As Available)

Purchases from Waste Heat from Exothermic Processes:

- PCS Phosphate (As Available)
- Citrus World (As Available)

Photovoltaics

- DEF-owned Solar Facilities (92.6 MW)
 - Osceola 3.8MW
 - Perry 5.1 MW
 - Suwannee 8.8MW
 - Hamilton 74.9MW

Customer-owned renewable generation under DEF's Net Metering Tariff (98 MW as of 12/31/18)

DEF also has several As-Available contracts utilizing solar PV technologies. As-Available energy purchases are made on an hour by hour basis for which contractual commitments to the quantity, time or reliability of delivery are not required. At this time, the solar developers are projecting in-service dates beyond 2019. As of December 31, 2018, DEF had over 6,100 MW of solar projects in the various grid interconnection queues in Florida, representing over 80 active projects. While some of those projects anticipate selling to entities other than DEF, the Company continues to have the obligation to purchase uncommitted energy from those certified QF facilities at As-Available energy rates. As a result, DEF has assumed the future presence of some 500 MW of QF solar projects over a 5-year period. In total, DEF is reasonably projecting over 2,500 MW of solar PV projects to be installed in the DEF territory over the 10-year period. Project ownership proportions may change over time based on specific project economics, development details, renewable energy incentives and other factors.

DEF continues to field inquiries from renewable suppliers and explore whether these potential QF suppliers can provide project commitments and reliable capacity or energy consistent with FERC Rules and the FPSC Rules, 25-17.080 through 25-17.310. DEF will continue to submit renewable contracts in compliance with all rules as appropriate.

Depending upon the mix of generators operating at any given time, the purchase of renewable energy may reduce DEF's use of fossil fuels. Renewable energy sources making firm commitments to the company can also defer or eliminate the need to construct more conventional generators. As part of DEF's integrated resource planning process, we are continually evaluating cost-effective alternatives to meet our customer's needs. DEF knows that renewable and distributed energy resources are an important part of Florida's energy future and we are committed to advancing these resources in an affordable and sustainable way. We are encouraged to see solar PV technology continue to reduce in price. As a result of the forecasts around solar PV technology, DEF has incorporated this clean energy source as a supply-side resource in both DEF's near-term and long-term generation plans.

The development, construction, commissioning and initial operation of the solar demonstration projects at Perry, Osceola, Suwannee and the now commercial Hamilton plant have provided DEF with valuable experience in siting, contracting, constructing, operating, and integrating solar photovoltaic technology facilities on the power grid. DEF has worked with the contractors and drawn experience from Duke's North Carolina jurisdiction to establish necessary standards for the construction and upkeep of utility grade facilities and to develop standards necessary to ensure the reliability of local distribution systems. In addition, operating data from these facilities will begin to provide DEF with a location specific understanding of solar energy production, potential fuel diversity contributions and how these will interact with the existing resource portfolio. Adding these near-term solar facilities is a natural evolution of integrating new generation technology, and supplements the solar PV research and demonstration pilots operated under DEF's conservation programs. The Osceola, Perry, Suwannee and Hamilton arrays are shown in Figures 3.2, 3.3, 3.4, and 3.5 below.

FIGURE 3.2
Osceola Solar Site



FIGURE 3.3
Perry Solar Site



FIGURE 3.4
Suwannee Solar Site



FIGURE 3.5
Hamilton Solar Site



DEF's current forecast, supporting the Base Expansion Plan includes over 700 MW of DEF-owned solar PV to be under development over the next four years and over 1,500 MW over the 10-year planning horizon. As with all forecasts included here, the forecast relies heavily on the forward-looking price for this technology, the value rendered by this technology, and considerations to other emerging and conventional cost-effective alternatives, including the use of emerging battery storage technology.

PLAN CONSIDERATIONS

Load Forecast

In general, higher-than-projected load growth would shift the need for new capacity to an earlier year and lower-than-projected load growth would delay the need for new resources. The Company's resource plan provides the flexibility to shift certain resources to earlier or later in-service dates should a significant change in projected customer demand begin to materialize. A specific discussion of DEF's review of load growth forecasts higher and lower than the base forecast can be found in the previous sections.

TRANSMISSION PLANNING

DEF's transmission planning assessment practices are developed to test the ability of the planned system to meet the reliability criteria as outlined in the FERC Form No. 715 filing, and to assure

the system meets DEF, Florida Reliability Coordinating Council, Inc. (FRCC), and North American Electric Reliability Corporation (NERC) criteria. This involves the use of load flow and transient stability programs to model various contingency situations that may occur, and in determining if the system response meets the reliability criteria. In general, this involves running simulations for the loss of any single line, generator, or transformer. DEF runs this analysis for contingencies that may occur at system peak and off-peak load levels, under both summer and winter conditions. Additional studies are performed to determine the system response to credible, but less probable criteria. These studies include the loss of multiple generators, transmission lines, or combinations of each (some load loss is permissible under the more severe disturbances). These credible, but less probable scenarios are also evaluated at various load levels, since some of the more severe situations occur at average or minimum load conditions. In particular, critical fault clearing times are typically the shortest (most severe) at minimum load conditions, with just a few large base load units supplying the system needs. As noted in the DEF reliability criteria, some remedial actions are allowed to reduce system loadings; in particular, sectionalizing is allowed to reduce loading on lower voltage lines for bulk system contingencies, but the risk to load on the sectionalized system must be reasonable (it would not be considered prudent to operate for long periods with a sectionalized system). In addition, the number of remedial action steps and the overall complexity of the scheme are evaluated to determine overall acceptability.

DEF presently uses the following reference documents to calculate and manage Available Transfer Capability (ATC), Total Transfer Capability (TTC) and Transmission Reliability Margin (TRM) for required transmission path postings on the Florida Open Access Same Time Information System (OASIS):

- http://www.oatiaoasis.com/FPC/FPCdocs/ATCID_Posted_Rev3.docx
- http://www.oatiaoasis.com/FPC/FPCdocs/TRMID_4.docx

DEF uses the following reference document to calculate and manage Capacity Benefit Margin (CBM):

- http://www.oatiaoasis.com/FPC/FPCdocs/CBMID_rev3.docx

CHAPTER 4

ENVIRONMENTAL AND LAND USE INFORMATION



CHAPTER 4

ENVIRONMENTAL AND LAND USE INFORMATION

PREFERRED SITES


DEF's 2019 TYSP Preferred Sites include the four solar generations sites; the Debary Solar Site, the Trenton Solar Site, the Lake Placid Solar Site and the Columbia Solar Site. These Preferred Sites are discussed below.

DEBARY SOLAR SITE

DEF has identified the existing Debary Energy Center site as a preferred site for future solar and/or natural gas fired simple cycle generation. The Debary site currently houses 9 simple cycle peaking units, an oil storage facility, transmission and distribution substations and is connected by both 115 kV and 230 kV transmission lines. Natural gas to the site is provide through a lateral from the Florida Gas Transmission system.

The Debary Solar Project site consists of approximately 450 acres in Volusia County, and is planned to generate 74.5 megawatts of electricity from approximately 300,000 solar panels. The site is currently undeveloped timber lands. The project will not impact any wetlands or floodplains. The site is located within the jurisdiction of the City of Debary and Duke requested a modification to the zoning regulations to allow solar development to occur. This request was approved on March 6, 2019. A Final Site Plan approval is required before construction can occur. The project plans to start construction in the second quarter of 2019 and achieve placed in service in the spring of 2020.

Debary Solar Project




DEF has identified the Trenton Project, a 74.9 MWac solar single-axis tracking PV project located in Gilchrist County, Florida. The site is former agricultural/cattle grazing and pine timber land and is relatively flat with minimal sloping that will allow for the use of a tracking system. There are no expected impacts to wetlands on site. DEF received approval of the Special Use Permit for solar from Gilchrist County in January 2019. Permits for gopher tortoise mitigation, and stormwater management along with the final site plan are expected to be approved in April 2019. The point of interconnection is the existing Trenton 69kV Substation and will be connected via a generation tie-line. The project is expected to start construction in the 2nd quarter of 2019 with an expected in-service date in the 4th quarter of 2019.

[illegible]

LAKE PLACID SOLAR POWER PLANT

DEF has identified the Lake Placid Project, a 45.0 MWac single-axis tracking solar PV project located in Highlands County, Florida. The facility will be constructed on approximately 380 acres that are under a long-term lease. The site is a former citrus grove and is relatively flat with minimal sloping that will allow for the use of a tracking system. The point of interconnection is the existing Lake Placid North 69kV Substation. The project is expected to start construction in the second quarter of 2019 with an expected in-service date in the fourth quarter of 2019. All environmental studies have been complete and the project will have no impacts, all permitting and agency approval have been received.

FIGURE 4.3
Lake Placid Solar Project



DEF has identified the Columbia Solar Project, a 74.9 MWac solar single-axis tracking PV project located in Columbia County, Florida. The site is a former agricultural and cattle grazing lands and is relatively flat with minimal sloping that will allow for the use of a tracking system. All permitting is complete and there will be no expected impacts to wetlands or endangered species. FDEP has requested a preconstruction survey for both Gopher Tortoises and American Kestrel to be completed just prior to construction. None are expected to be found. All environmental surveys are complete and DEF has received necessary pre-construction permits from Columbia County (Conditional Use Permit) and FDEP regarding stormwater (Environmental Resource Permit). The point of interconnection will be a new 69 kV 4 ring breaker bus switching station and will be connected via a generation tie-line. The project is expected to start construction in mid-2019 with an expected in-service date in the first quarter of 2020.

[illegible]

ST. PETERSBURG PIER SOLAR ENERGY CENTER

The St Petersburg Pier solar project is under construction midway between St Petersburg Museum of History and the end of the pier. The approximately 2-acre site includes paved areas used for parking and some open space. The area will be renovated and an enhanced parking area is under construction. The grid tied solar arrays will be installed on canopies covering parking spaces and will provide shade while generating energy. The site is already zoned for the proposed use and no additional environmental permits were required.

FIGURE 4.5
St Petersburg Pier Solar Energy Center

