



April 1, 2021

Adam Teitzman
Florida Public Service Commission
Office of Commission Clerk
2540 Shumard Oak Blvd
Tallahassee, Florida 32399-0850

Subject: 2021 Orlando Utilities Commission Ten-Year Site Plan

Dear Mr. Teitzman,

Enclosed please find an electronic copy of the 2021 Orlando Utilities Commission (OUC) Ten-Year Site Plan (TYSP). The 2021 OUC TYSP was prepared by nFront Consulting LLC (nFront) and is being submitted by nFront on behalf of OUC.

If you have any questions about this TYSP, please do not hesitate to contact me.

Respectfully submitted,

/s/ *Bradley Kushner*

Bradley Kushner
Executive Consultant
nFront Consulting LLC
BradKushner@nFrontConsulting.com
(816) 547-1637



The Reliable One®

**Orlando Utilities Commission
2021 Ten-Year Site Plan**

**Prepared by:
nFront Consulting LLC
April 1, 2021**



Table of Contents

| | |
|--|------|
| 1.0 Executive Summary..... | 1-1 |
| 2.0 Utility System Description..... | 2-1 |
| 2.1 Existing Generation System | 2-1 |
| 2.2 Purchase Power Resources | 2-4 |
| 2.3 Power Sales Contracts..... | 2-4 |
| 2.4 OUC’s Renewable Energy and Sustainability Initiatives and Community Activities | 2-6 |
| 2.5 Transmission System..... | 2-15 |
| 3.0 Strategic Considerations | 3-1 |
| 3.1 Strategic Business Units | 3-1 |
| 3.2 Florida Municipal Power Pool | 3-4 |
| 3.3 Security of Power Supply | 3-5 |
| 3.4 Environmental Performance | 3-5 |
| 3.5 Community Engagement, Connecting with Our Customers, and Economic Development..... | 3-6 |
| 4.0 Forecast of Peak Demand and Energy Consumption..... | 4-1 |
| 4.1 Forecast Methodology | 4-1 |
| 4.2 Base Case Forecast Assumptions | 4-4 |
| 4.3 Base Case Load Forecast | 4-5 |
| 4.4 High and Low Load Scenarios..... | 4-8 |
| 5.0 Demand-Side Management | 5-1 |
| 5.1 Energy Survey Programs | 5-3 |
| 5.2 Rebate Programs..... | 5-4 |
| 5.3 OUC’s Additional DSM/EE/Conservation Programs and Activities | 5-8 |
| 6.0 Forecast of Facilities Requirements | 6-1 |
| 6.1 Existing Capacity Resources | 6-1 |
| 6.2 Reserve Margin Requirements | 6-2 |
| 6.3 Future Resource Needs..... | 6-2 |
| 7.0 Supply-Side Alternatives | 7-1 |
| 8.0 Economic Evaluation Criteria and Methodology | 8-1 |
| 8.1 Economic Parameters | 8-1 |
| 8.2 Fuel Price Forecasts | 8-1 |
| 9.0 Analysis and Results | 9-1 |

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

9.1 CPWC Analysis.....9-1
10.0 Environmental and Land Use Information10-1
11.0 Conclusions11-1
12.0 Ten-Year Site Plan Schedules12-1

1.0 EXECUTIVE SUMMARY

This report documents the 2021 Orlando Utilities Commission (OUC) Ten-Year Site Plan pursuant to Section 186.801 Florida Statutes and Section 25-22.070 of Florida Administrative Code. OUC's Ten-Year Site Plan provides information required by this rule and consists of the following additional sections:

- Utility System Description (Section 2.0)
- Strategic Issues (Section 3.0)
- Forecast of Peak Demand and Energy Consumption (Section 4.0)
- Demand-Side Management (Section 5.0)
- Forecast of Facilities Requirements (Section 6.0)
- Supply-Side Alternatives (Section 7.0)
- Economic Evaluation Criteria and Methodology (Section 8.0)
- Analysis and Results (Section 9.0)
- Environmental and Land Use Information (Section 10.0)
- Conclusions (Section 11.0)
- Ten-Year Site Plan Schedules (Section 12.0)

In 2020 OUC finalized an Electric Integrated Resource Plan (EIRP), which provides a roadmap to enable OUC to achieve its goal of Net Zero Carbon by 2050, as well as interim goals of 50% carbon emissions reductions by 2030 and 75% carbon emissions reductions by 2040 as compared to 2005 levels. This commitment aligns with the City of Orlando's 2017 proclamation to achieve 100% renewable energy generation by 2050. The first major steps to achieving these carbon reduction targets will be converting two coal fired generating units (Stanton Energy Center Units 1 and 2) to cleaner-burning natural gas with the first unit converted no later than 2025 and the second unit converted no later than 2027, and adding 1,267 MWac of solar and 350 MW of battery storage by 2030.

OUC has assumed responsibility for supplying all of the City of St. Cloud (St. Cloud) loads through calendar year 2042. Load forecasts for OUC and St. Cloud have been integrated into one forecast, and details of the aggregated load forecast are provided in Section 4.0, including base-case growth, high-growth, and low-growth scenarios.

OUC has a contract to provide power to the City of Lake Worth Beach (Lake Worth) through calendar year 2025, a contract to provide power to the City of Winter Park (Winter Park) through calendar year 2026, a contract to provide power to the City of Mount Dora (Mt. Dora) through 2027, a contract to provide power to the City of Chattahoochee (Chattahoochee) through 2027, and a contract to provide power to Lakeland Electric (Lakeland) beginning in April 2021 and extending through December of 2023. The power OUC is currently planning to provide to Lake Worth, Winter Park, Mt. Dora, Chattahoochee, and Lakeland is summarized in Section 2.0.

OUC is a member of the Florida Municipal Power Pool (FMPP), which consists of OUC, Lakeland Electric (Lakeland), and the Florida Municipal Power Agency (FMPP) All-Requirements Project. Power for OUC is supplied by units owned entirely by OUC, as well as units in which OUC maintains joint ownership and power purchases. OUC's available capacity as of January 1, 2021, including capacity from units owned by OUC, St. Cloud's entitlement to Stanton Energy Center Unit 2, and OUC's current power purchases

(including natural gas, as well as landfill gas and solar resources), provides total net summer capacity of approximately 1,936 megawatts (MW) and total net winter capacity of approximately 1,920 MW¹.

As discussed throughout this Ten-Year Site Plan, consideration of OUC's current generating resources (including existing and planned power purchase agreements) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in this Ten-Year Site Plan). As such, no new capacity additions are included in this Ten-Year Site Plan, beyond the solar and battery storage purchases associated with OUC's EIRP and discussed throughout this Ten-Year Site Plan.

¹ Net seasonal capacity ratings as of January 1, 2021. Includes capacity owned by OUC and St. Cloud, as well as OUC's contractual power purchases. Includes capacity from OUC's share of McIntosh Unit 3, which, as discussed throughout this Ten-Year Site Plan, is anticipated to be removed from service by March 31, 2021.

2.0 UTILITY SYSTEM DESCRIPTION

At the turn of the 20th century, John M. Cheney, an Orlando, Florida judge, organized the Orlando Water and Light Company and supplied electricity on a part-time basis with a 100 kilowatt (kW) generator. Twenty-four-hour service began in 1903. The population of the City of Orlando (City) had grown to roughly 10,000 by 1922, and Cheney, realizing the need for wider services than his company was capable of supplying, urged his friends to work and vote for a \$975,000 bond issue to enable the citizens of Orlando to purchase and municipally operate his privately owned utility. The bond issue passed by a margin of almost three to one, as did a subsequent issue for additional improvements. The citizens of Orlando acquired Cheney's company and its 2,795 electricity and 5,000 water customers for a total initial investment of \$1.5 million.

In 1923, OUC was created by an act of the state legislature and was granted full authority to operate electric and water municipal utilities. The business was a paying venture from the start. By 1924, the number of customers had more than doubled, and OUC had contributed \$53,000 to the City.

When Orlando citizens took over operation of their utility, the City's population was less than 10,000; by 1925, it had grown to 23,000. That year, more than \$165,000 was transferred to the City, and an additional \$111,000 was transferred in 1926.

Today, OUC operates as a statutory commission created by the legislature of the State of Florida as a separate part of the government of the City. OUC has full authority over the management and control of the electric and waterworks plants in the City and has been approved by the Florida legislature to offer these services in Osceola County, as well as Orange County. OUC's charter allows it to undertake, among other things, the construction, operation, and maintenance of electric generation, transmission, and distribution systems, chilled water systems, as well as water production, transmission, and distribution systems, to meet the requirements of its customers.

In 1997, OUC entered into an Interlocal Agreement with the City of St. Cloud in which OUC assumed responsibility for supplying all of St. Cloud's loads for the 25-year term of the agreement, which added an additional 150 square miles of service area. OUC also assumed management of St. Cloud's existing generating units and power purchase contracts. This agreement has been extended through 2042.

2.1 Existing Generation System

Presently, OUC has ownership interests in four electric generating plants, which are described further in this section. Table 2-1 summarizes OUC's generating facilities, which include:

- Stanton Energy Center Units 1 and 2, Stanton A, and Stanton B.
- Indian River Plant Combustion Turbine Units A, B, C, and D².
- Lakeland Electric McIntosh Unit 3.
- Florida Power & Light Company (FPL) St. Lucie Unit 2 Nuclear Generating Facility.

² As discussed throughout this report, OUC has purchased the steam units at the Indian River site; however, the units are currently in Extended Cold Shutdown and, therefore, are not included in calculations of OUC's available capacity.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

Table 2-1 Summary of OUC Generation Facilities

(As of January 1, 2021)

| PLANT NAME | UNIT NO. | LOCATION (COUNTY) | UNIT TYPE | FUEL | | FUEL TRANSPORT | | COMMERCIAL IN-SERVICE MONTH/YEAR | EXPECTED RETIREMENT MONTH/YEAR | NET CAPABILITY | |
|--------------------------|----------|-------------------|-----------|------|-----|----------------|-----|----------------------------------|--------------------------------|----------------------|----------------------|
| | | | | Pri | Alt | Pri | Alt | | | Summer MW | Winter MW |
| Indian River | A | Brevard | GT | NG | FO2 | PL | TK | 06/89 | Unknown | 15.6 ⁽¹⁾ | 18.1 ⁽¹⁾ |
| Indian River | B | Brevard | GT | NG | FO2 | PL | TK | 07/89 | Unknown | 15.6 ⁽¹⁾ | 18.1 ⁽¹⁾ |
| Indian River | C | Brevard | GT | NG | FO2 | PL | TK | 08/92 | Unknown | 83.0 ⁽²⁾ | 88.5 ⁽²⁾ |
| Indian River | D | Brevard | GT | NG | FO2 | PL | TK | 10/92 | Unknown | 83.0 ⁽²⁾ | 88.5 ⁽²⁾ |
| Stanton Energy Center | 1 | Orange | ST | BIT | NG | RR | PL | 07/87 | Unknown | 305.1 ⁽³⁾ | 305.1 ⁽³⁾ |
| Stanton Energy Center | 2 | Orange | ST | BIT | NG | RR | PL | 06/96 | Unknown | 339.8 ⁽⁴⁾ | 339.8 ⁽⁴⁾ |
| Stanton Energy Center | A | Orange | CC | NG | FO2 | PL | TK | 10/01 | Unknown | 184.2 ⁽⁵⁾ | 188.4 ⁽⁵⁾ |
| Stanton Energy Center | B | Orange | CC | NG | FO2 | PL | TK | 02/10 | Unknown | 292.0 | 307.0 |
| McIntosh | 3 | Polk | ST | BIT | -- | RR | -- | 09/82 | 03/21 | 133.0 ⁽⁶⁾ | 136.0 ⁽⁶⁾ |
| St. Lucie ⁽⁷⁾ | 2 | St. Lucie | NP | UR | -- | TK | -- | 06/83 | Unknown | 60.0 | 62.0 |

⁽¹⁾Reflects an OUC ownership share of 48.8 percent.
⁽²⁾Reflects an OUC ownership share of 79.0 percent.
⁽³⁾Reflects an OUC ownership share of 68.6 percent.
⁽⁴⁾Reflects an OUC ownership share of 71.6 percent and St. Cloud entitlement of 3.4 percent.
⁽⁵⁾Reflects an OUC ownership share of 28.0 percent.
⁽⁶⁾Reflects an OUC ownership share of 40.0 percent.
⁽⁷⁾OUC owns approximately 6.1 percent of St. Lucie Unit No. 2. Reliability exchange divides 50 percent power from Unit No. 1 and 50 percent power from Unit No. 2.

The Stanton Energy Center is located 12 miles southeast of Orlando, Florida. The 3,280-acre site contains Units 1 and 2, as well as Units A and B, and the necessary supporting facilities. Stanton Unit 1 was placed in commercial operation on July 1, 1987, followed by Stanton Unit 2, which was placed in commercial operation on June 1, 1996. Both units are fueled primarily by pulverized coal and can generate up to approximately 70 MW each on natural gas, utilize natural gas igniters, and operate at emission levels that are within the Environmental Protection Agency (EPA) and the Florida Department of Environmental Protection (FDEP) requirement standards for sulfur dioxide (SO₂), nitrogen oxides (NO_x), and particulates (PM). Stanton Unit 1 is a 445 MW net coal-fired facility; OUC has a 68.6 percent ownership share of this unit, which provides 305 MW of capacity to the OUC system. Stanton Unit 2 is a 453 MW net coal-fired generating facility; OUC maintains a 71.6 percent (324 MW) ownership share of this unit. OUC anticipates converting both Stanton Unit 1 and Stanton Unit 2 to no longer operate on coal and instead operate only on natural gas during the 2025 to 2027 timeframe; OUC is in the process of determining the final timing of the natural gas conversion of each unit.

OUC has entered into an agreement with Kissimmee Utility Authority (KUA), FMPA, and Southern Company-Florida LLC (SCF, an affiliate of Southern Power), which governs the ownership of Stanton A, a combined cycle unit at the Stanton Energy Center that began commercial operation on October 1, 2003. NextEra Energy recently purchased Southern Power's interest in Stanton A, and as such, discussion of Stanton A's ownership structure refers to NextEra Energy throughout this Ten-Year Site Plan, as appropriate. OUC, KUA, FMPA, and NextEra Energy are joint owners of Stanton A, with OUC maintaining a 28 percent ownership share (and purchases 52 percent), KUA and FMPA each maintaining 3.5 percent ownership shares, and NextEra Energy maintaining the remaining 65 percent of Stanton A's capacity. Stanton A is a 2 X 1 combined cycle utilizing General Electric combustion turbines. Stanton A is dual-fueled with natural gas as the primary fuel and No. 2 oil as the backup fuel.

Stanton B is a 1 X 1 combined cycle utilizing General Electric combustion turbines. Stanton B is dual-fueled with natural gas as the primary fuel and No. 2 oil as the backup fuel. OUC is the sole owner of Stanton B.

The Indian River Plant is located four miles south of Titusville on US Highway 1. The 160-acre Indian River Plant site contains three steam electric generating units (No. 1, 2, and 3) and four combustion turbine units (A, B, C, and D). The three steam turbine units were sold to Reliant Energy in 1999, with OUC subsequently repurchasing the units. Given their current condition (the units are currently in Extended Cold Shutdown), the Indian River steam units do not provide generating capacity for OUC, but do provide OUC with future options for new generating capacity. The combustion turbine units are primarily fueled by natural gas, with No. 2 fuel oil as an alternative. OUC has a partial ownership share of 48.8 percent (approximately 31 MW summer and 36 MW winter) in Indian River Units A and B, as well as a partial ownership share of 79 percent (approximately 166 MW summer and 177 MW winter) in Indian River Units C and D.

McIntosh Unit 3 is a 340 MW net unit operated by Lakeland Electric. McIntosh Unit 3 is fueled primarily by pulverized coal and also uses supplementary natural gas. OUC has a 40 percent ownership share in McIntosh Unit 3, providing approximately 133 MW of capacity (summer capacity; winter capacity is 136 MW) to the OUC system. Lakeland Electric has indicated that McIntosh Unit 3 is expected to be removed from service by March 31, 2021.

OUC has a 6.08951 percent ownership share in St. Lucie Unit 2 (a nuclear generating facility operated by FPL), providing approximately 60 MW of summer and 62 MW of winter generating capacity to OUC. A reliability exchange with St. Lucie Unit 1 results in half of the capacity being supplied by St. Lucie Unit 1 and half by St. Lucie Unit 2.

St. Cloud has an entitlement to capacity from Stanton Unit 2 associated with its purchase through FMPA (related to FMPA's participation in the Stanton II Project). FMPA's ownership stake in Stanton Unit 2 through the Stanton II Project is 23.2 percent, and St. Cloud's purchase from FMPA's Stanton Unit 2 ownership is 14.67 percent (providing approximately 15 MW).

2.2 Purchase Power Resources³

OUC has a purchase power agreement (PPA) with NextEra Energy for 80 percent of NextEra Energy's ownership share of Stanton A. The term of OUC's Stanton A PPA is through December 2031.

2.3 Power Sales Contracts

OUC has the following contractual power sales:

- a contract to provide power to the City of Lake Worth Beach (Lake Worth) through 2025
- a contract to provide power to the City of Winter Park (Winter Park) through 2026
- a contract to provide power to Lakeland Electric (Lakeland) beginning April 1, 2021 and extending through 2023.
- a contract to provide power to the City of Mt. Dora (Mt. Dora) through 2027.
- a contract to provide power to the City of Chattahoochee (Chattahoochee) through 2027.

For purposes of this Ten-Year Site Plan, OUC has assumed the winter and summer capacities and annual energy presented in Table 2-2 will be provided to, Lake Worth, Winter Park Lakeland, Mt. Dora, and Chattahoochee.

³ OUC's renewable power purchases are discussed in Section 2.4 of this Ten-Year Site Plan.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

Table 2-2 Projected Annual Summer and Winter Peak Capacity (MW) and Annual Net Energy for Load (GWh) to be Provided to, Lake Worth, Winter Park, Mt. Dora, Chattahoochee, and Lakeland

| SUMMER MW | | | | | |
|----------------------------------|------------|-------------|----------|---------------|----------|
| Calendar Year | Lake Worth | Winter Park | Mt. Dora | Chattahoochee | Lakeland |
| 2021 | 50 | 17 | 23 | 8 | 125 |
| 2022 | 50 | 17 | 23 | 8 | 125 |
| 2023 | 50 | 17 | 23 | 8 | 75 |
| 2024 | 50 | 17 | 23 | 8 | 0 |
| 2025 | 50 | 17 | 23 | 8 | 0 |
| 2026 | 0 | 17 | 23 | 8 | 0 |
| 2027 | 0 | 0 | 23 | 8 | 0 |
| 2028 | 0 | 0 | 0 | 0 | 0 |
| 2029 | 0 | 0 | 0 | 0 | 0 |
| 2030 | 0 | 0 | 0 | 0 | 0 |
| WINTER MW | | | | | |
| Calendar Year | Lake Worth | Winter Park | Mt. Dora | Chattahoochee | Lakeland |
| 2021 | 25 | 17 | 17 | 6 | 0 |
| 2022 | 25 | 17 | 17 | 6 | 125 |
| 2023 | 25 | 17 | 17 | 6 | 125 |
| 2024 | 25 | 17 | 17 | 6 | 125 |
| 2025 | 25 | 17 | 17 | 6 | 0 |
| 2026 | 0 | 17 | 17 | 6 | 0 |
| 2027 | 0 | 0 | 17 | 6 | 0 |
| 2028 | 0 | 0 | 0 | 0 | 0 |
| 2029 | 0 | 0 | 0 | 0 | 0 |
| 2030 | 0 | 0 | 0 | 0 | 0 |
| ANNUAL GWh | | | | | |
| Calendar Year | Lake Worth | Winter Park | Mt. Dora | Chattahoochee | Lakeland |
| 2021 | 228 | 98 | 99 | 34 | 41 |
| 2022 | 223 | 98 | 101 | 34 | 55 |
| 2023 | 225 | 98 | 103 | 35 | 44 |
| 2024 | 226 | 98 | 105 | 36 | 0 |
| 2025 | 239 | 98 | 106 | 36 | 0 |
| 2026 | 0 | 98 | 108 | 37 | 0 |
| 2027 | 0 | 0 | 109 | 37 | 0 |
| 2028 | 0 | 0 | 0 | 0 | 0 |
| 2029 | 0 | 0 | 0 | 0 | 0 |
| 2030 | 0 | 0 | 0 | 0 | 0 |
| All rounded to nearest MW or GWh | | | | | |

2.4 OUC's Renewable Energy and Sustainability Initiatives and Community Activities

OUC is actively incorporating renewable technologies into its diverse generation portfolio and taking other steps to reduce carbon dioxide emissions. In 2020, OUC established new clean energy goals to achieve a 50 percent reduction in CO₂ emissions by 2030⁴, a 75 percent reduction in CO₂ emissions by 2040⁵, and net-zero CO₂ emissions by 2050. These targets require investments in technologies such as solar PV and energy storage. Such technologies will allow OUC to meet customer electricity demand while reducing harmful effects on the environment.

In 2019, Orlando was selected as a recipient of a \$2.5 million grant from the American Cities Climate Challenge (ACCC), a Bloomberg Philanthropies initiative that aims to accelerate and deepen efforts to make the greatest positive impact on climate change. The City and OUC agreed to execute eight actions: Meet municipal electricity demand with renewable resources; Expand solar projects in the community; Develop a green building incentive program; Pilot demonstration projects for building decarbonization (DEEP); Electrify city fleets and buses; Expand public EV charging infrastructure; Transform the EV market; Develop local energy resource centers.

Renewable energy, energy efficiency, sustainability and community engagement are crucial to achieving OUC's clean energy goals. OUC's recent renewable energy and sustainability initiatives, as well as activities in the community and customer education programs, are discussed in the following subsections⁶.

2.4.1 Solar

OUC is actively working to provide opportunities for its customers to participate in solar projects and programs. These initiatives include Solar Photovoltaic (PV) Net Metering, the solar aggregation program (referred to as the OUCollective Solar Program), Solar PV Residential Battery Rebate, OUCommunity Solar, and the Solar Thermal Program.

Customers who participate in the Solar PV Program or the OUCollective Solar Program receive the benefit of net metering, which provides the customers with a monthly credit on their utility bills for energy produced in excess of what the home or business can use. Any excess electricity generated and delivered by the solar PV systems back to OUC's electric grid is credited at the customer's full retail electric rate.

Customers who take part in the OUCollective Solar Program are able to reduce installation costs by leveraging economies-of-scale to drive down the costs for PV systems as well as for battery storage. Under the OUCollective Solar Program, customers have access to installations for a discounted fixed price and from a contractor that has been vetted by OUC. As of February 23, 2021, 105 customers, representing a total of approximately 1,229 kW of capacity, have participated in the program.

In 2019, OUC introduced a battery storage rebate program for residential solar PV customers. Under this program, eligible residential electric customers receive a one-time rebate of up to \$2,000 (limit one per customer) for the first 50 customers. In order to qualify for the rebate, batteries must be paired with a solar PV system and meet certain size and insurance requirements. Residential and commercial customers

⁴ Compared to a 2005 CO₂ baseline.

⁵ Compared to a 2005 CO₂ baseline.

⁶ Please refer to Section 5.0 of this Ten-Year Site Plan for discussion of OUC's conservation and demand-side management programs.

who want to benefit from solar energy but have no means of installing their own rooftop PV system can enroll in the OUC Community Solar program. Those enrolled subscribe all or a portion of their energy consumption to be produced by the Kenneth P. Ksionek Community Solar Farm, a utility-scale solar array at OUC's Stanton Energy Center in east Orlando.

Residential customers participating in the Solar Thermal Program receive a rebate of \$900 for installing a solar hot water system. Federal incentives, such as the investment tax credit, are available to eligible customers to help minimize costs of solar PV, battery storage and solar thermal systems.

To further facilitate development of solar energy, OUC supported Orange County in its efforts to obtain a \$2.5 million grant from the Florida Department of Environmental Protection to install a 1 MWac solar array on the Orange County Convention Center. The project "went live" in May 2009 and is currently producing clean, green power. In 2008, Orlando was designated a "Solar American City" by the U.S. Department of Energy (DOE). The ongoing partnership between OUC, the City and Orange County received \$450,000 in funding and technical expertise to help develop solar projects in OUC's service area that can be replicated across the country.

In 2009, OUC and clean energy company Petra Solar teamed up to launch the first utility pole-mounted solar PV system in Florida. Ten of Petra Solar's SunWave™ intelligent PV solar systems have been installed on OUC utility poles along Curry Ford Road. Together the panels can generate up to 2 kWac. The innovative solar panel demonstration project is expected to help enhance the smart grid capabilities and reliability of the electric distribution grid. Petra Solar worked in collaboration with the University of Central Florida in developing the pole-mounted approach to clean energy generation. The SunWave systems not only turn street light and utility poles into solar generators, but they also communicate with the electric grid and can offer smart grid capabilities. The systems can improve grid reliability through real-time communications between solar generators in the field and the utility control center. In addition, the systems enhance electric distribution grid reliability through a host of capabilities such as voltage and frequency monitoring and reactive power compensation.

In 2010, OUC invested \$100,000 in an educational partnership with the Orlando Science Center to build a 31 kWac PV array atop the Center's observatory. The system provides about 42,660 kilowatt-hours (kWh) of electricity per year, or enough power to serve about four homes. The PV installation not only provides green power to the Center but also an educational experience on the science of solar energy for the thousands of children who visit the center each year.

OUC is adding additional solar to its fleet of natural gas, coal, solar, and landfill gas generation already on-site at Stanton Energy Center. The Stanton Solar Farm, constructed in partnership with Duke Energy, was brought online in late 2011 and produces about 5 MWac. The first Stanton Solar Farm consists of more than 25,000 modules featuring solar PV panels with a patented single-axis tracking system design that increases electricity output by 30 percent and withstands category 4 hurricane winds. OUC purchases 100 percent of the output of this installation, which was the first solar farm in Orange County, for 20 years.

In 2013, OUC built the first Community Solar Farm in Central Florida. This innovative project allowed customers to "buy a piece of the sun" and receive the benefits of solar without having to install it on their own buildings. The 400 kWac system sold out in six days and had a total of 39 customers sign up. The American Public Power Association (APPA) awarded OUC the 2015 Energy Innovator award for its groundbreaking Community Solar Farm program.

In 2015, OUC signed a 20-year PPA for approximately 9 MWac of solar energy from a second solar farm at the Stanton Energy Center. Brought online in 2017, the Kenneth P. Ksionek Community Solar Farm provides enough electricity to power 2,100 homes. At the time the Kenneth P. Ksionek Community Solar Farm was constructed, only one other utility in the nation had placed panels over a coal ash byproduct landfill at a power plant. This solar farm is the latest addition to OUC Community Solar.

The Florida Municipal Solar Project is one of the largest municipal-backed solar projects in the United States. Approximately 900,000 solar panels will be installed on three solar sites in Osceola and Orange counties. Total planned capacity is 223.5 MWac, which is enough energy to power 45,000 average Florida homes. Each solar site is designed to generate 74.5 MWac of energy. OUC is a stakeholder in two of the sites, the Taylor Creek and Harmony Solar Energy Centers, which began operating in the summer of 2020. Under power purchase agreements with NextEra, OUC receives 108.5MWac from the two facilities, enough energy for 21,600 typical Florida homes. These two solar sites started commercial operations on June 30, 2020.

In February 2017, OUC installed an innovative floating solar array on a water retention pond at its Gardenia Operations Center. The 31.5 kWac pilot project, which has since been increased to 59.2 kWac, is the first in Florida to send power directly to the grid. Comprised of dozens of PV panels mounted on floats, it produces enough energy to power five homes. This design appeals to developers who want to invest in solar but do not want to cut down trees or use valuable land resources. Also, OUC is evaluating performance gains in energy production as a result of the increased reflectance and cooling effect of the water. More than 9,000 potential sites within Orange and Osceola counties have been identified where floating solar may be a viable option. In December 2020, OUC, joined by the City and the Greater Orlando Aviation Authority, dedicated a 123kWac floating solar array that was installed in a pond at Orlando International Airport. Shaped like the airport's "O" logo, the array is highly visible and produces enough power for 14 homes.

In August 2018, OUC completed the addition of a new solar test site at its Pershing Operations Center. This test site will allow OUC to study and test a variety of solar panels and tilt angles. OUC will also collect weather data from the site to compare with the solar production data. These studies will allow OUC to determine how to make future solar installations more efficient. The peak capacity for this test array is approximately 24 kWac depending on the number of solar panels being tested at any given time. All of the electricity produced by the array is supplied back to the grid. In 2020, the test array produced 17.6 MWh.

In January 2021, OUC announced plans to more than double its solar capacity under a new 20-year power purchase agreement with NextEra. OUC will be the sole recipient of two 74.5 MWac solar farms NextEra expects to complete by December of 2023. The additional 149 MWac of solar power will boost OUC's total solar capacity to 271.5 MWac of solar capacity — enough power for nearly 50,000 typical Florida homes.

Starting in 2019, OUC began to deploy weather stations with advanced sensors and measurement equipment that would record data including solar irradiance, beam radiation, wind speed, and soil moisture. With over 20 weather stations installed across our service territory, OUC is developing the capability to enhance solar production forecasting specifically to address high solar intermittency caused by dynamic cloud formation and cover, a common occurrence in Florida's climate. In 2020, OUC began

testing cloud-tracking technology at two solar farms. Created through a collaboration with University of Central Florida College of Engineering students, “skycam” keeps watch for clouds moving toward solar fields, forecasts how soon they’ll arrive and, once they do, their impact on solar production. This technology shows promise in helping OUC anticipate drop-offs in solar output and filling in the gaps with other generation assets.

In order to better utilize solar energy and increase its reliability during cloudy weather, OUC has embarked in designing its own advanced algorithms and control schemes. This has taken form in the project known as, “Nanogrid,” a living laboratory for testing the interoperability of multiple distributed energy resources and the ability to self-operate at OUC’s Gardenia facility. Nanogrid currently is comprised of 59 kWac of floating solar, 80 kWh of vanadium redox flow batteries, DC fast charging, Level 2 EV charging, V2G EV charging, as well as an intelligent control system developed in partnership with UCF – with more technology already in the planning stages. This level of control will enable solar to become more reliable during intermittent weather as well as help to drive down costs for energy storage.

OUC is also evaluating the efficiency of different solar PV technologies through real-world testing. In particular, OUC will install a 100 kWac solar array on the rooftop of its Gardenia office building. This array will be comprised of bifacial solar modules, which are expected to provide increased output as compared to mono-facial modules. This test array will enable OUC to evaluate any efficiency gains of bifacial panels in a real-world environment, which will inform decisions around large-scale solar PV installations in the future. Gardenia also is the host site of OUC’s first community solar farm, which consists of PV arrays set atop rows of parking shelters.

OUC also has showcased solar energy with high-visibility solar sculptures, including “solar trees” at Camping World Stadium and the Orange County Convention Center and, most recently, a soccer ball-shaped solar sculpture situated outside Exploria Stadium, home to the Orlando City Soccer Club. The soccer ball sculpture was designed by University of Central Florida (UCF) students through a multi-department competition. Additionally, OUC has deployed multiple solar mobile device charging stations at LYNX bus shelters to power up electronic devices while passengers are waiting.

2.4.2 Landfill Gas

Methane or landfill gas is created by the decomposition of wet organic waste under anaerobic, or oxygenless, conditions in a landfill. This gas is considered a renewable energy source because the anaerobic digestion process continues as waste materials are constantly added to the landfill.

In partnership with Orange County, OUC captures methane gas emissions from county landfill cells and pipes it to the Stanton Energy Center where it is co-fired with coal. In addition to helping to reduce greenhouse gas emissions, this 8 MW project has the potential to displace more than three percent of the coal burned at the Stanton Energy Center. It will be capable of producing in excess of 100,000 megawatt-hours (MWh) of reduced-emissions power – offsetting about 44,000 tons of coal each year. OUC and Orange County have signed new agreements for future landfill projects, expanding capacity to 22 MW.

In December 2015, OUC began receiving energy from the CBI project at the John Drury Landfill, located in Holopaw in Osceola County, for a minimum of 9 MW with an option to expand up to 25 MW of landfill gas energy. For the CBI project, OUC built a new 25 kV distribution line that is comprised of 15.5 miles of

overhead and nearly five miles of underground line. The new feeder line will send clean, renewable energy from the landfill to an OUC electric substation in St. Cloud and is the longest distribution feeder on the grid. This feeder will play a large role in OUC's clean energy strategy.

OUC has also entered into long-term PPAs for landfill gas projects with WMI in Broward County (6 MW) and GES in Charlotte County and Collier County (4 MW).

2.4.3 Carbon Capture

OUC has participated in research projects with the Department of Energy to investigate Carbon Capture and Utilization via recycling carbon from flue gases.

2.4.4 Carbon Reduction

With more than 775 vehicles – ranging from plug-in hybrids to bucket trucks – OUC's fleet logs more than 4.7 million miles annually. OUC reduces its carbon footprint by using alternative fuels, purchasing more electric vehicles and recycling automotive products to help the environment. As part of an overall plan to reduce emissions in its fleet, OUC uses "B20" – a blend of 80 percent petroleum diesel and 20 percent biodiesel – a clean-burning alternative fuel made from new or used vegetable oils and animal fats, including recycled cooking grease. Compared to petroleum diesel, biodiesel produces lower emissions, so it is better for the environment. B20 has been integrated seamlessly into the fueling system without any changes to vehicles or fuel storage and distribution equipment. OUC uses biodiesel at the Pershing Fleet Center and the Gardenia site. OUC has installed two 10,000-gallon fuel tanks that store E85 fuel at its Pershing and Gardenia sites.

Embracing fuel-efficient technology as a commitment to green initiatives, OUC has grown the commitment to include five all-electric cars, six plug-in electric hybrids, and 21 hybrids in the fleet and is one of only a few utilities throughout the country to test Nissan's new all-electric E-NV 200 cargo van. Additionally, OUC has installed more than 200 public charging stations and expects to have a total of 300 in place by the end of 2021. Up to 22 high-speed chargers are under development at the new Robinson Mobility Recharge Hub in downtown Orlando. The charging facility will be the largest of its kind in Florida and will be able to power up all kinds of EVs. An OUC-led partnership that includes the City, Orange County and Power Electronics, the maker of EV charging equipment, received a \$500,000 grant from the Florida Department of Environmental Protection to build the station. The charging hub complements OUC's support for a law Gov. Ron DeSantis signed in 2020 calling for the creation of a statewide EV charging infrastructure. These efforts have helped push Orlando to one of the top 5 EV ready cities in the United States. OUC has provided an additional 40 level 2 charging stations to meet the needs of our growing fleet and employee needs. OUC also offers discounts to employees who choose to charge their vehicles at work, utilize the SunRail commuter train, and use the LYNX city bus system to get to and from work.

Funded in part by a \$1.9 million "Low or No Emission Grant" from the Federal Transit Administration, Orlando's new e-bus pilot program puts innovation and clean energy exploration in motion. Partnering with LYNX and the City of Orlando, OUC invested in charging stations and batteries for the e-buses with the intention of gathering real world battery performance data. The first three of 14 LYNX battery-run electric buses are in service on LYNX's LYMMO Grapefruit, Lime and North Quarter lines. In addition to enhancing Orlando's charging infrastructure, the e-buses will help reduce emissions in some of our community's economically disadvantaged neighborhoods.

OUC currently has five hybrid bucket trucks and one auxiliary battery system to operate the aerial tower hydraulics. Bucket trucks are a promising application for hybrid technology since much of the vehicle's work is done when stationary. The hybrid diesel-electric system allows the main engine to be turned off while crews operate entirely off the battery, therefore reducing the production of greenhouse gases and reducing fuel consumption for idling.

OUC's Fleet Division has incorporated a number of eco-conscious policies, including the use of earth-friendly products and special care taken to dispose contaminated fuels according to environmental standards. Tires, batteries, and oil filters are recycled through vendors, while antifreeze and motor oil are handled on-site. OUC recycles about 20,000 gallons of used oil each year. OUC also has a vehicle idling policy that requires the engine to be turned off after five minutes. Diesel engines use about one gallon of fuel per hour when idling, so this policy saves about \$4 per hour per vehicle.

As part of OUC's commitment to alternative fuels and efficient transportation, three of the 32 EV charging stations at Reliable Plaza are offset by the sun. A 16-panel solar array provides a total of 2.8 kWac of power to charge the vehicles at stations in the garage. At night or on a cloudy day when the sun is not shining, the power is drawn from Reliable Plaza. When the sun is shining but no car is charging, the power is fed back into the building. OUC can access a special website to track real-time information and total system usage for its charging stations and the public charging in our territory. Users have a key fob for the charging station and supply their own power cord. Plug-in drivers can go to mychargepoint.net to locate available charging stations nationwide. Users register with ChargePoint to set up an account that links to their credit card. The power is billed through a third-party agreement with ChargePoint, which remits the electricity fees back to OUC each month.

In 2016, OUC enhanced its EV programs with the launch of a new Commercial EV Charging Station Program that encourages adoption of EVs by providing customers a turnkey option for charging stations at their facilities. The program offers two options: *Charge It*, where OUC owns and maintains the equipment with electric usage billed separately, and *Own It*, where OUC provides a turnkey solution and the commercial customer owns the equipment.

In 2018, OUC relaunched the Electrification program and established two key events that align with one of the program's initiatives to help increase electric vehicle adoption in Central Florida. The first event that OUC hosted was an EV Ride & Drive designed to introduce customers to electric vehicles and build awareness about electric vehicle technology. The event was held at Camping World Stadium June 15-16. Over two days, 140 guests completed 304 test drives. The following year, OUC hosted an EV Ride & Drive event in partnership with Valencia College and Enterprise Rent-a-Car on April 13, 2019, with 24 attendees. Due to the pandemic, OUC cancelled the 2020 EV Ride & Drive and in its place created EV education on OUC.com for customers to learn more about the benefits of electric vehicles and charging stations.

The second event is the Florida Utility Electric Vehicle Roundtable. This a semi-annual event was created to discuss EV-friendly policies, corridor charging planning and joint initiatives with all municipal and investor-owned utilities from across Florida. The first in the series of roundtables hosted by OUC was held on September 17, 2018, with more than 70 attendees. To date, OUC has hosted three additional roundtables, and discussions have included the current and future state of EVs in Florida, the Volkswagen settlement and two joint initiatives for data acquisition and a technology pilot.

In October 2020, OUC, in partnership with the City and Electrification Coalition, launched the Electrified Dealers Program. It's focused on expanding consumer adoption of EVs in Central Florida. Through direct engagement with dealers and by offering rebates, OUC seeks to improve the EV purchasing experience and reduce barriers to EV ownership. In addition to offering a rebate on a plug-in electric vehicle purchase or lease and providing a cost-effective for businesses to install EV charging stations, OUC, in 2020, committed to investing \$45 million in electrification programs aimed at putting more than 40,000 EVs on Central Florida's roads by 2030.

OUC is working on planting sections of the 3,280 acres at the Stanton Energy Center. The site uses less than 1,000 acres currently and by planting new trees, OUC intends to measure and track the recycling of CO₂ from the electric generating units to reduce its overall carbon footprint.

OUC continues to improve on operations at the Stanton Energy Center, having an improved design on the Unit 2 HP/IP and LP steam turbine that provides additional output without increasing fuel consumption or emissions. OUC has installed the same improvement on the Unit 1 HP/IP steam turbine. Other recent improvements include updated control systems for both units, and adding natural gas co-firing capability to both units. This enables them to run at lower loads and increases operational flexibility. OUC also installed variable frequency drives on Unit 2 to improve efficiency while operating at low load levels.

2.4.5 Energy Efficiency and Sustainability

OUC's commitment to efficiency and sustainability is also demonstrated by Reliable Plaza, OUC's energy and water efficient center on West Anderson Street that opened in 2008 and replaced OUC's 40-year-old Administration Building. Reliable Plaza earned Gold Leadership in Energy and Environmental Design (LEED) certification in 2009, officially cementing the 10-story administration and customer service center as the "Greenest Building in Downtown Orlando." The nonprofit U.S. Green Building Council awarded the Gold level certification after completing a review of the building's design and construction. Reliable Plaza also holds a Florida Water Star certification, a voluntary program for new and existing construction that encourages water efficiency in appliances, plumbing fixtures, irrigation systems and landscapes. Reliable Plaza utilizes a number of environmentally friendly features designed to use 28 percent less energy and 40 percent less water than a similarly sized facility.

To further demonstrate OUC's commitment to sustainability, many projects are active or are planned across its facilities. These projects focus on improving building efficiency through automation and control technology on its HVAC and lighting equipment in addition to smart irrigation and Xeriscape landscape designs. The latest example is at the Gardenia and Pershing campuses where they have undergone extensive LED lighting retrofits. Some buildings have received HVAC upgrades as well as new chiller investments.

In 2016, OUC built a living wall and rain harvest garden to showcase sustainable use of vertical space by replacing impervious surfaces while demonstrating water conservation examples along with Florida-friendly landscaping. The project underwent major improvements including irrigation changes that have improved water consumption. A new self-guided tour and marketing materials were developed with a focus on water education. Improvements in the garden structure increased the yield of harvests tenfold

from 2019. Edible plants from the garden are distributed to employees to raise awareness about the importance of buying and growing produce locally.

New construction projects will keep sustainability and energy efficiency at the forefront. This is exemplified by the planned construction of OUC's St. Cloud Operations & Maintenance Facility Project. A 24 acre property that will support permanent fleet and logistic operations, as well as accommodate a future new substation based on projected load growth. The intended goal is to make this into a net-zero energy campus as well as meeting the standards for LEED certification.

OUC's Commercial Indoor Lighting Program helps customers convert old, inefficient lighting to high-efficiency technology. OUC and Orlando Health, Orange County Public Schools and the Orlando Catholic Diocese have entered into master agreements to upgrade indoor lighting at most if not all of their facilities over the next 3-5 years. More than 25,000 fixtures are estimated to be replaced, which will reduce demand by approximately 1,100 kW with energy savings of more than 10 million kilowatt hours, or about \$945,000 in cost savings annually. Since launching the program in 2002, more than 45 million kWh and 10.5 MW demand has been saved in places such as public schools, churches, theme parks and hospitals, resulting in annual energy cost savings of about \$16 million.

In 2012, OUC launched a program to replace 100-watt equivalent streetlights with LED fixtures. The initiative was expanded in 2016 to include 250-watt and 400-watt fixtures, was completed in 2020 and replaced more than 20,000. These lights save the City more than 12 gigawatt-hours of annual energy and, equally important, LED lighting improves safety by emitting whiter, cleaner light that provides better visibility for motorists, pedestrians and law enforcement.

2.4.6 *OUC's Green Team*

With the philosophy that changing an organization's culture requires both corporate and individual accountability, OUC has established the Green Team – a dedicated group of employee volunteers who work to implement practical, sustainable operations in their respective work areas. In 2018, the Green Team went through a relaunch with the recruitment of new and passionate employees. Employees received training in sustainability and ecopractices. Furthermore, the Green Team has hosted e-waste collection events, has worked to vastly improve OUC's waste processes and has participated in national events such as Earth Hour.

The Green Team continues to identify ways to increase employee education and engagement and supports Corporate Sustainability projects to improve energy and water efficiency in OUC buildings, reduce waste, lower emissions from operations, and create a healthier, happier environment for employees and customers.

With the Gold LEED-certified Reliable Plaza setting the standard, other OUC facilities have followed suit, implementing a number of environmental efforts, including:

- Retrofitting and upgrading light bulbs and ballasts
- Installing light sensors
- Turning up thermostats
- Cutting back on landscape and exterior building lighting
- Purchasing Energy Star-rated appliances when replacements are needed

- Using environmentally friendly cleaning products
- Upgrading HVAC systems
- Installing rain sensors on irrigation systems
- Cutting grass less frequently at water plants, substations and areas not highly visible to the public

Going forward, OUC is planning a number of new green initiatives including establishing an Internal Operations Corporate Sustainability Plan. OUC currently has single stream recycling at all of its facilities and recycles industrial materials such as wood pallets, utility meters, wire reels and copper. It keeps metrics of its energy, water, and waste performance. It has developed internal policies such as electronic document storage, online document review, double-sided printing and specifies the use of recycled paper and office products whenever practical.

2.4.7 Sustainability Community Activities

In 2019, conservation specialists conducted presentations, provided face-to face consultations, scheduled audits, and disseminated information on conservation programs. With the onset of the pandemic in 2020, OUC suspended in-person events and replaced many of them with virtual community engagements. Below is a list of events the OUC Sustainability Department participated in along with Community Engagement:

- City of Orlando’s Green Academy
- City of Orlando’s Neighborhood & Community Summit
- 2020 Orange County Virtual Community Conference
- Lake Eola Earth Day
- St. Cloud Earth Day
- Apartment Association of Greater Orlando (AAGO) Trade Show
- Orange County Community Conference
- Fall Plant and Garden Festival
- City of Orlando District 2 Fall Events

In February 2021, OUC, along with the City and the Orlando Science Center, unveiled the Tiny Green Home as a mobile educational showcase of sustainable living. The 200-square-foot home is being used to raise awareness of the benefits of energy and water conservation, renewable energy, sustainability rebates, vehicle electrification, composting, growing food and sustainability programs offered by OUC, the City and the Science Center, the host site of the mobile exhibit. The City and OUC are able to transport the Tiny Green Home to events throughout the year. The micro-dwelling also includes a functioning roof-top solar array and a rain barrel to collect and conserve water, among other green features visitors can add to their own homes. The Tiny Green Home also offers an augmented reality experience. The project is funded equally by OUC and the city, along with support from the Bloomberg Philanthropies American Cities Climate Challenge.

2.4.8 Neighborhood Meetings

In 2018, OUC hosted six Fall Into Savings neighborhood meetings, traveling our service territory to visit residents in the City of Orlando Districts to share tips and programs available to help customers conserve and save money on their utility bill. More than 400 customers attended these meetings and had the

opportunity to learn about and sign up for various efficiency programs like Efficiency Delivered, OUC Power Pass, OUC Alerts, Residential Rebates, as well as to schedule free in-home energy/water audits. All attendees received a conservation kit and even had the chance to win raffle prizes that help with home efficiency upgrades. In 2019 and 2020, OUC hosted a series of five neighborhood meetings to educate residents on the Electric Integrated Resource Plan and to gather their feedback. At each meeting, attendees were asked to rank the following attributes in order of importance to them: sustainability, reliability, resiliency, affordability.

2.4.9 Home Utility Report Program

The Home Utility Report Program (HUR) is a free service offered to OUC customers designed to help them save energy, water, and money. The report compares a customer’s energy and water consumption to similar households, as well as provides personalized tips that show how much they can save by changing their behavior. Participants receive a free HUR bi-monthly via email or printed report. To administer the HUR program, OUC works with a third-party company that helps utilities meet their efficiency goals through effective customer engagement.

2.5 Transmission System

OUC’s existing transmission system in Orlando consists of 31 substations interconnected through approximately 338 miles of 230 kV, 115 kV, and 69 kV lines. OUC is integrated into the Florida Reliability Coordinating Council (FRCC) regional transmission grid through multiple utilities, as summarized in Table 2-3. Additionally, OUC is responsible via an Interlocal Agreement for planning, operating and maintaining St. Cloud’s five substations, 56 miles of transmission lines, and interconnections, as summarized in Table 2-4.

Table 2-3 OUC Transmission Interconnections

| UTILITY | KV | NUMBER OF INTERCONNECTIONS |
|---------------------------------------|-----------|-----------------------------------|
| FPL | 230 | 2 |
| Duke Energy Florida (DEF) | 230 | 9 |
| KUA | 230 | 2 |
| KUA/FMPA | 230 | 2 |
| Lakeland Electric | 230 | 1 |
| TECO | 230 | 2 |
| TECO/Reedy Creek Improvement District | 230 | 2 |
| DEF | 69 | 1 |
| NextEra | 230 | 1 |
| NextEra | 115 | 1 |
| St. Cloud | 69 | 1 |

Table 2-4 St. Cloud Transmission Interconnections

| UTILITY | KV | NUMBER OF INTERCONNECTIONS |
|----------------|-----------|-----------------------------------|
| OUC | 69 | 1 |
| DEF | 230 | 1 |
| KUA | 69 | 1 |
| NextEra | 230 | 1 |

3.0 STRATEGIC CONSIDERATIONS

OUC incorporates a number of strategic considerations while planning for the electrical system. This section provides an overview of a number of these strategic considerations.

3.1 Strategic Business Units

In 2018, OUC's Electric and Water operations were reorganized into three strategic business units: Energy & Water Production (EWP), Transmission (TRAN) and Energy and Water Distribution (EWD) that report to a Chief Operating Officer.

3.1.1 Energy and Water Production Business Unit

The EWP business unit has structured its operations based on a competitive environment that assumes that even OUC's customers are not captive. EWP will only be profitable if it can produce electricity and water that is competitively priced in the open market. In line with this strategy, OUC is continually studying strategic options to improve or reposition its generating assets, such as the 1999 sale and subsequent repurchase of the Indian River steam units (which provides OUC with full control over the Indian River site and additional alternatives for future new generating resources, including possible repowering of the units)⁷. In addition, OUC formally instituted its Energy Risk Management Program in 2000.

OUC's generating system has been designed over the years to take advantage of fuel diversity and the resultant system reliability and economic benefits. OUC's longstanding intent to achieve diversity in its fuel mix is evidenced by its participation in other generating facilities in the State of Florida. The first such endeavor occurred in 1977 when OUC secured a share of the Crystal River Unit 3 nuclear plant, followed by the acquisition of an ownership share in Lakeland Electric's McIntosh Unit 3 coal-fired unit in 1982. In 1983, OUC also acquired a share of the St. Lucie Unit 2 nuclear unit. Furthermore, OUC modified the Stanton Energy Center coal units to allow the units to offset a portion of their coal usage with natural gas. Additional details of OUC's generating facilities are presented in Table 2-1 and Schedule 1 of Section 12.0 of this Ten-Year Site Plan.

OUC's fuel diversity is further enhanced by the renewable energy technologies that contribute to OUC's generating resources. OUC's renewable resources are discussed in detail in Section 2.4 of this Ten-Year Site Plan.

In 2020 the Business Unit led the Electric Integrated Resource Plan that calls for a review of OUC's generation needs in light of the growing penetration of distributed energy resources, such as solar power, and a call to move to Net Zero Carbon by 2050. Florida-specific factors were taken into consideration because renewable resources are limited relative to other regions in the country and could impact fuel diversity. Currently, wind, hydroelectric and geothermal are not economically and/or technically viable in Florida – and biomass and landfill gas, while possible resources are only available in small quantities. While solar is feasible, it poses intermittency challenges, and back up resources will be necessary to ensure that

⁷ Based on the current condition of the Indian River steam units (Extended Cold Shutdown), OUC is not currently assigning a firm capacity value to the units for purposes of capacity planning.

power is always available. OUC will continue to evaluate wind-by-wire generation and monitor emerging clean technologies such as hydrogen, offshore wind and small modular nuclear power plants.

Table 3-1 summarizes OUC's existing (owned and purchased) capacity by fuel type, including renewable energy resources. The ability to generate up to approximately 70 MW while operating on natural gas in each of Stanton Units 1 and 2 further enhances the percentage of generating capacity fueled by natural gas.

Table 3-1 Capacity (MW) Owned and Purchased by OUC by Fuel Type
(As of January 1, 2021)

| PLANT NAME | WINTER CAPACITY | | | | | | SUMMER CAPACITY | | | | | |
|---------------------------|-----------------|---------|-------------|------|------|--------|-----------------|---------|-------------|------|------|--------|
| | Coal | Nuclear | Gas/ Oil | PV | LFG | Total | Coal | Nuclear | Gas/ Oil | PV | LFG | Total |
| Stanton ⁽¹⁾⁽²⁾ | 645 | | 846 | | | 1,491 | 645 | | 818 | 9 | | 1,472 |
| Indian River | | | 213 | | | 213 | | | 197 | | | 197 |
| C.D. McIntosh Jr. | 136 | | | | | 136 | 133 | | | | | 133 |
| St. Lucie | | 62 | | | | 62 | | 60 | | | | 60 |
| Other (MW) | | | | | 18 | 18 | | | | 54 | 19 | 72 |
| Total (MW) | 781 | 62 | 1,059 | 0 | 18 | 1,920 | 778 | 60 | 1,015 | 63 | 19 | 1,934 |
| Total (percent) | 40.7% | 3.2% | 55.2% | 0.0% | 1.0% | 100.0% | 40.2% | 3.1% | 52.5% | 3.3% | 0.9% | 100.0% |

⁽¹⁾ Includes OUC's share of the landfill gas burned in Stanton Units 1 and 2.
⁽²⁾ Stanton Units 1 and 2 can each generate up to approximately 70 MW while operating on natural gas.

3.1.2 Transmission Business Unit

The OUC Transmission Business Unit is responsible for the planning, engineering, construction, and maintenance of all substations and lines operating at 69kV or higher. To maintain reliable and economic service and proactively plan for the future, OUC is evaluating numerous upgrades to its transmission system. While these upgrades vary in scope and timing, the following list provides an overview of significant projects:

- A transmission line routing and feasibility engineering study for the addition of a new 230kV source into downtown Orlando has been conducted.
- Current growth rates support the need for adding several substation distribution transformers during the next five years.
- Planning and feasibility engineering are underway to evaluate options for potential projects to meet future growth on the St. Cloud system.
- The \$2.3 billion I-4 Ultimate project by the Florida Department of Transportation (FDOT) and its contractor is underway for 21 miles of roadway improvements between Kirkman Road and State Road 434. Coordination of construction activities and mitigation of conflicts around the America Substation, Robinson Substation and multiple transmission lines continue.

As part of the 2020 EIRP, transmission infrastructure was considered as a major component when considering resiliency of the system. Largely due to Florida being a peninsula, Florida can import energy only from its northern border. Unlike many of the others states where there are multiple paths to receive high-voltage energy, Florida has a lower overall import capacity – approximately 6% of total forecast summer peak load in 2020 as stated in various reports presented by Florida Reliability Coordinating Council (FRCC).

3.1.3 Energy and Water Distribution Business Unit

OUC's EWD business unit focuses on providing OUC's customers with the safest and most reliable electric service possible.

OUC's leadership in providing reliable electric distribution service is demonstrated by its commitment to making initial investments in high quality material and equipment. Additionally, more than 60 percent of OUC's distribution system is underground, protecting it from trees and high winds. OUC's dependability is also attributable to its proactive maintenance programs to identify and correct potential problems, proactive replacement of old equipment, and a tree-trimming program that minimizes tree-related service disruptions.

3.2 Florida Municipal Power Pool

In 1988, OUC joined Lakeland Electric and FMPA's All-Requirements Project members to form the Florida Municipal Power Pool (FMPP). Later, KUA joined FMPP. Over time, FMPA's All-Requirements Project has added members as well. FMPP is an operating-type electric pool, which dispatches all the pool members' generating resources in the most economical manner to meet the total load requirements of the pool. The central dispatch provides savings to all parties via reduced commitment costs and lower overall fuel costs. OUC serves as the FMPP dispatcher and handles all accounting for the allocation of fuel expenses and savings. The term of the pool agreement is three years and automatically renews until terminated by the consent of all participants.

OUC's participation in FMPP provides significant savings from the joint commitment and dispatch of FMPP's units. Participation in FMPP also provides OUC with a ready market for any excess energy available from OUC's generating units.

3.3 Security of Power Supply

OUC currently maintains interchange agreements with other utilities in Florida to provide electrical energy during emergency conditions. The reliability of the power supply is enhanced by metered interconnections with other Florida utilities, including ten interconnections with Duke Energy Florida, four with KUA, two each with Tampa Electric Company and Reedy Creek Improvement District, two with FPL, one each with Lakeland Electric and St. Cloud, and two with NextEra. Along with enhancing reliability, these interconnections also facilitate the marketing of electric energy by OUC to and from other electric utilities in Florida.

In addition, in 2017, OUC entered into a new five-year contract for the storage of natural gas to manage price volatility and provide backup fuel during emergencies. The fuel will provide up to 30,000 MMBtu/day to help ensure power reliability.

3.4 Environmental Performance⁸

As the quality of the environment is important to Florida, and especially important to the tourism-driven economy of Central Florida, OUC is committed to protecting human health and preserving the quality of life and the environment in Central Florida. To demonstrate this commitment, OUC has chosen to operate its generating units with emission levels below those required by permits and licenses by equipping its power plants with the best environmental protection systems available at the time of their construction and continuously enhancing these systems over time. Unit 2 is the first unit of its size and kind in the nation to use selective catalytic reduction (SCR) to remove nitrogen oxides (NO_x). Using SCR and low-NO_x burner technology, Stanton 2 successfully meets the stringent air quality requirements imposed upon it. Stanton A incorporates environmentally advanced technology and enables OUC to diversify its fuel mix while adding more flexibility to OUC's portfolio of owned generation and purchased power. As its newest generating asset, Stanton B further contributes to OUC's environmentally responsible portfolio of generating resources.

This superior environmental performance not only preserves the environment, but also results in many economic benefits, which help offset the costs associated with the superior environmental performance. For example, the high-quality coal burned at Stanton contributes to the high availability of the units as well as their low heat rates. Additionally, OUC has installed natural gas igniters for both Stanton 1 and Stanton 2, eliminating the use of No. 6 fuel oil and reducing the amount of coal burned during operations when economical to do so.

Further demonstrating its environmental commitment to clean air, OUC has signed a contract to burn methane gas collected from the Orange County landfill adjacent to Stanton Energy Center. OUC also receives the energy generated from the burning of methane gas collected from the John Drury Landfill.

⁸ Please refer to Section 2.4 of this Ten-Year Site Plan for a detailed discussion of OUC's renewable generating technologies and other environmental initiatives.

Methane gas, when released into the atmosphere, is considered 20 times more intense than carbon dioxide in terms of possible global warming effects. Stanton 1 and Stanton 2 both have the capability of burning methane.

OUC has also voluntarily implemented a product substitution program not only to protect workers' health and safety but to minimize hazardous waste generation and to prevent environmental impacts. The Environmental Affairs and Safety Divisions constantly review and replace products to eliminate the use of hazardous substances. To further prevent pollution and reduce waste generation, OUC also reuses and recycles many products.

3.4.1 Emphasis on Sustainability

OUC completed its first greenhouse gas inventory for the entire company in 2008 and updates the inventory regularly. This report helps OUC analyze how it impacts the environment and details operating emissions. The greenhouse gas inventory was only a part of a larger initiative to perform a comprehensive sustainability audit of every department in the company. The goal of this effort is to understand both short-term and long-term opportunities to reduce the corporate carbon footprint in all departments and business functions.

3.5 Community Engagement, Connecting with Our Customers, and Economic Development

3.5.1 Community Engagement

As Orlando's hometown utility, OUC is committed to helping the community it serves. Individuals and organizations know they can rely on the utility when it matters most—through board involvement, support, employee volunteerism and more. OUC supports more than 400 nonprofit and business-based organizations and participates in nearly 150 events each year, while employees volunteer more than 10,000 hours in the community. Many events incorporate sustainability messaging, encouraging the efficient use of energy and water.

From unique solar pavilions and sculptures at high visibility locations like Lake Lorna Doone Park, Exploria Stadium and St. Cloud's Lakefront Park, to solar mobile device charging stations at LYNX bus stations and H₂OUC Hydration Stations at parks and neighborhood centers, OUC's commitment to sustainability can be seen all around town.

OUC also supports a diverse group of business chambers within its service territory, including the Orlando Chamber, Lake Nona Chamber, St. Cloud Chamber and Indian American, Hispanic, African-American, Asian, Caribbean, Disability and LGBT chambers. It is also actively involved with economic gardening organizations such as GrowFL, National Entrepreneur Center, Prospera (formerly the Hispanic Business Initiative Fund), Black Business Investment Fund, Athena and technical associations. OUC helped power OiX Orlando, a collective of tech experts, entrepreneurs, and tech industry leaders fueling the explosion of high-tech startups in the region.

In 2020, OUC and SALT Outreach, Inc., provided energy-efficient showers to homeless citizens around Orlando. OUC partnered with the nonprofit to develop a solar-powered trailer with four bathrooms.

3.5.1.1 Utility and Community Volunteerism

OUC launched Project CARE, its utility assistance fund, in 1994. The program, managed by Heart of Florida United Way 2-1-1, a local, nonprofit organization, provides rapid response to customers in need through case management. Since its inception, Project CARE has allocated nearly \$7 million, assisting more than 24,000 households and thousands of families and individuals. For every \$1 donated by customers, OUC contributes \$2 to the program.

When the onset of the COVID-19 pandemic in early 2020 caused the local economy to nearly shut down completely, OUC took immediate steps to help impacted customers. In mid-March, OUC suspended electric and water disconnections for nonpayment and waived late payment fees. In April, the OUC Board approved a \$12.1 million customer-relief package that included \$7.5 million to lower electric fuel rates for May bills, representing a 11.4% overall decrease for residential customers and 11.2% to 19.7% reduction for commercial customers; a \$2.6 million contribution to Project CARE, in partnership with the City of Orlando; \$1.5 million for utility bill payment assistance to qualified small businesses; \$500,000 for new OUC Power Pass customers. Payment plans and deferred payment arrangements were offered to customers for up to 12 months depending on qualifying criteria. While OUC resumed disconnects in July 2020, OUC's efforts to assist financially distressed customers extended well into late 2020 and remains ongoing. By the end of 2020, more than 6,500 customers accessed Project CARE funds while more than 1,800 small businesses took advantage of the OUC relief program targeting them. Meanwhile, OUC connected more than 2,800 customers to the federal government's Low Income Home Energy Assistance Program (LIHEAP) and helped more than 40,000 set up payment plans, amounting to millions of dollars in deferred revenues.

Regarding volunteerism, OUC's Proud Volunteer program encourages and rewards employees for their volunteer work in the community. Employees volunteer more than 10,000 hours every year and help support a variety of nonprofit organizations in the community.

The annual OUC Charity Golf Tournament has raised over \$818,000 for more than 54 Central Florida nonprofits since its inception in 1995.

Each year, OUC participates in the annual Ride-4-Ronald bike ride to benefit Ronald McDonald House Charities of Central Florida. Since 2013, the OUC team has raised over \$90,000 for the charity event.

3.5.1.2 Water Color Project

Since 2006, OUC has hosted the Water Color Project, a conservation-themed art program that encourages students to highlight the importance of saving water through their artwork. While fourth- and fifth-grade students compete to have their artworks featured in OUC's Water Conservation Calendar, middle and high school students paint water-inspired themes on rain barrels. Their completed works are displayed in a traveling exhibit, judged and later sold in a silent auction, with the proceeds going back to the winning schools' art programs. More than 29,000 students from 200 local schools have participated in this program. In 2020, due to the pandemic, OUC created a virtual awards ceremony to recognize the hard work and creativity of participating students and teachers while educating the community on the importance of water conservation. The virtual event received more than 2,400 views.

3.5.1.3 Project AWESOME

OUC and the Orlando Science Center deliver energy and water conservation workshops to every fifth grader in OUC's service territory via Project AWESOME (Alternative Water & Energy Supply; Observation, Methods & Education). The educational program promotes both water and energy conservation through a hands-on curriculum using content approved by OUC that meets Common Core Standards. As part of an electric and water conservation and alternative sources educational program, the projects include making an aquifer, building a solar-powered car, and testing low-flow showerheads and compact fluorescent light bulbs (CFLs) against traditional fixtures. Project AWESOME, which launched in 2009, delivers two 90-minute classroom workshops (one per semester), as well as hands-on labs and pre- and post-classroom activities. Energy is covered as part of the earth science section that's taught in the fall semester while water is the focus of the spring semester's life science section. More than 94,000 students have gone through the curriculum. Due to COVID and schools turning to virtual learning in early 2020, Project AWESOME workshops shifted to online. The lessons were made available to teachers in the form of a voiced-over PowerPoint. Each lesson included science content, discussion questions and an activity for students to complete.

3.5.1.4 Strategic Partnerships Promote Awareness

OUC has leveraged highly visible, professional sports partnerships to highlight OUC's commitment to sustainability and high-impact economic development efforts.

After assisting with energy and water efficiency features in the design phase of the Orlando Magic's LEED-certified home, Amway Center, OUC promoted the facility's LEED certification and its energy and water efficiency features through highly visible educational signage and on-going digital media. In 2020, OUC partnered with the Magic for the OUC Community Assist Program: for every assist a Magic player made in the 2019-2020 season, OUC committed to donating a tree to the Central Florida community. This activation was originally planned to take place at the Central Florida Earth Day Festival in April, but it was transitioned to a drive-up event due to COVID 19. In September, OUC hosted a tree giveaway at our Gardenia Operations Facility as a drive-through event, giving away more than 1,500 trees to 161 people.

The Magic partnership served as a model for OUC's agreement with the United States Tennis Association (USTA). The new Home of American Tennis in Lake Nona meets LEED certification standards. OUC is exclusively designated as the "Official Sustainability & Utility Sponsor" and displays savings that can be achieved through initiatives such as EV charging stations, hydration stations, mobile device charging stations and solar arrays on the roofs of shade pavilions. It's estimated the facility has brought more than 150 high-wage jobs to the community and attracts 100,000 unique visitors per year.

In 2015, OUC became the exclusive electric, water and sustainability utility partner for Orlando City Soccer Club. Within Exploria Stadium, the club's new MLS home, OUC branded all water fountains and showcases the savings that can be achieved through sustainability initiatives. Both permanent and transitional signage highlighting the energy and water efficiency features were incorporated into the facility along with OUC's role in helping it achieve LEED certification. In addition, in November 2020, OUC oversaw the installation of a soccer-ball shaped solar sculpture outside the stadium. "Gyration," which measures 9.5 feet wide by 14.5 feet tall, was designed by an 11-member University of Central Florida team of mechanical engineering, electrical engineering and art students who responded to an OUC challenge to conceptualize a sculpture that doubles as a source of clean energy. During daylight hours, the sculpture's

photovoltaic modules generate electricity for OUC, producing 1,264 kilowatt hours (kWh) of electricity annually. At night, interior lighting illuminates some of Gyration's purple panels. With its clean energy production offsetting the conventionally generated power it consumes at night, Gyration yields net-zero carbon output.

3.5.1.5 OUC Empowerment Zone

OUC has a multi-year commitment to revitalizing the most economically disadvantaged zip code in its territory, 32805. The Empowerment Zone program encourages broad-based economic prosperity and community support, ensures improved access to OUC programs and improves the overall health and wellness of the community. In short: OUC's Empowerment Zone seeks to build thriving communities by leveraging OUC's resources and partnerships to enhance three pillars: Educational opportunities, sustainable housing, and health and wellness. Examples include:

- Virtual Tutoring Programs with ELEVATE Orlando, which OUC supported by donating 20 laptops.
- In 2019, OUC employees raised \$42,000 for New Image Youth Center (NIYC), as part OUC's annual workplace giving campaign, OUCares. NIYC works with at-risk students in grades K-12 in the Parramore community and provides academic support, social development, health and wellness programs and crisis intervention services.
- OUC is creating a pre-apprenticeship program to meet the goals of creating career opportunities vs. job opportunities; prioritizing diversity, equity and inclusion; and raising median incomes for the community. This approach will help to combat unemployment; increase livable wages; eliminate financial burdens on students; and provide a measurable impact.
- OUC partnered with the Central Florida Housing Trust - Parramore Asset Stabilization Fund on an affordable housing project. OUC's contribution to the initiative includes improving the efficiency of 83 residential units, with such upgrades as attic insulation and weather stripping, duct work repair, irrigation improvements, LED lighting, Energy Star® windows, hybrid water heaters and energy efficient AC systems. Residents of these homes could realize annual utility savings of approximately \$800.
- OUC also is developing cost-saving programs and providing conservation education through neighborhood advisory councils. OUC partnered with LIFT Orlando, a local nonprofit, to help revitalize the City of Orlando's Lake Lorna Doone Park, which is in the Empowerment Zone. OUC's is sponsoring the recently built 4,800-square-foot OUC Solar Pavilion at Lake Lorna Doone Park and EV charging stations and hydration stations in the park. The pavilion will serve as a hub for community events and activities while providing 42kWac of renewable energy.

3.5.2 Connecting with Our Customers

From providing better online access to their consumption history to designing convenient and effective conservation programs, OUC arms customers with the information and tools they need to optimize the efficiency of their homes and businesses. This includes the community outreach previously discussed in this report as well as a mix of new technologies and programs designed to provide customers with the information, control and options they desire.

3.5.2.1 Self-Service Options

OUC's informational website, self-service portal and automated phone system are used by over 170,000 customers each month.

Customers are able to find tips, videos on ways to save, and frequently asked questions regarding their services. Through their myOUC online profile, they are able to pay their bills, make service requests, request payment extensions and more. The Usage Dashboard and OUC Power Pass program continue to drive adoption of the website. The site is mobile friendly and accessible from a range of devices including tablets and smartphones.

3.5.2.2 Traditional Media and Digital Outreach

To reach the desired audience, OUC implements comprehensive, integrated media campaigns that utilize print, online, television, radio, social, outdoor media and community partnerships. By diversifying and targeting media, OUC can effectively reach the right customer with the right message. Campaigns cover a range of topics, from safety to storm prep to sustainability. These campaigns reinforce OUC's commitment to showing customers how to reduce their energy and water use and ultimately their utility bills while promoting programs and initiatives important to the community.

In 2020 as our customers spent more time in their homes as a result of the COVID-19 pandemic, OUC focused on conservation education and cost-saving measures to help them better manage their energy and water usage. One way of doing this was offering virtual energy/water efficiency audits over the telephone, with OUC conservation specialists reviewing customers' consumption patterns with the intention to find unusual activity, such as high-water usage possibly due to a leak, which could be corrected. Conservation specialists also conducted on-site efficiency audits from outside homes while talking via their mobile phone with customers. The OUC.com/HighBillSolutions webpage was created and shared numerous times with customers to raise awareness of and educate them on how to track daily energy usage, look for ways to save on their utility bills, schedule free home energy and water efficiency audits, and help them better understand the impact of having their families at home for an extended period of time. The page also contained links to information on OUC financial assistance and payment arrangements/plans.

3.5.2.3 Connections

Connections is a monthly newsletter sent to all OUC customers whether they receive a paper statement or e-bill. The newsletters are posted on www.OUC.com and feature OUC's programs, community events, sustainability initiatives, and energy- and water-saving tips.

3.5.2.4 OUC Blog

In 2019, OUC launched a blog called OUConnect (www.oucblog.com). On OUConnect, customers can learn ways to save energy, water and money and how OUC is creating innovative products and services to meet the ever-growing needs of Central Florida. Customers will also read articles about community initiatives, as well as profiles on employees making a difference both at work and in their hometowns.

3.5.2.5 OUCconnect E Newsletter

In April 2019, OUC launched a monthly email newsletter to all residential and commercial customers with email addresses (170,000). This newsletter keeps customers informed and connected to OUC's programs, products, provides conservation tips and more.

3.5.2.6 Social Media

Facebook, Twitter, YouTube, and NextDoor allow OUC to update customers about the Commission's community involvement, as well as provide them with conservation tips, outage and restoration updates, and other need-to-know, real-time information that may affect them. Social media platforms also serve as additional customer service outlets, allowing customers to notify OUC about issues needing quick resolution, and provide additional opportunities for the Commission to build interactive relationships with customers and potentially diffuse negative situations.

3.5.2.7 Digital Meters

OUC's entire service area was upgraded with nearly 370,000 digital electric and water meters. The digital meters are easier to read and provide detailed information about customers' daily energy and water use. Meters can be monitored remotely, which reduces costs and time while ensuring an accurate and timely reading for the customer. Remote monitoring also allows OUC to better predict and prevent outages and restore power faster. OUC created Florida's first meter farm consisting of 120 electric meters and four water meters at its Pershing facility. The farm provides information and shows OUC exactly how updates are installed to ensure the meters are working correctly.

3.5.2.8 OUC Power Pass Program

OUC Power Pass is a program that allows customers to pay-as-you-go or pay in advance for utility services allowing the option of avoiding deposits, late fees and a monthly bill. Statistics have shown that pay-before-consumption programs result in less electricity and water usage because customers are more aware of how much they are using. Customers can check on their electric bill or water usage every day using the OUC Power Pass portal or receive alerts via text, email and/or phone. More than 14,000 customers are enrolled in the program to date.

3.5.2.9 Usage Dashboard

Digital meter technology allows customers to monitor electric consumption on an hourly basis and water on a daily basis instead of waiting until the end of the month to receive their bills. The ability to track usage patterns and make adjustments to lower energy bills was one of the items most frequently requested by OUC customers. To accommodate their needs, OUC released the OUC Usage Dashboard to most residential customers through their myOUC online profile. Because the new system also provides high-consumption alerts via email, changes in usage can be made immediately, and costs can be kept in check.

3.5.2.10 Online Rebate Application

OUC supports an online rebate application tool for customers to apply for rebates without the hassle of paperwork. It is more convenient for customers and reduced transaction time. Customers are able to access the tool through their myOUC online profile. OUC is continuing the use of software through the next few years and implementing a new software solution for rebate processing in 2021.

3.5.2.11 Project Momentum & PowerShift

OUC upgraded its customer information system from PeopleSoft Enterprise Risk Management to Customer Care & Billing to improve the quality experience for all levels of customers. OUC undertook this major initiative to lay the foundation for future enhancements and new technologies. This complex endeavor took into account other affected systems such as Outage Management, Meter Data Management, Enterprise 1, Geographic Information System, the Web, and Interactive Voice Response. Kicked off in January 2015 and implemented in July 2017, Project Momentum required 200-plus employees from 17 OUC departments and partner contractors to understand and work through hundreds of business processes and thousands of data points. Delivering an improved quality experience for customers is a primary goal of OUC's Strategic Plan.

In 2019, OUC started launched a project to offer Time of Use (TOU) rates – internally known as PowerShift – to explore the viability of extending a new rate structure as an option for customers. As an exploratory phase, OUC gauged interest from each of its customer segments and ultimately chose 700 customers to conduct the pilot. Beginning in April 2021 and lasting about one year, the 700 pilot customers will be billed according to On-Peak (2 p.m.-8 p.m.) and Off-Peak rates, the latter being the lowest, in order to help customers save on their monthly bills and to also smooth OUC's power demand curve. OUC has created numerous marketing and communication materials to ensure customers are equipped with the tools and resources to be successful in the program. Feedback will be gathered via quarterly customer surveys. OUC will use data from these surveys, as well as other data points and metrics, to determine the future of TOU rates after the pilot's conclusion.

3.5.2.12 Outage Alerts

OUC launched the first phase of its OUC Alerts program with Outage Alerts in December 2017. The system allows customers to receive information about service outages, including the cause and an estimated restoration time, via text, voice or email.

3.5.2.13 Billing Alerts

In January 2019, the second phase of OUC's Alerts program expanded to include Billing Alerts. The new feature lets customers set an alert, via text, email or voice, to let them know when their new bill is ready to view and when payment is due. This alert, along with Outage Alerts, launched in 2017, are among new "two-way communication" initiatives OUC has introduced to provide customers. Future OUC Alerts program phases to consider include consumption notifications and marketing messages.

3.5.3 Economic Development

Orlando has undergone a radical transformation over the years to diversify its economy and attract high-wage positions in technology, medicine, life sciences, and modeling and simulation. With Orlando's increasing emphasis on recruiting, retaining and expanding commercial customers, OUC has become a major player in the region's economic development. Working in partnership with Enterprise Florida, the Orlando Economic Partnership, and city and county governments, the utility is attracting more companies to Orlando and St. Cloud and helping them grow into vital and valuable members of the business community.

To attract large businesses that enhance the vitality of the community, OUC offers two rates. For large power users who qualify, OUC is able to negotiate its already-affordable rates to fit their business needs. The Economic Development Rider (EDR) is available to new or expanding businesses representing select

target industries. Companies must add a minimum of 500 kW demand of new electric load and must create at least 25 new jobs at or above the 150 percent median income level to qualify. The Commercial Industrial Service Rider (CISR) is available to companies that have minimum load of 2,000 kW or greater, served by a single meter. Companies must provide validation of a lower rate offering outside OUC's service territory to qualify.

Details of these rates and other incentives are outlined at www.oucpowersgrowth.com – a website that assists site selectors and businesses seeking to locate and learn more about Orlando and OUC. The site includes property search functionality and is mobile friendly.

4.0 FORECAST OF PEAK DEMAND AND ENERGY CONSUMPTION

OUC prepares a set of sales, energy, and demand forecast models each year to support its budgeting and financial planning process as well as long-term planning requirements. In preparing the forecasts, OUC uses internal records, company knowledge of the service territory and customers, and economic projections. OUC draws on outside expertise as needed. IHS Markit Ltd provides the economic projection data. Itron provides primary forecasting software, analysis of end-use equipment saturation and efficiencies, and technical expertise. In this forecast, Siemens and the National Renewable Energy Laboratory were utilized to provide projections of electric vehicles and rooftop solar within OUC's service territory.

4.1 Forecast Methodology

OUC has adopted a Statistically Adjusted Engineering (SAE) modeling technique developed by Itron. This approach entails specifying end-use variables (xHeat for heating, xCool for cooling, and xOther for other use) and utilizing these variables in multi-regression models to forecast sales. SAE variables allow anticipated shifts in customer end-use consumption driven by the type, saturation and efficiency of heating and cooling equipment, and other end-use devices to be represented along with econometric drivers and the effects of photovoltaic systems (PV) and electric vehicles (EV) in the forecast models. Itron reviews OUC's application of these techniques and provides data on heating, cooling, and other end-use load trends. These techniques are used to develop the forecasts for both the OUC and St. Cloud service territories.

4.1.1 Residential

The residential sales forecast consists of both a customer forecast model and an average use per customer model. Monthly average usage models were estimated using actual data for the period 2011 to 2020. This provides 10 years of historical data and enough observations to estimate strong regression models. Once models showing the number of expected customers and the expected average use per customer are developed, the projected residential sales by year (y) and month (m) are calculated as the product of the customer and average usage forecasts:

$$Sales_{y,m} = Customers_{y,m} \times Average\ Usage_{y,m}$$

4.1.1.1 Residential Customer Forecast

Residential customers are forecast as a function of household growth for Orange County for the OUC service territory and Osceola County for the St. Cloud service territory. There is a strong correlation between historical changes in customer counts and historical changes in households. The multi-regression model for residential customers is represented as:

$$Customers_{y,m} = \beta_0 + \beta_1(Households_{y,m})$$

The coefficients (β) are outputs of the multi-regression models.

4.1.1.2 Average Use Forecast

The residential forecast models utilize multi-regression modeling made up of three major components:

1. Changes in the economy, such as median household income, household size, and the price of electricity.
2. End-use equipment index variables, which capture the long-term net effect of equipment saturation and equipment efficiency improvements.
3. Weather variables, which serve to allocate the seasonal impacts of weather throughout the year.

The SAE model framework begins by defining energy use for an average customer in year (y) and month (m) as the sum of energy used by heating equipment (xHeat_{y,m}), cooling equipment (xCool_{y,m}), and other equipment (xOther_{y,m}). The xHeat, xCool and xOther variables are defined as a product of an annual equipment index and a monthly usage multiplier. This model is represented as:

$$\text{Average Usage}_{y,m} = \beta_1(\text{xHeat}_{y,m}) + \beta_2(\text{xCool}_{y,m}) + \beta_3(\text{xOther}_{y,m})$$

Where:

$$\text{xHeat}_{y,m} = \text{Economics}_{y,m} \times \text{HeatingEquipment}_{y,m} \times \text{HDD_Index}_{y,m}$$

$$\text{xCool}_{y,m} = \text{Economics}_{y,m} \times \text{CoolingEquipment}_{y,m} \times \text{CDD_Index}_{y,m}$$

$$\text{xOther}_{y,m} = \text{Economics}_{y,m} \times \text{OtherEquipment}_{y,m}$$

A customer’s monthly usage level is impacted by several economic factors, including the price of electricity, household size, and household income in real dollars.

$$\text{Economics}_{y,m} = \left(\frac{\text{Price}_{y,m}}{\text{Price}_{\text{base } y}} \right)^{-0.1} \times \left(\frac{\text{HH Size}_{y,m}}{\text{HH Size}_{\text{base } y,m}} \right)^{0.2} \times \left(\frac{\text{HH Income}_{y,m}}{\text{HH Income}_{\text{base } y,m}} \right)^{0.2}$$

The annual equipment variables (HeatEquip, CoolEquip, OtherEquip) are defined as a weighted average across equipment types multiplied by equipment saturation levels normalized by operating efficiency levels.

$$\text{HeatEquip}_y = \sum_{\text{tech}} \text{Weight} \times \left(\frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

$$\text{CoolEquip}_y = \sum_{\text{tech}} \text{Weight} \times \left(\frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

$$\text{OtherEquip}_y = \sum_{\text{tech}} \text{Weight} \times \left(\frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

The following degree day index variables serve to allocate the seasonal impacts of weather throughout the year. For historic periods, actual heating degree days (“HDD”) and cooling degree days (“CDD”) are used. Normal HDDs and CDDs are used for forecast periods.

$$\text{HDD_Index}_{y,m} = \frac{\text{HDD}_{y,m}}{\text{Normal HDD}_y}$$

$$\text{CDD_Index}_{y,m} = \frac{\text{CDD}_{y,m}}{\text{Normal CDD}_y}$$

4.1.2 Non-Residential

4.1.2.1 General Service Non-Demand (GSND)

The General Service Non-Demand (GSND) and General Service Demand Secondary (GSD Secondary) classes are modeled as a combined General Service Secondary class (GS Secondary) because the historic data indicates customer migration has occurred back and forth between the two classes. The result is a single model, which produces predicted values with a higher correlation than that of two separate models. The

forecast is later split between GSND and GSD Secondary using the monthly relationships between the two classes in the most recent year of actual data.

The framework for the GS secondary class sales forecast is similar to the residential class sales forecast. It also has three major components and utilizes the SAE model framework. General service customers and general service average usage are modeled separately. The end-use equipment variables are based on commercial appliance and equipment saturation and efficiency projections. The economic drivers in the model are the commercial price of electricity and Orlando Standard Metropolitan Statistical Area (SMSA) Gross Metro Product in real dollars. The third component is the weather variable, which is entirely composed of CDDs. HDDs are not used in the GS Secondary model because no statistically valid correlation between HDDs and sales could be identified.

GS secondary customers are forecast as a function of population for Orange County for the OUC service territory and Osceola County for the St. Cloud service territory. There is a strong correlation between historical changes in customers counts and historical changes in the Orange County population. St. Cloud historical customers also correlates well with the Osceola County population.

The GS Secondary use per customer model is represented as:

$$Sales_{y,m} = Customers_{y,m} \times Average\ Usage_{y,m}$$

Sales to five large GSD Secondary customers are excluded from the GS Secondary model discussed above. These large customers are forecast individually using a combination of SAE techniques, individual customer trending, and customer-specific planning input. These large customers currently represent approximately four percent of OUC's total load and eight percent of the GS Secondary load. They are handled individually because each has identifiable growth plans or patterns and/or each individually represents a significant load.

4.1.2.2 General Service Demand (GSD)

Forecast sales to GSD Secondary customers were modeled as discussed above. In addition to the customers taking service at secondary voltage, OUC serves 21 customers (excluding OUC water plants) at primary voltage. Of those 21, 16 are modeled as a group because they have exhibited a consistent load over time. This group of 16 customers currently represents about 19 percent of the GSD Primary load.

The five remaining primary customers are forecast individually using a combination of techniques, which includes regression modeling, individual customer trending, and customer-specific planning input. These five customers represent approximately six percent of OUC's total load and 81 percent of the GSD Primary load.

Sales from the various GSD models are summed to complete the GSD forecast.

4.1.2.3 Streetlights

Private and public lighting consumption is forecast separately. Both classes are not impacted by the weather, and the SAE modeling approach does not apply. Therefore, simple exponential smoothing models are used to generate both forecasts. The forecast for private streetlights includes a linear trend to capture the historic organic growth that is expected to continue within the forecast period. The forecast for public streetlights does not include a linear trend as any growth in the number of lights has been offset by the replacement of traditional HPS and MH fixtures with LED fixtures.

4.1.2.4 OUC Use

OUC Use sales are those to OUC Water Plants, OUCooling Plants, and OUC facilities. The OUC Use models utilize CDDs, but not HDDs or the factors included in the "Other" SAE modeling variable.

4.1.3 Net Energy for Load (“NEL”) and Peak Demand Forecast

The individual OUC and St. Cloud net energy for load forecasts are generated based on the respective sales forecasts described above and the historic relationship between actual monthly sales and NEL. Peak demand forecasts are then developed for each system based on the forecast NEL and the historic relationship between NEL, peak demand and daily weather.

4.2 Base-Case Forecast Assumptions

Incorporated into the forecast regression models are sets of underlying economic and demographic, price of electricity, and weather assumptions.

4.2.1 Economics & Demographics

The economic and demographic assumptions are derived from forecasts for Orange County, Osceola County, and the Orlando SMSA provided by IHS Markit Ltd.

4.2.1.1 Median Household Income

The residential average usage forecast models use Median Household Income in real dollars, as shown in Table 4-1.

4.2.1.2 Gross Metro Product

The commercial average usage forecast models use Gross Metro Product in real dollars, as shown in Table 4-1.

4.2.1.3 Households and Population

The residential and commercial customer forecast models use households and population, respectively. The primary demographic drivers in the residential average usage forecast models are the number of households and the population (see Table 4-1). The population data is divided by the household data to determine household size used in the residential average usage forecast models.

4.2.2 Price of Electricity

The nominal price of electricity by customer class is forecast to increase at the same rate as inflation resulting in essentially no change to the real price of electricity. The real price of electricity by customer class is used in the residential and commercial forecast models.

Table 4-1 Economic & Demographic Projections

| Year | Orlando SMSA Median Household Income ¹ | Orlando SMSA Gross Metro Product (\$ Billions) ¹ | Orange County (Thousands) | | Osceola County (Thousands) | |
|-------------------------|---|---|---------------------------|------------|----------------------------|------------|
| | | | Households | Population | Households | Population |
| 2021 | \$46,455 | \$127.2 | 514.6 | 1,424.8 | 130.3 | 398.0 |
| 2026 | \$47,556 | \$155.4 | 561.7 | 1,527.8 | 152.4 | 459.1 |
| 2030 | \$48,630 | \$175.8 | 599.1 | 1,621.1 | 169.5 | 509.9 |
| Average Annual Increase | | | | | | |
| 21 - 26 | 0.5% | 4.1% | 1.8% | 1.4% | 3.2% | 2.9% |
| 21 - 30 | 0.5% | 3.7% | 1.7% | 1.4% | 3.0% | 2.8% |
| (1) 2012 dollars | | | | | | |

4.2.3 Weather

Weather is a key factor affecting electricity consumption for indoor cooling and heating. Monthly CDDs are used to capture electric cooling load requirements while HDDs are used to capture electric heating load requirements. CDDs and HDDs are calculated from the daily average temperatures as reported by the National Weather Service for the weather station at the Orlando International Airport. CDDs are calculated using a 65°F base temperature as follows:

$$CDD_d = (Avg Temp_d - 65°F) \text{ when } Avg Temp_d \geq 65°F$$

The daily CDD values are then aggregated to yield monthly CDDs for each year as follows:

$$CDD_{y,m} = \sum CDD_{y,m,d}$$

Daily HDD values are calculated in a similar manner using a base temperature of 65°F as follows:

$$HDD_d = (65°F - Avg Temp_d) \text{ when } Avg Temp_d \leq 65°F$$

The daily HDD values are then aggregated to yield monthly HDDs for each year as follows:

$$HDD_{y,m} = \sum HDD_{y,m,d}$$

“Normal” monthly weather is assumed to be the median annual degree days for the 20-year period ending 2019.

4.3 Base-Case Load Forecast

A long-term annual base-case forecast was developed using the methodology and assumptions outlined above.

4.3.1 Customer and Sales Forecast Results

Total customers and retail sales for OUC and St. Cloud are expected to increase as shown in Table 4-2 through Table 4-5.

4.3.1.1 Residential Forecast

With increasing appliance efficiency, increased customer conservation, and declining household size, average usage per residential customer is projected to decline over the forecast period 2021 through 2030. Residential sales are projected to grow at an average annual rate of 1.6 percent for OUC and at 3.1 percent for St. Cloud over this same period. The number of residential customers is projected to grow at an average annual rate of 1.6 percent for OUC and 3.4 percent for St. Cloud over this same period.

4.3.1.2 GSND Forecast

GSND is comprised of small commercial customers. GSND sales are projected to grow at an average annual rate of 1.7 percent and 3.9 percent for OUC and St. Cloud, respectively, between 2021 and 2030. The number of GSND customers is projected to grow at an average annual rate of 0.9 percent and 3.3 percent, respectively, for OUC and St. Cloud over this same period.

4.3.1.3 GSD Forecast

GSD is comprised of large commercial and industrial customers. Sales are projected to grow at an average annual rate of 2.0 percent and 3.9 percent for OUC and St. Cloud, respectively, between 2021 and 2030. The number of GSD customers is projected to grow at an average annual rate of 0.9 percent and 3.3 percent, respectively, for OUC and St. Cloud over this same period.

Table 4-2 OUC Long-Term Sales Forecast (GWh)

| Year | Residential | GSND | GSD | Lighting | OUC Use | Total Retail |
|-------------------------|-------------|------|-------|----------|---------|--------------|
| 2021 | 2,036 | 395 | 3,185 | 59 | 148 | 5,823 |
| 2026 | 2,166 | 436 | 3,634 | 62 | 239 | 6,538 |
| 2030 | 2,339 | 458 | 3,811 | 65 | 245 | 6,917 |
| Average Annual Increase | | | | | | |
| 21 - 26 | 1.2% | 2.0% | 2.7% | 1.1% | 10.0% | 2.3% |
| 21 - 30 | 1.6% | 1.7% | 2.0% | 1.0% | 5.7% | 1.9% |

Table 4-3 OUC Average Number of Customers Forecast

| Year | Residential | GSND | GSD | Total Retail |
|-------------------------|-------------|--------|-------|--------------|
| 2021 | 185,515 | 22,934 | 4,866 | 213,315 |
| 2026 | 201,257 | 23,923 | 5,075 | 230,254 |
| 2030 | 213,814 | 24,879 | 5,277 | 243,970 |
| Average Annual Increase | | | | |
| 21 - 26 | 1.6% | 0.8% | 0.8% | 1.5% |
| 21 - 30 | 1.6% | 0.9% | 0.9% | 1.5% |

Table 4-4 St. Cloud Long-Term Sales Forecast (GWh)

| Year | Residential | GSND | GSD | Lighting | Total Retail |
|-------------------------|-------------|------|------|----------|--------------|
| 2021 | 569 | 59 | 142 | 3 | 773 |
| 2026 | 668 | 72 | 174 | 3 | 917 |
| 2030 | 748 | 83 | 199 | 3 | 1,033 |
| Average Annual Increase | | | | | |
| 21 - 26 | 3.2% | 4.1% | 4.1% | 0.0% | 3.5% |
| 21 - 30 | 3.1% | 3.9% | 3.9% | 0.0% | 3.3% |

Table 4-5 St. Cloud Average Number of Customers Forecast

| Year | Residential | GSND | GSD | Total Retail |
|-------------------------|-------------|-------|------|--------------|
| 2021 | 41,376 | 3,735 | 341 | 45,451 |
| 2026 | 49,507 | 4,447 | 406 | 54,359 |
| 2030 | 55,820 | 5,015 | 458 | 61,293 |
| Average Annual Increase | | | | |
| 21 - 26 | 3.7% | 3.6% | 3.5% | 3.6% |
| 21 - 30 | 3.4% | 3.3% | 3.3% | 3.4% |

4.3.2 Forecast Hourly Peak Demand and NEL

Peak demand growth is driven by the aggregate retail load forecasts for OUC and St. Cloud. Seasonal hourly peaks and annual NEL are presented for OUC and St. Cloud in Tables 4-6 and 4-7, respectively. Table 4-8 represents the combined seasonal coincident hourly peak demand and NEL forecasts for OUC and St. Cloud.

Table 4-6 OUC Forecast Hourly Peak Demand (Summer and Winter) and NEL

| Year | Summer (MW) | Winter (MW) | NEL (GWh) |
|-------------------------|-------------|-------------|-----------|
| 2021 | 1,094 | 1,003 | 5,964 |
| 2026 | 1,245 | 1,128 | 6,708 |
| 2030 | 1,316 | 1,180 | 7,103 |
| Average Annual Increase | | | |
| 21 - 26 | 2.6% | 2.4% | 2.4% |
| 21 - 30 | 2.1% | 1.8% | 2.0% |

Table 4-7 St. Cloud Forecast Hourly Peak Demand (Summer and Winter) and NEL

| Year | Summer (MW) | Winter (MW) | NEL (GWh) |
|-------------------------|-------------|-------------|-----------|
| 2021 | 207 | 179 | 819 |
| 2026 | 246 | 211 | 972 |
| 2030 | 278 | 238 | 1,095 |
| Average Annual Increase | | | |
| 21 - 26 | 3.5% | 3.4% | 3.5% |
| 21 - 30 | 3.3% | 3.2% | 3.3% |

Table 4-8 System Forecast Coincident Hourly Peak Demand (Summer and Winter) and NEL (Total of OUC and St. Cloud)

| Year | Summer (MW) | Winter (MW) | NEL (GWh) |
|-------------------------|-------------|-------------|-----------|
| 2021 | 1,293 | 1,182 | 6,783 |
| 2026 | 1,484 | 1,326 | 7,680 |
| 2030 | 1,586 | 1,402 | 8,198 |
| Average Annual Increase | | | |
| 21 - 26 | 2.8% | 2.3% | 2.5% |
| 21 - 30 | 2.3% | 1.9% | 2.1% |

4.4 High and Low Load Scenarios

In addition to the base-case, two long-term forecast scenarios representing a high and low range around the forecast peak demand and NEL were constructed to test for sensitivity of uncertain economic conditions and customer growth. Weather conditions deviating from normal were not included in sensitivity testing due to non-growth-related impacts and an equal probability of affecting any given year either negatively or positively. The high and low load scenarios represent alternatives to the base-case forecast and are defined by 0.5 percent higher and 0.5 percent lower economic growth rates, respectively. Table 4-9 represents a summary of the high and low load scenarios.

Table 4-9 High and Low Scenario System Forecast Peak Demand (Summer and Winter) and NEL (Total of OUC and St. Cloud)

| High Load Scenario | | | |
|--------------------------------|------------------------|------------------------|----------------------|
| Year | Summer (MW) | Winter (MW) | NEL (GWh) |
| 2021 | 1,295 | 1,178 | 6,791 |
| 2026 | 1,510 | 1,336 | 7,788 |
| 2030 | 1,638 | 1,448 | 8,403 |
| Average Annual Increase | | | |
| 21 - 26 | 3.1% | 2.6% | 2.8% |
| 21 - 30 | 2.6% | 2.3% | 2.4% |
| Low Load Scenario | | | |
| Year | Summer (MW) | Winter (MW) | NEL (GWh) |
| 2021 | 1,291 | 1,178 | 6,775 |
| 2026 | 1,466 | 1,300 | 7,574 |
| 2030 | 1,554 | 1,378 | 8,003 |
| Average Annual Increase | | | |
| 21 - 26 | 2.6% | 2.0% | 2.3% |
| 21 - 30 | 2.1% | 1.8% | 1.9% |

5.0 DEMAND-SIDE MANAGEMENT

Sections 366.80 through 366.83, and 403.519, Florida Statutes (F.S.), are known collectively as the Florida Energy Efficiency and Conservation Act (FEECA). Section 366.82(2), F.S., requires the Florida Public Service Commission (PSC) to adopt appropriate goals designed to increase the conservation of expensive resources, such as petroleum fuels, to reduce and control the growth rates of electric consumption and weather-sensitive peak demand. Pursuant to Section 366.82(6), F.S., the PSC must review the conservation goals of each utility subject to FEECA at least every five years. The seven utilities subject to FEECA are Florida Power & Light Company (FPL), Progress Energy Florida, Inc. (PEF), Tampa Electric Company (TECO), Gulf Power Company (Gulf), Florida Public Utilities Company (FPUC), OUC, and JEA (referred to collectively as the FEECA utilities).

OUC’s residential and commercial/industrial numeric conservation goals for the 2020 through 2024 period were established by the PSC pursuant to Order No. PSC-2019-0509-FOF-EG. These PSC-established annual goals are presented in Tables 5-1, 5-2 and 5-3.

OUC, with its Board of Commissioners, sets locally focused energy efficiency goals which include measures beyond those measured through FEECA. Because OUC must operationally plan to generate enough energy to meet demand at all times, and because OUC can incentivize but not control actual adoption, this forecast is being used for purposes of the site plan.

Table 5-1 Residential DSM Goals Approved by the PSC

| Calendar Year | Summer (MW) | Winter (MW) | Annual (GWh) |
|---------------|-------------|-------------|--------------|
| 2020 | 0.21 | 0.21 | 0.77 |
| 2021 | 0.21 | 0.22 | 0.80 |
| 2022 | 0.19 | 0.20 | 0.72 |
| 2023 | 0.19 | 0.18 | 0.66 |
| 2024 | 0.16 | 0.16 | 0.57 |
| Total | 0.96 | 0.97 | 3.52 |

Table 5-2 Commercial/Industrial DSM Goals Approved by the PSC

| Calendar Year | Summer (MW) | Winter (MW) | Annual (GWh) |
|---------------|-------------|-------------|--------------|
| 2020 | 0.39 | 0.70 | 0.85 |
| 2021 | 0.40 | 0.78 | 0.86 |
| 2022 | 0.37 | 0.78 | 0.85 |
| 2023 | 0.39 | 0.74 | 0.82 |
| 2024 | 0.36 | 0.70 | 0.80 |
| Total | 1.91 | 3.70 | 4.18 |

Table 5-3 Total Residential and Commercial/Industrial DSM Goals Approved by the PSC

| Calendar Year | Summer (MW) | Winter (MW) | Annual (GWh) |
|---------------|-------------|-------------|--------------|
| 2020 | 0.60 | 0.91 | 1.62 |
| 2021 | 0.61 | 1.00 | 1.66 |
| 2022 | 0.56 | 0.98 | 1.56 |
| 2023 | 0.57 | 0.92 | 1.48 |
| 2024 | 0.52 | 0.86 | 1.37 |
| Total | 2.86 | 4.67 | 7.69 |

OUC has been increasingly emphasizing its DSM and conservation programs to increase customer awareness of such programs. Not only do these programs help customers save money by saving energy, the programs help OUC reduce emissions of greenhouse gases and better position OUC to meet possible future greenhouse gas regulations. It should be noted that government mandates have forced manufacturers to increase their efficiency standards, thereby decreasing the incremental amount of energy savings achievable. In addition, the efficiency of new generation has increased and natural gas prices have remained at or near historic lows for the last several years, and look to continue to do so for the near future. These appliance and generating unit efficiency improvements, coupled with low natural gas prices, have mitigated to some degree the effectiveness of DSM and conservation programs, as overall efficiency increases in the marketplace partially offset the benefit of such programs.

The conservation programs included in OUC’s 2020 DSM Plan (approved by the PSC on June 5, 2020) and offered to its customers in 2020 consist of the following:

- Residential Home Energy Survey Program – Walk-Through and Online
- Residential Duct Repair Rebates Program
- Residential Ceiling Insulation Rebates Program
- Residential High Performance Windows Rebate Program
- Residential Efficient Electric Heat Pump Rebates Program
- Residential New Home Rebates Program
- Residential Heat Pump Water Heater Rebates Program
- Residential Efficiency Delivered Program
- Commercial Energy Audit Program
- Commercial Efficient Electric Heat Pump Rebates Program
- Commercial Duct Repair Rebates Program
- Commercial Ceiling Insulation Rebates Program
- Commercial Cool/Reflective Roof Rebates Program
- Commercial Indoor Lighting Billed Solution Program
- Commercial Indoor Lighting Rebates Program
- Commercial Custom Incentives Program

The remainder of this section describes each of the DSM and conservation programs outlined above (Sections 5.1 and 5.2), as well as OUC's other DSM, conservation, and energy efficiency programs and activities not included in OUC's 2020 DSM Plan (Section 5.3). Incentives and rebate amounts included in the program descriptions are current as of the time this report was prepared. In addition to offering these programs, OUC continues to play an active role in promoting conservation through community relations as discussed in Section 2.4 and Section 3.6 of this Ten-Year Site Plan.

5.1 Energy Survey Programs

5.1.1 Residential Home Energy Survey Program

OUC has been offering home energy surveys dating back to the late 1970's. The home energy walk-through surveys were designed to provide residential customers with recommended energy efficiency measures and practices customers can implement and to encourage participation in various OUC rebate programs. The home energy surveys are available to both single family and multi-family residential customers.

The Residential Energy Walk-Through Survey includes a review of the customer electric consumption history as well as a walk-through review of the attic; heating, ventilation, and air conditioning (HVAC) system; air duct and air returns; window caulking; weather stripping around doors; faucets and toilets; and lawn sprinkler systems. OUC provides participating customers specific tips on conserving electricity and water as well as details on customer rebate programs. OUC Conservation Specialists are using this walk-through type audit as a means of motivating OUC customers to participate in other conservation programs and qualify for appropriate rebates.

In addition to the Energy Walk-Through, OUC offers customers an interactive Online Home Energy Audit. The Online Home Energy Audit walks the customer through an assessment of energy and water efficiency in his or her home. The online audit has several benefits over the walk-through survey, including the convenience of viewing it at any time without a scheduled appointment and the ability to conduct it numerous times. The interactive Online Home Energy Audit is available on OUC's web site through a customer's myOUC login.

One of the primary benefits of the Residential Energy Survey Program is the education it provides to customers on energy conservation measures and ways their lifestyle can directly affect their energy use. Customers participating in the Energy Survey Program are informed about their historical energy usage and conservation measures that they can implement. Customers will benefit from the increased efficiency in their homes, and decreased electric and water bills.

5.1.2 Commercial Energy Audit Program

The Commercial/Industrial Energy Survey Program has been offered for several years and is focused on increasing the energy efficiency of commercial buildings and includes a free survey comprised of a physical walk-through inspection of the commercial facility performed by trained and experienced energy experts. The survey will include a pre-walk-through review of historical energy usage as well as a walk-through to examine heating and air conditioning systems including duct work, refrigeration equipment, lighting, water heating, motors, process equipment, and the thermal characteristics of the building including insulation. Following the inspection the customer receives a written report detailing cost-effective recommendations to make the facility more energy and water efficient. Participating customers are

encouraged to participate in other OUC commercial programs and directly benefit from energy conservation, which decreases their electric and water bills.

OUC customers can participate by calling the OUC Customer Service Call Center and requesting an appointment for a Walk-Through Energy Survey. Participation is tracked through service orders that are produced when appointments are scheduled and completed.

5.2 Rebate Programs

The following outlines the various rebate programs OUC offers to its customers. Customers can participate by submitting a rebate application online at <http://www.OUC.com/rebates>. Proof of purchase and/or receipts are required to be attached to the application and repairs can be performed by a contractor or the customer. Participation is tracked based on the number of rebates processed. Typically these rebates are credited on the customer's bill, or a check can be processed and sent to the property owner who may have paid for the improvement.

5.2.1 Residential Duct Repair Rebates Program

The residential Duct Repair Rebates Program originated in 2000 and is designed to encourage customers to repair leaking ducts on existing systems. Qualifying customers must have an existing central air conditioning system of 5.5 tons or less and ducts must be sealed with mastic and fabric tape or any other Underwriters Laboratory (UL) approved duct tape. Participating customers receive a rebate for 100 percent of the cost of duct repairs on their homes, up to \$100.

5.2.2 Residential Ceiling Insulation Rebates Program

The attic is the easiest place to add insulation and lower total energy costs throughout the seasons. The residential Ceiling Insulation Rebates Program has been offered for several years and is designed to encourage customers to upgrade their attic insulation. Participating customers receive \$0.10 per square foot for upgrading their attic insulation to R-30 or higher. The program applies to conditioned areas only.

5.2.3 Residential High Performance Window Rebates Program

Energy-efficient windows can help minimize heating, cooling, and lighting costs. The residential High Performance Windows Rebates program has been offered for several years and is designed to encourage customers to install windows that improve energy efficiency in their homes. Customers will receive a \$1.50 rebate per square foot for the purchase of ENERGY STAR® rated energy efficiency windows.

5.2.4 Residential Efficient Electric Heat Pump Rebates Program

The residential Efficient Electric Heat Pump Rebates Program provides rebates to qualifying customers in existing homes who install heat pumps having a seasonal energy efficiency ratio (SEER) of 15.0 or higher. Customers will obtain a rebate in the form of a credit on their bill ranging up to \$1,630, depending upon the SEER rating and capacity (tons) of the new heat pump. The following table illustrates the incentives available depending on the size and efficiency of the Heat Pump installed.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

| | SEER | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------------------|-------|------|-------|-------|--------|--------|--------|--------|--------|--------|
| A / C Size (Tons) | 1 | \$ 5 | \$ 55 | \$ 95 | \$ 135 | \$ 170 | \$ 205 | \$ 230 | \$ 260 | \$ 280 |
| | 1 1/2 | 30 | 105 | 175 | 230 | 285 | 330 | 375 | 415 | 450 |
| | 2 | 60 | 160 | 250 | 325 | 400 | 460 | 520 | 570 | 620 |
| | 2 1/2 | 90 | 215 | 325 | 425 | 510 | 590 | 660 | 725 | 785 |
| | 3 | 115 | 270 | 400 | 520 | 625 | 720 | 805 | 885 | 955 |
| | 3 1/2 | 145 | 320 | 475 | 615 | 740 | 850 | 950 | 1,040 | 1,125 |
| | 4 | 175 | 375 | 550 | 710 | 850 | 975 | 1,090 | 1,195 | 1,290 |
| | 4 1/2 | 205 | 430 | 630 | 805 | 965 | 1,105 | 1,235 | 1,355 | 1,460 |
| | 5 | 230 | 485 | 705 | 900 | 1,075 | 1,235 | 1,380 | 1,510 | 1,630 |

5.2.5 Residential New Home Rebates Program

What was previously named The Residential Gold Ring Home Program has been transformed into a more flexible “a la carte” program offering a variety of choices for the builder or home buyer and has been renamed the New Home Rebates program. This transformation was based on feedback OUC received from the residential building community in order to increase the level of participation in OUC’s program. The table below reflects an example of the incentives available.

| Rebate | Rate of Rebate | Square Footage | Total |
|--|----------------|----------------|-------|
| Ceiling Insulation Upgrade to R-38 or higher | \$0.03/sq. ft. | 2,000 | \$60 |
| Heat Pump | Up to \$1,630 | N/A | \$500 |
| Energy Star® Heat Pump Water Heater | \$500 | N/A | \$500 |
| Solar Water Heater | \$900 | N/A | \$900 |

5.2.6 Residential Heat Pump Water Heater Rebates Program

Commonly referred to as hybrid electric heat pump water heaters, such water heaters with a coefficient of performance (COP) of greater than 2.0 can cut water heating electric use and costs by more than half. OUC’s Heat Pump Water Heater Rebates program provides rebates for the heat pumps for qualifying installations. The contractor and/or retailer’s invoice is required to receive this rebate and must reflect the system model number. If the receipt does not include the model number, a copy of the retailer’s item description of product installed should be submitted that can be matched to the proof of purchase. OUC’s rebate is \$500.

5.2.7 Residential Efficiency Delivered Program

What was once referred to as the Home Energy Fix-Up Program has been revamped and expanded to allow for any OUC customer (energy, water, or both energy and water) to participate and renamed the Efficiency Delivered program. The program is available to residential customers (single family homes) and provides up to \$2,500 of energy and water efficiency upgrades based on the needs of the customer’s home. A Conservation Specialist from OUC performs a survey at the home and determines which home improvements have the potential of saving the customer the most money. The program is income-based . OUC will help contribute toward the cost of improvements based on three household income tiers:

| Household Income | OUC Contribution |
|-------------------------|-----------------------------|
| Less than \$40,000 | 85% (not to exceed \$2,500) |
| \$40,001–\$60,000 | 50% (not to exceed \$2,500) |
| Greater than \$60,000 | Rebates only |

- \$40,000 or less OUC will contribute 85 percent of the total cost (not to exceed \$2,500),
- \$40,001 to \$60,000 OUC will contribute 50 percent of the total cost (not to exceed \$2,500),
- Greater than \$60,000 OUC will contribute the rebate incentives that apply toward the total cost.

Each customer must request and complete a free Residential Energy Survey. Ordinarily, Energy Survey recommendations require a customer to spend money replacing or adding energy conservation measures; however, customers may not have the discretionary income to implement these measures (especially those in the lower income tier). Under this program, OUC will arrange for a licensed, approved contractor to perform the necessary repairs based on a negotiated and contracted rate. The remaining portion of the cost the customer is responsible for can be paid directly to OUC or over an interest-free up to a 24-month period on the participant’s monthly electric bill.

To be eligible for this program, the customer’s account must be in good credit standing with the exception of low-income customers, who are only required to have a current balance that is not delinquent. Some of the improvements covered under this program include ceiling insulation, duct system repair, pipe insulation, window film, window caulk, door caulk, door weather stripping, door sweep, threshold plate, air filter replacement, toilet replacement, irrigation repairs, water flow restrictors and minor plumbing repairs. In 2020, several new measures were added to the program including: HVAC tune-up, evaporator coil cleaning, smart or programmable thermostats, blower door test, attic stair cover, and WaterSense irrigation controller.

The purpose of the program is to reduce energy and water costs, especially for low-income households, particularly those households with elderly persons, disabled persons and children. Through this program, OUC helps to lower the bills of customers who may have difficulty paying their bills, thereby decreasing the potential for costly service disconnect fees and late charges. OUC believes that this program will help customers afford other essential living expenses. For others, this program offers a one-stop-shop to facilitate the implementation of a whole suite of conservation measures at reasonable costs and pre-screened qualified contractors.

5.2.8 Commercial Efficient Electric Heat Pump Rebates Program

The commercial Efficient Electric Heat Pump Rebates Program provides rebates to qualifying customers in existing buildings who install heat pumps having a seasonal energy efficiency ratio (SEER) of 15.0 or higher. Customers will obtain a rebate in the form of a credit on their bill ranging up to \$1,630, depending upon the SEER rating and capacity (tons) of the new heat pump. The following table illustrates the incentives available depending on the size and efficiency of the heat pump installed.

| | SEER | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------------------|-------|------|-------|-------|--------|--------|--------|--------|--------|--------|
| A / C Size (Tons) | 1 | \$ 5 | \$ 55 | \$ 95 | \$ 135 | \$ 170 | \$ 205 | \$ 230 | \$ 260 | \$ 280 |
| | 1 1/2 | 30 | 105 | 175 | 230 | 285 | 330 | 375 | 415 | 450 |
| | 2 | 60 | 160 | 250 | 325 | 400 | 460 | 520 | 570 | 620 |
| | 2 1/2 | 90 | 215 | 325 | 425 | 510 | 590 | 660 | 725 | 785 |
| | 3 | 115 | 270 | 400 | 520 | 625 | 720 | 805 | 885 | 955 |
| | 3 1/2 | 145 | 320 | 475 | 615 | 740 | 850 | 950 | 1,040 | 1,125 |
| | 4 | 175 | 375 | 550 | 710 | 850 | 975 | 1,090 | 1,195 | 1,290 |
| | 4 1/2 | 205 | 430 | 630 | 805 | 965 | 1,105 | 1,235 | 1,355 | 1,460 |
| | 5 | 230 | 485 | 705 | 900 | 1,075 | 1,235 | 1,380 | 1,510 | 1,630 |

5.2.9 Commercial Duct Repair Rebates Program

The commercial Duct Repair Rebates program started in 2009. OUC will rebate 100 percent of cost, up to \$100. Qualifying customers must have an existing central air conditioning system of 5.5 tons or less and ducts must be sealed with mastic and fabric tape or Underwriters Laboratory (UL) approved duct tape.

5.2.10 Commercial Ceiling Insulation Rebates Program

The commercial Ceiling Insulation Rebates Program started in 2009 and was designed to increase a building's resistance to heat loss and gain. Participating customers receive \$0.10 per square foot, for upgrading their attic insulation to R-30 or higher.

5.2.11 Commercial Cool/Reflective Roof Rebates Program

The commercial Cool/Reflective Roof Rebates Program started in 2009 and was designed to reflect the sun's rays and lower roof surface temperature while increasing the lifespan of the roof. OUC will rebate customers at \$0.12 per square foot for ENERGY STAR® cool/reflective roofing that has an initial solar reflectance greater than or equal to 0.70.

5.2.12 Commercial Indoor Lighting Billed Solution Program

Converting old indoor lights to new lighting technologies is one of the most cost-effective improvements that a commercial customer can make. For some, the lack of capital or budget planning can be major barriers to making cost-effective investments. Since 2002, OUC's commercial Indoor Lighting program has assisted commercial customers with these investments through OUC's commercial Indoor Lighting Billed Solution program. Through a competitive RFP process, OUC selected a qualified lighting contractor to work with customers to develop proposals. Customers enter into an agreement with OUC to pay back the cost of the project based on the expected savings through monthly charges applied to their bill. Basically, it is a cash-flow neutral billed solution where the monthly savings pay for the project's cost over the pay-back period or term. The term cannot exceed five years.

5.2.13 Commercial Indoor Lighting Rebates Program

Commercial customers that upgrade the efficiency of their indoor lighting may be eligible to receive a rebate of \$250/kW through the commercial Indoor Lighting Rebates program. Participation is open to facilities located within OUC's service area that receive electric service under an OUC commercial rate. Participants or customers may be any of the following:

- Individual customers who install more efficient lighting in their own facilities.
- National or local companies that install more efficient lighting.

- Local contractors, design/build firms, architectural and engineering firms, and commercial property developers working on behalf of OUC commercial customers.

5.2.14 Commercial Custom Incentive Program

Through the commercial Custom Incentive program, commercial customers receive incentives based on the reduction in peak demand their projects achieve plus the first year energy savings. Energy and demand saving incentives are paid for the maximum one-hour average demand reduction that occurs during the Summer Demand period defined as weekdays, between 1 P.M. to 6 P.M., from April through October. Pre- and post-inspections are required. Incentives and other program considerations are summarized below.

- \$550 per kW reduction incentive and/or energy reduction measures at \$0.032 per kWh will also be incentivized.
- \$250 per kW reduction incentive for all lighting measures.
- Incentives shall not exceed 50% of project cost.
- Incentives may be paid at 50% on project completion and remainder at one year depending on performance results.
- All incentives will be paid as a credit appearing on the customer's OUC statement.
- Simple return on investment must be greater than 2 years.
- Energy and demand conservation measure should have a useful life of at least 10 years.
- A maximum incentive of \$100,000 per customer annually.

5.3 OUC's Additional DSM/EE/Conservation Programs and Activities

Besides the load and consumption reducing initiatives previously discussed such as: residential and commercial rebates, Indoor Lighting Billed Solution, LED Streetlighting, LEED buildings, Home Utility Reports, Power Pass, Solar PV and thermal, Batteries, etc., OUC continues to do more, including:

- Conservation Voltage Reduction (CVR) - The Conservation Voltage Reduction (CVR) Project is made possible by OUC's investment in its Advanced Meter Infrastructure (AMI) and more sophisticated distribution equipment. The availability of AMI customer load and voltage interval data provides an opportunity to optimize voltage control and thereby reduce energy consumption based on better awareness and monitoring of system conditions at customer service points. Benefits of CVR include conservation related reductions in customer energy usage and line losses (with associated reductions in fuel usage) and lower demands on generation resources. As of December 2020, OUC had 135 circuits of the total of 282 circuits under CVR control and savings of approximately 18,622,000 kWh annually.
- Power Plant Efficiency improvements - Over the last few years OUC has made additional investments in improving the energy efficiency at its generation facilities. Some of these investments include; a turbine upgrade, VFD and EMS in Stanton Unit 2 and a turbine upgrade, EMS and an AQC Duct Repair in Stanton Unit 1. The combined effects of these improvements contributed to 51,293,000 kWh savings in 2020.
- OUCooling Chilled Water District(s) Efficiency Improvements - OUCooling currently serves 48 customers and provides 46,413 tons of cooling. OUCooling's success has relied on the fact that OUCooling can deliver cooling more efficiently and less costly than what a customer would likely produce on their own. The way OUCooling succeeds is by investing in higher efficiency chillers and equipment and optimizes its operations on a continuous basis. The enhanced efficient operation of OUCooling is estimated to save approximately 21,485,000 kWh in 2020.

6.0 FORECAST OF FACILITIES REQUIREMENTS

6.1 Existing Capacity Resources

6.1.1 Existing Generating Capacity

OUC’s installed generating capability for OUC and St. Cloud (as of date this Ten-Year Site Plan was prepared) is 1,415 MW in the winter and 1,378 MW in the summer assuming Lakeland Electric removes McIntosh Unit 3 from service by March 31, 2021. OUC’s existing generating capability (described in more detail in Section 2.0) consists of the following:

- A joint ownership share in the Stanton Energy Center (Units 1, 2, and Stanton A)
- Sole ownership of Stanton Energy Center Unit B (Stanton B)
- Joint ownership shares of the Indian River combustion turbine units
- Joint ownership share of St. Lucie Unit 2 Nuclear Generating Facility

St. Cloud’s entitlement to capacity from Stanton Unit 2 is included as generating capability in Tables 6-1 and 6-2, consistent with the Interlocal Agreement described in Section 2.0.

6.1.2 Power Purchase Agreements

Corresponding to the construction of Stanton A, OUC entered into a PPA with SCF to purchase capacity from SCF’s 65 percent ownership share of Stanton A. The original Stanton A PPA was for a term of 10 years and allowed OUC, KUA, and FMPA to purchase all of SCF’s 65 percent capacity share. The utilities originally had options to extend the PPA beyond its initial term. OUC’s Stanton A PPA has been extended through December 2031. As discussed in Section 2, NextEra Energy has purchased SCF’s interest in Stanton A.

As discussed in Section 2, OUC added 108.5 MWac of solar capacity (nameplate) in June 2020 through PPAs with NextEra, and will add 149 MWac of solar capacity (nameplate) in December 2023, also through PPAs with NextEra.

In 2020, OUC completed a comprehensive Electric Integrated Resource Plan (EIRP) to guide OUC through the next 30 years. Based on the results of the EIRP, OUC anticipates entering into PPAs for approximately 1,267 MWac of solar (nameplate) and 350 MWac of energy storage by 2030 as summarized in Table 6-1.

Table 6-1 Anticipated Solar PPAs

| Commercial Operation Date | Nameplate Capacity (MWac) w/o Energy | Energy Storage (MW) |
|----------------------------------|---|----------------------------|
| June 2025 | 224 | 100 |
| June 2026 | 149 | 50 |
| June 2027 | 149 | 0 |
| June 2028 | 224 | 50 |
| June 2029 | 224 | 0 |
| June 2030 | 298 | 150 |

6.1.3 Power Sales Agreements

OUC's power sales to Lake Worth, Winter Park, Mt. Dora, Chattahoochee, and Lakeland Electric are described in Section 2.3.

6.1.4 Retirements and Modifications of Generating Facilities

OUC has not scheduled any unit retirements over the planning horizon, but will continue to evaluate options on an ongoing basis. One factor affecting potential unit modifications and/or retirements is the impact of pending future environmental regulations. OUC will continue to monitor future environmental regulations that may impact its operating fleet and decisions related to generating units, and develop appropriate corresponding compliance plans.

OUC anticipates converting both Stanton Unit 1 and Stanton Unit 2 to no longer operate on coal and instead operate only on natural gas with the first unit converted no later than 2025 and the second unit converted no later than 2027; OUC is in the process of determining the final timing of the natural gas conversion of each unit. Estimated changes to the capacity of Stanton Unit 1 and Stanton Unit 2 following the natural gas conversions are reflected in Tables 6-1 and 6-2.

Lakeland Electric has indicated that McIntosh Unit 3 is expected to be removed from service by March 31, 2021. As such, capacity associated with McIntosh Unit 3 is not reflected in Table 6-1 and is not reflected in Table 6-2 beginning in the winter of 2021/22.

6.2 Reserve Margin Requirements

The FPSC has established a minimum planned reserve margin criterion of 15 percent in 25-6.035 (1) Florida Administrative Code for the purposes of sharing responsibility for grid reliability. The 15 percent minimum planned reserve margin criterion is generally consistent with practice throughout much of the industry. OUC has adopted the 15 percent minimum reserve margin requirement as its planning criterion.

6.3 Future Resource Needs

6.3.1 Generator Capabilities and Requirements Forecast

Tables 6-2 and 6-3 (presented at the end of this section) display the forecast reserve margins for the combined OUC and St. Cloud systems for the winter and summer seasons, respectively. OUC's capacity from renewable projects (discussed in Section 2.4) that is projected to be available at the time of peak demand is also reflected in Tables 6-1 and 6-2. Also reflected in Tables 6-1 and 6-2 are expected capacity reductions for Stanton Unit 1 and Stanton Unit 2 following conversion to operate only on natural gas.

Table 6-2 and Table 6-3 indicate that OUC is projected to have adequate generating capacity to maintain the 15 percent reserve margin requirements through the period considered in this Ten-Year Site Plan (i.e. through 2030). As such, this Ten-Year Site Plan does not include any new capacity additions, beyond the solar purchases and battery storage associated with OUC's EIRP and discussed throughout this Ten-Year Site Plan.

6.3.2 Transmission Capability and Requirements Forecast

OUC continuously monitors and upgrades the bulk power transmission system as necessary to provide reliable electric service to its customers. OUC's current transmission system planning criteria are

summarized in its annual filing to the Federal Energy Regulatory Commission. Please see OUC’s FERC Form 715 for additional information.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

Table 6-2 Projected Winter Reserve Requirements – Base-Case

| Year | Retail and Wholesale Peak Demand (MW) ¹ | | | | | | | Available Capacity (MW) | | | | | Reserves (MW) | | | Excess/ (Deficit) Capacity to Maintain 15% Reserve Margin (MW) ⁽⁷⁾ |
|---------|--|-------------|---------------|----------|---------------|----------------|-------|--------------------------|--------------|-----------------|----------------------|---|----------------------|-------------------------|--------------------------|---|
| | OUC and STC | Mt. Dora | Chattahoochee | Lakeland | Lake Worth | Winter Park | Total | Installed ⁽²⁾ | SEC A PPA | Landfill Gas | Solar ⁽³⁾ | Battery Energy Storage ⁽³⁾ | Total ⁽⁴⁾ | Required ⁽⁵⁾ | Available ⁽⁶⁾ | |
| 2020/21 | 1,182 | 17 | 6 | 0 | 25 | 17 | 1,247 | 1,551 | 350 | 19 | 0 | 0 | 1,920 | 177 | 673 | 496 |
| 2021/22 | 1,199 | 17 | 6 | 125 | 25 | 17 | 1,389 | 1,415 | 350 | 19 | 0 | 0 | 1,784 | 180 | 396 | 216 |
| 2022/23 | 1,243 | 17 | 6 | 125 | 25 | 17 | 1,433 | 1,415 | 350 | 19 | 0 | 0 | 1,784 | 186 | 351 | 165 |
| 2023/24 | 1,253 | 17 | 6 | 125 | 25 | 17 | 1,443 | 1,415 | 350 | 19 | 0 | 0 | 1,784 | 188 | 342 | 154 |
| 2024/25 | 1,309 | 17 | 6 | 0 | 25 | 17 | 1,374 | 1,415 | 350 | 19 | 0 | 0 | 1,784 | 196 | 410 | 214 |
| 2025/26 | 1,339 | 17 | 6 | 0 | 0 | 17 | 1,379 | 1,409 | 350 | 19 | 0 | 100 | 1,878 | 201 | 499 | 298 |
| 2026/27 | 1,365 | 17 | 6 | 0 | 0 | 0 | 1,388 | 1,409 | 350 | 19 | 0 | 150 | 1,928 | 205 | 540 | 335 |
| 2027/28 | 1,345 | 0 | 0 | 0 | 0 | 0 | 1,345 | 1,402 | 350 | 19 | 0 | 150 | 1,922 | 202 | 577 | 375 |
| 2028/29 | 1,397 | 0 | 0 | 0 | 0 | 0 | 1,397 | 1,402 | 350 | 19 | 0 | 200 | 1,972 | 210 | 575 | 365 |
| 2029/30 | 1,419 | 0 | 0 | 0 | 0 | 0 | 1,419 | 1,402 | 350 | 19 | 0 | 350 | 2,122 | 213 | 703 | 490 |

(1). Peak Demands shown are non-coincident.
(2). Includes existing net capability to serve OUC and St. Cloud.
(3). Capacity of Solar reflects capacity projected to be available at time of seasonal peak demand, which is assumed to be 0% for winter and 100% of nameplate capacity of battery energy storage.
(4). "Totals" may not add due to rounding.
(5). "Required Reserves" include 15 percent reserve margin on OUC and St. Cloud retail peak demand. OUC is not responsible for providing reserves to Bartow, Winter Park, Mt. Dora, Chattahoochee, or Lakeland. Wholesale sale shown to Lake Worth includes reserves.
(6). "Available Reserves" equals the difference between total available capacity and total peak demand.
(7). Calculated as the difference between "Available Reserves" and "Required Reserves."

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

Table 6-3 Projected Summer Reserve Requirements – Base-Case

| Year | Retail and Wholesale Peak Demand (MW) ¹ | | | | | | | Available Capacity (MW) | | | | | Reserves (MW) | | | Excess/ (Deficit) Capacity to Maintain 15% Reserve Margin (MW) ⁽⁷⁾ |
|------|--|-------------|---------------|----------|---------------|----------------|-------|--------------------------|--------------|-----------------|----------------------|---|----------------------|-------------------------|--------------------------|---|
| | OUC and STC | Mt. Dora | Chattahoochee | Lakeland | Lake Worth | Winter Park | Total | Installed ⁽²⁾ | SEC A PPA | Landfill Gas | Solar ⁽³⁾ | Battery Energy Storage ⁽³⁾ | Total ⁽⁴⁾ | Required ⁽⁵⁾ | Available ⁽⁶⁾ | |
| 2021 | 1,300 | 23 | 8 | 125 | 50 | 17 | 1,523 | 1,378 | 342 | 19 | 63 | 0 | 1,803 | 195 | 279 | 84 |
| 2022 | 1,358 | 23 | 8 | 125 | 50 | 17 | 1,581 | 1,378 | 342 | 19 | 63 | 0 | 1,803 | 204 | 222 | 18 |
| 2023 | 1,387 | 23 | 8 | 75 | 50 | 17 | 1,560 | 1,378 | 342 | 19 | 63 | 0 | 1,803 | 208 | 242 | 34 |
| 2024 | 1,433 | 23 | 8 | 0 | 50 | 17 | 1,531 | 1,378 | 342 | 19 | 137 | 0 | 1,877 | 215 | 345 | 130 |
| 2025 | 1,468 | 23 | 8 | 0 | 50 | 17 | 1,566 | 1,378 | 342 | 19 | 249 | 100 | 2,089 | 220 | 522 | 302 |
| 2026 | 1,490 | 23 | 8 | 0 | 0 | 17 | 1,538 | 1,371 | 342 | 19 | 324 | 150 | 2,206 | 224 | 668 | 444 |
| 2027 | 1,514 | 23 | 8 | 0 | 0 | 0 | 1,545 | 1,365 | 342 | 19 | 398 | 150 | 2,275 | 227 | 729 | 502 |
| 2028 | 1,541 | 0 | 0 | 0 | 0 | 0 | 1,541 | 1,365 | 342 | 19 | 510 | 200 | 2,437 | 231 | 896 | 665 |
| 2029 | 1,567 | 0 | 0 | 0 | 0 | 0 | 1,567 | 1,365 | 342 | 19 | 622 | 200 | 2,549 | 235 | 981 | 746 |
| 2030 | 1,594 | 0 | 0 | 0 | 0 | 0 | 1,594 | 1,365 | 342 | 19 | 771 | 350 | 2,848 | 239 | 1,253 | 1,014 |

- (1). Peak Demands shown are non-coincident.
(2). Includes existing net capability to serve OUC and St. Cloud.
(3). Capacity of Solar reflects capacity projected to be available at time of seasonal peak demand, which is assumed to be 50% of nameplate capacity for summer solar without battery energy storage and 100% of nameplate capacity of battery energy storage.
(4). "Totals" may not add due to rounding.
(5). "Required Reserves" include 15 percent reserve margin on OUC and St. Cloud retail peak demand. OUC is not responsible for providing reserves to Bartow, Winter Park, Mt. Dora, Chattahoochee, or Lakeland. Wholesale sale shown to Lake Worth includes reserves.
(6). "Available Reserves" equals the difference between total available capacity and total peak demand.
(7). Calculated as the difference between "Available Reserves" and "Required Reserves."

7.0 SUPPLY-SIDE ALTERNATIVES

As discussed previously, consideration of OUC's current generating resources (including existing and planned PPAs) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in this Ten-Year Site Plan). As such, no new capacity additions have been evaluated as part of this Ten-Year Site Plan, beyond the solar purchases and battery storage associated with OUC's EIRP and discussed throughout this Ten-Year Site Plan.

8.0 ECONOMIC EVALUATION CRITERIA AND METHODOLOGY

This section presents the economic evaluation criteria and methodology used for OUC's current planning processes.

8.1 Economic Parameters

The economic parameters are summarized below and are presented on an annual basis.

8.1.1 Inflation and Escalation Rates

The general inflation rate, construction cost escalation rate, fixed O&M escalation rate, and nonfuel variable O&M escalation rate are each assumed to be 2.0 percent.

8.1.2 Present Worth Discount Rate

The present worth discount rate is assumed to be 6.5 percent.

8.2 Fuel Price Forecasts

The natural gas and fuel oil price forecasts reflected in this Ten-Year Site Plan were developed based on a combination of the NYMEX forward curve and projections provided by PIRA Energy Group (PIRA). PIRA was founded in 1976 and is an international energy consulting firm specializing in global energy market analysis and intelligence. Among other services, PIRA offers consulting on a broad range of subjects in the international crude oil, petroleum products, natural gas, electricity, coal, biofuels and emissions markets. PIRA's clients include international and national integrated oil and gas companies, independent producers, refiners, marketers, oil and gas pipelines, electric and gas utilities, industrials, trading companies, financial institutions and government agencies.

The coal forecast reflected in this Ten-Year Site Plan was developed based on projections by Energy Ventures Analysis, Inc. (EVA) for use by OUC as well as recent offers from coal suppliers of Illinois Basin coal. EVA is a consulting firm that engages in a variety of projects for private and public sector clients related to energy and environmental issues. In the energy area, much of EVA's work is related to analysis of the electric utility industry and fuel markets, particularly oil, natural gas, and coal. EVA's clients in these areas include coal, oil, and natural gas producers; electric utility and industrial energy consumers; and gas pipelines and railroads. EVA also works for a number of public agencies, such as state regulatory commissions, the US EPA, and the US DOE, as well as interveners in utility rate proceedings, such as consumer counsels and municipalities. Another group of clients include trade and industry associations, such as the Electric Power Research Institute, the Gas Research Institute, and the Center for Energy and Economic Development. EVA has provided testimony to numerous state public utility commissions, including the Florida Public Service Commission. Furthermore, the firm has filed testimony in a number of cases in both state and federal courts, as well as before the Federal Energy Regulatory Commission.

9.0 ANALYSIS AND RESULTS

As discussed previously, consideration of OUC's existing generating resources (including existing and planned PPAs) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in this Ten-Year Site Plan). As such, no new capacity additions are included in this Ten-Year Site Plan.

For informational purposes, OUC utilized PCI GenTrader to obtain the annual production costs associated for various load, fuel, and other sensitivity cases. GenTrader is a computer-based chronological production costing model developed for use in power supply system planning. GenTrader simulates the hour-by-hour operation of a power supply system over a specified planning period. Required inputs include the performance characteristics of generating units, fuel costs, and the system hourly load profile for each year.

The cumulative present worth cost (CPWC) calculations presented in this section account for annual system costs (i.e. fuel and energy, non-fuel variable O&M, and startup costs) for each year of the expansion planning period and discounts each back to 2021 at the present worth discount rate of 6.5 percent. These annual present worth costs are then summed over the 2021 through 2030 period to calculate the total CPWC of the expansion plan being considered.

9.1 CPWC Analyses

9.1.1 Base-Case Analysis

The base-case considers the base load forecast presented in Section 4 and the base fuel price forecasts. The CPWC associated with the base-case analysis is approximately \$1.930 billion.

9.1.2 Sensitivity Analyses

As part of its capacity planning process, OUC considers a number of sensitivity analyses to measure the impact of variations to critical assumptions. Among the numerous sensitivities that OUC may consider in its planning processes are high and low fuel prices, high and low load and energy growth projections, a case in which the differential between natural gas and coal price projections is held constant over time, and a high present worth discount rate case. Of these sensitivities, only the high load and energy growth projection sensitivity would potentially impact the timing of unit additions as compared to the base-case analysis. For informational purposes, the following subsections describe the high and low load and energy growth, the high and low fuel price, the constant differential fuel price, and the high present worth discount rate sensitivities.

9.1.2.1 High Load Forecast Sensitivity

The high load forecast is presented in Section 4.0; as with the base-case load forecast, OUC is anticipated to have sufficient capacity to maintain its 15 percent reserve margin under the high load forecast sensitivity. The CPWC associated with the high load analysis is approximately \$1.945 billion.

9.1.2.2 Low-Load Forecast Sensitivity

The low-load forecast is presented in Section 4.0; as with the base-case load forecast, OUC is anticipated to have sufficient capacity to maintain its 15 percent reserve margin under the low load forecast sensitivity. The CPWC associated with the low-load analysis is approximately \$1.927 billion.

9.1.2.3 High Fuel Price Forecast Sensitivity

OUC's contractual arrangements for coal delivery will mitigate the effects of volatility in coal prices; however, for purposes of this analysis, this factor was not considered. The CPWC associated with the high natural gas and coal price forecast sensitivity is approximately \$2.216 billion.

9.1.2.4 Low Fuel Price Forecast Sensitivity

OUC's contractual arrangements for coal delivery will mitigate the effects of volatility in coal prices; however, for purposes of this analysis, this factor was not considered. The CPWC associated with the low natural gas and coal price forecast sensitivity is approximately \$1.678 billion.

9.1.2.5 Constant Differential Natural Gas and Coal Price Forecast Sensitivity

The constant differential natural gas and coal price forecast sensitivity assumes that differential in price between coal and natural gas projected for 2019 will remain constant through 2028. The CPWC associated with the constant differential natural gas and coal price forecast sensitivity is approximately \$1.943 billion.

9.1.2.6 High Present Worth Discount Rate Sensitivity

The high present worth discount rate sensitivity assumes a 10 percent present worth discount rate instead of the 6.5 percent present worth discount rate used in the other economic analyses discussed in this section. The CPWC associated with the high present worth discount rate sensitivity is approximately \$1.705 billion.

10.0 ENVIRONMENTAL AND LAND USE INFORMATION

As discussed previously, consideration of OUC's current generating resources (including existing and planned PPAs) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in this Ten-Year Site Plan). As such, no new capacity additions are included in this Ten-Year Site Plan. In general, it should be noted that OUC's existing Stanton Energy Center and Indian River sites may accommodate future generating unit additions.

11.0 CONCLUSIONS

As discussed previously, consideration of OUC's current generating resources (including existing and planned PPAs) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in this Ten-Year Site Plan). As such, no new capacity additions are included in this Ten-Year Site Plan, beyond the solar purchases and energy storage associated with OUC's EIRP.

In 2020, OUC completed a comprehensive Electric Integrated Resource Plan to guide OUC through the next 30 years. Results of the EIRP have been discussed throughout this Ten-Year Site Plan; relevant highlights include:

- OUC anticipates entering into PPAs for approximately 1,267 MWac of solar (nameplate) and 350 MW of energy storage by 2030.
- OUC anticipates converting the two existing Stanton coal units to operate on 100 percent natural gas with the first unit converted no later than 2025 and the second unit converted no later than 2027.
- OUC has pledged to achieve Net Zero carbon emissions by 2050, with interim targets of 50% carbon emissions reductions by 2030 and 75% carbon emissions reductions by 2040, both as compared to 2005 levels.

12.0 TEN-YEAR SITE PLAN SCHEDULES

This section presents the schedules required by the Ten-Year Site Plan rules for the FPSC. The information contained within the FPSC Schedules is representative of the combined OUC and City of St. Cloud systems, consistent with all sections of the 2021 OUC Ten-Year Site Plan.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 1
Existing Generating Facilities
As of December 31, 2020**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) |
|--------------------------|----------|-----------|-----------|----------|-----|----------------|-----|----------------|----------------------------------|--------------------------------|---------------------------------------|----------------------|----------------------|
| Plant Name | Unit No. | Location | Unit Type | Fuel Pri | Alt | Fuel Transport | | Alt. Fuel Days | Commercial In-Service Month/Year | Expected Retirement Month/Year | Gen. Max. Nameplate KW ⁽¹⁾ | Net Capability | |
| | | | | | | Pri | Alt | Use | | | | Summer MW | Winter MW |
| Indian River | A | Brevard | GT | NG | DFO | PL | TK | 0.2 | 06/89 | Unknown | 41,400 | 15.6 ⁽²⁾ | 18.1 ⁽²⁾ |
| Indian River | B | Brevard | GT | NG | DFO | PL | TK | 0.2 | 07/89 | Unknown | 41,400 | 15.6 ⁽²⁾ | 18.1 ⁽²⁾ |
| Indian River | C | Brevard | GT | NG | DFO | PL | TK | 0.2 | 08/92 | Unknown | 130,000 | 83.0 ⁽³⁾ | 88.5 ⁽³⁾ |
| Indian River | D | Brevard | GT | NG | DFO | PL | TK | 0.2 | 10/92 | Unknown | 130,000 | 83.0 ⁽³⁾ | 88.5 ⁽³⁾ |
| Stanton Energy Center | 1 | Orange | ST | BIT | NA | RR | UN | UN | 07/87 | Unknown | 464,500 | 305.1 ⁽⁴⁾ | 305.1 ⁽⁴⁾ |
| Stanton Energy Center | 2 | Orange | ST | BIT | NA | RR | UN | UN | 06/96 | Unknown | 464,500 | 339.8 ⁽⁵⁾ | 339.8 ⁽⁵⁾ |
| Stanton Energy Center | A | Orange | CC | NG | DFO | PL | TK | 3 | 10/01 | Unknown | | 184.2 ⁽⁶⁾ | 188.4 ⁽⁶⁾ |
| Stanton Energy Center | B | Orange | CC | NG | DFO | PL | TK | 3 | 02/10 | Unknown | 333,000 | 292.0 | 307.0 |
| McIntosh | 3 | Polk | ST | BIT | NA | REF | UN | UN | 09/82 | 03/2021 | | 133.0 ⁽⁷⁾ | 136.0 ⁽⁷⁾ |
| St. Lucie ⁽⁸⁾ | 2 | St. Lucie | ST | NUC | NA | TK | UN | UN | 08/83 | Unknown | | 60.0 | 62.0 |

NOTES:

- ⁽¹⁾ Nameplate ratings are reported for units which OUC maintains majority ownership. Values reported are for the entire unit (not just OUC's ownership share)
- ⁽²⁾ Reflects an OUC ownership share of 48.8 percent.
- ⁽³⁾ Reflects an OUC ownership share of 79.0 percent.
- ⁽⁴⁾ Reflects an OUC ownership share of 68.6 percent.
- ⁽⁵⁾ Reflects an OUC ownership share of 71.6 percent and St. Cloud entitlement of 3.4 percent.
- ⁽⁶⁾ Reflects an OUC ownership share of 28.0 percent.
- ⁽⁷⁾ Reflects an OUC ownership share of 40.0 percent.
- ⁽⁸⁾ Capacity from Crystal River Unit No. 3 is not included as available capacity given it has not operated since summer of 2009 and is retired.
- ⁽⁹⁾ OUC owns approximately 6.1 percent of St. Lucie Unit No. 2. Reliability exchange divides 50 percent power from Unit No. 1 and 50 percent power from Unit No. 2.

**Schedule 2.1
History and Forecast of Energy Consumption and
Number of Customers by Customer Class**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
|------------------|------------|-----------------------|-------|---|--|-----|--|--|
| Year | Population | Members per Household | GWH | Rural and Residential Average No. of Customers | Average KWH Consumption Per Customer | GWH | Commercial Average No. of Customers | Average KWH Consumption Per Customer |
| HISTORY: | | | | | | | | |
| 2011 | 458,940 | 2.55 | 2,223 | 180,072 | 12,347 | 311 | 22,138 | 14,026 |
| 2012 | 466,940 | 2.56 | 2,140 | 182,570 | 11,723 | 319 | 23,198 | 13,730 |
| 2013 | 476,916 | 2.56 | 2,153 | 186,455 | 11,549 | 345 | 22,585 | 15,254 |
| 2014 | 485,016 | 2.55 | 2,264 | 190,279 | 11,899 | 379 | 23,376 | 16,230 |
| 2015 | 496,659 | 2.54 | 2,430 | 195,606 | 12,423 | 393 | 23,705 | 16,579 |
| 2016 | 514,813 | 2.56 | 2,491 | 201,424 | 12,369 | 401 | 23,991 | 16,719 |
| 2017 | 576,536 | 2.79 | 2,481 | 206,959 | 11,987 | 424 | 24,323 | 17,440 |
| 2018 | 577,895 | 2.74 | 2,576 | 210,899 | 12,212 | 475 | 25,020 | 18,966 |
| 2019 | 615,376 | 2.85 | 2,599 | 216,113 | 12,026 | 474 | 25,751 | 18,424 |
| 2021 | 634,982 | 2.86 | 2,750 | 221,756 | 12,402 | 459 | 26,391 | 17,408 |
| FORECAST: | | | | | | | | |
| 2021 | 640,054 | 2.82 | 2,606 | 226,891 | 11,484 | 453 | 26,669 | 17,004 |
| 2022 | 648,432 | 2.80 | 2,645 | 231,832 | 11,410 | 476 | 26,947 | 17,673 |
| 2023 | 659,949 | 2.79 | 2,685 | 236,592 | 11,349 | 487 | 27,295 | 17,857 |
| 2024 | 672,065 | 2.79 | 2,732 | 241,311 | 11,320 | 494 | 27,644 | 17,856 |
| 2025 | 684,293 | 2.78 | 2,782 | 246,040 | 11,307 | 500 | 28,001 | 17,869 |
| 2026 | 696,561 | 2.78 | 2,834 | 250,764 | 11,303 | 508 | 28,370 | 17,900 |
| 2027 | 709,050 | 2.78 | 2,891 | 255,485 | 11,318 | 516 | 28,748 | 17,942 |
| 2028 | 721,648 | 2.77 | 2,956 | 260,219 | 11,361 | 524 | 29,131 | 17,991 |
| 2029 | 734,265 | 2.77 | 3,027 | 264,933 | 11,426 | 533 | 29,512 | 18,045 |
| 2030 | 746,509 | 2.77 | 3,087 | 269,634 | 11,450 | 541 | 29,894 | 18,097 |

Notes:
Represents total of OUC and St. Cloud.

**Schedule 2.2
History and Forecast of Energy Consumption and
Number of Customers by Customer Class**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) |
|------------------|-------|--|--|----------------------------------|--|--|--|
| Year | GWH | Industrial Average No. of Customers | Average KWH Consumption Per Customer | Railroads and Railways GWH | Street & Highway Lighting GWH | Other Sales to Public Authorities GWH | Total Sales to Ultimate Consumers GWH |
| HISTORY: | | | | | | | |
| 2011 | 3,422 | 7,428 | 460,737 | 0 | 34 | 30 | 6,021 |
| 2012 | 3,392 | 7,558 | 448,853 | 0 | 35 | 30 | 5,916 |
| 2013 | 3,467 | 5,718 | 606,442 | 0 | 29 | 30 | 6,025 |
| 2014 | 3,489 | 5,618 | 621,007 | 0 | 30 | 29 | 6,191 |
| 2015 | 3,514 | 5,793 | 606,594 | 0 | 61 | 139 | 6,537 |
| 2016 | 3,506 | 5,811 | 603,333 | 0 | 61 | 142 | 6,601 |
| 2017 | 3,480 | 5,839 | 595,929 | 0 | 59 | 124 | 6,568 |
| 2018 | 3,513 | 5,709 | 615,262 | 0 | 61 | 146 | 6,769 |
| 2019 | 3,544 | 5,579 | 635,318 | 0 | 61 | 145 | 6,823 |
| 2020 | 3,336 | 5,301 | 629,406 | 0 | 62 | 131 | 6,740 |
| FORECAST: | | | | | | | |
| 2021 | 3,327 | 5,207 | 638,885 | 0 | 62 | 148 | 6,596 |
| 2022 | 3,489 | 5,247 | 665,016 | 0 | 63 | 159 | 6,832 |
| 2023 | 3,579 | 5,302 | 675,118 | 0 | 63 | 176 | 6,992 |
| 2024 | 3,664 | 5,360 | 683,542 | 0 | 64 | 236 | 7,189 |
| 2025 | 3,763 | 5,419 | 694,330 | 0 | 65 | 238 | 7,347 |
| 2026 | 3,808 | 5,481 | 694,779 | 0 | 65 | 239 | 7,455 |
| 2027 | 3,857 | 5,544 | 695,669 | 0 | 66 | 240 | 7,570 |
| 2028 | 3,907 | 5,607 | 696,755 | 0 | 67 | 242 | 7,696 |
| 2029 | 3,955 | 5,670 | 697,570 | 0 | 67 | 243 | 7,825 |
| 2030 | 4,010 | 5,735 | 699,261 | 0 | 68 | 245 | 7,951 |

Notes:
Represents total of OUC and St. Cloud.

**Schedule 2.3
History and Forecast of Energy Consumption and
Number of Customers by Customer Class**

| (1) | (2) | (3) | (4) | (5) | (6) |
|------------------|----------------------------|--------------------------------|-------------------------------|-------------------------------------|------------------------------|
| Year | Sales for Resale GWH | Utility Use & Losses GWH | Net Energy for Load GWH | Other Customers (Average No.) | Total No. of Customers |
| HISTORY: | | | | | |
| 2011 | 768 | 188 | 6,977 | 0 | 209,638 |
| 2012 | 764 | 346 | 7,026 | 0 | 213,325 |
| 2013 | 769 | 272 | 7,065 | 0 | 214,758 |
| 2014 | 1,000 | 332 | 7,523 | 0 | 219,272 |
| 2015 | 1,317 | 268 | 8,122 | 0 | 225,104 |
| 2016 | 1,100 | 278 | 7,979 | 0 | 231,226 |
| 2017 | 1,032 | 302 | 7,902 | 0 | 237,121 |
| 2018 | 1,040 | 189 | 7,998 | 0 | 241,628 |
| 2019 | 644 | 295 | 7,762 | 0 | 247,443 |
| 2020 | 665 | 220 | 7,625 | 0 | 253,448 |
| FORECAST: | | | | | |
| 2021 | 500 | 187 | 7,283 | 0 | 258,767 |
| 2022 | 511 | 197 | 7,541 | 0 | 264,026 |
| 2023 | 504 | 205 | 7,701 | 0 | 269,189 |
| 2024 | 465 | 213 | 7,867 | 0 | 274,315 |
| 2025 | 480 | 220 | 8,047 | 0 | 279,460 |
| 2026 | 243 | 225 | 7,922 | 0 | 284,615 |
| 2027 | 147 | 230 | 7,947 | 0 | 289,777 |
| 2028 | 0 | 236 | 7,932 | 0 | 294,957 |
| 2029 | 0 | 242 | 8,067 | 0 | 300,115 |
| 2030 | 0 | 248 | 8,198 | 0 | 305,263 |

Notes:

Represents total of OUC and St. Cloud.

2010 - 2012 "Sales for Resale" represent sales to City of Vero Beach.

2013-2020 "Sales for Resale" represents aggregation of sales to City of Vero Beach, City of Winter Park, City of Lake Worth, City of Bartow, and Florida Power & Light.

Forecast "Sales for Resale" include aggregated projected sales to City of Winter Park, City of Lake Worth Beach, City Mt. Dora, City of Chattahoochee, and

Lakeland Electric as summarized in Section 2 of OUC's 2021 Ten-Year Site Plan.

"Net Energy for Load" may not match other Schedules due to rounding.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 3.1
History and Forecast of Summer Peak Demand
Base Case**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
|------------------|-------|-----------|--------|---------------|-----------------------------|--------------------------|----------------------------|-------------------------|-----------------|
| Year | Total | Wholesale | Retail | Interruptible | Residential Load Management | Residential Conservation | Comm./Ind. Load Management | Comm./Ind. Conservation | Net Firm Demand |
| HISTORY: | | | | | | | | | |
| 2011 | 1,371 | 164 | 1,205 | 0 | 0 | 1.0 | 0.0 | 0.6 | 1,369 |
| 2012 | 1,381 | 165 | 1,214 | 0 | 0 | 0.6 | 0.0 | 1.7 | 1,379 |
| 2013 | 1,413 | 157 | 1,256 | 0 | 0 | 0.7 | 0.0 | 0.9 | 1,411 |
| 2014 | 1,500 | 203 | 1,297 | 0 | 0 | 0.6 | 0.0 | 0.2 | 1,499 |
| 2015 | 1,531 | 206 | 1,325 | 0 | 0 | 0.4 | 0.0 | 2.2 | 1,528 |
| 2016 | 1,620 | 252 | 1,368 | 0 | 0 | 0.5 | 0.0 | 2.5 | 1,617 |
| 2017 | 1,638 | 255 | 1,383 | 0 | 0 | 0.4 | 0.0 | 5.0 | 1,633 |
| 2018 | 1,541 | 207 | 1,334 | 0 | 0 | 0.4 | 0.0 | 3.7 | 1,537 |
| 2019 | 1,634 | 199 | 1,431 | 0 | 0 | 0.5 | 0.0 | 3.4 | 1,630 |
| 2020 | 1,590 | 224 | 1,362 | 0 | 0 | 0.8 | 0.0 | 2.3 | 1,586 |
| FORECAST: | | | | | | | | | |
| 2021 | 1,524 | 223 | 1,300 | 0 | 0 | 0.2 | 0 | 0.4 | 1,523 |
| 2022 | 1,582 | 223 | 1,358 | 0 | 0 | 0.4 | 0 | 0.8 | 1,581 |
| 2023 | 1,562 | 173 | 1,387 | 0 | 0 | 0.6 | 0 | 1.2 | 1,560 |
| 2024 | 1,533 | 98 | 1,433 | 0 | 0 | 0.8 | 0 | 1.5 | 1,531 |
| 2025 | 1,569 | 98 | 1,468 | 0 | 0 | 0.9 | 0 | 1.9 | 1,566 |
| 2026 | 1,542 | 48 | 1,490 | 0 | 0 | 1.1 | 0 | 2.2 | 1,538 |
| 2027 | 1,549 | 31 | 1,514 | 0 | 0 | 1.2 | 0 | 2.6 | 1,545 |
| 2028 | 1,545 | 0 | 1,541 | 0 | 0 | 1.4 | 0 | 3.0 | 1,541 |
| 2029 | 1,572 | 0 | 1,567 | 0 | 0 | 1.6 | 0 | 3.3 | 1,567 |
| 2030 | 1,600 | 0 | 1,594 | 0 | 0 | 1.7 | 0 | 3.7 | 1,594 |

Notes:

Represents total of OUC and St. Cloud. Peak demands may not match other schedules due to non-coincidence of OUC and St. Cloud peaks and/or rounding.

Historical "Residential Conservation" and "Comm/Ind. Conservation" represent annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

Forecast "Residential Conservation" and "Comm/Ind. Conservation" represent cumulative annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

2010 - 2012 "Wholesale" represent sales to City of Vero Beach.

2013-2020 "Wholesale" represents sales to City of Vero Beach, City of Winter Park, City of Lake Worth, and City of Bartow.

Forecast "Wholesale" includes aggregated projected sales to City of Winter Park, City of Lake Worth Beach, City Mt. Dora, City of Chattahoochee, and Lakeland Electric as summarized in Section 2 of OUC's 2021

Forecast "Net Firm Demand" may not exactly match up with peak demands presented in the 2021 OUC Ten-Year Site Plan due to coincidence and rounding.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 3.2
History and Forecast of Winter Peak Demand
Base Case**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
|------------------|-------|-----------|--------|---------------|-----------------------------|--------------------------|----------------------------|-------------------------|-----------------|
| Year | Total | Wholesale | Retail | Interruptible | Residential Load Management | Residential Conservation | Comm./Ind. Load Management | Comm./Ind. Conservation | Net Firm Demand |
| HISTORY: | | | | | | | | | |
| 2010/11 | 1,323 | 174 | 1,147 | 0 | 0 | 0.8 | 0.0 | 0.6 | 1,321 |
| 2011/12 | 1,216 | 182 | 1,032 | 0 | 0 | 0.5 | 0.0 | 1.8 | 1,214 |
| 2012/13 | 1,183 | 155 | 1,028 | 0 | 0 | 0.5 | 0.0 | 0.9 | 1,182 |
| 2013/14 | 1,275 | 201 | 1,074 | 0 | 0 | 0.4 | 0.0 | 0.2 | 1,275 |
| 2014/15 | 1,374 | 207 | 1,166 | 0 | 0 | 0.4 | 0.0 | 0.7 | 1,373 |
| 2015/16 | 1,320 | 243 | 1,077 | 0 | 0 | 0.4 | 0.0 | 1.3 | 1,319 |
| 2016/17 | 1,194 | 210 | 984 | 0 | 0 | 0.3 | 0.0 | 4.4 | 1,189 |
| 2017/18 | 1,410 | 182 | 1,228 | 0 | 0 | 0.3 | 0.0 | 4.7 | 1,405 |
| 2018/19 | 1,134 | 76 | 1,055 | 0 | 0 | 0.3 | 0.0 | 3.5 | 1,131 |
| 2019/20 | 1,160 | 67 | 1,090 | 0 | 0 | 0.8 | 0.0 | 2.0 | 1,157 |
| FORECAST: | | | | | | | | | |
| 2020/21 | 1,248 | 65 | 1,182 | 0 | 0 | 0.2 | 0 | 0.8 | 1,247 |
| 2021/22 | 1,391 | 190 | 1,199 | 0 | 0 | 0.4 | 0 | 1.6 | 1,389 |
| 2022/23 | 1,436 | 190 | 1,243 | 0 | 0 | 0.6 | 0 | 2.3 | 1,433 |
| 2023/24 | 1,446 | 190 | 1,253 | 0 | 0 | 0.8 | 0 | 3.1 | 1,443 |
| 2024/25 | 1,379 | 65 | 1,309 | 0 | 0 | 0.9 | 0 | 3.8 | 1,374 |
| 2025/26 | 1,384 | 40 | 1,339 | 0 | 0 | 1.1 | 0 | 4.5 | 1,379 |
| 2026/27 | 1,394 | 23 | 1,365 | 0 | 0 | 1.2 | 0 | 5.2 | 1,388 |
| 2027/28 | 1,352 | 0 | 1,345 | 0 | 0 | 1.4 | 0 | 5.9 | 1,345 |
| 2028/29 | 1,405 | 0 | 1,397 | 0 | 0 | 1.6 | 0 | 6.6 | 1,397 |
| 2029/30 | 1,428 | 0 | 1,419 | 0 | 0 | 1.7 | 0 | 7.3 | 1,419 |

Notes:

Represents total of OUC and St. Cloud. Peak demands may not match other schedules due to non-coincidence of OUC and St. Cloud peaks and/or rounding.

Historical "Residential Conservation" and "Comm/Ind. Conservation" represent annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

Forecast "Residential Conservation" and "Comm/Ind. Conservation" represent cumulative annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

2010 - 2012 "Wholesale" represent sales to City of Vero Beach.

2013-2020 "Wholesale" represents sales to City of Vero Beach, City of Winter Park, City of Lake Worth, and City of Bartow.

Forecast "Wholesale" includes aggregated projected sales to City of Winter Park, City of Lake Worth Beach, City Mt. Dora, City of Chattahoochee, and Lakeland Electric as summarized in Section 2 of OUC's 2021

Forecast "Net Firm Demand" may not exactly match up with peak demands presented in the 2021 OUC Ten-Year Site Plan due to coincidence and rounding.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 3.3
History and Forecast of Annual Net Energy for Load - GWH
Base Case**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
|------------------|-------|--------------------------|-------------------------|--------|-----------|----------------------|---------------------|---------------|
| Year | Total | Residential Conservation | Comm./Ind. Conservation | Retail | Wholesale | Utility Use & Losses | Net Energy for Load | Load Factor % |
| HISTORY: | | | | | | | | |
| 2011 | 6,983 | 2.7 | 3 | 6,021 | 768 | 188 | 6,977 | 58.2% |
| 2012 | 7,074 | 1.9 | 7.3 | 5,916 | 764 | 346 | 7,026 | 58.2% |
| 2013 | 7,072 | 1.9 | 4.5 | 6,025 | 769 | 272 | 7,065 | 57.2% |
| 2014 | 7,526 | 1.8 | 1.0 | 6,191 | 1,000 | 332 | 7,523 | 57.3% |
| 2015 | 8,136 | 0.8 | 13.4 | 6,537 | 1,317 | 268 | 8,122 | 57.3% |
| 2016 | 7,992 | 1.2 | 12.3 | 6,601 | 1,100 | 278 | 7,979 | 55.4% |
| 2017 | 7,934 | 0.8 | 31.0 | 6,568 | 1,032 | 302 | 7,902 | 55.3% |
| 2018 | 8,033 | 0.8 | 34.7 | 6,769 | 1,040 | 189 | 7,998 | 59.4% |
| 2019 | 7,778 | 1.0 | 14.3 | 6,823 | 644 | 295 | 7,762 | 54.4% |
| 2020 | 7,635 | 1.6 | 9.0 | 6,740 | 665 | 220 | 7,625 | 54.9% |
| FORECAST: | | | | | | | | |
| 2021 | 7,285 | 0.8 | 0.9 | 6,596 | 500 | 187 | 7,283 | 54.6% |
| 2022 | 7,544 | 1.5 | 1.7 | 6,832 | 511 | 197 | 7,541 | 54.5% |
| 2023 | 7,705 | 2.2 | 2.5 | 6,992 | 504 | 205 | 7,701 | 56.3% |
| 2024 | 7,873 | 2.8 | 3.3 | 7,189 | 465 | 213 | 7,867 | 58.7% |
| 2025 | 8,054 | 3.3 | 4.1 | 7,347 | 480 | 220 | 8,047 | 58.6% |
| 2026 | 7,931 | 3.9 | 4.9 | 7,455 | 243 | 225 | 7,922 | 58.8% |
| 2027 | 7,958 | 4.5 | 5.7 | 7,570 | 147 | 230 | 7,947 | 58.7% |
| 2028 | 7,943 | 5.0 | 6.5 | 7,696 | 0 | 236 | 7,932 | 58.8% |
| 2029 | 8,080 | 5.6 | 7.3 | 7,825 | 0 | 242 | 8,067 | 58.8% |
| 2030 | 8,213 | 6.2 | 8.1 | 7,951 | 0 | 248 | 8,198 | 58.7% |

Notes:

Represents total of OUC and St. Cloud. Peak demands may not match other schedules due to non-coincidence of OUC and St. Cloud peaks and/or rounding.

Historical "Residential Conservation" and "Comm./Ind. Conservation" represent annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

Forecast "Residential Conservation" and "Comm./Ind. Conservation" represent cumulative annual demand reductions associated with new participants in OUC's DSM programs described in Section 5 of OUC's 2021 Ten-Year Site Plan.

2010 - 2012 "Wholesale" represent sales to City of Vero Beach.

2013-2020 "Wholesale" represents sales to City of Vero Beach, City of Winter Park, City of Lake Worth, and City of Bartow.

Forecast "Wholesale" includes aggregated projected sales to City of Winter Park, City of Lake Worth Beach, City Mt. Dora, City of Chattahoochee, and Lakeland Electric as summarized in Section 2 of OUC's 2021 Ten-Year Site Plan.

Forecast "Net Energy for Load" may not exactly match up with peak demands presented in the 2021 OUC Ten-Year Site Plan due to rounding.

**Schedule 4
Previous Year and 2-Year Forecast of Retail Peak Demand and Net Energy for Load by Month**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) |
|-----------|----------------------------------|------------|------------------------------------|------------|------------------------------------|------------|
| Month | 2020 Actual Peak Demand MW | NEL GWH | 2021 Forecast Peak Demand MW | NEL GWH | 2022 Forecast Peak Demand MW | NEL GWH |
| January | 1,114 | 516 | 1,182 | 519 | 1,172 | 538 |
| February | 1,041 | 489 | 1,145 | 455 | 1,187 | 471 |
| March | 1,138 | 554 | 926 | 489 | 967 | 509 |
| April | 1,184 | 524 | 1,032 | 521 | 1,078 | 541 |
| May | 1,212 | 569 | 1,198 | 592 | 1,249 | 616 |
| June | 1,357 | 643 | 1,285 | 635 | 1,340 | 658 |
| July | 1,343 | 687 | 1,292 | 674 | 1,347 | 700 |
| August | 1,354 | 697 | 1,295 | 695 | 1,351 | 720 |
| September | 1,354 | 639 | 1,291 | 641 | 1,348 | 661 |
| October | 1,232 | 620 | 1,167 | 572 | 1,217 | 589 |
| November | 991 | 513 | 1,058 | 488 | 1,104 | 507 |
| December | 926 | 507 | 994 | 502 | 1,035 | 520 |

Notes:
 Represents the total of OUC and St. Cloud retail peak demands and net energy for load. Wholesale sales are not included.
 Peak demands may not match other schedules due to non-coincidence of OUC and St. Cloud peaks and/or rounding. NEL may not match other schedules due to rounding.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 5
Fuel Requirements**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|------|-------------------|-------|--------------|----------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Fuel Requirements | | Units | Actual 2019 | Actual 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| (1) | Nuclear | | Trillion BTU | 4 | 8 | 6 | 7 | 7 | 6 | 6 | 6 | 6 | 6 | 6 | 6 |
| (2) | Coal | | 1000 Ton | 1,242 | 1,430 | 1,440 | 1,501 | 1,512 | 1,627 | 1,078 | 874 | 748 | 0 | 0 | 0 |
| (3) | Residual | Total | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (4) | | Steam | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CT | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | Other | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | Distillate | Total | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (9) | | Steam | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (10) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CT | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (12) | | Other | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (13) | Natural Gas | Total | 1000 MCF | 23,313 | 31,333 | 19,547 | 20,484 | 20,373 | 16,374 | 29,895 | 32,540 | 35,694 | 49,789 | 47,496 | 48,538 |
| (14) | | Steam | 1000 MCF | 2,074 | 3,637 | 30 | 59 | 5 | 5 | 9,325 | 10,030 | 13,849 | 21,221 | 7,476 | 7,483 |
| (15) | | CC | 1000 MCF | 20,981 | 27,466 | 18,644 | 19,297 | 19,973 | 16,325 | 20,474 | 22,415 | 21,730 | 28,414 | 39,619 | 40,716 |
| (16) | | CT | 1000 MCF | 258 | 229 | 874 | 1,128 | 395 | 44 | 96 | 95 | 115 | 154 | 401 | 339 |
| (17) | Other (Specify) | | Trillion BTU | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:
Represents fuel required to serve OUC and St. Cloud, and sales to wholesale customers.
Natural gas CC includes purchases from Stanton A PPA

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 6.1
Energy Sources**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|------|-------------------------------|--------------|-------|----------------|----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Energy Sources | | Units | Actual 2019 | Actual 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| (1) | Firm Inter-Region Interchange | | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (2) | Nuclear | | GWH | 449 | 500 | 550 | 560 | 592 | 591 | 571 | 588 | 588 | 563 | 583 | 587 |
| (3) | Coal | | GWH | 3,614 | 2,778 | 3,520 | 3,641 | 3,681 | 3,986 | 2,686 | 2,161 | 1,863 | 0 | 0 | 0 |
| (4) | Residual | Total | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | Steam | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CC | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | CT | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | | Other | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (9) | Distillate | Total | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (10) | | Steam | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CC | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (12) | | CT | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (13) | | Other | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (14) | Natural Gas | Total | GWH | 3,554 | 4,090 | 2,674 | 2,796 | 2,840 | 2,283 | 3,773 | 4,144 | 4,462 | 6,332 | 6,455 | 6,584 |
| (15) | | Steam | GWH | 218 | 328 | 2 | 5 | 0 | 0 | 893 | 974 | 1,380 | 2,287 | 796 | 788 |
| (16) | | CC | GWH | 3,319 | 3,747 | 2,613 | 2,713 | 2,815 | 2,280 | 2,874 | 3,164 | 3,074 | 4,035 | 5,634 | 5,775 |
| (17) | | CT | GWH | 17 | 15 | 59 | 78 | 25 | 3 | 6 | 6 | 7 | 10 | 25 | 21 |
| (18) | NUG | | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (19) | Renewables | Total | GWH | 145 | 258 | 539 | 544 | 587 | 1,008 | 1,016 | 1,029 | 1,035 | 1,037 | 1,029 | 1,027 |
| (20) | | Biofuels | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (21) | | Biomass | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (22) | | Hydro | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (23) | | Landfill Gas | GWH | 123 | 126 | 199 | 203 | 216 | 230 | 242 | 256 | 264 | 265 | 264 | 264 |
| (24) | | MSW | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (25) | | Solar | GWH | 22 | 131 | 340 | 341 | 371 | 778 | 774 | 773 | 771 | 772 | 765 | 763 |
| (26) | | Wind | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (27) | | Other | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (28) | Other (Specify) | | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (29) | Net Energy for Load | | GWH | 7,762 | 7,625 | 7,283 | 7,541 | 7,701 | 7,867 | 8,047 | 7,922 | 7,947 | 7,932 | 8,067 | 8,198 |

Notes:
 Represents GWh required to serve OUC and St. Cloud, and sales to wholesale customers.
 Total Net Energy for Load may not correspond to other Schedules due to rounding.
 Natural gas CC includes purchases from Stanton A PPA

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 6.2
Energy Sources**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
|------|-------------------------------|--------------|-------|----------------|----------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | Energy Sources | | Units | Actual 2019 | Actual 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| (1) | Firm Inter-Region Interchange | | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (2) | Nuclear | | % | 5.78% | 6.55% | 7.55% | 7.43% | 7.69% | 7.51% | 7.10% | 7.42% | 7.40% | 7.10% | 7.23% | 7.16% |
| (3) | Coal | | % | 46.56% | 36.43% | 48.33% | 48.29% | 47.80% | 50.66% | 33.39% | 27.28% | 23.44% | 0.00% | 0.00% | 0.00% |
| (4) | Residual | Total | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (5) | | Steam | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (6) | | CC | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (7) | | CT | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (8) | | Other | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (9) | Distillate | Total | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (10) | | Steam | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (11) | | CC | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (12) | | CT | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (13) | | Other | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (14) | Natural Gas | Total | % | 45.79% | 53.64% | 36.72% | 37.07% | 36.88% | 29.02% | 46.89% | 52.31% | 56.14% | 79.83% | 80.02% | 80.31% |
| (15) | | Steam | % | 2.81% | 4.30% | 0.03% | 0.06% | 0.01% | 0.00% | 11.10% | 12.30% | 17.36% | 28.84% | 9.87% | 9.62% |
| (16) | | CC | % | 42.76% | 49.14% | 35.87% | 35.97% | 36.55% | 28.98% | 35.72% | 39.94% | 38.68% | 50.87% | 69.84% | 70.44% |
| (17) | | CT | % | 0.22% | 0.19% | 0.81% | 1.04% | 0.33% | 0.03% | 0.07% | 0.08% | 0.09% | 0.12% | 0.31% | 0.26% |
| (18) | NUG | | % | | | | | | | | | | | | |
| (19) | Renewables | Total | % | 1.87% | 3.38% | 7.40% | 7.21% | 7.62% | 12.81% | 12.63% | 12.99% | 13.02% | 13.07% | 12.76% | 12.53% |
| (20) | | Biofuels | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (21) | | Biomass | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (22) | | Hydro | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (23) | | Landfill Gas | % | 1.58% | 1.66% | 2.73% | 2.69% | 2.81% | 2.92% | 3.01% | 3.23% | 3.32% | 3.34% | 3.27% | 3.22% |
| (24) | | MSW | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (25) | | Solar | % | 0.28% | 1.72% | 4.67% | 4.52% | 4.82% | 9.89% | 9.62% | 9.76% | 9.70% | 9.73% | 9.48% | 9.31% |
| (26) | | Wind | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (27) | | Other | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (28) | Other (Specify) | | % | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| (29) | Net Energy for Load | | % | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% |

Notes:

Represents GWh required to serve OUC and St. Cloud, and sales to wholesale customers.
Natural gas CC includes purchases from Stanton A PPA

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 7.1
Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) |
|------------------|--------------------------------|----------------------------|----------------------------|----------|--------------------------------|--------------------------------------|---|-----------|-----------------------------|--|-----------|
| Year | Total Installed Capacity MW | Firm Capacity Import MW | Firm Capacity Export MW | QF MW | Total Capacity Available MW | System Firm Summer Peak Demand MW | Reserve Margin before Maintenance MW | % of Peak | Scheduled Maintenance MW | Reserve Margin after Maintenance MW | % of Peak |
| FORECAST: | | | | | | | | | | | |
| 2021 | 1,378 | 424 | 0 | 0 | 1,803 | 1,523 | 279 | 21% | 0 | 279 | 21% |
| 2022 | 1,378 | 424 | 0 | 0 | 1,803 | 1,581 | 222 | 16% | 0 | 222 | 16% |
| 2023 | 1,378 | 424 | 0 | 0 | 1,803 | 1,560 | 242 | 17% | 0 | 242 | 17% |
| 2024 | 1,378 | 498 | 0 | 0 | 1,877 | 1,531 | 345 | 24% | 0 | 345 | 24% |
| 2025 | 1,378 | 710 | 0 | 0 | 2,089 | 1,566 | 522 | 36% | 0 | 522 | 36% |
| 2026 | 1,371 | 835 | 0 | 0 | 2,206 | 1,538 | 668 | 45% | 0 | 668 | 45% |
| 2027 | 1,365 | 909 | 0 | 0 | 2,275 | 1,545 | 729 | 48% | 0 | 729 | 48% |
| 2028 | 1,365 | 1,071 | 0 | 0 | 2,437 | 1,541 | 896 | 58% | 0 | 896 | 58% |
| 2029 | 1,365 | 1,183 | 0 | 0 | 2,549 | 1,567 | 981 | 63% | 0 | 981 | 63% |
| 2030 | 1,365 | 1,482 | 0 | 0 | 2,848 | 1,594 | 1,253 | 79% | 0 | 1,253 | 79% |

Notes:

"Firm Capacity Import" includes OUC's existing and future power purchase agreements, including renewables.

"System Firm Summer Peak Demand" includes OUC and St. Cloud peak demand, as well as OUC's wholesale power sales.

"Reserve Margin (MW)" calculated as "Total Available Capacity" minus "System Firm Summer Peak Demand."

"Reserve Margin (% of Peak)" calculated as "Reserve Margin (MW)" divided by "System Firm Summer Peak Demand" after adjusting for sales to Lake Worth, Winter Park, Mt. Dora, Chatahoochee, and Lakeland. OUC's agreement with Lake Worth already includes reserve calculations and OUC is not responsible for providing reserves to Winter Park, Mt. Dora, Chatahoochee, or Lakeland.

"Scheduled Maintenance (MW)" is zero, as no units are scheduled for maintenance during peak periods.

Forecast "System Firm Summer Peak Demand" may not exactly match up with peak demands presented in the 2021 OUC Ten-Year Site Plan due to coincidence and rounding.

**ORLANDO UTILITIES COMMISSION
2021 TEN-YEAR SITE PLAN**

**Schedule 7.2
Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) |
|------------------|--------------------------------|----------------------------|----------------------------|----------|--------------------------------|--------------------------------------|---|-----------|-----------------------------|--|-----------|
| Year | Total Installed Capacity MW | Firm Capacity Import MW | Firm Capacity Export MW | QF MW | Total Capacity Available MW | System Firm Winter Peak Demand MW | Reserve Margin before Maintenance MW | % of Peak | Scheduled Maintenance MW | Reserve Margin after Maintenance MW | % of Peak |
| FORECAST: | | | | | | | | | | | |
| 2020/21 | 1,551 | 369 | 0 | 0 | 1,920 | 1,247 | 673 | 57% | 0 | 673 | 57% |
| 2021/22 | 1,415 | 369 | 0 | 0 | 1,784 | 1,389 | 396 | 33% | 0 | 396 | 33% |
| 2022/23 | 1,415 | 369 | 0 | 0 | 1,784 | 1,433 | 351 | 28% | 0 | 351 | 28% |
| 2023/24 | 1,415 | 369 | 0 | 0 | 1,784 | 1,443 | 342 | 27% | 0 | 342 | 27% |
| 2024/25 | 1,415 | 369 | 0 | 0 | 1,784 | 1,374 | 410 | 31% | 0 | 410 | 31% |
| 2025/26 | 1,409 | 469 | 0 | 0 | 1,878 | 1,379 | 499 | 37% | 0 | 499 | 37% |
| 2026/27 | 1,409 | 519 | 0 | 0 | 1,928 | 1,388 | 540 | 40% | 0 | 540 | 40% |
| 2027/28 | 1,402 | 519 | 0 | 0 | 1,922 | 1,345 | 577 | 43% | 0 | 577 | 43% |
| 2028/29 | 1,402 | 569 | 0 | 0 | 1,972 | 1,397 | 575 | 41% | 0 | 575 | 41% |
| 2029/30 | 1,402 | 719 | 0 | 0 | 2,122 | 1,419 | 703 | 50% | 0 | 703 | 50% |

Notes:

"Firm Capacity Import" includes OUC's existing and future power purchase agreements, including renewables.
 "System Firm Summer Peak Demand" includes OUC and St. Cloud peak demand, as well as OUC's wholesale power sales.
 "Reserve Margin (MW)" calculated as "Total Available Capacity" minus "System Firm Summer Peak Demand."
 "Reserve Margin (% of Peak)" calculated as "Reserve Margin (MW)" divided by "System Firm Summer Peak Demand" after adjusting for sales to Lake Worth, Winter Park, Mt. Dora, Chatahoochee, and Lakeland. OUC's agreement with Lake Worth already includes reserve calculations and OUC is not responsible for providing reserves to Winter Park, Mt. Dora, Chatahoochee, or Lakeland.
 "Scheduled Maintenance (MW)" is zero, as no units are scheduled for maintenance during peak periods.
 Forecast "System Firm Winter Peak Demand" may not exactly match up with peak demands presented in the 2021 OUC Ten-Year Site Plan due to coincidence and rounding.

**Schedule 8
Planned and Prospective Generating Facility Additions and Changes**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
|-----------------------|----------|----------|-----------|----------|----------|--------------------|--------------------|--------------------|-----------------------------|---------------------------|------------------------|--------------------------|--------------------------|--------|
| Plant Name | Unit No. | Location | Unit Type | Fuel Pri | Fuel Alt | Fuel Transport Pri | Fuel Transport Alt | Const. Start Mo/Yr | Commercial In-Service Mo/Yr | Expected Retirement Mo/Yr | Gen. Max. Nameplate KW | Net Capability Summer MW | Net Capability Winter MW | Status |
| Stanton Energy Center | 1 | Orange | ST | NG | N/A | PL | N/A | - | 04/27 | - | 464,500 | -6.1 | -6.1 | P |
| Stanton Energy Center | 2 | Orange | ST | NG | N/A | PL | N/A | - | 10/25 | - | 464,500 | -6.8 | -6.8 | P |

Notes:

Changes to Net Capability for Stanton Energy Center Units 1 and 2 represent reduction in output for OUC's ownership share of Stanton 1 and OUC plus STC's share of Stanton 2. Reductions shown are estimates associated with conversion of the units to operate on natural gas.

**Schedule 9
Status Report and Specifications of Proposed Generating Facilities**

- (1) Plant Name and Unit Number:
- (2) Capacity
 - a. Summer:
 - b. Winter:
- (3) Technology Type:
- (4) Anticipated Construction Timing
 - a. Field construction start-date:
 - b. Commercial in-service date:
- (5) Fuel
 - a. Primary fuel:
 - b. Alternate fuel:
- (6) Air Pollution Control Strategy:
- (7) Cooling Method:
- (8) Total Site Area:
- (9) Construction Status:
- (10) Certification Status:
- (11) Status with Federal Agencies:
- (12) Projected Unit Performance Data
 - Planned Outage Factor (POF):
 - Forced Outage Factor (FOF):
 - Equivalent Availability Factor (EAF):
 - Resulting Capacity Factor (%):
 - Average Net Operating Heat Rate (ANOHR):
- (13) Projected Unit Financial Data
 - Book Life (Years):
 - Total Installed Cost (In-Service Year \$/kW):
 - Direct Construction Cost (\$/kW):
 - AFUDC Amount (\$/kW):
 - Escalation (\$/kW):
 - Fixed O&M (\$/kW-Yr):
 - Variable O&M (\$/MWH):
 - K Factor:

Notes:
As discussed throughout OUC's 2021 Ten-Year Site Plan, consideration of OUC's current existing generating resources (including existing and planned PPAs) and OUC's current base-case load forecast indicates that OUC is projected to have adequate capacity to satisfy forecast reserve margin requirements through 2030 (the final year considered in the 2021 Ten-Year Site Plan). As such, no new capacity additions are included in the 2021 Ten-Year Site Plan.

Schedule 10
Status Report and Specifications of Proposed Directly Associated Transmission Lines

- (1) Point of Origin and Termination:
- (2) Number of Lines:
- (3) Right-of-Way:
- (4) Line Length:
- (5) Voltage:
- (6) Anticipated Construction Timing:
- (7) Anticipated Capital Investment:
- (8) Substations:
- (9) Participation with Other Utilities:

Notes:
OUC's 2021 Ten-Year Site Plan does not include any proposed directly associated transmission lines. Therefore, Schedule 10 is not applicable.