

21 West Church Street
Jacksonville, Florida 32202-3139



April 3rd, 2023

E L E C T R I C

Commission Clerk
Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

W A T E R

Commission Clerk:

S E W E R

On behalf of JEA, please accept the 2023 Ten Year Site Plan Submission in accordance with Florida Statutes section 186.80.

If you have any questions, please contact me by email at landsg@jea.com.

Sincerely,

A handwritten signature in black ink, appearing to read "S Landaeta", with a long horizontal flourish extending to the right.

Stephany Landaeta Gutierrez
Associate Engineer
JEA



Building Community®

TEN-YEAR SITE PLAN

April 2023

Table of Contents

Introduction 1

1. Description of Existing Facilities2

 1.1 Power Supply System Description2

 1.1.1 System Summary2

 1.1.2 Power Purchases2

 1.2 Transmission and Distribution8

 1.2.1 Transmission and Interconnections8

 1.2.2 Transmission System Considerations.....8

 1.2.3 Transmission Service Requirements9

 1.2.4 Distribution9

 1.3 Demand-Side Management (DSM) 10

 1.3.1 Interruptible Load 10

 1.3.2 Demand-Side Management Programs 10

 1.4 Clean Energy 12

 1.4.1 Clean Power Program 12

 1.4.2 Nuclear Generation 12

 1.4.3 Renewable Energy 13

 1.4.4 Research Efforts..... 17

2. Forecast of Electric Power Demand and Energy Consumption.....20

 2.1 Energy Forecast 20

 2.2 Peak Demand Forecast21

 2.3 Plug-in Electric Vehicles Peak Demand and Energy21

 2.4 Customer-Sited Renewables 22

 2.5 Electrification 22

3. Forecast of Facilities Requirements.....29

 3.1 Future Resource Needs29

 3.1.1 Integrated Resource Planning Study29

3.1.2 JEA Potential Goals by 203030

3.1.3 Capacity Needs31

3.2 Resource Plan33

4. Other Planning Assumptions and Information.....43

4.1 Fuel Price Forecast.....43

4.2 Economic Parameters.....44

4.2.1 Inflation and Escalation Rates44

4.2.2 Municipal Bond Interest Rate.....44

4.2.3 Present Worth Discount Rate44

4.2.4 Interest during Construction Interest Rate44

4.2.5 Levelized Fixed Charge Rate44

5. Environmental and Land Use Information.....46

List of Tables and Figures

Table 1: JEA Power Purchase Schedule.....5
 Table 2: DSM Portfolio 11
 Table 3: DSM Programs..... 11
 Table 4a: Resource Needs After Committed Units - Summer.....31
 Table 4b: Resource Needs After Committed Units - Winter.....32
 Table 5: Resource Plan.....34

List of Schedules

Schedule 1: Existing Generating Facilities7
 Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers23
 Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers24
 Schedule 3.1: History and Forecast of Summer Peak Demand.....25
 Schedule 3.2: History and Forecast of Winter Peak Demand.....26
 Schedule 3.3: History and Forecast of Annual Net Energy For Load.....27
 Schedule 4: Previous Year Actual and Two Year Forecast of Firm Peak Demand and
 Net Energy for Load By Month28
 Schedule 5: Fuel Requirements**Error! Bookmark not defined.**
 Schedule 6.1: Energy Sources (GWh)36
 Schedule 6.2: Energy Sources (Percent)**Error! Bookmark not defined.**
 Schedule 7.1: Summer Forecast of Capacity, Demand, and Scheduled Maintenance at
 Time of Peak38
 Schedule 7.2: Winter Forecast of Capacity, Demand, and Scheduled Maintenance at
 Time of Peak39
 Schedule 8: Planned and Prospective Generating Facility Additions and Changes.....40
 Schedule 9: Status Report and Specifications of Proposed Generating Facilities.....41
 Schedule 10: Status Report and Specification of Proposed Directly Associated
 Transmission Lines.....42

List of Abbreviations

Type of Generation Units

CA	Combined Cycle – Steam Turbine Portion, Waste Heat Boiler (only)
CC	Combined Cycle
CT	Combined Cycle – Combustion Turbine Portion
GT	Combustion Turbine
FC	Fluidized Bed Combustion
IC	Internal Combustion
ST	Steam Turbine, Boiler, Non-Nuclear

Status of Generation Units

FC	Existing generator planned for conversion to another fuel or energy source
M	Generating unit put in deactivated shutdown status
P	Planned, not under construction
RT	Existing generator scheduled to be retired
RP	Proposed for repowering or life extension
TS	Construction complete, not yet in commercial operation
U	Under construction, less than 50% complete
V	Under construction, more than 50% complete

Types of Fuel

BIT	Bituminous Coal
DFO	No. 2 Fuel Oil
RFO	No. 6 Fuel Oil
MTE	Methane
NG	Natural Gas
SUB	Sub-bituminous Coal
PC	Petroleum Coke
WH	Waste Heat

Fuel Transportation Methods

PL	Pipeline
RR	Railroad
TK	Truck
WA	Water

Introduction

The Florida Public Service Commission (FPSC) is responsible for ensuring that Florida's electric utilities plan, develop, and maintain a coordinated electric power grid throughout the state. The FPSC must also ensure that electric system reliability and integrity is maintained, that adequate electricity at a reasonable cost is provided, and that plant additions are cost-effective. In order to carry out these responsibilities, the FPSC must have information sufficient to assure that an adequate, reliable, and cost-effective supply of electricity is planned and provided.

The Ten-Year Site Plan (TYSP) provides information and data that will facilitate the FPSC's review. This TYSP provides information related to JEA's power supply strategy to adequately meet the forecasted needs of our customers for the planning period from January 1st, 2023, to December 31st, 2032. This power supply strategy maintains a balance of reliability, environmental stewardship, and low cost to the consumers.

1. Description of Existing Facilities

1.1 Power Supply System Description

1.1.1 System Summary

JEA is the eighth largest municipally owned electric utility in the United States in terms of number of customers. JEA's electric service area covers most of Duval County and portions of Clay and St. Johns Counties. JEA's service area covers approximately 900 square miles and serves more than 450,000 customers.

JEA consists of one financial entity: the JEA Electric System. The total projected net capability of JEA's generation system is 2,952 MW for winter and 2,799 MW for summer. Details of the existing facilities are displayed in TYSP Schedule 1.

1.1.1.1 The JEA Electric System

The JEA Electric System consists of generating facilities located on four plant sites within the City of Jacksonville (The City); the J. Dillon Kennedy Generating Station (Kennedy), the Northside Generating Station (Northside), the Brandy Branch Generating Station (Brandy Branch), and the Greenland Energy Center (GEC).

Collectively, these plants consist of two dual-fired (petroleum coke/coal) Circulating Fluidized Bed (CFB) steam turbine-generator units (Northside steam Units 1 and 2); one dual-fired (oil/gas) steam turbine-generator unit (Northside steam Unit 3); seven dual-fired (gas/diesel) combustion turbine-generator units (Kennedy GT7 and GT8, GEC GT1 and GT2 and Brandy Branch GT1, CT2, and CT3); four diesel-fired combustion turbine-generator units (Northside GTs 3, 4, 5, and 6); and one combined cycle heat recovery steam generator unit (Brandy Branch steam Unit 4).

During the spring of 2019, JEA upgraded Brandy Branch units CT2 and CT3. The upgrade involved the addition of General Electric's Advanced Gas Path (AGP) and 7FA.05 compressor modifications to the existing Brandy Branch CT2 and CT3 7FA.03 units. Refer to Schedule 1 for summer and winter net capability updates.

1.1.2 Power Purchases

1.1.2.1 Trail Ridge Landfill

JEA signed a PPA with Trail Ridge Energy, LLC (TRE) in 2006 (Phase One) for 9 net MW of the gas-to-energy facility at the Trail Ridge Landfill in Duval County. In 2011, JEA executed an amendment to the PPA (Phase Two) to purchase 9 additional MW from a gas-to-energy facility. LES developed the Sarasota County Landfill in Nokomis, Florida (up to 6 net MW) to serve part of the Phase Two agreement. This portion of the Phase Two purchase began in February 2015 (see Section 1.4.3.2).

1.1.2.2 Solar Power Purchase Agreements

In May 2009, JEA entered into a PPA with Jacksonville Solar, LLC (Jax Solar) to receive up to 12 MW_{AC} of as-available renewable energy from the solar plant located in western Duval County. The Jacksonville Solar facility consists of approximately 200,000 photovoltaic panels on a 100-acre site and was forecasted to produce an average of 22,340 megawatt-hours (MWh) of electricity per year. The Jacksonville Solar plant began commercial operation at full designed capacity on September 30, 2010. The facility generated 18,319 MWh during calendar year 2022 and was acquired by Rev Renewables, LLC, an LS Power company, on June 15th, 2021.

JEA issued two Solar PV Request for Proposals (RFP), one in December 2014 and another in April 2015, and awarded a total of 31.5 MW_{AC} of solar PV power purchase contracts with terms of 20-25 years to various vendors. Of the awarded contracts, only seven agreements were finalized for a total of 27 MW_{AC}. The last of these seven projects was completed in December 2019.

On January 24, 2023, JEA entered into a five-year agreement with The Energy Authority (TEA) to purchase 150 MW_{AC} of electric energy and capacity resources and renewable attributes (Solar) from Florida Power & Light. JEA has also entered into negotiation for multiple solar projects, up to a total of 150 MW_{AC}, expected to commission in 2026.

JEA additionally has sought bids for the development of 300 MW_{AC} of solar or solar plus energy storage systems on JEA-owned parcels. The solicitation, released January 31, 2023 and facilitated through TEA, is sourcing full attribute solar, or solar plus storage resource solutions formatted in multiple blocks, not to exceed 74.9 MW_{AC} each. The facilities are expected to commission in the third quarter of 2026.

On March 28, 2023, JEA's Potential Goals were presented to the JEA Board, which calls for 35% clean energy by 2030. To achieve the goal, JEA will need a total of 1,275 MW_{AC} of solar generation by 2030. JEA has identified that it can source an additional two 74.9 MW solar facilities on JEA-owned parcels, expected to achieve commercial operation in 2028. JEA will continue to plan and identify the addition of the remaining 525 MW_{AC} of solar generation by 2030. For the purpose of the TYSP, JEA will consider all new solar generation as PPAs, as summarized in Table 1.1b. More details about the Solar PPAs can also be found in section 1.4.3.1.

1.1.2.3 Nuclear Power Purchase Agreement

In June 2008, JEA entered into a 20-year PPA with the Municipal Electric Authority of Georgia (MEAG) for a portion of MEAG's entitlement to Vogtle Units 3 and 4. These two new nuclear units are under construction at the existing Plant Vogtle location in Burke County, GA. The current projected commercial operation dates for 100 net MW of capacity from Vogtle Unit 3 is May or June of 2023, and an additional 100 net MW from Vogtle Unit 4 is Q3 2023 or Q1 2024. However, for planning purposes, to ensure JEA plans for sufficient supply resources and capacity, JEA

assumes Vogtle Unit 3 and Unit 4 commercial operation dates to be Q3 2023 and Q3 2024, respectively.

1.1.2.4 Florida Power & Light Natural Gas Power Purchase Agreement

On August 25, 2020, JEA and FPL executed a Cooperation Agreement for the retirement of Plant Scherer Unit 4 with the firm capacity and energy to be replaced by a 20-year 200 MW PPA between JEA and FPL for a natural gas-fired system product beginning January 1, 2022, with a solar conversion option on or after the 10th anniversary from the PPA start date.

1.1.2.5 Cogeneration

Cogeneration facilities help meet the energy needs of JEA's system on an as-available, non-firm basis. Since these facilities are considered energy only resources, they are not forecasted to contribute firm capacity to JEA's reserve margin requirements.

Currently, JEA has contracts with one customer-owned qualifying facility (QF), as defined in the Public Utilities Regulatory Policy Act of 1978. Anheuser Busch has a total installed summer rated capacity of 8 MW and winter rated capacity of 9 MW.

Table 1a: JEA Existing Power Purchase Agreement Schedule

Contract		Start Date	End Date	MW _{AC}	Product Type
LES Trail Ridge	I	12/06/08	12/31/26	9	Annual
	II	02/01/14	12/31/26	6	Annual
MEAG Plant Vogtle	Unit 3 ⁽¹⁾⁽²⁾	Q3 2023	Q3 2043	100	Annual
	Unit 4 ⁽¹⁾⁽²⁾	Q3 2024	Q3 2044	100	Annual
FPL PPA		01/01/22	01/01/42	200	Annual
FPL Solar PPA		04/01/23	04/01/28	150	Annual
Jacksonville Solar		09/30/10	09/30/40	12	Annual
NW Jacksonville Solar		05/30/17	05/30/42	7	Annual
Old Plank Road Solar		10/13/17	10/13/37	3	Annual
Starratt Solar		12/20/17	12/20/37	5	Annual
Simmons Road Solar		01/17/18	01/17/38	2	Annual
Blair Site Solar		01/23/18	01/23/38	4	Annual
Old Kings Solar		10/15/18	10/15/38	1	Annual
SunPort Solar		12/04/19	12/04/39	5	Annual

- (1) After accounting for transmission losses, JEA expects to receive 100 MW from Vogtle Unit 3 and 100 MW from Vogtle Unit 4.
- (2) Start dates reflected are for JEA's planning purposes, not the current projected start dates.

Table 1.1b: JEA Future Power Purchase Agreement Schedule

Contract	Start Date	End Date	MW_{AC}	Product Type
Two (2) 74.9 MW Solar PPA	Q1 2026	Q1 2046	149.8	Annual
Four (4) 74.9 MW Solar PPA	Q3 2026	Q3 2046	299.6	Annual
Two (2) 74.9 MW Solar PPA	Q1 2028	Q1 2048	149.8	Annual
150 MW Solar PPA ⁽²⁾	Q2 2028	Q2 2048	150	Annual
Seven (7) 74.9 Solar PPA	Q1 2030	Q1 2050	524.3	Annual

(1) Refer to section 1.1.2.3 for details about the future solar PPAs.

(2) Option to negotiate an extension of the current FPL Solar PPA. Otherwise, a 150 MW solar PPA replacement will be acquired

Schedule 1: Existing Generating Facilities

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	FYI	(12)	(13)	(14)	(15)
Plant Name	Unit Number	Location	Unit Type	Fuel Type		Fuel Transport		Commercial In-Service	Expected Retirement	Gen Max Nameplate (b)	Gen Max Turbine	Net MW Capability		Ownership	Status
				Primary	Alt.	Primary	Alt.	Mo/Year	Mo/Year	kW	kW	Summer	Winter		
Kennedy										<u>407,600</u>	<u>346,400</u>	<u>357</u>	<u>382</u>		
	7	12-031	GT	NG	DFO	PL	WA	06/2000	(a)	203,800	173,200	179	191	Utility	
	8	12-031	GT	NG	DFO	PL	WA	06/2009	(a)	203,800	173,200	179	191	Utility	
Northside										<u>1,512,100</u>	<u>1,407,100</u>	<u>1,310</u>	<u>1,356</u>		
	1	12-031	ST	PC	BIT	WA		05/2003	(a)	350,000	297,500	293	293	Utility	
	2	12-031	ST	PC	BIT	WA		04/2003	(a)	350,000	297,500	293	293	Utility	
	3	12-031	ST	NG	RFO	PL	WA	07/1977	(a)	563,700	563,700	524	524	Utility	
	33-36	12-031	GT	DFO		TK		01/1975	(a)	248,400	248,400	200	246	Utility	
Brandy Branch										<u>879,800</u>	<u>745,100</u>	<u>774</u>	<u>831</u>		
	1	12-031	GT	NG	DFO	PL	TK	05/2001	(a)	203,800	173,200	179	191	Utility	
	2	12-031	CT	NG		PL		05/2001	(a)	203,800	173,200	190	212	Utility	
	3	12-031	CT	NG		PL		10/2001	(a)	203,800	173,200	190	212	Utility	
	4	12-031	CA	WH				01/2005	(a)	268,400	225,500	216	216	Utility	
Greenland Energy Center										<u>407,600</u>	<u>346,400</u>	<u>357</u>	<u>382</u>		
	1	12-031	GT	NG	DFO	PL	TK	06/2011	(a)	203,800	173,200	179	191	Utility	
	2	12-031	GT	NG	DFO	PL	TK	06/2011	(a)	203,800	173,200	179	191	Utility	
JEA System Total												2,799	2,952		(c)

Notes:

- (a) Units expected to be maintained throughout the TYSP period.
- (b) Generator Max Nameplate is total unit not ownership.
- (c) Numbers may not add due to rounding.

1.2 Transmission and Distribution

1.2.1 Transmission and Interconnections

JEA's transmission system consists of 744 circuit-miles of bulk power transmission facilities operating at four voltage levels: 69 kV, 138 kV, 230 kV, and 500 kV.

The 500 kV transmission lines are jointly owned by JEA and FPL, completing the path from FPL's Duval substation (located in the westerly portion of JEA's system) to the north to interconnect with the Georgia Integrated Transmission System (ITS). Along with JEA and FPL, Duke Energy Florida and the City of Tallahassee each own transmission interconnections with the Georgia ITS. JEA's import capacity is 1,228 MW over the 500 kV transmission lines through Duval substation.

The 230 kV and 138 kV transmission systems provide a backbone around JEA's service territory, with one river crossing in the north and no river crossings in the south, leaving an open loop. The 69 kV transmission system extends from JEA's core urban load center to the northwest, northeast, east, and southwest; covering the area not covered by the 230 kV and 138 kV transmission backbone.

JEA owns and operates a total of four 230 kV transmission interconnections at FPL's Duval substation in Duval County. JEA has one 230 kV transmission interconnection which terminates at Beaches Energy Services' Sampson substation (FPL metered) in St. Johns County. JEA's ownership of this interconnection ends at State Road 210 which is located just north of the Sampson substation. JEA has one 230 kV transmission interconnection terminating at Seminole Electric Cooperative Incorporated's (SECI) Black Creek substation in Clay County. JEA's ownership of this interconnection ends at the Duval County – Clay County line.

JEA has a 138 kV tie with Beaches Energy Services at JEA's Neptune substation. JEA owns and operates a 138 kV transmission loop that extends from the 138 kV backbone north to JEA's Nassau substation. This substation serves as a 138 kV transmission interconnection point for FPL's O'Neil substation and Florida Public Utilities Company's (FPU) Step Down substation. JEA's ownership of these two 138 kV interconnections end at the first transmission structure outside of the Nassau substation.

1.2.2 Transmission System Considerations

JEA continues to evaluate and upgrade the bulk power transmission system as necessary to provide reliable electric service to its customers. In compliance with North American Electric Reliability Corporation (NERC) and Florida Reliability Coordinating Council's (FRCC) standards, JEA continually assesses the needs and options for increasing the capability of the transmission system.

Since the FRCC region became the FL-Peninsula sub-region of SERC in July 2019, JEA has been following additional guidelines and actively participating in the SERC activities towards the reliability and security of the bulk electric system.

JEA performs system assessments using JEA's published Transmission Planning Process in conjunction with and as an integral part of the FRCC's published Regional Transmission Planning Process. FRCC's published Regional Transmission Planning Process facilitates coordinated planning by all transmission providers, owners, and stakeholders within the FRCC Region.

FRCC's members include investor-owned utilities, municipal utilities, power marketers, and independent power producers. The FRCC Board of Directors has the responsibility to ensure that the FRCC Regional Transmission Planning Process is fully implemented. The FRCC Planning Committee, which includes representation by all FRCC members, directs the FRCC Transmission Technical Subcommittee in conjunction with the FRCC Staff to conduct the necessary studies to fully implement the FRCC Regional Transmission Planning Process. The FRCC Regional Transmission Planning Process meets the principles of the Federal Energy Regulatory Commission (FERC) Final Rule in Docket No. RM05-35-000 for: (1) coordination, (2) openness, (3) transparency, (4) information exchange, (5) comparability, (6) dispute resolution, (7) regional coordination, (8) economic planning studies, and (9) cost allocation for new projects.

1.2.3 Transmission Service Requirements

JEA also engages in market transmission service obligations via the Open Access Same-time Information System (OASIS) where daily, weekly, monthly, and annual firm and non-firm transmission requests are submitted by potential transmission service subscribers.

The following existing transmission service contract is set to expire in the future during this Ten-Year Site Plan period:

- FPL purchased Cedar Bay plant and retired the generation in December 2016. The transmission service for the delivery of Cedar Bay generation has been converted to JEA's Open Access Transmission service and will remain with FPL through 2024.

1.2.4 Distribution

The JEA distribution system operates at three primary voltage levels (4.16 kV, 13.2 kV, and 26.4 kV). The 4.16 kV system serves a permanently defined area in older residential neighborhoods. The 13 kV system serves a permanently defined area in the urban downtown area. These two distribution systems serve any new customers that are located within their defined areas, but there are no plans to expand these two systems beyond their present boundaries. The 26.4 kV system serves approximately 90 percent of JEA's load, including 75 percent of the 4.16 kV substations. The current standard is to expand the 26.4 kV system as required to serve all new distribution loads, except loads that are within the boundaries of the 4.16 kV or 13.2 kV systems. JEA has approximately 7,268 miles of distribution circuits of which more than half is underground.

1.3 Demand-Side Management (DSM)

1.3.1 Interruptible Load

JEA currently offers Interruptible and Curtailable Service to eligible industrial class customers with peak demands of 750 kW or higher. Customers who subscribe to the Interruptible Service are subject to interruption of their full nominated load during times of system emergencies, including supply shortages. Customers who subscribe to the Curtailable Service may elect to voluntarily curtail portions of their nominated load based on economic incentives. For the purposes of JEA's planning reserve requirements, only customer load nominated for Interruptible Service is treated as non-firm. This non-firm load reduces the need for capacity planning reserves to meet peak demands. JEA forecasts 111 MW of interruptible peak load for the summer and 102 MW for the winter which remain constant throughout the study period. For 2023, the interruptible load represents 3.6 percent of the forecasted total peak demand in the winter and 4.1 percent of the forecasted total peak demand in the summer.

1.3.2 Demand-Side Management Programs

JEA continues to implement DSM programs that are economically beneficial and meet JEA's Florida Energy Efficiency and Conservation Act (FEECA) goals. JEA's programs focus on improving the efficiency of customer end use equipment, as well as, improving the system load factor through behavioral education and technology incentives.

JEA's forecast of annual incremental demand and energy reductions due to its current DSM energy efficiency programs is shown in Table 2. JEA's current and planned DSM programs are summarized by commercial and residential programs in Table 3.

Table 2: DSM Portfolio – Energy Efficiency Programs

ANNUAL INCREMENTAL		2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Annual Energy (GWh)	Residential	17.2	17.2	17.2	17.2	17.2	17.2	17.2	17.2	17.2	17.2
	Commercial	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4
	Total	34.6	34.6	34.6	34.6	34.6	34.6	34.6	34.6	34.6	34.6
Summer Peak (MW)	Residential	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
	Commercial	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	Total	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9
Winter Peak (MW)	Residential	3.7	3.7	3.7	3.7	3.7	3.7	3.7	3.7	3.7	3.7
	Commercial	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4
	Total	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1

Table 3: DSM Programs

Commercial Programs	Residential Programs
Commercial Energy Assessment Program	Residential Energy Assessment Program
Commercial Prescriptive Program	Residential Energy Efficiency Products
Commercial Custom Program	Residential Solar Water Heating
Small Business Direct Install Program	Neighborhood Energy Efficiency Program
	Residential Energy Upgrades

1.4 Clean Energy

JEA continues to investigate economic opportunities to incorporate clean energy into JEA's power supply portfolio. To that end, JEA has implemented several clean power and renewable energy initiatives and continues to evaluate potential new initiatives.

1.4.1 Clean Power Program

As established in JEA's "Clean Power Action Plan" and through routine Clean Power Program meetings from 1999-2014, JEA worked with the Sierra Club of Northeast Florida (Sierra Club), the American Lung Association (ALA), and local environmental groups as a means of providing guidance and recommendations to JEA in the development and implementation of the Clean Power Programs.

Since the conclusion of this program, JEA has continued to make considerable progress related to clean power initiatives. This progress includes installation of clean power systems, unit efficiency improvements, solar PPAs, legislative and public education activities, and research and development of clean power technologies.

1.4.2 Nuclear Generation

JEA's Board had established targets to acquire 10 percent of JEA's energy requirements from nuclear sources by 2018 and up to 30 percent carbon-neutral sources by 2030. In March 2008, the JEA Board of Directors approved the pursuit of nuclear energy partnerships as part of a strategy for greater regulatory and fuel diversification. In October 2017, the JEA Board modified this goal to allow 30 percent of the target to be met by any carbon-free or carbon-neutral generation. In March 2023, JEA presented its Potential Goals to the JEA Board that calls for 35% clean energy by 2030, where nuclear generation can contribute towards meeting that goal.

In June 2008, JEA entered into a 20-year PPA with the Municipal Electric Authority of Georgia (MEAG) for a portion of MEAG's entitlement to Vogtle Units 3 and 4. These two new nuclear units are under construction at the existing Plant Vogtle location in Burke County, GA. Under this PPA, JEA is entitled to a total of 206 MW of firm capacity from these units. After accounting for transmission losses, JEA is anticipating to receive a total of 200 MW of net firm capacity from these units.

The current projected commercial operation dates for 100 net MW of capacity from Vogtle Unit 3 is May or June of 2023, and an additional 100 net MW from Vogtle Unit 4 is Q4 2023 or Q1 2024. However, for planning purposes, to ensure JEA plans for sufficient supply resources and capacity, JEA assumes Vogtle Unit 3 and Unit 4 commercial operation dates to be Q3 2023 and Q3 2024, respectively.

1.4.3 Renewable Energy

In 2005, JEA received a Sierra Club Clean Power Award for its voluntary commitment to increasing the use of solar, wind and other renewable or green power sources. Since that time, JEA has implemented new renewable energy projects and continues to explore additional opportunities to increase its utilization of renewable energy. JEA issued several RFPs for solar energy that resulted in new resources for JEA's portfolio. As discussed below, JEA's existing renewable energy sources include installation of solar PV, and landfill gas capacity.

1.4.3.1 Solar and the Solar Incentive

JEA has installed 35 solar PV systems, totaling 222 kW, on public high schools in Duval County, as well as many of JEA's facilities and the Jacksonville International Airport. To further promote the acceptance and installation of solar energy systems, JEA implemented the Solar Incentive Program in early 2002. This program provided rebates for the installation of solar thermal systems.

In addition to the solar thermal system incentive program, JEA established a residential net metering program to encourage the use of customer-sited solar PV systems. The policy has since evolved with several revisions:

- 2009: Tier 1 & 2 Net Metering policy launched to include all customer-owned renewable generation systems less than or equal to 100 kW
- 2011: Tier 3 Net Metering policy established for customer-owned renewable generation systems greater than 100 kW up to 2 MW
- 2014: Policy updated to define Tier 1 as 10 kW or less, Tier 2 as greater than 10 kW – 100 kW, and Tier 3 as 100 kW – 2 MW. This policy was capped at 10 MW for total generation. All customer-owned generation in excess of 2 MW would be addressed in JEA's Distributed Generation (DG) Policy.
- 2017: In October, the JEA Board approved the consolidation of the Net Metering and DG Policies into a single, comprehensive DG Policy.
- 2018: Effective April 1, the comprehensive DG Policy qualified renewable and non-renewable customer-owned generation systems under the following ranges:
 - DG-1 – Less than or equal to 2 MW
 - DG-2D – Over 2 MW with distribution level connection
 - DG-2T – Over 2 MW with transmission level connection

This DG policy acts in concert with the JEA Battery Incentive Program (see Section 1.4.3.3 Energy Storage) and allows existing customers the option to be grandfathered under the 2014 Net Metering Policy for a period of 20 years.

JEA signed a PPA with Jacksonville Solar, LLC in May 2009 to provide energy from a 12 MW_{AC} rated solar farm, which began operation in summer 2010 (see Section 1.1.2.2 Jacksonville Solar).

In December 2014, a Solar Policy was approved by the JEA Board, setting forth the goal of an additional 38 MW_{AC} of solar PV power via power purchase contracts by the end of 2016. JEA issued three Solar PV RFPs and received a total of 73 bids. In 2015, JEA awarded a total of 31.5 MW_{AC} of solar PV power purchase contracts with terms of 20 to 25 years to various vendors. The PPA, 5 MW_{AC} on U.S. Navy owned land, awarded to Hecate Energy, LLC in 2016 was cancelled because JEA and the Navy were unable to reach an agreement on the land lease. A 4.5 MW_{AC} award to SunEdison Utility Solutions, LLC was cancelled due to failure of the contractor to secure site control. The following are the seven PPAs that were finalized for a total of 27 MW_{AC} in JEA's service territory of which JEA pays for the energy and has rights to the associated environmental attributes produced by the facilities:

- Northwest Jacksonville Solar Partners, LLC: 7 MW_{AC} / 25-year PPA. The NW Jax facility consists of 28,000 single-axis tracking photovoltaic panels on a vendor-leased site, owned by American Electric Power (AEP). The facility became operational on May 30, 2017.
- Old Plank Road Solar Farm, LLC: 3 MW_{AC} / 20-year PPA. The Old Plank Road Solar facility consists of 12,800 single-axis tracking photovoltaic panels on a vendor-leased 40-acre site, owned by Southeast Solar Farm Fund, a partnership between PEC Velo & Cox Communications. The site attained commercial operation on October 13, 2017.
- C2 Starratt Solar, LLC: 5 MW_{AC} / 20-year PPA. The Starratt Solar facility, on a vendor-leased site, is now owned by EDPR DR (acquired C2 Starratt Solar, LLC) and was constructed by Inman Solar, Incorporated. The site attained commercial operation on December 20, 2017.
- Inman Solar Holdings 2, LLC: 2 MW_{AC} / 20-year PPA. The Simmons Solar facility, on a vendor-leased site, is owned by Inman Solar Holdings 2, LLC and was constructed by Inman Solar, Inc. The site attained commercial operation on January 17, 2018.
- Hecate Energy Blair Road, LLC: 4 MW_{AC} / 20-year PPA. The Blair Road facility, on a vendor-leased site, is owned by Hecate Energy Blair Road, LLC and was constructed by Hecate Energy, LLC. The site attained commercial operation on January 23, 2018.
- JAX Solar Developers, a wholly-owned subsidiary of Mirasol Fafco Solar, Inc.: 1 MW_{AC} / 20-year PPA. The Old Kings Rd Solar facility is owned by EcoPower Development, LLC and was constructed by Mirasol Fafco Solar, Inc. The site attained commercial operation on October 15, 2018.
- Imeson Solar, LLC: 5 MW_{AC} solar PV / 2 MW, 4 MWh battery energy storage system (BESS) / 20-year PPA. The primary function of the BESS is to smooth the solar generation. It is the first utility scale solar plus storage facility interconnected to the JEA

grid. The site, labeled SunPort Solar, was constructed by 174 Power Global and attained commercial operation on December 4, 2019.

In October 2017, the JEA Board approved a further solar expansion consisting of five-50 MW_{AC} solar facilities to be constructed on JEA-owned property. These projects, totaling 250 MW_{AC}, were structured as PPAs. A RFQ to select the vendors was issued and a vendor short list was announced in November 2017. The RFP for the facilities was released to the short-listed vendors on January 2, 2018. JEA received and evaluated 50 proposals that conformed to the requirements of the RFP. JEA awarded the contracts to EDF Renewables Distributed Solutions in April 2018 and executed the contracts in the 1st quarter of 2019 with plans to purchase the produced energy, as well as the associated environmental attributes from each facility. Beaver Street Solar Center, Cecil Commerce Solar Center, Deep Creek Solar Center, Forest Trail Solar Center, and Westlake Solar Center were originally planned to be completed by the end of 2022, however, impacts caused by the COVID-19 pandemic resulted in project delays. As it stands now, all five of the EDF agreements have been terminated. Planning and identification of substitute projects and future solar generation has been included in JEA's ongoing Integrated Resource Planning process.

In tandem with the IRP process and aligning with JEA's commitment to increase its renewable portfolio, JEA entered into a five-year agreement with The Energy Authority (TEA) to purchase 150 MW_{AC} of electric energy and capacity resources and renewable attributes (Solar) from Florida Power & Light on January 24, 2023. JEA also entered into negotiation for multiple solar projects, up to a total of 150 MW_{AC}, expected to commission in 2026.

JEA additionally has sought bids for the development of 300 MW_{AC} of solar or solar plus energy storage systems on JEA-owned parcels. The solicitation, released on January 31, 2023 and facilitated through TEA, is sourcing full attribute solar, or solar plus storage resource solutions formatted in multiple blocks, not to exceed 74.9 MW_{AC} each. The facilities are expected to commission in the third quarter of 2026.

On March 28, 2023, JEA's Potential Goals were presented to the JEA Board, which calls for 35% clean energy by 2030. To achieve this goal, JEA will need a total of 1,275 MW_{AC} of solar generation by 2030. JEA has identified that it can source an additional two 74.9 MW_{AC} solar facilities on JEA-owned parcels, expected to achieve commercial operation in 2028. JEA will continue to plan and identify the addition of the remaining 525 MW_{AC} of solar generation by 2030. JEA will also perform studies to determine potential reliability considerations for the JEA system associated with the integration of a total of 1,275 MW_{AC} of solar PV.

1.4.3.2 Landfill Gas and Biogas

JEA owned three internal combustion engine generators located at the Girvin Road landfill. This facility was placed into service in July 1997 and was fueled by the methane gas produced by the landfill. The facility originally had four generators, with an aggregate net capacity of 3 MW. Since that time, methane gas generation has declined, and one generator was removed and placed into

service at the Buckman Wastewater Treatment facility and the remaining Girvin landfill generation facilities were decommissioned in 2014.

JEA's Buckman Wastewater Treatment Plant previously dewatered and incinerated the sludge from the treatment process and disposed of the ash in a landfill. The current facility manages the sludge using three anaerobic digesters and one sludge dryer to produce a pelletized fertilizer product. The methane gas from the digesters can be used as a fuel for the sludge dryer and the digester heaters.

In 2006, JEA entered into a power purchase agreement (PPA) with Trail Ridge Energy, LLC (TRE) to purchase energy and environmental attributes from up to 9 net MW of firm renewable generation capacity utilizing the methane gas from The City's Trail Ridge landfill located in western Duval County (the "Phase One Purchase"). The facility was one of the largest landfill gas-to-energy facilities in the Southeast when it began commercial operation on December 6, 2008.

JEA and TRE executed an amendment to this PPA on March 9, 2011 that included additional capacity. The "Phase Two Purchase" amendment included up to 9 additional net MW. Landfill Energy Systems (LES) developed the Sarasota County Landfill in Nokomis, Florida (up to 6 net MW) to serve part of this Phase Two agreement. This portion of the Phase Two purchase began in February 2015. These landfill gas projects generated 62,936 MWh during calendar year 2022.

1.4.3.3 Biomass

In 2008, to obtain cost-effective biomass generation, JEA completed a detailed feasibility study of both self-build stand-alone biomass units and the co-firing of biomass in Northside 1 and 2. The JEA self-build projects would not have been eligible for the federal tax credits afforded to developers. The co-firing alternative for Northside 1 and 2 considered potential reliability issues associated with those units. In addition, JEA conducted an analytical evaluation of specific biomass fuel types to determine the possibility of conducting a co-firing test in Northside 1 and 2.

In 2011, JEA co-fired biomass in Northside Units 1 and 2, utilizing wood chips from JEA tree trimming activities as a biomass energy source. Northside 1 and 2 produced a total of 2,154 MWh of energy from wood chips during 2011 and 2012. At that time, JEA received bids from local sources to provide biomass for potential use in Northside Units 1 and 2.

In 2021, JEA began co-firing up to 10% of biomass (approximately up to 240 Tons per Day) in Northside Unit 2 due to the high price of petcoke. In early 2022, JEA submitted a request and was granted an air construction permit with the Florida Department of Environment Protection (FDEP), to burn up to 1000 tons per day of biomass in Northside Units 1 and 2. At present, the price of petroleum coke continues to be volatile, and biomass is typically co-fired when available and economically beneficial.

1.4.4 Research Efforts

Many of Florida's renewable resources such as offshore wind, tidal, and energy crops require additional research and development before they can be implemented as large-scale power generating technologies. JEA's renewable energy research efforts have focused on the development of these technologies through a partnership with the University of North Florida's (UNF) Engineering Department. In the past, UNF and JEA have worked on the following projects:

- JEA and UNF worked to quantify the winter peak reductions of solar hot water systems.
- UNF, in association with the University of Florida, evaluated the effect of biodiesel fuel in a utility-scale combustion turbine. Biodiesel has been extensively tested on diesel engines, but combustion turbine testing has been very limited.
- UNF evaluated the tidal hydro-electric potential for North Florida, particularly in the Intracoastal Waterway, where small proto-type turbines have been tested.
- JEA, UNF, and other Florida municipal utilities partnered on a grant proposal to the Florida Department of Environmental Protection to evaluate the potential for offshore wind development in Florida.
- JEA provided solar PV equipment to UNF for installation of a solar system at the UNF Engineering Building to be used for student education.
- JEA developed a 15-acre biomass energy farm where the energy yields of various hardwoods and grasses were evaluated over a 3-year period.
- JEA participated in the research of a high temperature solar collector that has the potential for application to electric generation or air conditioning.

Through Florida State University (FSU), JEA participated in The Sunshine State Solar Grid Initiative (SUNGRIN) which was a five-year project (2010-2015) funded under the Department of Energy (DOE) Solar Energy Technologies Program, Systems Integration Subprogram, High Penetration Solar Deployment Projects. The goal of the SUNGRIN project, which started in spring 2010, was to gain significant insight into effects of high-penetration levels of solar PV systems in the power grid, through simulation-assisted research and development involving a technically varied and geographically dispersed set of real-world test cases within the Florida grid. JEA provided FSU with data from the output of the Jacksonville Solar project.

In 2016, JEA pledged its support to the proposed 3-year Florida Alliance for Accelerating Solar and Storage Technology Readiness (FAASSTeR) project. The program is led by Nhu Energy, Inc. and Florida Municipal Electric Association (FMEA) with partial funding from the DOE. FAASSTeR seeks to grow solar capacity in FMEA member utilities to over 10% by 2024 and provide increased value in terms of cost of service, electric infrastructure reliability, security, resilience, and environmental and broader economic benefits. With assistance from the National Renewable Energy Laboratory and Lawrence Berkeley National Laboratory, studies on cost and

performance of solar and solar plus storage applications were conducted. The program recently concluded after a no-cost extension, where Nhu Energy, Inc. provided technical assistance on various solar and solar plus storage applications, including proper storage sizing for solar ramp rate mitigation. The study results should aid JEA in making informed decisions regarding its generation strategy.

1.4.4.1 Generation Efficiency and New Natural Gas Generation

In the late 1990's, JEA began to modernize its natural gas/oil fleet of generating units by replacing inefficient steam units and inefficient combustion turbine units with more efficient natural gas-fired combustion turbines and combined cycle units. The retirement of units and their replacement with an efficient combined cycle unit and efficient simple cycle combustion turbines at Brandy Branch, Kennedy, and GEC significantly reduced CO2 emissions.

During the spring of 2019, JEA upgraded Brandy Branch units CT2 and CT3. The upgrade involved the addition of General Electric's Advanced Gas Path (AGP) and 7FA.05 compressor modifications to the existing Brandy Branch CT2 and CT3 7FA.03 units. These upgrades improved the efficiency of the Brandy Branch units CT2 and CT3 taking them from approximately 48% to 53% on an ISO basis.

1.4.4.2 Renewable Energy Credits (REC)

JEA makes all environmental attributes from renewable facilities available to sell in order to lower rates for JEA customers. JEA has sold environmental credits for specified periods. In 2022, JEA certified over 140,000 Solar RECs under the Green-e certification structure and tracked over 80,000 landfill gas RECs through the North America Renewables (NAR) registry.

1.4.4.3 Energy Storage

JEA continues its efforts to demonstrate its commitment to energy efficiency and environmental improvement by researching energy storage applications and methods to efficiently incorporate storage technologies into the JEA system.

JEA welcomed the first utility-scale battery energy storage system to its grid with the addition of the SunPort Solar facility's 4 MWh battery; the storage system levels the solar PV output. JEA is undertaking an Integrated Resource Plan (IRP), scoped to include supply-side and demand-side strategies and recommendations on existing resources and future resource additions/replacements, including battery energy storage and other storage technologies. For more information on JEA's IRP, see Section 3.1.1.

JEA's residential Battery Incentive Program enacted on April 1, 2018 has continued to provide financial incentive towards the cost of an energy storage system, subject to lawfully appropriated funds. The Program, used in concert with the 2018 DG Policy, is intended to assist customers in being efficient energy users. Customers who elect to collect the rebate are able to offset electricity consumption from JEA, up to the limits of their storage devices. Funds allotted to each customer

under the Program is subject to review and change to optimize adoption. Since its inception, over 370 residential storage systems have been installed.

1.4.4.4 Potential Hydrokinetic Project for the St. John's River

JEA is working with several parties regarding a potential Hydrokinetic Project for the St. John's River at The City's St. John's Marina. Hydrokinetic Energy Corp is working on a low velocity hydro turbine prototype (in Key West) and is looking to possibly partner with The City and JEA with the St. John's Marina project. Hydrokinetic is working with other parties to possibly make this a DOE project. The current proposal contains four 9kW turbines at the marina. The output of the turbines is variable depending on flow velocity of the river.

2. Forecast of Electric Power Demand and Energy Consumption

Annually, JEA develops forecasts of seasonal peak demands, net energy for load (NEL), interruptible customer demand, DSM, and the impact of plug-in electric vehicles (PEVs). JEA removes from the total load forecast all seasonal, coincidental non-firm sources and adds sources of additional demand to derive a firm load forecast.

JEA uses National Oceanic and Atmospheric Administration (NOAA) Weather Station - Jacksonville International Airport for the weather parameters, Moody's Analytics (Moody) economic parameters for Duval County, JEA's Data Warehouse to determine the total number of Residential accounts and CBRE Jacksonville for Commercial total inventory square footages. JEA develops its annual forecast using SAS and Microsoft Office Excel.

JEA's Calendar Year 2023 baseline forecast uses 10 years of historical data. Using the shorter period allows JEA to capture the more recent trends in customer behavior, and energy efficiency and conservation, where these trends are captured in the actual data and used to forecast projections.

2.1 Energy Forecast

JEA begins this forecast process by weather normalizing energy for each customer class. JEA uses NOAA Weather Station - Jacksonville International Airport for historical weather data. JEA develops the normal weather using 10-year historical average heating/cooling degree days and maximum/minimum temperatures. Normal months, with heating/cooling degree days and maximum/minimum temperatures that are closest to the averages, are then selected. JEA updates its normal weather every 5 years or more frequently, if needed.

The residential energy forecast was developed using multiple regression analysis of weather normalized historical residential energy, total population, number of households, median household income, total housing starts from Moody's Analytics, JEA's total residential accounts and JEA's residential electric rate.

The commercial energy forecast was developed using multiple regression analysis of weather normalized historical commercial energy, total commercial employment, commercial inventory square footage, and gross domestic product from Moody's Analytics.

The industrial energy forecast was developed using multiple regression analysis of weather normalized historical industrial energy, total industrial employment, gross domestic product from Moody's Analytics and JEA's Industrial accounts.

The lighting energy forecast was developed using the historical actual energy, number of luminaries and JEA's estimated High Pressure Sodium (HPS) to Light-Emitting Diode (LED) streetlight conversion schedule. The LEDs are estimated to use 45% less energy than the HPS streetlights. JEA developed the forecasted number of luminaries using regression analysis of the

number of JEA customers. The forecasted lighting energy was calculated using the forecasted number of luminaries, applied with the remaining HPS to LED streetlight conversions with all new streetlight additions as LED only.

JEA's forecasted Average Annual Growth Rate (AAGR) net energy for load during the TYSP period is 0.66 percent.

2.2 Peak Demand Forecast

JEA normalizes historical seasonal peaks using historical maximum and minimum temperatures. JEA uses 25°F as the normal temperature for the winter peak and 97°F for the normal summer peak demands. JEA develops the seasonal peak forecasts using normalized historical and forecasted residential, commercial, and industrial energy for winter/summer peak months, and the average load factor based on historical peaks and net energy for winter/summer peak months. JEA's forecasted AAGR for net firm peak demand during the TYSP period is 0.54 percent for summer and 0.55 percent for winter.

2.3 Plug-in Electric Vehicles Peak Demand and Energy

The PEVs demand and energy forecasts are developed using the historical number of PEVs in Duval County obtained from the Florida Department of Highway Safety and Motor Vehicles and the historical number of vehicles in Duval County from the U.S. Census Bureau.

JEA forecasted the number of vehicles in Duval County using multiple regression analysis of historical and forecasted Duval population, median household income and number of households from Moody's Analytics. The forecasted number of PEVs is modeled using multiple regression analysis of the number of vehicles, disposable income from Moody's Analytics, the average motor gasoline price from the U.S. Energy Information Administration (EIA) Annual Energy Outlook (AEO), and JEA's electric rates.

The usable battery capacity (85% of battery capacity) per vehicle was determined based on the current plug-in electric vehicle models in Duval County. The average usable battery capacity per PEV is calculated using the average usable battery capacity of each vehicle brand and then assumes the annual growth of usable battery capacity per PEV by using the historical 5-year AAGR of 0.02 kWh. Similarly, the peak capacity is determined based on the average on-board charging rate of each vehicle brand and the forecast peak capacity per PEV grows by 0.01 kW per year.

The PEVs peak demand forecast is developed using the on-board charging rate for each model, the PEVs daily charge pattern and the total number of PEVs each year. The PEVs energy forecast is developed simply by summing the hourly peak demand for each year.

JEA forecasts AAGRs for PEVs winter and summer coincidental peak demand of 24.5 percent and 29.8 percent, respectively, and total energy of 24.5 percent during the TYSP period.

2.4 Customer-Sited Renewables

A customer-sited renewables analysis on rooftop solar PV and battery storage installation was conducted by Black & Veatch Consulting group. The solar PV analysis accounted for available roof space (including pitched vs. flat roofs, other roof equipment, etc.), PV power density, hourly generation shapes, and AC/DC ratios, among other factors. These technical potential calculations were supplemented by forecasting market adoption of solar PV systems over a 30-year forecast horizon. A rigorous hourly economic analysis calculated the point at which it is cost-effective for customers to install a system as a function of \$/kW, discount rates, and other costs using the extensive sensitivity analysis capabilities of the modeling software.

The battery storage analysis focused primarily on technical potential for paired solar + energy storage systems. The modeling software accounted for the complex economics of a storage technology, which can shift load to reduce energy charges (e.g., through on/off peak period arbitration) or reduce peak demand charges, by utilizing an hourly battery storage dispatch optimization module. This analysis simulates the hourly dispatch of stand-alone or solar-paired storage systems, accounting for electric rate structure, system characteristics, customer load profile, and solar PV generation profile.

2.5 Electrification

JEA's electrification load growth assumptions align with the annual program goals for JEA's Electrification Rebates Program (ERP) through CY25 with the final year's goal projected forward to the end of the ten-year period. These goals were established for the program following a market potential study performed by ICF in June 2019. This study determined there were 803,465 MWh of existing convertible load in JEA's service territory at that time and made high/medium/low goal recommendations for the electrification program based on a prescriptive list of electrification measures for each scenario. JEA chose the medium scenario for the program which resulted in the electrification targets used for the program as well as projected load growth from electrification for the TYSP.

ERP is currently contracted through CY25 and will capture 22.5% of the market potential above when the contract expires. Following CY25, it is assumed that the program will be renewed resulting in continued load growth at least equal to the final contractual year of the current program. Assuming the goals are achieved, the resulting kWh of new load will be 46.8% of the market potential which is reasonable for a program in market for greater than 10 years.

Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Class

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Rural and Residential			Commercial			Industrial		
	GWH Sales	Average Number of Customers	Average kWh/ Customer	GWH Sales	Average Number of Customers	Average kWh/ Customer	GWH Sales	Average Number of Customers	Average kWh/ Customer
2013	4,852	377,326	12,860	3,777	47,691	79,204	2,804	219	12,795,722
2014	5,162	383,998	13,443	3,882	49,364	78,642	2,785	215	12,984,365
2015	5,197	391,219	13,285	4,001	50,821	78,733	2,806	207	13,531,924
2016	5,351	398,387	13,431	4,064	51,441	78,994	2,692	202	13,322,934
2017	5,199	404,806	12,842	4,011	51,970	77,176	2,777	202	13,717,349
2018	5,460	412,070	13,251	4,042	52,525	76,954	2,765	196	14,081,384
2019	5,479	420,831	13,019	4,060	53,153	76,389	2,733	194	14,085,278
2020	5,679	429,575	13,220	3,886	53,701	72,363	2,698	196	13,759,522
2021	5,551	441,909	12,562	3,848	54,692	70,355	2,612	198	13,191,463
2022	5,723	452,281	12,654	4,005	55,387	72,317	2,708	200	13,538,811
2023	5,741	458,878	12,510	4,005	56,133	71,352	2,703	200	13,489,789
2024	5,801	465,327	12,466	4,013	56,870	70,566	2,708	201	13,501,814
2025	5,859	471,816	12,418	4,023	57,600	69,846	2,717	201	13,538,980
2026	5,916	478,378	12,367	4,034	58,323	69,171	2,730	201	13,604,447
2027	5,972	484,999	12,314	4,045	59,039	68,518	2,744	201	13,671,865
2028	6,028	491,581	12,262	4,056	59,748	67,887	2,757	201	13,732,781
2029	6,080	498,008	12,210	4,067	60,449	67,274	2,769	201	13,789,070
2030	6,129	504,200	12,156	4,076	61,141	66,673	2,781	201	13,844,172
2031	6,175	510,096	12,106	4,086	61,826	66,087	2,793	201	13,898,580
2032	6,219	515,659	12,061	4,096	62,504	65,525	2,804	201	13,954,696

Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Class

Year	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18)
	Street & Highway Lighting	Other Sales to Ultimate Customers	Total Sales to Ultimate Customers	Sales for Resale	Utility Use & Losses	Net Energy for Load	Other Customers	Total Number of Customers
	GWH	GWH	GWH	GWH	GWH	GWH	(Avg. Number)	
2013	122	0	11,556	395	335	12,286	2	425,238
2014	105	0	11,934	472	252	12,658	2	433,578
2015	87	0	12,091	392	385	12,868	2	442,249
2016	77	0	12,184	490	263	12,937	2	450,033
2017	63	0	12,050	288	334	12,672	2	456,981
2018	59	0	12,326	82	405	12,813	1	464,793
2019	57	0	12,328	58	411	12,797	0	474,178
2020	56	0	12,319	7	414	12,740	0	483,471
2021	55	0	12,066	25	449	12,540	0	496,799
2022	55	0	12,491	30	408	12,930	0	507,868
2023	55	0	12,504	0	469	12,973	0	515,211
2024	56	0	12,578	0	469	13,047	0	522,398
2025	57	0	12,656	0	484	13,140	0	529,616
2026	58	0	12,739	0	503	13,242	0	536,901
2027	59	0	12,821	0	520	13,341	0	544,239
2028	60	0	12,901	0	536	13,437	0	551,530
2029	60	0	12,977	0	550	13,527	0	558,658
2030	61	0	13,048	0	562	13,610	0	565,542
2031	62	0	13,116	0	573	13,689	0	572,123
2032	63	0	13,182	0	582	13,765	0	578,364

Schedule 3.1: History and Forecast of Summer Peak Demand

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)		(11)	
Calendar Year	Total Demand (MW)	Interruptible Load	Load Management		QF Load Served by QF Generation	Cumulative Conservation		Net Firm Peak Demand (MW)	Time Of Peak			
			Residential	Comm/Ind.		Residential	Comm/Ind.		Month	Day	H.E.	Temp
2013	2,524	0	0	0	0	0	0	2,524	8	14	1600	91
2014	2,591	0	0	0	0	0	0	2,591	8	22	1600	98
2015	2,618	0	0	0	0	0	0	2,618	6	17	1600	95
2016	2,689	0	0	0	0	0	0	2,689	7	7	1700	98
2017	2,631	0	0	0	0	0	0	2,631	8	16	1700	95
2018	2,495	0	0	0	0	0	0	2,495	8	8	1500	90
2019	2,591	0	0	0	0	0	0	2,591	8	14	1600	94
2020	2,582	0	0	0	0	0	0	2,582	6	29	1800	93
2021	2,511	0	0	0	0	0	0	2,511	7	22	1700	83
2022	2,728	0	0	0	0	0	0	2,728	6	23	1700	99
2023	2,719	111	0	0	0	4	3	2,601	---	---	---	----
2024	2,738	111	0	0	0	8	5	2,614	---	---	---	----
2025	2,758	111	0	0	0	10	7	2,631	---	---	---	----
2026	2,779	111	0	0	0	13	9	2,646	---	---	---	----
2027	2,798	111	0	0	0	17	12	2,657	---	---	---	----
2028	2,821	111	0	0	0	21	14	2,674	---	---	---	----
2029	2,835	111	0	0	0	24	17	2,682	---	---	---	----
2030	2,857	111	0	0	0	27	19	2,700	---	---	---	----
2031	2,878	111	0	0	0	29	21	2,718	---	---	---	----
2032	2,896	111	0	0	0	32	23	2,730	---	---	---	----

Note: All projections coincident at time of peak

Schedule 3.2: History and Forecast of Winter Peak Demand

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)		
Calendar Year	Total Demand (MW)	Interruptible Load	Load Management		QF Load Served by QF Generation	Cumulative Conservation		Net Firm Peak Demand (MW)	Time Of Peak			
			Residential	Comm/Ind.		Residential	Comm/Ind.		Month	Day	H.E.	Temp
2013	2,529	0	0	0	0	0	0	2,529	2	18	800	29
2014	2,754	0	0	0	0	0	0	2,754	1	7	800	22
2015	2,791	0	0	0	0	0	0	2,791	2	20	800	26
2016	2,600	0	0	0	0	0	0	2,600	1	20	800	30
2017	2,433	0	0	0	0	0	0	2,433	1	9	800	32
2018	3,011	0	0	0	0	0	0	3,011	1	18	800	26
2019	2,410	0	0	0	0	0	0	2,410	1	31	800	34
2020	2,445	0	0	0	0	0	0	2,445	1	22	800	33
2021	2,532	0	0	0	0	0	0	2,532	2	4	800	30
2022	2,599	0	0	0	0	0	0	2,599	12	25	900	28
2023	2,841	102	0	0	0	2	2	2,735	---	---	---	----
2024	2,859	102	0	0	0	4	3	2,750	---	---	---	----
2025	2,879	102	0	0	0	6	4	2,767	---	---	---	----
2026	2,899	102	0	0	0	8	6	2,783	---	---	---	----
2027	2,919	102	0	0	0	10	7	2,800	---	---	---	----
2028	2,939	102	0	0	0	12	8	2,817	---	---	---	----
2029	2,957	102	0	0	0	15	10	2,829	---	---	---	----
2030	2,977	102	0	0	0	16	11	2,848	---	---	---	----
2031	2,994	102	0	0	0	19	13	2,859	---	---	---	----
2032	3,010	102	0	0	0	21	14	2,873	---	---	---	----

Note: All projections coincident at time of peak.

Schedule 3.3: History and Forecast of Annual Net Energy for Load

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Calendar Year	Total Energy for Load (GWH)	Interruptible Load	Load Management		QF Load Served by QF Generation	Cumulative Conservation		Net Energy for Load (GWH)	Load Factor
			Residential	Comm/Ind.		Residential	Comm/Ind.		
2013	12,286	0	0	0	0	0	0	12,286	55%
2014	12,658	0	0	0	0	0	0	12,658	52%
2015	12,868	0	0	0	0	0	0	12,868	53%
2016	12,937	0	0	0	0	0	0	12,937	57%
2017	12,672	0	0	0	0	0	0	12,672	59%
2018	12,813	0	0	0	0	0	0	12,813	49%
2019	12,797	0	0	0	0	0	0	12,797	61%
2020	12,740	0	0	0	0	0	0	12,740	59%
2021	12,540	0	0	0	0	0	0	12,540	57%
2022	12,930	0	0	0	0	0	0	12,930	57%
2023	13,007	0	0	0	0	17	17	12,973	54%
2024	13,116	0	0	0	0	34	35	13,047	54%
2025	13,244	0	0	0	0	52	52	13,140	54%
2026	13,380	0	0	0	0	69	70	13,242	54%
2027	13,514	0	0	0	0	86	87	13,341	54%
2028	13,644	0	0	0	0	103	104	13,437	54%
2029	13,769	0	0	0	0	120	122	13,527	55%
2030	13,887	0	0	0	0	138	139	13,610	55%
2031	14,001	0	0	0	0	155	157	13,689	55%
2032	14,111	0	0	0	0	172	174	13,765	55%

Schedule 4: Previous Year Actual and Two-Year Forecast of Firm Peak Demand and Net Energy for Load by Month

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Month	Actual	2022	Forecast	2023	Forecast	2024	Forecast	2025
	Firm Peak Demand (MW)	Net Energy for load (GWH)	Firm Peak Demand (MW)	Net Energy for load (GWH)	Firm Peak Demand (MW)	Net Energy for load (GWH)	Firm Peak Demand (MW)	Net Energy for load (GWH)
January	2,529	1,058	2,735	1,096	2,750	1,103	2,767	1,111
February	2,211	887	2,411	942	2,426	948	2,443	955
March	1,862	914	1,954	942	1,967	948	1,980	955
April	2,007	937	2,084	937	2,100	943	2,115	950
May	2,452	1,167	2,352	1,092	2,369	1,098	2,386	1,106
June	2,728	1,284	2,561	1,226	2,579	1,233	2,598	1,241
July	2,598	1,322	2,565	1,332	2,584	1,338	2,603	1,347
August	2,612	1,319	2,601	1,309	2,614	1,315	2,631	1,324
September	2,574	1,139	2,465	1,152	2,483	1,158	2,501	1,166
October	1,999	960	2,171	1,015	2,185	1,021	2,200	1,028
November	1,899	910	1,953	930	1,965	936	1,979	943
December	2,599	1,033	2,319	1,000	2,333	1,006	2,350	1,014
Annual Peak/Total Energy	2,728	12,930	2,735	12,973	2,750	13,047	2,767	13,140

3. Forecast of Facilities Requirements

3.1 Future Resource Needs

3.1.1 Integrated Resource Planning Study

JEA is in the process of completing its most recent Integrated Resource Plan, with the IRP expected to be finalized by the end of May 2023. The IRP was developed using a multi-scenario and sensitivity approach, which allowed for evaluations of new resource options under different potential futures. The primary variables and considerations that define these different potential futures include the following:

- Environmental Legislative and Regulatory Action
 - Cost for emissions of CO₂
 - Specific goals or targets for percentages of energy from sources that do not emit carbon dioxide (CO₂)
 - Retirement of solid fuel and/or natural gas-fired generation
 - 316(b) regulations
- Load Growth Forecasts
 - Energy
 - Peak demand
 - Demand-side management and energy efficiency
 - Plug-in electric vehicles
 - Electrification
 - Customer-sited renewables
- Fuel Costs
- Cost of New Generation
- Continued Operation of Existing Generating Units
- Other Considerations
 - Affordability
 - Reliability
 - Environmental
 - Economic development
 - CO₂ emissions reductions

As the IRP will not be completed at the time of this TYSP reporting, the resource expansion plan included in this TYSP is representative of what is presently indicated by the IRP and consists of the most common/frequent near-term resource additions identified across multiple scenarios and sensitivities within the IRP study. It should be noted that all aspects of the resource expansion

plan presented in this TYSP, including both schedule and content, are preliminary and subject to change. JEA will continue to evaluate new resource additions as part of its ongoing resource planning activities.

The preliminary IRP results consistently identified near-term installations of 300 MW_{AC} (nameplate rating) of solar PV across all scenarios and sensitivities, and JEA has begun the process of soliciting for such new resources. On January 31, 2023, TEA released a solicitation for 300 MW_{AC} of solar or solar plus energy storage systems on JEA-owned parcels, with expected on-line dates in the third quarter of 2026. Potential bidders are invited to propose PPAs or develop the project for JEA ownership. At this time, for the purpose of the TYSP, JEA will consider the 300 MW_{AC} of solar PV as PPAs. Preliminary results of the IRP also identified an additional 975 MW_{AC} (nameplate rating) of solar PV near the end of the TYSP period in many scenarios and sensitivities. JEA will be performing studies to determine potential reliability considerations for the JEA system associated with the integration of a total of 1,275 MW_{AC} of solar PV.

The IRP was developed reflecting consideration of JEA's existing 524 MW Northside Unit 3 being removed from service in the spring of 2029. Removal of this unit from service is influenced by multiple factors, including the need for capital upgrades to remain reliable and as a means of compliance with potential 316(b) surface water withdrawal regulations.

The preliminary IRP results consistently identified a 1x1 advanced-class combined cycle combustion turbine (CCCT) configuration in the 2029 timeframe as part of the least-cost resource plan across the majority of scenarios and sensitivities. Modeling results show that the retirement and replacement of JEA's Northside Unit 3 with an efficient, advanced-class CCCT provides JEA with a new cost-effective resource. This new resource will provide reliable dispatchable power, allow for more efficient use of natural gas, reduces system CO₂, NO_x and SO₂ emissions, provides support to reliably integrate more renewable energy into the JEA system and will also avoid costly upgrades that would otherwise be necessary to extend the life of the 46-year-old unit. It should be noted that in order to maintain reliable operation of JEA's system, Northside Unit 3 unit cannot be retired until a replacement unit has achieved commercial operation. Due to permitting requirements associated with the Florida Power Plant Siting Act (PPSA), specifically Determination of Need and Site Certification (environmental permitting) for a CCCT, Northside Unit 3 may need to continue to operate until the earliest commercial operation date of a new CCCT resource, which is estimated to be in the 2030 timeframe. Development considerations, such as permitting delays, supply chain difficulties, or construction delays, could impact the earliest commercial operation date.

3.1.2 JEA Potential Goals by 2030

On March 28, 2023, JEA's Potential Goals by 2030 were presented to the JEA Board. These goals include 35% of the total installed capacity of the JEA Electric System to be from clean energy, the retirement of the least efficient generating units in JEA's Electric System, 80% carbon emissions reductions as compared to 2005 levels, JEA facilities' house load to be served with

100% clean energy, and the offset of electrification demand by continuing to create and promote effective energy efficiency programs. As the IRP is near finalization, preliminary results have enabled JEA to start exploring strategic ways to reach these goals by 2030 as discussed in section 3.1.1.

3.1.3 Capacity Needs

JEA evaluates future supply capacity needs for the electric system based on peak demand and energy forecasts, existing supply resources and contracts, transmission considerations, existing unit capacity changes, and future committed resources as well as other planning assumptions.

The base capacity plan in Table 4 reflects the addition of the PPA with MEAG for Vogtle Units 3 and 4 in Q3 2023 and Q3 2024, respectively, 200 MW PPA with FPL in 2022, and JEA’s existing and future solar PPAs.

Table 4a: Resource Needs after Committed Units - Summer

Summer										
Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Reserve Margin After Maintenance	
		Import ⁽¹⁾	Export				MW	Percent	MW	Percent
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	Percent
2023	2,799	309	0	0	3,108	2,601	507	19%	507	19%
2024	2,799	414	0	0	3,213	2,614	599	23%	599	23%
2025	2,799	517	0	0	3,316	2,631	685	26%	685	26%
2026	2,799	606	0	0	3,405	2,646	758	29%	758	29%
2027	2,799	591	0	0	3,390	2,657	733	28%	733	28%
2028	2,799	614	0	0	3,413	2,674	739	28%	739	28%
2029	2,799	619	0	0	3,418	2,682	736	27%	736	27%
2030	2,793	727	0	0	3,520	2,700	819	30%	819	30%
2031	2,793	726	0	0	3,519	2,718	801	29%	801	29%
2032	2,793	726	0	0	3,519	2,730	788	29%	788	29%

Note:

(1) 20% of solar nameplate capacity from Solar PPAs and the FPL Solar PPA output in August at hour 17:00 are accounted for in the firm import capacity.

Table 4b: Resource Needs after Committed Units - Winter

Winter										
Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Reserve Margin After Maintenance	
		Import	Export				MW	Percent	MW	Percent
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	Percent
2022/23	2,952	215	0	0	3,167	2,735	432	16%	432	16%
2023/24	2,952	315	0	0	3,267	2,750	517	19%	517	19%
2024/25	2,952	415	0	0	3,367	2,767	600	22%	600	22%
2025/26	2,952	415	0	0	3,367	2,783	584	21%	584	21%
2026/27	2,952	400	0	0	3,352	2,800	552	20%	552	20%
2027/28	2,952	400	0	0	3,352	2,817	535	19%	535	19%
2028/29	2,952	400	0	0	3,352	2,829	523	18%	523	18%
2029/30	2,999	400	0	0	3,399	2,848	552	19%	552	19%
2030/31	2,999	400	0	0	3,399	2,859	541	19%	541	19%
2031/32	2,999	400	0	0	3,399	2,873	526	18%	526	18%

JEA’s Planning Reserve Policy defines the planning reserve requirements that are used to develop the resource portfolio through the IRP process. These guidelines set forth the planning criteria relative to the planning reserve levels and the constraints of the resource portfolio.

JEA’s system capacity is planned with a targeted 15 percent generation reserve level for forecasted wholesale and retail firm customer coincident one-hour peak demand, for both winter and summer seasons. This reserve level has been determined to be adequate to meet and exceed the industry standard Loss of Load Probability of 0.1 days per year. This level has been used by the FPSC for municipalities in the consideration of need for additional generation resources.

To meet these Planning Reserve Policy requirements, JEA will acquire the needed capacity and associated energy as identified in Table 4, for those years where the reserve margin is below 15 percent. JEA’s Planning Reserve Policy establishes a guideline that provides an allowance to meet the 15 percent reserve margin with up to 3 percent of forecasted firm peak demand in any season from purchases acquired in the operating horizon. Where JEA’s seasonal needs are greater than 3% of firm peak demand, TEA will acquire short-term seasonal market purchases for JEA no later than the season prior to the need. TEA actively trades energy with a large number of counterparties throughout the United States and is generally able to acquire capacity and energy from other market participants when any of its members require additional resources.

3.2 Resource Plan

To develop the resource plan outlined in this TYSP submittal, JEA included a review of existing electric supply resources, forecasts of customer energy requirements and peak demands, forecasts of fuel prices and fuel availability, committed unit additions, existing capacity changes and annual and seasonal capacity purchase additions. All of these factors considered collectively provide JEA with sufficient capacity to cover customer demand and reserves during this ten-year period. Table 5 presents the ten-year resource plan, which meets JEA's strategic goals. TYSP Schedules 5-10 provide further detail on this plan.

Table 5: Resource Plan

Year	Resource Plan
2023	FPL Solar PPA (150 MW)
	MEAG Plant Vogtle 3 Purchase (100 MW) ⁽¹⁾
2024	MEAG Plant Vogtle 4 Purchase (100 MW) ⁽¹⁾
2025	
2026	Trail Ridge Contract Expires (-15 MW) ⁽²⁾
	Six (6) 74.9 MW _{AC} Solar PPAs (~450 MW _{AC}) ⁽³⁾
2027	
2028	Two (2) 74.9 MW _{AC} Solar PPAs (~150 MW _{AC}) ⁽³⁾
	FPL Solar PPA (-150 MW)
	FPL Solar PPA Extension/Replacement (150 MW) ⁽⁴⁾
2029	
2030	Seven (7) 74.9 MW _{AC} Solar PPAs (~525 MW _{AC}) ⁽³⁾
2031	
2032	

Notes:

- (1) After accounting for transmission losses, JEA expects to receive 100 MW from Vogtle Unit 3 and 100 MW from Vogtle Unit 4. For planning purposes, JEA assumes Vogtle Unit 3 and Unit 4 in-service dates to be Q3 2023 and Q4 2024, respectively.
- (2) Trail Ridge contract ends December 31, 2026
- (3) Please refer to section 1.1.2.3 for details about the Solar PPAs
- (4) Option to negotiate an extension of the current FPL Solar PPA. Otherwise, a 150 MW solar PPA replacement will be acquired

Schedule 5: Fuel Requirements

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Fuel	Type	Units	Actual		2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
				2021	2022										
(1)	NUCLEAR														
	TOTAL	TRILLION BTU	0	0	0	0	0	0	0	0	0	0	0	0	0
(2)	COAL														
	TOTAL	1000 TON	1,499	624	423	720	881	583	701	680	865	207	266	308	
(3)	RESIDUAL														
(4)	STEAM	1000 BBL	18	69	0	0	0	0	0	0	0	0	0	0	0
(5)	CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0	0
(6)	CT/GT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0	0
	TOTAL	1000 BBL	18	69	0	0	0	0	0	0	0	0	0	0	0
(7)	DISTILLATE														
(8)	STEAM	1000 BBL	0.6	0	0	0	0	0	0	0	0	0	0	0	0
(9)	CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0	0
(10)	CT/GT	1000 BBL	14	15	54	9	31	6	3	7	20	11	1	2	
	TOTAL	1000 BBL	15	15	54	9	31	6	3	7	20	11	1	2	
(12)	NATURAL GAS														
(13)	STEAM	1000 MCF	18,288	20,060	25,968	22,534	14,628	17,785	18,274	13,591	11,578	150	108	138	
(14)	CC	1000 MCF	31,314	31,509	29,243	30,996	31,131	31,010	27,835	29,859	29,184	40,362	42,954	43,298	
(15)	CT/GT	1000 MCF	11,439	9,459	13,266	6,658	5,797	6,906	5,185	4,690	4,792	10,545	6,561	6,238	
	TOTAL	1000 MCF	61,041	61,028	68,477	60,188	51,557	55,701	51,294	48,140	45,554	51,057	49,624	49,674	
(17)	OTHER (SPECIFY)														
	TOTAL	TRILLION BTU	0	0	0	0	0	0	0	0	0	0	0	0	0

Note: Coal includes Northside Coal, Petroleum Coke, and Biomass

Schedule 6.1: Energy Sources (GWh)

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
	Fuel	Type	Units	Actual 2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
(1)	Firm Inter-Region Intchg. ^(a)		GWH	3,770	2,625	2,658	3,255	3,171	3,170	3,220	3,142	2,492	2,337	2,301
(2)	NUCLEAR		GWH	0	0	0	0	0	0	0	0	0	0	0
(3)	COAL ^(b)		GWH	1,404	1,059	1,809	2,194	1,451	1,737	1,696	2,165	499	649	757
(4)	RESIDUAL	STEAM	GWH	38	0	0	0	0	0	0	0	0	0	0
(5)		CC		0	0	0	0	0	0	0	0	0	0	0
(6)		CT		0	0	0	0	0	0	0	0	0	0	0
(7)		TOTAL		38	0	0	0	0	0	0	0	0	0	0
(8)	DISTILLATE	STEAM	GWH	0	0	0	0	0	0	0	0	0	0	0
(9)		CC		0	0	0	0	0	0	0	0	0	0	
(10)		CT		5	23	4	14	3	1	3	9	4	0	1
(11)		TOTAL		5	23	4	14	3	1	3	9	4	0	1
(12)	NATURAL GAS	STEAM	GWH	1,868	2,704	2,310	1,471	1,788	1,831	1,312	1,119	0	0	0
(13)		CC		4,768	4,740	5,021	5,035	5,015	4,498	4,793	4,675	6,285	6,770	6,820
(14)		CT		926	1,336	662	571	681	515	461	469	1,000	620	588
(15)		TOTAL		7,562	8,780	7,993	7,077	7,483	6,844	6,566	6,263	7,284	7,391	7,408
(16)	NUG		GWH	0	0	0	0	0	0	0	0	0	0	0
(17)	RENEWABLES	HYDRO	GWH	0	0	0	0	0	0	0	0	0	0	0
(18)		LANDFILL GAS		63	129	129	128	128	0	0	0	0	0	0
(19)		SOLAR		87	357	455	473	1,006	1,591	1,952	1,949	3,330	3,312	3,298
(20)		TOTAL		150	486	585	601	1,134	1,591	1,952	1,949	3,330	3,312	3,298
(22)	OTHER (SPECIFY)		GWH	0	0	0	0	0	0	0	0	0	0	0
(23)	NET ENERGY FOR LOAD ^(c)		GWH	12,930	12,973	13,047	13,140	13,242	13,341	13,437	13,527	13,610	13,689	13,765

Notes:

- (a) Nuclear PPA with MEAG starting in 2023 is included in Firm Inter-Regional Interchange
- (b) Coal includes Northside Coal, Petroleum Coke, and Biomass
- (c) May not add due to rounding

Schedule 6.2: Energy Sources (Percent)

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
	Fuel	Type	Units	Actual 2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
(1)	Firm Inter-Region Intchg. ^(a)		%	29.2	20.2	20.4	24.8	23.9	23.8	24.0	23.2	18.3	17.1	16.7
(2)	NUCLEAR		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	COAL ^(b)		%	10.9	8.2	13.9	16.7	11.0	13.0	12.6	16.0	3.7	4.7	5.5
(4)	RESIDUAL	STEAM	%	0.29	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)		CC		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)		CT		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)		TOTAL		0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)	DISTILLATE	STEAM	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9)		CC		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(10)		CT		0.0	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0
(11)		TOTAL		0.0	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0
(12)	NATURAL GAS	STEAM	%	14.5	20.8	17.7	11.2	13.5	13.7	9.8	8.3	0.0	0.0	0.0
(13)		CC		36.9	36.5	38.5	38.3	37.9	33.7	35.7	34.6	46.2	49.5	49.5
(14)		CT		7.2	10.3	5.1	4.3	5.1	3.9	3.4	3.5	7.3	4.5	4.3
(15)		TOTAL		58.5	67.7	61.3	53.9	56.5	51.3	48.9	46.3	53.5	54.0	53.8
(16)	NUG		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(17)	RENEWABLES	HYDRO	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(18)		LANDFILL GAS		0.487	1.0	1.0	1.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0
(19)		SOLAR		0.677	2.8	3.5	3.6	7.6	11.9	14.5	14.4	24.5	24.2	24.0
(20)		TOTAL		1.2	3.7	4.5	4.6	8.6	11.9	14.5	14.4	24.5	24.2	24.0
(22)	OTHER (SPECIFY)		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Notes:

- (a) Nuclear PPA with MEAG starting in 2023 is included in Firm Inter-Regional Interchange
- (b) Coal includes Northside Coal, Petroleum Coke, and Biomass
- (c) May not add due to rounding

Schedule 7.1: Summer Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Peak

Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Scheduled Maintenance	Reserve Margin After Maintenance	
		Import	Export				MW	Percent		MW	Percent
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	MW	Percent
2023	2,799	309	0	0	3,108	2,601	507	19%	0	507	19%
2024	2,799	414	0	0	3,213	2,614	599	23%	0	599	23%
2025	2,799	517	0	0	3,316	2,631	685	26%	0	685	26%
2026	2,799	606	0	0	3,405	2,646	758	29%	0	758	29%
2027	2,799	591	0	0	3,390	2,657	733	28%	0	733	28%
2028	2,799	614	0	0	3,413	2,674	739	28%	0	739	28%
2029	2,799	619	0	0	3,418	2,682	736	27%	0	736	27%
2030	2,793	727	0	0	3,520	2,700	819	30%	0	819	30%
2031	2,793	726	0	0	3,519	2,718	801	29%	0	801	29%
2032	2,793	726	0	0	3,519	2,730	788	29%	0	788	29%

Schedule 7.2: Winter Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Peak

Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Scheduled Maintenance	Reserve Margin After Maintenance	
		Import	Export				MW	Percent		MW	Percent
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	MW	Percent
2022/23	2,952	215	0	0	3,167	2,735	432	16%	0	432	16%
2023/24	2,952	315	0	0	3,267	2,750	517	19%	0	517	19%
2024/25	2,952	415	0	0	3,367	2,767	600	22%	0	600	22%
2025/26	2,952	415	0	0	3,367	2,783	584	21%	0	584	21%
2026/27	2,952	400	0	0	3,352	2,800	552	20%	0	552	20%
2027/28	2,952	400	0	0	3,352	2,817	535	19%	0	535	19%
2028/29	2,952	400	0	0	3,352	2,829	523	18%	0	523	18%
2029/30	2,999	400	0	0	3,399	2,848	552	19%	0	552	19%
2030/31	2,999	400	0	0	3,399	2,859	541	19%	0	541	19%
2031/32	2,999	400	0	0	3,399	2,873	526	18%	0	526	18%

Schedule 8: Planned and Prospective Generating Facility Additions and Changes

Planned and Prospective Generating Facility and Purchased Power Additions and Changes														
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel Type		Fuel Transport		Construction Start Date	Commercial/ In-Service or Change Date	Expected Retirement/ Shutdown Date	Gen Max Nameplate	Net Capability		Status
				Primary	Alternate	Primary	Alternate					Summer	Winter	
													kW	
Northside	Unit 3	12-031	ST	NG	RFO	PL	WA	N/A	Jul-77	Jan-30	563,700	-524	-524	RT
7HA.02 1x1	TBD	Jacksonville, FL	CCCT	NG	DFO	PL	TK/WA	Apr-27	Jan-30	Dec-50	TBD	518	571	P

Schedule 9: Status Report and Specifications of Proposed Generating Facilities

1	Plant Name and Unit Number:	7HA.02 1x1
2	Capacity:	
3	Summer MW:	518
4	Winter MW:	571.3
5	Technology Type:	CCCT
6	Anticipated Construction Timing:	
7	Field Construction Start-date:	Apr-27
8	Commercial In-Service date:	Jan-30
9	Fuel:	
10	Primary:	NG
11	Alternate:	DFO
12	Air Pollution Control Strategy:	As required by new source Performance Standards
13	Cooling Method:	Wet mechanical draft cooling tower
14	Total Site Area:	Block approximately 30 acres
15	Construction Status:	Not yet started
16	Certification Status:	Not yet started
17	Status with Federal Agencies:	Permitting not yet started
18	Projected Unit Performance Data:	
19	Planned Outage Factor (POF):	2%
20	Forced Outage Factor (FOF):	2%
21	Equivalent Availability Factor (EAF):	96%
22	Resulting Capacity Factor (%):	76%
23	Average Net Operating Heat Rate (ANOHR):	6,478 Btu/kWh
24	Projected Unit Financial Data:	
25	Book Life:	20 years
26	Total Installed Cost (In-Service year \$/kW):	1,445 \$/kW All-in
27	Direct Construction Cost (\$/kW):	Included above
28	AFUDC Amount (\$/kW):	IDC included above
29	Escalation (\$/kW):	Included above
30	Fixed O&M (\$/kW-yr):	7.22
31	Variable O&M (\$/MWh):	2.48

**Schedule 10: Status Report and Specification of Proposed Directly
Associated Transmission Lines**

1	Point of Origin and Termination	None to Report
2	Number of Lines	
3	Right of Way	
4	Line Length	
5	Voltage	
6	Anticipated Construction Time	
7	Anticipated Capital Investment	
8	Substations	
9	Participation with Other Utilities	

4. Other Planning Assumptions and Information

4.1 Fuel Price Forecast

The fuel price projections used in this forecast were developed based on long-term price forecasts from the Annual Energy Outlook 2022 (AEO2022) issued by the EIA. The Annual Energy Outlook 2023 was not released in time to be used. The AEO2022 presents projections of energy supply, demand, and prices through 2050. AEO2022 projections are based on results from the EIA's National Energy Modeling System (NEMS). NEMS is a computer-based energy-economy modeling system of U.S. energy markets. NEMS projects the production, imports, conversion, consumption, and prices of energy, subject to a variety of assumptions related to macroeconomic and financial factors, world energy markets, resource availability and costs, behavioral and technological choice criteria, cost and performance characteristics of energy technologies, and demographics.

Scherer Unit 4 retired at the end of calendar year 2021 and was replaced by a PPA with FPL that provides 200 MW of natural gas combined cycle power. The natural gas price projection was based on January 17, 2023, settle prices of short-term NYMEX natural gas strip and then escalated using the AEO2022 Henry Hub price forecast. The transportation costs are based on the PPA contract terms, and the total cost is escalated by an inflation rate of 3 percent thereafter.

Northside Units 1 and 2 burn a blend of petroleum coke, coal, biomass, and natural gas. The blends of these four fuel types vary during the forecast period based on the projected costs of the fuels and other constraints. The Northside coal price projections are based on January 17, 2023, settle prices of short-term NYMEX API2 Argus-McCloskey coal futures and then escalated using AEO2022 projections for Interior coal. Freight rates for waterborne delivery of Colombian coal were based on the historical average over the last five years and escalated using a 3 percent inflation rate to project transportation costs beyond 2023. A ratio of historical delivered petroleum coke and coal prices over the past three months was applied to the delivered Northside coal price projections to derive the projected petroleum coke price.

JEA currently operates eight units utilizing natural gas as a primary fuel. These units are GEC GT1 and GT2, Brandy Branch GT1, CT2 and CT3, Northside 3, and Kennedy GT7 and GT8. The natural gas price projection was based on January 17, 2023, settle prices of short-term NYMEX natural gas strip and then escalated using the AEO2022 Henry Hub price forecast. The transportation costs are a combination of historical Florida city gate market costs on Florida Gas Transmission and local distribution fees.

The 1970's-vintage combustion turbine units at Northside (GT3, GT4, GT5, and GT6) burn diesel fuel as the primary fuel type. Five JEA units utilize diesel fuel as an alternative to natural gas: Kennedy GT7 and GT8, GEC GT1 and GT2, and Brandy Branch GT1. Projections for the price of diesel fuel are based on 1/17/23 settle prices of short-term NYMEX ultra-low sulfur diesel futures pricing and then escalated using AEO2022 projections for ultra-low sulfur diesel.

JEA has a PPA with MEAG for 200 MW from Vogtle Units 3 and 4 currently under construction in Georgia with in-service dates expected in 2023 and 2024. The fuel price forecast accounts for the costs of mine-mouth uranium, enrichment, and fabrication.

4.2 Economic Parameters

This section presents the parameters and methodology used for economic evaluations as part of JEA's least-cost expansion plan to satisfy forecast capacity requirements throughout the TYSP period.

4.2.1 Inflation and Escalation Rates

The general inflation rate, construction cost escalation rate, fixed O&M escalation rate, and non-fuel variable O&M escalation rate are each assumed to be 3.00 percent.

4.2.2 Municipal Bond Interest Rate

JEA performs sensitivity assessments of project cost to test the robustness of JEA's resource plan. Project cost includes forecast of direct cost of construction, indirect cost, and financing cost. Financing cost includes the forecast of long term tax-exempt municipal bond rates, issuance cost, and insurance cost. For JEA's plan development, the long term tax-exempt municipal bond rate is assumed to be 4.00 percent. This rate is based on JEA's judgment and expectation that the long-term financial markets will return to historical stable behavior under more stable economic conditions.

4.2.3 Present Worth Discount Rate

The present worth discount rate is assumed to be equal to the tax-exempt municipal bond interest rate of 4.00 percent.

4.2.4 Interest during Construction Interest Rate

The interest during construction rate, or IDC, is assumed to be 4.00 percent.

4.2.5 Levelized Fixed Charge Rate

The fixed charge rate (FCR) represents the sum of a project's fixed charges as a percent of the initial investment cost. When the FCR is applied to the initial investment, the product equals the revenue requirements needed to offset the fixed charges during a given year. A separate FCR can be calculated and applied to each year of an economic analysis, but it is common practice to use a single, levelized FCR (LFCR) that has the same present value as the year-by-year FCR. Different generating technologies are assumed to have different economic lives and therefore different financing terms. Simple cycle combustion turbines are assumed to have a 20-year financing term, while natural gas-fired combined cycle units are assumed to be financed over 25 years. Given the various economic lives and corresponding financing terms, different LFCRs

were developed. All LFCR calculations assume the 4.00 percent tax-exempt municipal bond interest rate, a 1.00 percent bond issuance fee, and a 0.57 percent annual property insurance cost. The resulting 20-year FCR is 8.00 percent and the 25-year FCR is 7.00 percent.

5. Environmental and Land Use Information

JEA does not have any capacity build projects underway or planned for the term of this Ten-Year Site Plan. Therefore, there are no potential sites in which to report environmental and land use information.